

An inverse method for color uniformity in white LED spotlights

Citation for published version (APA):

Prins, C. R., Thije Boonkkamp, ten, J. H. M., Tukker, T. W., & IJzerman, W. L. (2013). *An inverse method for color uniformity in white LED spotlights*. (CASA-report; Vol. 1302). Technische Universiteit Eindhoven.

Document status and date:

Published: 01/01/2013

Document Version:

Publisher's PDF, also known as Version of Record (includes final page, issue and volume numbers)

Please check the document version of this publication:

- A submitted manuscript is the version of the article upon submission and before peer-review. There can be important differences between the submitted version and the official published version of record. People interested in the research are advised to contact the author for the final version of the publication, or visit the DOI to the publisher's website.
- The final author version and the galley proof are versions of the publication after peer review.
- The final published version features the final layout of the paper including the volume, issue and page numbers.

[Link to publication](#)

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal.

If the publication is distributed under the terms of Article 25fa of the Dutch Copyright Act, indicated by the "Taverne" license above, please follow below link for the End User Agreement:

www.tue.nl/taverne

Take down policy

If you believe that this document breaches copyright please contact us at:

openaccess@tue.nl

providing details and we will investigate your claim.

EINDHOVEN UNIVERSITY OF TECHNOLOGY
Department of Mathematics and Computer Science

CASA-Report 13-02
January 2013

An inverse method for color uniformity in white LED spotlights

by

C.R. Prins, J.H.M. ten Thije Boonkamp, T. Tukker, W. IJzerman



Centre for Analysis, Scientific computing and Applications
Department of Mathematics and Computer Science
Eindhoven University of Technology
P.O. Box 513
5600 MB Eindhoven, The Netherlands
ISSN: 0926-4507

An inverse method for color uniformity in white LED spotlights

Corien Prins^{*1}, Jan ten Thije Boonkamp¹, Teus Tukker² and Wilbert IJzerman³

¹Centre for Analysis, Scientific computing and Applications (CASA), TU/e, Eindhoven

²Philips Research

³Philips Lighting

Email: Corien Prins - c.r.prins@tue.nl; Jan ten Thije Boonkamp - tenthije@win.tue.nl; Teus Tukker - teus.tukker@philips.com; Wilbert IJzerman - wilbert.ijzerman@philips.com;

*Corresponding author

Abstract

Color over Angle (CoA) variation in the light output of white phosphor-converted LEDs is a common problem in LED lighting technology. In this article we propose an inverse method to design an optical element that eliminates the color variation for a point light source. The method in this article is an improved version of an earlier method [1], and provides more design freedom. We derive a mathematical model for color mixing in a collimator and present a numerical algorithm to solve it. We verify the results using Monte-Carlo ray tracing.

1 Introduction

LED is a rising technology in the field of lighting. In the past, LEDs were only suitable as indicator lights, but the enormous improvements in energy efficiency, cost and light output now allow the use of LEDs for lighting applications [2]. Additionally, LED lighting benefits from low maintenance cost and long lifetime.

Because LED is a rising technology, companies and researchers are constantly searching for methods to reduce the production cost and increase the efficiency, light output and light quality of LED-based lamps. An important issue for white LED lamps is color variation of the emitted light. This is caused by color variation in the light output of the most common type of white LED, the phosphor-converted LED. This type of LED consists of a blue LED with on top a so-called phosphor layer which converts part of the blue

light into yellow and red. The resulting output is white light. The distance that a light ray travels through the phosphor depends on the angle of emission. As a result, the light emitted normal to the LED surface is more bluish, while the light emitted nearly parallel to the surface is more yellowish [3, p. 353-357]. This phenomenon is called Color over Angle (CoA) variation.

A lot of research has been done to reduce this color variation. Introduction of bubbles in the phosphor layer causes scattering of light, reducing the color variation [4]. Another common method is the application of a dichroic coating on the LED [5]. However, these methods reduce the efficiency of the LED and increase the production costs. Wang et al. [6] proposed a modification of the optics on the LED to improve the color uniformity. In the case of a spot light, the LED is combined with a collimator. A collimator is an optical component that reduces the angular width of the light emitted by the LED. A common technique is to add a microstructure on top of the collimator. However, this microstructure introduces extra costs in the production process of the collimator, makes the collimator look unattractive and broadens the light beam.

None of the methods mentioned above rigorously solves the problem of color variation, and all methods reduce the efficiency of the optical system. In earlier work [1], we introduced an inverse method to design a specific type of collimator, the so-called TIR (total internal reflection) collimator. The TIR collimator designed with this method mixes light from a point source such that the color variation is completely eliminated. The collimator requires no microstructures nor scattering techniques. However, the inverse method left very little design freedom for optical designers. An optical designer wants to influence the height and width of the collimator, for example, to fit it into the available space in a lamp design. Also, optical designers want a color mixing collimator which resembles a standard collimator as closely as possible. The inverse method introduced in this paper is an improvement of the method introduced in [1]. The collimator has three free surfaces instead of two. As a result, the improved method offers more design freedom, and it is nearly impossible to distinguish the resulting collimator with the naked eye from a collimator without color correction.

The contents of this paper is the following. First we give a thorough introduction to inverse methods for optical systems and the theory of color mixing in Section 2. In Section 3 we explain the improved inverse method. Section 4 describes three examples where the new method is used. Finally, we end with concluding remarks in Section 5.

2 Design of a TIR collimator using inverse methods

A TIR collimator is a rotationally symmetric lens, usually made of a transparent plastic like polycarbonate (PC) or polymethyl methacrylate (PMMA), that is used to collimate the light of an LED into a compact beam. A profile of a TIR collimator can be seen in Figure 1. The design procedure using inverse methods consists of two steps: first we choose a relation between the angles t of rays leaving the LED and the angles θ of rays leaving the collimator, the so-called transfer functions. Subsequently we use these transfer functions to calculate the free surfaces of the TIR collimator such that the light is redirected according to the relation defined by the transfer functions. In Figure 1 these free surfaces are denoted by A, B and C.

2.1 Source and target intensities

The first requirement that determines the choice of the transfer functions is the intensity pattern of the light emitted from the TIR collimator. Let $I(t, u)$ [lm/sr] be the intensity distribution of the light source. The unit lm stands for lumen, and is the unit to denote energy flux corrected for the sensitivity of the eye at different wavelengths, and sr stands for steradian, the unit of solid angle. The angle $t \in [0, \pi/2]$ is the angle with respect to the z -axis (inclination), and $u \in [0, 2\pi)$ is the angle that rotates around the z -axis (azimuth). Because of the symmetry of the system, the intensity $I(t, u)$ is independent of u and denoted by $I(t)$. We introduce an effective intensity $\mathcal{I}(t)$, which is the flux per rad through the circular strip $[t, t + dt]$ on the unit sphere divided by 2π . We calculate $\mathcal{I}(t)$ by integrating $I(t)$ over the angle u :

$$\mathcal{I}(t) = \frac{1}{2\pi} \int_0^{2\pi} I(t) \sin(t) du = I(t) \sin(t). \quad (1)$$

The effective intensity has unit [lm/rad]. For an LED, the effective intensity is typically positive for $t \in (0, \pi/2)$.

The light emitted from the TIR collimator has a desired pattern in the far field, meaning that the TIR collimator itself can be considered a point source. The desired intensity profile is denoted by $G(\theta, \phi)$ [lm/sr], where $\theta \in [0, \theta_{\max}]$ is the inclination for some maximum inclination angle $0 < \theta_{\max} \leq \pi/2$, and $\phi \in [0, 2\pi)$ is the azimuth. We only consider intensity profiles that are rotationally symmetric and thus independent of ϕ . Integration over the angle ϕ results in an effective intensity $\mathcal{G}(\theta) = \sin(\theta) G(\theta)$ [lm/rad]. A more in-depth discussion of effective intensity distributions can be found in Maes [7]. The target intensity is multiplied by a constant $c > 0$ such that we have conservation of luminous flux for the optical system:

$$\int_0^{\pi/2} \mathcal{I}(t) dt = c \int_0^{\theta_{\max}} \mathcal{G}(\theta) d\theta. \quad (2)$$

The angular space $[0, \pi/2]$ of the light emitted by the LED is partitioned into $N \in \mathbb{N}$ segments $[\tau_{i-1}, \tau_i]$, $i = 1, 2, \dots, N$. For each segment we define a transfer function $\eta_i : [0, \theta_{\max}] \rightarrow [\tau_{i-1}, \tau_i] \subset [0, \pi/2]$. For a certain θ , $\eta_i(\theta)$ gives the emission angle t of the LED in $[\tau_{i-1}, \tau_i]$. We choose each transfer function to be strictly monotonic and thus invertible. The luminous flux emitted from the collimator in the interval $[\theta, \theta + d\theta]$ must be equal to the sum over i of the luminous fluxes emitted from the source in each interval $[\eta_i(\theta), \eta_i(\theta + d\theta)]$. This leads to the following relation:

$$\sum_{i=1}^N \sigma_i \mathcal{I}(\eta_i(\theta)) \eta_i'(\theta) = c \mathcal{G}(\theta), \quad (3)$$

where $\sigma_i = -1$ for monotonically decreasing transfer functions and $\sigma_i = 1$ for monotonically increasing transfer functions.

2.2 Color mixing

The second requirement on transfer functions is related to the color of the resulting beam from the collimator. First we give a short introduction to the theory of color perception, then we derive an ordinary differential equation describing the color of the beam.

Color perception is described extensively in [8, 9]. The human perception of a beam of light can be fully described by its luminous flux (in lm) and the two so-called chromaticity coordinates $0 < x, y < 1$. There is a simple rule to calculate the chromaticity coordinates (x, y) of the beam resulting from mixing two beams of light with luminous fluxes L_1 and L_2 and chromaticity coordinates (x_1, y_1) and (x_2, y_2) , respectively:

$$x = \frac{x_1 L_1 / y_1 + x_2 L_2 / y_2}{L_1 / y_1 + L_2 / y_2}, \quad (4a)$$

$$y = \frac{L_1 + L_2}{L_1 / y_1 + L_2 / y_2}. \quad (4b)$$

The resulting chromaticity coordinates are weighted averages of the chromaticity coordinates of the original beam with weights L_1/y_1 and L_2/y_2 . Note that a point (x, y) is on the straight line segment between (x_1, y_1) and (x_2, y_2) .

The chromaticity coordinates of the light emitted from an LED are not constant, but depend on the angle of emission t and are described by functions $x(t)$ and $y(t)$. From measured data we have observed an approximate linear relationship between $x(t)$ and $y(t)$, see Figure 3. From the color mixing rule, we conclude that if we mix light from different angles of the LED into a single beam with color coordinates (x_T, y_T) , these coordinates must be on the straight line segment relating $x(t)$ and $y(t)$. Therefore, given y_T , the chromaticity coordinate x_T is fully determined and we only need that the y -coordinate of the mixed

light equals a certain constant target value y_T . The light in the interval $[\theta, \theta + d\theta]$ emitted from the TIR collimator is the sum of beams with intensity $\sigma_i \mathcal{I}(\eta_i(\theta)) d\eta_i(\theta)$. The y -coordinate of this light is therefore

$$y_T = \frac{\sum_{i=1}^N \sigma_i \mathcal{I}(\eta_i(\theta)) d\eta_i(\theta)}{\sum_{i=1}^N \sigma_i \mathcal{I}(\eta_i(\theta)) / y(\eta_i(\theta)) d\eta_i(\theta)}. \quad (5)$$

Using (3) we find the following differential equation:

$$\sum_{i=1}^N \sigma_i \frac{\mathcal{I}(\eta_i(\theta))}{y(\eta_i(\theta))} \eta_i'(\theta) = c \mathcal{G}(\theta) / y_T. \quad (6)$$

2.3 Free surface calculations

The light paths in the TIR collimator shown in Figure 1 correspond to three transfer functions, one transfer function for each of the free surfaces A, B or C. These free surfaces can be calculated from the transfer functions using the 'generalized functional method' developed by Bortz and Shatz [10, 11]. They derived a differential equation that describes the location of a free surface, given a surface S from which the rays depart with a given angle \tilde{t} :

$$\frac{df}{ds} = \frac{d\tilde{t}}{ds} \tan(\beta) f + (\tan(\beta) \cos(\delta) + \sin(\delta)). \quad (7)$$

Here f is the distance a light ray travels from the surface S to the free surface, s is the arc-length along S , \tilde{t} is the angle of the ray leaving S with respect to the z -axis, and δ is the ray-emission angle measured counterclockwise with respect to the normal of S . The angle β is the angle of incidence on the free surface with respect to the surface normal. For the reflective surfaces B and C, the variables are illustrated in Figure 2. We like to formulate this differential equation in terms of t instead of s . Multiplication by ds/dt gives

$$\frac{df}{dt} = \frac{d\tilde{t}}{dt} \tan(\beta) f + \frac{ds}{dt} (\tan(\beta) \cos(\delta) - \sin(\delta)). \quad (8)$$

The parameters β and δ depend on t and are derived below.

Light propagates through the collimator by two type of routes. In the 'TIR route', light is refracted by surface S , reflected by surface B or C by total internal reflection and finally refracted by surface T . In the 'lens route', light is refracted by surface A and subsequently refracted by surface T .

First consider the surfaces B and C. These surfaces are on the 'TIR route', which is shown in Figure 2. Surface B is bounded at one side by the rays that leave the source at angle $t = \tau_1$. The boundary between surface B and C is marked by the rays that leave the collimator at angle $\theta = 0$, and we define the angle of this ray when leaving the light source to be $t = \tau_2$. The angles τ_1 and τ_2 are illustrated in Figure 1. First

the light is refracted at surface S . Let d be the distance from the left of surface S to the LED and α the clockwise angle of this surface with respect to the symmetry-axis. A ray that leaves the LED at angle t , will hit surface S at $(x_S(t), y_S(t))$ and leave surface S with angle $\tilde{t}(t)$ given by

$$x_S(t) = \frac{d}{\tan(t) + \tan(\alpha)}, \quad (9a)$$

$$y_S(t) = \frac{d \tan(t)}{\tan(t) + \tan(\alpha)}, \quad (9b)$$

$$\tilde{t}(t) = \arccos\left(\frac{\cos(\alpha + t)}{n}\right) - \alpha. \quad (9c)$$

Relation (9c) was derived using Snell's law of refraction. The refractive index of the material of the collimator is denoted by n . From (9a) and (9b) we find s , which is defined to be 0 at $t = \pi/2$. Also we calculate δ :

$$s(t) = \frac{d}{\cos(\alpha) \tan(t) + \sin(\alpha)}, \quad (10a)$$

$$\delta(t) = \tilde{t}(t) + \alpha - \frac{\pi}{2}. \quad (10b)$$

Subsequently, the rays are reflected at surface B or C. For a reflective surface we have [10]

$$\beta(t) = \frac{1}{2} (\tilde{t}(t) - \tilde{\theta}(t) - \pi). \quad (11)$$

Here $\tilde{\theta}$ is the angle of the rays with respect to the z -axis after reflection. Before the rays leave the TIR collimator, they are once more refracted by surface T . Rays that leave the collimator at angle $\theta = \eta^{-1}(t)$ must enter surface T at angle

$$\tilde{\theta}(t) = \pm \arcsin(\sin(\eta^{-1}(t))/n), \quad (12)$$

where the sign is negative if the rays cross the z -axis, and positive otherwise. Equation (12) is derived using Snell's law. Now we can calculate $f(t)$ by numerically integrating the ODE (8) backwards, starting at $t = \pi/2$. The parameters in (8) are given by (9c), (10a), (10b), (11) and (12). For surface C, a plus sign is chosen in (12) and for surface B a minus sign. The integration for surface C starts with $f(\pi/2) = b \geq 0$, which is usually chosen larger than 0 to prevent a sharp edge of the collimator for manufacturing purposes. At $t = \tau_2$, the final value $f(\tau_2)$ of the calculation of surface C is chosen as starting value for the calculation of surface B. The coordinates of the surfaces B and C can be calculated as

$$x_{B/C}(t) = x_S(t) + f(t) \cos(\tilde{t}(t)), \quad (13a)$$

$$y_{B/C}(t) = y_S(t) + f(t) \sin(\tilde{t}(t)). \quad (13b)$$

Now consider surface A, the 'lens route' of the collimator. The light incident on surface A comes from a single point, therefore the arc-length along the source surface is 0, so we take $s(t) = 0$. Furthermore, we

have $\tilde{t}(t) = t$. For a refractive surface we need the following expression for β [11]:

$$\tan(\beta) = \frac{\sin(\tilde{\theta} - \tilde{t})}{1/n - \cos(\tilde{\theta} - \tilde{t})}. \quad (14)$$

Using (12), the differential equation (8) is now

$$\frac{df}{dt} = \left(\frac{\sin(\tilde{\theta} - t)}{1/n - \cos(\tilde{\theta} - t)} \right) f, \quad (15)$$

which we solve by numerically integrating backwards subject to the end condition

$$f(\tau_1) = \sqrt{x_S(\tau_1)^2 + y_S(\tau_1)^2}. \quad (16)$$

Surface A can be calculated according to

$$x_A(t) = f(t) \cos(t), \quad (17a)$$

$$y_A(t) = f(t) \sin(t). \quad (17b)$$

3 A TIR collimator with three transfer functions

Our goal is to design a TIR collimator that has a beam with a specified intensity output $\mathcal{G}(\theta)$ and uniform chromaticity coordinates (x_T, y_T) . To achieve this, the transfer functions must satisfy (3) and (6). The layout of the TIR collimator as shown in Figure 1 corresponds to three transfer functions, so $N = 3$. For the lens part and surface C, t increases with θ , so $\sigma_1 = \sigma_3 = 1$. For surface B, t decreases for increasing values of θ , and thus $\sigma_2 = -1$. We use the following convention: $\mathcal{I}_i(\theta) = \mathcal{I}(\eta_i(\theta))$ and $y_i(\theta) = y(\eta_i(\theta))$. We now have the following system of differential equations:

$$\begin{pmatrix} \mathcal{I}_1(\theta) & -\mathcal{I}_2(\theta) & \mathcal{I}_3(\theta) \\ \mathcal{I}_1(\theta)/y_1(\theta) & -\mathcal{I}_2(\theta)/y_2(\theta) & \mathcal{I}_3(\theta)/y_3(\theta) \end{pmatrix} \begin{pmatrix} \eta'_1(\theta) \\ \eta'_2(\theta) \\ \eta'_3(\theta) \end{pmatrix} = c \mathcal{G}(\theta) \begin{pmatrix} 1 \\ 1/y_T \end{pmatrix}. \quad (18)$$

The initial and end conditions for the transfer functions follow from the signs σ_i and the boundaries τ_1 and τ_2 between the segments:

$$\eta_1(0) = 0, \eta_2(0) = \tau_2, \eta_3(0) = \tau_2, \quad (19a)$$

$$\eta_1(\theta_{\max}) = \tau_1, \eta_2(\theta_{\max}) = \tau_1, \eta_3(\theta_{\max}) = \pi/2. \quad (19b)$$

The system (18) is underdetermined, therefore we add an extra equation. We choose an equation which is as simple as possible, has an obvious physical interpretation and yields a regular coefficient matrix for the ODE system. The equation we choose corresponds to the requirement that the intensity resulting from one

of the transfer functions contributes a factor $r \in (0, 1)$ to the total target intensity. Let j be the index of this transfer function, then we impose

$$\sigma_j \mathcal{I}_j(\theta) \eta_j'(\theta) = r c \mathcal{G}(\theta). \quad (20)$$

For $j = 1$, the coefficient matrix of the system is singular for $\theta = 0$, and for $j = 3$, the coefficient matrix is singular for $\theta = \theta_{\max}$. Such a singular coefficient matrix does not occur for $j = 2$, so this will be our choice.

The ODE system is now

$$\begin{pmatrix} \mathcal{I}_1(\theta) & -\mathcal{I}_2(\theta) & \mathcal{I}_3(\theta) \\ \mathcal{I}_1(\theta)/y_1(\theta) & -\mathcal{I}_2(\theta)/y_2(\theta) & \mathcal{I}_3(\theta)/y_3(\theta) \\ 0 & -\mathcal{I}_2(\theta) & 0 \end{pmatrix} \begin{pmatrix} \eta_1'(\theta) \\ \eta_2'(\theta) \\ \eta_3'(\theta) \end{pmatrix} = c \mathcal{G}(\theta) \begin{pmatrix} 1 \\ 1/y_T \\ r \end{pmatrix}. \quad (21)$$

The system can be inverted, yielding the following explicit system

$$\eta_1'(\theta) = \frac{c \mathcal{G}(\theta)}{\mathcal{I}_1(\theta)} \frac{y_1(\theta)}{y_1(\theta) - y_3(\theta)} \left(1 - r - \frac{y_3(\theta)}{y_T} + r \frac{y_3(\theta)}{y_2(\theta)} \right), \quad (22a)$$

$$\eta_2'(\theta) = -r \frac{c \mathcal{G}(\theta)}{\mathcal{I}_2(\theta)}, \quad (22b)$$

$$\eta_3'(\theta) = \frac{c \mathcal{G}(\theta)}{\mathcal{I}_3(\theta)} \frac{y_3(\theta)}{y_3(\theta) - y_1(\theta)} \left(1 - r - \frac{y_1(\theta)}{y_T} + r \frac{y_1(\theta)}{y_2(\theta)} \right). \quad (22c)$$

The system (22) with boundary conditions (19) has three unknown functions $\eta_1(\theta)$, $\eta_2(\theta)$ and $\eta_3(\theta)$. The functions $\mathcal{I}(t)$ and $y(t)$ are known from measurements on the LED. The function $\mathcal{G}(\theta)$ can be chosen by the optical designer as a finite function on $[0, \theta_{\max}]$. The constants c , y_T and r cannot be chosen freely, we will show that their values follow from conservation of luminous flux, the law of color mixing and the choice of τ_1 and τ_2 , respectively. Also the values of τ_1 and τ_2 cannot be chosen freely, we will derive an inequality that guarantees monotonicity of the transfer functions.

Equation (22a) has a removable singularity at $\theta = 0$, because $\mathcal{G}(0) = 0$ and the initial values of the transfer functions imply $\eta_1(0) = 0$ and thus $\mathcal{I}_1(0) = \mathcal{I}(0) = 0$. We calculate $\eta_1'(0)$ using l'Hôpital's rule:

$$\eta_1'(0) = \sqrt{\frac{c \mathcal{G}'_+(0)}{\mathcal{I}'_+(0)} \frac{y_1(0)}{y_1(0) - y_3(0)} \left(1 - \frac{y_3(0)}{y_T} \right)}. \quad (23)$$

We choose the positive sign in front of the square root since $\eta_1'(0)$ should be positive. Here $\mathcal{G}'_+(0)$ and $\mathcal{I}'_+(0)$ are the right derivatives of $\mathcal{G}(\theta)$ at $\theta = 0$ and of $\mathcal{I}(t)$ at $t = 0$, respectively. These right derivatives are positive because $\mathcal{I}(t)$ and $\mathcal{G}(\theta)$ are positive at $t > 0$ and $\theta > 0$. We have $y(t) > 0$ by definition of chromaticity coordinates, and we assume based on measurements that $y(\tau_1) < y(\tau_2)$ and thus $y_1(0) < y_3(0)$. From this we see that we need to choose τ_2 such that $y(\tau_2) > y_T$, so the right hand side of (23) is positive and real.

3.1 The values of c , y_T and r

The system (21) with boundary conditions (19) appears to be overdetermined. However, the system contains three unknown parameters which still need to be chosen. We derive values for three constants c , y_T and r given the boundary conditions and assuming monotonicity of the transfer functions. Later we show that our choice of the constants c , y_T and r imply that three of the boundary conditions are superfluous.

The first unknown value is the constant c . Integration of the first row of (21), using the given boundary conditions and $\mathcal{I}_i(\theta) = \mathcal{I}(\eta_i(\theta))$, yields

$$c \int_0^{\theta_{\max}} \mathcal{G}(\theta) d\theta = \int_0^{\theta_{\max}} \sum_{i=1}^3 \sigma_i \mathcal{I}_i(\theta) \eta_i(\theta) d\theta = \int_0^{\pi/2} \mathcal{I}(t) dt. \quad (24)$$

The function $\mathcal{I}(t)$ is known from measurements on the LED, the function $\mathcal{G}(\theta)$ is chosen by the optical designer, so from this relation we derive the value of the constant c . This relation corresponds to conservation of luminous flux (Equation (2)).

The second unknown is the target chromaticity value y_T . Integration of the second row of (21) using the given boundary conditions and substitution of (24) yields

$$1/y_T \int_0^{\pi/2} \mathcal{I}(t) dt = \int_0^{\pi/2} \mathcal{I}(t)/y(t) dt. \quad (25)$$

This relation shows that y_T is the weighted harmonic average of the y -chromaticity coordinate of the light source. Like $\mathcal{I}(t)$, the function $y(t)$ is known from measurements on the LED, thus we can derive the value of y_T .

The third unknown is r . Integration of the third row of (21) with the given boundary conditions and substitution of (24) yields

$$r \int_0^{\pi/2} \mathcal{I}(t) dt = \int_{\tau_1}^{\tau_2} \mathcal{I}(t) dt. \quad (26)$$

This relations corresponds to conservation of luminous flux for the second transfer function.

3.2 Monotonicity of the transfer functions.

The transfer functions calculated from (22) should be monotonic, otherwise they have no physical meaning. From (22b) we can easily see that $\eta_2'(\theta) \leq 0$ because $r > 0$, $\mathcal{G}(\theta) \geq 0$ and $\mathcal{I}(t) \geq 0$, thus, $\eta_2(\theta)$ is monotonically decreasing. The monotonicity of η_1 and η_3 is more complicated to show and we need some additional assumptions to derive a sufficient condition for monotonicity.

Theorem 1. *Assume that the chromaticity coordinate function $y(t)$ satisfies the inequalities*

$$0 < y(t_1) < y(\tau_1) < y(t_2) < y(\tau_2) < y(t_3) \forall t_1, t_2, t_3 \text{ s.t. } 0 < t_1 < \tau_1 < t_2 < \tau_2 < t_3 < \pi/2., \quad (27)$$

and the transfer functions satisfy the bounds

$$0 \leq \eta_1(\theta) \leq \tau_1, \tau_1 \leq \eta_2(\theta) \leq \tau_2, \tau_2 \leq \eta_3(\theta) \leq \pi/2. \quad (28)$$

If

$$\frac{\int_{\tau_1}^{\tau_2} \mathcal{I}(t) dt}{\int_0^{\pi/2} \mathcal{I}(t) dt} = r < \min \left(\frac{y(\tau_1)}{y_{\text{T}}}, \frac{y(\tau_2)/y_{\text{T}} - 1}{y(\tau_2)/y(\tau_1) - 1}, \frac{1 - y(\tau_1)/y_{\text{T}}}{1 - y(\tau_1)/y(\tau_2)} \right), \quad (29)$$

then $\eta_1(\theta)$ and $\eta_3(\theta)$ are monotonically increasing.

Proof. We need to prove that the derivatives of η_1 and η_3 are positive. From (22a), using assumptions (27) and (28), we find that η_1 is monotonically increasing if

$$1 - r - \frac{y_3(\theta)}{y_{\text{T}}} + r \frac{y_3(\theta)}{y_2(\theta)} \leq 0,$$

and likewise η_3 is monotonically increasing if

$$1 - r - \frac{y_1(\theta)}{y_{\text{T}}} + r \frac{y_1(\theta)}{y_2(\theta)} \geq 0.$$

Subtracting the second inequality from the first we obtain

$$t - \frac{1}{y_{\text{T}}} (y_3(\theta) - y_1(\theta)) + \frac{r}{y_2(\theta)} (y_3(\theta) - y_1(\theta)) \leq 0.$$

Using (27) and (28) we find from the assumption $r < y(\tau_1)/y_{\text{T}}$ that

$$\frac{r}{y_2(\theta)} \leq \frac{1}{y_{\text{T}}}.$$

Define

$$M(\theta) = \frac{1 - r}{1/y_{\text{T}} - r/y_2(\theta)}.$$

Using $\frac{r}{y_2(\theta)} \leq \frac{1}{y_{\text{T}}}$, the inequality for the monotonicity of the first transfer function can be rewritten as $M(\theta) \leq y_3(\theta)$ and the inequality for the third transfer function as $y_1(\theta) \leq M(\theta)$. We combine these two results to obtain

$$y_1(\theta) \leq M(\theta) \leq y_3(\theta).$$

The function $M(\theta)$ is monotonically increasing because $\eta_2(\theta)$ is monotonically decreasing. Therefore, if $y(\tau_1) \leq M(0)$, we find using (27) and (28) that $y_1(\theta) \leq M(\theta)$ for all θ . Similarly, if $M(\theta_{\text{max}}) \leq y(\tau_2)$, then $M(\theta) \leq y_3(\theta)$ for all θ . The inequalities $y(\tau_1) \leq M(0)$ and $M(\theta_{\text{max}}) \leq y(\tau_2)$ are equivalent to the second and third inequality in (29). \square

Figure 4 shows a scatter plot of values of τ_1 and τ_2 for which (29) is satisfied for an LED which was also used in the numerical experiments. The acceptable values of τ_1 and τ_2 are bounded by the lines $\tau_1 = t_{av}$ and $\tau_2 = t_{av}$, where t_{av} is the such that $y(t_{av}) = y_T$. In this case, the value of t_{av} is unique. From (29) we see that $\tau_1 > t_{av}$ results in $y(\tau_1) > y_T$, and thus $r < 0$. Therefore we cannot guarantee the monotonicity of the transfer functions. Using (22c) we can verify that indeed the third transfer function is not monotonic at $\theta = \theta_{\max}$. Similarly, $\tau_2 < t_{av}$ results in $r < 0$, and we can verify using (23) that the first transfer function is not monotonic at $\theta = 0$.

3.3 The initial value problem

The ODE-system (21) with the boundary conditions (19) can be solved as an initial value problem. We remark that solving the system as an end value problem has no advantages or disadvantages. We discard the end conditions and solve the initial value problem using a Runge-Kutta method. The end conditions are satisfied as a result of our choices of c , y_T and r .

Theorem 2. *Assume monotonicity of the transfer functions. The solution of the initial value problem defined by the ODE system (21) and the initial conditions $\eta_1(0) = 0$, $\eta_2(0) = \eta_3(0) = \tau_2$ satisfies the end conditions $\eta_1(\theta_{\max}) = \eta_2(\theta_{\max}) = \tau_1$, $\eta_3(\theta_{\max}) = \pi/2$.*

Proof. First we show that $\eta_2(\theta_{\max}) = \tau_1$ is satisfied. Integration of the last row of (21) from $\theta = 0$ to $\theta = \theta_{\max}$ using (26) gives

$$-\int_0^{\theta_{\max}} \mathcal{I}_2(\theta) \eta_2'(\theta) d\theta = -\int_{\tau_2}^{\eta_2(\theta_{\max})} \mathcal{I}(t) dt = rc \int_0^{\theta_{\max}} \mathcal{G}(\theta) d\theta = \int_{\tau_1}^{\tau_2} \mathcal{I}(t) dt.$$

So we find

$$\int_{\tau_2}^{\eta_2(\theta_{\max})} \mathcal{I}(t) dt + \int_{\tau_1}^{\tau_2} \mathcal{I}(t) dt = 0.$$

Because $\mathcal{I}(t) > 0$ for all t except for two points at the boundary, we can conclude $\eta_2(\theta) = \tau_1$. Note that this implies $\tau_1 \leq \eta_2(\theta) \leq \tau_2$.

Using the monotonicity of the transfer functions, we can integrate the left hand side of the first row of (21):

$$\begin{aligned} & \int_0^{\theta_{\max}} (\mathcal{I}_1(\theta) \eta_1'(\theta) - \mathcal{I}_2(\theta) \eta_2'(\theta) + \mathcal{I}_3(\theta) \eta_3'(\theta)) d\theta = \\ & \int_0^{\eta_1(\theta_{\max})} \mathcal{I}(t) dt - \int_{\tau_2}^{\tau_1} \mathcal{I}(t) dt + \int_{\tau_2}^{\eta_3(\theta_{\max})} \mathcal{I}(t) dt. \end{aligned}$$

For the right hand side we have due to (24)

$$c \int_0^{\theta_{\max}} \mathcal{G}(\theta) d\theta = \int_0^{\pi/2} \mathcal{I}(t) dt.$$

By subtracting the last two relations we find

$$\int_{\tau_1}^{\eta_1(\theta_{\max})} \mathcal{I}(t) dt + \int_{\pi/2}^{\eta_3(\theta_{\max})} \mathcal{I}(t) dt = 0. \quad (*)$$

Similarly, we can derive from the second row of (21) using Equation (25)

$$\int_{\tau_1}^{\eta_1(\theta_{\max})} \frac{\mathcal{I}(t)}{y(t)} dt + \int_{\pi/2}^{\eta_3(\theta_{\max})} \frac{\mathcal{I}(t)}{y(t)} dt = 0.$$

The functions $\mathcal{I}(t)$ and $1/y(t)$ are continuous, and $\mathcal{I}(t)$ does not change sign in the interval $(0, \pi/2)$. Using the expanded first mean-value theorem for integrals [12, p.487], we find that for some $t_1 \in (\eta_1(\theta_{\max}), \tau_1)$ and some $t_3 \in (\eta_2(\theta_{\max}), \pi/2)$ we have

$$\frac{1}{y(t_1)} \int_{\tau_1}^{\eta_1(\theta_{\max})} \mathcal{I}(t) dt + \frac{1}{y(t_3)} \int_{\pi/2}^{\eta_3(\theta_{\max})} \mathcal{I}(t) dt = 0. \quad (**)$$

The equations (*) and (**) form a linear system for the integrals of $\mathcal{I}(t)$ over $[\tau_1, \eta_1(\theta_{\max})]$ and $[\pi/2, \eta_3(\theta_{\max})]$.

If $t_1 < \tau_2$, we find from the assumption $y(t_1) < y(t_3)$ that

$$\det \begin{pmatrix} 1 & 1 \\ 1/y(t_1) & 1/y(t_3) \end{pmatrix} \neq 0,$$

and thus

$$\begin{aligned} \int_{\tau_1}^{\eta_1(\theta_{\max})} \mathcal{I}(t) dt &= 0, \\ \int_{\pi/2}^{\eta_3(\theta_{\max})} \mathcal{I}(t) dt &= 0. \end{aligned}$$

Because $\mathcal{I}(t) > 0$ for all t except at the boundary points, we conclude

$$\begin{aligned} \eta_1(\theta_{\max}) &= \tau_1, \\ \eta_3(\theta_{\max}) &= \pi/2. \end{aligned}$$

□

4 Numerical procedure and results

We solved the mathematical model described in the previous section to design three different TIR collimators. The collimators were designed for two different LEDs, which we refer to as LED16 and LED02. Both of

LED	i	0	2	3	4	5	6	7
16	C_i	0	-181.8279	76.0797	221.9411	-624.0461	499.8253	-127.0787
	D_i^x	0.4013	0.0578	-0.0367	0.0271	-0.0564	0.0444	-0.0116
	D_i^y	0.3546	0.0988	-0.0557	0.0255	-0.0371	0.0196	-0.0034
02	C_i	0	-148.8533	-60.3797	520.5934	-913.6760	636.8623	-153.5863
	D_i^x	0.4591	0.0452	-0.0590	0.0916	-0.1399	0.1030	-0.0271
	D_i^y	0.3792	0.0892	-0.1790	0.3596	-0.4585	0.2823	-0.0658

Table 1: Coefficients from the linear least squares fits.

them are Luxeon Rebel IES white LEDs without a dichroic coating, and have a larger than usual CoA variation. The intensity and chromaticity-coordinates of the LEDs were measured, and the measured data were interpolated. The interpolation polynomials have been used to approximate $\mathcal{I}(t)$ and $y(t)$ in (22). The first two collimators were designed for LED16 and have a Gaussian-shaped target intensity profile. The two collimators differ in their values for τ_1 and τ_2 . The third collimator was designed for LED02 and has a block-shaped target intensity profile. The collimators were evaluated using the LightTools software package [13].

4.1 Modelling of the LEDs

The LEDs were measured using a goniophotometer [14]. A goniophotometer is a device that measures intensity, chromaticity coordinates and many other characteristics of light at different solid angles. Our LEDs were measured at 46 different angles t and 4 different angles u . For each LED, the chromaticity values were averaged and the intensities were summed over the angle u . These data have been interpolated with a least squares fit using the following polynomials:

$$I(t) = \sum_{i=2}^7 C_i (t^i - (\pi/2)^i), \quad (32a)$$

$$x(t) = D_0^x + \sum_{i=2}^7 D_i^x t^i, \quad (32b)$$

$$y(t) = D_0^y + \sum_{i=2}^7 D_i^y t^i. \quad (32c)$$

The polynomial for the intensity was chosen because it equals 0 at $t = \pi/2$ and has zero derivative at $t = 0$, both properties are characteristic for the intensity distribution of an LED. The effective intensity equals $\mathcal{I}(t) = \sin(t)I(t)$. The polynomials for the chromaticity coordinates were chosen because their derivative equals 0 at $t = 0$. The coefficients for the two LEDs can be found in Table 1.

In the LightTools software package, two three-dimensional models were built to simulate the LEDs. The

Collimator	LED	τ_1	τ_2	r	y_T	c	θ_{\max}
Gaussian, small 2 nd segment	LED16	0.20π	0.25π	0.1630	0.3862	5585.9	11.25π
Gaussian, large 2 nd segment	LED16	0.16π	0.30π	0.4417	0.3862	5585.9	11.25π
Block profile	LED02	0.20π	0.25π	0.1612	0.3986	4843.3	9π

Table 2: Parameter values and characteristics for the three different collimators.

range $(0, \frac{\pi}{2})$ of the angle t was discretized into 46 different subintervals, labeled $k = 1, 2, \dots, 46$. For $k = 1$ we have the interval $(0, \frac{\pi}{180})$, for $k = 2, \dots, 45$ we have $(\frac{(2k-3)\pi}{180}, \frac{(2k-1)\pi}{180})$ and finally for $k = 46$ we have $(\frac{89\pi}{180}, \frac{\pi}{2})$. The intensity and chromaticity coordinates of the LED models in these subintervals correspond to the measured data of the real LEDs at the angles $t = \frac{(2k-2)\pi}{180}$. The size of the LED model was reduced to 0.01mm by 0.01mm to simulate a point light source. A comparison of the measured data, the least squares fit and the raytracing results of the LightTools model of LED16 without collimator can be seen in Figure 5 and 6. A scatter plot of the measured x and y chromaticity coordinates for this LED was shown earlier in Figure 3. The plot shows the near-linear relationship between x and y , indeed.

4.2 Computation of the transfer functions

Three example collimators have been calculated. The first collimator was designed for a Gaussian target intensity [15] with full width at half maximum (FWHM) [16] at $\pi/9$. This yields the following effective target intensity:

$$\mathcal{G}(\theta) = \sin(\theta) \exp\left(-4 \ln(2) \left(\frac{\theta}{\theta_{\text{FWHM}}}\right)^2\right), \quad (33)$$

with $0 \leq \theta \leq 1.25\theta_{\text{FWHM}} = \theta_{\max}$, $\theta_{\text{FWHM}} = \pi/9$. The collimator was designed for LED16. The choice of τ_1 and τ_2 is restricted by (29). This relation is highly nonlinear. A scatter plot of values of τ_1 and τ_2 that satisfy (29) for LED16 is shown in Figure 4.

We chose $\tau_1 = 0.2\pi$ and $\tau_2 = 0.25\pi$. The second collimator was designed for the same LED and target intensity, but this time we chose $\tau_1 = 0.16\pi$ and $\tau_2 = 0.3\pi$, which gives a larger second segment. The third collimator was designed for LED02. The target intensity was chosen to be a block function, yielding the effective intensity $\mathcal{G}(\theta) = \sin(\theta)$, with $0 \leq \theta \leq \theta_{\max} = \pi/9$. We chose $\tau_1 = 0.2\pi$ and $\tau_2 = 0.25\pi$, which satisfies (29). An overview of the values chosen and calculated for the three collimator is shown in Table 2.

The ODE system (22) with initial conditions (19a) was solved using the ODE-solver `ode45` in Matlab. The calculation times were a few seconds on a laptop computer with a 2,4 GHz processor and 4 GB RAM. The calculated transfer functions are shown in Figure 7, 8 and 9. The transfer functions are indeed monotonic, as expected. Also, $\eta_1(\theta_{\max}) = \eta_2(\theta_{\max}) = \tau_1$ and $\eta_3(\theta_{\max}) = \pi/2$, as anticipated.

Collimator	LED	Target x	$\max(\Delta x)$	Target y	$\max(\Delta y)$
Gaussian, small 2 nd segment	LED16	0.4181	$4 \cdot 10^{-4}$	0.3862	$7 \cdot 10^{-4}$
Gaussian, large 2 nd segment	LED16	0.4181	$4 \cdot 10^{-4}$	0.3862	$1 \cdot 10^{-3}$
Block profile	LED02	0.4691	$4 \cdot 10^{-4}$	0.3985	$5 \cdot 10^{-4}$

Table 3: Average chromaticity coordinates of the LEDs and the maximum difference with the chromaticity coordinates in the simulations.

4.3 Performance of the TIR collimators

Subsequently, a TIR collimator was designed for each set of transfer functions, and evaluated using LightTools. We chose for all the collimators $d = 4\text{mm}$, $b = 0.4\text{mm}$ and $\alpha = 4\pi/180$. For every collimator, each free surface was discretized using 500 points and converted into a LightTools model. A screenshot of the LightTools model of the first collimator can be seen in Figure 10. Results of the simulations can be seen in Figure 11, 12 and 13. In these figures, we see the expected profiles of the effective intensity and chromaticity. In Figure 11 and 12 an irregularity is visible in the chromaticity coordinates near $\theta = \theta_{\max}$. This can be explained as follows. Every bar in the graph corresponds to a range of one degree ($\pi/180$ rad). We chose $\theta_{\max} = 25\pi/180$, and thus the flux at this angle should be zero. Due to small errors in the free surfaces, a small number of rays exits the collimator at angles larger than θ_{\max} . This happens at surface C , and therefore the chromaticity coordinates at $\theta > \theta_{\max}$ are larger than the target values. Because the luminous flux of this light is very small, the irregularity is not visible. A similar irregularity is visible for the collimator with the block profile, only with a smaller chromaticity difference.

Apart from this small irregularity, the variation in chromaticity is very small. The maximum difference between the average chromaticity of the LEDs and chromaticity coordinates in the simulations are shown in Table 3. A color difference of 0.003 is considered very good by optical designers and is invisible for the human eye [8, 17]. The measured color differences in the simulations are comfortably below this value, thus the color variation in the beam is eliminated.

5 Conclusions

We introduced an inverse method to design a TIR collimator that eliminates CoA variation for a point light source. This method improves the method introduced earlier in [1] by producing collimators that closely resemble standard collimators and at the same time have more parameters for optical design. In Section 3 we discussed which choices for these design parameters give meaningful results. In Section 4 we tested the method and verified the resulting collimators with Monte-Carlo raytracing using the software package LightTools. The simulations show color variations that are not visible with the human eye.

Unfortunately, LEDs are too large to be treated as a point light source. In future research, we would like to extend this method to take the finite size of the light source into account using iterative methods such as described in for example [18,19]. This point source method will be an important building block in such an iterative method.

References

1. Prins C, ten Thije Boonkkamp J, Tukker T, IJzerman W: **An inverse method for the design of TIR collimators to achieve a uniform color light beam**. 2012. [(to be published)].
2. Haitz R, Jeffrey YT: **Solid-state lighting: 'The case' 10 years after and future prospects**. *Physica Status Solidi A* 2011, **208**:17–29.
3. Schubert F: *Light-Emitting Diodes*. Cambridge University Press, 2nd edition 2006.
4. Wu H, Narendran N, Gu Y, Bierman A: **Improving the Performance of Mixed-Color White LED Systems by Using Scattered Photon Extraction Technique**. In *Light-Emitting Diodes, Volume 6669 of Proc. SPIE* 2007.
5. Mueller GO: **Luminescent ceramic for a light emitting device**. *United States patent US7361938 B2*.
6. Wang K, Wu D, Chen F, Liu Z, Luo X, Liu S: **Angular color uniformity enhancement of white light-emitting diodes integrated with freeform lenses**. *Optics Letters* 2010, **35**:1860–1862.
7. Maes M: **Mathematical methods for reflector design**. *PhD thesis*, University of Amsterdam 1997.
8. Malacara D: *Color Vision and Colorimetry. Theory and Applications*. SPIE Press 2002.
9. Wyszecki G, Stiles W: *Color Science. Concepts and Methods, Quantitative Data and Formulae*. John Wiley and Sons, INC, 2nd edition 2000.
10. Bortz J, Shatz N: **Generalized functional method of nonimaging optical design**. In *Nonimaging Optics and Efficient Illumination Systems III, Volume 6338 of Proc. SPIE*. Edited by R Winston & P Benitez 2006.
11. Bortz J, Shatz N: **Mathematical relationships between the generalized functional, edge-ray and sms design methods**. In *Nonimaging Optics: Efficient Design for Illumination and Solar Concentration, Volume 7785 of Nonimaging Optics: Efficient Design for Illumination and Solar Concentration*. Edited by R Winston & J M Gordon 2010.
12. Stöcker H: *Taschenbuch mathematischer Formeln und moderner Verfahren*. Verlag Harri Deutsch 1993.
13. **ORA LightTools product website**. http://www.opticalres.com/lt/ltprodds_f.html. [Accessed February 27, 2012].
14. **Instrument Systems - Light measurement**. <http://www.instrumentsystems.com/products/led-measurement-accessories/ledgon-goniophotometer/>. [Accessed July 10, 2012].
15. Weisstein E: **Gaussian Function**. <http://mathworld.wolfram.com/GaussianFunction.html>.
16. Weisstein E: **Full Width at Half Maximum**. <http://mathworld.wolfram.com/FullWidthatHalfMaximum.html>.
17. MacAdam D: **Visual Sensitivities to Color Differences in Daylight**. *Journal of the Optical Society of America* 1942, **32**:247–274.
18. Zhang W, Liu Q, Gao H, Yu F: **Free-form reflector optimization for general lighting**. *Optical Engineering* 2010, **49**.
19. Cassarly J: **Iterative Reflector Design Using a Cumulative Flux Compensation Approach**. In *Optical Engineering, Volume 7652 of Proc. of SPIE-OSA* 2010.

6 Figures

col3-ST

Figure 1: Profile of a TIR collimator. A full TIR collimator can be obtained by rotating the profile around the z -axis. Surface B and C are separated by the ray with angle $\theta = 0$.

generalizedmethod-2

Figure 2: Geometry of the free surfaces B and C. The grey arrow shows the 'TIR route' of the light.

xyscatter16

Figure 3: Scatter plot of the measured x and y chromaticity coordinates of the LED used in the numerical experiments in this article. The size of the circles corresponds to the effective intensity. The measured data in the lower left corner correspond small angles of t . The measured data for values of t close to $\pi/2$ around $(0.423, 0.4)$ are unreliable because of the low light intensities, causing the irregularity.

TIR3sufficientcondition

Figure 4: Scatter plot of the values of τ_1 and τ_2 for LED16 that guarantee monotonic transfer functions. t_{av} is such that $y(t_{av}) = y_T$

intensity-comp-16

Figure 5: Comparison of the measured effective intensity \mathcal{I} , the least squares fit and the LightTools model of LED16. The graph of the LightTools model is not visible because it is hidden behind the least squares fit.

xy-comp-16

Figure 6: Comparison of measured chromaticity coordinates x and y , the least squares fit and the LightTools Model of LED16. The graph of the LightTools model is not visible because it is hidden behind the least squares fit.

eta3seg-1

Figure 7: Transfer functions for the collimator with Gaussian profile and a small second segment.

eta3seg-2

Figure 8: Transfer functions for the collimator with Gaussian profile and a large second segment.

eta3seg-3

Figure 9: Transfer functions for the collimator with block profile.

3segcollimatorscreenshot

Figure 10: LightTools model of the first collimator

3seg-col1LT

Figure 11: LightTools simulation results for the collimator with Gaussian profile and a small second segment.

3seg-col2LT

Figure 12: LightTools simulation results for the collimator with Gaussian profile and a large second segment.

3seg-col3LT

Figure 13: LightTools simulation results for the collimator with Block profile for LED02.

PREVIOUS PUBLICATIONS IN THIS SERIES:

Number	Author(s)	Title	Month
12-44	J. Kruschwitz A. Muntean	On a pathological dependence of traffic flow fluxes on vehicle acceleration – a dimensional renormalization exercise	Dec. '12
12-45	B. Tasić J.J. Dohmen E.J.W. ter Maten T.G.J. Beelen W.H.A. Schilders A. de Vries M. van Beurden	Robust DC and efficient time-domain fast fault simulation	Dec. '12
12-46	C. Kaufmann M. Günther D. Klagges M. Knorrenschild M. Richwin S. Schöps E.J.W. ter Maten	Efficient frequency-transient co-simulation of coupled heat-electromagnetic problems	Dec. '12
13-01	C.J.J. Vleugels A. Muntean M.J.H. Anthonissen T.I. Seidman	Minimizing driver's irritation at a roadblock	Jan. '12
13-02	C.R. Prins J.H.M. ten Thije Boonkkamp T. Tukker W. IJzerman	An inverse method for color uniformity in white LED spotlights	Jan. '12