

# Feedforward Control for an Interventional X-ray

**Citation for published version (APA):**

Kon, J. J., Bruijnen, D., van de Wijdeven, J., Heertjes, M. F., & Oomen, T. A. E. (2023). *Feedforward Control for an Interventional X-ray: A Physics-Guided Neural Network Approach*. 163-163. Abstract from 42nd Benelux Meeting on Systems and Control 2023, Elspeet, Netherlands.

**Document status and date:**

Published: 16/03/2023

**Document Version:**

Publisher's PDF, also known as Version of Record (includes final page, issue and volume numbers)

**Please check the document version of this publication:**

- A submitted manuscript is the version of the article upon submission and before peer-review. There can be important differences between the submitted version and the official published version of record. People interested in the research are advised to contact the author for the final version of the publication, or visit the DOI to the publisher's website.
- The final author version and the galley proof are versions of the publication after peer review.
- The final published version features the final layout of the paper including the volume, issue and page numbers.

[Link to publication](#)

**General rights**

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal.

If the publication is distributed under the terms of Article 25fa of the Dutch Copyright Act, indicated by the "Taverne" license above, please follow below link for the End User Agreement:

[www.tue.nl/taverne](http://www.tue.nl/taverne)

**Take down policy**

If you believe that this document breaches copyright please contact us at:

[openaccess@tue.nl](mailto:openaccess@tue.nl)

providing details and we will investigate your claim.

# Feedforward Control for an Interventional X-ray: A Physics-Guided Neural Network Approach

Johan Kon<sup>i,\*</sup>, Dennis Bruijnen<sup>ii</sup>, Jeroen van de Wijdeven<sup>iii</sup>, Marcel Heertjes<sup>i,ii</sup>, and Tom Oomen<sup>i,iv</sup> <sup>1</sup>

## 1 Background

Interventional X-ray systems (IXs) are a key technology in healthcare that improve treatment quality through visualization of patient tissue. This enables minimally invasive therapies, resulting in faster patient recovery. To guarantee both high imaging quality as well as patient and operator safety, accurate feedforward control is essential during operation of an IX. A typical IX is visualized in Fig. 1.

## 2 Problem Formulation

The tracking performance of feedforward controllers based on first-principles modeling is limited by hard-to-model dynamics in the IX, such as the configuration-dependent cable forces and nonlinear friction characteristics in the guidance.

Instead, the goal of this work is to learn these hard-to-model dynamics from input-output data of the IX through capturing their contributions to the equations of motion using neural networks as flexible function approximators.

## 3 Physics-Guided Neural Network Feedforward

To compensate the hard-to-model dynamics, the feedforward controller is parametrized as a parallel combination of a physical model and neural network  $g_\phi$  such that the feedforward  $f$  for reference  $\theta_d$  is given by

$$f(\theta_d(k)) = M\ddot{\theta}_d(k) + mgh(\theta_d(k)) + g_\phi(T(\theta_d(k))), \quad (1)$$

where  $M$  and  $mgh(\theta)$  represent the inertia and gravity contribution derived from first-principles, and

$$T(\theta_d(k)) = [\theta_d(k) \quad \dot{\theta}_d(k) \quad \ddot{\theta}_d(k) \quad \text{relay}(\theta_d(k))]^T \quad (2)$$

represents is a physics-guided input transformation.

The parameters  $M, m, \phi$  are learned from input-output data  $\{u(k), y(k)\}_{k=1}^N$  through inverse system identification, i.e., by regressing the feedforward output  $f(y(k))$  on  $u(k)$  as

$$\sum_{k=1}^N (u(k) - f(y(k)))^2 + R(\phi). \quad (3)$$

$R(\phi)$  represents orthogonal projection-based regularization [1] to ensure that  $g_\phi$  does not learn modeled effects, such that the physical model remains interpretable.

## 4 Results

The feedforward controller is validated experimentally on the IX setup of Fig. 1. Fig. 2 shows the resulting tracking errors. The proposed feedforward controller (—) compensates almost all dynamics, resulting in a tracking error of a few encoder counts. In contrast, the physical-model-based feedforward controller (—) improves upon the feedback only case (—), but still contains predictable errors from uncompensated dynamics. Overall, the tracking error is reduced from 0.095 to 0.020 deg in mean absolute sense by the inclusion of a neural network.




Figure 1: Interventional X-ray system positioning the X-ray source and detector through rotating, i.a., the roll axis.




Figure 2: Error signals for proposed (—) and physical-model-based (—) feedforward controller compared to the feedback only case (—) with scaled velocity reference (—).

## References

- [1] J. Kon, D. Bruijnen, J. van de Wijdeven, M. Heertjes, and T. Oomen, “Physics-guided neural networks for feedforward control: An orthogonal projection-based approach,” in *Proc. Am. Control Conf.*, 2022.

<sup>1</sup>This work is supported by Topconsortia voor Kennis en Innovatie (TKI), and ASML and Philips Engineering Solutions.

<sup>i</sup>Control Systems Technology Group, Eindhoven University of Technology, P.O. Box 513, 5600 MB Eindhoven, The Netherlands. <sup>ii</sup>Philips Engineering Solutions, High Tech Campus 34, 5656 AE Eindhoven, The Netherlands.

<sup>iii</sup>ASML, De Run 6501, 5504 DR Veldhoven, The Netherlands. <sup>iv</sup>Delft University of Technology, P.O. Box 5, 2600 AA Delft, The Netherlands.

\*Email: j.j.kon@tue.nl