

U. PORTO

FEUP FACULDADE DE ENGENHARIA
UNIVERSIDADE DO PORTO



DESIGN OF A FIRE PROTECTION SYSTEM FOR AN INDUSTRIAL CHEMICAL PLANT WITH AUTOSPRINK – CASE STUDY

DANIEL FILIPE ROCHA AFONSO

Dissertation submitted for partial requirements attendance for the degree on
MASTER ON CIVIL ENGINEERING — BUILDING CONSTRUCTION SPECIALIZATION

Supervisor: Professor Doctor Miguel Jorge Chichorro Rodrigues Gonçalves

2020, JUNE

MESTRADO INTEGRADO EM ENGENHARIA CIVIL 2013/2014

DEPARTAMENTO DE ENGENHARIA CIVIL

Tel. +351-22-508 1901

Fax +351-22-508 1446

✉ miec@fe.up.pt

Editado por

FACULDADE DE ENGENHARIA DA UNIVERSIDADE DO PORTO

Rua Dr. Roberto Frias

4200-465 PORTO

Portugal

Tel. +351-22-508 1400

Fax +351-22-508 1440

✉ feup@fe.up.pt

🌐 <http://www.fe.up.pt>

Reproduções parciais deste documento serão autorizadas na condição que seja mencionado o Autor e feita referência a *Mestrado Integrado em Engenharia Civil - 2019/2020 - Departamento de Engenharia Civil, Faculdade de Engenharia da Universidade do Porto, Porto, Portugal, 2020.*

As opiniões e informações incluídas neste documento representam unicamente o ponto de vista do respetivo Autor, não podendo o Editor aceitar qualquer responsabilidade legal ou outra em relação a erros ou omissões que possam existir.

Este documento foi produzido a partir de versão eletrónica fornecida pelo respetivo Autor.

To my family and friends,

“From success, you learn absolutely nothing. From failure and setbacks, conclusions can be drawn. That goes for your private life as well as your career.”

Nikki Lauda

ACKNOWLEDGEMENTS

I would like to express my very great appreciation to the HSE department from Worley. Thank you for welcoming me so well and for making me feel so comfortable at work. To Polina, Ahmad, Rafael, Wendy and Bjorn, a big thanks. I am particularly grateful to Tinneke, for allowing me the opportunity to learn from her and for giving me the chance to join this team.

To Professor Miguel Chichorro Gonçalves, that from the moment I suggested the challenge of supervising this thesis abroad, took it with great enthusiasm and professionalism.

To mum and dad for providing all these years of education and the care throughout my life. Furthermore, to my brother Cláudio, for the support shown.

To Nando, Pedro, Jorge and Xano for the best advice someone can get from their uncles.

To André and David, for their fantastic friendship.

To Ivan, thesis' buddy, for all the conversations and discussions we had in this journey.

To my grandmas and especially to grandpa for “the example of rigour and demand that you have always transmitted to us”.

Thank you all.

ABSTRACT

The chemical industry is in an accelerated growth rhythm, naturally implying an increase in the associated risks, with fire being one of them. The treatment of chemical materials in the industry takes place, in most cases, at very high temperatures and pressures, thus requiring a reliable and efficient fire protection system that allows, in the event of an accident, a reliable and effective response of extinguishing and refrigerating agents.

The delay in the escalation of the fire is essential to give the competent authorities, the capacity of dealing with this type of accident in the chemical industry, time to attack and contain it.

There were two main objectives in carrying out this work. The first focused on the design and dimensioning of a network of automatic fire sprinklers, with water, for the process unit, object of study - case study. The second objective focused on the calculation of the needs of water and foam in a storage tank farm for highly flammable combustible materials.

The sprinkler network was designed in a BIM tool, with an extremely important the objective for the company where the dissertation was developed: to achieve an optimal space management in the chemical process unit. It is crucial, considering the complexity of such structures, where the chemical treatments of the flammable and combustible are processed.

As a second objective of the dissertation, a calculation sheet was developed in order to provide the engineer, in charge of the design of the storage tank farm for combustible materials, the worst fire case scenario. For this analysis, the needs of the water / foam mixture are compared, to cool (and eventually extinguish), a fire occurrence in each tank in the park. In addition, the sheet is prepared to calculate the need for water to cool adjacent tanks, subject to radiation from the one with the fire.

The amounts of water and foam are dependent on the physical characteristics of the reservoirs, such as the type of cover, either fixed, floating or interior floating, the height and diameter and even the type of liquid that is stored.

KEYWORDS: AutoSPRINK, Automatic extinguishing systems, space management, fire, fire safety, foam

RESUMO

A indústria química encontra-se num ritmo de crescimento acelerado, implicando naturalmente um incremento dos riscos associados, sendo o de incêndio um deles. O tratamento de matérias químicas na indústria acontece, na maior parte dos casos, a temperaturas e pressões muito elevadas sendo assim necessário um sistema de salvaguarda do incêndio fiável e eficaz que permita, em caso de algum acidente, uma resposta rápida e automática de agentes extintores e refrigeradores.

O retardamento no escalamento do incêndio é fundamental para dar tempo às autoridades competentes, e capazes de lidar com este tipo de sinistro na indústria química, fazerem o seu ataque e contenção.

Existiram dois objetivos principais com a realização deste trabalho. O primeiro concentrou-se no desenho e dimensionamento de uma rede de sprinklers automáticos de incêndio, com água para a unidade de processo, objeto de estudo – caso de estudo. Já o segundo objetivo, incidiu sobre o cálculo das necessidades de água e de espuma numa num parque de tanques de armazenamento de materiais combustíveis altamente inflamáveis.

A rede de sprinklers foi desenhada numa ferramenta BIM, com um grande objetivo que é de extrema importância para a empresa onde foi desenvolvida a dissertação: conseguir uma gestão ótima do espaço na unidade de processo químico. É crucial, tendo em conta a complexidade das estruturas que albergam os tratamentos químicos e a natureza inflamável e combustível dos elementos a processar.

Como segundo objetivo da dissertação, foi desenvolvida uma folha de cálculo com vista a fornecer ao engenheiro, encarregue do dimensionamento de um parque de tanques de armazenamento de materiais combustíveis, o caso de incêndio mais gravoso. Para esta análise, comparam-se as necessidades da mistura água/espuma, para arrefecer (e eventualmente extinguir) uma ocorrência de incêndio em cada tanque do parque. Adicionalmente, a folha está preparada para calcular a necessidade de água para arrefecer tanques adjacentes, sujeitos à radiação proveniente daquele que estiver com o incêndio.

As quantidades de água e de espuma estão dependentes das características físicas dos reservatórios, como o tipo de cobertura, quer seja fixa, flutuante ou interior flutuante, como a altura e diâmetro dos mesmos e ainda o tipo de líquido que está armazenado.

PALAVRAS-CHAVE: AutoSPRINK, sistemas automáticos de extinção, gestão de espaço, fogo, segurança contra incêndio, espuma

TABLE OF CONTENTS

| | |
|---|-----------|
| ACKNOWLEDGEMENTS | v |
| ABSTRACT | vii |
| RESUMO | ix |
| LIST OF ABBREVIATIONS AND SYMBOLS | xix |
| | |
| 1 INTRODUCTION | 1 |
| 1.1 Motivation | 1 |
| 1.2 Goals | 1 |
| 1.3 Methodology | 2 |
| 1.4 Potential Conclusions | 2 |
| 1.5 Dissertation Outline | 3 |
| | |
| 2 STATE OF THE ART | 5 |
| 2.1 Fire Principals | 5 |
| 2.1.1 Introduction..... | 5 |
| 2.1.2 Fire Growth..... | 6 |
| 2.2 World Regulations | 7 |
| 2.2.1 NFPA | 7 |
| 2.2.2 Belgium Legislation..... | 8 |
| 2.2.3 Portuguese Legislation | 8 |
| 2.3 Sprinkler System | 9 |
| 2.3.1 Introduction..... | 9 |
| 2.4 Sprinkler/Nozzle | 10 |
| 2.4.1 Introduction..... | 10 |
| 2.4.2 How to select the Nozzle | 10 |
| 2.5 Piping Layout | 13 |
| 2.5.1 Introduction..... | 13 |
| 2.5.2 Requirements of an Adequate Distribution System | 14 |
| 2.6 Deluge System | 14 |
| 2.7 Relevant Concepts | 17 |
| 2.7.1 Water Spray Systems..... | 17 |
| 2.7.2 Process Units | 17 |
| 2.7.3 Greenfield and Brownfield | 17 |
| 2.7.4 Active and Passive Fire Measures..... | 18 |
| 2.7.5 Fire and Gas Detection | 18 |
| 2.7.6 Fire Brigade Access | 19 |

| | |
|--|-----------|
| 3 CASE STUDY | 21 |
| 3.1 Project Description | 21 |
| 3.2 Process Description | 22 |
| 3.3 Product Characteristics | 23 |
| 3.4 Implemented Measures | 24 |
| 3.4.1 Compartmentation | 24 |
| 3.4.2 Detection System..... | 25 |
| 3.4.3 Fire Brigade Access | 25 |
| 3.5 Above Ground (AG) Network | 25 |
| 3.5.1 General Info | 25 |
| 3.5.2 Network..... | 25 |
| 3.5.3 Manifold | 26 |
| 3.5.4 Deluge Valve House..... | 27 |
| 3.5.5 Nozzle | 29 |
| 3.6 Under Ground (UG) Network | 30 |
| 3.6.1 Hydrants and Fire Monitors..... | 31 |
| 3.7 Portuguese Legislation | 33 |
| 3.7.1 Risk Classification | 33 |
| 4 HYDRAULIC DESIGN | 37 |
| 4.1 Introduction | 37 |
| 4.2 Active Fire Protection | 37 |
| 4.2.1 Water Spray System | 38 |
| 4.2.2 ‘Worst Case’ Scenario..... | 38 |
| 4.3 Calculations | 39 |
| 4.3.1 Calculation Method | 40 |
| 4.3.2 Hydraulic Calculation Procedures..... | 43 |
| 4.3.3 Formulas..... | 44 |
| 5 Water and Foam Fire Fighting | 48 |
| 5.1 Introduction | 48 |
| 5.1.1 Storage Tanks | 49 |
| 5.1.2 Ignition Sources | 51 |
| 5.2 Fire Protection of Tanks | 53 |
| 5.2.1 Water Cooling Systems..... | 53 |
| 5.3 Foam Systems | 54 |
| 5.3.1 Top pouring systems..... | 55 |
| 5.3.2 Foam Monitors | 56 |
| 5.4 Analysis of Low Expansion System Design | 56 |
| 5.4.1 Introduction..... | 56 |

| | | |
|------------|--|-----------|
| 5.4.2 | NFPA 11 Analysis | 57 |
| 5.4.3 | Storage Tanks | 57 |
| 5.4.4 | Diked Areas..... | 57 |
| 5.5 | Fire-Water Demand Calculation Sheet | 58 |
| 5.5.1 | Introduction..... | 58 |
| 5.5.2 | Goal | 59 |
| 5.5.3 | Data Input..... | 60 |
| 5.5.4 | Calculations | 61 |
| 5.5.5 | Case Study | 64 |
| 6 | RESULTS, ANALYSIS AND DISCUSSION | 68 |
| 6.1 | Conclusions | 68 |
| 6.1.1 | AutoSPRINK | 68 |
| 6.2 | Results | 69 |
| 6.2.1 | Network Design | 69 |
| 6.2.2 | NFPA 11 Analysis | 69 |
| 6.2.3 | Calculation Sheet..... | 70 |
| 6.3 | Future Developments Perspectives..... | 70 |
| | References..... | 72 |
| | APPENDICES..... | 76 |
| | APPENDIX A – HYDRAULIC CALCULATION | 78 |
| | APPENDIX B – NFPA 11 ANALYSIS..... | 82 |
| | APPENDIX C – CALCULATION SHEET | 88 |

LIST OF FIGURES

| | |
|--|----|
| Figure 2.1 - Fire Tetrahedron (2)..... | 5 |
| Figure 2.2 - Timeline of a fire development versus typical fire service response (3) | 6 |
| Figure 2.3 - Fire Development (5) | 7 |
| Figure 2.4 - Cover of the Technical Note 16 (7)..... | 8 |
| Figure 2.5 - Main elements of a sprinkler installation (9) | 9 |
| Figure 2.6 – Three different types of sprinklers (12) | 10 |
| Figure 2.7 - Loss Prevention Standard (13)..... | 11 |
| Figure 2.8 - Correlation between the particles' velocity and diameter (14) | 12 |
| Figure 2.9 - Full cone nozzle (15) | 13 |
| Figure 2.10 - Solid cone nozzle (11) | 13 |
| Figure 2.11 – Operating scheme from a TYCO deluge valve (18)..... | 15 |
| Figure 2.12 – Deluge valve in closed position (19) | 16 |
| Figure 2.13 – Deluge valve opened and flowing (19)..... | 17 |
| Figure 2.14 – Thermal velocimetric detector | 19 |
| Figure 3.1 – View of the Churchill Industrial Zone at the Port of Antwerp (26) | 21 |
| Figure 3.2 - Overview of the Alkylation Unit | 22 |
| Figure 3.3 – Alkylation Unit | 23 |
| Figure 3.4 – Air Temperatures in Antwerp (31)..... | 25 |
| Figure 3.5 - The network on AutoSPRINK | 26 |
| Figure 3.6 – Example of a manifold with several systems attached | 26 |
| Figure 3.7 – Location of the valve house | 27 |
| Figure 3.8 – Detail of the valve house..... | 28 |
| Figure 3.9 – Overview Scheme from the valve house | 28 |
| Figure 3.10 – The nozzle used in this project's network (32)..... | 29 |
| Figure 3.11 – Type MV design spray profiles..... | 29 |
| Figure 3.12 – Overview of the underground main ring..... | 30 |
| Figure 3.13 – Combination Unit (Hydrant/Fire Monitor) at a chemical plant | 31 |
| Figure 3.14 – Example of post guards protection a hydrant | 31 |
| Figure 3.15 – Location of combination units | 32 |
| Figure 3.16 – View plant of the first level | 33 |
| Figure 4.1 – Hydraulic Settings Calculations Tab | 39 |
| Figure 4.2 – Example of a Remote Area..... | 40 |

| | |
|--|----|
| Figure 4.3 – Nozzles a) and Coverage b) Properties Tabs..... | 42 |
| Figure 4.4 - Sprinkler coverage area at all levels..... | 43 |
| Figure 5.1 - Consequences of major accidents in process engineering facilities (43)..... | 48 |
| Figure 5.2 - Example of the open-top, floating-roof tanks (45)..... | 49 |
| Figure 5.3 - Possible fire scenarios that might occur in an open-top, floating-roof tank (45)..... | 49 |
| Figure 5.4 - example of an internal, floating-roof tank (45)..... | 50 |
| Figure 5.5 - Possible fire scenarios for an internal, floating-roof tank (45)..... | 50 |
| Figure 5.6 - Typical fixed-roof tank: the fixed roof may be a cone shape or a dome shape (45)..... | 51 |
| Figure 5.7 - Possible sequence of fire scenarios for a fixed-roof tank (45)..... | 51 |
| Figure 5.8 - Buncefield tank farm fire, which occurred on the 11th December, 2005, in Hertfordshire, England (48)..... | 52 |
| Figure 5.9 - Test of fire water system on spherical LPG storage tank (49)..... | 53 |
| Figure 5.10 - Base Injection Method (51)..... | 54 |
| Figure 5.11 - Discharge outlets working in an Open top Floating Roof Tank (52)..... | 55 |
| Figure 5.12 - Firefighting foam Top Pouring System (45)..... | 55 |
| Figure 5.13 - Trailer Mounted Foam Monitor..... | 56 |
| Figure 5.14 - NFPA 11, 2016 Edition cover..... | 57 |
| Figure 5.15 – Analysis of Fire Case in Diked Areas..... | 58 |
| Figure 5.16 – Example of a Loading and Unloading Station (54)..... | 59 |
| Figure 5.17 - Rim Seal Area Demonstration..... | 64 |
| Figure 5.18 – Storage Tanks..... | 65 |

LIST OF TABLES

Table 3.1– Ethylene Oxide properties24

Table 3.2 – Propylene Oxide properties.....24

Table 3.3 - Determination of the capacities.....34

Table 3.4 – Determination of the heat density (per square meter).....34

Table 3.5 – Modified Fire Load Parameters35

Table 3.6 – Design Criteria or Water Fixed Systems36

Table 4.1 - Application rates for water spray systems38

Table 4.2 – Overview of the sprinklers' characteristics41

Table 4.3 - Conversion from US to SI units.....46

Table 4.4 – C Value Multipliers for valves and fittings46

Table 4.5 – C Value Multipliers por pipes46

Table 5.1 – Overview of the Regulations Tab60

Table 5.2 – Overview of the Tank Data filling table.....61

Table 5.3 – Foam Calculation table62

Table 5.4 – Water Calculation table63

Table 5.5 – Tank's Characteristics65

Table 6.1 – Overall Results.....69

LIST OF ABBREVIATIONS AND SYMBOLS

In this section, a list of symbols and abbreviations used in the realisation of this dissertations is presented. In some cases, the same symbol may have different meanings due to the extensive number of formulas, variables and parameters that were used. However, each symbol is usually associated with a specific subject, and it is easy to distinguish its meaning, given the context in which it is presented.

Abbreviations

| | |
|------|--------------------------------------|
| NFPA | National Fire Protection Association |
| API | American Petroleum Institute |
| EO | Ethylene Oxide |
| PO | Propylene Oxide |
| gpm | Gallons Per Minute |
| lpm | Litters Per Minute |
| psi | Pound Per Square Inch |
| MTO | Material Take Off Per Minute |

Symbols

| | |
|----------------|---|
| A | Area or cross-section |
| a | Acceleration |
| D | Diameter |
| f | Frequency |
| H | Height |
| L | Length, travel length |
| P | Pressure |
| p_a | Atmospheric pressure (reference pressure) |
| V | Volume |
| m | Meters |
| m^2 | Square meters |
| m^3 | Cubic meters |
| $x\ y\ z\ XYZ$ | Horizontal (x and y) and vertical (z) axes and directions |
| Δ | Increment, difference |

1 INTRODUCTION

1.1 MOTIVATION

Fire safety has always had a significant impact on all engineering disciplines. It affects structural, mechanical, piping, electrical, environmental, hydraulic, among others. Given the increasing intricacy, not only of buildings but of all kind of industrial processes, efficient and effective fire safety projects are required. With the increment of the complexity, new problems arise, and this is where good engineering takes a fundamental role. The search for relevant and challenging problems led me to search for an international company outside of my home country.

The main objectives were the chance be on a corporate environment, instead of an academical one, the outlook to use more sophisticated designing methods, the opportunity to live abroad and develop the capability to handle adaptation problems and the chance to work with international clients with greater projects. Being part of a renamed company like Worley België BVBA, enabled me to achieve all this. Present in more than fifty countries around the world, the firm is a leading global provider of project and asset services in the energy, chemicals and resources sectors. Worley delivers specialist services across the full spectrum of projects within six markets: new energy, power, upstream and midstream, refining and chemicals, mining, minerals and metals and infrastructures.

The group works in a diverse geographic and cultural setting, from small brownfields services contracts to major greenfield projects including offshore and onshore, oil and gas, refining and petrochemicals and pipelines. The power customer sector group provides a full range of services to all types of powerplants, including conventional sources such as coal, nuclear and gas turbine plants. They are also experts in providing services to the renewable energy sector, solar, wind, biomass and hydroelectric.

1.2 GOALS

It is important to highlight that due to the period when this dissertation was developed, some objectives for the project were changed along the way.

The initial main focus was to design, study and compare a fire protection system that was designed without a BIM software, with this proposal, that utilises a program called AutoSPRINK. Due to external motives, the hydraulic calculation files, for the comparison, were only received late in June. Therefore, it was given a bigger significance to the second objective.

The second goal of this project was the execution of the water/foam demand calculation sheet. This study will allow the fire safety engineer to quickly calculate the worst-case scenario in case of fire in a tank farm and start designing all the firefighting procedures from there. It will be possible to quickly

extract key figures that are necessary for other departments, for example, for the mechanical engineers to proceed with the design of the fire tank and fire pump.

1.3 METHODOLOGY

AutoSPRINK is a revolutionary BIM tool, highly specialised in the design and dimensioning of fire networks, namely fixed systems of automatic water extinguishing, armed fire networks, external hydrant networks and water spray extinguishing systems (with or without foam).

This tool allows not only the design and hydraulic calculation of this type of network but also the production of maps of exact quantities and adjusted to the needs of the customer, to carry out the project (prefabrication and assembly) with high precision and rigour.

It works in Windows environment, allowing direct export to BIM platform (Revit) and the creation of an IFC file. The project can also be exported to AutoCAD with 3D visualisation, if necessary.

Thanks to its total compatibility with the BIM language, it uses objects with information and physical characteristics, allowing the creation and design of a precise, intelligent and real model, through three-dimensional simulation. Components behave as physically existing, both in appearance and functionality, as well as in the interaction between them. Each component also has updated information about its existence in the market, costs, models and characteristics.

This way, the designer can have access to the information he considers relevant about the installations designed with objects, such as the hydraulic needs of the systems, behaviour reports, material lists (quantities and characteristics), work plans, assembly plans, installation costs, profit margins, among others. The design can be carried out in accordance with the NFPA Standards, or adjusted to any regulation, legislation or technical specifications.

It works through modules, added according to the user's needs, highlighting as its main feature the three-dimensional design accompanied by precise, configurable and automatic hydraulic calculation, of high performance, always associated with databases and vast libraries. Although the design and dimensioning modules are entirely adjusted to the needs of engineering and architecture, the manufacturing (Stocklisting) and budgeting (Autopricer) modules are the perfect resource for installers of fire networks and extinguishing systems.

1.4 POTENTIAL CONCLUSIONS

Given the complexity of a fire protection system, both in the hydraulic calculation and in the design, it is ideal to have one tool that allows the engineer to have a three-dimensional view, and at the same time, a quick way to calculate water flow, speeds and pressures. As we face a transitioning phase in the construction world with digitalisation, a BIM tool is the best way to design a fire protection network. There are a few options available in the market like SprinkCAD 3D, HydraCAD, and AutoSPRINK, the software chosen to use in this dissertation.

As a natural evolutionary step in the industry, Worley acquired AutoSPRINK as a successor to a previous non-BIM program used in the design of water systems for fire protection. This choice was mainly prompted by the need of to have a more precise space management tool (that was compatible with the software used for other disciplines) and to reduce mistakes, naturally made by the engineers in the design of such complex systems. It will allow the engineer to have access, in seconds, to the hydraulic

calculations, exportable drawings, Material Take Off (MTO) and to budget estimations. The main improvements are transversal to all BIM tools (1):

- Reduction of manual data entry with a greater electronic information exchange;
- Reduction and elimination of low-value and no-value tasks;
- Reduction of time spent on “defensive documentation”;
- Integration of construction cost estimating with building information modelling;
- Reorganisation of business processes to enable more tasks to occur concurrently;
- Increased prefabrication of construction assemblies;
- Implementation of direct design-to-fabrication processes;
- Implementation of efforts to achieve and maintain optimal performance of operating systems and equipment;
- Implementation of continuous learning processes to improve the quality and profitability of the operations.

As in all transitions, there are downsides, like the associated costs. First of all, the actual cost of the software. Secondly, there may be charges associated with hardware, because such a powerful program requires an equally powerful computer to run it. Also important in this case, are the technical support, maintenance and program updates that are an extra every year. In addition to all this, the engineers that will learn how to use this program will need some time. Not only do the basic training, but for full integration to get up to speed with the already well-known software in the rest of the disciplines.

1.5 DISSERTATION OUTLINE

The dissertation is organised into six chapters, presented sequentially, in which all the work that was performed is described.

In this first chapter, it is possible to find the author’s motivation as well as a brief introduction to the company where the thesis was developed. It is also presented the main goals and the basic structure of the dissertation.

Chapter two is dedicated to the presentation of the state of the art, regarding fire safety regulations and sprinklers’ technological aspects. It is discussed the lack of proper rules in the firefighting in the chemical industry and how projects are developed. It is also presented some relevant concepts related to the industry and firefighting, for a better understanding of the design of the sprinkler network.

In the third chapter, it is displayed the case study. It begins with the categorisation of the project according to the NFPA and all its measures for firefighting. It is also presented the categorization according to the Portuguese standards. Chapter four is fully dedicated to the hydraulic calculation. The used formulas are shown as well as the material characteristics used.

In the fifth chapter the reader is presented with an analysis of NFPA 11 and the different approaches regarding the different kind of tanks and liquids inside. It is also shown the second goal of the dissertation, the water and foam demand for a storage tank farm. It was developed an Excel calculation

sheet, according to NFPA's standards, that is capable to automatically give the amount of water and foam need for the worst-case fire scenario in the tank farm.

Finally, on the sixth and last chapter, conclusions were drawn regarding the use of the sprinkler software as well a brief comparison with the results achieved by the Contractor that originally design the network.

Contained in Appendix A is the entire hydraulic calculations and the stock listing, both exported from AutoSPRINK. There are also graphicly coloured pictures of the network regarding flow and speed rates.

Contained in Appendix B are the Excel tables both for the generic version as well as for the example created to illustrate a real fire scenario.

Contained in Appendix C is the full analysis of the NFPA 11 and its respective tables with the minimum application rates and discharge times, for water and foam, for each type of tank and substance.

2

STATE OF THE ART

2.1 FIRE PRINCIPALS

2.1.1 INTRODUCTION

There are three universal principals that fire safety measures aim to comply with, which are the safeguard of:

- Human life;
- Environment;
- Cultural heritage.

To be able to meet these standards, Fire Safety Project will equip the structure that will:

- Reduce the likelihood of fires;
- Limiting the development of fire occurrence and minimising its effects;
- Preventing escalation;
- Circumscribing the spread of combustion gases;
- Facilitate the evacuation and rescue of personnel at risk;
- Allow effective and safe intervention of the emergency services.




Figure 2.1 - Fire Tetrahedron (2)

Extinguishers work by creating a barrier between the fire components – fuel, heat and air – thus preventing the chemical chain reaction from happening. To disrupt the elements that form the Fire Tetrahedron and thus put out the fire, you need to do one or more of these four things (2):

- Remove fuel sources. It is a preventative measure making sure potential fire hazards are stored safely or if a fire has started you can use water to disperse the fuel sources and to cool them;
- Cool the burning materials with water;
- Exclude oxygen. For example, with a fire blanket to prevent oxygen from reaching the process.
- Break the chemical reaction. It is the chain reaction that keeps a fire going.

2.1.2 FIRE GROWTH

The knowledge of how a fire develops (Figure 2.2), over time, will certainly allow to select the most appropriate means for each case.

The development of a fire depends on numerous factors; hence no two fires are the same. For the various possible combinations between the four elements of the fire tetrahedron, in the development of a fire, several factors are conditioning factors:

- Nature and quantity of fuel present;
- Fuel distribution and presentation;
- Amount of oxidant (oxygen) available, which depends on ventilation conditions;
- The geometry of the area on fire and the dimensions of the openings;
- Characteristics of floors, walls and coverings;
- Atmospheric conditions (temperature, wind direction).




Figure 2.2 - Timeline of a fire development versus typical fire service response (3)

However, it is possible to identify certain critical phases or characteristic moments that a fire presents in its natural development. Leça Coelho (4) identifies the five phases represented in Figure 2.2, namely, the following:

- Ignition;
- Propagation;
- Widespread inflammation (flashover);
- Continuous combustion;
- Decay.




Figure 2.3 - Fire Development (5)

The effectiveness of the extinguishing means depends, in large part, on the moment in which they are used, during the process of developing a fire. If they are applied at an early stage of a fire, only light means are needed, such as a sprinkler, which is quickly triggered near the fire by temperature, a portable extinguisher or an armed fire hydrant that is easily handled by the building's occupants.

2.2 WORLD REGULATIONS

It is important to notice that there is very little legislation available for such a specific engineering field as firefighting in the chemical industry. Therefore, these kinds of projects are often done based on good engineering practices and past experiences. It is also possible to find the most complete set of guidelines in the companies' standards as they are used to the challenges presented.

2.2.1 NFPA

Even though there is not a standard saying what to implement in which case, the National Fire Protection Association (NFPA) produces trustworthy standards that started being produced more than a hundred years ago. This Association is a global self-funded non-profit organization, established in 1896, devoted to eliminating death, injury, property and economic loss due to fire, electrical and related hazards. NFPA delivers information and knowledge through more than 300 consensus codes and standards, research, training, education, outreach and advocacy; and by partnering with others who share an interest in furthering our mission. Our mission is to help save lives and reduce loss with information, knowledge and passion (6).

These set of rules indicate a possible way to design, install and test equipment with the objective of control the fire and limit its impacts to the maximum.

2.2.2 BELGIUM LEGISLATION

As in most countries, Belgium does not have a specific firefighting legislation for process units. Consequently, the project is realized in an iterative manner with the local fire brigade and the client. Insurance companies usually have their input in the project and might be more demanding on the measures taken.

2.2.3 PORTUGUESE LEGISLATION

The Technical Note 16 (7) describes all types of equipment, concepts of design, installation and maintenance of the mechanisms to be used for water extinction through fixed and automatic systems applicable in Portugal. It has as references the NFPAs, European Norms and CEA 4001 (European Insurance and Reinsurance Federation).

The Technical Note (7) presents the configurations of automatic water-based fire extinguishing systems in terms of the type of installation, the type of sprinklers (being further evaluated according to the actuation element, the discharge hole), mounting position, among others. The choice of the type of sprinklers depends on what is described in the current regulation. These depend on the risk level of the spaces to be protected, the environmental conditions, the characteristics of the building elements, products manufactured and stored, among others (8).



NOTA TÉCNICA nº 16

Complementar do Regime Jurídico de SCIE

SISTEMAS AUTOMÁTICOS DE EXTINÇÃO POR ÁGUA

OBJECTIVO

Baseado no conhecimento dos mecanismos de extinção de incêndios procura caracterizar-se um dos métodos mais utilizados – a extinção por água – através dos sistemas fixos e automáticos (SAEI-Água), descrevendo tipos de equipamentos, conceitos de projecto, instalação e manutenção.

APLICAÇÃO

Proporcionar elementos de consulta a projectistas, instaladores e entidades de fiscalização.

Figure 2.4 - Cover of the Technical Note 16 (7)

2.3 SPRINKLER SYSTEM

2.3.1 INTRODUCTION

An automatic sprinkler system is designed to detect a fire and extinguish it with water in its early stages or hold the fire in check so that extinguishment can be completed by other means.

A sprinkler system consists of a water supply (or supplies) and one or more sprinkler installations; each installation consists of a set of installation main control valves and a pipe array fitted with sprinkler heads. The sprinkler heads are fitted at specified locations at the roof or ceiling, and where necessary between racks, below shelves, and in ovens or stoves. The main elements of a typical installation are shown in Figure 2.3 (9).

The sprinklers operate at predetermined temperatures to discharge water over the affected part of the area below. The flow of water through the alarm valve initiates a fire alarm. The operating temperature is generally selected to suit ambient temperature conditions.




Figure 2.5 - Main elements of a sprinkler installation (9)

There are several system elements associated with the network. The caption is possible to find bellow.

- | | |
|---------------------------|---------------------------|
| 1. Sprinkler Head | 6. Main Distribution Pipe |
| 2. Riser | 7. Control Valve Set |
| 3. Design Point | 8. Riser |
| 4. Distribution Pipe Spur | 9. Range Pipes |
| 5. Arm Pipe | 10. Drop |

2.4 SPRINKLER/NOZZLE

2.4.1 INTRODUCTION

Water spray systems as defined in NFPA 15 (10) can provide some of the most complex and challenging system designs encountered by fire protection professionals. The selection of the proper spray nozzle that achieves the coverage area and water density required for the hazard being protected is one of the most important steps necessary to ensure the successful operation of the system. Of course, there are many other steps of equal importance and complexity that are taken during the design and layout process for water spray systems, but it is the selection of the proper spray nozzles that can present one of the largest challenges and may ultimately determine whether or not the water spray system will perform as required. Because of the wide variations in the characteristics of water spray nozzles including discharge patterns, velocities, distances of projection and the variables of the hazards being protected, a careful evaluation of the nozzle selection should be completed by a professional with an in-depth knowledge of special hazards applications and water spray system design (11).

2.4.2 HOW TO SELECT THE NOZZLE

The complexity of nozzle selection can be increased in some cases where a limited amount of technical information is available describing the specific features or proper application for the spray nozzle being considered. In other cases, confusion may result from the terminology used in a manufacturer's technical data, such as high, medium and low velocity nozzles and the term velocity's relationship to the application. Given the substantial number of hazards where spray nozzles can be applied, and the various listings and approvals granted by Underwriters Laboratory, Factory Mutual and LPCB (Loss Prevention Certification Board), the design engineer and layout technician are presented with a demanding selection process. This paper will attempt to clarify spray nozzle selection criteria for several of the most complex water spray applications and the terminology used to identify the unique characteristic of the spray nozzles (11).




Figure 2.6 – Three different types of sprinklers (12)

The selection of spray nozzles involves consideration of several factors, primarily their ability to distribute water in a manner which allows the proper mechanism of extinguishment or control for the hazard to be achieved. Spray nozzles are available in a wide range of capacities and angles. The design

elements used within the spray nozzle to manipulate the movement of water through the spray nozzle will impact the discharge velocity of the water droplets and the discharge pattern's reach or range.

The velocity of the water droplets discharged from spray nozzles is not a factor for consideration of water spray system design within NFPA 15 or 13. However, terms referencing velocity are used extensively within manufacturer's technical data and within the testing and installation standards of the Loss Prevention Certification Board (LPCB) which are used in many parts of the world. The exact meaning of this terminology and how it applies to the spray nozzle application can be confusing and at times misleading, but it can be helpful to put a definition to the terms low, medium and high velocity if for no other reason than to help the designer and layout technician gain a better understanding of the nozzle application. The only written definitions for spray nozzles that can be found within the fire protection industry commonly referenced text are within the LPCB Standard 1277 (13).




Figure 2.7 - Loss Prevention Standard (13)

LPCB Standard 1277 defines medium velocity spray nozzles as “sprayers with deflection plates producing conical discharge patterns having bores not less than 1/4 inch (6.3 mm) and meeting the test requirements of this standard apart from the fire test. These sprayers may be opened or sealed; the seal is identical to that of a sprinkler” and “sprayers with swirl chambers producing conical discharge patterns and having internal waterways not less than 1/8 inch (3.1 mm) and final exit bores not less than 1/4 inch (6.3 mm) and meeting the requirements of this standard at a pressure of 20 psi (1.4 bar) apart from the fire test” (11).

Fixed nozzles have certain velocity or pressure ranges of effectiveness. Below the lower limit of the force range, the discharge pattern is ineffective; above the upper limit, velocities may be reached that will result in decreased effectiveness due to reduction in the discharge pattern, delivery distance and/or the water droplets. At the point where a droplet of water is discharged from a nozzle, it is carried forward by its momentum, downward by the force of gravity, and is retarded by friction in the air. The forward velocity of water droplets becomes very important in the reach of the nozzle. Spray nozzles are designed to have various spray angles. The volume of water being discharged, and the spray angle of the nozzle will determine the actual velocity of the water droplets and the range of the spray.

The size and velocity of the water particles will have an impact on the ability to extinguish or control a fire, as shown in Figure 2.8. If the droplets are too small, they cannot penetrate to the seat of the fire but are carried upward by the fire plume. If they are too large, their surface-to-mass ratio is small, and they cannot effectively cool the fire gases (11).




Figure 2.8 - Correlation between the particles' velocity and diameter (14)

High and medium velocity spray nozzles cover a much broader range of application. Due to a wide range of K factors and operating pressures the water droplet size can range from the larger droplets found in the discharge of a standard sprinkler to the much smaller water droplets that would be similar to the sizes found in water mist systems. When the water pressure range is between 20 psi (1.4 bar) and 50 psi (3.5 bar) the water droplet velocity is 49 ft/sec (15 m/sec) to 82 ft/sec (25 m/sec). High and medium velocity spray nozzles are used primarily within this pressure range so it can be anticipated that the water droplet velocity may be similar to this published information for many spray nozzles (11).

Extinguishing a flammable liquid fire is possible if the flammable liquid is miscible with water, and large quantities of water can dilute the liquid to the point where it is no longer flammable and cool the liquid below its flash point; however extreme care must be taken when using this approach to ensure the container which is holding the combustible liquid does not overflow and inadvertently spread the fire. One technique that can be used to prevent this situation is to select a nozzle which discharges a fine spray with droplets less than .4mm. The fine spray will dilute and cool the surface layer of the flammable liquid limiting the amount of water introduced to the container and reducing the possibility of an

overflow. Fires involving flammable liquids that are not completely miscible with water such as ether and ketones can be controlled utilizing water spray. Low to medium velocity solid cone nozzles are well suited for this type of application (Figure 2.9) (11).



Figure 2.9 - Full cone nozzle (15)

When being used to suppress flammable liquid fires with high flash points above 200°F, the water droplets must be traveling at a velocity sufficient to penetrate the surface of the flammable liquid. Fires involving combustible liquids with flash points above 200°F that are not miscible with water such as lubricating oil, can be suppressed using high velocity solid cone nozzles (Figure 2.10). When the water is discharged with a velocity that is sufficient to penetrate the surface of the combustible liquid, suppression is achieved by cooling the surface below the liquid's flash point (11).



Figure 2.10 - Solid cone nozzle (11)

2.5 PIPING LAYOUT

2.5.1 INTRODUCTION

Piping Network is a system of pipes and trenches which provide the appropriate quality and quantity of water to a community. The design, construction and layout of the piping network have to be carefully prepared in order to ensure that there is enough flow pressure to supply hygienically safe water. Once the network is constructed, its maintenance has to be performed, which includes repairs, leakage control, prevention of recontamination, among others.

2.5.2 REQUIREMENTS OF AN ADEQUATE DISTRIBUTION SYSTEM

For an adequate water distribution system, the requirements are as follows (16):

- Water quality should not deteriorate while flowing through the distribution pipes.
- The system should be capable of supplying water to all the intended places with sufficient pressure head.
- It should be capable of supplying the required amount of water during firefighting.
- The layout should be such that no consumer is without water supply, during the repair of any section of the system. 6. It should be fairly watertight to minimize losses due to leakage.

The design of water distribution for firefighting consists of the following main steps: preliminary studies, design phases, network layout and hydraulic analysis (16).

- 1- Preliminary Studies: This is the first and the most important step in the designing of water distribution system. Before any design work can commence, thorough observations and studies have to be carried out;
- 2- Design Phases: After the preliminary studies are performed, the next step is setting the Design Criteria. This step involves setting the required design limitations/parameters that are required to get the most effective and economical water-distribution in the chosen network. The required limitations/parameters can be determined on the basis of factors as hazard classification, demand, pressure, flow, pipe size, head loss and spacing;
- 3- Network Layout: After the design criteria is determined, the next step is to choose a suitable pipe network layout and to estimate pipe sizes on the basis of water demand and local code requirements. The pipes are then drawn on a digital map, starting from the water source. All the components i.e. pipes, valves, fire hydrants, etc. of the water network should be shown on the lines. These layouts are used by project executers (contractors) for implementation (installation);
- 4- Hydraulic Analysis (Of Distribution Systems): After the suitable type of pipe layout is chosen, the next and final step involves the analysis of the chosen layout. This involves calculating the flow rate, supplied water pressure, volume, losses, etc. The calculation process is done using hydraulic analysis software like AutoSPRINK or others described in the previous chapter (16)).

2.6 DELUGE SYSTEM

According to NFPA 13 (17), a deluge system is a sprinkler system employing open sprinklers or nozzles that are attached to a piping system that is connected to a water supply through a valve that is opened by the operation of a detection system installed in the same areas as the sprinklers or the nozzles. When this valve opens, water flows into the piping system and discharges from all sprinklers or nozzles attached thereto

Deluge-type systems are similar to dry-type systems; however, sprinklers are permanently open, with no metal fuses or glass bulbs, and the piping is completely empty downstream of the checkpoint. These systems are generally used in situations with special fire risks, where it is necessary, simultaneously, a dry type system and a fast action, over the entire protected area, in order to avoid the fire propagation as much as possible.

The discharge time, since the opening of the flood valve, should not exceed 60 s, considering the same requirement for dry type systems. The separation valve between the laden pipeline and the empty pipeline is called the flood valve and is placed at the checkpoint.

The opening of the deluge valve requires a complementary automatic detection and activation system, which allows the activation of the sprinkler system, to be faster than in the dry type systems, eliminating the need to install the opening accelerator device.

The deluge type automatic extinguishing systems have the schematic configuration shown in Figure 2.8 and are composed from the following main elements:

- Checkpoint with check valve and alarm (composed of a flood or flood check valve and connection to the alarm system);
- Alarm system (composed of a local alarm teller and an alarm pressure switch);
- Local alarm teller (composed of hydraulic motor and alarm bell);
- Alarm pressure switch (to report the alarm to the firefighters after system activation sprinklers);
- Test circuit (including drainage piping).




Figure 2.11 – Operating scheme from a TYCO deluge valve (18)

There are several system components. The caption is possible to find bellow.

1. Deluge Valve
2. Main Control Valve
3. Diaphragm Chamber Supply Control Valve
4. Local Manual Control System
5. Automatic Sprinklers
6. Wet Pilot Line Sprinklers (Fire Detection)
7. Water Supply Pressure Gauge
8. Diaphragm Chamber Pressure Gauge
9. Main Drain Valve
10. Diaphragm Chamber Automatic Shut-Off Valve
11. Waterflow Pressure Alarm Switch
12. Water Motor Alarm
13. Riser Check Valve
14. Supervisory Air Check Gauge
15. Automatic Supervisory Air/Nitrogen Supply
16. Supervisory Low-Pressure Alarm Switch
17. System Drain Valve

The opening of the check valve is achieved through an auxiliary activation system, which can be:

- Hydraulic (pneumatic actuator, with pilot piping filled with water, associated with fast acting sprinklers);
- Pneumatic (pneumatic actuator, with the pilot piping filled with compressed air, or pressurized inert gas, associated with fast-acting sprinklers);
- Electric (solenoid valve, with electrical piping, associated with electric fire detectors).

In order for the check valve to remain in the closed position (Figure 2.12), the valve sealing diaphragm is positioned in a chamber, which has a bypass, coming from the water supply branch, being pressurized and in hydraulic balance with the water supply circuit.




Figure 2.12 – Deluge valve in closed position (19)

The system is filled so that the diaphragm chamber is filled first (Figure 2.13), and then the manual shut-off valve on the system is opened, the system is armed and ready for use.




Figure 2.13 – Deluge valve opened and flowing (19)

The deluge valve opens when the auxiliary fire detection system is activated and promotes the opening of an automatic shut-off valve, which leads to the emptying of the diaphragm chamber. Immediately after opening the deluge valve, the dry tubing is flooded, and water is discharged by all open type sprinklers.

2.7 RELEVANT CONCEPTS

2.7.1 WATER SPRAY SYSTEMS

An automatic or manually actuated fixed pipe system connected to a water supply and equipped with water spray nozzles designed to provide a specific water discharge and distribution over the protected surfaces or area (20).

2.7.2 PROCESS UNITS

Process unit means the equipment assembled and connected by pipes and ducts to process raw materials and to manufacture either a final or intermediate product used in the onsite production of other products. The process unit also includes the purification of recovered by products (21).

2.7.3 GREENFIELD AND BROWNFIELD

That is term used in construction and development to reference land that has never been used, where there was no need to demolish or rebuild any existing structures (22)

2.7.4 ACTIVE AND PASSIVE FIRE MEASURES

There are two kinds of measures to take into account regarding safety, and they are grouped into active and passive measures. Active fire protection includes automatic fire detection and fire suppression systems, while the passive fire protection's main purpose is to attempt to contain fires or slower their spread (23)

The realisation of the importance of these measures is increasing every year. Oil & gas industry accounted for 24.8% of the global share in 2018 on account of the prevalence of high-risk environment owing to the presence of flammable and explosive compounds at the facilities. Passive fire protection systems have gained significant importance in the oil & gas industry as they help prevent structural damages (24).

Some of the passive measures adopted in this kind of projects are:

- Imposition of suitable fire resistance of structural elements of the structure in order to guarantee stability during a fire occurrence;
- Use of materials with the appropriate classes of heat reaction, like ceilings and floors, so as not to be inappropriately flammable or combustible;
- Fire compartmentalisation (achieved with distance block fields);
- Sleeves in the most critical fire-water sections of pipping.

Active measures adopted explicitly in the building under study were as follows:

- Installation of a detection system and fire alarm;
- Installation of an emergency lighting system and escape routing signalling;
- Installation of an automatic fire protection system;
- Placement of portable fire extinguishers;
- Installation of outdoor combined units to ensure supply and readiness of emergency services.

2.7.5 FIRE AND GAS DETECTION

An automatic fire detection system aims at the early detection of a hazard so that people can be alerted, and proper action can be initiated. It senses the presence of fire, smoke or heat and activates a fire suppression system and/or an automatic alarm system (20). Upon detection, it shall initiate one or more of the following actions:

- Give a local alarm signal and an alarm signal to the control room;
- Activate the emergency shutdown system in the affected zone and adjacent zones;
- Activate the water spray system in the areas where protection by water sprays is foreseen;
- To avoid false alarms, special attention should be given to reliability. Therefore 2 out of 3 systems are recommended.



Figure 2.14 – Thermal velocimetric detector

Regarding the activation, water spray systems can be activated by:

- Pilot system;
- Manually locally;
- Manually in the control room;
- Via gas detection (requires simultaneous activation of more than one detector).

2.7.6 FIRE BRIGADE ACCESS

Some specific requirements must be fulfilled by the owner of the plant. The owner is responsible for the following requirements:

- The width of the road should be at least 6 m;
- The maximum slope must be 6%;
- The turning radius had to be at least 11 m at the inside and at least 15 m at the outside;
- The bearing capacity so that the vehicles with a maximum weight of 13 tons can drive and stand still without sinking, even when they deform the terrain.

3 CASE STUDY

3.1 PROJECT DESCRIPTION

This chapter presents the practical application of a water spray fixed system for fire protection of a new alkylation unit. It is possible to define the alkylation reaction is the introduction of an alkyl group into an organic compound by substitution or addition in which a hydrogen atom is converted to an alky group can be considered an addition reaction. The greatest use of the alkylation process is in refineries for the production of alkylates that are used as a blending stock to produce gasoline (25).

For confidentiality reasons the name of the client will not be revealed, as well as the exact location of the project, however, for design purposes, it is known to be on the industrial area of Antwerp.



Figure 3.1 – View of the Churchill Industrial Zone at the Port of Antwerp (26)

The project was built on a greenfield and it includes a metal structure for the process unit, a loading and unloading stations and a tank farm. Flammables will be only present in the treatment section, so that is the area that will be on the author's case study.




Figure 3.2 - Overview of the Alkylation Unit

The structure, represented as the blue construction on the right-hand side of the Figure 3.2, will have a ground floor, plus four other accessible levels, being the height of the last floor 20,30 meters. Regarding the plan view, the structure occupies 180 m².

3.2 PROCESS DESCRIPTION

The process unit contains three sections:

1. Pre-treatment
2. Reaction
3. Post-treatment

In the pre-treatment section, starter product will be heated, catalysed and dried, above the flashpoint. In the reactor, this starter will react with ethylene oxide or propylene oxide to heavy polymers. It is an exothermic reaction where the heat will be extracted via an air-cooled high pressure. In the post-treatment system, the end product will be conditioned for storage. The end products are heavy polymers with high flashpoint. These products will be handled below flashpoint.




Figure 3.3 – Alkylation Unit

The process department identified the worst possible scenarios as loss of cooling or loss of circulation. Both these events can trigger a runaway reaction that is typically characterised by an exponential increase of the temperature inside the vessel so that the rate of heat generation becomes faster than the rate of heat removal/loss, with a consequent accumulation of heat and acceleration of the reaction rate (27).

3.3 PRODUCT CHARACTERISTICS

Fire risk assessment is the evaluation of the relative danger of the start and spread of fire; the generation of smoke, gases, or toxic fumes; and the possibility of explosion or other occurrence endangering the lives and safety of personnel or causing significant damage to property (28).

As mentioned before, the reaction system will be using two highly flammable products, ethylene oxide (EO) or propylene oxide (PO), as catalysts for the alkylation. The products characteristics are given below in Table 3.1 (29) and Table 3.2 (30).

There is an important property, which is the amount of heat released, in kJ/kg, that will be used later in the analysis according to the Portuguese Regulations. It is when a substance is completely oxidised to yield stable end products, including water as a vapour, as measured using an oxygen bomb calorimeter (20).

Table 3.1– Ethylene Oxide properties

| Property | Value | Unit |
|---------------------------|------------|--------|
| Density | 882 @ 20°C | kg/mol |
| Flash Point | -18 | °C |
| Melting Point | -112.5 | °C |
| Boiling Point | 10.5 | °C |
| Auto Ignition Temperature | 429 | °C |
| Relative Vapor Density | 1.5 | - |
| Molecular Weight | 44.05 | g/mol |
| Heat of Combustion | -29,076 | kJ/kg |

Table 3.2 – Propylene Oxide properties

| Property | Value | Unit |
|---------------------------|------------|--------|
| Density | 882 @ 20°C | kg/mol |
| Flash Point | -37 | °C |
| Melting Point | -112 | °C |
| Boiling Point | 34.2 | °C |
| Auto Ignition Temperature | 449 | °C |
| Relative Vapor Density | 2.0 | - |
| Molecular Weight | 58.08 | g/mol |
| Heat of Combustion | -33,035 | kJ/kg |

It is possible to observe that these products are extremely flammable liquefied gases because of their low boiling point and flashpoint. They can also burn without air since they furnish their own oxygen (29). It is furthermore worth to mention that EO is highly toxic (29). This is an additional reason to install a water spray system on every possible leak of these products.

3.4 IMPLEMENTED MEASURES

3.4.1 COMPARTMENTATION

Compartmentation, similar to the one done in buildings, does not make sense in this kind of structure. It is then accomplished by distance according to Heat Radiation analysis. It is also not considered the possibility of another fire occurrence in an adjacent field, as a likely or credible scenario. Block field separation generates safe distances. Portable extinguishers are present in the structure in case a small fire is detected by a field worker.

3.4.2 DETECTION SYSTEM

The fire detection system, including activation of the deluge valves (electrically or pneumatically), alarm and communication strategy, was designed by the firefighting contractor in compliance with the existing system of the client. The fire detection system consists of pilot lines with thermo-velocimetric detectors.

3.4.3 FIRE BRIGADE ACCESS

Access to the alkylation unit is possible by two different fire brigades although there is a proper fire crew at the Port of Antwerp there is well equipped and trained to deal with industrial hazards.

3.5 ABOVE GROUND (AG) NETWORK

3.5.1 GENERAL INFO

Bearing in mind that the temperatures in Antwerp will certainly drop below 4 degree Celsius, especially between November and March, (see Figure 3.4 below), dry systems will be used in all above-ground structures, water spray network and in the hydrants.




Figure 3.4 – Air Temperatures in Antwerp (31)

3.5.2 NETWORK

The water spray system, in Figure 3.5 bellow, was designed in full compliance with NFPA 15. For each area, a fixed water spray system that fulfils the described duty was designed, supplied and installed by the Contractor. The fixed water spray system for the entire equipment area is a pilot operated system. Meaning a standard spray sprinkler or thermostatic fixed temperature release devices used as detectors to pneumatically or hydraulically release the main valve, controlling the flow of water into a fire protection system (20).




Figure 3.5 - The network on AutoSPRINK

3.5.3 MANIFOLD

The manifold, an assembly of pipe and fittings for connecting two or more cylinders for the purpose of supplying water to a piping system or directly to a consuming device (20), with all outlets and valves will be installed in a deluge house.



Figure 3.6 – Example of a manifold with several systems attached

The following minimum design criteria will be met for the manifold:

- The deluge system shall be activated automatically. It shall also be capable of being activated remotely from the control room or locally via manual override;
- All valves will have position supervision and pressure switches with indication on the fire control system and will have a block valve downstream and a drainage connection to allow testing of the valve;
- The electrical valves require the possibility for manual operation in case of electrical failure;
- Manual valves to isolate and/or test the system shall be provided (Figure 3.8):
 - One valve on the common fire water pipe;
 - Two valves on the system: 1 upstream and one downstream of deluge valve;
- All necessary drains and test connections shall be provided.

3.5.4 DELUGE VALVE HOUSE

The location of the deluge house should be proximate to the structure, as shown in the following figure. It shall contain a deluge valve, that will activate and allow the water to flow into the network and two section valves to permit maintenance work to be performed on both sides of the underground ring, as shown in the valve scheme in Figure 3.8.




Figure 3.7 – Location of the valve house

The deluge house (represented in Figure 3.8 in an AutoSPRINK drawing and in Figure 3.9 as a scheme) shall meet the following minimum criteria:

- Constructed according to good practice and legal requirements from Energy Performance Building Regulations (EPB);
- Equipped with electrical heating and lighting;
- Door will be located on the north side (for heat radiation purposes).




Figure 3.8 – Detail of the valve house




Figure 3.9 – Overview Scheme from the valve house

3.5.5 NOZZLE

The Contactor opted by a nozzle from Tyco – Fire Protection Products, type MV nozzle that are open (non-automatic) directional spray nozzles designed for use in water spray fixed systems for fire protection applications. They are external deflector-type nozzles that discharge a uniformly filled cone of medium velocity water droplets (32).




Figure 3.10 – The nozzle used in this project’s network (32)

3.5.5.1 Placement

Where direct impingement of water spray onto all of the protected surface is required by the authority having jurisdiction, TYCO Type MV Nozzles are to be spaced and directed so that their spray patterns will completely cover the plane-of-protection with the minimum required average density. However, it is recommended that indoor nozzle spacing be 3,7 m (12 ft) or less and that outdoor nozzle spacing be 3,0 m (10 ft) or less (32).

3.5.5.2 Spray Pattern

The Design Spray Profiles for nozzle spray angles of 90 to 160 degrees are shown in the Figure 3.11 and apply to discharge pressures of 1,4 to 4,1 bar. Discharge pressures in excess of 4,1 bar will result in a decrease in coverage area since the spray patterns tend to draw inwards at higher pressures (32).




Figure 3.11 – Type MV design spray profiles

3.6 UNDER GROUND (UG) NETWORK

A ring-type fire water underground main is installed in the plant (Figure 3.11). A new loop extending the existing underground fire water main will be installed by the Contractor, connecting the new unit, the loading and unloading area and the storage tank area. The use of loops smaller than 8” (200 mm) is not recommended as per NFPA 24 (33) the pipe supplying hydrants shall not be smaller than 6” (152 mm).

Glass fiber reinforced piping with vinyl ester resins will be used for underground fire-water piping (34). When installing the glass-reinforced epoxy (GRE) and where traffic can negatively impact (e.g. at road crossings) regarding the routing proposed, the Contractor shall provide sleeve pipes to protect the fire-water pipes.




Figure 3.12 – Overview of the underground main ring

3.6.1 HYDRANTS AND FIRE MONITORS

The fire main was equipped with above ground combination units (hydrant/fire monitor as shown in Figure 3.12) located at regular intervals around the chemical plant. The minimum flow required per combination unit is 2000 L/min (35). The proposal shall include four units as a minimum so that the entire structure gets overlapped coverage.



Figure 3.13 – Combination Unit (Hydrant/Fire Monitor) at a chemical plant

The hydrants will be installed in such a way that (Figure 3.13):

- They are unobstructed (within one meter in radius), marked and accessible by emergency response personnel;
- The heat radiation from the fire to be addressed is less than 3 kW/m² at the hydrant;
- A breakaway coupling must be a part of the hydrant;
- The hydrant must be equipped with two 70 mm bronze gate valves with attached 70 mm DSP coupling, with cover and with one 110 mm AR coupling with cover.

Where hydrants/fire monitors and the post indicators of the isolation valves are vulnerable to mechanical damage, they shall be protected with high visibility bollards (Figure 3.13).



Figure 3.14 – Example of post guards protection a hydrant




Figure 3.15 – Location of combination units

Hydrants were placed in sufficient number around the storage tank area and the loading and unloading area to provide water spray coverage around the full periphery (Figure 3.14), from at least two directions as per Client regulations.

3.7 PORTUGUESE LEGISLATION

3.7.1 RISK CLASSIFICATION

3.7.1.1 Standard Utilisation (SU)

According to the Portuguese “Legal Regulations for Safety Against Fires in Buildings and Open Spaces” (36), this structure fits in the Standard Utilisation XII, named Industries and Warehouses. It is now imperative to take notice that, for this evaluation, this dissertation’s project is not about a building, but about an open structure (Figure 3.15). The entire design process changes thanks to this fact.

Portuguese legislation takes into account, that open spaces have naturally different conditions, and apply softer evaluations. The risk assessment shifts from evaluation two parameters: Modified Fire Load and Number of Stores Occupied above the Reference Level to just the Modified Fire Load (which gets multiplied by two).




Figure 3.16 – View plant of the first level

In the next table, it was determined the capacities of the three tanks from the alkylation unit. Tank number two and number three are both composed by a main cylinder shell with a bottom part of a conical shape. Tank number one, the pre-treatment section, is also composed by the cylinder but the bottom part is part spherical.

Table 3.3 - Determination of the capacities

| Tank 1 | Tank 2 | Tank 3 |
|--|--|--|
| <p>D = 3.2m H = 7.0m h1 = 1.0m</p> | <p>D = 3.2m H = 7.0m h2 = 2.0m</p> | <p>D = 3.2m H = 7.0m h2 = 2.0m</p> |
| $VT1 = V_{cylinder} + \frac{1}{3} V_{sphere}$ | $VT2 = V_{cylinder} + V_{cone}$ | $VT3 = V_{cylinder} + V_{cone}$ |
| $VT1 = \frac{D^2 * \pi}{4} * H + \frac{1}{3} * \left(\frac{4}{3} * \pi * r^3 \right)$ | $VT2 = \frac{D^2 * \pi}{4} * H + \left(\frac{1}{3} * \pi * r^2 * h2 \right)$ | $VT3 = \frac{D^2 * \pi}{4} * H + \left(\frac{1}{3} * \pi * r^2 * h2 \right)$ |
| $VT1 = \frac{3.2^2 * \pi}{4} * 7 + \frac{1}{3} * \left(\frac{4}{3} * \pi * 1.6^3 \right)$ | $VT2 = \frac{3.2^2 * \pi}{4} * 7 + \left(\frac{1}{3} * \pi * 1.6^2 * 2 \right)$ | $VT3 = \frac{3.2^2 * \pi}{4} * 7 + \left(\frac{1}{3} * \pi * 1.6^2 * 2 \right)$ |
| VT1 = 62 m³ | VT2 = 62 m³ | VT3 = 62 m³ |

It was considered that the bottom part of Tank 1 was a third of a sphere, confirmed later by the capacity calculation of the three tanks, that is naturally the same.

Table 3.4 – Determination of the heat density (per square meter)

| CHARACTERISTICS | Units | Ethylene Oxide (EO) | Propylene Oxide (PO) |
|-----------------------|-------------------|--------------------------------------|--------------------------------------|
| Density | kg/m ³ | 882 | 882 |
| Heat of Combustion | kJ/kg | -29 076 | -33 035 |
| Total Volume | m ³ | 3 x 62 = 186 | 3 x 62 = 186 |
| Total Weight | Kg | 186 x 882 = 164 052 | 186 x 882 = 164 052 |
| Heat Release | kJ | -29 076 x 164 052 = 4 769 975 952 | -33 035 x 164 052 = 5 419 457 820 |
| Heat Per Square Meter | MJ/m ² | 4 769 975 952 / 180 = 26 500 | 5 419 457 820 / 180 = 30 108 |

Portuguese regulations have slightly different approaches for activities inherent to SU XI and XII, regarding the fact of being in storage or not. The modified fire load density (q_s), in MJ / m², was calculated following Dispatch No. 2074/2009 of January 15 (36) according to the following formula:

$$q_s = \frac{\sum_{i=1}^{i=N_{ai}} q_{si} \cdot S_i \cdot C_i \cdot R_{ai}}{\sum_{i=1}^{i=N_{ai}} S_i} \quad (\text{MJ/m}^2) \quad (3.1)$$

In which:

q_{si} = density of fire load relative to the type of activity (i), in MJ / m² (previously calculated);

S_i = area assigned to the activity zone (i), in m²;

C_i = is the combustibility coefficient, relative to the combustible material in storage area i, dimensionless, whose value depends on the combustibility risk of the material in question, taking the value of 1.60, 1.30 or 1.00, depending on the risk is high, medium, or low, respectively;

R_{ai} = is the activation coefficient, relative to the combustible material in storage area i, dimensionless, whose value depends on the risk of activation of the material in question, taking the value of 3.00, 1.50 or 1.00, depending on the risk is high, medium, or low, respectively

In this case, as the entire structure is dedicated to the same activity there is no need to calculate the S_i parameter.

As it is possible to observe in Table 3.3, the presence of Propylene Oxide will be the worst-case scenario in case of a fire, therefore, to determine the structure's risk category, a fire load density of 30 108 MJ/m² will be used.

Thus, the density of the modified fire load in the structure was determined, taking into account the following data:

Table 3.5 – Modified Fire Load Parameters

| Parameter | Description | Value | Unit |
|-----------|----------------------------|------------------|---------------------------|
| q_{si} | Fire load density | 30,108 | MJ / m ² |
| S_i | Area assigned | 180 | m ² |
| C_i | Combustibility coefficient | 1.6 | - |
| R_{ai} | Activation coefficient | 3.0 | - |
| q_s | Modified Fire Load | 144,518.4 | MJ / m² |

From this data results a modified fire load of 144,518.4 MJ/m² as seen in the Table 3.4. Comparing with the limit values of table X of RJ-SCIE [1], it appears that the structure in study falls into the 4th risk category, due to the fact that the modified load density of the fire is greater than 30,000 MJ/m².

3.7.1.2 Measures

According to the Technical Note 16 (37), SU XII structures under the 2nd, 3rd or 4th risk category will need Automatic Fire Extinction Systems (AFES), by water, meaning the use of sprinklers. Also, in case of presence of liquid or flammable gases.

Thus, in this project’s case, the regulations demand as minimum design criteria (Table 3.6):

Table 3.6 – Design Criteria or Water Fixed Systems

| Standard Utilization | Density [l/min/m ²] | Area of Operation [m ²] | Number of Nozzles Working Simultaneously | Calibre of the nozzle [mm] | Discharge Time [min] |
|----------------------|---------------------------------|-------------------------------------|--|----------------------------|----------------------|
| XII | 10 | 260 | 29 | 20 | 90 |

With these characteristics it is possible to conclude that most aspects of the network design would need to be changed. First of all, the area of operation is only 260m². As the process unit’s structure is composed by three levels of 180 m² each, three sprinkler checkpoints would need to be activated. Secondly, the maximum number of nozzles working simultaneously is just 29, therefore that might be the need of breaking up the network again in smaller networks. Finally, NFPA 15 refers one hour as the minimum discharge time applicable as in the Technical Note 16, for SU XII, ninety minutes is advised. One aspect that remains similar is the discharge rate of 10 l/min/m² compared to the 10.2 l/min/m² the American standard recommends.

4

HYDRAULIC DESIGN

4.1 INTRODUCTION

A project for the execution of a water fire extinguishing network (BIM sprinkler system design) consists of:

- Realistic and specific designed parts and construction details;
- 2D and 3D BIM Modelling - Network layout, location and design characteristics of all its components;
- Maps of quantities and/or cost planning - List of components and characteristics of the piping and accessories;
- Definition and characterisation of the fire pumping group;
- Hydraulic system simulation - Calculation of all Sprinkler networks.

To obtain a high-quality sprinkler network design, the engineer can adopt several strategies being the most common one the following:

- 1- Identify Hazard Category;
- 2- Determine Sprinkler Spacing;
- 3- Determine Piping Arrangement;
- 4- Calculate amount of water needed per sprinkler;
- 5- Calculate number and location of open sprinklers in the hydraulically most demanding area;
- 6- Start at the most remote sprinkler and work towards the water supply calculating flows and pressures;
- 7- Compare demand with supply.

4.2 ACTIVE FIRE PROTECTION

The protection concept is based on a combination of measures:

- Active fire protection systems, connected to the underground fire water network:
 - Hydrants and fire monitors;
 - Fixed water spray systems (stage four of Figure 4.1);
 - Mobile firefighting (design by the client).
- Fire and gas detection and alarm system.

4.2.1 WATER SPRAY SYSTEM

According to the standard in use, open water spray nozzles shall be used. The selection of the type and size of spray nozzles shall be made with proper consideration given to such factors as discharge characteristics, physical character of the hazard involved, ambient conditions, material likely to be burning, and the design objectives of the system (10).

Water spray nozzles shall be permitted to be placed in any position, within their listing limitations, necessary to obtain proper coverage of the protected area. The positioning of water spray nozzles shall include an evaluation of all the following factors (38):

- The shape and size of the area to be protected;
- The nozzle design and characteristics of the water spray pattern to be produced;
- The effect of wind and fire draft on very small drop sizes or on large drop sizes with little initial velocity;
- The potential to miss the target surface and increase water wastage;
- The effects of nozzle orientation on coverage characteristics;
- The potential for mechanical damage.

The design of the water spray system and the application rate will depend on the fire risk. For areas with a lower risk of fire, an application rate of 10.2 L/min.m² will be assigned (10)). The main design parameters are summarised in Table 4.1.

Table 4.1 - Application rates for water spray systems

| Area | Water Spray System | Application Rate [(L/min)/m ²] | Discharge Time (minutes) |
|--------------|--------------------|---|-----------------------------|
| Modular Unit | At all levels | 10.2 | 60 |
| Pipe Rack | At all levels | 10.2 | 60 |

On the modular unit, the protection will be used as well to avoid a toxic cloud escape, and therefore the design shall be to cover the entire equipment. For the pipe rack, the flanges will be protected by a water spray system activated by a single deluge valve.

4.2.2 'WORST CASE' SCENARIO

To determine the maximum water capacity, the 'worst case' scenario has to be identified. For the 'worst case' it is considered that when a fire in the modular unit occurs, the water spray system of the three levels will be activated simultaneously to avoid toxic cloud release and apply water cooling over the entire equipment surface.

To determine the maximum fire water demand, the following protection systems are taken into account:

- Water spray system of the modular unit + pipe rack (in accordance with the standard, the maximum discharge from a deluge system should not be greater than 11355 l/min (39));
- Additional operation of two hydrants/monitors (120 m³/h per monitor).

4.3 CALCULATIONS

The Calculator tab (Figure 4.1) is divided into several dialogue boxes, each containing options for defining the hydraulic calculation method, sprinkler pressure minimum, maximum velocity pressure, hydraulic elevation datum, and riser tag counting method (40).




Figure 4.1 – Hydraulic Settings Calculations Tab

The Hydraulic Calculations dialogue features four tabs (Calculator, Fittings, Node Tags and Manually Flowing) with adjustable characteristics for the Calculation Method, Sprinkler Pressure, Hydraulic Loss at Fittings, Node Tag placement and individual definitions for manually flowing. Changing any of the options on these pages will force a regeneration of the Hydraulic data for the reports. See the topics for each individual page for more information [adapted from (40)].

According to NFPA 15 8.1.2, the minimum operating pressure of any nozzle protecting outdoor hazards shall be 20 psi (1.4 bar) (41). Due to a long experience in the field and designing this kind of networks, the Contractor opted to use as minimum pressure 1.8 bar instead of the 1.4 bar.

4.3.1 CALCULATION METHOD

AutoSPRINK allows the use of two hydraulic calculation methods: Hazen-Williams and Darcy-Weisbach. Hazen-Williams is the default choice; however, if anything other than water at normal temperature is to be used in the drawing, Darcy-Weisbach must be used. When this calculation method is first selected, it will default to calculate the system as if it was water at normal temperature (40). It is important that if there is a fluid used, that is different from water the designer show go to Fluid/Antifreeze Properties tab and configure according to the properties of the liquid.

By default, the first calculation method option is selected: Satisfy minimum demand at the most remote sprinkler. If desired, either of two last options that define the pressure at the water supply can be chosen. In either case, users must insert the pressure amount or percentage of pressure below the available supply. Four decimal digit-accuracy is an editable field should users need fewer (or more) digits of accuracy. By default, the last option is selected, which will calculate live hydraulic flows while drawing or dragging Remote Areas in the drawing (40).

In the Figure 4.2 below, it is possible to see one of the first remote areas being drawn on the first level of sprinklers. It was a test done on a very early design period. On the top left-hand side corner, it is possible to see a live system demand graph forming, while the red rectangle, the Remote Area, is being dragged downwards.




Figure 4.2 – Example of a Remote Area

Using the Darcy-Weisbach calculation method will automatically adjust all sprinklers’ K-factors according to what is necessary to keep the correct pressure per the calculations. This change, however, is not visible in sprinklers’ properties. It is only visible in the Analysis Reports (40).

When calculating the demand on the water supply, the user should specify the minimum flowing nozzle pressure in the field (1.8 bar in this case).

The option of choosing, whether or not, to include velocity pressure in Hydraulic Calculations is from the user. If so, the maximum velocity and maximum underground velocity has to be set. As in this case, it was not possible to get this information, velocity pressure was not considered in the calculations.

If desired, the user-specified elevation value can be added to each node tag and will be calculated in the Hydraulic Reports. By default, it is set at zero elevation, so, unless adjusted, will remain at zero elevation for the reports (40).


4.3.1.1 Relevant Design Characteristics

Before running the hydraulics calculations, there are still some parameters that have to be set. The nozzle characteristics inputted was based on the information available from the Contractor.


Table 4.2 – Overview of the sprinklers’ characteristics

| Characteristic | Input | Units |
|----------------------|-----------|-------------|
| Device Type | Sprinkler | - |
| Orientation | Open | - |
| Temperature | N/A | °C |
| Finish | Brass | - |
| Thread Size | 15 | Millimetres |
| Head Length | 81 | Millimetres |
| Head Diameter | 203 | Millimetres |
| K Factor Sprinkler 1 | 28.8 | Kbar |
| K Factor Sprinkler 2 | 31.7 | Kbar |
| K Factor Sprinkler 3 | 36.0 | Kbar |

In the next two images, Figure 4.3 a) and Figure 4.3 b), it is possible to see the menus where the user is able to decide and later change sprinkler’s properties. Among these definitions, the designer is able to change all the existing characteristics such as type of nozzle, orientation, response and K factor. This information is based on a limited number of manufactures that have uploaded their catalogue into AutoSPRINK. Like in this case, the materials that the Contractor used were not present at the database, the software lets the user overwrite all values.



a)



b)

Figure 4.3 – Nozzles a) and Coverage b) Properties Tabs




Figure 4.4 - Sprinkler coverage area at all levels

As it is possible to see in Figure 4.4 above, there are no blind spots regarding water coverage by the three levels of the sprinkler network.

4.3.2 HYDRAULIC CALCULATION PROCEDURES

According to NFPA 15, sub chapter 8.3, hydraulic calculations shall be prepared on forms that include a summary sheet, detailed worksheet, and a graph sheet. The summary sheet (is it possible to find an example in Annex B of the standard) shall contain all of the following information where applicable:

- The date;
- The location;
- The name of the owner and occupant;
- The building or plant number;
- A description of the hazard;
- The name and address of the contractor and calculator;
- The name of the authority having jurisdiction;
- The design purpose;
- The rates of the water application (density) and applied areas in $L/min/m^2$;
- The total system water requirements as calculated, including allowance for hose streams;
- The total designed water demand with number of systems designed to operate simultaneously at a reference point, preferably the source of supply, including hose streams and other fire protection equipment;
- Water supply information.

The Detailed worksheets or computer printout sheets (for sample worksheet, consult Annex B of the present standard), shall contain all of the following information:

- Sheet number, date, job number, and identification of calculations covered;
- Description of discharge constant (K) (or provide the discharge curve or tabulation) for each nozzle type;
- Hydraulic reference points;
- Flow in gpm (L/min);
- Pipe size in in. (mm);
- Pipe lengths, center to center of fittings (or cut lengths) in ft (m);
- Equivalent pipe lengths for fittings and devices in ft (m);
- Friction loss in psi (bar) between reference points;
- Total friction loss in psi (bar) between reference points;
- Elevation head in psi (bar) between reference points;
- Required pressure in psi (bar) at each reference point;
- Velocity pressure and normal pressure if included in calculations;
- Notes to indicate starting points, reference to other sheets, or to clarify data shown;
- Combined K-factor calculations for nozzles on drops, armovers, or sprigs where calculations do not begin at a nozzle;
- Where extending existing equipment, hydraulic calculations indicating the previous design, volume, and pressure at points of connection, and adequate additional calculations to indicate effect on existing systems.

Water supply curves and system requirements, plus hose demand if required, shall be plotted to present a graphic summary of the complete hydraulic calculation.

The following information shall be included on the plans and calculations:

- Location and elevation of static and residual test gauge, with relation to the system actuation valve reference point;
- Flow location;
- Static pressure, psi (bar);
- Residual pressure, psi (bar);
- Flow, gpm (L/min);
- Date;
- Time;
- Source of water flow test information;
- Other sources of water supply, with pressure or elevation.

4.3.3 FORMULAS

4.3.3.1 Friction Loss

Pipe friction losses shall be determined on the basis of the Hazen-Williams formula:

$$P_m = 6.05 * \frac{Q_m^{1.85}}{C^{1.85} * d_m^{4.87}} * 10^5 \quad (\text{in SI units})$$

Where:

- P_m = frictional resistance (bars per meter of pipe);
- Q_m = flow (L/min);
- C = friction loss coefficient;
- d_m = actual internal diameter (mm).

4.3.3.2 Velocity Pressure

The velocity pressure shall be determined on the basis of the formula:

$$P_v = \frac{0.001123 \cdot Q^2}{D^4} \quad (\text{U.S. units})$$

Where:

- P_v = velocity pressure (psi);
- Q = flow (gpm);
- D = inside diameter (in.).

4.3.3.3 Normal Pressure

Normal pressure shall be determined on the basis of the formula:

$$P_n = P_t - P_v$$

Where:

- P_n = normal pressure [psi (bar)];
- P_t = total pressure [psi (bar)];
- P_v = velocity pressure [psi (bar)].

4.3.3.4 Nozzle Discharge

The discharge of a nozzle shall be calculated by the formula:

$$Q_m = K_m * \sqrt{P_m}$$

Where:

- Q_m = flow (L/min);
- K_m = nozzle K-factor (where K_m equals 14.4 K);
- P_m = total pressure at flow Q_m (bar).

As some of the original formulas are not updated to SI units, it is possible to find the conversions in the Table 4.3 next page.

Table 4.3 - Conversion from US to SI units

| U.S. Units | S.I. Units |
|------------|-------------|
| 1 psi | 0.06895 bar |
| 1 gpm | 3.79 lpm |
| 1 in | 25.4 mm |

4.3.3.5 Equivalent Pipe Lengths of Valves and Fittings

Table A.1 shall be used to determine equivalent lengths of valves and fittings, unless the manufacturer’s test data indicates that other factors are appropriate. Table A.1 shall be used with a Hazen-Williams C factor of 120 only. For other values of C, the quantities in Table A.1 shall be multiplied by the factors given in Table 4.4.

Table 4.4 – C Value Multipliers for valves and fittings

| Hazen-Williams C Value | Multiplying Factor |
|------------------------|--------------------|
| 100 | 0.713 |
| 120 | 1.00 |
| 130 | 1.16 |
| 140 | 1.33 |
| 150 | 1.51 |

4.3.3.6 Pipe Friction Loss

Pipe friction loss shall be calculated in accordance with the Hazen-Williams formula, using C values as shown in Table 4.5, and using the actual internal pipe diameter in the formula. Different C values shall be permitted to be used where required by the authority having jurisdiction.

Table 4.5 – C Value Multipliers por pipes

| Pipe or Tube | Hazen-Williams C Value |
|--|------------------------|
| Unlined cast or ductile iron | 100 |
| Black steel (wet systems including deluge systems) | 120 |
| Black steel (dry systems including preaction systems) | 100 |
| Galvanized steel (wet systems including deluge systems) | 120 |
| Galvanized steel (dry systems including preaction systems) | 100 |
| Cement-lined cast or ductile iron | 140 |
| Copper tube or stainless steel | 150 |

5

Water and Foam Fire Fighting

5.1 INTRODUCTION

With the rapid development of the chemical industry, the demand for petrochemical products increases dramatically. The oil depot's scale has expanded dramatically compared with a ten years ago. The crude oil tank farm has been drawn attention because of its serious consequence of fire or explosion. On July 16, 2005, a powerful fire and explosion devastated the thing farm of Dalian Petrochemical Company, which revealed the weakness of firefighting emergency capabilities in the tank farm. Firefighting emergency system in a tank farm plays a vital role in dealing in dealing with the fire and explosion, which will escalate the scale of the accident if the system loses out of control (42).

Information about likelihood of fire incidents in chemical or process plants (Figure 5.1) are hard to find. For industrial buildings fire frequency is $6.4 \cdot 10^{-6}$ [1/m²/a] referred to figures from Finland [Tillander K., 2003]. In comparison fire frequency of residential buildings is $4.7 \cdot 10^{-6}$ [1/m²/a], which means fire probability is 25% lower related to area. Assuming the area of mid-sized chemical plant of 5000 m² the probability of fire is 2.5% per year or statistically every 40 years a fire incident hits the plant (43).

The regular investigations of incidents and losses led to better understanding of process hazards and influenced best practice and legislation in a positive way.




Figure 5.1 - Consequences of major accidents in process engineering facilities (43)

5.1.1 STORAGE TANKS

5.1.1.1 Open-top, Floating Roof Tank

Open-top, floating-roof tanks, as described in the API Standard 650 (44), have either a single deck, which has a pontoon to keep the roof deck afloat, or a double deck floating-roof, or some other approved flotation device. In Figure 5.2 shows an example of a pontoon single deck and a double deck installed in an open-top, floating-roof tank. There is a flexible seal around the rim of the floating roof to prevent liquid leakage onto the top of the roof. Sealing devices include rubber or foam tubes, spring-loaded fabric and pantograph mechanisms.




Figure 5.2 - Example of the open-top, floating-roof tanks (45)

Although there is no specific ignition source normally present in the space above the roof, various sources will exist, particularly if a major fire incident is occurring nearby. These ignition sources might include:

- Hot soot particles that may fall out of smoke arising from the nearby tank fire;
- Radiant heat may raise the temperature of the wall above the floating-roof (if it is not cooled) or the temperature of the floating-roof to a degree sufficient for ignition to take place;
- Emergency pumping out of the tank, if its roof has tilted due to vapour generation, can lead to frictional heating or sparking.




Figure 5.3 - Possible fire scenarios that might occur in an open-top, floating-roof tank (45)

In Figure 5.3, it is shown the possible fire scenarios that might occur in an open-top, floating roof tank.

5.1.1.2 Internal, Floating Roof Tank

The design of an internal, floating-roof tank is a tank that has a floating roof, which is protected by another fixed roof against the weather or for environmental control. In Figure 5.4 it is shown a typical example of an internal, floating-roof tank. During the filling operation, flammable mixture can be present in the vapour space between the floating roof and the fixed roof. Recent updates of the LASTFIRE (46) study confirmed that fixed-roof tanks fitted with an internal floating roof have a very low probability of suffering an internal fire. However, this type of tank is more vulnerable to explosion, due to the presence of an explosive mixture between the two roofs (45).




Figure 5.4 - example of an internal, floating-roof tank (45)

In Figure 5.5, it is shown the possible fire scenarios in an open top floating roof tank. As the vents are the only area in contact with the exterior, it is the most likely place where a fire can occur.




Figure 5.5 - Possible fire scenarios for an internal, floating-roof tank (45)

5.1.1.3 Fixed Roof Tanks

The fixed-roof tank is the least expensive to construct and is generally considered the minimum, in terms of acceptable equipment for the storing of petroleum products. A typical fixed-roof tank, as shown in Figure 5.6, consists of a cylindrical wall with a dome-shaped, fixed roof, which is permanently fixed to the tank wall. The fixed-roof tank is normally used to store low volatility, high flashpoint liquids, such as kerosene.




Figure 5.6 - Typical fixed-roof tank: the fixed roof may be a cone shape or a dome shape (45)

The consequences of fixed-roof tanks being exposed to fire are, initially, quite different from those associated with floating-roof tanks: radiant heat from an adjacent tank fire will enter through the wall and will be absorbed by both vapour and liquid (Figure 5.7) (45).




Figure 5.7 - Possible sequence of fire scenarios for a fixed-roof tank (45)

5.1.2 IGNITION SOURCES

According to the most recent fire statistics (47) from the National Fire Protection Association, between 2011 and 2015, U.S. municipal fire departments responded to an estimated average of 37,000 fires at industrial and manufacturing properties, every year.

These incidents result in:

- 18 civilian deaths;
- 279 civilian injuries;
- \$1 billion in direct property damage.



Figure 5.8 - Buncefield tank farm fire, which occurred on the 11th December, 2005, in Hertfordshire, England (48)

These disasters happen for many reasons, and the most common are (45):

- Lighting;
- Hot Work;
- Spontaneous Ignition;
- Electrostatic Electricity;
- Exposure to Radiant Heat.

5.1.2.1 Lightning

Lightning is by far the most frequent source of ignition, with regards to the occurrence of fires within floating-roof storage tanks. In the LASTFIRE (46) incident survey study from 2012, it was reported that 52 of the 62 initial fire events within the scope of the survey were lightning-ignited rim-seal fires.

5.1.2.2 Hot Work

There are several incidents where hot work, such as welding or grinding, is identified as the ignition source for fires: two rim seal fires recorded in the LASTFIRE incident survey from 1997, started as a result of hot work on live tanks. In these cases, heat from welding caused flammable vapours to be emitted from hydrocarbon deposits, or sparks were carried from gas free areas into regions where there were flammable mixtures (45).

5.1.2.3 Spontaneous Ignition

Zalosh (2003) mentioned that the spontaneous ignition of a fuel vapour/air mixture can be caused by pyrophoric iron sulphide on the tank walls, which is formed by a slow reaction between the tank wall and the hydrogen sulphide present in some petroleum liquids: the reaction can be faster under moist and oxygen deficient atmospheres (45).

5.1.2.4 Electrostatic electricity

In the LASTFIRE (46) incident survey the electrostatic electricity has been postulated as the source of ignition in several fires that have occurred when foam has been placed onto tanks, upon discovery that the roof has sunk or partially sunk. The same study reported that the electrostatic discharge may occur if the electrical bonding between the roof and shell of the tank or the earthing of the tank are inadequate (45).

5.1.2.5 Exposure to Radiant Heat

Radiant heat is the dominant mode of heat transfer, in terms of the spread of flames within premises (Karlsson and Quintiere, 2000). However, in the reviewed tank fire incidents, radiant heat was not the prime means of ignition of atmospheric storage tank fires, however, it is still the main cause for escalation. An earlier compilation of API storage tank incidents in 1976 stated that 6% of the incidents reviewed were ignited by exposure to fires (Zalosh, 2003). In a historical incident review of atmospheric storage tank fires, carried out by Pitblado et al. (1990), 5% of 85 tank fires were ignited by exposure to radiant heat from an external fire (45).

5.2 FIRE PROTECTION OF TANKS

There are many causes and types of tank fires. In general, storage tanks pose a significant potential risk to life and property. In most cases, the risk factor is substantial, due to the relatively large quantities of fuels or unstable liquids that are stored in one location. For this reason, fire protection principles have been incorporated into the engineering codes and standards and many industries have generated additional practices that are more conservative than those specified by the engineering codes (45).

5.2.1 WATER COOLING SYSTEMS

Cooling of an adjacent atmospheric storage tank wall and roof is an effective means of maintaining temperatures within acceptable limits that will not cause the steel to collapse, the flammable vapours to be discharged to the atmosphere or the hot surfaces to form a source of ignition (45).



Figure 5.9 - Test of fire water system on spherical LPG storage tank (49)

5.2.1.1 Water Spray and Deluge Systems

Water spray and deluge system is the most efficient method of delivering water to the outside roof and wall of the fixed-roof storage tank and there are two principal ways of accomplishing this:

a) Using concentric rings of piping supported about 0.3 m above the roof. These rings are fitted with spray nozzles that form overlapping spray pattern to cover the whole roof with water. The wall is similarly protected, usually with one spray ring at the top of and about 0.6 m clear of the wall. Spray nozzles are fitted to this ring and are angled down slightly, in order to direct the spray of water over the whole circumference so that it can run down the wall.

b) The deluge system consists of a single water main being led to the tank roof, where the water is directed vertically onto the roof and is evenly spread over the roof, through the use of a conical nozzle at the end of the outlet pipe or a coronet attached to the roof plating. As the water streams down the roof, it is directed onto the wall by splash plates fitted to the edge of the wall: these plates are angled so that, as the water hits them, it is directed against the wall and thus runs down the wall.

These systems can be fed from a water deluge valve, which is automatically triggered by some form of electric, pneumatic or hydraulic system following fire detection (45).

5.2.1.2 Fixed and Trailer Mounted Water Monitors

Both fixed and trailer mounted water monitors are a cost-effective means of delivering water to cool storage tanks and the number, capacity, position and distribution of such monitors depends upon individual site requirements. However, problems with access and local water supply considerations must be taken into account, when considering the introduction of water monitors (45).

5.3 FOAM SYSTEMS

Foam is an aggregate of air-filled bubbles formed from aqueous solutions which is lower in density than flammable liquids. It is used principally to form a cohesive floating blanket on flammable and combustible liquids and prevents or extinguishes fire by excluding air and cooling the fuel. It also prevents reignition by suppressing formation of flammable vapors. It has the property of adhering to surfaces, which provides a degree of exposure protection from adjacent fires (50).




Figure 5.10 - Base Injection Method (51)

Foam methods are the most widely used firefighting system, as it is believed that they provide an acceptable overall level of protection. Foam fire-fighting systems, work by the introduction of a foam making concentrate into the firefighting water main. This produces a solution, which is fed to a foam generator, and the resulting foam is directed onto the fire. For fixed-roof, open-top, floating-roof and internal, floating-roof storage tanks, there are three principle foam systems available: these are base injection (Figure 5.10), top foam pouring (Figure 5.11) and foam monitors (Figure 5.13).



Figure 5.11 - Discharge outlets working in an Open top Floating Roof Tank (52)

5.3.1 TOP POURING SYSTEMS

As top foam pouring systems are the safest and most used systems, they are going to be the only explained. These systems are used to protect fixed-roof and internal, floating-roof storage tanks. In each case, the systems are designed on the basis that the fire risk involves the total surface area of the stored product. The system operates by introducing the foam making concentrate into the firefighting water feed line outside the tank bund area. This line is led to a foam generator, foam box and pourer, all of which are mounted in line at the top of the tank wall, as shown in Figure 5.12. When initiated, the foam solution is propelled to the tank, where the foam generator aerates the solution and delivers the resulting foam through a bursting disc in the foam box. A pourer unit immediately inside the tank wall and connected to the foam box directs the foam down the wall to form a blanket, which extinguishes the burning product.




Figure 5.12 - Firefighting foam Top Pouring System (45)

5.3.2 FOAM MONITORS

Fixed and trailer mounted foam monitors are suitable for protecting all types of vertical storage tanks and, although subject to performance limitations, they can be used as the primary protection system for tanks up to 18 meters in diameter (Long and Garner, 2004). However, some engineering codes, such as NFPA 11, state that monitors should not be used as the primary attack method for tanks greater than approximately 20 meters in diameter. In practice, they have been used for larger tanks, although they have had limited use in tanks greater than 40m (Ramsden, 2008). Foam monitors are often better suited and more commonly installed as either a secondary fixed foam system or to tackle spill fires, with the added benefit of being able to be used for tank cooling. Ramsden (2008) also explained that the most important consideration when proposing foam monitors as the primary system is that, to be effective, the foam must reach the seat of the fire. As in most systems, foam monitors will be close to the ground and the foam produced will first be required to reach up and over the tank wall. This requirement may be difficult to achieve as a result of many factors, such as the height of the tank, the distance between the tanks, the position of the monitor and weather conditions. Figure 5.13 shows the foam monitor.




Figure 5.13 - Trailer Mounted Foam Monitor

5.4 ANALYSIS OF LOW EXPANSION SYSTEM DESIGN

5.4.1 INTRODUCTION

NFPA's standards are often complex and lengthy documents, so to better understand and explain to the clients their options, an analysis was done to NFPA 11. This standard is applicable for Low-, Medium, and High-Expansion Foam and the version used was the latest, the 2016's.

The main objective was to analyse low-expansion systems, so chapter 5 got the most attention. Inside this section, it is examined the different types of hazards, the various roof's configurations, indoor hazards, diked areas, among others. Microsoft Visio was the program used to synthesise and make the following schemes.




Figure 5.14 - NFPA 11, 2016 Edition cover

In this study the author focused on the needs of the company and dissected subchapter 5.2 to 5.4, regarding tanks and also 5.7 which is about diked areas. For the purpose of this standard, diked areas shall be areas bounded by contours of land or physical barriers that retain a fuel to a depth greater than 25.4 millimetres (one inch) (50).

5.4.2 NFPA 11 ANALYSIS

5.4.3 STORAGE TANKS

As previously explained, there are different tank types, and the method used to fight a fire on them will depend on their characteristics. It is then essential to understand the different approaches to take, depending on what type of tank roof was being analysed.

In case we have the internal floating roof, there are two different approaches to have: design to full surface fire or to a seal area fire. The NFPA refers that, in this case, we shall have to either, design like fixed or open-top roofs, respectively. After identifying this, the standard presents three fighting systems which are, discharge outlets, monitors and handlines. As it will be possible to observe on the scheme bellow, monitors and handlines are very limited in usage for primary protection system. They are only effective in smaller tanks. Therefore, fixed system (or discharge outlets), are the most common type of protection used. For a full understanding of the analysis, consult Appendix B, where it is also located the tables with the discharge rates and duration for the applications.

5.4.4 DIKED AREAS

A diked area is defined as an area bounded by contours of land or a physical barrier that retains a fuel to a depth greater than 1 inch. At many manufacturing or storage facilities, the flammable liquid storage area can be a number of small tanks within a common diked area (53).




Figure 5.15 – Analysis of Fire Case in Diked Areas

It is possible to conclude from this subchapter, that for a fire in a diked area there are three ways to battle it: with discharge outlets, with foam monitors (from a distance) or by a fixed system (with water and foam simultaneously). It also says, that in case the flow is greater than 225 liters per minute, which it will always be because it is a relatively low flow rate, the engineer should use either the monitors or the fixed system as primary protection, and the first one as secondary. The discharge rates and durations are also present, along with a bigger scheme in Appendix B.

5.5 FIRE-WATER DEMAND CALCULATION SHEET

The records of the German major accidents reporting system – ZEMA (Zentrale Melde- und Auswertestelle für Störfälle und Störungen in verfahrenstechnischen Anlagen) shows consequences of major accidents in process engineering facilities for a time period from 2003 to 2013. It reveals that releases and fires are the most common consequences of accidents. In many cases the released substances are combustible, and the releases could lead with an ignition source to a fire, too. Summarizing it can be stated that fire is the essential hazard of chemical production plants with respect to ZEMA accidents reports (43).

5.5.1 INTRODUCTION

In an era where engineering is fast headed towards becoming more efficient, reliability cannot be forgotten. With this in mind, and with the need for a trustworthy and straightforward tool, it was developed a calculation sheet, for the needs of water and foam in case of a fire in a tank farm.

This tool was developed in Excel and, for now, it is only based on NFPA 11 (for the design and operation of medium expansion foam) and on NFPA 15 (for the water spray fixed systems).

For future developments, it would be interesting to do the same evaluation and programming of tabs for the remaining parts of a tank farm, besides the storage tanks:

- Bund;
- Process Unit;
- Loading and Unloading station.



Figure 5.16 – Example of a Loading and Unloading Station (54)

It would also be possible and helpful to set up the calculations for other than NFPA’s regulations. API Standards are also worldwide recognised and with a simple change in a dropdown cell, the entire calculation sheet would be redone.

It is important to take into consideration that these automations do not exclude the firefighting engineer from doing a recheck, and if necessary, an adjustment to the calculation sheet, as it is an easily editable tool. Also, take into consideration that all values can be overwritten in the “Regulation” tab. Sometimes, either by the Clients decision or simply by past experiences or good engineering practise, this fact can happen.

5.5.2 GOAL

The calculation sheet was created to define the fire protection required for the scenarios that are identified. It also had the goal of calculating the amount of water and foam needed in the different fire scenarios. The main objective is to determine the worst-case scenario and subsequently obtain the designing values for fire water and foam supply.

The current version of the calculation sheet is giving the following results:

- Blanket supply;
- Foam volume;
- Water flow;
- Water Volume.

The first two values will be related to the actual extinguishment of the fire, whereas the last two are will be used in the cooling down of the adjacent tanks.

5.5.3 DATA INPUT

The Foam concentration cell, on the Design Basis table, is the only field needed to be introduced on the first tab of the sheet. It was created an in-cell dropdown with the three options given by NFPA, one, three or six per cent of foal concentration.

Table 5.1 – Overview of the Regulations Tab

| DATA | | | | | | | | | | |
|---|-------------------|---|-------------------|----------------------------------|-------------------|---------------------|--------------|--|------------------------|--|
| <table border="1" style="margin: auto;"> <thead> <tr> <th colspan="2">Design Basis</th> </tr> </thead> <tbody> <tr> <td style="width: 50%;">Foam concentration (%)</td> <td style="width: 50%;"></td> </tr> </tbody> </table> | | | | | | | Design Basis | | Foam concentration (%) | |
| Design Basis | | | | | | | | | | |
| Foam concentration (%) | | | | | | | | | | |
| FOAM | | DISCHARGE OUTLETS | | MONITORS | | References | | | | |
| Design parameters | | Minimum Density Application Rate | Duration | Minimum Density Application Rate | Duration | | | | | |
| | | [l/min/m ²] | [min] | [l/min/m ²] | [min] | | | | | |
| Fixed Roof | Flammable | 4,1 | 30 | 6,5 | 65 | NFPA 11 - Table B.1 | | | | |
| | Combustible | 4,1 | 20 | 6,5 | 50 | | | | | |
| Floating Roof | Flammable | 12,2 | 20 | 6,5 | 65 | | | | | |
| | Combustible | 12,2 | 20 | 6,5 | 50 | | | | | |
| WATER | | FIXED WATER SPRAY SYSTEM AND WATER MONITORS | | | | References | | | | |
| Equipment Protection | | Minimum Density Application Rate | Duration | | | | | | | |
| | | [l/min/m ²] | [min] | | | | | | | |
| Static | Static Equipment | 10,2 | 120 | | | NFPA 15 - §7.4.3.4 | | | | |
| | Storage Tanks | 10,2 | | | | NFPA 15 - §7.4.2.1 | | | | |
| Rotating | Compressors Area | 20,4 | | | | NFPA 15 - §7.3.2 | | | | |
| | Pumps Area | 20,4 | | | | NFPA 15 - §7.3.2 | | | | |
| RESULTS | | | | | | | | | | |
| Blanket supply Water + Foam | | Foam Concentration Supply | | Water for cooling | | | | | | |
| [l] | [m ³] | [l] | [m ³] | Flow | Volume | | | | | |
| | | | | [m ³ /h] | [m ³] | | | | | |
| 0 | 0 | 0 | 0 | 0 | 0 | | | | | |

The Results table in the bottom will give the engineer the desired values after the introduction of the remaining data in the next tab.

The next Excel tab is where the tank information will be introduced. The user should fill all the light blue cells. The first four columns will not influence the rest of the sheet, but it is crucial to have an idea of the product that will be inside the tank, as well as the respective capacities. In the last two columns, it is identified if the liquid is a flammable or combustible and its respective class.

Take into consideration that the next three Tables should be read in sequence. To find the complete table, it is at Appendix C.

Table 5.2 – Overview of the Tank Data filling table

| Tank Data | | | | | | | | | |
|------------|------|-------|-------------------|--------------------|-------------------|-------------|-----------------|-----|----------|
| Number | Name | Tag | Capacity | Roof Type | Protection Type | Flash Point | Main Dimensions | | |
| | | | [m ³] | (Fixed / Floating) | (Fixed / Monitor) | [°C] | H | D | Rim Seal |
| | | | | | | | [m] | [m] | [m] |
| Scenario 1 | | | | | | | | | |
| 1 | | T-001 | | Fixed | Fixed | | | | - |
| 2 | | T-002 | | Fixed | Monitor | | | | - |
| 3 | | T-003 | | Floating | Fixed | | | | |
| 4 | | T-004 | | Floating | Monitor | | | | |
| 5 | | T-005 | | Fixed | Fixed | | | | - |
| 6 | | T-006 | | Fixed | Monitor | | | | - |
| 7 | | T-007 | | Floating | Fixed | | | | |
| 8 | | T-008 | | Floating | Monitor | | | | |

5.5.3.1 Liquids Classification

Combustible liquid is any liquid that has a closed-cup flashpoint at or above 100°F (37.8°C), as determined by the test procedures. (51). Flammable liquid is any liquid that has a closed-cup flash point below 100°F (37.8°C), as determined by the test procedures and a Reid vapour pressure that does not exceed an absolute pressure of 40 psi (276 kPa) at 100°F (37.8°C), as determined by ASTM D323, Standard Test Method for Vapor Pressure of Petroleum Products (Reid Method). (51).

Flammable liquids, as just defined, shall be classified as Class I liquids and shall be further subclassified in accordance with the following:

- Class IA Liquid — Any liquid that has a flashpoint below 73°F (22.8°C) and a boiling point below 100°F (37.8°C);
- Class IB Liquid — Any liquid that has a flashpoint below 73°F (22.8°C) and a boiling point at or above 100°F (37.8°C);
- Class IC Liquid — Any liquid that has a flashpoint at or above 73°F (22.8°C), but below 100°F (37.8°C).

Combustible liquids, as prior defined, shall be classified in accordance with the following:

- Class II Liquid — Any liquid that has a flashpoint at or above 100°F (37.8°C) and below 140°F (60°C);
- Class III Liquid — Any liquid that has a flashpoint at or above 140°F (60°C);
 - Class IIIA Liquid — Any liquid that has a flashpoint at or above 140°F (60°C), but below 200°F (93°C);
 - Class IIIB Liquid — Any liquid that has a flashpoint at or above 200°F (93°C).

5.5.4 CALCULATIONS

The next step is deciding in which tank to do the fire simulation. It is only a likely or credible scenario to have a fire in a single tank, due to the small probability of having any.

Turning the in-cell dropdown from, “No” to “Yes”, will automatically assign an Application Rate and Discharge Time based in the tables already analysed and programmed in Excel. The following cell,

Surface Area, was already filled by the filling of the tank’s roof information’s. The Flow Rate is a simple multiplication of the Application Rate times the Area as well as the Blanket supply cell, which is the Flow rate multiplied by the time. Finally, the Concentration supply is the amount of foam from the water previously calculated. It comes from multiplying the previous cell with designed based, foam concentration.

Table 5.3 – Foam Calculation table

| Foam Calculation | | | | | | |
|------------------|-------------------------|-------|-------------------|-----------|----------------|----------------------|
| Addition of Foam | Application rate | Time | Surface Area | Flow rate | Blanket supply | Concentration Supply |
| (Yes/No) | [l/min.m ²] | [min] | [m ²] | [l/min] | [l] | [l] |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| | | | | Σ= | 0 | 0 |

The following phase in the design of the fire protection, is the cooling of the adjacent tanks. It might not always be the tanks right next to the one that is on fire, but with a Heat Radiation Study, it is possible to say which need the water, for cooling. It is again just the choice of turning the in-cell dropdown from, “No” to “Yes”, and all the cells on the right-hand side will be automatically filled based on the information previously given.

The Roof area is just the area of a circle, the top of the tank. The Vessel Area is the area of a cylinder, the shell of the tank, and the Total Surface is the sum of the previous two. The Water Flow will be the multiplication of the water application rate with the total surface. Finally, the water volume is water flow times the duration (in this case it will always be 120 minutes (41)).

Table 5.4 – Water Calculation table

| Water Calculation | | | | | | |
|-------------------|---------------------------------|-------------------|-------------------|-------------------|---------------------|-------------------|
| Addition of Water | Selected water application rate | Roof Area | Vessel Area | Total surface | Water Flow | Water Volume |
| (Yes/No) | [l/min/m ²] | [m ²] | [m ²] | [m ²] | [m ³ /h] | [m ³] |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| No | - | - | - | - | - | - |
| Σ= | | | | | 0 | 0 |

Returning to the first tab, in the Results table at the bottom, it is possible to see a summary of what happen in the calculation tab just described. It is shown the minimum flows and volumes, of water and foam needed in case of a fire in the Storage Tank Area in the Tank Farm.

To finalize it is only necessary to show the formulas used:

- Area of the circle = $D^2 * \pi / 4$
- Volume of the tank = $A_{circle} * H$
- Perimeter of the circle = $D * \pi$
- Area of sidewall = $P_{circle} * H$
- Area of the vessel = $A_{circle} + A_{sidewall}$
- Flowrate = $Application\ rate * Surface\ Area$
- Blanket supply = $Flow\ Rate * Time$
- Concentration Supply = $Blanket\ supply * Foam\ \%$

There is only a particular formula that needs some context, the calculation of the rim seal area. In case of a studied a floating roof tank and it is being designed for a fire in the seal, the calculation sheet is ready to deliver that “ring area”. There are three factors related in this formula, the diameter of both the tank and the floating roof, and the length of the rim seal:

The length of the rim seal is equal to the difference of the radius of the tank roofs (or half of their diameters).




Figure 5.17 - Rim Seal Area Demonstration

Therefore, relating both the areas of the roofs and the rim seal, it is possible to get the formula used to calculate the surface where the fire may occur:

$$\text{Rim seal Area} = (\pi * r) * (D - r) \quad [\text{m}^2]$$

As this study might be done in an early project phase, and the Process Department is not able yet, to give an exact size of the seal, the user will need to arbitrate a value (that is usually between one and two meters).

5.5.5 CASE STUDY

It is now presented a small example, so that the reader can better understand how much water and foam these kinds of system require, and therefore the importance of having these numbers correctly calculated. It was created a random storage tank area with four tanks as shown next page:




Figure 5.18 – Storage Tanks

The tank farm is constituted by four storage tanks, two fixed and two floating roofs. The four chemical products inside tanks were randomly arbitrated. It was decided to give different flash points, in order to get different flammability classes. The floating tanks will have rim seals of two meters in tank number three, and one meter in the number four. In the following table is possible to see the remaining characteristics:

Table 5.5 – Tank’s Characteristics

| Name | Roof Type | Protection Type | Flash Point | Main Dimensions | | |
|--------|--------------------|-------------------|-------------|-----------------|-----|----------|
| | (Fixed / Floating) | (Fixed / Monitor) | [°C] | H | D | Rim Seal |
| | | | | [m] | [m] | [m] |
| Tank 1 | Fixed | Fixed | -26 | 20 | 18 | - |
| Tank 2 | Fixed | Monitor | 7 | 22 | 20 | - |
| Tank 3 | Floating | Fixed | 55 | 24 | 22 | 2 |
| Tank 4 | Floating | Monitor | 100 | 26 | 24 | 1 |

It is fairly simple to fill this part of the table. The user just adds the information once, on the Scenario 1 table, and then copy and pastes, three times in this case (it will always be n, the number of tanks, or fire scenarios, minus one). On the table immediately on the right-hand side, the user should select the option addition of foam to “Yes”, once per scenario, as previously explained, because its likelihood. For the complete Table, it is possible to see it in Appendix C.

It is possible to observe that the worst-case scenario in this situation would be the number two, by some margin. Largely due to the fact of the protection type chosen to be monitors. This increased, both the application rate and the discharge time.

Next, it is simulated that all three remaining tanks, without a fire occurrence, need to be cooled down. The user would need again to change the configuration of the “Addition of Water” cells to “Yes” and all the remaining cells are automatically calculated accordingly to the formulas previously explained in sub chapter 4.5.4.

As expected, the water volume does not vary much, due to the initial impositions of similar tank’s heights and diameters. Even so, the worst-case scenario will be observed with the first set-up, with the need of more than 7500 cubic meters of water.

Going back to the first tab of the sheet it is possible to find a brief summary of the obtained results.

The reader should take into account that, for a better reading, both the pages from Appendix C should be printed in A3 size.

6

RESULTS, ANALYSIS AND DISCUSSION

6.1 CONCLUSIONS

A look on loss statistics of reportable incidents reveals that fire is the most important cause of major losses in the chemical industry. Therefore, it pays off to think about how advanced fire precautions may help to minimize the risk of such damages (43).

6.1.1 AutoSPRINK

With a high-performance BIM Software like AutoSPRINK, the design methodologies were redefined for the designers of automatic extinguishing systems and fire networks. The software is currently recognised as the most accurate and rigorous BIM tool, it allows rapid 3D modelling, complemented by a powerful hydraulic calculation tool associated with a vast database and library of BIM objects.

As a downside, the software does not have the most user-friendly interface. The icons are very small, and some are hard to interpret. There is another detail that makes the designing process to take a longer period, that is the lack of a command bar. This way, like it happens in AutoCAD, for instance, the user would be able to type the wished command, instead of going with the mouse to find the button. Also, the ability to understand the mistakes, like leaks or the lack of water flowing. Specially in the beginning, when the designer is not used to the tools available, the water is not running through the pipes and the user does not know why.

Directly impacting my design, with the help of internet tutorials and online forums it was possible to manage most of the errors that appeared except for the valves used. Hydraulically, it does not impact the design, because it is possible to consider the local losses, but there is not a deluge valve with the diameter of 200 millimeters (eight inches). Therefore, the stock listing is not completely correct, but the engineer in charge of the design would have to leave a memorandum.

The other feature that was missed, was the approximate mathematical expression of both the supply and system demand curves. It only made possible to compare the results based on graph comparison and maximum values on flow and pressure.

6.2 RESULTS

6.2.1 NETWORK DESIGN

As previously said, the information of the hydraulic calculation only arrived late in June, therefore it was not possible to do a deeper analysis and comparison.

The Water Supply Curve for the Contractor’s design is approximately, the one bellow (Formula 6.1). As for the author’s, as previously explained, AutoSPRINK does not provide such information but the actual graph is at the second page of the Hydraulic Calculation file at Appendix A

$$P = (1.310 * 10^{-7} * Q^2) + (1.493 * 10^{-4} * Q) + 1.132 \quad [\text{bar}] \quad (6.1)$$

What is possible to compare are the actual numbers for the maximum flow and pressure running in the system with all nozzles flowing (Table 6.1).

Table 6.1 – Overall Results

| | Contractor | Author | Difference | |
|-----------------------|------------|---------|------------|-------|
| | | | Δ | % |
| Flow (lpm) | 7180.546 | 7315.58 | -135.034 | -1.85 |
| Pressure (bar) | 8.961 | 8.789 | +0.172 | +1.94 |

As it is possible to perceive from the Table 6.1 above, the results attained with the software and the ones sent by the Contractor are very similar (less than 2% in difference, both on flow and pressure), which can be easily explained with some small height differences, pipe roughness, digit rounding among others.

With this information, I firmly believe that Worley can start doing a part of the sprinklers network “at home”. The biggest impact of this change would be on having a quicker and most accessible network design that is a very iterative process with other disciplines, given that space management is crucial in the design at the firm.

6.2.2 NFPA 11 ANALYSIS

National Fire Protection Association Standards are, at the same time, worldwide recognized but often seen as difficult to interpret. If they are a theme of debate and discussion among specialists in the firefighting area, to explain some requirements and even concepts to clients can be challenging.

With the diagrams produced (Appendix B), it was intended to simplify these explanations and also for new engineers in the area to have a clearer picture on how to deal with the fire protection equipment depending on the type of tank that is being dealt with.

6.2.3 CALCULATION SHEET

The author hopes, with this simulation to sensitize the community for a need of a reliable tool that in the next iterations will allow the Fire Fighting Engineer to combine different standards and overwrite any values based on previous experiences and good engineering practises.

6.3 FUTURE DEVELOPMENTS PERSPECTIVES

Regarding the network design, the results achieved proved that AutoSPRINK is ready to be used. There are, of course, improvements, like the inclusion of new accessories families, like fittings and valves. It was also meant, but for lack of time, the designing of the hangers, by NFPA 13, is missing, and is an important information for the colleagues of the structural department to add as loads.

Future works on the Excel sheet, should primarily focus on adding the calculations for the remaining areas of the project (bund, loading and unloading station, pumps and compressors, and finally columns, vessels and reactors). Secondly, it would be very beneficial if, with just button click, the sheet could reorganize itself and re-calculate according to a different standard (API, for instance), or even to overwrite some values with more reliable and trusted numbers by the engineer.

REFERENCES

1. **M.E.P.CAD, Inc.** MEPCAD. [Online] 2005-2012. <http://www.mepcad.com/autosprink/astestimonials.aspx>.
2. **Spruce, Hannah.** High Speed Training. [Online] 16 March 2016. <https://www.highspeedtraining.co.uk/hub/fire-triangle-tetrahedron-combustion/>.
3. *Environmental Impact of Automatic Fire Sprinklers: Part 2. Experimental Study.* **Ditch, Ben.** s.l. : FM Global.
4. **Coelho, António Leça.** *Incêndios em edifícios.* 2010.
5. **US, CFBT -.** <http://cfbt-us.com>. [Online] <http://cfbt-us.com/pdfs/FBIandFireDevelopment.pdf>.
6. **National Fire Protection Association.** [Online] <https://www.nfpa.org/Codes-and-Standards/Standards-development-process/How-the-process-works/History-of-standards-development>.
7. *Nota Técnica Nº 16 - Sistemas Automáticos de Extinção por Água.* **Autoridade Nacional de Proteção Civil.**
8. *Meios de extinção de incêndio por água – Análise regulamentar comparativa.* **Carvalho, Joana Raquel Rodrigues de Oliveira.** November 2016.
9. **BRITISH STANDARD.** *Fixed firefighting systems — Automatic sprinkler systems — Design, installation and maintenance.* [Online] <http://tomrobbo.com/dbsinfo/Regs%20&%20Data%20Sheets/BS%20EN%2012845%202004.pdf>.
10. **NFPA.** NFPA 15 - Standard for Water Spray Fixed Systems for Fire Protection. 2017, p. 20.
11. **Martorano, Scott.** Viking Group. [Online] <https://www.vikinggroupinc.com/sites/default/files/documents/Spray%20Nozzle%20Selections.pdf>.
12. **Kinetix Fire.** Kinetixfire.com. [Online] <https://kinetixfire.com/the-difference-between-various-types-of-fire-sprinklers/>.
13. *Requirements for LPCB certification and Redbook listing of Supervised Premises Transceivers: Intrusion and Hold-up Alarm Systems.* **BRE Global Ltd.** 2016.
14. *Design and operation of sprinkler systems.* **Martin, D.L., Kincaid, Dennis C. and Lyle, William M.** 2007.
15. **Direct Industry.** [Online] <https://www.directindustry.com/prod/hd-fire-protect-pvt-ltd/product-188290-2235501.html>.
16. *Piping layout for fire sprinkler system: An overview.* **Vishnoi, Kshitiz.**
17. **NFPA.** NFPA 13 - Standard for the Installation of Sprinkler Systems. 2019, p. 31.
18. **TYCO.** TYCO - Fire. [Online] https://www.tyco-fire.com/TD_TFP/TFP/TFP1420_10_2014.pdf.
19. **Inst Tools.** [Online] <https://instrumentationtools.com/deluge-valve-working-principle/>.
20. *NFPA Glossary of Terms - 2019 Edition.* 2019.
21. **Law Insider.** Law Insider. [Online] <https://www.lawinsider.com/dictionary/process-unit>.

22. Beal, Vangie. Webopedia. *Webopedia.com*. [Online] <https://www.webopedia.com/TERM/G/greenfield.html>.
23. *Advantages and disadvantages of bim platforms on construction site*. Fernandes, Rui Pedro Lopes. July 2013, p. 136.
24. 360 Feed Wire. *Passive Fire Protection Market Size, Share & Trends Analysis Report By Application (Construction, Oil & Gas, Industrial, Warehousing), By Product (Intumescent Coating, Cementitious Material), And Segment Forecasts, 2019 - 2025*. 2019.
25. Speight, James. *Environmental Organic Chemistry for Engineers*. s.l. : Elsevier Inc., 2017. pp. 87-151.
26. www.europeanceo.com. [Online] European CEO. <https://www.europeanceo.com/finance/the-port-of-antwerp-boasts-excellent-connections-at-the-heart-of-europe/>.
27. Coker, A. Kayode. *Ludwig's Applied Process Design for Chemical and Petrochemical Plants*. s.l. : Gulf Professional Publishing, 2007. p. 104. Vol. 1.
28. Diebel, James, Norda, Jacob and Kretchmer, Orna. Weatherspark. *watherspark.com*. [Online] <https://weatherspark.com/y/51236/Average-Weather-in-Antwerpen-Belgium-Year-Round>.
29. Grumbles, Tom, et al. American Chemistry. *www.americanchemistry.com*. [Online] <https://www.americanchemistry.com/ProductsTechnology/Ethylene-Oxide/EO-Product-Stewardship-Manual-3rd-edition/EO-Product-Stewardship-Manual-Design-of-Facilities.pdf>.
30. BASF SE; BAYER MATERIALSCIENCE AG; INEOS Manufacturing Deutschland GmbH; DOW EUROPE GmbH; LYONDELLBASELL INDUSTRIES; REPSOL QUIMICA; SHELL CHEMICALS EUROPE BV. Lyondellbasell. *www.lyondellbasell.com*. [Online] <https://www.lyondellbasell.com/globalassets/documents/polymers-technical-literature/guidelines-for-the-distribution-of-propylene-oxide---2013.pdf>.
31. Weather Atlas. [Online] <https://www.weather-atlas.com/en/belgium/antwerp-climate#temperature>.
32. Tyco. Tyco Fire. *www.tyco-fire.com*. [Online] August 2018. https://www.tyco-fire.com/TD_TFP/TFP/TFP807_08_2018.pdf.
33. *NFPA 24 - Standard for the Installation of Private Fire Service Mains and Their*. s.l. : National Fire Protection Association, 2019.
34. European Standard - EN 13121-1. *GRP tanks and vessels for use above ground - Part 1: Raw materials - Specification conditions and acceptance conditions*. 2003.
35. Brière, François G. Google Books. [Online] <https://books.google.pt/books?id=4bO4jNGVEyUC&pg=PA369&lpg=PA369&dq=hydrant+flow+2000l/+min&source=bl&ots=TYZE1cXJ3T&sig=ACfU3U3a0ayc2cfGDyDOdVkj1HvzcDe4og&hl=pt-PT&sa=X&ved=2ahUKEwiB2Lao4obqAhUYAWMBHWXIDJcQ6AEwAnoECAkQAQ#v=onepage&q=hydrant%20flow%202000>.
36. RJ-SCIE. *Regime Jurídico da Segurança Contra Incêndio em Edifícios*.
37. ProCiv. *ProCiv*. [Online] <http://www.prociv.pt/en-us/Pages/default.aspx>.
38. *NFPA 15 - Standard for Water Spray Fixed Systems for Fire Protection*. s.l. : National Fire Protection Association, 2017, p. 14.

39. NFPA 15 - Standard for Water Spray Fixed Systems for Fire Protection. 2017, p. 45.
40. AutoSPRINK Settings. *AutoSPRINK Web Site*. [Online] January 2020. <https://autosprink.com/help>.
41. *NFPA 15 - Standard for Water Spray Fixed Systems for Fire Protection*. s.l. : Nation Fire Protection Association, 2017.
42. *Firefighting Emergency Capability Evaluation on Crude Oil Tank Farm*. Liu, Yi, Zhou, Huan and Liu, Lu. s.l. : Procedia Engineering, 2018.
43. *Fire Protection in the Chemical Industry*. Wehmeier, Guido and Mitropetros, Konstantinos. [ed.] Eddy de Rademaeker and Peter Schmelzer. s.l. : The Italian Association of Chemical Engineering Online, 2016, Chemical Engineering Transactions, Vol. 48.
44. API. *API 650 - Welded Steel Tanks for Oil Storage*.
45. Mansour, Khalid Abusaieda. *Fires in Large Atmospheric Storage Tanks and their Effect on Adjacent Tanks*. 2012.
46. LASTFIRE. Lastfire - Large Atmospheric Storage Tank Fires. [Online] <http://www.lastfire.co.uk/default.aspx?ReturnUrl=%2f>.
47. NFPA. [Online] <https://www.nfpa.org/News-and-Research/Data-research-and-tools/Building-and-Life-Safety/Fires-in-US-Industrial-and-Manufacturing-Facilities>.
48. ENDS Report. [Online] <https://www.endsreport.com/article/1563219/buncefield-firms-pay-94m-safety-pollution-offences>.
49. Siraga. [Online] http://www.siraga.com/media/15543/Fire_Water_Systems_ENG.pdf.
50. [book auth.] NFPA. *NFPA 11 Standard for Low-, Medium-, and High-Expansion Foam*. 2016, p. 23.
51. WilliamsFire. Petroleum Storage Tank - Fire Protection. [Online] <https://www.slideshare.net/MarcoMedrano1/tank-protection-86944431>.
52. Sensor - ACM. [Online] <https://www.sensor-acm.pl/our-offer/for-fuel-energy-and-chemical-industry/tank-gauging-equipment-and-solutions/foam-and-spray-systems/>.
53. ChemGuard. [Online] <https://www.chemguard.com/pdf/design-manuals/D10D03200.pdf>.
54. B & J Group. [Online] <https://www.bandjgroup.com/?p=466>.
55. *NFPA 30 - Flammable and Combustible Liquids Code*. s.l. : National Fire Protection Association, 2018.
56. *Study on the Failure Probability of Occupant Evacuation with the Method of Monte Carlo Sampling*. Chen, Hao-nan and Mao, Zhan-li. 2018, Procedia Engineering, Vol. 211, pp. 55-62.
57. NCDOL. North Carolina Department of Insurance. *NCDOL*. [Online] https://www.ncdoi.com/OSFM/RPD/PT/Documents/Coursework/Ethanol/Module5_ParticipantManuals.pdf.
58. NFPA. *NFPA 13 - Standard for the Installation of Sprinkler Systems*. 2019, pp. 292-297.
59. Guardian Fire Protection. [Online] <https://www.guardianfireprotection.com/fire-sprinkler-installation>.

60. Meyer Fire. Meyer Fire Blog. [Online] <https://www.meyerfire.com/blog/advantages-of-return-bends-in-fire-sprinkler-systems>.

61. *Nota Técnica nº 8 - Grau de Prontidão de Socorro*. ANPC.

62. Verhaert. Verhaert - Master in Inovation. [Online] <https://verhaert.com/safesens-improve-safety-security/>.

APPENDICES

APPENDIX A – HYDRAULIC CALCULATION

Hydraulic Calculations

for

Project Name: Thesis

Location: , ,

Drawing Name: Alkox 1.8 bar 10.06

Calculation Date: 10/06/2020

Design

Remote Area Number:

Occupancy Classification: Other

Density: 10.20L/min/m²

Area of Application: 540.00m² (Actual 186.40m²)

Coverage per Sprinkler: 9.29m²

Type of sprinklers calculated: Pendent

No. of sprinklers calculated: 120

Type of System: Volume of Dry or PreAction System: N/A

In-rack Demand: N/A L/min at Node: N/A

Hose Streams: 0.0 L/min at Node: 25 Type: Allowance at Source

Total Water Required (including Hose Streams where applicable):

From Water Supply at Node 25: 7315.58L/min @ 8.789bar

Water Supply Information:

Name of Contractor:

Address: ,

Phone Number:

Name of designer: Daniel Rocha Afonso

Authority Having Jurisdiction:

Notes:


Automatic peaking results Left: N/A Right: N/A

Hydraulic Graph

Job Name: Thesis
Remote Area Number:

N^{1.85}

Date: 10/06/2020



**Water Supply
Summary Sheet
Node: 25**





Summary Of Outflowing Devices

| Device | Actual Flow (L/min) | Minimum Flow (L/min) | K-Factor (K bar) | Pressure (bar) | Density (lpm/m ²) | Coverage (Meter) |
|---------------|---------------------|----------------------|------------------|----------------|-------------------------------|--------------------|
| Sprinkler 201 | 48.30L/min | 48.30L/min | 36Kbar | 1.800bar | 5.20L/min/m ² | 9.29m ² |
| Sprinkler 202 | 48.34L/min | 48.30L/min | 36Kbar | 1.803bar | 5.20L/min/m ² | 9.29m ² |
| Sprinkler 203 | 49.14L/min | 48.30L/min | 36Kbar | 1.863bar | 5.29L/min/m ² | 9.29m ² |
| Sprinkler 204 | 49.32L/min | 48.30L/min | 36Kbar | 1.877bar | 5.31L/min/m ² | 9.29m ² |
| Sprinkler 205 | 50.99L/min | 48.30L/min | 36Kbar | 2.006bar | 5.49L/min/m ² | 9.29m ² |
| Sprinkler 206 | 53.41L/min | 48.30L/min | 36Kbar | 2.202bar | 5.75L/min/m ² | 9.29m ² |
| Sprinkler 207 | 53.47L/min | 48.30L/min | 36Kbar | 2.206bar | 5.75L/min/m ² | 9.29m ² |
| Sprinkler 208 | 53.47L/min | 48.30L/min | 36Kbar | 2.206bar | 5.76L/min/m ² | 9.29m ² |
| Sprinkler 209 | 53.93L/min | 48.30L/min | 36Kbar | 2.244bar | 5.80L/min/m ² | 9.29m ² |
| Sprinkler 210 | 55.01L/min | 48.30L/min | 36Kbar | 2.335bar | 5.92L/min/m ² | 9.29m ² |
| Sprinkler 211 | 55.07L/min | 48.30L/min | 36Kbar | 2.340bar | 5.93L/min/m ² | 9.29m ² |
| Sprinkler 212 | 55.83L/min | 48.30L/min | 36Kbar | 2.405bar | 6.01L/min/m ² | 9.29m ² |
| Sprinkler 213 | 55.88L/min | 48.30L/min | 36Kbar | 2.410bar | 6.02L/min/m ² | 9.29m ² |
| Sprinkler 214 | 56.36L/min | 48.30L/min | 36Kbar | 2.451bar | 6.07L/min/m ² | 9.29m ² |
| Sprinkler 215 | 56.84L/min | 48.30L/min | 36Kbar | 2.492bar | 6.12L/min/m ² | 9.29m ² |
| Sprinkler 216 | 56.96L/min | 48.30L/min | 36Kbar | 2.504bar | 6.13L/min/m ² | 9.29m ² |
| Sprinkler 217 | 57.37L/min | 48.30L/min | 36Kbar | 2.540bar | 6.18L/min/m ² | 9.29m ² |
| Sprinkler 218 | 57.48L/min | 48.30L/min | 36Kbar | 2.550bar | 6.19L/min/m ² | 9.29m ² |
| Sprinkler 219 | 57.53L/min | 48.30L/min | 36Kbar | 2.554bar | 6.19L/min/m ² | 9.29m ² |
| Sprinkler 220 | 58.08L/min | 48.30L/min | 36Kbar | 2.603bar | 6.25L/min/m ² | 9.29m ² |
| Sprinkler 221 | 59.22L/min | 48.30L/min | 36Kbar | 2.706bar | 6.37L/min/m ² | 9.29m ² |
| Sprinkler 222 | 59.37L/min | 48.30L/min | 36Kbar | 2.719bar | 6.39L/min/m ² | 9.29m ² |
| Sprinkler 223 | 59.51L/min | 48.30L/min | 36Kbar | 2.732bar | 6.41L/min/m ² | 9.29m ² |
| Sprinkler 224 | 59.53L/min | 48.30L/min | 36Kbar | 2.735bar | 6.41L/min/m ² | 9.29m ² |
| Sprinkler 225 | 60.07L/min | 48.30L/min | 36Kbar | 2.784bar | 6.47L/min/m ² | 9.29m ² |
| Sprinkler 226 | 60.20L/min | 48.30L/min | 36Kbar | 2.796bar | 6.48L/min/m ² | 9.29m ² |
| Sprinkler 227 | 61.25L/min | 48.30L/min | 36Kbar | 2.895bar | 6.59L/min/m ² | 9.29m ² |
| Sprinkler 228 | 61.26L/min | 48.30L/min | 36Kbar | 2.896bar | 6.59L/min/m ² | 9.29m ² |
| Sprinkler 229 | 61.80L/min | 48.30L/min | 36Kbar | 2.947bar | 6.65L/min/m ² | 9.29m ² |
| Sprinkler 230 | 61.90L/min | 48.30L/min | 36Kbar | 2.956bar | 6.66L/min/m ² | 9.29m ² |
| Sprinkler 231 | 62.03L/min | 48.30L/min | 36Kbar | 2.969bar | 6.68L/min/m ² | 9.29m ² |
| Sprinkler 232 | 62.65L/min | 48.30L/min | 36Kbar | 3.029bar | 6.74L/min/m ² | 9.29m ² |
| Sprinkler 233 | 63.55L/min | 48.30L/min | 36Kbar | 3.116bar | 6.84L/min/m ² | 9.29m ² |
| Sprinkler 234 | 55.98L/min | 42.53L/min | 31.7Kbar | 3.118bar | 6.03L/min/m ² | 9.29m ² |
| Sprinkler 235 | 56.00L/min | 42.53L/min | 31.7Kbar | 3.121bar | 6.03L/min/m ² | 9.29m ² |
| Sprinkler 236 | 56.39L/min | 42.53L/min | 31.7Kbar | 3.165bar | 6.07L/min/m ² | 9.29m ² |
| Sprinkler 237 | 64.74L/min | 48.30L/min | 36Kbar | 3.234bar | 6.97L/min/m ² | 9.29m ² |
| Sprinkler 238 | 57.27L/min | 42.53L/min | 31.7Kbar | 3.264bar | 6.16L/min/m ² | 9.29m ² |
| Sprinkler 239 | 66.01L/min | 48.30L/min | 36Kbar | 3.362bar | 7.10L/min/m ² | 9.29m ² |
| Sprinkler 240 | 58.98L/min | 42.53L/min | 31.7Kbar | 3.461bar | 6.35L/min/m ² | 9.29m ² |
| Sprinkler 241 | 61.09L/min | 42.53L/min | 31.7Kbar | 3.714bar | 6.58L/min/m ² | 9.29m ² |
| Sprinkler 242 | 57.39L/min | 38.64L/min | 28.8Kbar | 3.971bar | 6.18L/min/m ² | 9.29m ² |
| Sprinkler 243 | 57.41L/min | 38.64L/min | 28.8Kbar | 3.974bar | 6.18L/min/m ² | 9.29m ² |
| Sprinkler 244 | 57.42L/min | 38.64L/min | 28.8Kbar | 3.975bar | 6.18L/min/m ² | 9.29m ² |
| Sprinkler 245 | 57.44L/min | 38.64L/min | 28.8Kbar | 3.978bar | 6.18L/min/m ² | 9.29m ² |
| Sprinkler 246 | 57.47L/min | 38.64L/min | 28.8Kbar | 3.983bar | 6.19L/min/m ² | 9.29m ² |
| Sprinkler 247 | 57.49L/min | 38.64L/min | 28.8Kbar | 3.985bar | 6.19L/min/m ² | 9.29m ² |
| Sprinkler 248 | 57.66L/min | 38.64L/min | 28.8Kbar | 4.008bar | 6.21L/min/m ² | 9.29m ² |
| Sprinkler 249 | 57.68L/min | 38.64L/min | 28.8Kbar | 4.011bar | 6.21L/min/m ² | 9.29m ² |
| Sprinkler 250 | 57.74L/min | 38.64L/min | 28.8Kbar | 4.020bar | 6.22L/min/m ² | 9.29m ² |
| Sprinkler 251 | 57.77L/min | 38.64L/min | 28.8Kbar | 4.024bar | 6.22L/min/m ² | 9.29m ² |
| Sprinkler 252 | 57.83L/min | 38.64L/min | 28.8Kbar | 4.032bar | 6.22L/min/m ² | 9.29m ² |
| Sprinkler 253 | 58.01L/min | 38.64L/min | 28.8Kbar | 4.057bar | 6.24L/min/m ² | 9.29m ² |
| Sprinkler 254 | 58.50L/min | 38.64L/min | 28.8Kbar | 4.126bar | 6.30L/min/m ² | 9.29m ² |
| Sprinkler 255 | 58.52L/min | 38.64L/min | 28.8Kbar | 4.128bar | 6.30L/min/m ² | 9.29m ² |
| Sprinkler 256 | 58.52L/min | 38.64L/min | 28.8Kbar | 4.128bar | 6.30L/min/m ² | 9.29m ² |
| Sprinkler 257 | 58.57L/min | 38.64L/min | 28.8Kbar | 4.136bar | 6.30L/min/m ² | 9.29m ² |
| Sprinkler 258 | 58.79L/min | 38.64L/min | 28.8Kbar | 4.167bar | 6.33L/min/m ² | 9.29m ² |
| Sprinkler 259 | 58.86L/min | 38.64L/min | 28.8Kbar | 4.176bar | 6.34L/min/m ² | 9.29m ² |
| Sprinkler 260 | 59.20L/min | 38.64L/min | 28.8Kbar | 4.226bar | 6.37L/min/m ² | 9.29m ² |
| Sprinkler 261 | 59.22L/min | 38.64L/min | 28.8Kbar | 4.228bar | 6.37L/min/m ² | 9.29m ² |
| Sprinkler 262 | 59.23L/min | 38.64L/min | 28.8Kbar | 4.230bar | 6.38L/min/m ² | 9.29m ² |



Summary Of Outflowing Devices

| Device | Actual Flow (L/min) | Minimum Flow (L/min) | K-Factor (K bar) | Pressure (bar) | Density (lpm/m ²) | Coverage (Meter) |
|---------------|---------------------|----------------------|------------------|----------------|-------------------------------|--------------------|
| Sprinkler 263 | 59.58L/min | 38.64L/min | 28.8Kbar | 4.279bar | 6.41L/min/m ² | 9.29m ² |
| Sprinkler 264 | 59.61L/min | 38.64L/min | 28.8Kbar | 4.284bar | 6.42L/min/m ² | 9.29m ² |
| Sprinkler 265 | 60.17L/min | 38.64L/min | 28.8Kbar | 4.364bar | 6.48L/min/m ² | 9.29m ² |
| Sprinkler 266 | 60.21L/min | 38.64L/min | 28.8Kbar | 4.371bar | 6.48L/min/m ² | 9.29m ² |
| Sprinkler 267 | 60.34L/min | 38.64L/min | 28.8Kbar | 4.389bar | 6.49L/min/m ² | 9.29m ² |
| Sprinkler 268 | 60.37L/min | 38.64L/min | 28.8Kbar | 4.394bar | 6.50L/min/m ² | 9.29m ² |
| Sprinkler 269 | 60.40L/min | 38.64L/min | 28.8Kbar | 4.398bar | 6.50L/min/m ² | 9.29m ² |
| Sprinkler 270 | 60.42L/min | 38.64L/min | 28.8Kbar | 4.401bar | 6.50L/min/m ² | 9.29m ² |
| Sprinkler 271 | 66.54L/min | 42.53L/min | 31.7Kbar | 4.406bar | 7.16L/min/m ² | 9.29m ² |
| Sprinkler 272 | 66.74L/min | 42.53L/min | 31.7Kbar | 4.432bar | 7.18L/min/m ² | 9.29m ² |
| Sprinkler 273 | 60.73L/min | 38.64L/min | 28.8Kbar | 4.446bar | 6.54L/min/m ² | 9.29m ² |
| Sprinkler 274 | 60.77L/min | 38.64L/min | 28.8Kbar | 4.452bar | 6.54L/min/m ² | 9.29m ² |
| Sprinkler 275 | 67.31L/min | 42.53L/min | 31.7Kbar | 4.508bar | 7.25L/min/m ² | 9.29m ² |
| Sprinkler 276 | 61.36L/min | 38.64L/min | 28.8Kbar | 4.539bar | 6.60L/min/m ² | 9.29m ² |
| Sprinkler 277 | 61.54L/min | 38.64L/min | 28.8Kbar | 4.566bar | 6.62L/min/m ² | 9.29m ² |
| Sprinkler 278 | 62.22L/min | 38.64L/min | 28.8Kbar | 4.667bar | 6.70L/min/m ² | 9.29m ² |
| Sprinkler 279 | 62.79L/min | 38.64L/min | 28.8Kbar | 4.753bar | 6.76L/min/m ² | 9.29m ² |
| Sprinkler 280 | 62.81L/min | 38.64L/min | 28.8Kbar | 4.757bar | 6.76L/min/m ² | 9.29m ² |
| Sprinkler 281 | 62.91L/min | 38.64L/min | 28.8Kbar | 4.771bar | 6.77L/min/m ² | 9.29m ² |
| Sprinkler 282 | 63.13L/min | 38.64L/min | 28.8Kbar | 4.806bar | 6.80L/min/m ² | 9.29m ² |
| Sprinkler 283 | 63.14L/min | 38.64L/min | 28.8Kbar | 4.806bar | 6.80L/min/m ² | 9.29m ² |
| Sprinkler 284 | 63.16L/min | 38.64L/min | 28.8Kbar | 4.810bar | 6.80L/min/m ² | 9.29m ² |
| Sprinkler 285 | 69.57L/min | 42.53L/min | 31.7Kbar | 4.816bar | 7.49L/min/m ² | 9.29m ² |
| Sprinkler 286 | 63.25L/min | 38.64L/min | 28.8Kbar | 4.824bar | 6.81L/min/m ² | 9.29m ² |
| Sprinkler 287 | 63.48L/min | 38.64L/min | 28.8Kbar | 4.859bar | 6.83L/min/m ² | 9.29m ² |
| Sprinkler 288 | 63.50L/min | 38.64L/min | 28.8Kbar | 4.862bar | 6.84L/min/m ² | 9.29m ² |
| Sprinkler 289 | 63.53L/min | 38.64L/min | 28.8Kbar | 4.865bar | 6.84L/min/m ² | 9.29m ² |
| Sprinkler 290 | 63.59L/min | 38.64L/min | 28.8Kbar | 4.875bar | 6.84L/min/m ² | 9.29m ² |
| Sprinkler 291 | 63.61L/min | 38.64L/min | 28.8Kbar | 4.878bar | 6.85L/min/m ² | 9.29m ² |
| Sprinkler 292 | 63.71L/min | 38.64L/min | 28.8Kbar | 4.894bar | 6.86L/min/m ² | 9.29m ² |
| Sprinkler 293 | 63.74L/min | 38.64L/min | 28.8Kbar | 4.898bar | 6.86L/min/m ² | 9.29m ² |
| Sprinkler 294 | 63.83L/min | 38.64L/min | 28.8Kbar | 4.913bar | 6.87L/min/m ² | 9.29m ² |
| Sprinkler 295 | 63.86L/min | 38.64L/min | 28.8Kbar | 4.917bar | 6.87L/min/m ² | 9.29m ² |
| Sprinkler 296 | 63.88L/min | 38.64L/min | 28.8Kbar | 4.919bar | 6.88L/min/m ² | 9.29m ² |
| Sprinkler 297 | 63.89L/min | 38.64L/min | 28.8Kbar | 4.921bar | 6.88L/min/m ² | 9.29m ² |
| Sprinkler 298 | 63.97L/min | 38.64L/min | 28.8Kbar | 4.934bar | 6.89L/min/m ² | 9.29m ² |
| Sprinkler 299 | 63.98L/min | 38.64L/min | 28.8Kbar | 4.936bar | 6.89L/min/m ² | 9.29m ² |
| Sprinkler 300 | 64.07L/min | 38.64L/min | 28.8Kbar | 4.949bar | 6.90L/min/m ² | 9.29m ² |
| Sprinkler 301 | 64.22L/min | 38.64L/min | 28.8Kbar | 4.972bar | 6.91L/min/m ² | 9.29m ² |
| Sprinkler 302 | 64.24L/min | 38.64L/min | 28.8Kbar | 4.975bar | 6.91L/min/m ² | 9.29m ² |
| Sprinkler 303 | 64.46L/min | 38.64L/min | 28.8Kbar | 5.010bar | 6.94L/min/m ² | 9.29m ² |
| Sprinkler 304 | 64.59L/min | 38.64L/min | 28.8Kbar | 5.030bar | 6.95L/min/m ² | 9.29m ² |
| Sprinkler 305 | 64.61L/min | 38.64L/min | 28.8Kbar | 5.033bar | 6.95L/min/m ² | 9.29m ² |
| Sprinkler 306 | 64.78L/min | 38.64L/min | 28.8Kbar | 5.059bar | 6.97L/min/m ² | 9.29m ² |
| Sprinkler 307 | 65.18L/min | 38.64L/min | 28.8Kbar | 5.123bar | 7.02L/min/m ² | 9.29m ² |
| Sprinkler 308 | 65.20L/min | 38.64L/min | 28.8Kbar | 5.125bar | 7.02L/min/m ² | 9.29m ² |
| Sprinkler 309 | 71.88L/min | 42.53L/min | 31.7Kbar | 5.142bar | 7.74L/min/m ² | 9.29m ² |
| Sprinkler 310 | 65.34L/min | 38.64L/min | 28.8Kbar | 5.147bar | 7.03L/min/m ² | 9.29m ² |
| Sprinkler 311 | 65.56L/min | 38.64L/min | 28.8Kbar | 5.182bar | 7.06L/min/m ² | 9.29m ² |
| Sprinkler 312 | 66.16L/min | 38.64L/min | 28.8Kbar | 5.277bar | 7.12L/min/m ² | 9.29m ² |
| Sprinkler 313 | 66.31L/min | 38.64L/min | 28.8Kbar | 5.301bar | 7.14L/min/m ² | 9.29m ² |
| Sprinkler 314 | 66.58L/min | 38.64L/min | 28.8Kbar | 5.345bar | 7.17L/min/m ² | 9.29m ² |
| Sprinkler 315 | 67.21L/min | 38.64L/min | 28.8Kbar | 5.445bar | 7.23L/min/m ² | 9.29m ² |
| Sprinkler 316 | 67.57L/min | 38.64L/min | 28.8Kbar | 5.505bar | 7.27L/min/m ² | 9.29m ² |
| Sprinkler 317 | 68.19L/min | 38.64L/min | 28.8Kbar | 5.606bar | 7.34L/min/m ² | 9.29m ² |
| Sprinkler 318 | 68.35L/min | 38.64L/min | 28.8Kbar | 5.632bar | 7.36L/min/m ² | 9.29m ² |
| Sprinkler 319 | 77.80L/min | 42.53L/min | 31.7Kbar | 6.024bar | 8.37L/min/m ² | 9.29m ² |
| Sprinkler 320 | 83.36L/min | 42.53L/min | 31.7Kbar | 6.914bar | 8.97L/min/m ² | 9.29m ² |

Most Demanding Sprinkler Data

| Supply Analysis | | | | | | | |
|------------------------|------------------------|--------------|------------------------|---------------------------|---|----------------------|-------------------------|
| Node | Name | Static (bar) | Residual (bar) | Flow (L/min) | Available (bar) | Total Demand (L/min) | Required Pressure (bar) |
| 25 | Water Supply | 9.400bar | 9.236bar | 7315.58L/min | 9.236bar | 7315.58L/min | 8.789bar |
| Node Analysis | | | | | | | |
| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes | | |
| 25 | 2637mm | Supply | 8.789bar | 7315.58L/min | | | |
| 201 | 5306mm | Sprinkler | 1.800bar | 48.30L/min | Density: 5.20L/min/m ² Coverage: 9.29m ² | | |
| 202 | 5306mm | Sprinkler | 1.803bar | 48.34L/min | Density: 5.20L/min/m ² Coverage: 9.29m ² | | |
| 203 | 5306mm | Sprinkler | 1.863bar | 49.14L/min | Density: 5.29L/min/m ² Coverage: 9.29m ² | | |
| 204 | 5306mm | Sprinkler | 1.877bar | 49.32L/min | Density: 5.31L/min/m ² Coverage: 9.29m ² | | |
| 205 | 5310mm | Sprinkler | 2.006bar | 50.99L/min | Density: 5.49L/min/m ² Coverage: 9.29m ² | | |
| 206 | 5306mm | Sprinkler | 2.202bar | 53.41L/min | Density: 5.75L/min/m ² Coverage: 9.29m ² | | |
| 207 | 5310mm | Sprinkler | 2.206bar | 53.47L/min | Density: 5.75L/min/m ² Coverage: 9.29m ² | | |
| 208 | 5306mm | Sprinkler | 2.206bar | 53.47L/min | Density: 5.76L/min/m ² Coverage: 9.29m ² | | |
| 209 | 5306mm | Sprinkler | 2.244bar | 53.93L/min | Density: 5.80L/min/m ² Coverage: 9.29m ² | | |
| 210 | 5306mm | Sprinkler | 2.335bar | 55.01L/min | Density: 5.92L/min/m ² Coverage: 9.29m ² | | |
| 211 | 5310mm | Sprinkler | 2.340bar | 55.07L/min | Density: 5.93L/min/m ² Coverage: 9.29m ² | | |
| 212 | 5306mm | Sprinkler | 2.405bar | 55.83L/min | Density: 6.01L/min/m ² Coverage: 9.29m ² | | |
| 213 | 5306mm | Sprinkler | 2.410bar | 55.88L/min | Density: 6.02L/min/m ² Coverage: 9.29m ² | | |
| 214 | 5306mm | Sprinkler | 2.451bar | 56.36L/min | Density: 6.07L/min/m ² Coverage: 9.29m ² | | |
| 215 | 5310mm | Sprinkler | 2.492bar | 56.84L/min | Density: 6.12L/min/m ² Coverage: 9.29m ² | | |
| 216 | 5306mm | Sprinkler | 2.504bar | 56.96L/min | Density: 6.13L/min/m ² Coverage: 9.29m ² | | |
| 217 | 5306mm | Sprinkler | 2.540bar | 57.37L/min | Density: 6.18L/min/m ² Coverage: 9.29m ² | | |
| 218 | 5306mm | Sprinkler | 2.550bar | 57.48L/min | Density: 6.19L/min/m ² Coverage: 9.29m ² | | |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|---|
| 219 | 5306mm | Sprinkler | 2.554bar | 57.53L/min | Density: 6.19L/min/m ² Coverage: 9.29m ² |
| 220 | 5306mm | Sprinkler | 2.603bar | 58.08L/min | Density: 6.25L/min/m ² Coverage: 9.29m ² |
| 221 | 5306mm | Sprinkler | 2.706bar | 59.22L/min | Density: 6.37L/min/m ² Coverage: 9.29m ² |
| 222 | 5306mm | Sprinkler | 2.719bar | 59.37L/min | Density: 6.39L/min/m ² Coverage: 9.29m ² |
| 223 | 5306mm | Sprinkler | 2.732bar | 59.51L/min | Density: 6.41L/min/m ² Coverage: 9.29m ² |
| 224 | 5306mm | Sprinkler | 2.735bar | 59.53L/min | Density: 6.41L/min/m ² Coverage: 9.29m ² |
| 225 | 5306mm | Sprinkler | 2.784bar | 60.07L/min | Density: 6.47L/min/m ² Coverage: 9.29m ² |
| 226 | 5304mm | Sprinkler | 2.796bar | 60.20L/min | Density: 6.48L/min/m ² Coverage: 9.29m ² |
| 227 | 5306mm | Sprinkler | 2.895bar | 61.25L/min | Density: 6.59L/min/m ² Coverage: 9.29m ² |
| 228 | 5306mm | Sprinkler | 2.896bar | 61.26L/min | Density: 6.59L/min/m ² Coverage: 9.29m ² |
| 229 | 5306mm | Sprinkler | 2.947bar | 61.80L/min | Density: 6.65L/min/m ² Coverage: 9.29m ² |
| 230 | 5310mm | Sprinkler | 2.956bar | 61.90L/min | Density: 6.66L/min/m ² Coverage: 9.29m ² |
| 231 | 5310mm | Sprinkler | 2.969bar | 62.03L/min | Density: 6.68L/min/m ² Coverage: 9.29m ² |
| 232 | 5306mm | Sprinkler | 3.029bar | 62.65L/min | Density: 6.74L/min/m ² Coverage: 9.29m ² |
| 233 | 5306mm | Sprinkler | 3.116bar | 63.55L/min | Density: 6.84L/min/m ² Coverage: 9.29m ² |
| 234 | 5306mm | Sprinkler | 3.118bar | 55.98L/min | Density: 6.03L/min/m ² Coverage: 9.29m ² |
| 235 | 5306mm | Sprinkler | 3.121bar | 56.00L/min | Density: 6.03L/min/m ² Coverage: 9.29m ² |
| 236 | 5306mm | Sprinkler | 3.165bar | 56.39L/min | Density: 6.07L/min/m ² Coverage: 9.29m ² |
| 237 | 5304mm | Sprinkler | 3.234bar | 64.74L/min | Density: 6.97L/min/m ² Coverage: 9.29m ² |
| 238 | 5306mm | Sprinkler | 3.264bar | 57.27L/min | Density: 6.16L/min/m ² Coverage: 9.29m ² |
| 239 | 5306mm | Sprinkler | 3.362bar | 66.01L/min | Density: 7.10L/min/m ² Coverage: 9.29m ² |
| 240 | 5306mm | Sprinkler | 3.461bar | 58.98L/min | Density: 6.35L/min/m ² Coverage: 9.29m ² |
| 241 | 5304mm | Sprinkler | 3.714bar | 61.09L/min | Density: 6.58L/min/m ² Coverage: 9.29m ² |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|---|
| 242 | 14856mm | Sprinkler | 3.971bar | 57.39L/min | Density: 6.18L/min/m ² Coverage: 9.29m ² |
| 243 | 14854mm | Sprinkler | 3.974bar | 57.41L/min | Density: 6.18L/min/m ² Coverage: 9.29m ² |
| 244 | 14856mm | Sprinkler | 3.975bar | 57.42L/min | Density: 6.18L/min/m ² Coverage: 9.29m ² |
| 245 | 14856mm | Sprinkler | 3.978bar | 57.44L/min | Density: 6.18L/min/m ² Coverage: 9.29m ² |
| 246 | 14856mm | Sprinkler | 3.983bar | 57.47L/min | Density: 6.19L/min/m ² Coverage: 9.29m ² |
| 247 | 14856mm | Sprinkler | 3.985bar | 57.49L/min | Density: 6.19L/min/m ² Coverage: 9.29m ² |
| 248 | 14856mm | Sprinkler | 4.008bar | 57.66L/min | Density: 6.21L/min/m ² Coverage: 9.29m ² |
| 249 | 14856mm | Sprinkler | 4.011bar | 57.68L/min | Density: 6.21L/min/m ² Coverage: 9.29m ² |
| 250 | 14856mm | Sprinkler | 4.020bar | 57.74L/min | Density: 6.22L/min/m ² Coverage: 9.29m ² |
| 251 | 14856mm | Sprinkler | 4.024bar | 57.77L/min | Density: 6.22L/min/m ² Coverage: 9.29m ² |
| 252 | 14856mm | Sprinkler | 4.032bar | 57.83L/min | Density: 6.22L/min/m ² Coverage: 9.29m ² |
| 253 | 14856mm | Sprinkler | 4.057bar | 58.01L/min | Density: 6.24L/min/m ² Coverage: 9.29m ² |
| 254 | 14856mm | Sprinkler | 4.126bar | 58.50L/min | Density: 6.30L/min/m ² Coverage: 9.29m ² |
| 255 | 14856mm | Sprinkler | 4.128bar | 58.52L/min | Density: 6.30L/min/m ² Coverage: 9.29m ² |
| 256 | 14856mm | Sprinkler | 4.128bar | 58.52L/min | Density: 6.30L/min/m ² Coverage: 9.29m ² |
| 257 | 14856mm | Sprinkler | 4.136bar | 58.57L/min | Density: 6.30L/min/m ² Coverage: 9.29m ² |
| 258 | 14856mm | Sprinkler | 4.167bar | 58.79L/min | Density: 6.33L/min/m ² Coverage: 9.29m ² |
| 259 | 14856mm | Sprinkler | 4.176bar | 58.86L/min | Density: 6.34L/min/m ² Coverage: 9.29m ² |
| 260 | 14856mm | Sprinkler | 4.226bar | 59.20L/min | Density: 6.37L/min/m ² Coverage: 9.29m ² |
| 261 | 14856mm | Sprinkler | 4.228bar | 59.22L/min | Density: 6.37L/min/m ² Coverage: 9.29m ² |
| 262 | 14856mm | Sprinkler | 4.230bar | 59.23L/min | Density: 6.38L/min/m ² Coverage: 9.29m ² |
| 263 | 14856mm | Sprinkler | 4.279bar | 59.58L/min | Density: 6.41L/min/m ² Coverage: 9.29m ² |
| 264 | 14856mm | Sprinkler | 4.284bar | 59.61L/min | Density: 6.42L/min/m ² Coverage: 9.29m ² |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|---|
| 265 | 14854mm | Sprinkler | 4.364bar | 60.17L/min | Density: 6.48L/min/m ² Coverage: 9.29m ² |
| 266 | 14854mm | Sprinkler | 4.371bar | 60.21L/min | Density: 6.48L/min/m ² Coverage: 9.29m ² |
| 267 | 14856mm | Sprinkler | 4.389bar | 60.34L/min | Density: 6.49L/min/m ² Coverage: 9.29m ² |
| 268 | 14854mm | Sprinkler | 4.394bar | 60.37L/min | Density: 6.50L/min/m ² Coverage: 9.29m ² |
| 269 | 14856mm | Sprinkler | 4.398bar | 60.40L/min | Density: 6.50L/min/m ² Coverage: 9.29m ² |
| 270 | 14856mm | Sprinkler | 4.401bar | 60.42L/min | Density: 6.50L/min/m ² Coverage: 9.29m ² |
| 271 | 5304mm | Sprinkler | 4.406bar | 66.54L/min | Density: 7.16L/min/m ² Coverage: 9.29m ² |
| 272 | 5300mm | Sprinkler | 4.432bar | 66.74L/min | Density: 7.18L/min/m ² Coverage: 9.29m ² |
| 273 | 14854mm | Sprinkler | 4.446bar | 60.73L/min | Density: 6.54L/min/m ² Coverage: 9.29m ² |
| 274 | 14856mm | Sprinkler | 4.452bar | 60.77L/min | Density: 6.54L/min/m ² Coverage: 9.29m ² |
| 275 | 5304mm | Sprinkler | 4.508bar | 67.31L/min | Density: 7.25L/min/m ² Coverage: 9.29m ² |
| 276 | 14854mm | Sprinkler | 4.539bar | 61.36L/min | Density: 6.60L/min/m ² Coverage: 9.29m ² |
| 277 | 14854mm | Sprinkler | 4.566bar | 61.54L/min | Density: 6.62L/min/m ² Coverage: 9.29m ² |
| 278 | 14858mm | Sprinkler | 4.667bar | 62.22L/min | Density: 6.70L/min/m ² Coverage: 9.29m ² |
| 279 | 19046mm | Sprinkler | 4.753bar | 62.79L/min | Density: 6.76L/min/m ² Coverage: 9.29m ² |
| 280 | 19046mm | Sprinkler | 4.757bar | 62.81L/min | Density: 6.76L/min/m ² Coverage: 9.29m ² |
| 281 | 19046mm | Sprinkler | 4.771bar | 62.91L/min | Density: 6.77L/min/m ² Coverage: 9.29m ² |
| 282 | 19046mm | Sprinkler | 4.806bar | 63.13L/min | Density: 6.80L/min/m ² Coverage: 9.29m ² |
| 283 | 19046mm | Sprinkler | 4.806bar | 63.14L/min | Density: 6.80L/min/m ² Coverage: 9.29m ² |
| 284 | 19046mm | Sprinkler | 4.810bar | 63.16L/min | Density: 6.80L/min/m ² Coverage: 9.29m ² |
| 285 | 5304mm | Sprinkler | 4.816bar | 69.57L/min | Density: 7.49L/min/m ² Coverage: 9.29m ² |
| 286 | 19046mm | Sprinkler | 4.824bar | 63.25L/min | Density: 6.81L/min/m ² Coverage: 9.29m ² |
| 287 | 19046mm | Sprinkler | 4.859bar | 63.48L/min | Density: 6.83L/min/m ² Coverage: 9.29m ² |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|---|
| 288 | 14854mm | Sprinkler | 4.862bar | 63.50L/min | Density: 6.84L/min/m ² Coverage: 9.29m ² |
| 289 | 19046mm | Sprinkler | 4.865bar | 63.53L/min | Density: 6.84L/min/m ² Coverage: 9.29m ² |
| 290 | 14856mm | Sprinkler | 4.875bar | 63.59L/min | Density: 6.84L/min/m ² Coverage: 9.29m ² |
| 291 | 14856mm | Sprinkler | 4.878bar | 63.61L/min | Density: 6.85L/min/m ² Coverage: 9.29m ² |
| 292 | 19046mm | Sprinkler | 4.894bar | 63.71L/min | Density: 6.86L/min/m ² Coverage: 9.29m ² |
| 293 | 19046mm | Sprinkler | 4.898bar | 63.74L/min | Density: 6.86L/min/m ² Coverage: 9.29m ² |
| 294 | 19046mm | Sprinkler | 4.913bar | 63.83L/min | Density: 6.87L/min/m ² Coverage: 9.29m ² |
| 295 | 19046mm | Sprinkler | 4.917bar | 63.86L/min | Density: 6.87L/min/m ² Coverage: 9.29m ² |
| 296 | 19046mm | Sprinkler | 4.919bar | 63.88L/min | Density: 6.88L/min/m ² Coverage: 9.29m ² |
| 297 | 19046mm | Sprinkler | 4.921bar | 63.89L/min | Density: 6.88L/min/m ² Coverage: 9.29m ² |
| 298 | 14856mm | Sprinkler | 4.934bar | 63.97L/min | Density: 6.89L/min/m ² Coverage: 9.29m ² |
| 299 | 19046mm | Sprinkler | 4.936bar | 63.98L/min | Density: 6.89L/min/m ² Coverage: 9.29m ² |
| 300 | 19046mm | Sprinkler | 4.949bar | 64.07L/min | Density: 6.90L/min/m ² Coverage: 9.29m ² |
| 301 | 19046mm | Sprinkler | 4.972bar | 64.22L/min | Density: 6.91L/min/m ² Coverage: 9.29m ² |
| 302 | 19046mm | Sprinkler | 4.975bar | 64.24L/min | Density: 6.91L/min/m ² Coverage: 9.29m ² |
| 303 | 19046mm | Sprinkler | 5.010bar | 64.46L/min | Density: 6.94L/min/m ² Coverage: 9.29m ² |
| 304 | 19046mm | Sprinkler | 5.030bar | 64.59L/min | Density: 6.95L/min/m ² Coverage: 9.29m ² |
| 305 | 19046mm | Sprinkler | 5.033bar | 64.61L/min | Density: 6.95L/min/m ² Coverage: 9.29m ² |
| 306 | 14856mm | Sprinkler | 5.059bar | 64.78L/min | Density: 6.97L/min/m ² Coverage: 9.29m ² |
| 307 | 19046mm | Sprinkler | 5.123bar | 65.18L/min | Density: 7.02L/min/m ² Coverage: 9.29m ² |
| 308 | 19046mm | Sprinkler | 5.125bar | 65.20L/min | Density: 7.02L/min/m ² Coverage: 9.29m ² |
| 309 | 5304mm | Sprinkler | 5.142bar | 71.88L/min | Density: 7.74L/min/m ² Coverage: 9.29m ² |
| 310 | 19046mm | Sprinkler | 5.147bar | 65.34L/min | Density: 7.03L/min/m ² Coverage: 9.29m ² |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|---|
| 311 | 19046mm | Sprinkler | 5.182bar | 65.56L/min | Density: 7.06L/min/m ² Coverage: 9.29m ² |
| 312 | 19046mm | Sprinkler | 5.277bar | 66.16L/min | Density: 7.12L/min/m ² Coverage: 9.29m ² |
| 313 | 19046mm | Sprinkler | 5.301bar | 66.31L/min | Density: 7.14L/min/m ² Coverage: 9.29m ² |
| 314 | 14854mm | Sprinkler | 5.345bar | 66.58L/min | Density: 7.17L/min/m ² Coverage: 9.29m ² |
| 315 | 19046mm | Sprinkler | 5.445bar | 67.21L/min | Density: 7.23L/min/m ² Coverage: 9.29m ² |
| 316 | 19046mm | Sprinkler | 5.505bar | 67.57L/min | Density: 7.27L/min/m ² Coverage: 9.29m ² |
| 317 | 19046mm | Sprinkler | 5.606bar | 68.19L/min | Density: 7.34L/min/m ² Coverage: 9.29m ² |
| 318 | 19046mm | Sprinkler | 5.632bar | 68.35L/min | Density: 7.36L/min/m ² Coverage: 9.29m ² |
| 319 | 5304mm | Sprinkler | 6.024bar | 77.80L/min | Density: 8.37L/min/m ² Coverage: 9.29m ² |
| 320 | 5304mm | Sprinkler | 6.914bar | 83.36L/min | Density: 8.97L/min/m ² Coverage: 9.29m ² |
| 1 | 5506mm | | 1.792bar | | |
| 2 | 5506mm | | 1.803bar | | |
| 3 | 5506mm | | 1.861bar | | |
| 4 | 5506mm | | 1.881bar | | |
| 5 | 5506mm | | 2.013bar | | |
| 6 | 5506mm | | 2.214bar | | |
| 7 | 5506mm | | 2.504bar | | |
| 8 | 5506mm | | 3.001bar | | |
| 9 | 5506mm | | 3.062bar | | |
| 10 | 5506mm | | 3.151bar | | |
| 11 | 5506mm | | 3.271bar | | |
| 12 | 5506mm | | 3.400bar | | |
| 13 | 5506mm | | 3.489bar | | |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|-------|
| 14 | 5506mm | | 3.744bar | | |
| 15 | 5506mm | | 4.429bar | | |
| 16 | 5506mm | | 4.523bar | | |
| 17 | 5506mm | | 4.558bar | | |
| 18 | 5506mm | | 4.833bar | | |
| 19 | 5506mm | | 5.161bar | | |
| 20 | 5506mm | | 6.046bar | | |
| 21 | 5506mm | | 7.044bar | | |
| 22 | 5506mm | | 8.114bar | | |
| 23 | 7577mm | | 7.968bar | | |
| 24 | 7577mm | | 8.147bar | | |
| 26 | 5506mm | | 1.795bar | | |
| 27 | 5506mm | | 1.856bar | | |
| 28 | 5506mm | | 2.210bar | | |
| 29 | 5506mm | | 2.253bar | | |
| 30 | 5506mm | | 2.345bar | | |
| 31 | 5506mm | | 2.409bar | | |
| 32 | 5506mm | | 2.552bar | | |
| 33 | 5506mm | | 2.979bar | | |
| 34 | 5506mm | | 2.988bar | | |
| 35 | 5506mm | | 2.200bar | | |
| 36 | 5506mm | | 2.416bar | | |
| 37 | 5506mm | | 2.462bar | | |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|-------|
| 38 | 5506mm | | 2.562bar | | |
| 39 | 5506mm | | 2.734bar | | |
| 40 | 5506mm | | 2.405bar | | |
| 41 | 5506mm | | 2.567bar | | |
| 42 | 5506mm | | 2.615bar | | |
| 43 | 5506mm | | 2.720bar | | |
| 44 | 5506mm | | 2.879bar | | |
| 45 | 5506mm | | 2.912bar | | |
| 46 | 5506mm | | 2.747bar | | |
| 47 | 5506mm | | 2.799bar | | |
| 48 | 5506mm | | 2.911bar | | |
| 49 | 5506mm | | 2.732bar | | |
| 50 | 5506mm | | 2.964bar | | |
| 51 | 5506mm | | 2.973bar | | |
| 52 | 5506mm | | 2.986bar | | |
| 53 | 5506mm | | 3.047bar | | |
| 54 | 5506mm | | 3.135bar | | |
| 55 | 5506mm | | 3.129bar | | |
| 56 | 5506mm | | 3.176bar | | |
| 57 | 5506mm | | 3.276bar | | |
| 58 | 5506mm | | 3.116bar | | |
| 59 | 5506mm | | 3.254bar | | |
| 60 | 5506mm | | 3.383bar | | |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|-------|
| 61 | 5506mm | | 3.475bar | | |
| 62 | 5506mm | | 3.730bar | | |
| 63 | 15056mm | | 3.983bar | | |
| 64 | 15056mm | | 4.032bar | | |
| 65 | 15056mm | | 4.240bar | | |
| 66 | 15056mm | | 4.464bar | | |
| 67 | 15056mm | | 4.538bar | | |
| 68 | 15056mm | | 4.548bar | | |
| 69 | 15056mm | | 4.649bar | | |
| 70 | 15056mm | | 4.678bar | | |
| 71 | 15056mm | | 4.837bar | | |
| 72 | 15056mm | | 4.873bar | | |
| 73 | 15056mm | | 5.378bar | | |
| 74 | 15056mm | | 6.626bar | | |
| 75 | 15056mm | | 7.072bar | | |
| 76 | 15056mm | | 3.969bar | | |
| 77 | 15056mm | | 3.988bar | | |
| 78 | 15056mm | | 4.037bar | | |
| 79 | 15056mm | | 4.142bar | | |
| 80 | 15056mm | | 4.373bar | | |
| 81 | 15056mm | | 4.373bar | | |
| 82 | 15056mm | | 4.380bar | | |
| 83 | 15056mm | | 4.381bar | | |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|-------|
| 84 | 15056mm | | 4.403bar | | |
| 85 | 15056mm | | 4.405bar | | |
| 86 | 15056mm | | 4.455bar | | |
| 87 | 15056mm | | 3.974bar | | |
| 88 | 15056mm | | 3.995bar | | |
| 89 | 15056mm | | 4.044bar | | |
| 90 | 15056mm | | 4.149bar | | |
| 91 | 15056mm | | 3.981bar | | |
| 92 | 15056mm | | 4.021bar | | |
| 93 | 15056mm | | 4.070bar | | |
| 94 | 15056mm | | 4.181bar | | |
| 95 | 15056mm | | 4.007bar | | |
| 96 | 15056mm | | 4.139bar | | |
| 97 | 15056mm | | 4.190bar | | |
| 98 | 15056mm | | 4.299bar | | |
| 99 | 15056mm | | 4.125bar | | |
| 100 | 15056mm | | 4.242bar | | |
| 101 | 15056mm | | 4.294bar | | |
| 102 | 15056mm | | 4.405bar | | |
| 103 | 15056mm | | 4.227bar | | |
| 104 | 15056mm | | 4.362bar | | |
| 105 | 15056mm | | 4.369bar | | |
| 106 | 15056mm | | 4.392bar | | |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|-------|
| 107 | 15056mm | | 4.414bar | | |
| 108 | 15056mm | | 4.468bar | | |
| 109 | 15056mm | | 4.583bar | | |
| 110 | 15056mm | | 4.399bar | | |
| 111 | 5506mm | | 4.428bar | | |
| 112 | 15056mm | | 4.444bar | | |
| 113 | 5506mm | | 4.510bar | | |
| 114 | 15056mm | | 4.537bar | | |
| 115 | 15056mm | | 4.665bar | | |
| 116 | 19272mm | | 5.057bar | | |
| 117 | 19272mm | | 5.113bar | | |
| 118 | 19272mm | | 5.232bar | | |
| 119 | 19272mm | | 5.435bar | | |
| 120 | 19272mm | | 5.440bar | | |
| 121 | 19272mm | | 5.456bar | | |
| 122 | 19272mm | | 5.495bar | | |
| 123 | 19272mm | | 5.563bar | | |
| 124 | 19272mm | | 5.688bar | | |
| 125 | 19272mm | | 5.859bar | | |
| 126 | 19272mm | | 6.237bar | | |
| 127 | 19272mm | | 6.650bar | | |
| 128 | 19272mm | | 5.061bar | | |
| 129 | 19272mm | | 5.118bar | | |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|-------|
| 130 | 19272mm | | 5.236bar | | |
| 131 | 19272mm | | 5.077bar | | |
| 132 | 19272mm | | 5.133bar | | |
| 133 | 19272mm | | 5.252bar | | |
| 134 | 19272mm | | 5.114bar | | |
| 135 | 19272mm | | 5.170bar | | |
| 136 | 19272mm | | 5.290bar | | |
| 137 | 5506mm | | 4.819bar | | |
| 138 | 15056mm | | 4.861bar | | |
| 139 | 19272mm | | 5.177bar | | |
| 140 | 19272mm | | 5.234bar | | |
| 141 | 19272mm | | 5.355bar | | |
| 142 | 15056mm | | 4.894bar | | |
| 143 | 15056mm | | 4.953bar | | |
| 144 | 15056mm | | 5.079bar | | |
| 145 | 15056mm | | 5.359bar | | |
| 146 | 15056mm | | 5.359bar | | |
| 147 | 15056mm | | 4.877bar | | |
| 148 | 19272mm | | 5.042bar | | |
| 149 | 19272mm | | 5.046bar | | |
| 150 | 19272mm | | 5.061bar | | |
| 151 | 19272mm | | 5.098bar | | |
| 152 | 19272mm | | 5.294bar | | |

| Node Number | Elevation (Millimeter) | Node Type | Pressure at Node (bar) | Discharge at Node (L/min) | Notes |
|-------------|------------------------|-----------|------------------------|---------------------------|-------|
| 153 | 19272mm | | 5.352bar | | |
| 154 | 19272mm | | 5.476bar | | |
| 155 | 19272mm | | 5.161bar | | |
| 156 | 19272mm | | 5.277bar | | |
| 157 | 19272mm | | 5.453bar | | |
| 158 | 19272mm | | 5.513bar | | |
| 159 | 19272mm | | 5.641bar | | |
| 160 | 5506mm | | 5.146bar | | |
| 161 | 19272mm | | 5.436bar | | |
| 162 | 15056mm | | 5.346bar | | |
| 163 | 19272mm | | 5.794bar | | |
| 164 | 19272mm | | 5.857bar | | |
| 165 | 19272mm | | 5.992bar | | |
| 166 | 19272mm | | 6.222bar | | |
| 167 | 19272mm | | 5.776bar | | |
| 168 | 5506mm | | 6.032bar | | |
| 169 | 5506mm | | 6.041bar | | |

| Pipe Information | | | | | | | | | |
|------------------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | Total (Millimeter) | | | Friction(Pf) | |
| 201 | 5306mm | 36Kbar | 48.30L/min | 25 | (See Notes) | 200mm | 100 | 1.800bar | ***** Route 1 ***** Sprinkler, E(435mm) |
| 1 | 5506mm | | 48.30L/min | 26.6446 | | 435mm | 0.000018 | -0.020bar | |
| | | | | | | 635mm | | 0.011bar | |
| 1 | 5506mm | | | 32 | (See Notes) | 1166mm | 100 | 1.792bar | T(1304mm) |
| 2 | 5506mm | | 48.30L/min | 35.0520 | | 1304mm | 0.000005 | | |
| | | | | | | 2470mm | | 0.012bar | |
| 2 | 5506mm | | 48.34L/min | 32 | (See Notes) | 2089mm | 100 | 1.803bar | Flow (q) from Route 2 T(1304mm) |
| 3 | 5506mm | | 96.64L/min | 35.0520 | | 1304mm | 0.000017 | | |
| | | | | | | 3393mm | | 0.058bar | |
| 3 | 5506mm | | 49.14L/min | 32 | | 550mm | 100 | 1.861bar | Flow (q) from Route 3 |
| 4 | 5506mm | | 145.78L/min | 35.0520 | | | 0.000036 | | |
| | | | | | | 550mm | | 0.020bar | |
| 4 | 5506mm | | 49.32L/min | 32 | | 2100mm | 100 | 1.881bar | Flow (q) from Route 4 |
| 5 | 5506mm | | 195.10L/min | 35.0520 | | | 0.000063 | | |
| | | | | | | 2100mm | | 0.131bar | |
| 5 | 5506mm | | 50.99L/min | 32 | | 2100mm | 100 | 2.013bar | Flow (q) from Route 5 |
| 6 | 5506mm | | 246.09L/min | 35.0520 | | | 0.000096 | | |
| | | | | | | 2100mm | | 0.202bar | |
| 6 | 5506mm | | 53.47L/min | 32 | | 2100mm | 100 | 2.214bar | Flow (q) from Route 7 |
| 7 | 5506mm | | 299.56L/min | 35.0520 | | | 0.000138 | | |
| | | | | | | 2100mm | | 0.290bar | |
| 7 | 5506mm | | 56.84L/min | 32 | (See Notes) | 1302mm | 100 | 2.504bar | Flow (q) from Route 15 PO(1304mm) |
| 8 | 5506mm | | 356.39L/min | 35.0520 | | 1304mm | 0.000191 | | |
| | | | | | | 2606mm | | 0.497bar | |
| 8 | 5506mm | | 6L/min + 62.03 | 80 | | 3000mm | 100 | 3.001bar | Flow (q) from Route 6 and 31 |
| 9 | 5506mm | | 870.38L/min | 77.9272 | | | 0.000020 | | |
| | | | | | | 3000mm | | 0.061bar | |
| 9 | 5506mm | | 3L/min + 62.65 | 80 | | 2350mm | 100 | 3.062bar | Flow (q) from Route 12 and 32 |
| 10 | 5506mm | | 1217.96L/min | 77.9272 | | | 0.000038 | | |
| | | | | | | 2350mm | | 0.089bar | |
| 10 | 5506mm | | 6L/min + 63.55 | 80 | | 2100mm | 100 | 3.151bar | Flow (q) from Route 23 and 33 |
| 11 | 5506mm | | 1521.87L/min | 77.9272 | | | 0.000057 | | |
| | | | | | | 2100mm | | 0.120bar | |

| Pipe Information | | | | | | | | | |
|------------------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | Total (Millimeter) | | | Friction(Pf) | |
| 11 | 5506mm | | 64.74L/min | 80 | | 2100mm | 100 | 3.271bar | Flow (q) from Route 37 |
| 12 | 5506mm | | 1586.61L/min | 77.9272 | | 2100mm | 0.000062 | 0.129bar | |
| 12 | 5506mm | | 5L/min + 66.01 | 80 | | 933mm | 100 | 3.400bar | Flow (q) from Route 16 and 39 |
| 13 | 5506mm | | 2005.87L/min | 77.9272 | | 933mm | 0.000095 | 0.089bar | |
| 13 | 5506mm | | 4L/min + 58.98 | 80 | | 2100mm | 100 | 3.489bar | Flow (q) from Route 34 and 40 |
| 14 | 5506mm | | 2290.48L/min | 77.9272 | | 2100mm | 0.000122 | 0.255bar | |
| 14 | 5506mm | | 61.09L/min | 80 | (See Notes) | 2100mm | 100 | 3.744bar | Flow (q) from Route 41 T(3260mm) |
| 15 | 5506mm | | 2351.57L/min | 77.9272 | | 3260mm | 0.000128 | 0.684bar | |
| | | | | | 5360mm | | | | |
| 15 | 5506mm | | 66.54L/min | 80 | | 700mm | 100 | 4.429bar | Flow (q) from Route 71 |
| 16 | 5506mm | | 2418.11L/min | 77.9272 | | 700mm | 0.000134 | 0.094bar | |
| 16 | 5506mm | | 67.31L/min | 80 | | 250mm | 100 | 4.523bar | Flow (q) from Route 75 |
| 17 | 5506mm | | 2485.42L/min | 77.9272 | | 250mm | 0.000141 | 0.035bar | |
| 17 | 5506mm | | 66.74L/min | 80 | | 1850mm | 100 | 4.558bar | Flow (q) from Route 72 |
| 18 | 5506mm | | 2552.15L/min | 77.9272 | | 1850mm | 0.000149 | 0.275bar | |
| 18 | 5506mm | | 69.57L/min | 80 | | 2100mm | 100 | 4.833bar | Flow (q) from Route 85 |
| 19 | 5506mm | | 2621.72L/min | 77.9272 | | 2100mm | 0.000156 | 0.328bar | |
| 19 | 5506mm | | 71.88L/min | 80 | (See Notes) | 2131mm | 100 | 5.161bar | Flow (q) from Route 109 T(3260mm) |
| 20 | 5506mm | | 2693.61L/min | 77.9272 | | 3260mm | 0.000164 | 0.885bar | |
| | | | | | 5391mm | | | | |
| 20 | 5506mm | | 77.80L/min | 80 | (See Notes) | 2571mm | 100 | 6.046bar | Flow (q) from Route 119 2E(1600mm) |
| 21 | 5506mm | | 2771.41L/min | 77.9272 | | 3200mm | 0.000173 | 0.999bar | |
| | | | | | 5771mm | | | | |
| 21 | 5506mm | | 83.36L/min | 80 | (See Notes) | 1567mm | 100 | 7.044bar | Flow (q) from Route 120 2E(1600mm), LtE(1087mm) |
| 22 | 5506mm | | 2854.77L/min | 77.9272 | | 4287mm | 0.000183 | 1.070bar | |
| | | | | | 5853mm | | | | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 22 | 5506mm | | | 150 | (See Notes) | 2071mm | 100 | 8.114bar | T(6520mm) |
| 23 | 7577mm | | 2854.77L/min | 154.0510 | | 6520mm | 0.000007 | -0.203bar | |
| | | | | | | 8591mm | | 0.057bar | |
| 23 | 7577mm | | 4460.81L/min | 200 | (See Notes) | 12442mm | 100 | 7.968bar | Flow (q) from Route 42 2LtE(2825mm) |
| 24 | 7577mm | | 7315.58L/min | 202.7174 | | 5650mm | 0.000010 | | |
| | | | | | | 18093mm | | 0.179bar | |
| 24 | 7577mm | | | 200 | (See Notes) | 12120mm | 120 | 8.147bar | 3LtE(4654mm), S |
| 25 | 2637mm | | 7315.58L/min | 209.5246 | | 13962mm | 0.000006 | 0.484bar | |
| | | | | | | 26082mm | | 0.157bar | |
| | | | 0.00L/min | | | | | 8.789bar | Hose Allowance At Source |
| 25 | | | 7315.58L/min | | | | | | Total(Pt) Route 1 |
| 202 | 5306mm | 36Kbar | 48.34L/min | 25 | (See Notes) | 200mm | 100 | 1.803bar | ***** Route 2 ***** Sprinkler, E(435mm) |
| 26 | 5506mm | | 48.34L/min | 26.6446 | | 435mm | 0.000018 | -0.020bar | |
| | | | | | | 635mm | | 0.011bar | |
| 26 | 5506mm | | | 32 | (See Notes) | 550mm | 100 | 1.795bar | T(1304mm) |
| 2 | 5506mm | | 48.34L/min | 35.0520 | | 1304mm | 0.000005 | | |
| | | | | | | 1854mm | | 0.009bar | |
| | | | | | | | | 1.803bar | Total(Pt) Route 2 |
| 203 | 5306mm | 36Kbar | 49.14L/min | 25 | (See Notes) | 200mm | 100 | 1.863bar | ***** Route 3 ***** Sprinkler, E(435mm) |
| 27 | 5506mm | | 49.14L/min | 26.6446 | | 435mm | 0.000019 | -0.020bar | |
| | | | | | | 635mm | | 0.012bar | |
| 27 | 5506mm | | | 32 | (See Notes) | 1166mm | 100 | 1.856bar | |
| 3 | 5506mm | | 49.14L/min | 35.0520 | | | 0.000005 | | |
| | | | | | | 1166mm | | 0.006bar | |
| | | | | | | | | 1.861bar | Total(Pt) Route 3 |
| 204 | 5306mm | 36Kbar | 49.32L/min | 25 | (See Notes) | 200mm | 100 | 1.877bar | ***** Route 4 ***** Sprinkler, T(1087mm) |
| 4 | 5506mm | | 49.32L/min | 26.6446 | | 1087mm | 0.000019 | -0.020bar | |
| | | | | | | 1287mm | | 0.024bar | |
| | | | | | | | | 1.881bar | Total(Pt) Route 4 |
| 205 | 5310mm | 36Kbar | 50.99L/min | 25 | (See Notes) | 196mm | 100 | 2.006bar | ***** Route 5 ***** Sprinkler, T(1087mm) |
| 5 | 5506mm | | 50.99L/min | 26.6446 | | 1087mm | 0.000020 | -0.019bar | |
| | | | | | | 1283mm | | 0.025bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | Total (Millimeter) | | | Friction(Pf) | |
| | | | | | | | | 2.013bar | Total(Pt) Route 5 |
| 206 | 5306mm | 36Kbar | 53.41L/min | 25 | (See Notes) | 200mm | 100 | 2.202bar | ••••• Route 6 ••••• Sprinkler, T(1087mm) |
| 28 | 5506mm | | 53.41L/min | 26.6446 | | 1087mm | 0.000022 | -0.020bar | |
| | | | | | | 1287mm | | 0.028bar | |
| 28 | 5506mm | | 53.47L/min | 32 | | 2100mm | 100 | 2.210bar | Flow (q) from Route 8 |
| 29 | 5506mm | | 106.88L/min | 35.0520 | | 2100mm | 0.000021 | 0.043bar | |
| 29 | 5506mm | | 53.93L/min | 32 | | 2100mm | 100 | 2.253bar | Flow (q) from Route 9 |
| 30 | 5506mm | | 160.81L/min | 35.0520 | | 2100mm | 0.000044 | 0.092bar | |
| 30 | 5506mm | | 55.01L/min | 32 | | 851mm | 100 | 2.345bar | Flow (q) from Route 10 |
| 31 | 5506mm | | 215.82L/min | 35.0520 | | 851mm | 0.000075 | 0.064bar | |
| 31 | 5506mm | | 55.07L/min | 32 | | 1249mm | 100 | 2.409bar | Flow (q) from Route 11 |
| 32 | 5506mm | | 270.89L/min | 35.0520 | | 1249mm | 0.000115 | 0.143bar | |
| 32 | 5506mm | | 57.37L/min | 32 | (See Notes) | 1302mm | 100 | 2.552bar | Flow (q) from Route 17 PO(1304mm) |
| 33 | 5506mm | | 328.27L/min | 35.0520 | | 1304mm | 0.000164 | | |
| | | | | | | 2606mm | | 0.426bar | |
| 33 | 5506mm | | 61.80L/min | 80 | | 2117mm | 100 | 2.979bar | Flow (q) from Route 29 |
| 34 | 5506mm | | 390.06L/min | 77.9272 | | 2117mm | 0.000005 | 0.010bar | |
| 34 | 5506mm | | 61.90L/min | 80 | | 2100mm | 100 | 2.988bar | Flow (q) from Route 30 |
| 8 | 5506mm | | 451.96L/min | 77.9272 | | 2100mm | 0.000006 | 0.013bar | |
| | | | | | | | | 3.001bar | Total(Pt) Route 6 |
| 207 | 5310mm | 36Kbar | 53.47L/min | 25 | (See Notes) | 196mm | 100 | 2.206bar | ••••• Route 7 ••••• Sprinkler, T(1087mm) |
| 6 | 5506mm | | 53.47L/min | 26.6446 | | 1087mm | 0.000022 | -0.019bar | |
| | | | | | | 1283mm | | 0.028bar | |
| | | | | | | | | 2.214bar | Total(Pt) Route 7 |
| 208 | 5306mm | 36Kbar | 53.47L/min | 25 | (See Notes) | 200mm | 100 | 2.206bar | ••••• Route 8 ••••• Sprinkler, E(435mm) |
| 35 | 5506mm | | 53.47L/min | 26.6446 | | 435mm | 0.000022 | -0.020bar | |
| | | | | | | 635mm | | 0.014bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 35 | 5506mm | | | 32 | | 1716mm | 100 | 2.200bar | |
| 28 | 5506mm | | 53.47L/min | 35.0520 | | 1716mm | 0.000006 | 0.010bar | |
| | | | | | | | | 2.210bar | Total(Pt) Route 8 |
| 209 | 5306mm | 36Kbar | 53.93L/min | 25 | (See Notes) | 200mm | 100 | 2.244bar | ***** Route 9 ***** Sprinkler, T(1087mm) |
| 29 | 5506mm | | 53.93L/min | 26.6446 | | 1087mm | 0.000022 | -0.020bar | |
| | | | | | | 1287mm | | 0.028bar | |
| | | | | | | | | 2.253bar | Total(Pt) Route 9 |
| 210 | 5306mm | 36Kbar | 55.01L/min | 25 | (See Notes) | 200mm | 100 | 2.335bar | ***** Route 10 ***** Sprinkler, T(1087mm) |
| 30 | 5506mm | | 55.01L/min | 26.6446 | | 1087mm | 0.000023 | -0.020bar | |
| | | | | | | 1287mm | | 0.029bar | |
| | | | | | | | | 2.345bar | Total(Pt) Route 10 |
| 211 | 5310mm | 36Kbar | 55.07L/min | 25 | (See Notes) | 2313mm | 100 | 2.340bar | ***** Route 11 ***** Sprinkler, E(435mm), T(1087mm) |
| 31 | 5506mm | | 55.07L/min | 26.6446 | | 1521mm | 0.000023 | -0.019bar | |
| | | | | | | 3834mm | | 0.088bar | |
| | | | | | | | | 2.409bar | Total(Pt) Route 11 |
| 212 | 5306mm | 36Kbar | 55.83L/min | 25 | (See Notes) | 200mm | 100 | 2.405bar | ***** Route 12 ***** Sprinkler, T(1087mm) |
| 36 | 5506mm | | 55.83L/min | 26.6446 | | 1087mm | 0.000023 | -0.020bar | |
| | | | | | | 1287mm | | 0.030bar | |
| 36 | 5506mm | | 55.88L/min | 32 | | 2100mm | 100 | 2.416bar | Flow (q) from Route 13 |
| 37 | 5506mm | | 111.71L/min | 35.0520 | | 2100mm | 0.000022 | 0.047bar | |
| 37 | 5506mm | | 56.36L/min | 32 | | 2100mm | 100 | 2.462bar | Flow (q) from Route 14 |
| 38 | 5506mm | | 168.08L/min | 35.0520 | | 2100mm | 0.000047 | 0.100bar | |
| 38 | 5506mm | | 57.48L/min | 32 | | 2100mm | 100 | 2.562bar | Flow (q) from Route 18 |
| 39 | 5506mm | | 225.56L/min | 35.0520 | | 2100mm | 0.000082 | 0.172bar | |
| 39 | 5506mm | | 59.37L/min | 32 | (See Notes) | 1302mm | 100 | 2.734bar | Flow (q) from Route 22 PO(1304mm) |
| 9 | 5506mm | | 284.93L/min | 35.0520 | | 1304mm | 0.000126 | | |
| | | | | | | 2606mm | | 0.328bar | |
| | | | | | | | | 3.062bar | Total(Pt) Route 12 |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 213 | 5306mm | 36Kbar | 55.88L/min | 25 | (See Notes) | 200mm | 100 | 2.410bar | ••••• Route 13 ••••• Sprinkler, E(435mm) |
| 40 | 5506mm | | 55.88L/min | 26.6446 | | 435mm | 0.000024 | -0.020bar | |
| | | | | | | 635mm | | 0.015bar | |
| 40 | 5506mm | | | 32 | | 1716mm | 100 | 2.405bar | |
| 36 | 5506mm | | 55.88L/min | 35.0520 | | 1716mm | 0.000006 | 0.011bar | |
| | | | | | | | | 2.416bar | Total(Pt) Route 13 |
| 214 | 5306mm | 36Kbar | 56.36L/min | 25 | (See Notes) | 200mm | 100 | 2.451bar | ••••• Route 14 ••••• Sprinkler, T(1087mm) |
| 37 | 5506mm | | 56.36L/min | 26.6446 | | 1087mm | 0.000024 | -0.020bar | |
| | | | | | | 1287mm | | 0.031bar | |
| | | | | | | | | 2.462bar | Total(Pt) Route 14 |
| 215 | 5310mm | 36Kbar | 56.84L/min | 25 | (See Notes) | 196mm | 100 | 2.492bar | ••••• Route 15 ••••• Sprinkler, T(1087mm) |
| 7 | 5506mm | | 56.84L/min | 26.6446 | | 1087mm | 0.000024 | -0.019bar | |
| | | | | | | 1283mm | | 0.031bar | |
| | | | | | | | | 2.504bar | Total(Pt) Route 15 |
| 216 | 5306mm | 36Kbar | 56.96L/min | 25 | (See Notes) | 2518mm | 100 | 2.504bar | ••••• Route 16 ••••• Sprinkler, 2E(435mm) |
| 41 | 5506mm | | 56.96L/min | 26.6446 | | 869mm | 0.000024 | -0.020bar | |
| | | | | | | 3387mm | | 0.083bar | |
| 41 | 5506mm | | 57.53L/min | 32 | | 2100mm | 100 | 2.567bar | Flow (q) from Route 19 |
| 42 | 5506mm | | 114.50L/min | 35.0520 | | 2100mm | 0.000023 | 0.049bar | |
| 42 | 5506mm | | 58.08L/min | 32 | | 2100mm | 100 | 2.615bar | Flow (q) from Route 20 |
| 43 | 5506mm | | 172.57L/min | 35.0520 | | 2100mm | 0.000050 | 0.105bar | |
| 43 | 5506mm | | 59.22L/min | 32 | | 1852mm | 100 | 2.720bar | Flow (q) from Route 21 |
| 44 | 5506mm | | 231.79L/min | 35.0520 | | 1852mm | 0.000086 | 0.159bar | |
| 44 | 5506mm | | 60.20L/min | 32 | | 248mm | 100 | 2.879bar | Flow (q) from Route 26 |
| 45 | 5506mm | | 291.99L/min | 35.0520 | | 248mm | 0.000132 | 0.033bar | |
| 45 | 5506mm | | 61.26L/min | 32 | (See Notes) | 1300mm | 100 | 2.912bar | Flow (q) from Route 28 PO(1304mm) |
| 12 | 5506mm | | 353.25L/min | 35.0520 | | 1304mm | 0.000187 | | |
| | | | | | | 2604mm | | 0.488bar | |

| Pipe Information | | | | | | | | | |
|------------------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| | | | | | | | | 3.400bar | Total(Pt) Route 16 |
| 217 | 5306mm | 36Kbar | 57.37L/min | 25 | (See Notes) | 200mm | 100 | 2.540bar | Route 17 Sprinkler, T(1087mm) |
| 32 | 5506mm | | 57.37L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| | | | | | | | | 2.552bar | Total(Pt) Route 17 |
| 218 | 5306mm | 36Kbar | 57.48L/min | 25 | (See Notes) | 200mm | 100 | 2.550bar | Route 18 Sprinkler, T(1087mm) |
| 38 | 5506mm | | 57.48L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| | | | | | | | | 2.562bar | Total(Pt) Route 18 |
| 219 | 5306mm | 36Kbar | 57.53L/min | 25 | (See Notes) | 200mm | 100 | 2.554bar | Route 19 Sprinkler, T(1087mm) |
| 41 | 5506mm | | 57.53L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| | | | | | | | | 2.567bar | Total(Pt) Route 19 |
| 220 | 5306mm | 36Kbar | 58.08L/min | 25 | (See Notes) | 200mm | 100 | 2.603bar | Route 20 Sprinkler, T(1087mm) |
| 42 | 5506mm | | 58.08L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| | | | | | | | | 2.615bar | Total(Pt) Route 20 |
| 221 | 5306mm | 36Kbar | 59.22L/min | 25 | (See Notes) | 200mm | 100 | 2.706bar | Route 21 Sprinkler, T(1087mm) |
| 43 | 5506mm | | 59.22L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.034bar | |
| | | | | | | | | 2.720bar | Total(Pt) Route 21 |
| 222 | 5306mm | 36Kbar | 59.37L/min | 25 | (See Notes) | 200mm | 100 | 2.719bar | Route 22 Sprinkler, T(1087mm) |
| 39 | 5506mm | | 59.37L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.034bar | |
| | | | | | | | | 2.734bar | Total(Pt) Route 22 |
| 223 | 5306mm | 36Kbar | 59.51L/min | 25 | (See Notes) | 200mm | 100 | 2.732bar | Route 23 Sprinkler, T(1087mm) |
| 46 | 5506mm | | 59.51L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.034bar | |
| 46 | 5506mm | | 59.53L/min | 32 | | 2100mm | 100 | 2.747bar | Flow (q) from Route 24 |
| 47 | 5506mm | | 119.04L/min | 35.0520 | | 2100mm | 0.000025 | 0.053bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. | |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|------------|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | | |
| | | | | | Total (Millimeter) | | | Friction(Pf) | | |
| 47 | 5506mm | | 60.07L/min | 32 | | 2100mm | 100 | 2.799bar | Flow (q) from Route 25 | |
| 48 | 5506mm | | 179.11L/min | 35.0520 | | 2100mm | 0.000053 | 0.112bar | | |
| 48 | 5506mm | | 61.25L/min | 32 | (See Notes) | 1300mm | 100 | 2.911bar | Flow (q) from Route 27 | |
| | | | | | | 1304mm | 0.000092 | | | |
| 10 | 5506mm | | 240.36L/min | 35.0520 | | 2604mm | | | 0.239bar | PO(1304mm) |
| | | | | | | | | 3.151bar | Total(Pt) Route 23 | |
| 224 | 5306mm | 36Kbar | 59.53L/min | 25 | (See Notes) | 200mm | 100 | 2.735bar | Route 24 Sprinkler, E(435mm) | |
| 49 | 5506mm | | 59.53L/min | 26.6446 | | 435mm | 0.000026 | -0.020bar | | |
| | | | | | | 635mm | | 0.017bar | | |
| 49 | 5506mm | | | 32 | | 2100mm | 100 | 2.732bar | | |
| 46 | 5506mm | | 59.53L/min | 35.0520 | | 2100mm | 0.000007 | 0.015bar | | |
| | | | | | | | | 2.747bar | Total(Pt) Route 24 | |
| 225 | 5306mm | 36Kbar | 60.07L/min | 25 | (See Notes) | 200mm | 100 | 2.784bar | Route 25 Sprinkler, T(1087mm) | |
| 47 | 5506mm | | 60.07L/min | 26.6446 | | 1087mm | 0.000027 | -0.020bar | | |
| | | | | | | 1287mm | | 0.035bar | | |
| | | | | | | | | 2.799bar | Total(Pt) Route 25 | |
| 226 | 5304mm | 36Kbar | 60.20L/min | 25 | (See Notes) | 2302mm | 100 | 2.796bar | Route 26 Sprinkler, E(435mm), T(1087mm) | |
| 44 | 5506mm | | 60.20L/min | 26.6446 | | 1521mm | 0.000027 | -0.020bar | | |
| | | | | | | 3824mm | | 0.103bar | | |
| | | | | | | | | 2.879bar | Total(Pt) Route 26 | |
| 227 | 5306mm | 36Kbar | 61.25L/min | 25 | (See Notes) | 200mm | 100 | 2.895bar | Route 27 Sprinkler, T(1087mm) | |
| 48 | 5506mm | | 61.25L/min | 26.6446 | | 1087mm | 0.000028 | -0.020bar | | |
| | | | | | | 1287mm | | 0.036bar | | |
| | | | | | | | | 2.911bar | Total(Pt) Route 27 | |
| 228 | 5306mm | 36Kbar | 61.26L/min | 25 | (See Notes) | 200mm | 100 | 2.896bar | Route 28 Sprinkler, T(1087mm) | |
| 45 | 5506mm | | 61.26L/min | 26.6446 | | 1087mm | 0.000028 | -0.020bar | | |
| | | | | | | 1287mm | | 0.036bar | | |
| | | | | | | | | 2.912bar | Total(Pt) Route 28 | |
| 229 | 5306mm | 36Kbar | 61.80L/min | 25 | (See Notes) | 200mm | 100 | 2.947bar | Route 29 Sprinkler, T(1087mm) | |
| 50 | 5506mm | | 61.80L/min | 26.6446 | | 1087mm | 0.000028 | -0.020bar | | |
| | | | | | | 1287mm | | 0.036bar | | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 50 | 5506mm | | | 32 | (See Notes) | 700mm | 100 | 2.964bar | PO(1304mm) |
| 33 | 5506mm | | 61.80L/min | 35.0520 | | 1304mm | 0.000007 | | |
| | | | | | | 2004mm | | 0.015bar | |
| | | | | | | | | 2.979bar | Total(Pt) Route 29 |
| 230 | 5310mm | 36Kbar | 61.90L/min | 25 | (See Notes) | 196mm | 100 | 2.956bar | ••••• Route 30 ••••• Sprinkler, T(1087mm) |
| 51 | 5506mm | | 61.90L/min | 26.6446 | | 1087mm | 0.000028 | -0.019bar | |
| | | | | | | 1283mm | | 0.036bar | |
| 51 | 5506mm | | | 32 | (See Notes) | 700mm | 100 | 2.973bar | PO(1304mm) |
| 34 | 5506mm | | 61.90L/min | 35.0520 | | 1304mm | 0.000007 | | |
| | | | | | | 2004mm | | 0.015bar | |
| | | | | | | | | 2.988bar | Total(Pt) Route 30 |
| 231 | 5310mm | 36Kbar | 62.03L/min | 25 | (See Notes) | 196mm | 100 | 2.969bar | ••••• Route 31 ••••• Sprinkler, T(1087mm) |
| 52 | 5506mm | | 62.03L/min | 26.6446 | | 1087mm | 0.000029 | -0.019bar | |
| | | | | | | 1283mm | | 0.037bar | |
| 52 | 5506mm | | | 32 | (See Notes) | 700mm | 100 | 2.986bar | PO(1304mm) |
| 8 | 5506mm | | 62.03L/min | 35.0520 | | 1304mm | 0.000008 | | |
| | | | | | | 2004mm | | 0.015bar | |
| | | | | | | | | 3.001bar | Total(Pt) Route 31 |
| 232 | 5306mm | 36Kbar | 62.65L/min | 25 | (See Notes) | 200mm | 100 | 3.029bar | ••••• Route 32 ••••• Sprinkler, T(1087mm) |
| 53 | 5506mm | | 62.65L/min | 26.6446 | | 1087mm | 0.000029 | -0.020bar | |
| | | | | | | 1287mm | | 0.037bar | |
| 53 | 5506mm | | | 32 | (See Notes) | 700mm | 100 | 3.047bar | PO(1304mm) |
| 9 | 5506mm | | 62.65L/min | 35.0520 | | 1304mm | 0.000008 | | |
| | | | | | | 2004mm | | 0.015bar | |
| | | | | | | | | 3.062bar | Total(Pt) Route 32 |
| 233 | 5306mm | 36Kbar | 63.55L/min | 25 | (See Notes) | 200mm | 100 | 3.116bar | ••••• Route 33 ••~••• Sprinkler, T(1087mm) |
| 54 | 5506mm | | 63.55L/min | 26.6446 | | 1087mm | 0.000030 | -0.020bar | |
| | | | | | | 1287mm | | 0.038bar | |
| 54 | 5506mm | | | 32 | (See Notes) | 700mm | 100 | 3.135bar | PO(1304mm) |
| 10 | 5506mm | | 63.55L/min | 35.0520 | | 1304mm | 0.000008 | | |
| | | | | | | 2004mm | | 0.016bar | |
| | | | | | | | | 3.151bar | Total(Pt) Route 33 |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 234 | 5306mm | 31.7Kbar | 55.98L/min | 25 | (See Notes) | 200mm | 100 | 3.118bar | ••••• Route 34 ••••• Sprinkler, T(1087mm) |
| 55 | 5506mm | | 55.98L/min | 26.6446 | | 1087mm | 0.000024 | -0.020bar | |
| | | | | | | 1287mm | | 0.030bar | |
| 55 | 5506mm | | 56.00L/min | 32 | | 2100mm | 100 | 3.129bar | Flow (q) from Route 35 |
| 56 | 5506mm | | 111.98L/min | 35.0520 | | 2100mm | 0.000022 | 0.047bar | |
| 56 | 5506mm | | 56.39L/min | 32 | | 2100mm | 100 | 3.176bar | Flow (q) from Route 36 |
| 57 | 5506mm | | 168.37L/min | 35.0520 | | 2100mm | 0.000048 | 0.100bar | |
| 57 | 5506mm | | 57.27L/min | 32 | (See Notes) | 1300mm | 100 | 3.276bar | Flow (q) from Route 38 PO(1304mm) |
| | | | | | | 1304mm | 0.000082 | | |
| 13 | 5506mm | | 225.64L/min | 35.0520 | | 2604mm | | 0.213bar | |
| | | | | | | | | 3.489bar | Total(Pt) Route 34 |
| 235 | 5306mm | 31.7Kbar | 56.00L/min | 25 | (See Notes) | 200mm | 100 | 3.121bar | ••••• Route 35 ••••• Sprinkler, E(435mm) |
| 58 | 5506mm | | 56.00L/min | 26.6446 | | 435mm | 0.000024 | -0.020bar | |
| | | | | | | 635mm | | 0.015bar | |
| 58 | 5506mm | | | 32 | | 2100mm | 100 | 3.116bar | |
| 55 | 5506mm | | 56.00L/min | 35.0520 | | 2100mm | 0.000006 | 0.013bar | |
| | | | | | | | | 3.129bar | Total(Pt) Route 35 |
| 236 | 5306mm | 31.7Kbar | 56.39L/min | 25 | (See Notes) | 200mm | 100 | 3.165bar | ••••• Route 36 ••••• Sprinkler, T(1087mm) |
| 56 | 5506mm | | 56.39L/min | 26.6446 | | 1087mm | 0.000024 | -0.020bar | |
| | | | | | | 1287mm | | 0.031bar | |
| | | | | | | | | 3.176bar | Total(Pt) Route 36 |
| 237 | 5304mm | 36Kbar | 64.74L/min | 25 | (See Notes) | 202mm | 100 | 3.234bar | ••••• Route 37 ••••• Sprinkler, T(1087mm) |
| 59 | 5506mm | | 64.74L/min | 26.6446 | | 1087mm | 0.000031 | -0.020bar | |
| | | | | | | 1289mm | | 0.040bar | |
| 59 | 5506mm | | | 32 | (See Notes) | 700mm | 100 | 3.254bar | PO(1304mm) |
| | | | | | | 1304mm | 0.000008 | | |
| 11 | 5506mm | | 64.74L/min | 35.0520 | | 2004mm | | 0.016bar | |
| | | | | | | | | 3.271bar | Total(Pt) Route 37 |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 238 | 5306mm | 31.7Kbar | 57.27L/min | 25 | (See Notes) | 200mm | 100 | 3.264bar | ***** Route 38 ***** Sprinkler, T(1087mm) |
| 57 | 5506mm | | 57.27L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| | | | | | | | | 3.276bar | Total(Pt) Route 38 |
| 239 | 5306mm | 36Kbar | 66.01L/min | 25 | (See Notes) | 200mm | 100 | 3.362bar | ***** Route 39 ***** Sprinkler, T(1087mm) |
| 60 | 5506mm | | 66.01L/min | 26.6446 | | 1087mm | 0.000032 | -0.020bar | |
| | | | | | | 1287mm | | 0.041bar | |
| 60 | 5506mm | | | 32 | (See Notes) | 700mm | 100 | 3.383bar | PO(1304mm) |
| 12 | 5506mm | | 66.01L/min | 35.0520 | | 1304mm | 0.000008 | | |
| | | | | | | 2004mm | | 0.017bar | |
| | | | | | | | | 3.400bar | Total(Pt) Route 39 |
| 240 | 5306mm | 31.7Kbar | 58.98L/min | 25 | (See Notes) | 200mm | 100 | 3.461bar | ***** Route 40 ***** Sprinkler, T(1087mm) |
| 61 | 5506mm | | 58.98L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.033bar | |
| 61 | 5506mm | | | 32 | (See Notes) | 700mm | 100 | 3.475bar | PO(1304mm) |
| 13 | 5506mm | | 58.98L/min | 35.0520 | | 1304mm | 0.000007 | | |
| | | | | | | 2004mm | | 0.014bar | |
| | | | | | | | | 3.489bar | Total(Pt) Route 40 |
| 241 | 5304mm | 31.7Kbar | 61.09L/min | 25 | (See Notes) | 202mm | 100 | 3.714bar | ***** Route 41 ***** Sprinkler, T(1087mm) |
| 62 | 5506mm | | 61.09L/min | 26.6446 | | 1087mm | 0.000028 | -0.020bar | |
| | | | | | | 1289mm | | 0.036bar | |
| 62 | 5506mm | | | 32 | (See Notes) | 700mm | 100 | 3.730bar | PO(1304mm) |
| 14 | 5506mm | | 61.09L/min | 35.0520 | | 1304mm | 0.000007 | | |
| | | | | | | 2004mm | | 0.015bar | |
| | | | | | | | | 3.744bar | Total(Pt) Route 41 |
| 242 | 14856mm | 28.8Kbar | 57.39L/min | 25 | (See Notes) | 200mm | 100 | 3.971bar | ***** Route 42 ***** Sprinkler, T(1087mm) |
| 63 | 15056mm | | 57.39L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| 63 | 15056mm | | 57.41L/min | 32 | | 2100mm | 100 | 3.983bar | Flow (q) from Route 43 |
| 64 | 15056mm | | 114.80L/min | 35.0520 | | 2100mm | 0.000023 | 0.049bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|-----------------------|------------------------|--------------|--------------------------------|-------------------|-----------------------|------------------------|-------------------------|---------------------------------------|--|
| | Node 2 | | Elev 2 (Millimeter) | Total Flow (Q) | | Actual ID | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | |
| Total (Millimeter) | | Friction(Pf) | | | | | | | |
| 64 | 15056mm | | 57.74L/min | 32 | (See Notes) | 2866mm | 100 | 4.032bar | Flow (q) from Route 50 2E(652mm) |
| 65 | 15056mm | | 172.54L/min | 35.0520 | | 1304mm | 0.000050 | | |
| | | | | | | 4170mm | | 0.208bar | |
| 65 | 15056mm | | 59.20L/min | 32 | (See Notes) | 1300mm | 100 | 4.240bar | Flow (q) from Route 60 PO(1304mm) |
| 66 | 15056mm | | 231.75L/min | 35.0520 | | 1304mm | 0.000086 | | |
| | | | | | | 2604mm | | 0.224bar | |
| 66 | 15056mm | | 936.14L/min | 80 | | 2120mm | 100 | 4.464bar | Flow (q) from Route 44 |
| 67 | 15056mm | | 1167.88L/min | 77.9272 | | 2120mm | 0.000035 | 0.074bar | |
| | | | | | | | | | |
| 67 | 15056mm | | 235.48L/min | 80 | | 213mm | 100 | 4.538bar | Flow (q) from Route 54 |
| 68 | 15056mm | | 1403.37L/min | 77.9272 | | 213mm | 0.000049 | 0.010bar | |
| | | | | | | | | | |
| 68 | 15056mm | | 61.36L/min | 80 | | 1901mm | 100 | 4.548bar | Flow (q) from Route 76 |
| 69 | 15056mm | | 1464.72L/min | 77.9272 | | 1901mm | 0.000053 | 0.101bar | |
| | | | | | | | | | |
| 69 | 15056mm | | 238.37L/min | 80 | | 400mm | 100 | 4.649bar | Flow (q) from Route 61 |
| 70 | 15056mm | | 1703.09L/min | 77.9272 | | 400mm | 0.000070 | 0.028bar | |
| | | | | | | | | | |
| 70 | 15056mm | | 62.22L/min | 80 | | 2116mm | 100 | 4.678bar | Flow (q) from Route 78 |
| 71 | 15056mm | | 1765.30L/min | 77.9272 | | 2116mm | 0.000075 | 0.159bar | |
| | | | | | | | | | |
| 71 | 15056mm | | 243.13L/min | 80 | | 385mm | 100 | 4.837bar | Flow (q) from Route 69 |
| 72 | 15056mm | | 2008.43L/min | 77.9272 | | 385mm | 0.000095 | 0.037bar | |
| | | | | | | | | | |
| 72 | 15056mm | | 63.50L/min | 80 | (See Notes) | 894mm | 100 | 4.873bar | Flow (q) from Route 88 T(4100mm) |
| 73 | 15056mm | | 2071.93L/min | 77.9272 | | 4100mm | 0.000101 | | |
| | | | | | | 4994mm | | 0.505bar | |
| 73 | 15056mm | | 322.52L/min | 80 | (See Notes) | 8800mm | 100 | 5.378bar | Flow (q) from Route 90 EE(652mm) |
| 74 | 15056mm | | 2394.46L/min | 77.9272 | | 652mm | 0.000132 | | |
| | | | | | | 9452mm | | 1.248bar | |
| 74 | 15056mm | | | 80 | (See Notes) | 219mm | 120 | 6.626bar | PO(6145mm) |
| 75 | 15056mm | | 2394.46L/min | 82.8040 | | 6145mm | 0.000070 | | |
| | | | | | | 6364mm | | 0.446bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | Total (Millimeter) | | | Friction(Pf) | |
| 75 | 15056mm | | 2066.35L/min | 150 | (See Notes) | 7479mm | 120 | 7.072bar | Flow (q) from Route 79 T(11497mm) |
| 23 | 7577mm | | 4460.81L/min | 161.4678 | | 11497mm | 0.000009 | 0.733bar | |
| | | | | | | 18976mm | | 0.163bar | |
| | | | | | | | | 7.968bar | Total(Pt) Route 42 |
| 243 | 14854mm | 28.8Kbar | 57.41L/min | 25 | (See Notes) | 202mm | 100 | 3.974bar | ••••• Route 43 ••••• Sprinkler, E(435mm) |
| 76 | 15056mm | | 57.41L/min | 26.6446 | | 435mm | 0.000025 | -0.020bar | |
| | | | | | | 637mm | | 0.016bar | |
| 76 | 15056mm | | | 32 | | 2100mm | 100 | 3.969bar | |
| 63 | 15056mm | | 57.41L/min | 35.0520 | | | 0.000007 | | |
| | | | | | | 2100mm | | 0.014bar | |
| | | | | | | | | 3.983bar | Total(Pt) Route 43 |
| 244 | 14856mm | 28.8Kbar | 57.42L/min | 25 | (See Notes) | 200mm | 100 | 3.975bar | ••••• Route 44 ••••• Sprinkler, T(1087mm) |
| 77 | 15056mm | | 57.42L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| 77 | 15056mm | | 57.44L/min | 32 | | 2100mm | 100 | 3.988bar | Flow (q) from Route 45 |
| 78 | 15056mm | | 114.86L/min | 35.0520 | | | 0.000023 | | |
| | | | | | | 2100mm | | 0.049bar | |
| 78 | 15056mm | | 57.77L/min | 32 | | 2100mm | 100 | 4.037bar | Flow (q) from Route 51 |
| 79 | 15056mm | | 172.64L/min | 35.0520 | | | 0.000050 | | |
| | | | | | | 2100mm | | 0.105bar | |
| 79 | 15056mm | | 58.52L/min | 32 | (See Notes) | 1400mm | 100 | 4.142bar | Flow (q) from Route 55 PO(1304mm) |
| 80 | 15056mm | | 231.15L/min | 35.0520 | | 1304mm | 0.000086 | | |
| | | | | | | 2704mm | | 0.231bar | |
| 80 | 15056mm | | | 80 | | 163mm | 100 | 4.373bar | |
| 81 | 15056mm | | 231.15L/min | 77.9272 | | | 0.000002 | | |
| | | | | | | 163mm | | 0.000bar | |
| 81 | 15056mm | | 60.17L/min | 80 | | 2599mm | 100 | 4.373bar | Flow (q) from Route 65 |
| 82 | 15056mm | | 291.32L/min | 77.9272 | | | 0.000003 | | |
| | | | | | | 2599mm | | 0.007bar | |
| 82 | 15056mm | | 60.21L/min | 80 | | 168mm | 100 | 4.380bar | Flow (q) from Route 66 |
| 83 | 15056mm | | 351.54L/min | 77.9272 | | | 0.000004 | | |
| | | | | | | 168mm | | 0.001bar | |

| Pipe Information | | | | | | | | | |
|------------------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 83 | 15056mm | | 231.36L/min | 80 | | 2333mm | 100 | 4.381bar | Flow (q) from Route 46 |
| 84 | 15056mm | | 582.90L/min | 77.9272 | | 2333mm | 0.000010 | 0.023bar | |
| 84 | 15056mm | | 60.37L/min | 80 | | 167mm | 100 | 4.403bar | Flow (q) from Route 68 |
| 85 | 15056mm | | 643.27L/min | 77.9272 | | 167mm | 0.000012 | 0.002bar | |
| 85 | 15056mm | | 232.14L/min | 80 | | 2434mm | 100 | 4.405bar | Flow (q) from Route 48 |
| 86 | 15056mm | | 875.41L/min | 77.9272 | | 2434mm | 0.000021 | 0.050bar | |
| 86 | 15056mm | | 60.73L/min | 80 | | 366mm | 100 | 4.455bar | Flow (q) from Route 73 |
| 66 | 15056mm | | 936.14L/min | 77.9272 | | 366mm | 0.000023 | 0.009bar | |
| | | | | | | | | 4.464bar | Total(Pt) Route 44 |
| 245 | 14856mm | 28.8Kbar | 57.44L/min | 25 | (See Notes) | 200mm | 100 | 3.978bar | Route 45 Sprinkler, E(435mm) |
| 87 | 15056mm | | 57.44L/min | 26.6446 | | 435mm | 0.000025 | -0.020bar | |
| | | | | | | 635mm | | 0.016bar | |
| 87 | 15056mm | | | 32 | | 2100mm | 100 | 3.974bar | |
| 77 | 15056mm | | 57.44L/min | 35.0520 | | 2100mm | 0.000007 | 0.014bar | |
| | | | | | | | | 3.988bar | Total(Pt) Route 45 |
| 246 | 14856mm | 28.8Kbar | 57.47L/min | 25 | (See Notes) | 200mm | 100 | 3.983bar | Route 46 Sprinkler, T(1087mm) |
| 88 | 15056mm | | 57.47L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| 88 | 15056mm | | 57.49L/min | 32 | | 2100mm | 100 | 3.995bar | Flow (q) from Route 47 |
| 89 | 15056mm | | 114.97L/min | 35.0520 | | 2100mm | 0.000023 | 0.049bar | |
| 89 | 15056mm | | 57.83L/min | 32 | | 2100mm | 100 | 4.044bar | Flow (q) from Route 52 |
| 90 | 15056mm | | 172.79L/min | 35.0520 | | 2100mm | 0.000050 | 0.105bar | |
| 90 | 15056mm | | 58.57L/min | 32 | (See Notes) | 1400mm | 100 | 4.149bar | Flow (q) from Route 57 PO(1304mm) |
| 83 | 15056mm | | 231.36L/min | 35.0520 | | 1304mm | 0.000086 | | |
| | | | | | | 2704mm | | 0.232bar | |
| | | | | | | | | 4.381bar | Total(Pt) Route 46 |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 247 | 14856mm | 28.8Kbar | 57.49L/min | 25 | (See Notes) | 200mm | 100 | 3.985bar | ••••• Route 47 ••••• Sprinkler, E(435mm) |
| 91 | 15056mm | | 57.49L/min | 26.6446 | | 435mm | 0.000025 | -0.020bar | |
| | | | | | | 635mm | | 0.016bar | |
| 91 | 15056mm | | | 32 | | 2100mm | 100 | 3.981bar | |
| 88 | 15056mm | | 57.49L/min | 35.0520 | | 2100mm | 0.000007 | 0.014bar | |
| | | | | | | | | 3.995bar | Total(Pt) Route 47 |
| 248 | 14856mm | 28.8Kbar | 57.66L/min | 25 | (See Notes) | 200mm | 100 | 4.008bar | ••••• Route 48 ••••• Sprinkler, T(1087mm) |
| 92 | 15056mm | | 57.66L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| 92 | 15056mm | | 57.68L/min | 32 | | 2100mm | 100 | 4.021bar | Flow (q) from Route 49 |
| 93 | 15056mm | | 115.34L/min | 35.0520 | | 2100mm | 0.000024 | 0.050bar | |
| 93 | 15056mm | | 58.01L/min | 32 | | 2200mm | | 100 | 4.070bar |
| 94 | 15056mm | | 173.35L/min | 35.0520 | | 2200mm | 0.000050 | 0.110bar | |
| 94 | 15056mm | | 58.79L/min | 32 | (See Notes) | 1300mm | | 100 | 4.181bar |
| 85 | 15056mm | | 232.14L/min | 35.0520 | | 1304mm | 0.000086 | | |
| | | | | | | 2604mm | | 0.224bar | |
| | | | | | | | | 4.405bar | Total(Pt) Route 48 |
| 249 | 14856mm | 28.8Kbar | 57.68L/min | 25 | (See Notes) | 200mm | 100 | 4.011bar | ••••• Route 49 ••••• Sprinkler, E(435mm) |
| 95 | 15056mm | | 57.68L/min | 26.6446 | | 435mm | 0.000025 | -0.020bar | |
| | | | | | | 635mm | | 0.016bar | |
| 95 | 15056mm | | | 32 | | 2100mm | 100 | 4.007bar | |
| 92 | 15056mm | | 57.68L/min | 35.0520 | | 2100mm | 0.000007 | 0.014bar | |
| | | | | | | | | 4.021bar | Total(Pt) Route 49 |
| 250 | 14856mm | 28.8Kbar | 57.74L/min | 25 | (See Notes) | 200mm | 100 | 4.020bar | ••••• Route 50 ••••• Sprinkler, T(1087mm) |
| 64 | 15056mm | | 57.74L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| | | | | | | | | 4.032bar | Total(Pt) Route 50 |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes |
|--------|------------------------|----------|--------------------------------|------------|-----------------------|------------------------|----------|-----------|---|
| | | | | | | | | | |
| 251 | 14856mm | 28.8Kbar | 57.77L/min | 25 | (See Notes) | 200mm | 100 | 4.024bar | ***** Route 51 ***** Sprinkler, T(1087mm) |
| 78 | 15056mm | | 57.77L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| | | | | | | | | 4.037bar | Total(Pt) Route 51 |
| 252 | 14856mm | 28.8Kbar | 57.83L/min | 25 | (See Notes) | 200mm | 100 | 4.032bar | ***** Route 52 ***** Sprinkler, T(1087mm) |
| 89 | 15056mm | | 57.83L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| | | | | | | | | 4.044bar | Total(Pt) Route 52 |
| 253 | 14856mm | 28.8Kbar | 58.01L/min | 25 | (See Notes) | 200mm | 100 | 4.057bar | ***** Route 53 ***** Sprinkler, T(1087mm) |
| 93 | 15056mm | | 58.01L/min | 26.6446 | | 1087mm | 0.000025 | -0.020bar | |
| | | | | | | 1287mm | | 0.032bar | |
| | | | | | | | | 4.070bar | Total(Pt) Route 53 |
| 254 | 14856mm | 28.8Kbar | 58.50L/min | 25 | (See Notes) | 200mm | 100 | 4.126bar | ***** Route 54 ***** Sprinkler, T(1087mm) |
| 96 | 15056mm | | 58.50L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.033bar | |
| 96 | 15056mm | | 58.52L/min | 32 | | 2100mm | 100 | 4.139bar | Flow (q) from Route 56 |
| 97 | 15056mm | | 117.02L/min | 35.0520 | | 2100mm | 0.000024 | 0.051bar | |
| 97 | 15056mm | | 58.86L/min | 32 | | 2100mm | 100 | 4.190bar | Flow (q) from Route 59 |
| 98 | 15056mm | | 175.87L/min | 35.0520 | | 2100mm | 0.000052 | 0.108bar | |
| 98 | 15056mm | | 59.61L/min | 32 | (See Notes) | 1400mm | 100 | 4.299bar | Flow (q) from Route 64 PO(1304mm) |
| 67 | 15056mm | | 235.48L/min | 35.0520 | | 1304mm | 0.000089 | | |
| | | | | | | 2704mm | | 0.239bar | |
| | | | | | | | | 4.538bar | Total(Pt) Route 54 |
| 255 | 14856mm | 28.8Kbar | 58.52L/min | 25 | (See Notes) | 200mm | 100 | 4.128bar | ***** Route 55 ***** Sprinkler, T(1087mm) |
| 79 | 15056mm | | 58.52L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.033bar | |
| | | | | | | | | 4.142bar | Total(Pt) Route 55 |
| 256 | 14856mm | 28.8Kbar | 58.52L/min | 25 | (See Notes) | 200mm | 100 | 4.128bar | ***** Route 56 ***** Sprinkler, E(435mm) |
| 99 | 15056mm | | 58.52L/min | 26.6446 | | 435mm | 0.000026 | -0.020bar | |
| | | | | | | 635mm | | 0.016bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 99 | 15056mm | | | 32 | | 2100mm | 100 | 4.125bar | |
| 96 | 15056mm | | 58.52L/min | 35.0520 | | 2100mm | 0.000007 | 0.014bar | |
| | | | | | | | | 4.139bar | Total(Pt) Route 56 |
| 257 | 14856mm | 28.8Kbar | 58.57L/min | 25 | (See Notes) | 200mm | 100 | 4.136bar | Route 57 Sprinkler, T(1087mm) |
| 90 | 15056mm | | 58.57L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.033bar | |
| | | | | | | | | 4.149bar | Total(Pt) Route 57 |
| 258 | 14856mm | 28.8Kbar | 58.79L/min | 25 | (See Notes) | 200mm | 100 | 4.167bar | Route 58 Sprinkler, T(1087mm) |
| 94 | 15056mm | | 58.79L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.033bar | |
| | | | | | | | | 4.181bar | Total(Pt) Route 58 |
| 259 | 14856mm | 28.8Kbar | 58.86L/min | 25 | (See Notes) | 200mm | 100 | 4.176bar | Route 59 Sprinkler, T(1087mm) |
| 97 | 15056mm | | 58.86L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.033bar | |
| | | | | | | | | 4.190bar | Total(Pt) Route 59 |
| 260 | 14856mm | 28.8Kbar | 59.20L/min | 25 | (See Notes) | 200mm | 100 | 4.226bar | Route 60 Sprinkler, T(1087mm) |
| 65 | 15056mm | | 59.20L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.034bar | |
| | | | | | | | | 4.240bar | Total(Pt) Route 60 |
| 261 | 14856mm | 28.8Kbar | 59.22L/min | 25 | (See Notes) | 200mm | 100 | 4.228bar | Route 61 Sprinkler, T(1087mm) |
| 100 | 15056mm | | 59.22L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.034bar | |
| 100 | 15056mm | | 59.23L/min | 32 | | 2100mm | 100 | 4.242bar | Flow (q) from Route 62 |
| 101 | 15056mm | | 118.45L/min | 35.0520 | | 2100mm | 0.000025 | 0.052bar | |
| 101 | 15056mm | | 59.58L/min | 32 | | 2100mm | 100 | 4.294bar | Flow (q) from Route 63 |
| 102 | 15056mm | | 178.03L/min | 35.0520 | | 2100mm | 0.000053 | 0.111bar | |
| 102 | 15056mm | | 60.34L/min | 32 | (See Notes) | 1400mm | 100 | 4.405bar | Flow (q) from Route 67 PO(1304mm) |
| 69 | 15056mm | | 238.37L/min | 35.0520 | | 1304mm | 0.000091 | 0.245bar | |
| | | | | | | 2704mm | | 0.245bar | |
| | | | | | | | | 4.649bar | Total(Pt) Route 61 |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | Total (Millimeter) | | | Friction(Pf) | |
| 262 | 14856mm | 28.8Kbar | 59.23L/min | 25 | (See Notes) | 200mm | 100 | 4.230bar | ••••• Route 62 ••••• Sprinkler, E(435mm) |
| 103 | 15056mm | | 59.23L/min | 26.6446 | | 435mm | 0.000026 | -0.020bar | |
| | | | | | | 635mm | | 0.017bar | |
| 103 | 15056mm | | | 32 | | 2100mm | 100 | 4.227bar | |
| 100 | 15056mm | | 59.23L/min | 35.0520 | | 2100mm | 0.000007 | 0.014bar | |
| | | | | | | | | 4.242bar | Total(Pt) Route 62 |
| 263 | 14856mm | 28.8Kbar | 59.58L/min | 25 | (See Notes) | 200mm | 100 | 4.279bar | ••••• Route 63 ••••• Sprinkler, T(1087mm) |
| 101 | 15056mm | | 59.58L/min | 26.6446 | | 1087mm | 0.000026 | -0.020bar | |
| | | | | | | 1287mm | | 0.034bar | |
| | | | | | | | | 4.294bar | Total(Pt) Route 63 |
| 264 | 14856mm | 28.8Kbar | 59.61L/min | 25 | (See Notes) | 200mm | 100 | 4.284bar | ••••• Route 64 ••••• Sprinkler, T(1087mm) |
| 98 | 15056mm | | 59.61L/min | 26.6446 | | 1087mm | 0.000027 | -0.020bar | |
| | | | | | | 1287mm | | 0.034bar | |
| | | | | | | | | 4.299bar | Total(Pt) Route 64 |
| 265 | 14854mm | 28.8Kbar | 60.17L/min | 25 | (See Notes) | 202mm | 100 | 4.364bar | ••••• Route 65 ••••• Sprinkler, E(435mm) |
| 104 | 15056mm | | 60.17L/min | 26.6446 | | 435mm | 0.000027 | -0.020bar | |
| | | | | | | 637mm | | 0.017bar | |
| 104 | 15056mm | | | 32 | (See Notes) | 300mm | 100 | 4.362bar | PO(1304mm) |
| 81 | 15056mm | | 60.17L/min | 35.0520 | | 1304mm | 0.000007 | | |
| | | | | | | 1604mm | | 0.011bar | |
| | | | | | | | | 4.373bar | Total(Pt) Route 65 |
| 266 | 14854mm | 28.8Kbar | 60.21L/min | 25 | (See Notes) | 202mm | 100 | 4.371bar | ••••• Route 66 ••••• Sprinkler, E(435mm) |
| 105 | 15056mm | | 60.21L/min | 26.6446 | | 435mm | 0.000027 | -0.020bar | |
| | | | | | | 637mm | | 0.017bar | |
| 105 | 15056mm | | | 32 | (See Notes) | 300mm | 100 | 4.369bar | PO(1304mm) |
| 82 | 15056mm | | 60.21L/min | 35.0520 | | 1304mm | 0.000007 | | |
| | | | | | | 1604mm | | 0.011bar | |
| | | | | | | | | 4.380bar | Total(Pt) Route 66 |
| 267 | 14856mm | 28.8Kbar | 60.34L/min | 25 | (See Notes) | 200mm | 100 | 4.389bar | ••••• Route 67 ••••• Sprinkler, T(1087mm) |
| 102 | 15056mm | | 60.34L/min | 26.6446 | | 1087mm | 0.000027 | -0.020bar | |
| | | | | | | 1287mm | | 0.035bar | |
| | | | | | | | | 4.405bar | Total(Pt) Route 67 |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 268 | 14854mm | 28.8Kbar | 60.37L/min | 25 | (See Notes) | 202mm | 100 | 4.394bar | ••••• Route 68 ••••• Sprinkler, E(435mm) |
| 106 | 15056mm | | 60.37L/min | 26.6446 | | 435mm | 0.000027 | -0.020bar | |
| | | | | | | 637mm | | 0.017bar | |
| 106 | 15056mm | | | 32 | (See Notes) | 300mm | 100 | 4.392bar | PO(1304mm) |
| 84 | 15056mm | | 60.37L/min | 35.0520 | | 1304mm | 0.000007 | | |
| | | | | | | 1604mm | | 0.011bar | |
| | | | | | | | | 4.403bar | Total(Pt) Route 68 |
| 269 | 14856mm | 28.8Kbar | 60.40L/min | 25 | (See Notes) | 200mm | 100 | 4.398bar | ••••• Route 69 ••••• Sprinkler, T(1087mm) |
| 107 | 15056mm | | 60.40L/min | 26.6446 | | 1087mm | 0.000027 | -0.020bar | |
| | | | | | | 1287mm | | 0.035bar | |
| 107 | 15056mm | | 60.42L/min | 32 | | 2100mm | 100 | 4.414bar | Flow (q) from Route 70 |
| 108 | 15056mm | | 120.82L/min | 35.0520 | | 2100mm | 0.000026 | 0.054bar | |
| | | | | | | | | | |
| 108 | 15056mm | | 60.77L/min | 32 | | 2100mm | 100 | 4.468bar | Flow (q) from Route 74 |
| 109 | 15056mm | | 181.58L/min | 35.0520 | | 2100mm | 0.000055 | 0.115bar | |
| | | | | | | | | | |
| 109 | 15056mm | | 61.54L/min | 32 | (See Notes) | 1400mm | 100 | 4.583bar | Flow (q) from Route 77 PO(1304mm) |
| 71 | 15056mm | | 243.13L/min | 35.0520 | | 1304mm | 0.000094 | | |
| | | | | | | 2704mm | | 0.254bar | |
| | | | | | | | | 4.837bar | Total(Pt) Route 69 |
| 270 | 14856mm | 28.8Kbar | 60.42L/min | 25 | (See Notes) | 200mm | 100 | 4.401bar | ••••• Route 70 ••••• Sprinkler, E(435mm) |
| 110 | 15056mm | | 60.42L/min | 26.6446 | | 435mm | 0.000027 | -0.020bar | |
| | | | | | | 635mm | | 0.017bar | |
| 110 | 15056mm | | | 32 | | 2100mm | 100 | 4.399bar | |
| 107 | 15056mm | | 60.42L/min | 35.0520 | | 2100mm | 0.000007 | 0.015bar | |
| | | | | | | | | | |
| | | | | | | | | 4.414bar | Total(Pt) Route 70 |
| 271 | 5304mm | 31.7Kbar | 66.54L/min | 25 | (See Notes) | 202mm | 100 | 4.406bar | ••••• Route 71 ••••• Sprinkler, T(1087mm) |
| 111 | 5506mm | | 66.54L/min | 26.6446 | | 1087mm | 0.000032 | -0.020bar | |
| | | | | | | 1289mm | | 0.042bar | |
| 111 | 5506mm | | | 50 | | 700mm | 100 | 4.428bar | |
| 15 | 5506mm | | 66.54L/min | 52.5018 | | 700mm | 0.000001 | | |
| | | | | | | | | 0.001bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| | | | | | | | | 4.429bar | Total(Pt) Route 71 |
| 272 | 5300mm | 31.7Kbar | 66.74L/min | 25 | (See Notes) | 2306mm | 100 | 4.432bar | Route 72 Sprinkler, T(1087mm), PO(1087mm) |
| 17 | 5506mm | | 66.74L/min | 26.6446 | | 2173mm | 0.000033 | -0.020bar | |
| | | | | | | 4480mm | | 0.146bar | |
| | | | | | | | | 4.558bar | Total(Pt) Route 72 |
| 273 | 14854mm | 28.8Kbar | 60.73L/min | 25 | (See Notes) | 202mm | 100 | 4.446bar | Route 73 Sprinkler, E(435mm) |
| 112 | 15056mm | | 60.73L/min | 26.6446 | | 435mm | 0.000027 | -0.020bar | |
| | | | | | | 637mm | | 0.017bar | |
| 112 | 15056mm | | | 32 | (See Notes) | 300mm | 100 | 4.444bar | T(1304mm) |
| 86 | 15056mm | | 60.73L/min | 35.0520 | | 1304mm | 0.000007 | | |
| | | | | | | 1604mm | | 0.012bar | |
| | | | | | | | | 4.455bar | Total(Pt) Route 73 |
| 274 | 14856mm | 28.8Kbar | 60.77L/min | 25 | (See Notes) | 200mm | 100 | 4.452bar | Route 74 Sprinkler, T(1087mm) |
| 108 | 15056mm | | 60.77L/min | 26.6446 | | 1087mm | 0.000027 | -0.020bar | |
| | | | | | | 1287mm | | 0.035bar | |
| | | | | | | | | 4.468bar | Total(Pt) Route 74 |
| 275 | 5304mm | 31.7Kbar | 67.31L/min | 25 | (See Notes) | 202mm | 100 | 4.508bar | Route 75 Sprinkler, E(435mm) |
| 113 | 5506mm | | 67.31L/min | 26.6446 | | 435mm | 0.000033 | -0.020bar | |
| | | | | | | 637mm | | 0.021bar | |
| 113 | 5506mm | | | 32 | (See Notes) | 200mm | 100 | 4.510bar | PO(1304mm) |
| 16 | 5506mm | | 67.31L/min | 35.0520 | | 1304mm | 0.000009 | | |
| | | | | | | 1504mm | | 0.013bar | |
| | | | | | | | | 4.523bar | Total(Pt) Route 75 |
| 276 | 14854mm | 28.8Kbar | 61.36L/min | 25 | (See Notes) | 202mm | 100 | 4.539bar | Route 76 Sprinkler, E(435mm) |
| 114 | 15056mm | | 61.36L/min | 26.6446 | | 435mm | 0.000028 | -0.020bar | |
| | | | | | | 637mm | | 0.018bar | |
| 114 | 15056mm | | | 32 | (See Notes) | 300mm | 100 | 4.537bar | PO(1304mm) |
| 68 | 15056mm | | 61.36L/min | 35.0520 | | 1304mm | 0.000007 | | |
| | | | | | | 1604mm | | 0.012bar | |
| | | | | | | | | 4.548bar | Total(Pt) Route 76 |
| 277 | 14854mm | 28.8Kbar | 61.54L/min | 25 | (See Notes) | 202mm | 100 | 4.566bar | Route 77 Sprinkler, T(1087mm) |
| 109 | 15056mm | | 61.54L/min | 26.6446 | | 1087mm | 0.000028 | -0.020bar | |
| | | | | | | 1289mm | | 0.036bar | |

| Pipe Information | | | | | | | | | |
|------------------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| | | | | | | | | 4.583bar | Total(Pt) Route 77 |
| 278 | 14858mm | 28.8Kbar | 62.22L/min | 25 | (See Notes) | 198mm | 100 | 4.667bar | ••••• Route 78 ••••• Sprinkler, E(435mm) |
| 115 | 15056mm | | 62.22L/min | 26.6446 | | 435mm | 0.000029 | -0.019bar | |
| | | | | | | 633mm | | 0.018bar | |
| 115 | 15056mm | | | 32 | (See Notes) | 300mm | 100 | 4.665bar | PO(1304mm) |
| 70 | 15056mm | | 62.22L/min | 35.0520 | | 1304mm | 0.000008 | | |
| | | | | | | 1604mm | | 0.012bar | |
| | | | | | | | | 4.678bar | Total(Pt) Route 78 |
| 279 | 19046mm | 28.8Kbar | 62.79L/min | 15 | (See Notes) | 226mm | 100 | 4.753bar | ••••• Route 79 ••••• Sprinkler, T(652mm) |
| 116 | 19272mm | | 62.79L/min | 15.7988 | | 652mm | 0.000372 | -0.022bar | |
| | | | | | | 878mm | | 0.327bar | |
| 116 | 19272mm | | 63.71L/min | 32 | | 2000mm | 100 | 5.057bar | Flow (q) from Route 92 |
| 117 | 19272mm | | 126.50L/min | 35.0520 | | 2000mm | 0.000028 | 0.056bar | |
| 117 | 19272mm | | 63.13L/min | 32 | | 2000mm | 100 | 5.113bar | Flow (q) from Route 82 |
| 118 | 19272mm | | 189.64L/min | 35.0520 | | 2000mm | 0.000059 | 0.119bar | |
| 118 | 19272mm | | 63.86L/min | 32 | (See Notes) | 700mm | 100 | 5.232bar | Flow (q) from Route 95 PO(1304mm) |
| 119 | 19272mm | | 253.50L/min | 35.0520 | | 1304mm | 0.000101 | | |
| | | | | | | 2004mm | | 0.203bar | |
| 119 | 19272mm | | | 80 | | 2150mm | 100 | 5.435bar | Flow (q) from Route 80 |
| 120 | 19272mm | | 253.50L/min | 77.9272 | | 2150mm | 0.000002 | 0.004bar | |
| 120 | 19272mm | | 253.60L/min | 80 | | 2150mm | 100 | 5.440bar | |
| 121 | 19272mm | | 507.10L/min | 77.9272 | | 2150mm | 0.000007 | 0.016bar | |
| 121 | 19272mm | | 253.98L/min | 80 | | 2500mm | 100 | 5.456bar | Flow (q) from Route 81 |
| 122 | 19272mm | | 761.08L/min | 77.9272 | | 2500mm | 0.000016 | 0.040bar | |
| 122 | 19272mm | | 254.90L/min | 80 | | 2500mm | 100 | 5.495bar | Flow (q) from Route 83 |
| 123 | 19272mm | | 1015.99L/min | 77.9272 | | 2500mm | 0.000027 | 0.068bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 123 | 19272mm | | 256.47L/min | 80 | | 3050mm | 100 | 5.563bar | Flow (q) from Route 89 |
| 124 | 19272mm | | 1272.46L/min | 77.9272 | | 3050mm | 0.000041 | 0.125bar | |
| 124 | 19272mm | | 259.35L/min | 80 | | 2950mm | 100 | 5.688bar | Flow (q) from Route 102 |
| 125 | 19272mm | | 1531.81L/min | 77.9272 | | 2950mm | 0.000058 | 0.170bar | |
| 125 | 19272mm | | 263.23L/min | 80 | (See Notes) | 780mm | 100 | 5.859bar | Flow (q) from Route 108 T(4100mm) |
| 126 | 19272mm | | 1795.04L/min | 77.9272 | | 4100mm | 0.000077 | 0.378bar | |
| 126 | 19272mm | | 271.31L/min | 80 | (See Notes) | 850mm | | 100 | 6.237bar |
| 127 | 19272mm | | 2066.35L/min | 77.9272 | | 3260mm | 0.000101 | 0.413bar | |
| 127 | 19272mm | | | 150 | | 4216mm | | 120 | 6.650bar |
| 75 | 15056mm | | 2066.35L/min | 161.4678 | | 4216mm | 0.000002 | 0.009bar | |
| | | | | | | | | 7.072bar | Total(Pt) Route 79 |
| 280 | 19046mm | 28.8Kbar | 62.81L/min | 15 | (See Notes) | 226mm | 100 | 4.757bar | ••••• Route 80 ••••• Sprinkler, T(652mm) |
| 128 | 19272mm | | 62.81L/min | 15.7988 | | 652mm | 0.000372 | -0.022bar | |
| | | | | | 878mm | 0.327bar | | | |
| 128 | 19272mm | | 63.74L/min | 32 | | 2000mm | 100 | 5.061bar | Flow (q) from Route 93 |
| 129 | 19272mm | | 126.55L/min | 35.0520 | | 2000mm | 0.000028 | 0.056bar | |
| 129 | 19272mm | | 63.16L/min | 32 | | 2000mm | 100 | 5.118bar | Flow (q) from Route 84 |
| 130 | 19272mm | | 189.71L/min | 35.0520 | | 2000mm | 0.000059 | 0.119bar | |
| 130 | 19272mm | | 63.89L/min | 32 | (See Notes) | 700mm | 100 | 5.236bar | Flow (q) from Route 97 PO(1304mm) |
| 120 | 19272mm | | 253.60L/min | 35.0520 | | 1304mm | 0.000102 | 0.203bar | |
| | | | | | | | | 5.440bar | Total(Pt) Route 80 |
| 281 | 19046mm | 28.8Kbar | 62.91L/min | 15 | (See Notes) | 226mm | 100 | 4.771bar | ••••• Route 81 ••••• Sprinkler, T(652mm) |
| 131 | 19272mm | | 62.91L/min | 15.7988 | | 652mm | 0.000373 | -0.022bar | |
| | | | | | 878mm | 0.328bar | | | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. | |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|-----------|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | | |
| 131 | 19272mm | | 63.83L/min | 32 | | 2000mm | 100 | 5.077bar | Flow (q) from Route 94 | |
| 132 | 19272mm | | 126.74L/min | 35.0520 | | 2000mm | 0.000028 | 0.056bar | | |
| 132 | 19272mm | | 63.25L/min | 32 | | 2000mm | 100 | 5.133bar | Flow (q) from Route 86 | |
| 133 | 19272mm | | 190.00L/min | 35.0520 | | 2000mm | 0.000060 | 0.119bar | | |
| 133 | 19272mm | | 63.98L/min | 32 | (See Notes) | 700mm | 100 | 5.252bar | Flow (q) from Route 99 PO(1304mm) | |
| | | | | | | 1304mm | 0.000102 | | | |
| 121 | 19272mm | | 253.98L/min | 35.0520 | | 2004mm | | | | 0.204bar |
| | | | | | | | | 5.456bar | Total(Pt) Route 81 | |
| 282 | 19046mm | 28.8Kbar | 63.13L/min | 15 | (See Notes) | 226mm | 100 | 4.806bar | ***** Route 82 ***** Sprinkler, T(652mm) | |
| | | | | | | 652mm | 0.000376 | | | -0.022bar |
| 117 | 19272mm | | 63.13L/min | 15.7988 | | 878mm | | | | 0.330bar |
| | | | | | | | | 5.113bar | Total(Pt) Route 82 | |
| 283 | 19046mm | 28.8Kbar | 63.14L/min | 15 | (See Notes) | 226mm | 100 | 4.806bar | ***** Route 83 ***** Sprinkler, T(652mm) | |
| | | | | | | 652mm | 0.000376 | | | -0.022bar |
| 134 | 19272mm | | 63.14L/min | 15.7988 | | 878mm | | | | 0.330bar |
| 134 | 19272mm | | 64.07L/min | 32 | | 2000mm | 100 | 5.114bar | Flow (q) from Route 100 | |
| 135 | 19272mm | | 127.20L/min | 35.0520 | | 2000mm | 0.000028 | 0.057bar | | |
| 135 | 19272mm | | 63.48L/min | 32 | | 2000mm | 100 | 5.170bar | Flow (q) from Route 87 | |
| 136 | 19272mm | | 190.69L/min | 35.0520 | | 2000mm | 0.000060 | 0.120bar | | |
| 136 | 19272mm | | 64.22L/min | 32 | (See Notes) | 700mm | 100 | 5.290bar | Flow (q) from Route 101 PO(1304mm) | |
| | | | | | | 1304mm | 0.000102 | | | |
| 122 | 19272mm | | 254.90L/min | 35.0520 | | 2004mm | | | | 0.205bar |
| | | | | | | | | 5.495bar | Total(Pt) Route 83 | |
| 284 | 19046mm | 28.8Kbar | 63.16L/min | 15 | (See Notes) | 226mm | 100 | 4.810bar | ***** Route 84 ***** Sprinkler, T(652mm) | |
| | | | | | | 652mm | 0.000376 | | | -0.022bar |
| 129 | 19272mm | | 63.16L/min | 15.7988 | | 878mm | | | | 0.330bar |
| | | | | | | | | 5.118bar | Total(Pt) Route 84 | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 285 | 5304mm | 31.7Kbar | 69.57L/min | 25 | (See Notes) | 202mm | 100 | 4.816bar | ***** Route 85 ***** Sprinkler, E(435mm) |
| 137 | 5506mm | | 69.57L/min | 26.6446 | | 435mm | 0.000035 | -0.020bar | |
| | | | | | | 637mm | | 0.022bar | |
| 137 | 5506mm | | | 32 | (See Notes) | 200mm | 100 | 4.819bar | PO(1304mm) |
| 18 | 5506mm | | 69.57L/min | 35.0520 | | 1304mm | 0.000009 | | |
| | | | | | | 1504mm | | 0.014bar | |
| | | | | | | | | 4.833bar | Total(Pt) Route 85 |
| 286 | 19046mm | 28.8Kbar | 63.25L/min | 15 | (See Notes) | 226mm | 100 | 4.824bar | ***** Route 86 ***** Sprinkler, T(652mm) |
| 132 | 19272mm | | 63.25L/min | 15.7988 | | 652mm | 0.000377 | -0.022bar | |
| | | | | | | 878mm | | 0.331bar | |
| | | | | | | | | 5.133bar | Total(Pt) Route 86 |
| 287 | 19046mm | 28.8Kbar | 63.48L/min | 15 | (See Notes) | 226mm | 100 | 4.859bar | ***** Route 87 ***** Sprinkler, T(652mm) |
| 135 | 19272mm | | 63.48L/min | 15.7988 | | 652mm | 0.000380 | -0.022bar | |
| | | | | | | 878mm | | 0.333bar | |
| | | | | | | | | 5.170bar | Total(Pt) Route 87 |
| 288 | 14854mm | 28.8Kbar | 63.50L/min | 25 | (See Notes) | 202mm | 100 | 4.862bar | ***** Route 88 ***** Sprinkler, E(435mm) |
| 138 | 15056mm | | 63.50L/min | 26.6446 | | 435mm | 0.000030 | -0.020bar | |
| | | | | | | 637mm | | 0.019bar | |
| 138 | 15056mm | | | 32 | (See Notes) | 300mm | 100 | 4.861bar | PO(1304mm) |
| 72 | 15056mm | | 63.50L/min | 35.0520 | | 1304mm | 0.000008 | | |
| | | | | | | 1604mm | | 0.013bar | |
| | | | | | | | | 4.873bar | Total(Pt) Route 88 |
| 289 | 19046mm | 28.8Kbar | 63.53L/min | 15 | (See Notes) | 226mm | 100 | 4.865bar | ***** Route 89 ***** Sprinkler, T(652mm) |
| 139 | 19272mm | | 63.53L/min | 15.7988 | | 652mm | 0.000380 | -0.022bar | |
| | | | | | | 878mm | | 0.334bar | |
| 139 | 19272mm | | 64.46L/min | 32 | | 2000mm | 100 | 5.177bar | Flow (q) from Route 103 |
| 140 | 19272mm | | 127.99L/min | 35.0520 | | 2000mm | 0.000029 | 0.057bar | |
| | | | | | | 2000mm | | | |
| 140 | 19272mm | | 63.88L/min | 32 | | 2000mm | 100 | 5.234bar | Flow (q) from Route 96 |
| 141 | 19272mm | | 191.86L/min | 35.0520 | | 2000mm | 0.000061 | 0.121bar | |
| | | | | | | 2000mm | | | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | Total (Millimeter) | | | Friction(Pf) | |
| 141 | 19272mm | | 64.61L/min | 32 | (See Notes) | 700mm | 100 | 5.355bar | Flow (q) from Route 105 PO(1304mm) |
| 123 | 19272mm | | 256.47L/min | 35.0520 | | 1304mm | 0.000104 | | |
| | | | | | | 2004mm | | 0.208bar | |
| | | | | | | | | 5.563bar | Total(Pt) Route 89 |
| 290 | 14856mm | 28.8Kbar | 63.59L/min | 25 | (See Notes) | 200mm | 100 | 4.875bar | ***** Route 90 ***** Sprinkler, T(1087mm) |
| 142 | 15056mm | | 63.59L/min | 26.6446 | | 1087mm | 0.000030 | -0.020bar | |
| | | | | | | 1287mm | | 0.038bar | |
| 142 | 15056mm | | 63.61L/min | 32 | (See Notes) | 2100mm | 100 | 4.894bar | Flow (q) from Route 91 |
| 143 | 15056mm | | 127.19L/min | 35.0520 | | 2100mm | 0.000028 | 0.059bar | |
| 143 | 15056mm | | 63.97L/min | 32 | (See Notes) | 2100mm | 100 | 4.953bar | Flow (q) from Route 98 |
| 144 | 15056mm | | 191.16L/min | 35.0520 | | 2100mm | 0.000060 | 0.126bar | |
| 144 | 15056mm | | 64.78L/min | 32 | (See Notes) | 1400mm | 100 | 5.079bar | Flow (q) from Route 106 PO(1304mm) |
| 145 | 15056mm | | 255.94L/min | 35.0520 | | 1304mm | 0.000103 | | |
| | | | | | | 2704mm | | 0.279bar | |
| 145 | 15056mm | | | 80 | (See Notes) | 300mm | 100 | 5.359bar | Flow (q) from Route 114 T(4100mm) |
| 146 | 15056mm | | 255.94L/min | 77.9272 | | 300mm | 0.000002 | 0.001bar | |
| 146 | 15056mm | | 66.58L/min | 80 | (See Notes) | 1605mm | 100 | 5.359bar | Flow (q) from Route 114 T(4100mm) |
| 73 | 15056mm | | 322.52L/min | 77.9272 | | 4100mm | 0.000003 | | |
| | | | | | | 5705mm | | 0.018bar | |
| | | | | | | | | 5.378bar | Total(Pt) Route 90 |
| 291 | 14856mm | 28.8Kbar | 63.61L/min | 25 | (See Notes) | 200mm | 100 | 4.878bar | ***** Route 91 ***** Sprinkler, E(435mm) |
| 147 | 15056mm | | 63.61L/min | 26.6446 | | 435mm | 0.000030 | -0.020bar | |
| | | | | | | 635mm | | 0.019bar | |
| 147 | 15056mm | | | 32 | (See Notes) | 2100mm | 100 | 4.877bar | Flow (q) from Route 91 |
| 142 | 15056mm | | 63.61L/min | 35.0520 | | 2100mm | 0.000008 | 0.017bar | |
| | | | | | | | | 4.894bar | Total(Pt) Route 91 |
| 292 | 19046mm | 28.8Kbar | 63.71L/min | 15 | (See Notes) | 226mm | 100 | 4.894bar | ***** Route 92 ***** Sprinkler, E(217mm) |
| 148 | 19272mm | | 63.71L/min | 15.7988 | | 217mm | 0.000382 | -0.022bar | |
| | | | | | | 444mm | | 0.169bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 148 | 19272mm | | | 32 | | 2000mm | 100 | 5.042bar | |
| 116 | 19272mm | | 63.71L/min | 35.0520 | | 2000mm | 0.000008 | 0.016bar | |
| | | | | | | | | 5.057bar | Total(Pt) Route 92 |
| 293 | 19046mm | 28.8Kbar | 63.74L/min | 15 | (See Notes) | 226mm | 100 | 4.898bar | Route 93 Sprinkler, E(217mm) |
| 149 | 19272mm | | 63.74L/min | 15.7988 | | 217mm | 0.000382 | -0.022bar | |
| | | | | | | 444mm | | 0.170bar | |
| 149 | 19272mm | | | 32 | | 2000mm | 100 | 5.046bar | |
| 128 | 19272mm | | 63.74L/min | 35.0520 | | 2000mm | 0.000008 | 0.016bar | |
| | | | | | | | | 5.061bar | Total(Pt) Route 93 |
| 294 | 19046mm | 28.8Kbar | 63.83L/min | 15 | (See Notes) | 226mm | 100 | 4.913bar | Route 94 Sprinkler, E(217mm) |
| 150 | 19272mm | | 63.83L/min | 15.7988 | | 217mm | 0.000383 | -0.022bar | |
| | | | | | | 444mm | | 0.170bar | |
| 150 | 19272mm | | | 32 | | 2000mm | 100 | 5.061bar | |
| 131 | 19272mm | | 63.83L/min | 35.0520 | | 2000mm | 0.000008 | 0.016bar | |
| | | | | | | | | 5.077bar | Total(Pt) Route 94 |
| 295 | 19046mm | 28.8Kbar | 63.86L/min | 15 | (See Notes) | 226mm | 100 | 4.917bar | Route 95 Sprinkler, T(652mm) |
| 118 | 19272mm | | 63.86L/min | 15.7988 | | 652mm | 0.000384 | -0.022bar | |
| | | | | | | 878mm | | 0.337bar | |
| | | | | | | | | 5.232bar | Total(Pt) Route 95 |
| 296 | 19046mm | 28.8Kbar | 63.88L/min | 15 | (See Notes) | 226mm | 100 | 4.919bar | Route 96 Sprinkler, T(652mm) |
| 140 | 19272mm | | 63.88L/min | 15.7988 | | 652mm | 0.000384 | -0.022bar | |
| | | | | | | 878mm | | 0.337bar | |
| | | | | | | | | 5.234bar | Total(Pt) Route 96 |
| 297 | 19046mm | 28.8Kbar | 63.89L/min | 15 | (See Notes) | 226mm | 100 | 4.921bar | Route 97 Sprinkler, T(652mm) |
| 130 | 19272mm | | 63.89L/min | 15.7988 | | 652mm | 0.000384 | -0.022bar | |
| | | | | | | 878mm | | 0.337bar | |
| | | | | | | | | 5.236bar | Total(Pt) Route 97 |
| 298 | 14856mm | 28.8Kbar | 63.97L/min | 25 | (See Notes) | 200mm | 100 | 4.934bar | Route 98 Sprinkler, T(1087mm) |
| 143 | 15056mm | | 63.97L/min | 26.6446 | | 1087mm | 0.000030 | -0.020bar | |
| | | | | | | 1287mm | | 0.039bar | |

| Pipe Information | | | | | | | | | |
|------------------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | Total (Millimeter) | | | Friction(Pf) | |
| | | | | | | | | 4.953bar | Total(Pt) Route 98 |
| 299 | 19046mm | 28.8Kbar | 63.98L/min | 15 | (See Notes) | 226mm | 100 | 4.936bar | Route 99 Sprinkler, T(652mm) |
| 133 | 19272mm | | 63.98L/min | 15.7988 | | 652mm | 0.000385 | -0.022bar | |
| | | | | | | 878mm | | 0.338bar | |
| | | | | | | | | 5.252bar | Total(Pt) Route 99 |
| 300 | 19046mm | 28.8Kbar | 64.07L/min | 15 | (See Notes) | 226mm | 100 | 4.949bar | Route 100 Sprinkler, E(217mm) |
| 151 | 19272mm | | 64.07L/min | 15.7988 | | 217mm | 0.000386 | -0.022bar | |
| | | | | | | 444mm | | 0.171bar | |
| 151 | 19272mm | | | 32 | | 2000mm | 100 | 5.098bar | |
| 134 | 19272mm | | 64.07L/min | 35.0520 | | | 0.000008 | | |
| | | | | | 2000mm | 0.016bar | | | |
| | | | | | | | | 5.114bar | Total(Pt) Route 100 |
| 301 | 19046mm | 28.8Kbar | 64.22L/min | 15 | (See Notes) | 226mm | 100 | 4.972bar | Route 101 Sprinkler, T(652mm) |
| 136 | 19272mm | | 64.22L/min | 15.7988 | | 652mm | 0.000388 | -0.022bar | |
| | | | | | | 878mm | | 0.340bar | |
| | | | | | | | | 5.290bar | Total(Pt) Route 101 |
| 302 | 19046mm | 28.8Kbar | 64.24L/min | 15 | (See Notes) | 226mm | 100 | 4.975bar | Route 102 Sprinkler, T(652mm) |
| 152 | 19272mm | | 64.24L/min | 15.7988 | | 652mm | 0.000388 | -0.022bar | |
| | | | | | | 878mm | | 0.341bar | |
| 152 | 19272mm | | 65.18L/min | 32 | | 2000mm | 100 | 5.294bar | Flow (q) from Route 107 |
| 153 | 19272mm | | 129.42L/min | 35.0520 | | 2000mm | 0.000029 | 0.059bar | |
| 153 | 19272mm | | 64.59L/min | 32 | | 2000mm | 100 | 5.352bar | Flow (q) from Route 104 |
| 154 | 19272mm | | 194.02L/min | 35.0520 | | 2000mm | 0.000062 | 0.124bar | |
| 154 | 19272mm | | 65.34L/min | 32 | (See Notes) | 700mm | 100 | 5.476bar | Flow (q) from Route 110 PO(1304mm) |
| 124 | 19272mm | | 259.35L/min | 35.0520 | | 1304mm | 0.000106 | | |
| | | | | | | 2004mm | | 0.212bar | |
| | | | | | | | | 5.688bar | Total(Pt) Route 102 |
| 303 | 19046mm | 28.8Kbar | 64.46L/min | 15 | (See Notes) | 226mm | 100 | 5.010bar | Route 103 Sprinkler, E(217mm) |
| 155 | 19272mm | | 64.46L/min | 15.7988 | | 217mm | 0.000390 | -0.022bar | |
| | | | | | | 444mm | | 0.173bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|-----------------------|--------------------------------|-------------------|-----------------------|------------------------|----------------------------------|---------------------------------------|--|
| | Node 2 | | Elev 2 (Millimeter) | Total Flow (Q) | | Actual ID | Equiv. Length (Millimeter) | Pf Friction Loss Per Unit (bar) | |
| | | Total (Millimeter) | | | | | | | |
| 155 | 19272mm | | | 32 | | 2000mm | 100 | 5.161bar | |
| 139 | 19272mm | | 64.46L/min | 35.0520 | | 2000mm | 0.000008 | 0.016bar | |
| | | | | | | | | 5.177bar | Total(Pt) Route 103 |
| 304 | 19046mm | 28.8Kbar | 64.59L/min | 15 | (See Notes) | 226mm | 100 | 5.030bar | ***** Route 104 ***** Sprinkler, T(652mm) |
| 153 | 19272mm | | 64.59L/min | 15.7988 | | 652mm | 0.000392 | -0.022bar | |
| | | | | | | 878mm | | 0.344bar | |
| | | | | | | | | 5.352bar | Total(Pt) Route 104 |
| 305 | 19046mm | 28.8Kbar | 64.61L/min | 15 | (See Notes) | 226mm | 100 | 5.033bar | ***** Route 105 ***** Sprinkler, T(652mm) |
| 141 | 19272mm | | 64.61L/min | 15.7988 | | 652mm | 0.000392 | -0.022bar | |
| | | | | | | 878mm | | 0.344bar | |
| | | | | | | | | 5.355bar | Total(Pt) Route 105 |
| 306 | 14856mm | 28.8Kbar | 64.78L/min | 25 | (See Notes) | 200mm | 100 | 5.059bar | ***** Route 106 ***** Sprinkler, T(1087mm) |
| 144 | 15056mm | | 64.78L/min | 26.6446 | | 1087mm | 0.000031 | -0.020bar | |
| | | | | | | 1287mm | | 0.040bar | |
| | | | | | | | | 5.079bar | Total(Pt) Route 106 |
| 307 | 19046mm | 28.8Kbar | 65.18L/min | 15 | (See Notes) | 226mm | 100 | 5.123bar | ***** Route 107 ***** Sprinkler, E(217mm) |
| 156 | 19272mm | | 65.18L/min | 15.7988 | | 217mm | 0.000399 | -0.022bar | |
| | | | | | | 444mm | | 0.177bar | |
| 156 | 19272mm | | | 32 | | 2000mm | 100 | 5.277bar | |
| 152 | 19272mm | | 65.18L/min | 35.0520 | | 2000mm | 0.000008 | 0.016bar | |
| | | | | | | | | 5.294bar | Total(Pt) Route 107 |
| 308 | 19046mm | 28.8Kbar | 65.20L/min | 15 | (See Notes) | 226mm | 100 | 5.125bar | ***** Route 108 ***** Sprinkler, T(652mm) |
| 157 | 19272mm | | 65.20L/min | 15.7988 | | 652mm | 0.000399 | -0.022bar | |
| | | | | | | 878mm | | 0.350bar | |
| 157 | 19272mm | | 66.16L/min | 32 | | 2000mm | 100 | 5.453bar | Flow (q) from Route 112 |
| 158 | 19272mm | | 131.36L/min | 35.0520 | | 2000mm | 0.000030 | 0.060bar | |
| 158 | 19272mm | | 65.56L/min | 32 | | 2000mm | 100 | 5.513bar | Flow (q) from Route 111 |
| 159 | 19272mm | | 196.92L/min | 35.0520 | | 2000mm | 0.000064 | 0.127bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | | Total (Millimeter) | | Friction(Pf) | |
| 159 | 19272mm | | 66.31L/min | 32 | (See Notes) | 700mm | 100 | 5.641bar | Flow (q) from Route 113 PO(1304mm) |
| 125 | 19272mm | | 263.23L/min | 35.0520 | | 1304mm | 0.000109 | | |
| | | | | | | 2004mm | | 0.218bar | |
| | | | | | | | | 5.859bar | Total(Pt) Route 108 |
| 309 | 5304mm | 31.7Kbar | 71.88L/min | 25 | (See Notes) | 202mm | 100 | 5.142bar | ***** Route 109 ***** Sprinkler, E(435mm) |
| 160 | 5506mm | | 71.88L/min | 26.6446 | | 435mm | 0.000037 | -0.020bar | |
| | | | | | | 637mm | | 0.024bar | |
| 160 | 5506mm | | | 32 | (See Notes) | 200mm | 100 | 5.146bar | PO(1304mm) |
| 19 | 5506mm | | 71.88L/min | 35.0520 | | 1304mm | 0.000010 | | |
| | | | | | | 1504mm | | 0.015bar | |
| | | | | | | | | 5.161bar | Total(Pt) Route 109 |
| 310 | 19046mm | 28.8Kbar | 65.34L/min | 15 | (See Notes) | 226mm | 100 | 5.147bar | ***** Route 110 ***** Sprinkler, T(652mm) |
| 154 | 19272mm | | 65.34L/min | 15.7988 | | 652mm | 0.000400 | -0.022bar | |
| | | | | | | 878mm | | 0.352bar | |
| | | | | | | | | 5.476bar | Total(Pt) Route 110 |
| 311 | 19046mm | 28.8Kbar | 65.56L/min | 15 | (See Notes) | 226mm | 100 | 5.182bar | ***** Route 111 ***** Sprinkler, T(652mm) |
| 158 | 19272mm | | 65.56L/min | 15.7988 | | 652mm | 0.000403 | -0.022bar | |
| | | | | | | 878mm | | 0.354bar | |
| | | | | | | | | 5.513bar | Total(Pt) Route 111 |
| 312 | 19046mm | 28.8Kbar | 66.16L/min | 15 | (See Notes) | 226mm | 100 | 5.277bar | ***** Route 112 ***** Sprinkler, E(217mm) |
| 161 | 19272mm | | 66.16L/min | 15.7988 | | 217mm | 0.000410 | -0.022bar | |
| | | | | | | 444mm | | 0.182bar | |
| 161 | 19272mm | | | 32 | | 2000mm | 100 | 5.436bar | |
| 157 | 19272mm | | 66.16L/min | 35.0520 | | | 0.000008 | | |
| | | | | | | 2000mm | | 0.017bar | |
| | | | | | | | | 5.453bar | Total(Pt) Route 112 |
| 313 | 19046mm | 28.8Kbar | 66.31L/min | 15 | (See Notes) | 226mm | 100 | 5.301bar | ***** Route 113 ***** Sprinkler, T(652mm) |
| 159 | 19272mm | | 66.31L/min | 15.7988 | | 652mm | 0.000411 | -0.022bar | |
| | | | | | | 878mm | | 0.361bar | |
| | | | | | | | | 5.641bar | Total(Pt) Route 113 |
| 314 | 14854mm | 28.8Kbar | 66.58L/min | 25 | (See Notes) | 202mm | 100 | 5.345bar | ***** Route 114 ***** Sprinkler, E(435mm) |
| 162 | 15056mm | | 66.58L/min | 26.6446 | | 435mm | 0.000033 | -0.020bar | |
| | | | | | | 637mm | | 0.021bar | |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes |
|--------|------------------------|----------|--------------------------------|------------|-----------------------|------------------------|----------|-----------|---|
| | | | | | | | | | |
| 162 | 15056mm | | | 32 | (See Notes) | 300mm | 100 | 5.346bar | PO(1304mm) |
| 146 | 15056mm | | 66.58L/min | 35.0520 | | 1304mm | 0.000009 | | |
| | | | | | | 1604mm | | 0.014bar | |
| | | | | | | | | 5.359bar | Total(Pt) Route 114 |
| 315 | 19046mm | 28.8Kbar | 67.21L/min | 15 | (See Notes) | 226mm | 100 | 5.445bar | ***** Route 115 ***** Sprinkler, T(652mm) |
| 163 | 19272mm | | 67.21L/min | 15.7988 | | 652mm | 0.000422 | -0.022bar | |
| | | | | | | 878mm | | 0.370bar | |
| 163 | 19272mm | | 68.19L/min | 32 | | 2000mm | 100 | 5.794bar | Flow (q) from Route 117 |
| 164 | 19272mm | | 135.39L/min | 35.0520 | | 2000mm | 0.000032 | 0.064bar | |
| 164 | 19272mm | | 67.57L/min | 32 | | 2000mm | 100 | 5.857bar | Flow (q) from Route 116 |
| 165 | 19272mm | | 202.97L/min | 35.0520 | | 2000mm | 0.000067 | 0.134bar | |
| 165 | 19272mm | | 68.35L/min | 32 | (See Notes) | 700mm | 100 | 5.992bar | Flow (q) from Route 118 PO(1304mm) |
| 166 | 19272mm | | 271.31L/min | 35.0520 | | 1304mm | 0.000115 | | |
| | | | | | | 2004mm | | 0.231bar | |
| 166 | 19272mm | | | 80 | (See Notes) | 2070mm | 100 | 6.222bar | T(4100mm) |
| 126 | 19272mm | | 271.31L/min | 77.9272 | | 4100mm | 0.000002 | | |
| | | | | | | 6170mm | | 0.014bar | |
| | | | | | | | | 6.237bar | Total(Pt) Route 115 |
| 316 | 19046mm | 28.8Kbar | 67.57L/min | 15 | (See Notes) | 226mm | 100 | 5.505bar | ***** Route 116 ***** Sprinkler, T(652mm) |
| 164 | 19272mm | | 67.57L/min | 15.7988 | | 652mm | 0.000426 | -0.022bar | |
| | | | | | | 878mm | | 0.374bar | |
| | | | | | | | | 5.857bar | Total(Pt) Route 116 |
| 317 | 19046mm | 28.8Kbar | 68.19L/min | 15 | (See Notes) | 226mm | 100 | 5.606bar | ***** Route 117 ***** Sprinkler, E(217mm) |
| 167 | 19272mm | | 68.19L/min | 15.7988 | | 217mm | 0.000433 | -0.022bar | |
| | | | | | | 444mm | | 0.192bar | |
| 167 | 19272mm | | | 32 | | 2000mm | 100 | 5.776bar | |
| 163 | 19272mm | | 68.19L/min | 35.0520 | | 2000mm | 0.000009 | 0.018bar | |
| | | | | | | | | 5.794bar | Total(Pt) Route 117 |

Pipe Information

| Node 1 | Elev 1 (Millimeter) | K-Factor | Flow added this step (q) | Nominal ID | Fittings & Devices | Length (Millimeter) | C Factor | Total(Pt) | Notes Fitting/Device (Equivalent Length) Fixed Pressure Losses, when applicable, are added directly to (Pf) and shown as a negative value. |
|--------|------------------------|----------|--------------------------------|------------|----------------------------------|-------------------------|---------------------------------------|--------------|--|
| Node 2 | Elev 2 (Millimeter) | | Total Flow (Q) | Actual ID | Equiv. Length (Millimeter) | Fitting (Millimeter) | Pf Friction Loss Per Unit (bar) | Elev(Pe) | |
| | | | | | Total (Millimeter) | | | Friction(Pf) | |
| 318 | 19046mm | 28.8Kbar | 68.35L/min | 15 | (See Notes) | 226mm | 100 | 5.632bar | ***** Route 118 ***** Sprinkler, T(652mm) |
| 165 | 19272mm | | 68.35L/min | 15.7988 | | 652mm | 0.000435 | -0.022bar | |
| | | | | | | 878mm | | 0.382bar | |
| | | | | | | | | 5.992bar | Total(Pt) Route 118 |
| 319 | 5304mm | 31.7Kbar | 77.80L/min | 25 | (See Notes) | 202mm | 100 | 6.024bar | ***** Route 119 ***** Sprinkler, E(435mm) |
| 168 | 5506mm | | 77.80L/min | 26.6446 | | 435mm | 0.000043 | -0.020bar | |
| | | | | | | 637mm | | 0.028bar | |
| 168 | 5506mm | | | 32 | (See Notes) | 200mm | 100 | 6.032bar | E(652mm) |
| 169 | 5506mm | | 77.80L/min | 35.0520 | | 652mm | 0.000011 | | |
| | | | | | | 852mm | | 0.010bar | |
| 169 | 5506mm | | | 50 | (See Notes) | 569mm | 100 | 6.041bar | T(2173mm) |
| 20 | 5506mm | | 77.80L/min | 52.5018 | | 2173mm | 0.000002 | | |
| | | | | | | 2742mm | | 0.004bar | |
| | | | | | | | | 6.046bar | Total(Pt) Route 119 |
| 320 | 5304mm | 31.7Kbar | 83.36L/min | 25 | (See Notes) | 1085mm | 100 | 6.914bar | ***** Route 120 ***** Sprinkler, 2E(435mm), PO(1087mm) |
| 21 | 5506mm | | 83.36L/min | 26.6446 | | 1956mm | 0.000049 | -0.020bar | |
| | | | | | | 3041mm | | 0.150bar | |
| | | | | | | | | 7.044bar | Total(Pt) Route 120 |

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$


| | | | | |
|--------------------|-------|------|------|------|
| Value Of C | 100 | 130 | 140 | 150 |
| Multiplying Factor | 0.713 | 1.16 | 1.33 | 1.51 |


Fittings Legend

| | | |
|--------------------------------|---------------------------|-----------------------------|
| ALV Alarm Valve | AngV Angle Valve | b Bushing |
| BaIV Ball Valve | BFP Backflow Preventer | BV Butterfly Valve |
| C Cross Flow Turn 90° | cplg Coupling | Cr Cross Run |
| CV Check Valve | DelV Deluge Valve | DPV Dry Pipe Valve |
| E 90° Elbow | EE 45° Elbow | Ee1 11¼° Elbow |
| Ee2 22½° Elbow | f Flow Device | fd Flex Drop |
| FDC Fire Department Connection | fE 90° FireLock(TM) Elbow | fEE 45° FireLock(TM) Elbow |
| flg Flange | FN Floating Node | fT FireLock(TM) Tee |
| g Gauge | GloV Globe Valve | GV Gate Valve |
| Ho Hose | Hose Hose | HV Hose Valve |
| Hyd Hydrant | LtE Long Turn Elbow | mecT Mechanical Tee |
| Noz Nozzle | P1 Pump In | P2 Pump Out |
| PIV Post Indicating Valve | PO Pipe Outlet | PRV Pressure Reducing Valve |
| PrV Pressure Relief Valve | red Reducer/Adapter | S Supply |
| sCV Swing Check Valve | Spr Sprinkler | St Strainer |
| T Tee Flow Turn 90° | Tr Tee Run | U Union |
| WirF Wirsbo | WMV Water Meter Valve | Z Cap |




Flow Diagram (Top View)







Multiple Connection Diagram






Figure A.1 – Flow Coloured Graph




Figure A.2 – Velocity Coloured Graph

Contract Information

| | |
|--------------------------------------|------------|
| Contractor: | Contact: : |
| | Phone: |
| | FAX: |
| | E-mail: |
| | Web-Site: |
| Design Engineer: Daniel Rocha Afonso | |
| Phone: | |
| FAX: | |

Job Information


| | |
|------------------|--|
| Job Number: 1 | List Area: Default List Area |
| Job Name: Thesis | Last Listed: 10/06/2020 |
| Customer: | Black-Black: <input type="checkbox"/> <input type="checkbox"/> |
| Customer Name: | Number of Heads: 120 |
| | Total Weight: 4474lb 0oz |
| | Weld Count: 46 |

Shipping Information

| | |
|-----------|------|
| Ship To: | POJ: |
| | |
| | |
| Ship Via: | |

Table of Contents

| |
|------------------------------|
| Cover Sheet |
| Material Summary |
| Material Summary, Threaded |
| Material Summary, Welded |
| Pipeline Configuration |
| Sprinkler Summary |
| Loose Material |
| Nipple List |
| Non-Graphical Welded Mains |
| Welded Mains |
| Threaded Fabrication Report |
| Threaded Fabrication By Size |
| Threaded Branchline Report |
| Pipelines |
| Threaded Pipelines |
| Welded Pipelines |
| Other Pipelines |
| Cut Pipe, Threaded |
| Cut Pipe, Welded |
| Threaded Labels |
| Welded Labels (Cut Order) |
| Other Pipe |
| Multiple Connections Diagram |

| Black-Black | | Material Summary | | Current Date |
|---|--------------|---|-------------|------------------|
|  | | 1 - Thesis | | Date Required |
| | | Default List Area | | POJ |
| Quantity | Size | Description, Finish | Part Number | Manufacturer |
| Grooved Fittings | | | | |
| 1 | 150 | Grooved 90° Elbow | | |
| 4 | 80 | Grooved 90° Elbow, style 06 | 06P088 | Modgal Metal Ltd |
| 5 | 200 | Grooved 90° Lg Rad Steel Elbow | | |
| 6 | 80 | Grooved Cap, style 02 | 02P088 | Modgal Metal Ltd |
| 1 | 150 | Grooved Cap, style 02 | 02P168 | Modgal Metal Ltd |
| 1 | 80 x 80 x 32 | Grooved Reducing Tee, SS | | |
| 2 | 80 | Grooved Short Radius Tee, style 65 | 65P088 | Modgal Metal Ltd |
| 2 | 80 | Grooved Tee | | |
| Threaded Fittings | | | | |
| 6 | 25 | Threaded 90° Elbow, Equal nr. 90 | | Georg Fischer |
| 2 | 32 | Threaded 90° Elbow, Equal nr. 90 | | Georg Fischer |
| 27 | 32 x 25 | Threaded 90° Elbow, reducing nr. 90R | | Georg Fischer |
| 8 | 32 x 15 | Threaded 90° Reducing Elbow | | |
| 1 | 50 x 32 | Threaded 90° Reducing Elbow | | |
| 1 | 25 | Threaded Cap, nr.300 | | Georg Fischer |
| 10 | 32 | Threaded Cap, nr.300 | | Georg Fischer |
| 24 | 32 x 32 x 15 | Threaded Reducing Tee | | |
| 1 | 32 x 25 x 25 | Threaded Reducing Tee, reducing, nr. 130R | | Georg Fischer |
| 56 | 32 x 32 x 25 | Threaded Reducing Tee, reducing, nr. 130R | | Georg Fischer |
| 1 | 50 x 32 x 25 | Threaded Reducing Tee, reducing, nr. 130R | | Georg Fischer |
| 88 | 25 x 15 | Threaded Socket, reducing, nr. 240 | | Georg Fischer |
| 1 | 25 | Threaded Straight Tee, equal, nr. 130 | | Georg Fischer |
| 2 | 32 | Threaded Straight Tee, equal, nr. 130 | | Georg Fischer |
| Pipe | | | | |
| 74900mm | 80 | Pipe, Schedule 10 (8 Sticks x 10922mm) 0.42 Bundles Welded | | |
| 13740mm | 150 | Pipe, Schedule 10 (2 Sticks x 11840mm) 0.20 Bundles Welded | | |
| 9600mm | 200 | Pipe, Schedule 10 (2 Sticks x 7408mm) 0.29 Bundles Welded | | |
| 4110mm | 25 | Pipe, Schedule 40 (Galv) (1 Stick x 6401mm) 0.01 Bundles Threaded | | |
| 5050mm | 25 | Pipe, Schedule 40 (1 Stick x 6401mm) 0.01 Bundles Threaded | | |
| 173550mm | 32 | Pipe, Schedule 40 (29 Sticks x 6401mm) 0.57 Bundles Threaded | | |
| 2440mm | 32 | Pipe, Schedule 40 (1 Stick x 6401mm) 0.02 Bundles Threaded | | |
| 1000mm | 50 | Pipe, Schedule 40 (1 Stick x 6401mm) 0.03 Bundles Threaded | | |
| 11360mm | 200 | Pipe, Schedule 40 (2 Sticks x 6401mm) 0.13 Bundles Welded | | |
| Couplings | | | | |
| 2 | 80 x 50 | Grooved Reducer Coupling | | |
| 1 | 32 | Grooved Rigid Coupling | | |
| 39 | 80 | Grooved Rigid Coupling | | |
| 4 | 150 | Grooved Rigid Coupling | | |
| 11 | 200 | Grooved Rigid Coupling | | |
| Pipe Outlets | | | | |
| 2 | 80 x 25 | Thread-O-Let | | |
| 41 | 80 x 32 | Thread-O-Let | | |
| 3 | 150 x 80 | Welded Outlet-Grooved | | |
| Sprinklers | | | | |
| 88 | 15 | K=1.9, Open, Brass (Pendent) | | |
| 32 | 15 | K=2.8, Open, Brass (Pendent) | | |
| Nipples | | | | |
| 32 | 15 x 191 | Nipple, Schedule 40 | | |
| 87 | 25 x 165 | Nipple, Schedule 40 | | |
| 1 | 25 x 178 | Nipple, Schedule 40 | | |

Black-Black



Material Summary

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Quantity | Size | Description, Finish | Part Number | Manufacturer |
|----------|----------|----------------------------|-------------|--------------|
| 1 | 25 x 178 | Nipple, Schedule 40 (Galv) | | |
| 1 | 25 x 250 | Nipple, Schedule 40 | | |
| 3 | 32 x 114 | Nipple, Schedule 40 | | |
| 1 | 32 x 140 | Nipple, Schedule 40 | | |
| 1 | 32 x 191 | Nipple, Schedule 40 | | |
| 7 | 32 x 216 | Nipple, Schedule 40 | | |

Black-Black



Material Summary, Threaded

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Quantity | Size | Description, Finish | Part Number | Manufacturer |
|----------|------|---------------------|-------------|--------------|
|----------|------|---------------------|-------------|--------------|

Pipe

| | | | | |
|----------|----|---|--|--|
| 4110mm | 25 | Pipe, Schedule 40 (Galv) (1 Stick x 6401mm) 0.01 Bundles Threaded | | |
| 5050mm | 25 | Pipe, Schedule 40 (1 Stick x 6401mm) 0.01 Bundles Threaded | | |
| 173550mm | 32 | Pipe, Schedule 40 (29 Sticks x 6401mm) 0.57 Bundles Threaded | | |
| 2440mm | 32 | Pipe, Schedule 40 (1 Stick x 6401mm) 0.02 Bundles Threaded | | |
| 1000mm | 50 | Pipe, Schedule 40 (1 Stick x 6401mm) 0.03 Bundles Threaded | | |

Threaded Fittings

| | | | | |
|----|--------------|---|--|--|
| 6 | 25 | Threaded 90° Elbow, Equal nr. 90 | | |
| 2 | 32 | Threaded 90° Elbow, Equal nr. 90 | | |
| 27 | 32 x 25 | Threaded 90° Elbow, reducing nr. 90R | | |
| 8 | 32 x 15 | Threaded 90° Reducing Elbow | | |
| 1 | 50 x 32 | Threaded 90° Reducing Elbow | | |
| 1 | 25 | Threaded Cap, nr.300 | | |
| 10 | 32 | Threaded Cap, nr.300 | | |
| 24 | 32 x 32 x 15 | Threaded Reducing Tee | | |
| 1 | 32 x 25 x 25 | Threaded Reducing Tee, reducing, nr. 130R | | |
| 56 | 32 x 32 x 25 | Threaded Reducing Tee, reducing, nr. 130R | | |
| 1 | 50 x 32 x 25 | Threaded Reducing Tee, reducing, nr. 130R | | |
| 88 | 25 x 15 | Threaded Socket, reducing, nr. 240 | | |
| 1 | 25 | Threaded Straight Tee, equal, nr. 130 | | |
| 2 | 32 | Threaded Straight Tee, equal, nr. 130 | | |

Black-Black



Material Summary, Welded

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Quantity | Size | Description, Finish | Part Number | Manufacturer |
|----------|------|---------------------|-------------|--------------|
|----------|------|---------------------|-------------|--------------|

Pipe

| | | | | |
|---------|-----|--|--|--|
| 74900mm | 80 | Pipe, Schedule 10 (8 Sticks x 10922mm) 0.42 Bundles Welded | | |
| 13740mm | 150 | Pipe, Schedule 10 (2 Sticks x 11840mm) 0.20 Bundles Welded | | |
| 9600mm | 200 | Pipe, Schedule 10 (2 Sticks x 7408mm) 0.29 Bundles Welded | | |
| 11360mm | 200 | Pipe, Schedule 40 (2 Sticks x 6401mm) 0.13 Bundles Welded | | |

Pipe Outlets

| | | | | |
|----|----------|-----------------------|--|--|
| 41 | 80 x 32 | Thread-O-Let | | |
| 2 | 80 x 25 | Thread-O-Let | | |
| 3 | 150 x 80 | Welded Outlet-Grooved | | |

Black-Black



Pipeline Configuration

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Branch Line | Quantity: | BL20, a | Quantity: 1 |
|----------------|--------------------|----------------|--------------|
| | | Attached Lines | Qty Per Line |
| BL1, a | Quantity: 4 | DR1 | 1 |
| BL2, a | Quantity: 1 | DR1 | 6 |
| BL3, a | Quantity: 4 | DR1 | 1 |
| BL4, a | Quantity: 6 | DR1 | 4 |
| BL5, a | Quantity: 7 | DR1 | 1 |
| BL6, a | Quantity: 1 | DR1 | 7 |
| BL7, a | Quantity: 8 | DR2 | 4 |
| BL8, a | Quantity: 1 | DR1 | 1 |
| BL9, a | Quantity: 1 | DR1 | 5 |
| BL10, a | Quantity: 1 | DR1 | 4 |
| BL11, a | Quantity: 1 | DR1 | 4 |
| BL12, a | Quantity: 1 | DR1 | 6 |
| BL13, a | Quantity: 1 | DR3 | 1 |
| BL14, a | Quantity: 1 | DR1 | 4 |
| BL15, a | Quantity: 3 | DR1 | 1 |
| BL16, a | Quantity: 1 | DR4 | 1 |
| BL17, a | Quantity: 1 | DR1 | 1 |
| BL18, a | Quantity: 1 | DR1 | 4 |
| BL19, a | Quantity: 1 | DR1 | 1 |

Black-Black



Sprinkler Summary

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area


POJ

| Quantity | Thread Size | Description | Part Number | Manufacturer |
|----------|-------------|-------------|-------------|--------------|
|----------|-------------|-------------|-------------|--------------|

Pendent

| | | | | |
|----|----|--------------------|--|--|
| 88 | 15 | K=1.9, Open, Brass | | |
|----|----|--------------------|--|--|

| | | | | |
|----|----|--------------------|--|--|
| 32 | 15 | K=2.8, Open, Brass | | |
|----|----|--------------------|--|--|

| | | |
|---|--------------------------|----------------------------|
| Black-Black  | Loose Material | Current Date 10/06/2020 |
| | 1 - Thesis | Date Required |
| | Default List Area | POJ |

| Quantity | Size | Description, Finish | Part Number | Manufacturer |
|----------|------|---------------------|-------------|--------------|
|----------|------|---------------------|-------------|--------------|

| | | | | |
|-------------------------|--|--|--|--|
| Grooved Fittings | | | | |
|-------------------------|--|--|--|--|

| | | | | |
|---|--------------|------------------------------------|--------|------------------|
| 1 | 150 | Grooved 90° Elbow | | |
| 4 | 80 | Grooved 90° Elbow, style 06 | 06P088 | Modgal Metal Ltd |
| 5 | 200 | Grooved 90° Lg Rad Steel Elbow | | |
| 6 | 80 | Grooved Cap, style 02 | 02P088 | Modgal Metal Ltd |
| 1 | 150 | Grooved Cap, style 02 | 02P168 | Modgal Metal Ltd |
| 1 | 80 x 80 x 32 | Grooved Reducing Tee, SS | | |
| 2 | 80 | Grooved Short Radius Tee, style 65 | 65P088 | Modgal Metal Ltd |
| 2 | 80 | Grooved Tee | | |

| | | | | |
|------------------|--|--|--|--|
| Couplings | | | | |
|------------------|--|--|--|--|

| | | | | |
|----|---------|--------------------------|--|--|
| 2 | 80 x 50 | Grooved Reducer Coupling | | |
| 1 | 32 | Grooved Rigid Coupling | | |
| 39 | 80 | Grooved Rigid Coupling | | |
| 4 | 150 | Grooved Rigid Coupling | | |
| 11 | 200 | Grooved Rigid Coupling | | |

| | | | | |
|-------------------|--|--|--|--|
| Sprinklers | | | | |
|-------------------|--|--|--|--|

| | | | | |
|----|----|------------------------------|--|--|
| 88 | 15 | K=1.9, Open, Brass (Pendent) | | |
| 32 | 15 | K=2.8, Open, Brass (Pendent) | | |

Black-Black



Nipple List

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Quantity | Size | Nipple | Make-on |
|----------|----------|----------------------------|--|
| 32 | 15 x 191 | Nipple, Schedule 40 | No Fitting |
| 87 | 25 x 165 | Nipple, Schedule 40 | 25 x 15 Threaded Socket, reducing, nr. 240 |
| 1 | 25 x 178 | Nipple, Schedule 40 | 25 x 15 Threaded Socket, reducing, nr. 240 |
| 1 | 25 x 178 | Nipple, Schedule 40 (Galv) | 25 Threaded 90° Elbow, Equal nr. 90 |
| 1 | 25 x 250 | Nipple, Schedule 40 | 25 Threaded 90° Elbow, Equal nr. 90 |
| 3 | 32 x 114 | Nipple, Schedule 40 | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| 1 | 32 x 140 | Nipple, Schedule 40 | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| 1 | 32 x 191 | Nipple, Schedule 40 | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 7 | 32 x 216 | Nipple, Schedule 40 | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |

Black-Black



Non-Graphical Welded Mains

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|--------------------------|
| CM1 - A | 1 | 200 - SCH 40 | 1580mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (1580mm) | | |
| G | ---- | 1580mm | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|--------------------------|
| CM1 - B | 1 | 200 - SCH 40 | 6400mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (6400mm) | | |
| G | ---- | 6400mm | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|--------------------------|
| CM1 - C | 1 | 200 - SCH 40 | 3380mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (3380mm) | | |
| G | ---- | 3380mm | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|--------------------------|
| CM1 - D | 1 | 200 - SCH 10 | 380mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (380mm) | | |
| G | ---- | 380mm | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|--------------------------|
| CM1 - E | 1 | 200 - SCH 10 | 5070mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (5070mm) | | |
| G | ---- | 5070mm | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|--------------------------|
| CM1 - F | 1 | 200 - SCH 10 | 3120mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (3120mm) | | |
| G | ---- | 3120mm | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |



Black-Black



Non-Graphical Welded Mains

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|--------|------------------|--------|--------------------------|
| CM1 - G | 1 | 200 - SCH 10 | 1030mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (1030mm) | | |
| G ---- | 1030mm | | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|--------------------------|
| CM2 - A | 1 | 80 - SCH 10 | 60mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (60mm) | | |
| G ---- | 60mm | | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|--------|------------------|--------|--------------------------|
| CM2 - B | 1 | 80 - SCH 10 | 2290mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (2290mm) | | |
| G ---- | 2290mm | | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|--------------------------|
| CM2 - C | 1 | 80 - SCH 10 | 100mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (100mm) | | |
| G ---- | 100mm | | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|--------|------------------|--------|--------------------------|
| CM2 - D | 1 | 80 - SCH 10 | 6320mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (6320mm) | | |
| G ---- | 6320mm | | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |



Black-Black



Non-Graphical Welded Mains

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|-----------------------------|----|
| CM2 - E | 1 | 80 - SCH 10 | 6400mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (246888mm) | | |
| X | ---- | 246888mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (115824mm) | | |
| X | ---- | 362712mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (646176mm) | | |
| X | ---- | 1008888mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (121920mm) | | |
| X | ---- | 1130808mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (579120mm) | | |
| X | ---- | 1709928mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (64008mm) | | |
| X | ---- | 1773936mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (176784mm) | | |
| G | ---- | 6400mm | | |

TOTAL NUMBER OF WELDS: 6

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|-----------------------------|----|
| CM2 - F | 1 | 80 - SCH 10 | 1800mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (469392mm) | | |
| X | ---- | 469392mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (79248mm) | | |
| G | ---- | 1800mm | | |

TOTAL NUMBER OF WELDS: 1

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|-----------------------------|----|
| CM2 - G | 1 | 80 - SCH 10 | 6400mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (710184mm) | | |
| X | ---- | 710184mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (48768mm) | | |
| X | ---- | 758952mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (713232mm) | | |
| X | ---- | 1472184mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (48768mm) | | |
| X | ---- | 1520952mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (429768mm) | | |
| G | ---- | 6400mm | | |

TOTAL NUMBER OF WELDS: 4



Black-Black



Non-Graphical Welded Mains

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|-----------------------------|----|
| CM2 - H | 1 | 80 - SCH 10 | 1560mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (362712mm) | | |
| X | ---- | 362712mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (51816mm) | | |
| X | ---- | 414528mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (60960mm) | | |
| G | ---- | 1560mm | | |

TOTAL NUMBER OF WELDS: 2

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|-----------------------------|----|
| CM2 - I | 1 | 80 - SCH 10 | 1970mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (463296mm) | | |
| X | ---- | 463296mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (91440mm) | | |
| X | ---- | 554736mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (45720mm) | | |
| G | ---- | 1970mm | | |

TOTAL NUMBER OF WELDS: 2

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|----|
| CM3 - A | 1 | 80 - SCH 10 | 600mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (600mm) | | |
| G | ---- | 600mm | | |

TOTAL NUMBER OF WELDS: 0

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|----------------------------|----|
| CM3 - B | 1 | 80 - SCH 10 | 6400mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (210312mm) | | |
| X | ---- | 210312mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (899160mm) | | |
| X | ---- | 1109472mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (841248mm) | | |
| G | ---- | 6400mm | | |

TOTAL NUMBER OF WELDS: 2



Black-Black



Non-Graphical Welded Mains

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|------------------------|-------|------------------|----------------------------|----|
| CM3 - C | 1 | 80 - SCH 10 | 6400mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (88392mm) | | |
| X | ---- | 88392mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (762000mm) | | |
| X | ---- | 850392mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (762000mm) | | |
| X | ---- | 1612392mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (338328mm) | | |
| G | ---- | 6400mm | | |
| TOTAL NUMBER OF WELDS: | | | | 3 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|------------------------|-------|------------------|----------------------------|----|
| CM3 - D | 1 | 80 - SCH 10 | 3500mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (316992mm) | | |
| X | ---- | 316992mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (655320mm) | | |
| X | ---- | 972312mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (94488mm) | | |
| G | ---- | 3500mm | | |
| TOTAL NUMBER OF WELDS: | | | | 2 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|------------------------|-------|------------------|-----------------------------|----|
| CM3 - E | 1 | 80 - SCH 10 | 2130mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (606552mm) | | |
| X | ---- | 606552mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (42672mm) | | |
| G | ---- | 2130mm | | |
| TOTAL NUMBER OF WELDS: | | | | 1 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|------------------------|-------|------------------|--------|----|
| CM4 - A | 1 | 80 - SCH 10 | 160mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (160mm) | | |
| G | ---- | 160mm | | |
| TOTAL NUMBER OF WELDS: | | | | 0 |



Black-Black



Non-Graphical Welded Mains

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|------------------------|-------|------------------|--------|----|
| CM4 - B | 1 | 80 - SCH 10 | 280mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (280mm) | | |
| G ---- | 280mm | | | |
| TOTAL NUMBER OF WELDS: | | | | 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|------------------------|-------|------------------|--------|----|
| CM4 - C | 1 | 80 - SCH 10 | 580mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (580mm) | | |
| G ---- | 580mm | | | |
| TOTAL NUMBER OF WELDS: | | | | 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|------------------------|---------|----------------------------|--------|----|
| CM4 - D | 1 | 80 - SCH 10 | 950mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (33528mm) | | |
| X ---- | 33528mm | 3 x 1 Thread-O-Let @ RIGHT | | |
| : | | (256032mm) | | |
| G ---- | 950mm | | | |
| TOTAL NUMBER OF WELDS: | | | | 1 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|------------------------|-------|------------------|--------|----|
| CM4 - E | 1 | 80 - SCH 10 | 900mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (900mm) | | |
| G ---- | 900mm | | | |
| TOTAL NUMBER OF WELDS: | | | | 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|------------------------|-------|------------------|--------|----|
| CM4 - F | 1 | 80 - SCH 10 | 290mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (290mm) | | |
| G ---- | 290mm | | | |
| TOTAL NUMBER OF WELDS: | | | | 0 |



Black-Black



Non-Graphical Welded Mains

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|--------------------------|
| CM4 - G | 1 | 80 - SCH 10 | 440mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (440mm) | | |
| G ---- | 440mm | | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-----------|----------------------------|--------|--------------------------|
| CM4 - H | 1 | 80 - SCH 10 | 6380mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (484632mm) | | |
| X ---- | 484632mm | 3 x 1¼ Thread-O-Let @ LEFT | | |
| : | | (640080mm) | | |
| X ---- | 1124712mm | 3 x 1¼ Thread-O-Let @ LEFT | | |
| : | | (563880mm) | | |
| X ---- | 1688592mm | 3 x 1 Thread-O-Let @ RIGHT | | |
| : | | (76200mm) | | |
| X ---- | 1764792mm | 3 x 1¼ Thread-O-Let @ LEFT | | |
| : | | (179832mm) | | |
| G ---- | 6380mm | | | |
| | | | | TOTAL NUMBER OF WELDS: 4 |

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|--------|------------------|--------|--------------------------|
| CM4 - I | 1 | 80 - SCH 10 | 1670mm | GG |
| ARROW: Down | | | | |
| G ---- | 0mm | | | |
| : | | (1670mm) | | |
| G ---- | 1670mm | | | |
| | | | | TOTAL NUMBER OF WELDS: 0 |



Black-Black



Non-Graphical Welded Mains

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|-----------------------------|----|
| CM4 - J | 1 | 80 - SCH 10 | 6400mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (100584mm) | | |
| X | ---- | 100584mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (640080mm) | | |
| X | ---- | 740664mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (0mm) | | |
| X | ---- | 740664mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (283464mm) | | |
| X | ---- | 1024128mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (0mm) | | |
| X | ---- | 1024128mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (640080mm) | | |
| X | ---- | 1664208mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (286512mm) | | |
| G | ---- | 6400mm | | |

TOTAL NUMBER OF WELDS: 6

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|-----------------------------|----|
| CM4 - K | 1 | 80 - SCH 10 | 10920mm | GG |
| ARROW: Down | | | | |
| G | ---- | 0mm | | |
| : | | (353568mm) | | |
| X | ---- | 353568mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (0mm) | | |
| X | ---- | 353568mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (716280mm) | | |
| X | ---- | 1069848mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (0mm) | | |
| X | ---- | 1069848mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (914400mm) | | |
| X | ---- | 1984248mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (0mm) | | |
| X | ---- | 1984248mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (640080mm) | | |
| X | ---- | 2624328mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (646176mm) | | |
| X | ---- | 3270504mm | 3 x 1¼ Thread-O-Let @ LEFT | |
| : | | (0mm) | | |
| X | ---- | 3270504mm | 3 x 1¼ Thread-O-Let @ RIGHT | |
| : | | (57912mm) | | |
| G | ---- | 10920mm | | |

TOTAL NUMBER OF WELDS: 9



Black-Black



Non-Graphical Welded Mains

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|---------|----|
| FR1 - A | 1 | 150 - SCH 10 | 11840mm | GG |
| ARROW: Down | | | | |

| | | | | |
|---|------|-----------|---------------|-------------------------------------|
| G | ---- | 0mm | | |
| : | | | (42702mm) | |
| X | ---- | 42702mm | | 6 x 3 Welded Outlet-Grooved @ RIGHT |
| : | | | (1286256mm) | |
| X | ---- | 1328958mm | | 6 x 3 Welded Outlet-Grooved @ RIGHT |
| : | | | (2279874mm) | |
| G | ---- | 11840mm | | |

TOTAL NUMBER OF WELDS: 2

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|----|
| FR1 - B | 1 | 150 - SCH 10 | 1500mm | GG |
| ARROW: Down | | | | |

| | | | | |
|---|------|--------|------------|--|
| G | ---- | 0mm | | |
| : | | | (1500mm) | |
| G | ---- | 1500mm | | |

TOTAL NUMBER OF WELDS: 0

| MAIN I.D.: | QUAN. | PIPE DESCRIPTION | LENGTH | EP |
|-------------|-------|------------------|--------|----|
| FR1 - C | 1 | 150 - SCH 10 | 400mm | GG |
| ARROW: Down | | | | |

| | | | | |
|---|------|--------|--------------|----------------------------------|
| G | ---- | 0mm | | |
| : | | | (6096mm) | |
| X | ---- | 6096mm | | 6 x 3 Welded Outlet-Grooved @ Up |
| : | | | (115824mm) | |
| G | ---- | 400mm | | |

TOTAL NUMBER OF WELDS: 1



Black-Black



Welded Mains - Fabrication Report

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

CM1 Quantity: 1

Piece: A (200 - SCH 40 1580mm G-G)
No Fitting

No Fitting



1580mm

1580mm

Piece: B (200 - SCH 40 6400mm G-G)
No Fitting

No Fitting



6400mm

6400mm

Piece: C (200 - SCH 40 3380mm G-G)
No Fitting

No Fitting



3380mm

3380mm

Piece: D (200 - SCH 10 380mm G-G)
No Fitting

No Fitting



380mm

380mm

Piece: E (200 - SCH 10 5070mm G-G)
No Fitting

No Fitting



5070mm

5070mm

Piece: F (200 - SCH 10 3120mm G-G)
No Fitting

No Fitting



3120mm

3120mm

Piece: G (200 - SCH 10 1030mm G-G)
No Fitting

No Fitting



1030mm

1030mm

CM2 Quantity: 1

Black-Black



Welded Mains - Fabrication Report

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

CM2 Quantity: 1

Piece: A (80 - SCH 10 60mm G-G)



No Fitting

No Fitting



60mm

60mm

Piece: B (80 - SCH 10 2290mm G-G)



No Fitting

No Fitting



2290mm

2290mm

Piece: C (80 - SCH 10 100mm G-G)



No Fitting

No Fitting



100mm

100mm

Piece: D (80 - SCH 10 6320mm G-G)



No Fitting

No Fitting



6320mm

6320mm

Piece: E (80 - SCH 10 6400mm G-G)



No Fitting

No Fitting



80 x 32 TOL (Away:270)

80 x 32 TOL (Away:270)

80 x 32 TOL (Away:270)

80 x 32 TOL (Toward:90)

80 x 32 TOL (Toward:90)

80 x 32 TOL (Toward:90)

810mm 380mm 2120mm 400mm 1900mm 210m580mm

810mm 1190mm 3310mm 3710mm 5610mm 5820r6400mm

Piece: F (80 - SCH 10 1800mm G-G)



No Fitting

No Fitting



80 x 32 TOL (Toward:90)

1540mm

260mm

1540mm

1800mm

Black-Black



Welded Mains - Fabrication Report

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

CM2 Quantity: 1

Piece: G (80 - SCH 10 6400mm G-G)

No Fitting

No Fitting




80 x 32 TOL (Toward:90)

80 x 32 TOL (Toward:90)

80 x 32 TOL (Away:270)

80 x 32 TOL (Away:270)



Piece: H (80 - SCH 10 1560mm G-G)


No Fitting

No Fitting



80 x 32 TOL (Away:270)

80 x 32 TOL (Toward:90)



Piece: I (80 - SCH 10 1970mm G-G)

No Fitting

No Fitting



80 x 32 TOL (Toward:90)

80 x 32 TOL (Away:270)



CM3 Quantity: 1

Piece: A (80 - SCH 10 600mm G-G)

No Fitting

No Fitting



600mm

600mm

Piece: B (80 - SCH 10 6400mm G-G)


No Fitting

No Fitting



80 x 32 TOL (Away:270)

80 x 32 TOL (Away:270)



Black-Black



Welded Mains - Fabrication Report

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

CM3 Quantity: 1

Piece: C (80 - SCH 10 6400mm G-G)

No Fitting

No Fitting



80 x 32 TOL (Away:270) 80 x 32 TOL (Away:270) 80 x 32 TOL (Away:270)

290mm 2500mm 2500mm 1110mm

290mm 2790mm 5290mm 6400mm

Piece: D (80 - SCH 10 3500mm G-G)

No Fitting

No Fitting



80 x 32 TOL (Away:270) 80 x 32 TOL (Away:270)

1040mm 2150mm 310mm

1040mm 3190mm 3500mm

Piece: E (80 - SCH 10 2130mm G-G)

No Fitting

No Fitting



80 x 32 TOL (Toward:90)

1990mm 140mm

1990mm 2130mm

CM4 Quantity: 1

Piece: A (80 - SCH 10 160mm G-G)

No Fitting

No Fitting



160mm

160mm

Piece: B (80 - SCH 10 280mm G-G)

No Fitting

No Fitting



280mm

280mm

Piece: C (80 - SCH 10 580mm G-G)

No Fitting

No Fitting



580mm

580mm

Black-Black



Welded Mains - Fabrication Report

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

CM4 Quantity: 1


Piece: D (80 - SCH 10 950mm G-G)

No Fitting

No Fitting



80 x 25 TOL (Toward:90)



Piece: E (80 - SCH 10 900mm G-G)

No Fitting

No Fitting



900mm

900mm

Piece: F (80 - SCH 10 290mm G-G)

No Fitting

No Fitting



290mm

290mm

Piece: G (80 - SCH 10 440mm G-G)

No Fitting

No Fitting



440mm

440mm

Piece: H (80 - SCH 10 6380mm G-G)

No Fitting

No Fitting




80 x 32 TOL (Away:270)

80 x 32 TOL (Away:270)

80 x 25 TOL (Toward:90)

80 x 32 TOL (Away:270)



Piece: I (80 - SCH 10 1670mm G-G)

No Fitting

No Fitting



1670mm

1670mm

Black-Black



Welded Mains - Fabrication Report

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

CM4 Quantity: 1

Piece: J (80 - SCH 10 6400mm G-G)

No Fitting

No Fitting




80 x 32 TOL (Away:270) 80 x 32 TOL (Toward:90) 80 x 32 TOL (Away:270)

80 x 32 TOL (Away:270)

80 x 32 TOL (Toward:90)

80 x 32 TOL (Away:270)



Piece: K (80 - SCH 10 10920mm G-G)


No Fitting

No Fitting




80 x 32 TOL (Toward:90) 80 x 32 TOL (Toward:90) 80 x 32 TOL (Toward:90)

80 x 32 TOL (Away:270) 80 x 32 TOL (Away:270) 80 x 32 TOL (Away:270)



80 x 32 TOL (Away:270) 80 x 32 TOL (Toward:90)

80 x 32 TOL (Away:270)



FR1 Quantity: 1

Black-Black



Welded Mains - Fabrication Report

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

FR1 Quantity: 1

Piece: A (150 - SCH 10 11840mm G-G)


No Fitting

No Fitting



150 x 80 Welded Outlet-Grooved (Toward:90)

150 x 80 Welded Outlet-Grooved (Toward:45)



Piece: B (150 - SCH 10 1500mm G-G)

No Fitting

No Fitting



1500mm

1500mm


Piece: C (150 - SCH 10 400mm G-G)

No Fitting

No Fitting



150 x 80 Welded Outlet-Grooved (Up:0)





Threaded Fabrication Report

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Length | Description | Quantity | End Prep | Fitting | Line |
|-----------------|-------------------|----------|----------|--|-------|
| Size: 50 | | | | | |
| 570mm | Pipe, Schedule 40 | 1 | G-T | Threaded Reducing Tee, reducing, nr. 130R | BL13a |
| 430mm | Pipe, Schedule 40 | 1 | G-T | 50 x 32 Thrd Red 90 | BL19a |
| Size: 32 | | | | | |
| 2140mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL11a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL10a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL10a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL11a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL11a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL12a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL14a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL14a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL18a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL18a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL2a |
| 2050mm | Pipe, Schedule 40 | 6 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL4a |
| 2050mm | Pipe, Schedule 40 | 6 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL4a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL6a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL6a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL9a |
| 2050mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL9a |
| 2040mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL10a |
| 2040mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL12a |
| 2040mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL14a |
| 2040mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL2a |
| 2040mm | Pipe, Schedule 40 | 6 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL4a |
| 2040mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL6a |
| 2040mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL9a |
| 2030mm | Pipe, Schedule 40 | 1 | T-T | Threaded Straight Tee, equal, nr. 130(Bull Head) | BL6a |
| 1970mm | Pipe, Schedule 40 | 8 | T-T | 32 x 32 x 15 Thrd Red T | BL7a |
| 1960mm | Pipe, Schedule 40 | 8 | T-T | 32 x 32 x 15 Thrd Red T | BL7a |
| 1960mm | Pipe, Schedule 40 | 8 | T-T | 32 x 15 Thrd Red 90 | BL7a |
| 1800mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL12a |
| 1710mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL18a |
| 1670mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL9a |
| 1660mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL2a |
| 1310mm | Pipe, Schedule 40 | 6 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL4a |
| 1210mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL10a |
| 1210mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL11a |
| 1210mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL12a |
| 1210mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL14a |
| 1210mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL18a |
| 1210mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL2a |
| 1210mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL6a |
| 1210mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL9a |
| 1200mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL2a |
| 1120mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL6a |
| 1120mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL6a |
| 800mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL2a |
| 620mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, Equal nr. 90 | BL18a |
| 620mm | Pipe, Schedule 40 | 8 | T-T | 32 x 32 x 15 Thrd Red T | BL7a |
| 610mm | Pipe, Schedule 40 | 4 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL1a |
| 610mm | Pipe, Schedule 40 | 4 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL3a |
| 610mm | Pipe, Schedule 40 | 1 | T-T | Threaded Reducing Tee, reducing, nr. 130R | BL8a |
| 570mm | Pipe, Schedule 40 | 1 | T-T | Threaded Cap, nr.300 | BL13a |
| 570mm | Pipe, Schedule 40 | 4 | T-T | Threaded Cap, nr.300 | BL1a |
| 570mm | Pipe, Schedule 40 | 4 | T-T | Threaded Cap, nr.300 | BL3a |
| 570mm | Pipe, Schedule 40 | 1 | T-T | Threaded Cap, nr.300 | BL8a |
| 500mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, reducing nr. 90R | BL6a |
| 490mm | Pipe, Schedule 40 | 1 | T-T | Threaded Straight Tee, equal, nr. 130 | BL6a |
| 370mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, Equal nr. 90 | BL18a |
| 170mm | Pipe, Schedule 40 | 1 | G-T | Threaded 90° Elbow, reducing nr. 90R | BL17a |

Black-Black



Threaded Fabrication Report

Current Date
10/06/2020

1 - Thesis


Date Required

Default List Area

POJ

| Length | Description | Quantity | End Prep | Fitting | Line |
|-----------------|--------------------------|----------|----------|---------------------------------------|-------|
| Size: 25 | | | | | |
| 2070mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, Equal nr. 90 | BL2a |
| 2060mm | Pipe, Schedule 40 (Galv) | 1 | T-T | Threaded 90° Elbow, Equal nr. 90 | BL12a |
| 2050mm | Pipe, Schedule 40 (Galv) | 1 | T-T | Threaded 90° Elbow, Equal nr. 90 | BL12a |
| 2010mm | Pipe, Schedule 40 | 1 | T-T | Threaded Straight Tee, equal, nr. 130 | BL16a |
| 500mm | Pipe, Schedule 40 | 1 | T-T | Threaded 90° Elbow, Equal nr. 90 | BL20a |
| 470mm | Pipe, Schedule 40 | 1 | T-T | Threaded Cap, nr.300 | BL16a |

Black-Black



Threaded Fabrication Report - By Size

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Line | Description | Quantity | Length | End Prep | Fitting |
|-----------------|--------------------------|----------|--------|----------|--|
| Size: 25 | | | | | |
| BL2a | Pipe, Schedule 40 | 1 | 2070mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| BL12a | Pipe, Schedule 40 (Galv) | 1 | 2050mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| BL12a | Pipe, Schedule 40 (Galv) | 1 | 2060mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| BL16a | Pipe, Schedule 40 | 1 | 2010mm | T-T | Threaded Straight Tee, equal, nr. 130 |
| BL16a | Pipe, Schedule 40 | 1 | 470mm | T-T | Threaded Cap, nr.300 |
| BL20a | Pipe, Schedule 40 | 1 | 500mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| Size: 32 | | | | | |
| BL1a | Pipe, Schedule 40 | 4 | 610mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL1a | Pipe, Schedule 40 | 4 | 570mm | T-T | Threaded Cap, nr.300 |
| BL2a | Pipe, Schedule 40 | 1 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL2a | Pipe, Schedule 40 | 1 | 1200mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL2a | Pipe, Schedule 40 | 1 | 800mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL2a | Pipe, Schedule 40 | 1 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL2a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL2a | Pipe, Schedule 40 | 1 | 1660mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| BL3a | Pipe, Schedule 40 | 4 | 610mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL3a | Pipe, Schedule 40 | 4 | 570mm | T-T | Threaded Cap, nr.300 |
| BL4a | Pipe, Schedule 40 | 6 | 1310mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL4a | Pipe, Schedule 40 | 6 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL4a | Pipe, Schedule 40 | 6 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL4a | Pipe, Schedule 40 | 6 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| BL6a | Pipe, Schedule 40 | 1 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL6a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL6a | Pipe, Schedule 40 | 1 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL6a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL6a | Pipe, Schedule 40 | 1 | 490mm | T-T | Threaded Straight Tee, equal, nr. 130 |
| BL6a | Pipe, Schedule 40 | 1 | 1120mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| BL6a | Pipe, Schedule 40 | 1 | 2030mm | T-T | Threaded Straight Tee, equal, nr. 130(Bull Head) |
| BL6a | Pipe, Schedule 40 | 1 | 1120mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| BL6a | Pipe, Schedule 40 | 1 | 500mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| BL7a | Pipe, Schedule 40 | 8 | 620mm | T-T | 32 x 32 x 15 Thrd Red T |
| BL7a | Pipe, Schedule 40 | 8 | 1960mm | T-T | 32 x 32 x 15 Thrd Red T |
| BL7a | Pipe, Schedule 40 | 8 | 1970mm | T-T | 32 x 32 x 15 Thrd Red T |
| BL7a | Pipe, Schedule 40 | 8 | 1960mm | T-T | 32 x 15 Thrd Red 90 |
| BL8a | Pipe, Schedule 40 | 1 | 610mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL8a | Pipe, Schedule 40 | 1 | 570mm | T-T | Threaded Cap, nr.300 |
| BL9a | Pipe, Schedule 40 | 1 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL9a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL9a | Pipe, Schedule 40 | 1 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL9a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL9a | Pipe, Schedule 40 | 1 | 1670mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| BL10a | Pipe, Schedule 40 | 1 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL10a | Pipe, Schedule 40 | 1 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL10a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL10a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| BL11a | Pipe, Schedule 40 | 1 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL11a | Pipe, Schedule 40 | 1 | 2140mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL11a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL11a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| BL12a | Pipe, Schedule 40 | 1 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL12a | Pipe, Schedule 40 | 1 | 1800mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL12a | Pipe, Schedule 40 | 1 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL12a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL13a | Pipe, Schedule 40 | 1 | 570mm | T-T | Threaded Cap, nr.300 |
| BL14a | Pipe, Schedule 40 | 1 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL14a | Pipe, Schedule 40 | 1 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL14a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL14a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| BL17a | Pipe, Schedule 40 | 1 | 170mm | G-T | Threaded 90° Elbow, reducing nr. 90R |
| BL18a | Pipe, Schedule 40 | 1 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL18a | Pipe, Schedule 40 | 1 | 370mm | T-T | Threaded 90° Elbow, Equal nr. 90 |

Black-Black



Threaded Fabrication Report - By Size

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Line | Description | Quantity | Length | End Prep | Fitting |
|-----------------|-------------------|----------|--------|----------|---|
| Size: 32 | | | | | |
| BL18a | Pipe, Schedule 40 | 1 | 620mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| BL18a | Pipe, Schedule 40 | 1 | 1710mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL18a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL18a | Pipe, Schedule 40 | 1 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Size: 50 | | | | | |
| BL13a | Pipe, Schedule 40 | 1 | 570mm | G-T | Threaded Reducing Tee, reducing, nr. 130R |
| BL19a | Pipe, Schedule 40 | 1 | 430mm | G-T | 50 x 32 Thrd Red 90 |



| Quantity | Description | Length | End Prep | Fitting |
|-----------------------------|------------------------------|--------|----------|--|
| Armovers/Drop/Sprigs | | | | |
| Line: DR1 | | | | |
| 86 | 25 x 165-Nipple, Schedule 40 | 170mm | T-T | Threaded Socket, reducing, nr. 240 |
| Line: DR2 | | | | |
| 32 | 15 x 191-Nipple, Schedule 40 | 200mm | T-T | No Fitting |
| Line: DR3 | | | | |
| 1 | 25 x 165-Nipple, Schedule 40 | 160mm | T-T | Threaded Socket, reducing, nr. 240 |
| Line: DR4 | | | | |
| 1 | 25 x 178-Nipple, Schedule 40 | 180mm | T-T | Threaded Socket, reducing, nr. 240 |
| Branch Line | | | | |
| Line: BL1a | | | | |
| 4 | 32-Pipe, Schedule 40 | 610mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 4 | 32-Pipe, Schedule 40 | 570mm | T-T | Threaded Cap, nr.300 |
| Line: BL2a | | | | |
| 1 | 32-Pipe, Schedule 40 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 1200mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 25-Pipe, Schedule 40 | 2070mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| 1 | 32-Pipe, Schedule 40 | 800mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 1660mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL3a | | | | |
| 4 | 32-Pipe, Schedule 40 | 610mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 4 | 32-Pipe, Schedule 40 | 570mm | T-T | Threaded Cap, nr.300 |
| Line: BL4a | | | | |
| 6 | 32-Pipe, Schedule 40 | 1310mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 6 | 32-Pipe, Schedule 40 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 6 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 6 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL5a | | | | |
| 7 | 32 x 216-Nipple, Schedule 40 | 210mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL6a | | | | |
| 1 | 32-Pipe, Schedule 40 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 490mm | T-T | Threaded Straight Tee, equal, nr. 130 |
| 1 | 32-Pipe, Schedule 40 | 1120mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| 1 | 32-Pipe, Schedule 40 | 2030mm | T-T | Threaded Straight Tee, equal, nr. 130(Bull Head) |
| 1 | 32-Pipe, Schedule 40 | 1120mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| 1 | 32-Pipe, Schedule 40 | 500mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL7a | | | | |
| 8 | 32-Pipe, Schedule 40 | 620mm | T-T | 32 x 32 x 15 Thrd Red T |
| 8 | 32-Pipe, Schedule 40 | 1960mm | T-T | 32 x 32 x 15 Thrd Red T |
| 8 | 32-Pipe, Schedule 40 | 1970mm | T-T | 32 x 32 x 15 Thrd Red T |
| 8 | 32-Pipe, Schedule 40 | 1960mm | T-T | 32 x 15 Thrd Red 90 |
| Line: BL8a | | | | |
| 1 | 32-Pipe, Schedule 40 | 610mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 570mm | T-T | Threaded Cap, nr.300 |
| Line: BL9a | | | | |
| 1 | 32-Pipe, Schedule 40 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 1670mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL10a | | | | |
| 1 | 32-Pipe, Schedule 40 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |



| Quantity | Description | Length | End Prep | Fitting |
|--------------------|-------------------------------------|--------|----------|---|
| Branch Line | | | | |
| Line: BL10a | | | | |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL11a | | | | |
| 1 | 32-Pipe, Schedule 40 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2140mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL12a | | | | |
| 1 | 32-Pipe, Schedule 40 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32 x 191-Nipple, Schedule 40 | 190mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 1800mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 25 x 178-Nipple, Schedule 40 (Galv) | 180mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| 1 | 25-Pipe, Schedule 40 (Galv) | 2050mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| 1 | 25-Pipe, Schedule 40 (Galv) | 2060mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| Line: BL13a | | | | |
| 1 | 50-Pipe, Schedule 40 | 570mm | G-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 570mm | T-T | Threaded Cap, nr.300 |
| Line: BL14a | | | | |
| 1 | 32-Pipe, Schedule 40 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2040mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL15a | | | | |
| 3 | 32 x 114-Nipple, Schedule 40 | 110mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL16a | | | | |
| 1 | 25-Pipe, Schedule 40 | 2010mm | T-T | Threaded Straight Tee, equal, nr. 130 |
| 1 | 25-Pipe, Schedule 40 | 470mm | T-T | Threaded Cap, nr.300 |
| Line: BL17a | | | | |
| 1 | 32-Pipe, Schedule 40 | 170mm | G-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL18a | | | | |
| 1 | 32-Pipe, Schedule 40 | 1210mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 370mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| 1 | 32-Pipe, Schedule 40 | 620mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| 1 | 32-Pipe, Schedule 40 | 1710mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded Reducing Tee, reducing, nr. 130R |
| 1 | 32-Pipe, Schedule 40 | 2050mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL19a | | | | |
| 1 | 50-Pipe, Schedule 40 | 430mm | G-T | 50 x 32 Thrd Red 90 |
| 1 | 32 x 140-Nipple, Schedule 40 | 140mm | T-T | Threaded 90° Elbow, reducing nr. 90R |
| Line: BL20a | | | | |
| 1 | 25 x 250-Nipple, Schedule 40 | 250mm | T-T | Threaded 90° Elbow, Equal nr. 90 |
| 1 | 25-Pipe, Schedule 40 | 500mm | T-T | Threaded 90° Elbow, Equal nr. 90 |

Black-Black



Pipelines

1 - Thesis

Default List Area

Current Date
10/06/2020

Date Required

POJ

| Description | Length | End Prep | Fitting |
|---|--------|----------|--|
| Line: BL1-a Quantity: 4 | | | |
| 32 - Pipe, Schedule 40 | 610mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 570mm | T - T | 32 Threaded Cap, nr.300 |
| Line: BL2-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 1200mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 25 - Pipe, Schedule 40 | 2070mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| 32 - Pipe, Schedule 40 | 800mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 1660mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL3-a Quantity: 4 | | | |
| 32 - Pipe, Schedule 40 | 610mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 570mm | T - T | 32 Threaded Cap, nr.300 |
| Line: BL4-a Quantity: 6 | | | |
| 32 - Pipe, Schedule 40 | 1310mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL5-a Quantity: 7 | | | |
| 32 x 216 - Nipple, Schedule 40 (Single Stick) | 210mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL6-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 490mm | T - T | 32 Threaded Straight Tee, equal, nr. 130 |
| 32 - Pipe, Schedule 40 | 1120mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | 2030mm | T - T | 32 Threaded Straight Tee, equal, nr. 130(Bull Head) |
| 32 - Pipe, Schedule 40 | 1120mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | 500mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL7-a Quantity: 8 | | | |
| 32 - Pipe, Schedule 40 | 620mm | T - T | 32 x 32 x 15 Threaded Reducing Tee |
| 32 - Pipe, Schedule 40 | 1960mm | T - T | 32 x 32 x 15 Threaded Reducing Tee |
| 32 - Pipe, Schedule 40 | 1970mm | T - T | 32 x 32 x 15 Threaded Reducing Tee |
| 32 - Pipe, Schedule 40 | 1960mm | T - T | 32 x 15 Threaded 90° Reducing Elbow |
| Line: BL8-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 610mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 570mm | T - T | 32 Threaded Cap, nr.300 |
| Line: BL9-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |

Black-Black



Pipelines

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Description | Length | End Prep | Fitting |
|--|--------|----------|--|
| Line: BL9-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 1670mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL10-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL11-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2140mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL12-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 x 191 - Nipple, Schedule 40 (Single Stick) | 190mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 1800mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 25 x 178 - Nipple, Schedule 40 (Single Stick) (Galv) | 180mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| 25 - Pipe, Schedule 40 (Galv) | 2050mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| 25 - Pipe, Schedule 40 (Galv) | 2060mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| Line: BL13-a Quantity: 1 | | | |
| 50 - Pipe, Schedule 40 | 570mm | G - T | 50 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 570mm | T - T | 32 Threaded Cap, nr.300 |
| Line: BL14-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL15-a Quantity: 3 | | | |
| 32 x 114 - Nipple, Schedule 40 (Single Stick) | 110mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL16-a Quantity: 1 | | | |
| 25 - Pipe, Schedule 40 | 2010mm | T - T | 25 Threaded Straight Tee, equal, nr. 130 |
| 25 - Pipe, Schedule 40 | 470mm | T - T | 25 Threaded Cap, nr.300 |
| Line: BL17-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 170mm | G - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL18-a Quantity: 1 | | | |

Black-Black**Pipelines**Current Date
10/06/2020**1 - Thesis**

Date Required

Default List Area

POJ

| Description | Length | End Prep | Fitting |
|---|---------|----------|--|
| Line: BL18-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 370mm | T - T | 32 Threaded 90° Elbow, Equal nr. 90 |
| 32 - Pipe, Schedule 40 | 620mm | T - T | 32 Threaded 90° Elbow, Equal nr. 90 |
| 32 - Pipe, Schedule 40 | 1710mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL19-a Quantity: 1 | | | |
| 50 - Pipe, Schedule 40 | 430mm | G - T | 50 x 32 Threaded 90° Reducing Elbow |
| 32 x 140 - Nipple, Schedule 40 (Single Stick) | 140mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL20-a Quantity: 1 | | | |
| 25 x 250 - Nipple, Schedule 40 (Single Stick) | 250mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| 25 - Pipe, Schedule 40 | 500mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| Line: CM1- Quantity: 1 | | | |
| 200 - Pipe, Schedule 40 | 1580mm | G - G | No Fitting |
| 200 - Pipe, Schedule 40 | 6400mm | G - G | No Fitting |
| 200 - Pipe, Schedule 40 | 3380mm | G - G | No Fitting |
| 200 - Pipe, Schedule 10 | 380mm | G - G | No Fitting |
| 200 - Pipe, Schedule 10 | 5070mm | G - G | No Fitting |
| 200 - Pipe, Schedule 10 | 3120mm | G - G | No Fitting |
| 200 - Pipe, Schedule 10 | 1030mm | G - G | No Fitting |
| Line: CM2- Quantity: 1 | | | |
| 80 - Pipe, Schedule 10 | 60mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 2290mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 100mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6320mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 1800mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 1560mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 1970mm | G - G | No Fitting |
| Line: CM3- Quantity: 1 | | | |
| 80 - Pipe, Schedule 10 | 600mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 3500mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 2130mm | G - G | No Fitting |
| Line: CM4- Quantity: 1 | | | |
| 80 - Pipe, Schedule 10 | 160mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 280mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 580mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 950mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 900mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 290mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 440mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6380mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 1670mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 10920mm | G - G | No Fitting |
| Line: DR1- Quantity: 86 | | | |
| 25 x 165 - Nipple, Schedule 40 (Single Stick) | 170mm | T - T | 25 x 15 Threaded Socket, reducing, nr. 240 |
| Line: DR2- Quantity: 32 | | | |
| 15 x 191 - Nipple, Schedule 40 (Single Stick) | 200mm | T - T | No Fitting |
| Line: DR3- Quantity: 1 | | | |
| 25 x 165 - Nipple, Schedule 40 (Single Stick) | 160mm | T - T | 25 x 15 Threaded Socket, reducing, nr. 240 |

Black-Black



Pipelines

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Description | Length | End Prep | Fitting |
|--|---------|----------|--|
| Line: DR3- Quantity: 1 | | | |
| Line: DR4- Quantity: 1 | | | |
| 25 x 178 - Nipple, Schedule 40 (Single Stick) | 180mm | T - T | 25 x 15 Threaded Socket, reducing, nr. 240 |
| Line: FR1- Quantity: 1 | | | |
| 150 - Pipe, Schedule 10 | 11840mm | G - G | No Fitting |
| 150 - Pipe, Schedule 10 | 1500mm | G - G | No Fitting |
| 150 - Pipe, Schedule 10 | 400mm | G - G | No Fitting |

Black-Black



Threaded Pipelines

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Description | Length | End Prep | Fitting |
|---|--------|----------|--|
| Line: BL1-a Quantity: 4 | | | |
| 32 - Pipe, Schedule 40 | 610mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 570mm | T - T | 32 Threaded Cap, nr.300 |
| Line: BL2-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 1200mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 25 - Pipe, Schedule 40 | 2070mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| 32 - Pipe, Schedule 40 | 800mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 1660mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL3-a Quantity: 4 | | | |
| 32 - Pipe, Schedule 40 | 610mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 570mm | T - T | 32 Threaded Cap, nr.300 |
| Line: BL4-a Quantity: 6 | | | |
| 32 - Pipe, Schedule 40 | 1310mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL5-a Quantity: 7 | | | |
| 32 x 216 - Nipple, Schedule 40 (Single Stick) | 210mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL6-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 490mm | T - T | 32 Threaded Straight Tee, equal, nr. 130 |
| 32 - Pipe, Schedule 40 | 1120mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | 2030mm | T - T | 32 Threaded Straight Tee, equal, nr. 130(Bull Head) |
| 32 - Pipe, Schedule 40 | 1120mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | 500mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL7-a Quantity: 8 | | | |
| 32 - Pipe, Schedule 40 | 620mm | T - T | 32 x 32 x 15 Threaded Reducing Tee |
| 32 - Pipe, Schedule 40 | 1960mm | T - T | 32 x 32 x 15 Threaded Reducing Tee |
| 32 - Pipe, Schedule 40 | 1970mm | T - T | 32 x 32 x 15 Threaded Reducing Tee |
| 32 - Pipe, Schedule 40 | 1960mm | T - T | 32 x 15 Threaded 90° Reducing Elbow |
| Line: BL8-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 610mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 570mm | T - T | 32 Threaded Cap, nr.300 |
| Line: BL9-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |

Black-Black



Threaded Pipelines

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Description | Length | End Prep | Fitting |
|--|--------|----------|--|
| Line: BL9-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 1670mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL10-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL11-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2140mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL12-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 x 191 - Nipple, Schedule 40 (Single Stick) | 190mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 1800mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 25 x 178 - Nipple, Schedule 40 (Single Stick) (Galv) | 180mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| 25 - Pipe, Schedule 40 (Galv) | 2050mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| 25 - Pipe, Schedule 40 (Galv) | 2060mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| Line: BL13-a Quantity: 1 | | | |
| 50 - Pipe, Schedule 40 | 570mm | G - T | 50 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 570mm | T - T | 32 Threaded Cap, nr.300 |
| Line: BL14-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2040mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL15-a Quantity: 3 | | | |
| 32 x 114 - Nipple, Schedule 40 (Single Stick) | 110mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL16-a Quantity: 1 | | | |
| 25 - Pipe, Schedule 40 | 2010mm | T - T | 25 Threaded Straight Tee, equal, nr. 130 |
| 25 - Pipe, Schedule 40 | 470mm | T - T | 25 Threaded Cap, nr.300 |
| Line: BL17-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 170mm | G - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL18-a Quantity: 1 | | | |

Black-Black**Threaded Pipelines**Current Date
10/06/2020**1 - Thesis**

Date Required

Default List Area

POJ

| Description | Length | End Prep | Fitting |
|---|--------|----------|--|
| Line: BL18-a Quantity: 1 | | | |
| 32 - Pipe, Schedule 40 | 1210mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 370mm | T - T | 32 Threaded 90° Elbow, Equal nr. 90 |
| 32 - Pipe, Schedule 40 | 620mm | T - T | 32 Threaded 90° Elbow, Equal nr. 90 |
| 32 - Pipe, Schedule 40 | 1710mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | 2050mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL19-a Quantity: 1 | | | |
| 50 - Pipe, Schedule 40 | 430mm | G - T | 50 x 32 Threaded 90° Reducing Elbow |
| 32 x 140 - Nipple, Schedule 40 (Single Stick) | 140mm | T - T | 32 x 25 Threaded 90° Elbow, reducing nr. 90R |
| Line: BL20-a Quantity: 1 | | | |
| 25 x 250 - Nipple, Schedule 40 (Single Stick) | 250mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| 25 - Pipe, Schedule 40 | 500mm | T - T | 25 Threaded 90° Elbow, Equal nr. 90 |
| Line: DR1- Quantity: 86 | | | |
| 25 x 165 - Nipple, Schedule 40 (Single Stick) | 170mm | T - T | 25 x 15 Threaded Socket, reducing, nr. 240 |
| Line: DR2- Quantity: 32 | | | |
| 15 x 191 - Nipple, Schedule 40 (Single Stick) | 200mm | T - T | No Fitting |
| Line: DR3- Quantity: 1 | | | |
| 25 x 165 - Nipple, Schedule 40 (Single Stick) | 160mm | T - T | 25 x 15 Threaded Socket, reducing, nr. 240 |
| Line: DR4- Quantity: 1 | | | |
| 25 x 178 - Nipple, Schedule 40 (Single Stick) | 180mm | T - T | 25 x 15 Threaded Socket, reducing, nr. 240 |

Black-Black



Welded Pipelines

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Description | Length | End Prep | Fitting |
|------------------------------------|---------|----------|------------|
| Line: CM1- Quantity: 1 | | | |
| 200 - Pipe, Schedule 40 | 1580mm | G - G | No Fitting |
| 200 - Pipe, Schedule 40 | 6400mm | G - G | No Fitting |
| 200 - Pipe, Schedule 40 | 3380mm | G - G | No Fitting |
| 200 - Pipe, Schedule 10 | 380mm | G - G | No Fitting |
| 200 - Pipe, Schedule 10 | 5070mm | G - G | No Fitting |
| 200 - Pipe, Schedule 10 | 3120mm | G - G | No Fitting |
| 200 - Pipe, Schedule 10 | 1030mm | G - G | No Fitting |
| Line: CM2- Quantity: 1 | | | |
| 80 - Pipe, Schedule 10 | 60mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 2290mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 100mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6320mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 1800mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 1560mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 1970mm | G - G | No Fitting |
| Line: CM3- Quantity: 1 | | | |
| 80 - Pipe, Schedule 10 | 600mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 3500mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 2130mm | G - G | No Fitting |
| Line: CM4- Quantity: 1 | | | |
| 80 - Pipe, Schedule 10 | 160mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 280mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 580mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 950mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 900mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 290mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 440mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6380mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 1670mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 6400mm | G - G | No Fitting |
| 80 - Pipe, Schedule 10 | 10920mm | G - G | No Fitting |
| Line: FR1- Quantity: 1 | | | |
| 150 - Pipe, Schedule 10 | 11840mm | G - G | No Fitting |
| 150 - Pipe, Schedule 10 | 1500mm | G - G | No Fitting |
| 150 - Pipe, Schedule 10 | 400mm | G - G | No Fitting |

Black-Black



Other Pipelines

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Description | Length | End Prep | Fitting |
|---|---------|----------|--|
| Line: DR1- Quantity: 86 | | | |
| 25 x 165 - Nipple, Schedule 40 (Single Stick) | 170mm | T - T | 25 x 15 Threaded Socket, reducing, nr. 240 |
| Line: DR2- Quantity: 32 | | | |
| 15 x 191 - Nipple, Schedule 40 (Single Stick) | 200mm | T - T | No Fitting |
| Line: DR3- Quantity: 1 | | | |
| 25 x 165 - Nipple, Schedule 40 (Single Stick) | 160mm | T - T | 25 x 15 Threaded Socket, reducing, nr. 240 |
| Line: DR4- Quantity: 1 | | | |
| 25 x 178 - Nipple, Schedule 40 (Single Stick) | 180mm | T - T | 25 x 15 Threaded Socket, reducing, nr. 240 |
| Line: FR1- Quantity: 1 | | | |
| 150 - Pipe, Schedule 10 | 11840mm | G - G | No Fitting |
| 150 - Pipe, Schedule 10 | 1500mm | G - G | No Fitting |
| 150 - Pipe, Schedule 10 | 400mm | G - G | No Fitting |

Black-Black



Cut Pipe Report - Threaded

Current Date
10/06/2020


1 - Thesis

Date Required

Default List Area

POJ

| Piece | Length | End Prep | Fitting |
|-------------------------------|-----------------|----------|---|
| 50 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL13-a-A 570mm | GxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL19-a-A 430mm | GxT | 50 x 32 Thrd Red 90 |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL9-a-A 1210mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL18-a-C 620mm | TxT | Threaded 90° Elbow, Equal nr. 90 |
| | BL8-a-A 610mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| 1 @ 6401mm : | BL11-a-B 2140mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL4-a-C 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL4-a-D 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL4-a-D 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| | BL11-a-D 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| | BL18-a-E 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL17-a-A 170mm | GxT | Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL4-a-C 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL4-a-C 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL18-a-F 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL4-a-C 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL4-a-D 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| | BL4-a-D 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL4-a-D 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| | BL6-a-D 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL9-a-D 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL2-a-F 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL4-a-C 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL9-a-B 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL4-a-D 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| | BL12-a-E 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL14-a-C 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL4-a-C 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL10-a-C 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL10-a-D 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL6-a-B 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL11-a-C 2050mm | TxT | Threaded Reducing Tee, reducing, nr. 130R |
| | BL14-a-D 2050mm | TxT | Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | | | |

|  | | Cut Pipe Report - Threaded | | | Current Date 10/06/2020 |
|--|----------|----------------------------|---------|--|----------------------------|
| | | 1 - Thesis | | | Date Required |
| | | Default List Area | | | POJ |
| Piece | Length | End Prep | Fitting | | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL4-a-B | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| | BL6-a-C | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| | BL10-a-B | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL4-a-B | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| | BL4-a-B | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| | BL9-a-C | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL2-a-E | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| | BL4-a-B | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| | BL12-a-D | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL4-a-B | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| | BL4-a-B | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| | BL14-a-B | 2040mm | TxT | Threaded Reducing Tee, reducing, nr. 130R | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL6-a-G | 2030mm | TxT | Threaded Straight Tee, equal, nr. 130(Bull Head) | |
| | BL7-a-C | 1970mm | TxT | 32 x 32 x 15 Thrd Red T | |
| | BL7-a-C | 1970mm | TxT | 32 x 32 x 15 Thrd Red T | |
| | BL18-a-B | 370mm | TxT | Threaded 90° Elbow, Equal nr. 90 | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL7-a-C | 1970mm | TxT | 32 x 32 x 15 Thrd Red T | |
| | BL7-a-C | 1970mm | TxT | 32 x 32 x 15 Thrd Red T | |
| | BL7-a-C | 1970mm | TxT | 32 x 32 x 15 Thrd Red T | |
| | BL6-a-E | 490mm | TxT | Threaded Straight Tee, equal, nr. 130 | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL7-a-C | 1970mm | TxT | 32 x 32 x 15 Thrd Red T | |
| | BL7-a-C | 1970mm | TxT | 32 x 32 x 15 Thrd Red T | |
| | BL7-a-C | 1970mm | TxT | 32 x 32 x 15 Thrd Red T | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL7-a-D | 1960mm | TxT | 32 x 15 Thrd Red 90 | |
| | BL7-a-D | 1960mm | TxT | 32 x 15 Thrd Red 90 | |
| | BL7-a-D | 1960mm | TxT | 32 x 15 Thrd Red 90 | |
| | BL6-a-I | 500mm | TxT | Threaded 90° Elbow, reducing nr. 90R | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL7-a-B | 1960mm | TxT | 32 x 32 x 15 Thrd Red T | |
| | BL7-a-D | 1960mm | TxT | 32 x 15 Thrd Red 90 | |
| | BL7-a-D | 1960mm | TxT | 32 x 15 Thrd Red 90 | |
| 32 - Pipe, Schedule 40 | | | | | |
| 1 @ 6401mm : | BL7-a-B | 1960mm | TxT | 32 x 32 x 15 Thrd Red T | |
| | BL7-a-D | 1960mm | TxT | 32 x 15 Thrd Red 90 | |
| | BL7-a-D | 1960mm | TxT | 32 x 15 Thrd Red 90 | |
| 32 - Pipe, Schedule 40 | | | | | |

Black-Black**Cut Pipe Report - Threaded**Current Date
10/06/2020**1 - Thesis**

Date Required

Default List Area

POJ

| Piece | Length | End Prep | Fitting |
|-------------------------------|----------|----------|---|
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL7-a-B | 1960mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-B | 1960mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-B | 1960mm | TxT 32 x 32 x 15 Thrd Red T |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL7-a-B | 1960mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-B | 1960mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-D | 1960mm | TxT 32 x 15 Thrd Red 90 |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL7-a-B | 1960mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL12-a-C | 1800mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL18-a-D | 1710mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL2-a-D | 800mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL9-a-E | 1670mm | TxT Threaded 90° Elbow, reducing nr. 90R |
| | BL2-a-G | 1660mm | TxT Threaded 90° Elbow, reducing nr. 90R |
| | BL4-a-A | 1310mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL4-a-A | 1310mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL4-a-A | 1310mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL4-a-A | 1310mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL4-a-A | 1310mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL4-a-A | 1310mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL6-a-H | 1120mm | TxT Threaded 90° Elbow, reducing nr. 90R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL2-a-A | 1210mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL6-a-A | 1210mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL11-a-A | 1210mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL12-a-A | 1210mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL18-a-A | 1210mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL10-a-A | 1210mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL14-a-A | 1210mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL2-a-B | 1200mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL6-a-F | 1120mm | TxT Threaded 90° Elbow, reducing nr. 90R |
| | BL7-a-A | 620mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-A | 620mm | TxT 32 x 32 x 15 Thrd Red T |
| 32 - Pipe, Schedule 40 | | | |


Black-Black**Cut Pipe Report - Threaded**Current Date
10/06/2020**1 - Thesis**

Date Required

Default List Area

POJ

| Piece | Length | End Prep | Fitting |
|--|----------|----------|---|
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL7-a-A | 620mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-A | 620mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-A | 620mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-A | 620mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-A | 620mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL7-a-A | 620mm | TxT 32 x 32 x 15 Thrd Red T |
| | BL1-a-A | 610mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL3-a-A | 610mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL3-a-A | 610mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL3-a-A | 610mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL1-a-A | 610mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL1-a-A | 610mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL1-a-A | 610mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL3-a-A | 610mm | TxT Threaded Reducing Tee, reducing, nr. 130R |
| | BL1-a-B | 570mm | TxT Threaded Cap, nr.300 |
| | BL1-a-B | 570mm | TxT Threaded Cap, nr.300 |
| | BL1-a-B | 570mm | TxT Threaded Cap, nr.300 |
| | BL3-a-B | 570mm | TxT Threaded Cap, nr.300 |
| | BL3-a-B | 570mm | TxT Threaded Cap, nr.300 |
| | BL13-a-B | 570mm | TxT Threaded Cap, nr.300 |
| 32 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL1-a-B | 570mm | TxT Threaded Cap, nr.300 |
| | BL3-a-B | 570mm | TxT Threaded Cap, nr.300 |
| | BL3-a-B | 570mm | TxT Threaded Cap, nr.300 |
| | BL8-a-B | 570mm | TxT Threaded Cap, nr.300 |
| 25 - Pipe, Schedule 40 (Galv) | | | |
| 1 @ 6401mm : | BL12-a-H | 2060mm | TxT Threaded 90° Elbow, Equal nr. 90 |
| | BL12-a-G | 2050mm | TxT Threaded 90° Elbow, Equal nr. 90 |
| 25 - Pipe, Schedule 40 | | | |
| 1 @ 6401mm : | BL2-a-C | 2070mm | TxT Threaded 90° Elbow, Equal nr. 90 |
| | BL16-a-A | 2010mm | TxT Threaded Straight Tee, equal, nr. 130 |
| | BL20-a-B | 500mm | TxT Threaded 90° Elbow, Equal nr. 90 |
| | BL16-a-B | 470mm | TxT Threaded Cap, nr.300 |

|  | | Cut Pipe Report - Welded | | | Current Date 10/06/2020 |
|--|--------|--------------------------|---------|------------|----------------------------|
| | | 1 - Thesis | | | Date Required |
| | | Default List Area | | | POJ |
| Piece | Length | End Prep | Fitting | | |
| 200 - Pipe, Schedule 10 | | | | | |
| 1 @ 7408mm : | CM1--E | 5070mm | GxG | No Fitting | |
| | CM1--G | 1030mm | GxG | No Fitting | |
| | CM1--D | 380mm | GxG | No Fitting | |
| 200 - Pipe, Schedule 10 | | | | | |
| 1 @ 7408mm : | CM1--F | 3120mm | GxG | No Fitting | |
| 150 - Pipe, Schedule 10 | | | | | |
| 1 @ 11840mm : | FR1--A | 11840mm | GxG | No Fitting | |
| 150 - Pipe, Schedule 10 | | | | | |
| 1 @ 11840mm : | FR1--B | 1500mm | GxG | No Fitting | |
| | FR1--C | 400mm | GxG | No Fitting | |
| 80 - Pipe, Schedule 10 | | | | | |
| 1 @ 10922mm : | CM4--K | 10920mm | GxG | No Fitting | |
| 80 - Pipe, Schedule 10 | | | | | |
| 1 @ 10922mm : | CM4--J | 6400mm | GxG | No Fitting | |
| | CM3--D | 3500mm | GxG | No Fitting | |
| | CM4--D | 950mm | GxG | No Fitting | |
| | CM2--A | 60mm | GxG | No Fitting | |
| 80 - Pipe, Schedule 10 | | | | | |
| 1 @ 10922mm : | CM2--G | 6400mm | GxG | No Fitting | |
| | CM2--B | 2290mm | GxG | No Fitting | |
| | CM3--E | 2130mm | GxG | No Fitting | |
| | CM2--C | 100mm | GxG | No Fitting | |
| 80 - Pipe, Schedule 10 | | | | | |
| 1 @ 10922mm : | CM3--C | 6400mm | GxG | No Fitting | |
| | CM2--I | 1970mm | GxG | No Fitting | |
| | CM2--F | 1800mm | GxG | No Fitting | |
| | CM3--A | 600mm | GxG | No Fitting | |
| 80 - Pipe, Schedule 10 | | | | | |
| 1 @ 10922mm : | CM3--B | 6400mm | GxG | No Fitting | |
| | CM4--I | 1670mm | GxG | No Fitting | |
| | CM2--H | 1560mm | GxG | No Fitting | |
| | CM4--E | 900mm | GxG | No Fitting | |
| | CM4--F | 290mm | GxG | No Fitting | |
| 80 - Pipe, Schedule 10 | | | | | |
| 1 @ 10922mm : | CM2--E | 6400mm | GxG | No Fitting | |
| | CM4--C | 580mm | GxG | No Fitting | |
| | CM4--G | 440mm | GxG | No Fitting | |
| | CM4--B | 280mm | GxG | No Fitting | |
| | CM4--A | 160mm | GxG | No Fitting | |
| 80 - Pipe, Schedule 10 | | | | | |
| 1 @ 10922mm : | CM4--H | 6380mm | GxG | No Fitting | |
| 80 - Pipe, Schedule 10 | | | | | |
| 1 @ 10922mm : | CM2--D | 6320mm | GxG | No Fitting | |
| 200 - Pipe, Schedule 40 | | | | | |

Black-Black



Cut Pipe Report - Welded

Current Date
10/06/2020



1 - Thesis

Date Required

Default List Area

POJ



| Piece | Length | End Prep | Fitting | |
|--------------------------------|--------|----------|---------|------------|
| 200 - Pipe, Schedule 40 | | | | |
| 1 @ 6401mm : | CM1--B | 6400mm | GxG | No Fitting |
| 200 - Pipe, Schedule 40 | | | | |
| 1 @ 6401mm : | CM1--C | 3380mm | GxG | No Fitting |
| | CM1--A | 1580mm | GxG | No Fitting |

Black-Black  **BL13a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL13a
Fitting: 50 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **50 - SCH 40 G-T Length: 570mm**



Pipe: 50 - SCH 40 Length: 570mm

Black-Black  **BL11a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL11a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2140mm**



Pipe: 32 - SCH 40 Length: 2140mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL18a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL18a
Fitting: 32 Threaded 90° Elbow, Equal nr. 90
Pipe: **32 - SCH 40 T-T Length: 620mm**



Pipe: 32 - SCH 40 Length: 620mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL19a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL19a
Fitting: 50 x 32 Thrd Red 90
Pipe: **50 - SCH 40 G-T Length: 430mm**



Pipe: 50 - SCH 40 Length: 430mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2050mm**

Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL9a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL9a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 1210mm**



Pipe: 32 - SCH 40 Length: 1210mm

Black-Black  **BL8a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL8a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 610mm**



Pipe: 32 - SCH 40 Length: 610mm

Black-Black  **BL11a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL11a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL18a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL18a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL18a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL18a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL17a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL17a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 G-T Length: 170mm**



Pipe: 32 - SCH 40 Length: 170mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL6a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL6a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL9a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL9a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL14a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL14a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL10a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL10a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL2a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL2a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL9a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL9a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL12a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL12a
Fitting: 32 x 25 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL10a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL10a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: 32 - SCH 40 T-T Length: 2050mm



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL6a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL6a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL14a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL14a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL6a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL6a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL9a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL9a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL11a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL11a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2050mm**



Pipe: 32 - SCH 40 Length: 2050mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL10a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL10a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL2a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL2a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL14a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL14a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**


Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL7a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: **32 - SCH 40 T-T Length: 1970mm**



Pipe: 32 - SCH 40 Length: 1970mm

Black-Black  **BL18a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL18a
Fitting: 32 Threaded 90° Elbow, Equal nr. 90
Pipe: **32 - SCH 40 T-T Length: 370mm**



Pipe: 32 - SCH 40 Length: 370mm

Black-Black  **BL12a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL12a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL4a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 2040mm**



Pipe: 32 - SCH 40 Length: 2040mm

Black-Black  **BL6a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL6a
Fitting: 32 Threaded Straight Tee, equal, nr. 130 (Bull Head)
Pipe: **32 - SCH 40 T-T Length: 2030mm**



Pipe: 32 - SCH 40 Length: 2030mm

Black-Black  **BL7a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: **32 - SCH 40 T-T Length: 1970mm**



Pipe: 32 - SCH 40 Length: 1970mm

Black-Black  **BL7a** 

Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: **32 - SCH 40 T-T Length: 1970mm**

Pipe: 32 - SCH 40 Length: 1970mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1970mm

Pipe: 32 - SCH 40 Length: 1970mm

Black-Black  BL6a 
Job: 1 - Thesis
Area: Default List Area



Line: BL6a
Fitting: 32 Threaded Straight Tee, equal, nr. 130
Pipe: 32 - SCH 40 T-T Length: 490mm

Pipe: 32 - SCH 40 Length: 490mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1970mm

Pipe: 32 - SCH 40 Length: 1970mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 15 Thrd Red 90
Pipe: 32 - SCH 40 T-T Length: 1960mm

Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 15 Thrd Red 90
Pipe: 32 - SCH 40 T-T Length: 1960mm

Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1970mm

Pipe: 32 - SCH 40 Length: 1970mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1970mm

Pipe: 32 - SCH 40 Length: 1970mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1970mm

Pipe: 32 - SCH 40 Length: 1970mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 15 Thrd Red 90
Pipe: 32 - SCH 40 T-T Length: 1960mm

Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL6a 
Job: 1 - Thesis
Area: Default List Area

Line: BL6a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: 32 - SCH 40 T-T Length: 500mm



Pipe: 32 - SCH 40 Length: 500mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 15 Thrd Red 90
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 15 Thrd Red 90
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 15 Thrd Red 90
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 15 Thrd Red 90
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL18a 

Job: 1 - Thesis
Area: Default List Area

Line: BL18a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1710mm



Pipe: 32 - SCH 40 Length: 1710mm

Black-Black  BL9a 

Job: 1 - Thesis
Area: Default List Area

Line: BL9a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: 32 - SCH 40 T-T Length: 1670mm



Pipe: 32 - SCH 40 Length: 1670mm

Black-Black  BL4a 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1310mm



Pipe: 32 - SCH 40 Length: 1310mm

Black-Black  BL7a 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 15 Thrd Red 90
Pipe: 32 - SCH 40 T-T Length: 1960mm



Pipe: 32 - SCH 40 Length: 1960mm

Black-Black  BL12a 

Job: 1 - Thesis
Area: Default List Area

Line: BL12a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1800mm



Pipe: 32 - SCH 40 Length: 1800mm

Black-Black  BL2a 

Job: 1 - Thesis
Area: Default List Area

Line: BL2a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 800mm



Pipe: 32 - SCH 40 Length: 800mm

Black-Black  BL2a 

Job: 1 - Thesis
Area: Default List Area

Line: BL2a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: 32 - SCH 40 T-T Length: 1660mm



Pipe: 32 - SCH 40 Length: 1660mm

Black-Black  BL4a 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1310mm



Pipe: 32 - SCH 40 Length: 1310mm

Black-Black  BL4a 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1310mm



Pipe: 32 - SCH 40 Length: 1310mm

Black-Black  BL4a 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1310mm


Pipe: 32 - SCH 40 Length: 1310mm

Black-Black  BL6a 

Job: 1 - Thesis
Area: Default List Area

Line: BL6a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: 32 - SCH 40 T-T Length: 1120mm

Pipe: 32 - SCH 40 Length: 1120mm

Black-Black  BL6a 

Job: 1 - Thesis
Area: Default List Area

Line: BL6a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1210mm



Pipe: 32 - SCH 40 Length: 1210mm

Black-Black  BL12a 

Job: 1 - Thesis
Area: Default List Area

Line: BL12a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1210mm



Pipe: 32 - SCH 40 Length: 1210mm

Black-Black  BL4a 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1310mm



Pipe: 32 - SCH 40 Length: 1310mm

Black-Black  BL4a 

Job: 1 - Thesis
Area: Default List Area

Line: BL4a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1310mm



Pipe: 32 - SCH 40 Length: 1310mm

Black-Black  BL2a 

Job: 1 - Thesis
Area: Default List Area

Line: BL2a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1210mm



Pipe: 32 - SCH 40 Length: 1210mm

Black-Black  BL11a 

Job: 1 - Thesis
Area: Default List Area

Line: BL11a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1210mm



Pipe: 32 - SCH 40 Length: 1210mm

Black-Black  BL18a 

Job: 1 - Thesis
Area: Default List Area

Line: BL18a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 1210mm



Pipe: 32 - SCH 40 Length: 1210mm

Black-Black  **BL10a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL10a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 1210mm**



Pipe: 32 - SCH 40 Length: 1210mm

Black-Black  **BL2a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL2a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 1200mm**



Pipe: 32 - SCH 40 Length: 1200mm

Black-Black  **BL7a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: **32 - SCH 40 T-T Length: 620mm**


Pipe: 32 - SCH 40 Length: 620mm

Black-Black  **BL7a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: **32 - SCH 40 T-T Length: 620mm**



Pipe: 32 - SCH 40 Length: 620mm

Black-Black  **BL7a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: **32 - SCH 40 T-T Length: 620mm**



Pipe: 32 - SCH 40 Length: 620mm

Black-Black  **BL14a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL14a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: **32 - SCH 40 T-T Length: 1210mm**



Pipe: 32 - SCH 40 Length: 1210mm

Black-Black  **BL6a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL6a
Fitting: 32 x 25 Threaded 90° Elbow, reducing nr. 90R
Pipe: **32 - SCH 40 T-T Length: 1120mm**



Pipe: 32 - SCH 40 Length: 1120mm

Black-Black  **BL7a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: **32 - SCH 40 T-T Length: 620mm**



Pipe: 32 - SCH 40 Length: 620mm

Black-Black  **BL7a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: **32 - SCH 40 T-T Length: 620mm**



Pipe: 32 - SCH 40 Length: 620mm

Black-Black  **BL7a** 

Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: **32 - SCH 40 T-T Length: 620mm**

Pipe: 32 - SCH 40 Length: 620mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area



Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 620mm

Pipe: 32 - SCH 40 Length: 620mm

Black-Black  BL1a 
Job: 1 - Thesis
Area: Default List Area

Line: BL1a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 610mm

Pipe: 32 - SCH 40 Length: 610mm

Black-Black  BL3a 
Job: 1 - Thesis
Area: Default List Area

Line: BL3a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 610mm

Pipe: 32 - SCH 40 Length: 610mm

Black-Black  BL1a 
Job: 1 - Thesis
Area: Default List Area



Line: BL1a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 610mm

Pipe: 32 - SCH 40 Length: 610mm

Black-Black  BL1a 
Job: 1 - Thesis
Area: Default List Area



Line: BL1a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 610mm

Pipe: 32 - SCH 40 Length: 610mm

Black-Black  BL7a 
Job: 1 - Thesis
Area: Default List Area


Line: BL7a
Fitting: 32 x 32 x 15 Thrd Red T
Pipe: 32 - SCH 40 T-T Length: 620mm

Pipe: 32 - SCH 40 Length: 620mm

Black-Black  BL3a 
Job: 1 - Thesis
Area: Default List Area


Line: BL3a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 610mm

Pipe: 32 - SCH 40 Length: 610mm

Black-Black  BL3a 
Job: 1 - Thesis
Area: Default List Area



Line: BL3a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 610mm

Pipe: 32 - SCH 40 Length: 610mm

Black-Black  BL1a 
Job: 1 - Thesis
Area: Default List Area


Line: BL1a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 610mm

Pipe: 32 - SCH 40 Length: 610mm

Black-Black  BL3a 
Job: 1 - Thesis
Area: Default List Area

Line: BL3a
Fitting: 32 x 32 x 25 Threaded Reducing Tee, reducing, nr. 130R
Pipe: 32 - SCH 40 T-T Length: 610mm



Pipe: 32 - SCH 40 Length: 610mm

Black-Black  BL1a 

Job: 1 - Thesis
Area: Default List Area

Line: BL1a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm



Pipe: 32 - SCH 40 Length: 570mm

Black-Black  BL1a 

Job: 1 - Thesis
Area: Default List Area

Line: BL1a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm


Pipe: 32 - SCH 40 Length: 570mm

Black-Black  BL3a 

Job: 1 - Thesis
Area: Default List Area

Line: BL3a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm



Pipe: 32 - SCH 40 Length: 570mm

Black-Black  BL1a 

Job: 1 - Thesis
Area: Default List Area

Line: BL1a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm

Pipe: 32 - SCH 40 Length: 570mm

Black-Black  BL3a 

Job: 1 - Thesis
Area: Default List Area

Line: BL3a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm



Pipe: 32 - SCH 40 Length: 570mm

Black-Black  BL1a 

Job: 1 - Thesis
Area: Default List Area

Line: BL1a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm

Pipe: 32 - SCH 40 Length: 570mm

Black-Black  BL3a 

Job: 1 - Thesis
Area: Default List Area

Line: BL3a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm

Pipe: 32 - SCH 40 Length: 570mm

Black-Black  BL13a 

Job: 1 - Thesis
Area: Default List Area

Line: BL13a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm



Pipe: 32 - SCH 40 Length: 570mm

Black-Black  BL3a 

Job: 1 - Thesis
Area: Default List Area

Line: BL3a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm



Pipe: 32 - SCH 40 Length: 570mm

Black-Black  BL8a 

Job: 1 - Thesis
Area: Default List Area

Line: BL8a
Fitting: 32 Threaded Cap, nr.300
Pipe: 32 - SCH 40 T-T Length: 570mm



Pipe: 32 - SCH 40 Length: 570mm

Black-Black  **BL12a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL12a
Fitting: 25 Threaded 90° Elbow, Equal nr. 90
Pipe: **25 - SCH 40 T-T Length: 2060mm**

Pipe: 25 - SCH 40 Length: 2060mm

Black-Black  **BL2a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL2a
Fitting: 25 Threaded 90° Elbow, Equal nr. 90
Pipe: **25 - SCH 40 T-T Length: 2070mm**



Pipe: 25 - SCH 40 Length: 2070mm

Black-Black  **BL20a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL20a
Fitting: 25 Threaded 90° Elbow, Equal nr. 90
Pipe: **25 - SCH 40 T-T Length: 500mm**



Pipe: 25 - SCH 40 Length: 500mm

Black-Black  **BL12a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL12a
Fitting: 25 Threaded 90° Elbow, Equal nr. 90
Pipe: **25 - SCH 40 T-T Length: 2050mm**

Pipe: 25 - SCH 40 Length: 2050mm

Black-Black  **BL16a** 

Job: 1 - Thesis
Area: Default List Area

Line: BL16a
Fitting: 25 Threaded Straight Tee, equal, nr. 130
Pipe: **25 - SCH 40 T-T Length: 2010mm**











Pipe: 25 - SCH 40 Length: 2010mm











Black-Black  **BL16a** 











Job: 1 - Thesis
Area: Default List Area






Line: BL16a
Fitting: 25 Threaded Cap, nr.300
Pipe: **25 - SCH 40 T-T Length: 470mm**

Pipe: 25 - SCH 40 Length: 470mm









Black-Black



Other Pipe

Current Date
10/06/2020

1 - Thesis

Date Required

Default List Area

POJ

| Quantity | Description | Length | End Prep | Fitting |
|----------|-------------|--------|----------|---------|
|----------|-------------|--------|----------|---------|

Armovers/Drop/Sprigs

Line: DR1 Quantity: 86

Threaded Pieces

| | | | | |
|---|--|-------|-----|--|
| 1 | 25 x 165 - Nipple, Schedule 4025 x 165 - Nipple, Sched | 170mm | T-T | 25 x 15 Threaded Socket, reducing, nr. 240 |
|---|--|-------|-----|--|

Line: DR2 Quantity: 32

Threaded Pieces

| | | | | |
|---|--|-------|-----|------------|
| 1 | 15 x 191 - Nipple, Schedule 4015 x 191 - Nipple, Sched | 200mm | T-T | No Fitting |
|---|--|-------|-----|------------|

Line: DR3 Quantity: 1

Threaded Pieces

| | | | | |
|---|--|-------|-----|--|
| 1 | 25 x 165 - Nipple, Schedule 4025 x 165 - Nipple, Sched | 160mm | T-T | 25 x 15 Threaded Socket, reducing, nr. 240 |
|---|--|-------|-----|--|

Line: DR4 Quantity: 1

Threaded Pieces

| | | | | |
|---|--|-------|-----|--|
| 1 | 25 x 178 - Nipple, Schedule 4025 x 178 - Nipple, Sched | 180mm | T-T | 25 x 15 Threaded Socket, reducing, nr. 240 |
|---|--|-------|-----|--|

Feed Risers

Line: FR1 Quantity: 1

Threaded Pieces

Non - Threaded Pieces

| | | | | |
|---|--|---------|-----|------------|
| 1 | 150 - Pipe, Schedule 10150 - Pipe, Schedule 10 | 400mm | G-G | No Fitting |
| 1 | 150 - Pipe, Schedule 10150 - Pipe, Schedule 10 | 1500mm | G-G | No Fitting |
| 1 | 150 - Pipe, Schedule 10150 - Pipe, Schedule 10 | 11840mm | G-G | No Fitting |

| Fittings and Valves Expressed in Equivalent Feet (Meters) of Pipe | | | | | | | | | | | | | | | |
|---|-------|-----|-------|-----|--------|-----|--------|-----|-------|-----|--------|-----|-------|-----|--|
| Fittings and Valves | ¾ in. | | 1 in. | | 1¼ in. | | 1½ in. | | 2 in. | | 2½ in. | | 3 in. | | |
| | ft | m | ft | m | ft | m | ft | m | ft | m | ft | m | ft | m | |
| 45° elbow | 1 | 0.3 | 1 | 0.3 | 1 | 0.3 | 2 | 0.6 | 2 | 0.6 | 3 | 0.9 | 3 | 0.9 | |
| 90° standard elbow | 2 | 0.6 | 2 | 0.6 | 3 | 0.9 | 4 | 1.2 | 5 | 1.5 | 6 | 1.8 | 7 | 2.1 | |
| 90° long turn elbow | 1 | 0.3 | 2 | 0.6 | 2 | 0.6 | 2 | 0.6 | 3 | 0.9 | 4 | 1.2 | 5 | 1.5 | |
| Tee or cross (flow turned 90°) | 4 | 1.2 | 5 | 1.5 | 6 | 1.8 | 8 | 2.4 | 10 | 3.1 | 12 | 3.7 | 15 | 4.6 | |
| Gate valve | — | — | — | — | — | — | — | — | 1 | 0.3 | 1 | 0.3 | 1 | 0.3 | |
| Butterfly valve | — | — | — | — | — | — | — | — | 6 | 1.8 | 7 | 2.1 | 10 | 3.1 | |
| Swing check* | 4 | 1.2 | 5 | 1.5 | 7 | 2.1 | 9 | 2.7 | 11 | 3.4 | 14 | 4.3 | 16 | 4.9 | |

| Fittings and Valves Expressed in Equivalent Feet (Meters) of Pipe | | | | | | | | | | | | | | | |
|---|--------|-----|-------|-----|-------|-----|-------|-----|-------|------|--------|------|--------|------|--|
| Fittings and Valves | 3½ in. | | 4 in. | | 5 in. | | 6 in. | | 8 in. | | 10 in. | | 12 in. | | |
| | ft | m | ft | m | ft | m | ft | m | ft | m | ft | m | ft | m | |
| 45° elbow | 3 | 0.9 | 4 | 1.2 | 5 | 1.5 | 7 | 2.1 | 9 | 2.7 | 11 | 3.4 | 13 | 4.0 | |
| 90° standard elbow | 8 | 2.4 | 10 | 3.1 | 12 | 3.7 | 14 | 4.3 | 18 | 5.5 | 22 | 6.7 | 27 | 8.2 | |
| 90° long turn elbow | 5 | 1.5 | 6 | 1.8 | 8 | 2.4 | 9 | 2.7 | 13 | 4.0 | 16 | 4.9 | 18 | 5.5 | |
| Tee or cross (flow turned 90°) | 17 | 5.2 | 20 | 6.1 | 25 | 7.6 | 30 | 9.2 | 35 | 10.7 | 50 | 15.3 | 60 | 18.3 | |
| Gate valve | 1 | 0.3 | 2 | 0.6 | 2 | 0.6 | 3 | 0.9 | 4 | 1.2 | 5 | 1.5 | 6 | 1.8 | |
| Butterfly valve | — | — | 12 | 3.7 | 9 | 2.7 | 10 | 3.1 | 12 | 3.7 | 19 | 5.8 | 21 | 6.4 | |
| Swing check* | 19 | 5.8 | 22 | 6.7 | 27 | 8.2 | 32 | 9.8 | 45 | 13.7 | 55 | 16.8 | 65 | 19.8 | |

Table A.1 – Equivalent Pipe Length

APPENDIX B – NFPA 11 ANALYSIS




Table B.1 – Number of Fixed Foam Discharge Outlets for Fixed-Roof Tanks Containing Hydrocarbons or Flammable and Combustible Liquids Requiring Alcohol-Resistant Foams

| Tank Diameter (or Equivalent Area) | | Minimum Number of Discharge Outlets |
|---------------------------------------|-----------------|--|
| m | ft | |
| Up to 24 | Up to 80 | 1 |
| Over 24 to 36 | Over 80 to 120 | 2 |
| Over 36 to 42 | Over 120 to 140 | 3 |
| Over 42 to 48 | Over 140 to 160 | 4 |
| Over 48 to 54 | Over 160 to 180 | 5 |
| Over 54 to 60 | Over 180 to 200 | 6 |
| Over 60 | Over 200 | 6 |
| | | Plus 1 outlet for each additional 465 m ² (5000 ft ²) |

Table B.2 – Minimum Discharge Times and Application Rates for Type II Fixed Foam Discharge Outlets on Fixed-Roof (Cone) Storage Tanks Containing Hydrocarbons

| Hydrocarbon Type | Minimum Application Rate | | Minimum Discharge Time (minutes) |
|---|--------------------------|---------------------|-------------------------------------|
| | L/min · m ² | gpm/ft ² | |
| Flash point between 37.8°C and 60°C (100°F and 140°F) | 4.1 | 0.10 | 30 |
| Flash point below 37.8°C (100°F) or liquids heated above their flash points | 4.1 | 0.10 | 55 |
| Crude petroleum | 4.1 | 0.10 | 55 |

Table B.3 – Foam Handline and Monitor Protection for Fixed-Roof Storage Tanks Containing Hydrocarbons

| Hydrocarbon Type | Minimum Application Rate | | Minimum Discharge Time (minutes) |
|---|--------------------------|---------------------|--|
| | L/min · m ² | gpm/ft ² | |
| Flash point between 37.8°C and 60°C (100°F and 140°F) | 6.5 | 0.16 | 50 |
| Flash point below 37.8°C (100°F) or liquids heated above their flash points | 6.5 | 0.16 | 65 |
| Crude petroleum | 6.5 | 0.16 | 65 |

Table B.4 – Top-of-Seal Fixed Foam Discharge Protection for Open-Top and Internal Floating Roof Tanks

| Seal Type | Applicable Illustration Detail | Minimum Application Rate | | Minimum Discharge Time (minutes) | Maximum Spacing Between Discharge Outlets with | | | |
|--|--------------------------------|--------------------------|---------------------|----------------------------------|--|----|--------------------------|----|
| | | L/min · m ² | gpm/ft ² | | 305 mm (12 in.) Foam Dam | | 610 mm (24 in.) Foam Dam | |
| | | | | | m | ft | m | ft |
| Mechanical shoe seal | A | 12.2 | 0.3 | 20 | 12.2 | 40 | 24.4 | 80 |
| Tube seal with metal weather shield | B | 12.2 | 0.3 | 20 | 12.2 | 40 | 24.4 | 80 |
| Fully or partly combustible secondary seal | C | 12.2 | 0.3 | 20 | 12.2 | 40 | 24.4 | 80 |
| All metal secondary seal | D | 12.2 | 0.3 | 20 | 12.2 | 40 | 24.4 | 80 |

Note: Where the fixed foam discharge outlets are mounted above the top of the tank shell, a foam splashboard is necessary due to the effect of winds.

Table B.5 – Bellow-the-Seal Fixed Foam Discharge Protection for Open-Top Floating Roof Tanks

| Seal Type | Applicable Illustration Detail | Minimum Application Rate | | Minimum Discharge Time (minutes) | Maximum Spacing Between Discharge Outlets |
|--|--------------------------------|--------------------------|---------------------|----------------------------------|---|
| | | L/min · m ² | gpm/ft ² | | |
| Mechanical shoe seal | A | 20.4 | 0.5 | 10 | 39 m (130 ft) — Foam dam not required |
| Tube seal with more than 152 mm (6 in.) between top of tube and top of pontoon | B | 20.4 | 0.5 | 10 | 18 m (60 ft) — Foam dam not required |
| Tube seal with less than 152 mm (6 in.) between top of tube and top of pontoon | C | 20.4 | 0.5 | 10 | 18 m (60 ft) — Foam dam required |
| Tube seal with foam discharge below metal secondary seal* | D | 20.4 | 0.5 | 10 | 18 m (60 ft) — Foam dam not required |




Figure B.2 – Analysis of NFPA 11 Sub Chapter 5.7 – Diked Areas

Table B.6 – Minimum Application Rates and Discharge Times for Fixed Foam Application on Diked Areas Involving Hydrocarbon Liquids

| Type of Foam Discharge Outlets | Minimum Application Rate | | Minimum Discharge Time (minutes) | |
|----------------------------------|--------------------------|---------------------|----------------------------------|----------------------|
| | L/min · m ² | gpm/ft ² | Class I Hydrocarbon | Class II Hydrocarbon |
| Low-level foam discharge outlets | 4.1 | 0.10 | 30 | 20 |
| Foam monitors | 6.5 | 0.16 | 30 | 20 |

APPENDIX C – CALCULATION SHEET

| DATA | | | | | | |
|------------------------|------------------|---|----------|----------------------------------|----------|---------------------|
| | | | | | | |
| | | | | | | |
| Foam concentration (%) | | 3 | | | | |
| FOAM | | DISCHARGE OUTLETS | | MONITORS | | References |
| Design parameters | | Minimum Density Application Rate | Duration | Minimum Density Application Rate | Duration | |
| | | [l/min/m ²] | [min] | [l/min/m ²] | [min] | |
| Fixed Roof | Flammable | 4,1 | 30 | 6,5 | 65 | NFPA 11 - Table B.1 |
| | Combustible | 4,1 | 20 | 6,5 | 50 | |
| Floating Roof | Flammable | 12,2 | 20 | 6,5 | 65 | |
| | Combustible | 12,2 | 20 | 6,5 | 50 | |
| WATER | | FIXED WATER SPRAY SYSTEM AND WATER MONITORS | | | | References |
| Equipment Protection | | Minimum Density Application Rate | Duration | | | |
| | | [l/min/m ²] | [min] | | | |
| Static | Static Equipment | 10,2 | 120 | | | NFPA 15 - §7.4.3.4 |
| | Storage Tanks | 10,2 | | | | NFPA 15 - §7.4.2.1 |
| Rotating | Compressors Area | 20,4 | | | | NFPA 15 - §7.3.2 |
| | Pumps Area | 20,4 | | | | NFPA 15 - §7.3.2 |

| RESULTS | | | | | |
|--------------------------------|-------------------|---------------------------|-------------------|-----------------------------|-----------------------------|
| Blanket supply Water + Foam | | Foam Concentration Supply | | Water for cooling | |
| [l] | [m ³] | [l] | [m ³] | Flow [m ³ /h] | Volume [m ³] |
| 132732 | 133 | 3982 | 4 | 3763 | 7525 |

| Tank Data | | | | | | | | | | Foam Calculation | | | | | | | Water Calculation | | | | | | | | | |
|-------------------|---------|-------|------------------|---------------------------------|--------------------------------------|---------------------|-----------------|----------|-----------------|---------------------------------|-----------------------------------|---------------|----------------------|----------------------|--------------------------|--------------------------------|----------------------------------|--|----------------------|------------------------|--------------------------|-------------------------|-------------------------|--|--|--|
| Number | Name | Tag | Capacity [m³] | Roof Type (Fixed / Floating) | Protection Type (Fixed / Monitor) | Flash Point [°C] | Main Dimensions | | | Addition of Foam (Yes/No) | Application rate [l/min.m²] | Time [min] | Surface Area [m²] | Flow rate [l/min] | Blanket supply [l] | Concentration Supply [l] | Addition of Water (Yes/No) | Selected water application rate [l/min/m²] | Roof Area [m²] | Vessel Area [m²] | Total surface [m²] | Water Flow [m³/h] | Water Volume [m³] | | | |
| | | | | | | | H [m] | D [m] | Rim Seal [m] | | | | | | | | | | | | | | | | | |
| Scenario 1 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Hexene | T-001 | 500 | Fixed | Fixed | -26 | 20 | 18 | - | Yes | 4,1 | 30 | 254,5 | 1043 | 31300 | 939 | No | - | - | - | - | - | | | | |
| 2 | Octane | T-002 | 1000 | Fixed | Monitor | 7 | 22 | 20 | - | No | - | - | - | - | - | - | Yes | 10,2 | 314 | 1382 | 1696 | 1038 | 2076 | | | |
| 3 | Decene | T-003 | 2000 | Floating | Fixed | 55 | 24 | 22 | 2 | No | - | - | - | - | - | - | Yes | 10,2 | 380 | 1659 | 2039 | 1248 | 2496 | | | |
| 4 | Alcohol | T-004 | 4000 | Floating | Monitor | 100 | 26 | 24 | 1 | No | - | - | - | - | - | - | Yes | 10,2 | 452 | 1960 | 2413 | 1477 | 2953 | | | |
| | | | | | | | | | | | | | | Σ= | 31300 | 939 | | | | | | | | | | |
| Scenario 2 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Hexene | T-001 | 500 | Fixed | Fixed | -26 | 20 | 18 | - | No | - | - | - | - | - | - | Yes | 10,2 | 254 | 1131 | 1385 | 848 | 1696 | | | |
| 2 | Octane | T-002 | 1000 | Fixed | Monitor | 7 | 22 | 20 | - | Yes | 6,5 | 65 | 314,2 | 2042 | 132732 | 3982 | No | - | - | - | - | - | - | | | |
| 3 | Decene | T-003 | 2000 | Floating | Fixed | 55 | 24 | 22 | 2 | No | - | - | - | - | - | - | Yes | 10,2 | 380 | 1659 | 2039 | 1248 | 2496 | | | |
| 4 | Alcohol | T-004 | 4000 | Floating | Monitor | 100 | 26 | 24 | 1 | No | - | - | - | - | - | - | Yes | 10,2 | 452 | 1960 | 2413 | 1477 | 2953 | | | |
| | | | | | | | | | | | | | | Σ= | 132732 | 3982 | | | | | | | | | | |
| Scenario 3 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Hexene | T-001 | 500 | Fixed | Fixed | -26 | 20 | 18 | - | No | - | - | - | - | - | - | Yes | 10,2 | 254 | 1131 | 1385 | 848 | 1696 | | | |
| 2 | Octane | T-002 | 1000 | Fixed | Monitor | 7 | 22 | 20 | - | No | - | - | - | - | - | - | Yes | 10,2 | 314 | 1382 | 1696 | 1038 | 2076 | | | |
| 3 | Decene | T-003 | 2000 | Floating | Fixed | 55 | 24 | 22 | 2 | Yes | 12,2 | 20 | 125,7 | 1533 | 30662 | 920 | No | - | - | - | - | - | - | | | |
| 4 | Alcohol | T-004 | 4000 | Floating | Monitor | 100 | 26 | 24 | 1 | No | - | - | - | - | - | - | Yes | 10,2 | 452 | 1960 | 2413 | 1477 | 2953 | | | |
| | | | | | | | | | | | | | | Σ= | 30662 | 920 | | | | | | | | | | |
| Scenario 4 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Hexene | T-001 | 500 | Fixed | Fixed | -26 | 20 | 18 | - | No | - | - | - | - | - | - | Yes | 10,2 | 254 | 1131 | 1385 | 848 | 1696 | | | |
| 2 | Octane | T-002 | 1000 | Fixed | Monitor | 7 | 22 | 20 | - | No | - | - | - | - | - | - | Yes | 10,2 | 314 | 1382 | 1696 | 1038 | 2076 | | | |
| 3 | Decene | T-003 | 2000 | Floating | Fixed | 55 | 24 | 22 | 2 | No | - | - | - | - | - | - | Yes | 10,2 | 380 | 1659 | 2039 | 1248 | 2496 | | | |
| 4 | Alcohol | T-004 | 4000 | Floating | Monitor | 100 | 26 | 24 | 1 | Yes | 6,5 | 50 | 72,3 | 470 | 23483 | 705 | No | - | - | - | - | - | - | | | |
| | | | | | | | | | | | | | | Σ= | 23483 | 705 | | | | | | | | | | |

