



AALBORG UNIVERSITY
DENMARK

Aalborg Universitet

Water Evaporation in Swimming Baths

Hyldgård, Carl-Erik

Publication date:
1990

Document Version
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

Citation for published version (APA):
Hyldgård, C-E. (1990). *Water Evaporation in Swimming Baths*. Institut for Bygningsteknik, Aalborg Universitet. Indoor Environmental Technology Vol. R9045 No. 16

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.


- ? Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- ? You may not further distribute the material or use it for any profit-making activity or commercial gain
- ? You may freely distribute the URL identifying the publication in the public portal ?

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

INSTITUTTET FOR BYGNINGSTEKNIK

DEPT. OF BUILDING TECHNOLOGY AND STRUCTURAL ENGINEERING
AALBORG UNIVERSITETSCENTER • AUC • AALBORG • DANMARK



INDOOR ENVIRONMENTAL TECHNOLOGY


PAPER NO. 16

Presented at ROOMVENT '90, International Conference on Engineering
Aero- and Thermodynamics of Ventilated Rooms, Oslo, June 1990

C. E. HYLDGAARD
WATER EVAPORATION IN SWIMMING BATHS
DECEMBER 1990

ISSN 0902-7513 R9045

The papers on INDOOR ENVIRONMENTAL TECHNOLOGY are issued for early dissemination of research results from the Indoor Environmental Technology Group at the University of Aalborg. These papers are generally submitted to scientific meetings, conferences or journals and should therefore not be widely distributed. Whenever possible reference should be given to the final publications (proceedings, journals, etc.) and not to the paper in this series.



INDOOR ENVIRONMENTAL TECHNOLOGY

PAPER NO. 16

**Presented at ROOMVENT '90, International Conference on Engineering
Aero- and Thermodynamics of Ventilated Rooms, Oslo, June 1990**

C. E. HYLDGAARD
WATER EVAPORATION IN SWIMMING BATHS
DECEMBER 1990

ISSN 0902-7513 R9045

WATER EVAPORATION IN SWIMMING BATHS

C.E. Hyldgaard
University of Aalborg
Aalborg, Denmark

SUMMARY

This paper is publishing measuring results from models and full-scale baths of the evaporation in swimming baths, both public baths and retraining baths. Moreover, the heat balance of the basin water is measured. In addition the full-scale measurements have given many experiences which are represented in instructions for carrying out and running swimming baths. If you follow the instructions you can achieve less investments, less heat consumption and a better comfort to the bathers.

INTRODUCTION

For many years design engineers have calculated the evaporation in a swimming bath with the equation:

$$W = (25 + 19v)(x_m - x_r)$$

in which W = evaporation, g/m²h
 v = air velocity at the surface, m/s
 x_m = water content in saturated air at the water temperature, g/kg
 x_r = water content in the air, g/kg

In technical literature within the area of water evaporation you can find other equations or graphs as results of measurements. But apparently there are no measurements of the evaporation in swimming baths and the different sources are giving very different and too large amounts of evaporation for the same situation in the bath.

In the years 1976-1982 a research in this area was done at our university. A report was published in Danish in the Scandinavian countries. Since the results were rather revolutionary the report attracted a good deal of attention. Later the directions in the report have been tried in existing swimming baths in Scandinavia. Hereby the energy consumption for dehumidifying the air was reduced to 20-50%. This is the background for this paper.

1. Water temperature \leq air temperature

Swimming baths can be divided into two groups, ordinarily public or private swimming baths and baths for retraining at hospitals etc. In this section the first mentioned type will be treated. In these swimming baths the water temperature is less than the air temperature, or it ought to be as shown later.

1.1 Laboratory set-up

At figure 1 you can see the used model. The inside dimensions of the room were $L \times W \times H = 5,43 \times 3,60 \times 2,42$ m, but on the floor a platform was built up at a height of 20 cm around a 7 m² basin made of a plastic film. The depth of the water was about 18 cm.




Fig. 1. Room model with "swimming pool".

The significant parameters appeared to be:

- Air temperature
- Air humidity
- Water temperature at the surface
- Air velocity above the surface

So these parameters and the evaporation had to be measured. The question was, how to make these measurements and where.

A short description of the chosen methods and the proved accuracy of the measurements will follow.

Air temperature

A test above the centre of the basin gave examples of stratification as shown in fig. 2.




Fig. 2. Temperature in the air above the centre of the basin. Air velocity 2 cm above the surface = \bar{v} . Water temperatures between 24 and 28 C.

As seen from fig. 2 and the following humidity stratification a measuring height of 20 cm was chosen. 9 thermocouples type K were distributed 20 cm above the surface. They were scanned each 30 min. in a typical measuring period of 16 hours and a mean value was calculated. The uncertainty of the mean temperature was $\pm 0.2 \text{ C}$.

Air humidity

A test with Assmann's psychrometer above the centre of the pool showed a humidity distribution in the room as shown in fig. 3.




Fig. 3. Humidity in the air above the centre of the basin. Air velocity 2 cm above the surface = v .

As the humidity is varying very much near the surface but only a little in the upper regions a measuring height of 20 cm was chosen. To measure the humidity with sufficient accuracy is difficult. So a new measuring equipment was developed and used. This new

equipment had an accuracy of about $\pm 1\%$ humidity but because of the varying humidity with the time and with the position a total accuracy of $\pm 5\%$ humidity was suggested.

Water temperature

The water was taken out of the basin by a pump, heated to the desired temperature by an electric heater controlled by a thermostat, and injected into the basin again. Thus the water was rotated slowly horizontally. You had no proven stratification of the water temperature. so the surface temperature could easily be measured down in the water with a thermocouple. The accuracy of the mean value was proven to be ± 0.1 C.

Air velocity

After pilot experiments it was chosen to measure the air velocity 2 cm above the water surface with a hotwire probe. 18 measuring points were distributed above the pool area and the measuring time in each point was several minutes. To avoid too much time consumption the air velocity was divided into groups, average velocity $v < 0.1$ m/s and $v = 0.15$ m/s. As seen later the evaporation is very dependent of the air velocity but it was necessary to reduce the number of measurements since you had four parameters.

Amount of evaporation

Determination of the evaporation could be done by measuring the airflow and the humidity in the inlet and the exsuction of air. But this would give a low accuracy in the result. So it was chosen to measure the amount of evaporation directly. To weigh the basin could not be done so a new method in measuring the water level was developed. This method consisted of a special submerged pipe through which air was bubbling. The supply pressure which was determined very exactly was proved to give an accuracy of ± 0.02 mm corresponding to ± 0.14 l water. To reach a sufficient accuracy did normally mean a necessary measuring time of 16 hours i.e. a night. To measure low amounts of evaporation for example $5 \text{ g/m}^2\text{h}$ a week-end corresponding to about 62 hours was used. This gave an accuracy of about $\pm 6.5\%$ of the measured value of evaporation.

1.2 Experimental results

Evaporation

About 200 measurements were made, besides measurements which had to be rejected because of too great variation in a parameter. So with all the difficulties which always occur this part of the work took about a year. In the figures 4-8 the results are shown in graphs.




Fig. 4. Evaporation from a quiet surface of water. The air temperature t_{air} and humidity ϕ are measured 20 cm above the surface. The water surface temperature is t_w . The mean air velocity v is measured 2 cm above the surface. Warning: you can interpolate but not extrapolate in the graph!




Fig. 5. Evaporation from a quiet surface of water. The air temperature t_{air} and humidity ϕ are measured 20 cm above the surface. The water surface temperature is t_w . The mean air velocity v is measured 2 cm above the surface. Warning: you can interpolate but not extrapolate in the graph!




Fig. 6. Evaporation from a quiet surface of water. The air temperature t_{air} and humidity ϕ are measured 20 cm above the surface. The water surface temperature is t_w . The mean air velocity v is measured 2 cm above the surface. Warning: you can interpolate but not extrapolate in the graph!




Fig. 7. Evaporation from a quiet surface of water. The air temperature t_{air} and humidity ϕ are measured 20 cm above the surface. The water surface temperature is t_w . The mean air velocity v is measured 2 cm above the surface. Warning: you can interpolate but not extrapolate in the graph!




Fig. 8. Evaporation from a quiet surface of water. The air temperature t_{air} and humidity ϕ are measured 20 cm above the surface. The water surface temperature is t_w . The mean air velocity v is measured 2 cm above the surface. Warning: you can interpolate but not extrapolate in the graph!

Let it be said emphatically that interpolation in the graphs is allowed but extrapolation is absolutely inadmissible. This applies to all parameters especially the air velocity.

Also, I will not have somebody to transform the graphs to equations and forget to mention limitation areas as happened before.

Heating effect to the water

To clarify how much effect you must have to keep the basin water temperature at the wanted level a new and smaller model of the basin was built up. It had a water surface of 1 m². The sides and the bottom were well insulated so that the heat loss could be controlled. It was proved that the evaporation was proportional to that of the 7 m² basin. Because of the time consumption the measurements were only carried out at air velocities about 0,15 m/s. The results are shown in fig. 9.




Fig. 9. Necessary heating added to the basin water Φ_{added} as a function of the evaporation W . $\Delta t = t_{\text{air}} - t_{\text{w}}$ is parameter. Air velocity 2 cm above the surface = 0.15 m/s.

A very important thing to notice in fig. 9 is that if you run your swimming bath rationally, for example at $W = 20$ g/m²h and $\Delta t = 4$ C, you will have to cool the water -not to heat it. This is proved by measurement in real swimming baths as described later.

1.3 Valuation of results

It can be seen that the evaporation graphs are curved in the case $v < 0.1$ m/s but they are straight lines for $v = 0.15$ m/s. The explanation is: At low forced velocities free thermal flows at the surface matter a great deal. When the air temperature exceeds the water temperature with more than about 3 C everything is becoming quietly. In this area the density of the saturated vapour at the surface is greater than the density of the air at higher levels. At quiet circumstances of air movements you have thus a layer of saturated vapour just above the water surface and here the determining factor for the evaporation is the vapour pressure differences.

However, at lower temperature differences between the air and the water you have a changing in the relationship between the densities. Depending on the air humidity you have a change at $t_{\text{air}} - t_{\text{w}} =$ one to three degrees and below this value the density of the saturated vapour is less than the density of the air at higher levels. So in this area the diffusion will be dominated by a pell-mell change which increases the evaporation strongly.

The graphs for $v < 0.1$ m/s are stopped at left where measuring of the air velocity exceeded 0.1 m/s because of the effect as described above. In this area you will have to use the figures 7 and 8.

At greater air velocities as in figures 7 and 8 you have not this dominating effect of thermal flows. The measurements did show a little break at the graphs, but since this break was very little and the curves were nearly straight lines, it was chosen to ignore it. So already at this small air velocity of 0.15 m/s the free thermal flow is losing its influence and this corresponds to the measurements of other researchers at higher velocities.

In actual swimming baths it will be seldom to have air velocities 2 cm above the water which are > 0.15 m/s. So normally the figures 4-6 can be used if you can keep the pool water cold enough and do not have a great thermal radiation to the surface of the water as described later in section 3.

As mentioned in the introduction evaporation has been examined earlier. But apparently it was common to all this research that the method aimed to let an air flow pass a little water bowl. So it has not been possible to research the evaporation at low velocities. Some of the researchers have examined the velocity area 2-5 m/s others 0.5-4 m/s. Nobody has examined the evaporation below 0.5 m/s. Moreover, the earlier research has used high water temperature while the air temperature in many cases is not even recorded. So this research cannot be used in a swimming bath.

A comparison between our results at $v < 0.1$ m/s and the equation mentioned in the introduction is made in figure 10:

$$W = (25 + 19v)(x_m - x_r) \quad (1)$$

in which W = the evaporation, g/m²h
 v = the air velocity at the surface, m/s
 x_m = the water content in saturated air at the water temperature, g/kg
 x_r = the water content in the air, g/kg.

Just for this equation somebody has forgotten to mention limitation areas, even so the equation is a composition of researches.

Apparently the equation comes from Lurie and Michailoff [10] who examined the area:

$$\begin{aligned} 1 &< v < 7.5 \text{ m/s} \\ 40 \text{ C} &< t_{\text{air}} < 222 \text{ C} \\ 10 \text{ g/kg} &< x_{\text{air}} < 250 \text{ g/kg} \\ &t_w \text{ "until } 65 \text{ C"} \end{aligned}$$

Moreover, it apparently comes from Thiesenhusen [13] who mentions the limitation area:

$$0.5 \text{ m/s} < v < 1.5 \text{ m/s}$$

$$t_{\text{air}} \approx 20 \text{ C}$$

$$\phi_{\text{air}} \approx 0.7$$

$$52 \text{ C} < t_w < 83.5 \text{ C}$$




Fig. 10. Comparison with earlier equation. ϕ is the humidity and t_w the water temperature.

So it is proved that the equation mentioned above cannot be used for the situation in a swimming bath. This is also seen in fig. 10 where curves from the equation with the velocity $v = 0.1$ m/s are inserted. A comparison with our measurements shows a really great disagreement as expected.

Besides this earlier result there have been many others. They shall not be mentioned here because they are disagreeing and all of them are giving too high values of evaporation when they are used for the situation in a swimming bath.

It could be expected that waves would exceed the evaporation. To examine this a little wave machine was used to generate waves all over the surface with a wave height of about 2 cm. Unexpectedly the small waves did not exceed the evaporation. This seems to show that waves do not disturb the layer of saturated vapour at the surface. If you are blowing smoke against the water surface you will see that it stays quietly at the surface just following the waves up and down. Only a rather powerful blow disturbs this layer as it was the case with the quiet surface. The conclusion for a swimming bath is that waves without spray do not exceed the evaporation. The influence of the bathers will be mentioned later.

2. Water temperatur \geq air temperature

After the publication of the results mentioned in part 1 above many questions were received about retraining baths at hospitals which normally have a higher water temperature. So new investigations were started to clarify the evaporation and the heat consumption to the water in this case.

2.1 Laboratory set-up

Since the previously mentioned measurements showed a good agreement between small models and full-scale room a plastic bowl with surface area of 1×0.5 m was chosen. The basin was placed in the middle of the climate room and was well insulated. The water could be heated with electric heaters and the total heat exchange could be measured. The set-up was supplied with all the necessary equipment to measure the parameters.

To save time measurements were only carried out at a humidity of 60% taken 20 cm above the surface. Likely, only the water temperatures 29, 31, 33, 35 and 37 C were examined. Some pilot experiments at air velocities between 0.04 and 0.17 m/s taken 2 cm above the surface revealed a little influence of the air velocity at the evaporation at these relatively high temperatures of the water. So all the measurements named in the following were carried out at air velocities 0.15 m/s.

2.2 Experimental results

Evaporation

In fig. 11 the measurements are shown graphically. To make a comparison with the results mentioned in part 1 a series of experiments at $t_w = 28$ C was done. As the agreement was good these measurements are not presented in fig. 11.




Fig. 11. Evaporation from a quiet water surface. The air temperature t_{air} and humidity ϕ are measured 20 cm above the surface. The water surface temperature is t_w . The mean air velocity measured 2 cm above the surface is $v = 0.15$ m/s. Warning: you can interpolate but not extrapolate in the graphs.

Heating effect to the water. As mentioned before the heating effect added to the water was measured exactly. The heat loss is consisting of heat conduction through the sides and the bottom, heat of evaporation, heat radiation from the surface to the surroundings and convection to the room air.

The heat conduction through sides and bottom was calculated in the light of the measured temperature stratification in the insulation. This part was only about only 6% of the added effect.

The heat of evaporation could easily be calculated in the light of the known evaporation, since the heat of evaporation for water Φ_{ev} is:

$$\Phi_{ev} = 2500-2.26 \cdot t \quad (\text{kJ/kg}) \quad (2)$$

Since the water temperature t (C) only has a little influence the heat of evaporation is everywhere set to 2420 kJ/kg.

The temperatures of the water surface and of the surroundings were measured and the heat radiation calculated by the equation:

$$\Phi_r = \sigma_w \cdot A_w [T_w^4 - T_s^4] \quad (3)$$

where $\sigma_w = 5.54 \cdot 10^{-8} \text{ W/m}^2\text{K}^4$ for a water surface

A_w = area of the water surface, m^2

T_w = water surface temperature, K

T_s = surrounding surface temperature, K

By subtraction of the heat losses mentioned above from the added heat, the heat loss by convection was calculated. Of course this way is not an exact one to determine the convection but the tendency was $\alpha_c = 6-7 \text{ W/m}^2\text{C}$ at the used circumstances.

In the figures 12-16 you can see the measured added heat effect, the effect used to the evaporation and heat loss by radiation and convection. The heat conduction is taken out of the heat balance.




Fig. 12. Water heat balance at 29 C.




Fig. 13. Water heat balance at 31 C.




Fig. 14. Water heat balance at 33 C.




Fig. 15. Water heat balance at 35 C.




Fig. 16. Water heat balance at 37 C.

2.3 Valuation of results

Fig. 11 can be used to find the evaporation from a retraining bath. You might want values at lower velocities but the strong evaporation does not allow low velocities, so these values at $v = 0,15$ m/s must be reasonable. Also you might want other humidities but 60% is reasonable when energy consumption and moisture are considered.

If you are using the figures 12-16 to find out the necessary heating to the pool water you must remember that in full-scale the heat loss by radiation can be greater than in the model where surrounding surfaces nearly have had the air temperature. If the surrounding surfaces have a temperature less than the air temperature you must correct for this by using the equation (3). Also in current cases the heat conduction from the basin must be calculated and added to the reading.

3. Full-scale measurements

It was planned to carry out measurements in three real swimming baths, partly to control the model results partly to clarify the influence of the bathers. But difficulties in measuring airflow and humidity in the air supply and extraction did that only one of them was useful.

3.1 Aars swimming bath

Briefing

Fig. 17 shows a sketch plan for the swimming bath in Aars.

The measurements in this bath were succesful. The only handicap was that measurings of the airflows could only be made with intake of fresh air i.e. no recirculating air so that the humidity in the room could not be controlled when measuring of the evaporation was going on.




Fig. 17. Ventilation plan for Aars swimming bath. The flow of fresh air is controlled by the humidity probe H placed in the extraction pipe. The temperature in the room is controlled by the thermostat T1 placed in the extraction pipe yet the minimum thermostat T2 is setting the lower limit to the inlet temperature.

Oscillation

However, the first measurements in this bath showed the same great problem as in the others. The inlet temperature was oscillating very much and it was not the bathers who caused it. In fig. 18 you can see an example, made in a week-end, where the bath was not open to bathers. The temperature of the outdoor air was 10-15 C.




Fig. 18. Conditions in Aars swimming bath on a Saturday with no bathers and 100% fresh air intake. t_w = temperature of the water, t_r = room air temperature measured 1.5 m above the water, t_i = inlet temperature, x_i = water content in the extraction, ϕ_r = humidity. W = amount of evaporation.

Fig. 18 shows that the system can be quiet for example from 03.00 to 11.00 a.m. but then for one reason or another the system is oscillating. A slow oscillation with an oscillating time of about one hour is noticed just as it was the case in the other swimming baths.

From experiences with the model it was tried to stop this oscillation by raising $t_{i,\text{minimum}}$. The result was exceeding the expectations. The system was not oscillating any more with 100% intake of fresh air. Further it was examined whether the system was in balance at normal running i.e. humidity controlled recirculation with night stop. One of the analog results is seen in fig. 19. Here the reference is 29 C for t_r and the reference for the humidity ϕ_r is changed from 50% to 60% at 4.p.m. $t_{i,\text{minimum}}$ is set to 30 C.




Fig. 19. Conditions in Aars swimming bath at normal running. t_w = water temperature, t_r = room air temperature 1.5 m above the water, t_i = temperature of inlet air and ϕ_r = humidity.

It is seen in fig. 19 that at the time when the night running is started at midnight the room air temperature is decreasing as expected and ϕ_r is exceeding. t_i is decreasing because the probe is cooled by the surroundings when the ventilation is stopped. When the humidity probe is demanding ventilation start at 02.30 and 04.00 a.m. the inlet temperature of course is at maximum. When day run is started 05.30 a.m. the inlet temperature is starting at maximum but becomes quickly steady even after this chock.

How oscillation is avoided

By other measurements it was clarified that if the minimum inlet temperature was at least about two degrees above the room air temperature oscillations were avoided. The explanation of the pending problem is: If t_i at decreasing load happens to get less than the room air temperature the air inlet is falling down because of greater density. This makes, no matter what type of inlet, in every swimming bath an increasing in air velocity by the water surface and hereby an increasing evaporation. The increasing evaporation causes an even greater cooling of the room air. When the temperature control system is reacting the inlet temperature is increased, the air velocity at the surface is decreasing,

the evaporation is getting less, the cooling of the air is decreasing and by this the room air temperature is increasing still more and so on.

Of course many swimming baths will be able to get a better comfort and at the same time a decreasing energy consumption by using this discovery. The reaction to the first published report indicates that the oscillation is a common problem.

The evaporation

In fig. 18 it is seen that the evaporation is 110-140 g/m²h with no bathers. A comparison with the evaporation curves indicates a mean velocity at the surfaces a little below 0.15 m/s. Smoke tests were indicating a rather high mean velocity at the surface. After having reduced the airflow to 88% the evaporation was at first reduced to 90 g/m²h at the same conditions as before. But with less evaporation the water temperature was increasing until $\Delta t = t_{\text{air}} - t_{\text{w}} =$ about 1.5 C at $\phi_r = 0.40$ while the balance condition was $\Delta t = t_{\text{air}} - t_{\text{w}} = 2.5$ C at $\phi_r = 0,40$ before.

So the evaporation could not be reduced so much as wanted because the water could not be cooled enough in spite of the fact that the water heat exchanger was stopped. An example of the same problem can be seen in fig. 19 where the water temperature is increasing in spite of the water heater is stopped.

3.2 Valuation of full-scale results

If you want a low evaporation in a public swimming bath, for example below 20 g/m²h as shown in fig. 4, 5 and 6, you must cool the water in the basin. This can be done cheaply by preheating the tap water. Besides you must take care that the radiation to the surface of the water is as low as possible and that the heating of the basin water caused by the filter circulation pump and underwater lights are not too large. So, just set up the energy balance to the water and cool it if necessary. If you are heating the water as usual you are in fact increasing the evaporation and the energy consumption. A good advice is to use $t_{\text{w}} = 26$ C and $t_{\text{air}} = 29$ C. $\phi_{\text{air}} = 0.60$ in public swimming baths and in this way you can avoid covering the water at night.

The evaporation caused by the bathers will depend on many things, among them the activity of the bathers and the water level in the basin. Our measurements indicated an enlarged evaporation caused by bathers whether they were children or grown-ups of about 0.8 kg per visit. This number, however, must depend on the swimming bath, the conditions and so on.

4. Conclusion

The described results should hopefully cause radical changes in carrying out and run of swimming baths. It is remarkable that both investments and working expences can be reduced and in addition a better comfort to the bathers can be achieved. The following instructions are valid for public swimming baths and retraining baths.

4.1 Instructions for public swimming baths

Windows are unwanted in a swimming bath. If windows still are mounted they must be small and facing north or shielded so that sunshine at the water surface is avoided. In this way you will achieve two things, reduced working expenses and a possibility that the lifeguard can see the bottom of the basin.

Technical gallery all around the basin is a good thing. Inspection of installations and leakages in the basin is necessary. If ventilation pipes are following the technical gallery this is getting a temperature so that expensive floor heating of the platforms around the pool can be avoided. Besides, floor heating pipes in swimming baths are corroded in a few years. Remember installation of floor drain in the technical gallery.

Water circulation. The inlets for purified water to the pool is placed about 20 cm above the bottom, also in the deep part of the basin. In this way you can achieve very small temperature differences in the water and a good stirring. Placing inlets just below the surface can give a bad stirring and temperature differences of 6-8 C in deep basins.

Heat exchanger for pool water. To heat the pool water for the first time will take about 7 weeks without heat exchanger but with ventilation and purifying pump running. So if you cannot accept this period you must have a heat exchanger for this first time heating. Later you must have a heat exchanger for cooling the pool water. This can be done cheaply by preheating the tap water. Automatic control of the cooling is not necessary because of the great volume of water in the pool-manual control is sufficient. The heat balance of the water in the pool will cause that a wanted water temperature can be achieved by regulating the air temperature.

The ventilation plant is carried out with humidity controlled recirculation of air. An air to air heat exchanger outside the recirculation is normally a good investment. The inlet temperature can be controlled by a phial in the extraction pipe but with a minimum thermostat placed in the inlet. The minimum thermostat is set 2-3 degrees higher than the room air temperature.

The air change rate must ensure a good stirring of the room air but on the other side low velocities above the water surface are very important. So a tune up of the air change rate and if necessary of the air supply devices must be done. Adjust the inlet temperature to its maximum in the winter case, add smoke to the ventilating air, and control that the smoke is distributed all over the room in a few minutes. In this case the stirring of the room air is sufficient but it can be too strong. Whether it is too large can be seen by measuring the air velocity above the water. But this is a difficult matter because of the changes with the place and time. A better way is to add smoke along the beach around the pool and thus estimate the air velocity. It demands some experience but generally it is so that if the air is moving promptly in the expected direction the velocity is too high. If the air sometimes is hesitating or moving up and down the velocity is suitable.

Adjusting temperature and humidity. When, by means of recording instruments, the water temperature, the air inlet temperature, the room air temperature and humidity are measured then the adjusting is easy. The room air thermostat is set to the wanted value

and the minimum thermostat 2-3 degrees higher. The humidity can for instance be set to 60%. Control that the air inlet temperature is not oscillating and the minimum value is not passed. Without bathers the air inlet temperature shall be total quiet, with bathers it will move about 2-3 degrees if the system is not oscillating. If the system is oscillating quickly something is wrong in the control device. The proportional band can be too narrow or the integrating time too little. If the system is oscillating slowly with an oscillating time of 1-1.5 hours the minimum inlet temperature has to be raised. The temperature of the water ought to be at least 2-3 degrees below the room air temperature and this can only be reached by cooling the pool water. Do not think you will have to heat it!

So you could for instance chose these values for a public bath:

$$\begin{aligned} t_w &= 26 \text{ C} \\ t_{\text{air}} &= 29 \text{ C} \\ t_{i,\text{min.}} &= 31-32 \text{ C} \\ \phi_{\text{air}} &= 60\% \end{aligned}$$

This will give a good comfort to the bathers (not to the lifeguard if he/she is wearing too much clothes).

4.2 Instructions for retraining baths

Some of the things said about public baths cannot be used about retraining baths. In this case you must heat the pool water to achieve high temperature of the water without raising the air temperature. But as seen in the figures 12-16 it is still a good idea to have a relatively high temperature of the room air for example 29 C. It is still a bad idea to lower the air temperature to save energy because the heat conduction through the climate shield does not mean so much as the evaporation. Therefore, it is a better idea to keep the air temperature and to stop the heat exchange to the water in periods where the pool is out of use. As cooling down and reheating are taking time this can only be done for longer periods. Perhaps it would be a good idea to cover the water at night, and it will probably be profitable to use a heat pump to dehumidify the room air and return the heat effect to the water.

So in the case of a retraining bath you can use fig. 11 to get the evaporation and the figures 12-16 to get the necessary heat effect to the water. Correct this effect to your case, choose a suitable ventilating plant and suitable conditions and adjust the system. This last thing is the most important just as it was the case in a public swimming baths.

REFERENCES

- [1] Häussler, Werner: Zur Wasserverdunstung aus offenen Oberflächen. Wissenschaftliche Zeitschrift der Technischen Hochschule Dresden. 7(1957/58) Heft 5.
- [2] Dienelt, Heiz: Verdunstungsversuche an ruhenden Wasseroberflächen. Fakultät für Maschinenbau der Technischen Hochschule Karl-Marx-Stadt 1967.
- [3] Eckert, E.: Einführung in den Wärme- und Stoffaustausch. 3. Aufl. (1966) Springer Verlag, Berlin.
- [4] Häussler, W.: Die temperaturverteilung im Wasser und in der Luft beim gekoppelten Wärme- und Stoffaustausch. Dissertation (1955) Technischen Hochschule, Dresden.
- [5] Häussler, W.: Zur Wasserverdunstung aus offenen Oberflächen. Wissenschaft. Z. der TH Dresden 7(1957/58) H.5.
- [6] Hofmann, E.: Wärme- und Stoffübertragung II. Teil im Handbuch der Kältetechnik 3. Bd. Herausgeber R. Plank. Springer Verlag (1959) Berlin.
- [7] Klenke, W.: Die Wärme- und Stoffübertragung bei Verdunstungskühlung und die Beurteilung von Kühltürmen. Dissertation (1964) TH Braunschweig.
- [8] Krischer, O.: Die wissenschaftlichen Grundlagen der Trochungstechnik. Springer Verlag (1956) Berlin.
- [9] Lewis, W.K.: The evaporation of a Liquid into a Gas. A Correction. Mec. Engineering 55 (1933) s. 567.
- [10] Lurie u. Micailoff: Die Verdunstung von Wasser aus offenen Oberflächen. Gesundh.-Ing. 59 (1936) Nr. 21 s. 289/294.
- [11] Merkel, F.: Verdunstungskühlung. VDI-Forschungsheft 275 (1925).
- [12] Sprenger, E.: Verdunstung von Wasser aus offenen Oberflächen. Z. Heizung und Lüftung 17 (1943) H. 1 s. 7/8.
- [13] Thiesenhusen, H.: Untersuchungen über die Wasserverdunstungsgeschwindigkeit in Abhängigkeit von der Temperatur des Wassers, der Luftfeuchtigkeit und Windgeschwindigkeit. Gesundh.-Ing. 53 (1930) H. 8 s. 113/119.

PAPERS ON INDOOR ENVIRONMENTAL TECHNOLOGY

PAPER NO. 1: C. E. Hyldgård: *Aerodynamic Control of Exhaust*. ISSN 0902-7513 R8712.

PAPER NO. 2: Per Heiselberg, Peter V. Nielsen: *The Contaminant Distribution in a Ventilated Room with Different Air Terminal Devices*. ISSN 0902-7513 R8713.

PAPER NO. 3: Peter V. Nielsen, L. Evensen, Peter Grabau, J. H. Thulesen-Dahl: *Air Distribution in Rooms with Ceiling-Mounted Obstacles and Three-Dimensional Flow*. ISSN 0902-7513 R8714.

PAPER NO. 4: Peter V. Nielsen, Åke T. A. Möller: *Measurements on Buoyant Wall Jet Flows in Air-Conditioned Rooms*. ISSN 0902-7513 R8715.

PAPER NO. 5: Peter V. Nielsen: *Numerical Prediction of Air Distribution in Rooms. Status and Potentials*. ISSN 0902-7513 R8823.

PAPER NO. 6: Peter V. Nielsen, Åke T. Möller: *Measurements on Buoyant Jet Flows from a Ceiling-Mounted Slot Diffuser*. ISSN 0902-7513 R8832.

PAPER NO. 7: Peter Kofoed, Peter V. Nielsen: *Thermal Plumes in Ventilated Rooms - An Experimental Research Work*. ISSN 0902-7513 R8833.

PAPER NO. 8: Peter V. Nielsen, Lars Hoff, Lars Germann Pedersen: *Displacement Ventilation by Different Types of Diffusers*. ISSN 0902-7513 R8834.

PAPER NO. 9: Per Heiselberg, Peter V. Nielsen: *Flow Conditions in a Mechanically Ventilated Room with a Convective Heat Source*. ISSN 0902-7513 R8835.

PAPER NO. 10: Peter V. Nielsen: *Displacement Ventilation in a Room with Low-Level Diffusers*. ISSN 0902-7513 R8836.

PAPER NO. 11: Peter V. Nielsen: *Airflow Simulation Techniques - Progress and Trends*. ISSN 0902-7513 R8926.

PAPER NO. 12: M. Skovgaard, C. E. Hyldgaard & P. V. Nielsen: *High and Low Reynolds Number Measurements in a Room with an Impinging Isothermal Jet*. ISSN 0902-7513 R9003

PAPER NO. 13: M. Skovgaard, P. V. Nielsen: *Numerical Prediction of Air Distribution in Rooms with Ventilation of the Mixing Type using the Standard K, ϵ -Model*. ISSN 0902-7513 R9042.

PAPER NO. 14: P. Kofoed, P. V. Nielsen: *Thermal Plumes in Ventilated Rooms - Measurements in Stratified Surroundings and Analysis by Use of an Extrapolation Method*. ISSN 0902-7513 R9043.

PAPER NO. 15: P. Heiselberg, M. Sandberg: *Convection from a Slender Cylinder in a Ventilated Room*. ISSN 0902-7513 R9044.

PAPERS ON INDOOR ENVIRONMENTAL TECHNOLOGY

PAPER NO. 16: C. E. Hyldgaard: *Water Evaporation in Swimming Baths*. ISSN 0902-7513 R9045.

PAPER NO. 17: H. Overby, M. Steen-Thøde: *Calculation of Vertical Temperature Gradients in Heated Rooms*. ISSN 0902-7513 R9046.

**Department of Building Technology and Structural Engineering
The University of Aalborg, Sohngaardsholmsvej 57. DK 9000 Aalborg
Telephone: 45 98 14 23 33 Telefax: 45 98 14 82 43**