

ornl

**OAK RIDGE
NATIONAL
LABORATORY**

MARTIN MARIETTA


**RECEIVED
FEB 29 1996
OSTI**

ORNL/TM-13042

**Advanced Neutron Source Dynamic
Model (ANSDEM) Code Description
and User Guide**

Jose March-Leuba

August 1995



MANAGED BY
MARTIN MARIETTA ENERGY SYSTEMS, INC.
FOR THE UNITED STATES
DEPARTMENT OF ENERGY

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED
www

MASTER

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

**ADVANCED NEUTRON SOURCE DYNAMIC MODEL (ANSDM)
CODE DESCRIPTION AND USER GUIDE**

Jose March-Leuba

Date published: August 1995

Prepared by
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37831
managed by
LOCKHEED MARTIN ENERGY SYSTEMS
for the
U.S. DEPARTMENT OF ENERGY
under contract DE-AC05-84OR21400

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED w/w





TABLE OF CONTENTS


Page

LIST OF FIGURES	v
LIST OF TABLES	vii
ACRONYMS AND INITIALISMS	ix
ABSTRACT	xi
1. INTRODUCTION	1
2. MODEL COMPONENTS	3
2.1 CORE AND CORE PRESSURE BOUNDARY TUBE REGIONS	3
2.2 REFLECTOR REGION	3
2.3 COOLING SYSTEMS	3
2.4 GAS ACCUMULATORS	4
2.5 MAKEUP AND LETDOWN SYSTEMS	4
2.6 SECONDARY COOLING SYSTEMS	4
2.7 CONTROL SYSTEMS	5
2.8 INSTRUMENTATION	5
2.9 BREAKS	5
3. MODELS AND EMPIRICAL CORRELATIONS	7
3.1 HEAVY WATER PROPERTIES	7
3.2 FRICTION FACTORS	7
3.2.1 Turbulent Regime	7
3.2.2 Laminar Regime	9
3.2.3 Transition Regime	9
3.3 HEAT TRANSFER COEFFICIENTS	9
3.3.1 Core Region	9
3.3.2 Piping Region	9
3.4 INCIPIENT BOILING	10
3.5 CRITICAL HEAT FLUX	10
3.6 FLOW EXCURSION	10
4. MODEL PARAMETERS	11
5. SAMPLE PROCEDURES	15
Appendix A. HEAVY WATER CORRELATIONS	A-1
Appendix B. COOLANT-RELATED CORRELATIONS	B-1
Appendix C. HEAT TRANSFER AND CRITICAL HEAT FLUX CORRELATIONS	C-1
Appendix D. STANDARD MACRO DEFINITION FILE (ANS.CMD) FOR ANSDM	D-1
Appendix E. NOMINAL ANS OPERATING CONDITIONS PREDICTED BY ANSDM	E-1
Appendix F. LIST OF ALL ANSDM MODEL VARIABLES AND THEIR NOMINAL VALUES	F-1




LIST OF FIGURES

<i>Figure</i>		<i>Page</i>
1	Friction factor calculated by Advanced Neutron Source Dynamic Model after scram and transition to natural circulation.	7




LIST OF TABLES

<i>Table</i>		<i>Page</i>
1	Interpretation of the first two characters of Advanced Neutron Source Dynamic Model variable names	12
2	Interpretation of the node characters in Advanced Neutron Source Dynamic Model variable names	13
3	Interpretation of the node interface characters in Advanced Neutron Source Dynamic Model variable names	14




ACRONYMS AND INITIALISMS

ACSL	Advanced Continuous Simulation Language
ANS	Advanced Neutron Source
ANSDM	Advanced Neutron Source Dynamic Model
BOC	beginning of cycle
CHF	critical heat flux
EOC	end of cycle
LOCA	loss-of-coolant accident



ABSTRACT

A mathematical model is designed that simulates the dynamic behavior of the Advanced Neutron Source (ANS) reactor. Its main objective is to model important characteristics of the ANS systems as they are being designed, updated, and employed; its primary design goal, to aid in the development of safety and control features. During the simulations the model is also found to aid in making design decisions for thermal-hydraulic systems. Model components, empirical correlations, and model parameters are discussed; sample procedures are also given. Modifications are cited, and significant development and application efforts are noted focusing on examination of instrumentation required during and after accidents to ensure adequate monitoring during transient conditions.




1. INTRODUCTION

The Advanced Neutron Source Dynamic Model (ANSDM) is a mathematical model that simulates the dynamic behavior of the Advanced Neutron Source (ANS) reactor in a personal computer. The main objective was to model important characteristics of the ANS systems as they were being designed, updated, and employed. The primary ANSDM design goal was to aid the development of safety and control features, but it also has aided in making design decisions for thermal-hydraulic systems. The model has been modified to evaluate possible design changes, to study the performance of control algorithms, and to support safety analyses. Significant ANSDM development and application efforts have been focused on examining the instrumentation required during and after accidents to ensure adequate monitoring during transient conditions.

The most important limitations of this model are:

- Point kinetics for the neutron dynamics in the core region. The power is distributed among different components (i.e., upper and lower fuel elements, reflector, bypass region) based on steady-state power fraction distributions that have been estimated for the specific ANS conditions. This is not such a bad approximation because most transients result in a reactor scram within the first few milliseconds and then the power is determined by a decay heat correlation.
- Incompressible flow. The model is limited to liquid-phase state; when a transient results in saturated boiling, the simulation fails. Note that the core typically is damaged (owing either to critical heat flux or to flow excursion instabilities) well before saturated boiling can be established; thus, this approximation is fairly accurate except when acoustic wave propagation is a relevant effect such as during large-break loss-of-coolant accidents (LOCAs).
- Single loop flow dynamics. All three active loops are simulated by one effective loop. Because of this approximation, the model is not able to simulate imbalances between loops (e.g., we cannot model directly the shutdown of one pump while the other two remain on). These imbalances must be simulated by, for example, reducing the pump speed to 80% to simulate a one-out-of-three pump trip.
- Poor reverse flow model. The model fails to compute enthalpies properly if reverse flow is established. Note, however, that reverse flow occurs only in the hot leg during large-break LOCAs, and the hot leg enthalpy is fairly irrelevant during these transients. The reverse flow model in ANSDM is designed to “ride through” short (i.e., a few milliseconds) flow reversals that may occur during severe transients, which do not affect significantly the later evolution of the event.



2. MODEL COMPONENTS

The ANSDM has been programmed in the Advanced Continuous Simulation Language, giving it fairly good flexibility of operation at run time. This model was designed for testing and defining control and plant protection system design requirements; it also has been used to evaluate reactivity events in the Conceptual Safety Analysis Report and other transient events to evaluate different design options. The model is composed of a collection of modules, most of which are reused throughout the model.

2.1 CORE AND CORE PRESSURE BOUNDARY TUBE REGIONS

The power generation in the core is estimated from the addition of two components: (1) the core neutronics (modeled using point kinetics) with delayed neutrons (including photo-delayed neutrons) and (2) decay heat (based on an ANS-specific correlation).

ANSMD models the average channel fuel and coolant dynamics. The average channel determines the average core outlet conditions. A single axial node is used for this calculation. The dynamics of the hot streak of the upper and lower element are simulated separately from the average channel calculation. The lower element is typically limited at beginning of cycle (BOC); the upper element, at end of cycle (EOC). Thus, in our model we use the BOC axial power shape and hot streak factors for the lower element hot channel and the EOC conditions for the upper element. The two hot channels are divided into up to 50 axial nodes (typically, we use 27) where local temperatures, pressures, and heat fluxes are estimated to determine its margin to incipient boiling, critical heat flux, and flow excursion instability.

A single bypass region simulates the flow of heavy water that bypasses the fuel elements inside the pressure vessel. This coolant is typically colder than the core outlet coolant such that when it mixes, the vessel outlet temperature (which is computed dynamically) is lower than the core outlet temperature.

2.2 REFLECTOR REGION

A reflector region is modeled with a very simplified one-node approach. The reflector provides some (but not much) reactivity feedback to the core owing to the direct neutron and gamma heating. ANSDM does not model the reflector coolant systems. The main purpose of this node is to provide for an estimate of the reflector temperature feedback.

2.3 COOLING SYSTEMS

Cooling system pipes are modeled, and they release heat to the appropriate surrounding light water pools. Whenever parallel flows exists (i.e., multiple hot legs), ANSDM uses a single pipe with an effective flow area and equivalent diameter.

Containment light water pools (i.e., the main reactor pool, the pipe chase pool, the heat exchangers pool) are modeled. These pools take heat from the reactor piping according to their relative temperature and based on natural convection heat transfer coefficients. The heat exchanger pool also cools the emergency heat exchanger secondary side by natural circulation.

The main heat exchanger is modeled with the primary flow in the shell side and with the secondary flow in the tube side. Heat transfer characteristics are adjustable by varying the tube diameter and surface area; typically, values include a fouling heat transfer resistance factor.

The emergency heat exchanger is modeled in series with the main heat exchanger. Primary flow is in the shell side, and secondary flow is on the tube side. The shell side (primary) assumes "turbulizers" so that the flow is never laminar regardless of Reynolds number. The tube's diameter is designed to be about 0.05 m (2 in.) so that the Reynolds number will be large enough to ensure turbulent flow even at the low natural circulation flow rates. The secondary side of the emergency heat exchanger is connected to the heat exchanger pool and allowed to flow by natural circulation.

Main circulation pumps are modeled according to the head-flow characteristic curve. The characteristic curve scales the flow directly proportional to the pump rotational speed; the pump head is proportional to the square of the pump speed; and the power required is proportional to the cube of the speed. Pump coast-down is modeled based on a conservation of angular momentum; the resulting differential equation that is solved by the model is:

$$\frac{dn}{dt} = \frac{n^2 - n_0^2}{\tau}, \quad (1)$$

where n is the pump rotational speed, n_0 is the desired equilibrium speed (e.g., $n_0 = 10\%$ if a reduction to pony flow is desired), and τ is the pump half speed time constant. The coast-down flow and pump head are computed by scaling the characteristic pump curve using the calculated speed, n .

2.4 GAS ACCUMULATORS

The gas accumulator is assumed to follow the ideal gas law ($P V^\gamma = \text{constant}$). The default values in ANSDM assume that the accumulators expand isothermally (i.e., $\gamma = 1.0$), but a model parameter (KGCGAC) can be changed to 1.4 for an adiabatic expansion. The initial gas-to-liquid ratio is such that the liquid level will not reach the bottom of the accumulator after the gas has expanded to the depressurized condition; for a 2.0-MPa core outlet pressure, the liquid-to-gas ratio is 20 to 1.

2.5 MAKEUP AND LETDOWN SYSTEMS

The reactor pressure is maintained high by a makeup flow. The model simulates this flow with a pump module (i.e., the pressurizer pump) with a suction in a constant pressure tank (i.e., the letdown system tank). The makeup pump speed is maintained constant unless a coast-down (e.g., loss of off-site power) is required. During normal operation the makeup flow adjusts itself to the system pressure (e.g., as the system pressure lowers, the makeup flow increases). These changes, however, are not sufficient to maintain constant pressure. The pressure regulation is accomplished by modulating the flow through the letdown valves. The letdown valves are modeled as a pressure drop with variable coefficient (according to valve opening); the letdown flow is collected in the letdown tank. The model does not simulate the low-pressure cleanup system, and this tank is assumed to have an infinite supply of D₂O such that makeup can always be maintained. Makeup supply problems can be simulated at any time by tripping the makeup pump that is simulated with a perfect (i.e., no reverse flow) check valve.

2.6 SECONDARY COOLING SYSTEMS

The secondary side of the ANS cooling system is represented by:

- the secondary side of the main heat exchanger in the tube side,

- the secondary hot leg,
- main cooling towers and the cooling towers basin,
- the secondary circulation pump, and
- the secondary cold leg.

All these components use approximations similar to those in the primary system.

2.7 CONTROL SYSTEMS

A preliminary control system, simulated in the model, includes:

- control rod position based on the measured power-to-flow ratio,
- pressure control that actuates the letdown valve based on hot-leg pressure measurements, and
- core inlet temperature control that actuates on the secondary flow based on the temperature measured at the heat exchanger outlet.

2.8 INSTRUMENTATION

Sensor dynamics are modeled as first-order lag systems. The required time constants have been determined through simulation of control and plant protection system challenges. The time constants currently in the model are those required to satisfy most design basis events requirements.

2.9 BREAKS

Breaks are simulated as a flow through an orifice (of the break effective diameter) from the inside of the main piping system to the light water pools. The leak flow, W_{lk} , is estimated from the orifice relation as

$$W_{lk} = \frac{C_v}{\sqrt{1 - \left(\frac{D_b}{D}\right)^4}} \frac{\pi D^2}{4} \sqrt{2\rho(P - P_{lk})}, \quad (2)$$

where P_{lk} is the pool pressure, P is the system pressure, C_v is the orifice coefficient (taken as 0.6 for a sharp orifice), D_b is the break effective diameter, and D is the pipe diameter.

Breaks are opened exponentially over a finite period of time, τ , following the expression

$$D(t) = D_b (e^{\frac{t}{\tau} \ln 2} - 1) \quad \text{if } 0 \leq t \leq \tau, \quad (3)$$

and

$$D(t) = D_b \quad \text{if } t \geq \tau, \quad (4)$$

where $D(t)$ is the effective break diameter, D_b is the final break size, and τ is the break time constant (typically 250 ms). ANSDM does not model the compressibility of D_2O such that the effective speed of sound is infinite. Therefore, ANSDM cannot model fast-opening large breaks where the pressure perturbations are large and speed-of-sound effects are relevant.



3. MODELS AND EMPIRICAL CORRELATIONS

This section documents the empirical correlations used in ANSDM. Unless otherwise stated, the units for all correlations are SI, energy is in joules, temperature is in degrees Celsius, length is in meters, and time is in seconds.

3.1 HEAVY WATER PROPERTIES

ANSDM uses the standard ANS D₂O correlations that define some D₂O properties required by ANSDM as a function of known parameters. Appendix A documents the specific correlation parameters and units used in ANSDM; the actual FORTRAN Program used is shown.

3.2 FRICTION FACTORS

Appendix B lists the actual FORTRAN coding used to estimate the friction factor. Figure 1 shows the friction factor calculated by ANSDM following a scram and complete loss of pumping power (i.e., natural circulation). This section discusses some of the approximations used.

3.2.1 Turbulent Regime

In the turbulent regime ($Re > 4240$), ANSDM uses two different correlations to estimate the Darcy friction factor: the Filonenko correlation in the core region and the Colebrook and White correlation for the piping sections. If a relative roughness other than zero is input, ANSDM uses the Colebrook and White correlation; otherwise, it uses the Filonenko correlation.




Fig. 1. Friction factor calculated by the Advanced Neutron Source Dynamic Model after scram and transition to natural circulation.

The Filonenko correlation used for ANS design applies to smooth surfaces. When a correction for rectangular channels and coolant properties is included, the correlation takes the form.

$$f_D = \frac{1.0875 - 0.1125 (b/s)}{(1.82 \log_{10} Re_b - 1.64)^2} \left[\frac{7 - (\mu_b/\mu_w)}{6} \right]. \quad (5)$$

ANSDM does not use this form of the correlation. It uses the following approximation:

$$f_D = \frac{1.0836}{(1.82 \log_{10} Re_b - 1.64)^2}. \quad (6)$$

ANSDM collapses both the upper and lower fuel elements into a single average channel; thus, it uses an average of the span-to-gap aspect ratio (b/s) for the upper and lower elements, resulting in the term 1.8036, which includes an average aspect ratio for both cores.

The last term in Eq. (5) is a correction proposed by Petukhov to account for the effect of heated fluids, which have lower viscosity near the wall. ANSDM ignores this term to avoid the need for iterative solutions that involve the fuel temperature. The effect of this term is fairly small. For instance, the core average coolant outlet temperature is 85°C, and the average fuel wall temperature is 121°C. With these numbers, the error introduced by neglecting the second term in Filonenko's correlation is about 7% (ANSDM estimates higher friction than the actual one). This error is partly offset by the fact that ANSDM estimates the pressure drop based on the outlet conditions of a single axial node in the core region. We estimate the error caused by this single-node approximation to be about 10% (the friction factor at 85°C is 0.0174 and at 45°C is 0.0209; the average is 0.0191, or about 10% higher than ANSDM estimates). Thus, ANSDM assumes that the 7% error introduced by ignoring the second term in Filonenko's correlation is partially offset by the 10% error caused by the single-node approximation. The error caused by these two approximations diminishes as the power is decreased (e.g., following scram). Because of these approximations, the pressure-drop estimate accuracy in ANSDM is assumed to be $\pm 10\%$ but is probably lower owing to cancellation of errors.

In the piping region the Filonenko correlation is not applicable because the pipes have an appreciable roughness factor, ϵ . In this region ANSDM uses the Colebrook and White correlation. The friction factor is estimated by direct iteration from the following implicit equation:

$$\sqrt{f_D/4} = \frac{1}{3.48 - 1.7372 \ln \left(\frac{\epsilon}{2D_e} + \frac{9.35}{Re \sqrt{f_D/4}} \right)}. \quad (7)$$

To initiate the iteration, ANSDM uses the Moody correlation as the initial guess:

$$f_D/4 = 0.001375 \left[1 + 21.544 \left(\frac{\epsilon}{2D_e} + \frac{100}{R_e} \right)^{\frac{1}{3}} \right]. \quad (8)$$

3.2.2 Laminar Regime

In the laminar regime ANSDM uses the standard laminar friction factor correlation:

$$f_D = 4 \frac{23.532}{Re} . \quad (9)$$

3.2.3 Transition Regime

To avoid possible numerical instabilities, the transition regime is modeled at Reynolds numbers lower than 4240 by selecting the higher of two numbers: the laminar friction factor at the actual Reynolds number or the turbulent friction factor at $Re = 4240$. This approximation results in a constant friction factor for Reynolds numbers between 2300 and 4240. In this way, a smooth transition between laminar and turbulent is achieved.

3.3 HEAT TRANSFER COEFFICIENTS

3.3.1 Core Region

Appendix C documents the actual FORTRAN coding for heat flux and heat transfer correlations. In the fully developed turbulent regime ($Re > 2300$) ANSDM uses the Petukhov correlation to estimate the heat transfer between the fuel plates and the core coolant. This correlation takes the form

$$h_{\text{turbulent}} = \frac{k}{D_e} \frac{\left(f_D/8\right) Re_b Pr_b \left(\mu_b/\mu_w\right)^{0.11}}{\left(1 + 3.4f_D\right) + \left(11.7 + \frac{1.8}{Pr^{1/3}}\right) \sqrt{f_D/8} \left(Pr^{2/3} - 1\right)} . \quad (10)$$

In the laminar regime ($Re < 2300$) ANSDM uses a constant Nusselt number of 7.627 with a correction for heated fluid. The actual correlation takes the form

$$h_{\text{laminar}} = \frac{k}{D_e} 7.627 \left(\mu_b/\mu_w\right)^{0.11} . \quad (11)$$

3.3.2 Piping Region

ANSMD estimates the heat lost to the containment light-water pools. The heat transfer coefficient inside the circular pipes is estimated using the following correlations:

$$h_{\text{turbulent}} = \frac{k}{D_e} \left[6.3 + \frac{0.079 \sqrt{f_D/8} Re Pr}{\left(1 + Pr^{0.8}\right)^{5/6}} \right] , \quad (12)$$

and

$$h_{\text{laminar}} = \frac{k}{D_e} 4.364 . \quad (13)$$

The heat transfer coefficient outside of the pipes is input manually, and it is maintained constant during all transients.

3.4 INCIPIENT BOILING

ANSDEM uses an incipient boiling correlation based on local conditions at the hot spot. The correlation used is that of Bergles and Rosenhow. The incipient boiling flux is estimated by iteration between the two following equations:

$$Q_{IB} = 0.9 \times 1.7978 \times 10^{-6} \times P^{1.156} \times [1.8 (T_w - T_b)]^{(2.8285/P^{0.0234})} , \quad (14)$$

and

$$Q_{IB} = h(T_w - T_b) , \quad (15)$$

where h is the local heat transfer coefficient estimated using the Petukhov correlation.

3.5 CRITICAL HEAT FLUX

ANSDEM estimates the critical heat flux (CHF) using the Gambill additive CHF correlation, the Weatherhead correlation for CHF wall temperature, and the Petukhov heat transfer coefficient correlation. The flowing equations are used:

$$Q_{pool} = 0.18 h_{fg} \rho_v \left(\sigma g \frac{\rho_l - \rho_v}{\rho_v^2} \right)^{1/4} \left(1 + \left[\frac{\rho_l}{\rho_v} \right]^{3/4} c_p \frac{T_{sat} - T_{bulk}}{9.8 h_{fg}} \right) , \quad (16)$$

and

$$Q_{crit} = Q_{pool} + h (T_{wall} - T_{bulk}) , \quad (17)$$

where h is the local heat transfer coefficient estimated using the Petukhov correlation, and T_{wall} (i.e., the critical wall temperature) is estimated from the following equation:

$$T_{wall} = T_{sat} + (47.7 - 0.127 T_{sat}) \left(\frac{Q_{crit}}{3.1546E6} \right)^{1/4} . \quad (18)$$

Because T_{wall} depends on the critical flux, Q_{crit} , the solution of the above equation requires an iteration procedure. To initiate the iteration, T_{wall} is estimated without the Weatherhead correction using the following equation:

$$T_{wall} = T_{sat} + 84.96 - 0.1313 (T_{sat} + 273.16) . \quad (19)$$

3.6 FLOW EXCURSION

Flow excursion is a special case of critical heat flux that is caused by a flow instability rather than a change in boiling regime. ANSDM uses the Costa correlation to estimate this critical heat flux:

$$Q_{crit} = \frac{(T_{sat} - T_{bulk}) \sqrt{u}}{12.8E-6} . \quad (20)$$

4. MODEL PARAMETERS

All model variables are accessible at run time for display, and they can also be modified at any time. In this way, different power levels or reactor configurations can be input at run time with simple “set” commands that can be prepared in a command file for multiple uses or that can be input from the keyboard. The variable nomenclature, thus, is important. This section describes this nomenclature, and Appendix F lists all variables and their nominal values.

An ACSL variable name has up to six characters. In ANSDM the first one, two, or three characters describe the type of parameter, and the last three or four characters describe the location on the model. For example, the variable *TCORO* represents the temperature (variable type = *T*) at the core outlet (location = *CORO*). Table 1 documents the interpretation of the first two characters, Table 2 documents the model nodes (i.e., three character locations that relate to node-average variables), and Table 3 documents the interconnection locations (i.e., four character locations that relate to node-boundary variables).

Table 1. Interpretation of the first two characters of Advanced Neutron Source Dynamic Model variable names

Characters	Variable type	Units	Characters	Variable type	Units
CFR	Critical heat flux ratio (Gambill correlation)	Adimensional	P	Pressure	Pa
CIR	Critical heat flux ratio (incipient boiling)	Adimensional	PS	Saturation pressure	Pa
CSR	Critical heat flux ratio (flow excursion)	Adimensional	PR	Prandtl number	Adimensional
CK	Coolant conductivity	W/(m · K)	Q	Heat flux	W/m ²
CP	Heat capacity	J/(kg · K)	R	Coolant density or reactivity	kg/m ³ Dollars
F	Neutron flux (also) friction coefficient	n/m ² Adimensional	RE	Reynolds number	Adimensional
H	Heat transfer coefficient	W/(m ² · K)	T	Temperature	C
J	Power	W	TS	Saturation temperature	C
K	Constant parameter. Type depends on next character		U	Velocity	m/s
MU	Viscosity	kg/(s · m)	V	Control variable. Type depends on next character	
MCR	Minimum critical heat flux ratio along all channels	Adimensional	W	Mass flow rate	kg/s
MIR	Minimum incipient boiling ratio along channel	Adimensional	X	Position	m
MSR	Minimum flow excursion ratio along all channels	Adimensional	Z	Internal node variable. Type depends on next character	
N	Angular speed (for pumps)	Normalized			

Table 2. Interpretation of the node characters in Advanced Neutron Source Dynamic Model variable names

Node	Module ^a	Description
TRA	1	Externally imposed transients
ANS	1	Main ANSDM module
DET	2	Detectors
CON	2	Controls
PPS	2	Plant protection system
SCRAM	3	Scram module
ICR	2	Inner control rod
OCR	2	Outer control rod
VES	2	CPBT and core region
REF	3	Reflector region
IPR	3	Inlet plenum region
COR	3	Core region
CPG	4	Core power generation
CDH	5	Core decay heat
CNT	5	Core neutronics
POI	5	Neutron poisons model
ACC	4	Average channel coolant
ACF	4	Average channel fuel
ACH	4	Average channel
BYP	4	Bypass
HCL	4	Hot channel lower core
HCU	4	Hot channel upper core
HLC	4	Hot channel lower core coolant
HLF	4	Hot channel lower core fuel
HUC	4	Hot channel upper core coolant
HUF	4	Hot channel upper core fuel
OPR	4	Outlet plenum region
CCS	2	Coolant cooling systems
CIL	3	Core inlet leak
CLR	3	Cold leg riser
COL	3	Core outlet leak
EHX	3	Emergency heat exchange
EPP	3	Emergency heat exchanger primary side
ESP	3	Emergency heat exchanger secondary
GAC	3	Gas accumulator
HLR	3	Hot leg riser
HXP	3	Heat exchangers pool
LDS	3	Letdown system
MCL	3	Main cold leg (horizontal part)
MCP	3	Main coolant pump
MCS	3	Storage (controls pressure dynamics)
MHL	3	Main hot leg (horizontal part)
MHP	3	Main heat exchanger primary side
MHX	3	Main heat exchange
MRP	3	Main reactor pool
MUS	3	Makeup system
PCH	3	Pipe chase pool
POL	3	Pump outlet leak module
SHP	3	Main heat exchanger secondary side
SCC	3	Secondary cooling circuits
CTB	4	Cooling towers basin
TCL	4	Secondary cold leg (tower to MHX)
THL	4	Secondary hot leg (MHX to tower)

^aNumbers indicate parent module sequence.

Table 3. Interpretation of the node interface characters in Advanced Neutron Source Dynamic Model variable names

Node interface	Description
ACHI	Average channel inlet
ACHO	Average channel outlet
AREA	Accident reactivity
BYPI	Bypass inlet
BYPO	Bypass outlet
CILC	Core inlet leak at containment side
CLRI	Cold leg riser inlet
CLRO	Cold leg riser outlet
CNXF	Core neutron flux
COLC	Core outlet leak at containment side
CORO	Core outlet at outlet plenum
CROD	Control rods (inner + outer)
CTBI	Cooling towers basin inlet (hot leg)
CTBO	Cooling towers basin outlet (cold leg)
DHFX	Core gamma flux
DHFX	Decay heat fluxes
ESCL	Secondary cold leg at emergency heat exchanger inlet
ESHL	Secondary hot leg at emergency heat exchanger outlet
HCLI	Hot channel lower core inlet
HCLO	Hot channel lower core outlet
HCUI	Hot channel upper core inlet
HCUO	Hot channel upper core outlet
HLRI	Hot leg riser inlet
HLRO	Hot leg riser outlet
HSFC	Hot spot coolant
HXPI	Heat exchangers pool coolant flow inlet (cold)
HXPO	Heat exchangers pool coolant flow outlet (hot)
IPCI	Inlet plenum outlet at core inlet
LDSI	Letdown system inlet
MCLI	Main cold leg inlet (at pump outlet leak location)
MCLX	Emergency heat exchanger outlet (cold leg inlet)
MCPI	Main coolant pump inlet
MCPO	Main coolant pump outlet
MCSO	Main cold leg at storage module outlet
MHLA	Main hot leg at accumulator outlet
MHLL	Main hot leg at letdown outlet
MHLO	Main hot leg outlet
MHXO	Main heat exchanger outlet
MRPI	Main reactor pool coolant flow inlet (cold)
MRPO	Main reactor pool coolant flow outlet (hot)
MUSO	Makeup system outlet
PCHI	Pipe chase pool coolant flow inlet (cold)
PCHO	Pipe chase pool coolant flow outlet (hot)
POLC	Pump outlet leak at containment side
REFC	Reflector-core interface
REFI	Reflector inlet
REFO	Reflector outlet
SCLX	Secondary cold leg at main heat exchanger inlet
SHLX	Secondary hot leg at main heat exchanger outlet
TCLI	Secondary cold leg inlet at tower
TCLO	Secondary cold leg outlet at MHX
THLO	Secondary hot leg outlet at towers
VESI	CPBT inlet
VESO	CPBT outlet
XESM	Neutron poisons

5. SAMPLE PROCEDURES

Within the ACSL the user can define macros to execute procedures in a consistent manner. Appendix D shows the standard ANSDM macro file (ANS.CMD) that defines the most common procedures that can be exercised with ANSDM. In this we show and describe an example procedure to run a natural circulation transient.

Either at ACSL run time or by loading a command file, the user defines the following procedure, called *natcir*, that sets a transition to natural circulation by tripping the pump at the beginning of the transient. The procedure is defined as follows:


```
proced natcir
  set hvdprn=.true.
  ! Pry pump speed will be set to 0 (natural circulation) at time 0
  set hvdprn=false.
  action /var = 0., /val = 0., /loc = zn0mcp
  p2off
end    ! of procedure natcir
```

The first line defines the name of the procedure; this is further defined by the lines that follow and is delimited by the *end* statement. Comments following an exclamation mark (!) are ignored. Variable *hvdprn* is an internal ACSL variable that controls the high-volume display to the screen; it is originally set to *.true.* to output the comment to the screen and then set to *false*. to avoid unnecessary screen I/O. The *action* statement instructs ACSL to set variable *zn0mcp* (i.e., the main coolant pump speed setpoint) to zero (*/val = 0.*) at time zero (*/var = 0.*). The final statement *p2off* executes a procedure (or macro) that has been defined previously in file ANS.CMD (see Appendix D); this procedure trips the secondary cooling circuit pumps and resets the temperature control parameters.


To execute a transition to natural circulation, the user must invoke the *natcir* procedure and then start the simulation. In ACSL run time language, the following steps are performed:

```
ACSL> natcir
ACSL> start
```

After the simulation is completed, the user may print or plot any of the variables that have been prepared (or saved). Appendix D lists the standard variables prepared automatically by ANS.CMD. Appendix E shows nominal operating conditions predicted by ANSDM.



Appendix A
HEAVY WATER CORRELATIONS



APPENDIX A. HEAVY WATER CORRELATIONS

```

c
c ** Physical properties of D2O
c ** Official ANS correlations as of September 30
1991
c ** Memo from Moshw Siman-Tov to D.G. Selby
c
c ** Note: Some correlations here use different
units
c ** than in the "official" correlations in the
memo
c
c
-----
c
***** *****
c
-----
c D2O Saturation Temperature
c   INPUT :
c     . P      Pressure (Pa)
c   OUTPUT :
c     D_TSAT    Saturation temperature (C)
c
-----
real function D_TSAT(P)
  real    P
  real    a0, a1, a2, a3
  data   a0/5.194927982/,
a1/2.36771673e-1/,
>           a2/-2.615268e-3/, a3/1.708386e-3/

```

A-3

```

x   = alog(ABS(P)/1.e6)
D_TSAT= exp(a0 + a1*x + a2*x**2 + a3*x**3)
return
end
c
c
-----
c
***** *****
c
-----
c D2O Liquid Density
c   INPUT :
c     T      Temperature (C)
c   OUTPUT :
c     D_RHOL   Liquid density (kg/m3)
c
-----
real function D_RHOL(T)
  real    T
  real    a0, a1, a2
  data   a0/1.117772605e3|,
a1/-7.7855e-2|,
>           a2/-8.42e-4/
  x   = 32. + 1.8*T
  D_RHOL= a0 + a1*x + a2*x**2
  return
end
c

```

```

c
-----
c
***** *****
c
-----
c D2O Saturated Liquid Thermal Conductivity
c   INPUT :
c     T      Temperature (C)
c   OUTPUT :
c     D_K    Liquid Conductivity (W/m/K)
c
-----
real function D_K(T)
  real    T
  real    a0, a1, a2, a3
  data   a0/-4.521496e-1,
a1/3.60743280e1/,
  >          a2/-3.579973221e2/,
a3/9.240219962e2/,
  >          conv/1.729577/

  x = (491.67 + 1.8*T)/1.e4
  D_K = a0 + a1*x + a2*x**2 + a3*x**3
  return
end

c
c
***** *****

```

A-4

```

c
-----
c D2O Saturated Liquid Specific Heat
c Note: "Official" correlation uses energy in KJ.
Use conv for J
c   INPUT :
c     T      Temperature (C)
c   OUTPUT :
c     D_CP   Liquid Specific Heat (J/kg/K)
c
-----
real function D_CP(T)
  real    T
  real    a0, a1, a2, a3
  data   a0/2.237124/,
a1/1.22217151e2/,
  >          a2/-2.303384060e3/,
a3/1.3555737878e4/,
  >          conv/1.e3/

  x = (491.67 + 1.8*T)/1.e4
  D_CP = conv*(a0 + a1*x + a2*x**2 +
a3*x**3)
  return
end

c
c
***** *****
c
-----
```

```

c D2O Surface Tension
c   INPUT :
c     T      Temperature (C)
c   OUTPUT :
c     D_SIG Surface Tension (N/m)
c
-----
real function D_SIG(T)
  real    T
  real    a, b, c
  data   a/2.44835759e-1/, b/1.269/, 
>          c/-6.660709649e-1/
  x    = (371.49 - T)/644.65
  D_SIG  = a * ABS(x)**b * (1. + c*x)
  return
end
c
c
-----
c *****
c *****
c
c
c D2O Latent Heat of Vaporization
c Note: "Official" correlation uses energy in KJ.
c Use conv for J
c   INPUT :
c     T      Temperature (C)
c   OUTPUT :
c     D_HFG Latent Heat of Vaporization
c           (J/kg)
c

```

A5

```

-----
real function D_HFG(T)
  real    T
  real    a0, a1, a2
  data   a0/5.080936669e5/, 
a1/1.7006921765e4/, 
>          a2/-1.1009078e1/, conv/1.e3/
  x    = 371.49 - T
  D_HFG  = conv*sqrt(ABS(a0 + a1*x +
a2*x**2))
  return
end
c
c
-----
c *****
c *****
c
c
c D2O Saturated Vapor Density
c   INPUT :
c     T      Temperature (C)
c   OUTPUT :
c     D_RHOV    Saturated Vapor Density
c           (kg/m3)
c
-----
real function D_RHOV(T)
  real    P
  real    a0, a1, a2, b0, b1, b2
  data   a0/-5.456208705/, 

```

```

a1/6.0526809e-2/,
>           a2/-1.11360e-4/,   b0/1.0/,
>           b1/2.386228e-3/,   b2/-1.15778e-5/

      D_RHOV = exp((a0 + a1*T + a2*T**2) / (b0 +
b1*T + b2*t**2))
      return
end

c
c
-----
c *****
c *****

c D2O Liquid Dynamic Viscosity
c INPUT :
c     T      Temperature (C)
c OUTPUT :
c     D_MU  Liquid Dynamic Viscosity (Pa s)
c
-----

real function D_MU(T)
  real    T
  real    a0, a1, b1, b2
  data   a0/-1.111606e-4/, a1/9.46e-8/
  >          b1/8.873655375e-2|,
b2/4.111103409e-1/

  x    = 32. + T*1.8
  D_MU = a0 + a1*x + b1/x + b2/x**2
  return
end

c
c
-----
c
*****
```

```


-----
C
*****
*****  

C
-----
C
c D2O Liquid Specific Heat as function of enthalpy
c Note: "Official" correlation uses energy in KJ.
Use conv for J
c      INPUT :
c          H      Enthalpy (J/kg)
c      OUTPUT :
c          D_CP_H      Liquid Specific Heat
(J/kg/K)
c
-----
real function D_CP_H(H)
real      H
real      a0, a1, a2, a3
data      a0/4.303528320/,
a1/-4.09143e-4/,
>           a2/-2.037e-7|,
a3/8.6071287e-10|,
>           conv/1.e3/
x = H/1.e3
D_CP_H= conv*(a0 + a1*x + a2*x**2 +
a3*x**3)
return
end
C
C
-----
```

```

-----
C
*****
*****  

C
-----
C
c D2O Saturation Pressure
c      INPUT :
c          T      Temperature (C)
c      OUTPUT :
c          D_PSAT      Saturation Pressure (Pa)
c
-----
real function D_PSAT(T)
real      T
real      a0, a1, a2, a3, conv
data      a0/9.5720020e1/, a1/1.2010e-2/
b1/-8.439470752e3|,
c1/-1.3496506e1/
>           conv/1.e6/
x = 273.16 + T
D_PSAT= conv*exp(a0 + a1*x + b1/x +
c1*log(x))
return
end
-----
```



Appendix B
COOLANT-RELATED CORRELATIONS



APPENDIX B. COOLANT-RELATED CORRELATIONS

```

SUBROUTINE CPROPH(CL, H_CL,
>                 CP_CL, T_CL, R_CL, RH_CL, MU_CL,
CK_CL, PS_CL)
C
C
-----
C
*****  
*****  
*****
C
C      This subroutine computes coolant properties  

that depend  

on the enthalpy.  

C      See MACRO CPROP (File CPROP.M10) for a  

description of all  

the variables
C
C
-----
C
*****  
*****  
*****
C
C      CHARACTER *4 CL
REAL H_CL, CP_CL, T_CL, R_CL, RH_CL, MU_CL,
CK_CL

```

```

DATA HMAX/1.2E6/, HMIN/4.E4/
C
C
-----
C
*****  
*****  
*****
C
C      ! AVOID OVERFLOWS IF H_CL UNDEFINED
H = H_CL
IF(H_CL .GT. PMAX .OR. H_CL .LT. PMIN) THEN
  WRITE(*,'('' <CPROP::'', A4, ''> ERROR. H
= ''
C      > , G15.5)'') CL, H
  IF(H.LT.HMIN) H = HMIN
  IF(H.GT.HMAX) H = HMAX
ENDIF

CP_CL = D_CP_H(H)
T_CL = H/CP_CL
R_CL = D_RHOL(T_CL)
RH_CL = D_RH(T_CL)
MU_CL = D_MU(T_CL)
CK_CL = D_K(T_CL)
PS_CL = D_PSAT(T_CL)
RETURN
END

C
C
C

```

B3

```

SUBROUTINE CPROP(W_CL, R_CL, KA_CL,
CP_CL,
    >      MU_CL, CK_CL, KD_CL, KE_CL,
    >      U_CL, PR_CL, RE_CL, F_CL, HW_CL)
C
C
-----
C
*****  

*****  

C
-----  

C
-----  

C
C      This subroutine computes coolant properties  

that depend  

on the flow.  

C      See MACRO CPROP (File CPROP.M10) for a  

description of all  

C      the variables
C
C
-----
C
*****  

*****  

C
-----  

C
-----  

C
CHARACTER *4 CL
REAL W_CL, R_CL, KA_CL, CP_CL, MU_CL, CK_CL,
KD_CL, KE_CL,
    >      U_CL, PR_CL, RE_CL, F_CL, HW_CL
DATA RE_TUR/4240./

```

C
C

C

C

C

C
U_CL = W_CL / R_CL / KA_CL
PR_CL = ABS(CP_CL * MU_CL / CK_CL)
RE_CL = MAX(ABS(U_CL*KD_CL*R_CL/MU_CL),
1.E-4) ! Core friction correlation
IF(KE_CL .LE. 0.) THEN
C ! If smooth use Filonenko (for
core)
 IF(RE_CL .GT. RE_TUR) THEN
 F_CL = F_FILO(CL, RE_CL, KE_CL, KD_CL)
 ELSE
 F_MIN = F_FILO(CL, RE_TUR, KE_CL,
KD_CL)
 F_L = F_LAM(CL, RE_CL, KE_CL, KD_CL)
 F_CL = MAX(F_MIN, F_L)
 ENDIF
C ! IF KE_CL<0 USE AS FUDGING FACTOR
 IF(KE_CL .LT. 0.) F_CL = F_CL*ABS(KE_CL)
ELSE
C ! Else use Colebrook and White
 IF(RE_CL .GT. RE_TUR) THEN
 F_CL = F_CW(CL, RE_CL, KE_CL, KD_CL)
 ELSE
 F_MIN = F_CW(CL, RE_TUR, KE_CL, KD_CL)
 F_L = F_LAM(CL, RE_CL, KE_CL, KD_CL)
 F_CL = MAX(F_MIN, F_L)
 ENDIF

```
        ENDIF
        ENDIF

C
C ** Heat transfer coefficients
C           ! Inside tube
XNUL = 4.364
XNUT = 6.3 +
0.079*SQRT(ABS(F_CL)/8.)*RE_CL*PR_CL /
>           (1. + PR_CL**0.8)**(5./6.)

IF(RE_CL .LT. 2200) THEN
  XNU = XNUL
ELSE
  XNU = XNUT
ENDIF

C           ! This corr may give problem if
variables undefined
C   XNU = ( XNUL**10 + ( EXP(
(2200.-RE_CL)/365.)/XNUL**2 +
C     >           XNUT**(-2) )**(-5)
)**0.1
  HW_CL = CK_CL*XNU/KD_CL
C           ! Outside tube
C   HW_CL = R_CL * U_CL * CP_CL * 0.03 /
RE_CL**0.2 /
C   >           PR_CL**(2./3.)

RETURN
END

C
C
C
SUBROUTINE CPROPP(CL, P_CL,
>                 TS_CL)
C
```

```
-----
-----
C
***** *****
C
-----
C
C   This subroutine computes coolant properties
that depend
C   on the pressure.
C   See MACRO CPROP (File CPROP.M10) for a
description of all
C   the variables
C
C
-----
C
***** *****
C
-----
C
CHARACTER *4 CL
REAL P_CL, TS_CL
DATA PMIN/0.03E6/, PMAX/8.4E6/
C
C
-----
C
***** *****
C
```

B-5

```

-----
C
      P      = P_CL
      IF(P_CL.LT.PMIN .OR. P_CL.GT.PMAX) THEN
C        WRITE(*,'('' <CPROP::'', A4,'> ERROR P =
<>''
C        >           , G15.5)') CL, P_CL
      IF(P.LT.PMIN) P = PMIN
      IF(P.GT.PMAX) P = PMAX
      ENDIF

      TS_CL = D_TSAT(P)

      RETURN
      END

C
C
C      FUNCTION F_LAM(CL, RE_CL, KE_CL, KD_CL)
C
C
-----
```

B-6

```

C
***** *****
C
-----
```

C This function estimates the laminar friction coefficient

C This function returns 4*f

C

C CL C*4 Coolant node

C RE_CL R*4 Reynolds number

```

C      KE_CL R*4   Pipe roughness (m)
C      KD_CL R*4   Pipe diameter (m)
C
C
-----
```

C

C

C

C

CHARACTER *4 CL

REAL RE_CL, KE_CL, KD_CL

C

C

C

C

F_LAM = 4.*23.532/RE_CL

RETURN

END

C

C

C FUNCTION F_FILO(CL, RE_CL, KE_CL, KD_CL)

C

C

```

C ****
C
C ****
C This function estimates the turbulent friction
C coefficient
C based on teh Filonenko correlation for ANS core
C This function returns 4*f
C
C   CL    C*4   Coolant node
C   RE_CL R*4  Reynolds number
C   KE_CL R*4  Pipe roughness (m)
C   KD_CL R*4  Pipe diameter (m)
C
C ****
C
C ****
C
CHARACTER *4 CL
REAL RE_CL, KE_CL, KD_CL
C
C ****
C
C ****
C

```

```

F_FILO = 4.*0.2709/(1.82*ALOG10(RE_CL) -
1.64)**2
RETURN
END
C
C
C FUNCTION F_CW(CL, RE_CL, KE_CL, KD_CL)
C
C ****
C

```

```

C ****
C This function estimates the turbulent friction
C coefficient
C based on Colebrook and White correlation for
circular pipes
C This function returns 4*f
C
C   CL    C*4   Coolant node
C   RE_CL R*4  Reynolds number
C   KE_CL R*4  Pipe roughness (m)
C   KD_CL R*4  Pipe diameter (m)
C
C ****
C

```

```

***** *****
C
-----
C
CHARACTER *4 CL
REAL RE_CL, KE_CL, KD_CL
DATA ERROR/0.001/
C
C
-----
C
*****
C
*****
C
C1 = KE_CL/(KD_CL/2.)
C2 = 9.35/RE_CL

C           ! Moody correlation (f/4) for first
guess
F_M = 1.375E-3*(1. + 21.544*(C1 +
100/RE_CL)**(1./3.))
SF = SQRT(F_M)

NITER = 20
DO 100 I = 1, NITER
SF0 = SF
SF = 1. / (3.48 - 1.7372 * ALOG(C1 + C2/SF))
SFERR = ABS((SF - SF0)/SF0)
IF(SFERR .LT. ERROR) NITER = 0
100 CONTINUE
F_CW = 4.*SF**2

      IF(NITER .EQ. 20)
      >      WRITE(*,'(" <', A4,
      >      ''> F_COLEBRROK&WHITE DID NOT
CONVERGE.  F = ''', G20.5)')
      >      CL, F_CW
      RETURN
      END

```

Appendix C

HEAT TRANSFER AND CRITICAL HEAT FLUX CORRELATIONS

s

APPENDIX C. HEAT TRANSFER AND CRITICAL HEAT FLUX CORRELATIONS

```

SUBROUTINE CMFUEL(NODE, T, Q, UCL, TCL, PCL
>           , HL, DE, CHFTYP
>           , QI, QC, QS, TW, PW, H)
C
C
-----
C
***** *****
***** *****
C
-----
```

C ** MFUEL.F10 04-NOV-88 J M-L

C ** This subroutine is called by MACRO CMFUEL.

C ** It checks for

C ** parameters out of bounds. (Melting,

C ** superheating...)

C ** And calculates critical heat fluxes and wall

C ** temperature

C ** See MACRO MFUEL for more details.

C INTERCONNECTING VARIABLES :

C INPUT :

C NODE : Node name (R*4 as C*4)

C T : Actual temperature (melting

C included) (C)

C Q : Fuel/coolant heat flux (w/m²)

C UCL : Coolant velocity (m/s)

C TCL : Coolant temperature (C)

C PCL : Coolant pressure (Pa)

C HL : Heated length (m)

C DE : Equivalent diameter (m)

C CHFTYP : Type of CHF correlation

0-Bernath 1-Gambill 2-Costa

C

C OUTPUTS :

C QI : Incipient boiling heat flux (W/m²)

C QC : Critical heat flux (W/m²)

C QS : Flow stability (COSTA) heat flux

(W/m²)

C TW : Fuel wall temperature (C)

C PW : Press. required to avoid incipient

boiling (Pa)

C H : Wal heat transfer coefficient

(W/m²/C)

C

C

C

C

C

REAL NODE, T, Q

C ! Pure Al data

DATA TMELT/660.2/, HMELT/397061.6/,

CP/920.48/

C

C

C

```

C
-----
C
C      IF(T .GE. TMELT)
C      >      WRITE(*,'('' <'',A4,'> FUEL TEMP >
MELTING ''')') NODE

C ----- Heat transfer coeff (W/m2/C)
C       Iterate to find T_Wall
      TW = (D_TSAT(PCL) + TCL)/2.
      ICOUNT = 0
10    CONTINUE
      CALL HANS(UCL, TCL, TW, PCL, DE, HL, H,
H_LAM, H_TUR)

C ----- Fuel wall temperature (C)
      TWO = TW
      TW = TCL + Q/H
      ICOUNT = ICOUNT + 1
      IF(ICOUNT.GT.20) STOP 'T-WALL ITERATION
FAILED'
      IF(ABS(TWO - TW).GT.1.) GOTO 10
      CALL HANS(UCL, TCL, TW, PCL, DE, HL, H,
H_LAM, H_TUR)

C ----- Critical
COSTA-flow-excursion-instability power
      ITYPE = 2
      CALL QCRIT(ITYPE, UCL, TCL, PCL, H_TUR, QS,
TS)

C      IF(CSR .LE. 1.0)
C      >      WRITE(*,'('' <'',A4,'> FLOW
EXCURSION INSTABILITY''')') NODE

C ----- Critical heat flux (W/m2)
      ITYPE = INT(CHFTYP)
      CALL QCRIT(ITYPE, UCL, TCL, PCL, H_TUR, QC,
TC)

C      IF(CFR .LE. 1.0)
C      >      WRITE(*,'('' <'',A4,'> CRITICAL HEAT
FLUX REACHED''')') NODE

C ----- Pressure required to avoid incipient
boiling
      PW = D_PSAT(TW)

C ----- Incipient boiling heat flux (W/m2)
      ITYPE = 3
      CALL QCRIT(ITYPE, UCL, TCL, PCL, H_TUR, QI,
TI)

C      IF(CIR .LE. 1.0)
C      >      WRITE(*,'('' <'',A4,'> INCIPIENT
BOILING''')') NODE
      RETURN
      END
C
C
C
      SUBROUTINE HANS(U, TB, TW, P, DE, HL, H,
H_LAM, H_TUR)
C
C
-----
C
*****
```

C

```

-----
C
C ** This subroutine computes the heat transfer
coefficient
C ** in W/m2 based on ANS-specific correlation.
C ** Laminar corr for Re<2300 Nu=7.627
C ** Petukhov corr for Re>2300
C
C   INPUTS
C **   U      R*4    Coolant velocity (m/s)
C **   TB     R*4    Coolant bulk temperature
(C)
C **   TW     R*4    Fuel surface velocity (C)
C **   P      R*4    Coolant bulk pressure (Pa)
C **   DE     R*4    Equivalent diameter (m)
C **   HL     R*4    Heated length (m)
C   OUTPUT
C **   H      R*4    Film heat transfer coeff W/m2/K
C **   H_LAM R*4    Laminar film heat transfer coeff
W/m2/K
C **   H_TUR R*4    Turbulent film heat transfer
coeff W/m2/K
C
C
-----
C
*****
*****
```

C REAL U, TB, TW, P, DE, HL, H, H_LAM, H_TUR
C C ** Channel gap (B) and Span (S) (Avg of
lower&upper)

```

C
REAL B, S
DATA B/0.00127/, S/0.07882/
C
C
-----
C
*****
*****
```

C ! Saturation temp (C)
TSAT = D_TSAT(P)
C ! Coolant density (Kg/s)
C_RHO = D_RHOL(TB)
C ! Coolant viscosity
(Kg/s/m)
C_MUB = D_MU(TB)
C ! Coolant viscosity
@Wall (Kg/s/m)
TWALL = MAX(TB, MIN(TW, TSAT))
C_MUW = D_MU(TWALL)
C ! Coolant conductivity
(W/m/K)
C_K = D_K(TB)
C ! Coolant heat capacity
(J/Kg/K)
C_CP = D_CP(TB)
C
C

C


```

*****
C
-----
C
C           ! Prandtl number
C     PR = C_CP*C_MUB/C_K
C           ! Reynolds number
C     RE = ABS(U)*DE*C_RHO/C_MUB

C ** Laminar Flow (Nu = 7.627)
C     H_LAM = (C_K/DE) * 7.627 *
(C_MUB/C_MUW)**0.11

C ** Transition + Turbulent Flow (Petukhov)
C ** Friction factor Filonenko
C ** Filonenko not corrected for temp for use
with Petukhov
      F = (1.0875 -
0.1125*B/S)/(1.82*ALOG10(Re) - 1.64)**2
C     >          * (7. - C_MUB/C_MUW)/6.
C     H_TUR = ( (C_K/DE) * (F/8.) * RE * PR *
(C_MUB/C_MUW)**0.11 )
C     >          / ( (1. + 3.4*F) + (11.7 +
1.8/PR**0.333)
C     >          * SQRT(F/8.) * (PR**0.666 -
1. ) )
H_NUM = (C_K/DE) * (F/8.) * RE * PR *
(C_MUB/C_MUW)**0.11
H_D1 = (1. + 3.4*F)
H_D2 = (11.7 + 1.8/PR**0.333)
H_D2 = H_D2*SQRT(F/8.)
H_D2 = H_D2*(PR**0.666 - 1.)
H_TUR = H_NUM/(H_D1+H_D2)

C
IF(RE .LT. 2300) THEN
  H = H_LAM
  ELSE
    H = H_TUR
  ENDIF

  RETURN
END

C
C
C           SUBROUTINE QCRIT(itype, U, T, P, H_TUR, QC,
TC)
C
C
C
C
*****
```

C-6

```

C ** TC  R*$ Critical fuel surface (Wall)
temperature (C)
C
C
-----
-----
C
*****
***** ! Default is Gambill/Weatherhead
IF(ITYPE.LT.0 .OR. ITYPE.GT.3) ITYPE = 1

C ** Bernath (Critical Heat Flux)
IF(ITYPE .EQ. 0) THEN
  PM = P/1.E6
  TC = 571.76 - 273.16 + 60.* ALOG(PM)
  >      - 80.8*(PM/(PM+0.0931)) -
U*0.8202
  QC = H_TUR*(TC - T)
  RETURN
ENDIF

C ** Gambill/Weatherhead (Critical Heat Flux)
IF(ITYPE .EQ. 1) THEN
  QC = QC_GW(P, T, H_TUR)
  TC = T + QC/H_TUR
  RETURN
ENDIF

C ** Costa (Flow excursion instability)
C ** Note: "Official" correlations are in
KJ/s/m2. Here I use W/m2
C ** Thus, the factor of 1.E3 when fluxes are

```

C

```

multiplied or divided
IF(ITYPE .EQ. 2) THEN
  TSAT = D_TSAT(P)
  QC = SQRT(U)*(TSAT - T)/12.8E-6
  TC = T + QC/H_TUR
  RETURN
ENDIF

C ** Bergles and Rosenhow (Incipient boiling)
IF(ITYPE .EQ. 3) THEN
  QC = QC_BR(P, T, H_TUR)
  TC = T + QC/H_TUR
  RETURN
ENDIF

QC = 1.E-32
WRITE(*,'(" Selected correlation out of
range'')
>      '' SET CHFTYP    0 - Bernath''
>      ''                      1 - Gambill
Weatherhead''
>      ''                      2 - Costa''
>      ''                      3 - Bergles &
Rosenhow'')')

RETURN
END

C
C
C
REAL FUNCTION QC_GW(P, T, H)
C
C
-----
C
*****

```

```
*****
C
-----
C
C ** Gambill/Weatherhead critical heat flux
correlation
C ** Note: "Official" correlations are in
KJ/s/m2. Here I use W/m2
C ** Thus, the factor of 1.E3 when fluxes are
multiplied or divided
C
C ** INPUT
C      P      Coolant bulk pressure (Pa)
C      T      Coolant bulk temperature (C)
C      H      Film heat transfer coeff
(Pethukov) (W/m2/K)
C ** OUTPUT
C      QC_GW Crit heat flux (W/m2)
C
C
```

C

C

C

DATA G/9.81/, CONV/1.E-3/,
> ITERMX/20/

C

C

C

C

C
C ** D2O Properties
C HFG Latent heat of vaporization
(J/kg)
C RHOL Liquid density at bulk coolant
pressure (kg/m3)
C RHOG Vapor density at bulk coolant
pressure (kg/m3)
C CP Specific heat (J/kg/K)
C SIG Surface tension (N/m)
C TSAT Coolant saturation temp @bulk
pressure (C)
C

TSAT = D_TSAT(P)
HFG = D_HFG(TSAT)
RHOL = D_RHOL(TSAT)
RHOV = D_RHOV(TSAT)
CP = D_CP(TSAT)
SIG = D_SIG(TSAT)

C

c ** Correlation is only valid for subcooled flow

c

```
IF(T .GE. TSAT) THEN
  QC_GW = -1.E32
  RETURN
ENDIF
```

c ! pool crit heat flux in W/m2

Q_POOL =

0.18*HFG*RHOV*(SIG*G*(RHOL-RHOV)/RHOV**2)**0.25
> *(1. + (RHOL/RHOV)**0.75 *
CP*(TSAT-T)/9.8/HFG)

```

C ! initial guess use crit t_wall without
Weatherhead correction
    TW = TSAT + 84.96 - 0.1313*(TSAT + 273.16)
    QC = Q_POOL + H*(TW - T)
    ITER = 0

10 CONTINUE
    ITER = ITER + 1
    TW = (47.7 -
0.127*TSAT)*ABS(QC/3.1546E6)**0.25 + TSAT
    OLD_QC = QC
    QC = Q_POOL + H*(TW - T)

    IF(ITER.GT.ITERMX) THEN
        WRITE(*,'(" !! ERROR in crit heat flux
iteration'))'
        QC_GW = -1.E32
        RETURN
    ENDIF

    IF(ABS((QC - OLD_QC)/QC).GT.CONV) GOTO 10

    QC_GW = QC

    RETURN
END

C
C
C
REAL FUNCTION QC_BR(P, T, H)
C
C
-----
```

C9

```

C
-----
C
C ** Bergles & Rohsenow Incipient boiling heat
flux correlation
C ** Note: "Official" correlations are in
KJ/s/m2. Here I use W/m2
C ** Thus, the factor of 1.E3 when fluxes are
multiplied or divided
C
C ** INPUT
C          P      Coolant bulk pressure (Pa)
C          T      Coolant bulk temperature (C)
C          H      Film heat transfer coeff
(Pethukov) (W/m2/K)
C ** OUTPUT
C          QC_BR Incipient boiling heat flux
(W/m2)
C
C
*****
C
*****
C
*****
C
DATA CONV/1.E3/, ITERMX/20/
C
C
*****
C
*****
```

```

*****
C
-----
C
C ** D2O Properties
C      TSAT Coolant saturation temp @bulk
pressure (C)
C
C
C
-----
C
*****
*****  

*****  

C
-----
C
C
TSAT = D_TSAT(P)
C   C1   =
3.1546*0.98*15.6*((P/6.8948E3)**1.156)
C   C2   = (2.3/(P/6.8948E3)**0.0234)
      C1   = CONV * 0.9 * 1.7978E-6 *
(P)**1.156
      C2   = 2.8285/(P)**0.0234
TC   = TSAT + 10.
TW   = TC

NITER = 0
10 NITER = NITER + 1
      QC = C1*(1.8*ABS(TW - TSAT))**C2
      TC = T + QC/H
      F   = TW - TC
      DFDT = 1. - C1*C2/H * 1.8 *
(1.8*ABS(TW - TSAT))**(C2 - 1.)

```

```

DT = -F/DFDT


IF(NITER .LT. ITERMX) THEN
  IF(ABS(DT) .GT. 0.01) THEN
    TW = TW + DT
    IF(TW .LT. TSAT) TW = TSAT + 1.
    GOTO 10
  ENDIF
ELSE
  WRITE(*,'(" Incipient boiling iteration
not converged")')
  QC = -1.E32
ENDIF

QC_BR = QC
RETURN
END

```

Appendix D

STANDARD MACRO DEFINITION FILE (ANS.CMD) FOR THE ADVANCED NEUTRON SOURCE DYNAMIC MODEL



APPENDIX D. STANDARD MACRO DEFINITION FILE (ANS.CMD) FOR ANSDM

```

set hvdpm = .true.
! Delete after rebuilding 11/8/94 (fixed anomalous OCR worth value)
set kwocr(0) = -4
! Delete after rebuild 4/8/94 (Updated reactivity coefficients)
set kracor=7.4
set kfcor=1.25e-3
set kgfcor=0.5e-3
set kkcon=1

set hvdpm = .false.
set fbpit = .true.    ! Flyback trace suspension
set cjvlg = .false.  ! No check Jacob validity
set ecstg = .false.  ! Relative error based on MAX value
set nxstg = .false.  ! Eval deriv before communication intvl
set weditg = .false. ! No scheduled events info
set wesitg = .false. ! No error control info
set nstp = 10000
set tntg = 1.e32     ! Jacobian nonlinearity threshold
* grdcpl=.false.    ! No grids on plots

! Restoring binary data ...
! RESTOR

proc settim
  s hvdpm=.t
  ! Actions for standard time intervals set
  s hvdpm=.f.
  s tstop = 604800.          ! 1 week
  s cint = 1.e-3
  action var'=0.02, val=0.01,'loc'=cint
  action var'=0.2, val=0.1,'loc'=cint
  action var'=2., val=1.,'loc'=cint
  action var'=20., val=10.,'loc'=cint
  action var'=200., val=100.,'loc'=cint
  action var'=1800., val=1800.,'loc'=cint
  action var'=86400., val=21600.,'loc'=cint
end
settim

proc locat
  s hvdpm=.t
  ! Actions for LOCA time intervals set
  s hvdpm=.f.
  s tstop = 604800.
  s cint = 1.e-3
  action var'=0.02, val=0.01,'loc'=cint
  action var'=2., val=0.1,'loc'=cint
  action var'=20., val=1.,'loc'=cint
  action var'=200., val=10.,'loc'=cint
  action var'=1800., val=1800.,'loc'=cint
  action var'=86400., val=21600.,'loc'=cint
end

proc relapt
  s hvdpm=.t
  ! Actions for RELAP time intervals set
  s hvdpm=.f.
  s cint = 2.e-4

  s tstop= 25.
  action var'=0.01, val=0.001,'loc'=cint
  action var'=0.05, val=0.033,'loc'=cint
  action var'=0.974, val=0.026,'loc'=cint
  action var'=1.0, val=0.33,'loc'=cint
  action var'=4.96, val=0.04,'loc'=cint
  action var'=5.0, val=1.65,'loc'=cint
  action var'=24.8, val=0.2,'loc'=cint
end

proc ppoff
  s hvdpm=.t
  ! Plant protection system off.
  s hvdpm=.f.
  set oseisc = .f., oseosc = .f.
end

proc ppson
  s hvdpm=.t
  ! Plant protection system on
  s hvdpm=.f.
  set oseisc = .t., oseosc = .t.
end

proc norcon
  ! Rods will not move
  set kvrlcr = 0., kvfrcr = 0.
end

proc roff
  set hvdpm=.t
  ! External reactivity set to zero
  set hvdpm=.f.
  set karra(1) = 0., 0., 0., 0., 0., 0., 0.
  set karra(11) = 0., 1.e10, 1.e10, 1.e10, 1.e10, 1.e10, 1.e10
end

proc ron
  set hvdpm=.t
  ! External reactivity set to 1.0 dol step (in 1 ms)
  set hvdpm=.f.
  set karra(1) = 0., 1.0, 1.0
  set karra(11) = 0., 0.001, 1.e10
end

proc p2off
  set hvdpm=.t
  ! Secondary pump speed will trip to nat circ. at t=0
  ! Control pars KKTCON and KTNCON have been changed.
  set hvdpm=.f.
  action var'=0, val=0.0,'loc'=kn0con
  s kkcon = 0.
  s kncon = 5.
end

proc pony
  set hvdpm=.t
  ! Pump speed will be set to pony speed (10%) at time 0
  set hvdpm=.f.
  action var'=0, val=0.1,'loc'=zn0mcn
  p2off
end

proc natcir
  set hvdpm=.t
  ! Ptry pump speed will be set to 0 (natural circulation) at time 0

```

```

set hvdpms=.f.
action 'var'=0.,'val'=0.,'loc'=zn0mcnp
p2off
end

proced nopers
set hvdpms=.t.
! pressure dynamics turned off
set hvdpms=.f.
s offgac = .t.
s kpmmc = 0.
s kwiccs = 0.
end

proced no2con
set hvdpms = .t.
! No secondary control
set hvdpms=.f.
s kk2con = 0.
s kb2con = 0.
s kb2con = 0.
s kw2con = 1.
s kw2con = 1.
end

proced ionhs
set hvdpms=.t.
! Loss of normal heat sink. Main heat exchangers disabled at time 0
set hvdpms=.f.
action 'var'=0.,'val'=0.,'loc'=kaemhx ! No heat tr area in MHX
action 'var'=0.,'val'=0.,'loc'=kofsc0 ! No heat sink @ tower
end

proced lotow
set hvdpms=.t.
! Loss of normal heat sink. Tower cooling disabled at time 0
set hvdpms=.f.
action 'var'=0.,'val'=0.,'loc'=kofsc0 ! No heat sink @ tower
end

proced mhxooff
set hvdpms=.t.
! Eliminate main heat exchanger (set HT area=0) at time 0
set hvdpms=.f.
action 'var'=0.,'val'=0.,'loc'=zaemhx ! MHX off
end

proced ehxoff
set hvdpms=.t.
! Eliminate Emergency heat exchanger (set HT area=0) at time 0
set hvdpms=.f.
action 'var'=0.,'val'=0.,'loc'=zaeсхx ! MHX off
end

proced isolat
set hvdpms=.t.
! Containment will be isolated at time 0
! Loss: MHX, all pool cooling, makeup flow
set hvdpms=.f.
action 'var'=0.,'val'=1.E-3,'loc'=wmrpo
off
action 'var'=0.,'val'=1.E-3,'loc'=wpcho
cooling off
I RX pool cooling
I Pipe chase

action 'var'=0.,'val'=1.E-3,'loc'=whtopo ! HX pool cooling off
mhxooff
MHX off
s kofmuc = .true.
Turn makeup off
end

proced nohw
set hvdpms=.t.
! Disable pipe heat losses to pools
set hvdpms=.f.
s khwhir = 0,
s khwmhl = 0,
s khwhnl = 0,
s khwpcl = 0,
s khwmcl = 0,
s khwcrl = 0.
end

proced hw
set hvdpms=.t.
! Set heat losses to pool hot transfer coeff
set hvdpms=.f.
s khwhir = 250. ! W/m2/K
s khwmhl = 250.
s khwhnl = 250.
s khwpcl = 250.
s khwmcl = 250.
s khwcrl = 250.
end

proced loahs
set hvdpms=.t.
! Loss of all heat sinks. Containment will be isolated at time 0
! Cooling tower basin will still be available
set hvdpms=.f.
action 'var'=0.,'val'=0.,'loc'=kofsc0
action 'var'=0.,'val'=0.,'loc'=wmrpo
action 'var'=0.,'val'=0.,'loc'=wpcho
action 'var'=0.,'val'=0.,'loc'=whtopo
I s kwiccs = 0.
I s kwmccon = 0.
s kofmuc=.true. ! Turn off makeup injection
end

proced loop2
set hvdpms=.t.
! Approximate 1 loop operation with 2 HX will be set at time 0
set hvdpms=.f.
action 'var'=0.,'val'=1.65,'loc'=kcvml
action 'var'=0.,'val'=0.164,'loc'=kfamhl
action 'var'=0.,'val'=14.36,'loc'=ksamhl

action 'var'=0.,'val'=1.65,'loc'=kcvmd
action 'var'=0.,'val'=0.164,'loc'=kfamcl
action 'var'=0.,'val'=14.36,'loc'=ksamcl

action 'var'=0.,'val'=1.32,'loc'=kcvcrl
action 'var'=0.,'val'=0.164,'loc'=kfacr
action 'var'=0.,'val'=11.49,'loc'=ksacrl

action 'var'=0.,'val'=3000.,'loc'=kaemhx
action 'var'=0.,'val'=20.,'loc'=kcvmhlp
I

action 'var'=0.,'val'=1.25,'loc'=kfamhp
action 'var'=0.,'val'=116.75,'loc'=ksamhp
action 'var'=0.,'val'=20.,'loc'=kcvshp
action 'var'=0.,'val'=1.15,'loc'=kfashp

action 'var'=0.,'val'=250.,'loc'=kaeehx
action 'var'=0.,'val'=12.,'loc'=kcvtl
action 'var'=0.,'val'=0.59,'loc'=kdatl
action 'var'=0.,'val'=12.,'loc'=kcvtcl
action 'var'=0.,'val'=0.59,'loc'=kdatl
action 'var'=0.,'val'=3000.,'loc'=kcvtcb
action 'var'=0.,'val'=150.,'loc'=kcvtch

set knpisc = 0.05 ! Pony speed (10%/2) after scram
end

proced scram
set hvdpms=.t.
! Reactor scram request set at 1 ms. Delay still active
set hvdpms=.f.
s ksisc = 0.001
end

proced nolim
set hvdpms=.t.
! Control rod limits of servo motion removed
set hvdpms=.f.
s koscir = 1.e10
end

proced nopol
s kipol = 0. ! No initial Iodine
s kbpol = 0. ! No initial Xenon
end

proced digcon
set hvdpms = .t.
! Digital control active. DTFCON, DTPCON, DTTCON set sampling
time
set hvdpms = .f.
set odcon = .true.
set DTFCON = 0.01 ! Power (flux) control sampling time
set DTPCON = 0.5 ! Pressure control sampling time
set DTTCCN = 0.5 ! Temperature control sampling time
d dticon, dpccon, dttcon
end

PROCED U95
set hvdpms=.t.
I 95/95 Uncertainties (FAX DGM-JML 4/23/92 11:00)
I Not valid if CHF limit is at inlet or outlet (use kugcor=1.631)
set hvdpms=.f.

s khcor = 1.074 ! Hot streak uncertainty
s kugcor = 1.554 ! Hot spot unc. for CHF
s kuccor = 1.305 ! Hot spot unc. for FE
END

```

```

PROCED U99
  set hvdpmt.t
  ! 99.999 Uncertainties (FAX DGM-JML 4/23/92 11:00)
  ! Not valid if CHF limit is at inlet or outlet (use kugcor=1.995)
  set hvdpmt.f.

  s khucor = 1.113          ! Hot streak uncertainty
  s kugcor = 1.899          ! Hot spot unc. for CHF
  s kuccor = 1.502          ! Hot spot unc. for FE ???
END

PROCED UMULT
  set hvdpmt.t
  ! Multiplicative uncertainties (Old HFIR type) used JM-L pg 72
  set hvdpmt.f.

  s khucor = 1.259          ! Hot streak uncertainty
  s kugcor = 1.46             ! Hot spot unc. for CHF
  s kuccor = 1.46             ! Hot spot unc. for FE ???
END

PROCED UPS2
  set hvdpmt.t
  ! SQRT(SUM_var) uncertainties (PS2 type) used JM-L pg 72.  II Grade
  set hvdpmt.f.

  s khucor = 1.144          ! Hot streak uncertainty
  s kugcor = 1.52             ! Hot spot unc. for CHF
  s kuccor = 1.32             ! Hot spot unc. for FE ???
END

PROCED UNO
  set hvdpmt.t
  ! No uncertainties used.
  set hvdpmt.f.

  s khucor = 1.0              ! Hot streak uncertainty
  s kugcor = 1.0              ! Hot spot unc. for CHF
  s kuccor = 1.0              ! Hot spot unc. for FE ???
END

PROCED II1BOC
  set hvdpmt.t
  ! Beginning of cycle detailed power shapes (27 nodes)
  set hvdpmt.f.

  ! Lower core BOC. II
  s kpcor = 1.319
  s knnhcl = 27
  s kpshcl = 1.215, 1.368, 1.407, 1.391, 1.386, 1.382, 1.396, ...
  1.374, 1.373, 1.364, 1.372, 1.373, 1.382, 1.386, ...
  1.386,..., 1.394, 1.397, 1.401, 1.402, 1.350, 1.289, 1.279,..., 1.219, 1.164, 1.114, 1.036, 0.926, 0.793
  0.614,..., 0.597, 0.579, 0.563, 0.547, 0.525, 0.500,

```

```

  0.487,..., 0.487, 0.450, 0.453, 0.426, 0.380, 0.306
END

PROCED II1EOC
  set hvdpmt.t
  ! End of cycle detailed power shapes (27 nodes)
  set hvdpmt.f.

  ! Lower core EOC. II
  s kpcor = 0.992
  s knnhcl = 27
  s kpshcl = 0.463, 0.502, 0.529, 0.520, 0.500, 0.463, 0.474, ...
  0.441, 0.427, 0.412, 0.406, 0.399, 0.399,..., 0.306,..., 0.403, 0.407, 0.415, 0.423, 0.416, 0.412, 0.423,..., 0.431, 0.431, 0.452, 0.482, 0.552, 0.627
  0.423,..., 0.431,..., 0.452,..., 0.552,..., 0.627

  ! Upper core EOC. II
  s kpcor = 1.258
  s knnhcl = 27
  s kpshcl = 0.877, 1.119, 1.281, 1.419, 1.426, 1.434, 1.430,..., 1.555, 1.418, 1.281, 1.288, 1.286, 1.283, 1.270,..., 1.264, 1.252, 1.241, 1.220, 1.199, 1.165, 1.140,..., 1.117, 1.120, 1.143, 1.147, 1.207, 1.339
END

PROCED II1
  set hvdpmt.t
  ! I1 Grade. BOC power shape for lower core, EOC for upper.
  set hvdpmt.f.

  ! Upper core EOC. II
  s kpcor = 1.258 ! EOC
  s knnhcl = 27
  s kpshcl = 50°
  s kpshcl = 0.877, 1.119, 1.281, 1.419, 1.426, 1.434, 1.430,..., 1.555, 1.418, 1.281, 1.288, 1.286, 1.283, 1.270,..., 1.264, 1.252, 1.241, 1.220, 1.199, 1.165, 1.140,..., 1.117, 1.120, 1.143, 1.147, 1.207, 1.339

  ! Lower core BOC. II
  s kpcor = 1.319 ! BOC
  s knnhcl = 27
  s kpshcl = 50°
  s kpshcl = 1.215, 1.368, 1.407, 1.391, 1.386, 1.382, 1.396,..., 1.374, 1.373, 1.364, 1.372, 1.373, 1.382, 1.386,..., 1.394, 1.397, 1.401, 1.402, 1.350, 1.289, 1.279,..., 1.219, 1.164, 1.114, 1.038, 0.926, 0.793
END

PROCED I3
  set hvdpmt.t
  ! I3 Grade. EOC
  set hvdpmt.f.

  ! Upper core EOC. I3
  s kpcor = 1.53176 ! EOC. To agree with RELAP MW/m2
  s knnhcl = 23
  s kpshcl = 50°

```

D-5

```

  s kpshcl = 50°, 1.362, 1.614, 1.568, 1.517, 1.517
  ! Lower core EOC. I3
  s kpcor = 0.96658 ! EOC. To agree with RELAP MW/m2
  s knnhcl = 5
  s kpshcl = 50°, 1.109, 1.034, 0.963, 0.901, 0.864
END

PROCED M1
  set hvdpmt.t
  ! M1 core power distributions.
  set hvdpmt.f.

  s kpcor = 1.417174
  s knnhcl = 35
  s kpshcl = ...
  .143363E+01, .144865E+01, .150308E+01, .171713E+01, .168831E+01,..., .152097E+01, .142640E+01, .140383E+01, .145661E+01, .141338E+01,..., .155626E+01, .158702E+01, .155000E+01, .159092E+01, .158396E+01,..., .161399E+01, .158341E+01, .162455E+01, .158724E+01, .162086E+01,..., .157873E+01, .144618E+01, .140452E+01, .152382E+01, .148467E+01,..., .121482E+01, .122511E+01, .124843E+01, .122010E+01, .128158E+01,..., .105417E+01, .988099E+00, .102623E+01, .953267E+00, .966873E+00
  ! Lower core BOC. M1
  s kpcor = 1.46936
  s knnhcl = 35
  s kpshcl = ...
  .198589E+01, .199856E+01, .182327E+01, .197119E+01, .195061E+01,..., .192850E+01, .191143E+01, .191442E+01, .193013E+01, .195302E+01,..., .199781E+01, .184419E+01, .189851E+01, .179257E+01, .183855E+01,..., .188571E+01, .195197E+01, .163039E+01, .167774E+01, .151195E+01,..., .154781E+01, .138763E+01, .140760E+01, .120002E+01, .119880E+01,..., .980262E+00, .963091E+00, .936532E+00, .778620E+00, .737582E+00,..., .705839E+00, .529689E+00, .499613E+00, .579974E+00, .535297E+00
  END

PROCED L7
  set hvdpmt.t
  ! L7 Grade. BOC power shape for lower core, EOC for upper.
  set hvdpmt.f.

  ! Upper core EOC. L7
  s kpcor = 1.49 ! EOC Upper Core relative power
  s knnhcl = 23
  s kpshcl = 50°.

```

```

s kpshcu = ...
  1.20, 1.32, 1.38, 1.45, 1.51, ...
  1.51, 1.54, 1.58, 1.64, 1.67, ...
  1.70, 1.75, 1.75, 1.74, 1.71, ...
  1.68, 1.57, 1.49, 1.43, 1.26, ...
  1.16, 1.06, 1.03

! Lower core BOC, L7
s kplicor = 1.70 ! BOC Lower Core relative power
s knnhcl = 23
s kpshcl = 50*0.
s kpshcl = ...
  2.31, 2.29, 2.28, 2.27, 2.25, ...
  2.24, 2.21, 2.18, 2.12, 2.08, ...
  2.02, 1.88, 1.80, 1.71, 1.61, ...
  1.30, 1.29, 1.12, 1.04, 0.89, ...
  0.80, 0.73, 0.67
END

PROCED L7NS
set hvdpmt=t
! 5-node L7 Grade, BOC power shape for lower core, EOC for upper.
set hvdpmt=f.

! Upper core EOC, L7
s kpucor = 1.49 ! EOC Upper Core relative power
s knnhcu = 5
s kpshcu = 50*0.
s kpshcu = 1.384, 1.588, 1.720, 1.543, 1.133

! Lower core BOC, L7
s kplicor = 1.70 ! BOC Lower Core relative power
s knnhcl = 5
s kpshcl = 50*0.
s kpshcl = 2.28, 2.160, 1.804, 1.21, 0.773
END

PROCED GRODS
set hvdpmt=t
! Gravity outer rods, Inner rods disabled
set hvdpmt=f.

  s oseisc = .false.
  s kficon = 0.
  s kasocr = 0.81, 0.81, 0.81
END

PROCED HERODS
set hvdpmt=t
! He3 shutdown system, 3 dollars worth
set hvdpmt=f.
s kwrocr = 0., 0., -3., -3.
s kwrocr(22) = -1.e10, -0.4, 1., 1.e10
s kasocr = 1.e3, 1.e3, 1.e3
END

PROCED HRODS
set hvdpmt=t
! Hydraulic outer rods (20m, 1inch, P0=2MPa, Tvalv=50ms)
set hvdpmt=f.
s kasocr = 5, 25, 25, 0, 0.01, 10
END

```

```

PROCED P335
set hvdpmt=t
! 335 MWt, 3.0 MPa @fuel_element_inlet, 25 m/s, PS2 uncert, M1
grade
set hvdpmt=f.
s kjncor=335.e6, kj0cor=335.e6, kpcccs=3.15e6, kwcccs=2144
UPS2
M1
END

PROCED RELAP1
set hvdpmt=t
! RELAP5 Benchmark Parameters for 10/01 (See RELAP2 10/02)
set hvdpmt=f.

  t3                                     ! L3 Grading used
In RELAP
  s khcor = 1.14                         ! Hot streak uncertainty
  SORT(SUM **2)
  s khshcu = 1.305, 1.217, 1.204, 1.243, 1.312 ! Hot spot unc. upper
  core
  s khshcl = 1.394, 1.406, 1.374, 1.352, 1.243 ! Hot spot unc. lower
  core
  s kjncor = 350.e6                       ! Core fission power (W)
  s kj0cor = 350.e6                       ! Core fission power (W)
  s kficon = 0.0692247
  s kdecor = 0.002489
  s kercon = 2.0e-6
  s kerres = 2.0e-6
  s kwcccs = 2462.9
  s kkccil = 1.09024                      !For RELAP benchmark only, WRONG #####
  s kkcfid = 0,                            !For RELAP benchmark only, WRONG #####
  s kbwcor = 0.1664636
  s kfifac = 0.025
  s kfifhl = 1.2                           ! Match RELAP P @ accumulator
  s kfpcf = 1.                             ! Match RELAP P @
  accumulator
  s kfmcil = 1.                           ! Match RELAP P @
  accumulator
  s kfclr = 1.                            ! Match RELAP P @
  accumulator
  s kfifid = 0.5                          ! Match RELAP P @ accumulator
  s kz0gac = 3.7
END

PROCED RELAP2
set hvdpmt=t
! RELAP5 Benchmark Parameters for 10/02 (Close to CDR config)
set hvdpmt=f.

L7                                     ! L7 Grading
used in RELAP
U95                                     ! 95% uncertainties
  s kjncor = 330.e6                       ! Core nominal fission power
(W)
  s kj0cor = 343.86e6                     ! Initial power (W) (104.2%)
  s kdecor = 0.002489
  ! s kercon = 0.14e-6
  ! s kerres = 0.14e-6
  ! s kwcccs = 1994.2
  ! s kbwcor = 0.0065
  ! s kfifac = 15.0
  ! s kfmcil = 5.
  ! Extra dP to fudge chk v/v

```

```

s kgfjac = 3.02                         ! Initial gas fraction 0.1:5 m3
s kvagac = 15.                           ! 3 accumulators 5 m3 each
s kgcjac = 1.0                           ! Isothermal accumulator
s kz0gac = 3.7
s kpicon = 0.15e6
s kdcor = kfcor
s kbcor = kbcor
END

```

```

PROCED RELAP3
set hvdpmt=t
! RELAP5 Benchmark Parameters for 10/02 (200 MW (104.2%), 17.0
m/s)
set hvdpmt=f.

```

```

RELAP2
  s kjncor = 200.e6                      ! Core nominal fission power
(W)
  s kj0cor = 208.e6                       ! Initial power (W) (104.2%)
  s kwcccs = 1338.
  s kpcccs = 2.39e6
  s kfifac = 0.85
  s kficon = 1.042
END

```

```

PROCED RELAP4
set hvdpmt=t
! RELAP5 Benchmark Parameters for 10/02 (Almost CDR config)
set hvdpmt=f.

```

```

RELAP2
  s kgfjac = 3.069                        ! Initial gas fraction 0.52:7.52 m3
  s kvagac = 22.56                         ! 3 accumulators 7.52 m3 each
  s kercon = -1.13                         ! Force agreement with RELAP P-out
  s kfifac = 0.85
  s kficon = 1.042
END

```

```

proc RNC
set hvdpmt=t
! RELAP5 Benchmark - Nat Circ (10/02)
set hvdpmt=f.

```

```

! This is a strange (very) station blackout. If I understand
! the RELAP data correctly, At time=0 they isolate the secondary
! (10 seconds for 0 sec. flow) and trip the makeup pump (5 s)
! but the primary pumps keep running until scram
! also, secondary side natural circulation is disabled (they
! assume total isolation
! The letdown valve is also assumed fully open

```

```

! This macro does not really do all that, it makes some approx
action 'clear'

```

```

prepar 'clear', t, jcpg, thclo, tvesl, tveso, twhlf, zqwhci(23)
prepar pipcl, zipopr, nmcp, usacho
prepar wmcpo, wsbx, wmuuso, wgac
prepar csrhci(23), cfrci(23), zqshci(23), csrhci(23)

RELAP3          I 200 MW, 17 m/s core

s ktrmcnp = 3.   I Try to match RELAP cooldown
s knpisc = -0.15 I Trip MC Pumps to nat circ on LP scram
!      set speed to -15% to fudge RELAP's friction

s kdkcon = 0.    I Keep letdown valve at current position

s kofmusp = .t. I Trip makeup pump at t=0
s ktlimus = 2.   I Makeup coasts down as e-(t/2)

s kdkcon = 0.    I Trip secondary coolant pump
s ktcon = 2.     I Trip secondary pump as e-(t/2)
!      ans cut down all heat transfer at time 10 s
action 'var'=10., 'val'=0., 'loc'=kaemhx
! s kdthtl = 0.1
! s kdhtci = -0.1  to limit nat circ in sec (isolation)

s tstop = 400
s cint = 1.
s maxt = 1.
action 'var'= 6., 'val'=0.1,'loc'=cint
action 'var'=10.,'val'=1.0,'loc'=cint
action 'var'=50.,'val'=10.,'loc'=cint

I Modified 6/21/93 to fudge old pump trip with scram function
s knpmcp = -0.15
s kptmcnp = 0.91 I To trip at approx same time as core

start

print t, jcpg, thclo, tvesl, tveso, twhlf, zqwhci(23)
print t, pipcl, zipopr, nmcp, usacho
print t, wmcpo, wsbx, wmuuso, wgac
print t, csrhci(23), cfrci(23)
print t, zqwhci(23), zqshci(23), csrhci(23)

end

PROCED R80C
set hvdpm=.t.
I RELAPS Benchmark - 80 CENT REACTIVITY STEP
set hvdpm=.f.

action 'clear'
RELAP4

I set kbcor = 0.006 I CSAR values, use new one : 0.0078
I set kgcor = 0.5e-3 I CSAR values, use new one : 1.5 ms
set kartra(1) = 0., 0.8, 0.8
set kartra(11) = 0., 0.001, 1.e10

prepar 'clear', t, fcnnfx, jachlo, jcpg, msrhci, mcrhci
prepar xcfr, rcr, xcr, rocr
prepar pcoro, phclo, tcoro, thclo, thcuo
prepar tshclo, uhclo, phclo, zqshci(23), csrhci(23)

```

```

s tstop=0.5,cint=0.002
start

print t, fcnnfx, jachlo, jcpg, msrhci, mcrhci
print t, xcfr, rcr, xcr, rocr
print t, pcoro, phclo, tcoro, thclo, thcuo
print t, shclo, uhclo, phclo, zqshci(23), csrhci(23)

END

PROCED RTD
set hvdpm=.t.
I RELAPS Benchmark - Cl 14inch DEG break 1.1 s (11/92)
set hvdpm=.f.

action 'clear'
RELAP4

s kbdcll = kdecil  I 14 inches ID
s kgbcil = .true.  I DEG break (doubles flow)
s ktcll = 1.1
prepar 'clear', t, pipcl, zipopr, wvseso, wcllc, pdet
prepar qstff, zqshci(23), csrhci(23), msrhci, mcrhci
prepar pveso, phro, pmhlo, pgac, pmcpl, pmcpo

s tstop=1,cint=0.01
start

print t, pipcl, zipopr, wvseso, wcllc, pdet
print t, qstff, zqshci(23), csrhci(23), msrhci, mcrhci
print t, pveso, phro, pmhlo, pgac, pmcpl, pmcpo

END

PROCED R2B
set hvdpm=.t.
I RELAPS 10/91Benchmark. 2 inch, sharp edge, 250 ms CPBT break
set hvdpm=.f.

RELAP1

s knpisc = 1.e10           I Do not trip main pumps
s ktmsic = 1.e10           I Do not trip secondary pumps
s kpifsc = 0.86             I Scram @86% nominal press (1.41MPa)
s kpccol = 0.211e6          I RELAPS pool pressure
s kbdcll = 0.0506          I 2 Inch
s ktcll = 0.25              I 250 ms time constant
s kwfcos = 30                I letdown flow
s kgcgac = 1.4               I Adiabatic accumulator
s kticon = 100              I To close letdown vlv in ~1.5 s

prepar 'clear', t
prepar wvseso, wvsesi, whiro, wdsi, wmuuso, wgac
prepar jcpg, fcnnfx, fdhfx
prepar qshuf, qchuf, qshhf, ztwhci(5), zqwhci(5)
prepar qshf, qchf, qshff, ztwhci(5), zqwhci(5)
prepar zipopr, pgac

action 'clear'
relapt
action 'var'=5., 'val'= 68., 'loc'=wmuuso I standby pump

```

D-7

```

s cint = 0.0002
start

print t, wvseso, wvsesi, whiro, wdsi, wmuuso, wgac
print t, jcpg, fcnnfx, fdhfx
print t, qshuf, qchuf, qshhf, ztwhci(5), zqwhci(5)
print t, qshf, qchf, qshff, ztwhci(5), zqwhci(5)
print t, zipopr, pgac
END

PROCED SSPAR
I Parameter's fudged to agree with Grady's SS code
I Set by hand the inlet/outlet pressure (KPCCCS=2.77E6)
s kfcor = 0.0315 I Heat flux area accounts for unheated
s kercor=-0.96 I Filonenko friction -4%
END

proc CSARF
s hvdpm=.t.
I CSAR Full power initial conditions
I (includes measurement+operational uncer)
s hvdpm=.f.
I restor 'csar'

s kjocor = 343.992e6 I Set initial power at 104.24%
s kwcccs = 2122.56 I Set initial flow at 99%
s kfcon = 1.0424 I Control power at 104.24%
s ktcon = 45.6 I Control temperature at 101.41%
I Parameters to agree with s.s. code conservative assumptions
s kpcccs = 2.77e6 I To set P-inlet = 2.85
s kpcon = 1.433e6 I To set P_outlet = 1.61
s kercor = -0.96 I To fudge core dp = 1.25
s kfcor = 0.0315 I To agree on IB limit 329MWth 95/95
end

proc CSARL
s hvdpm=.t.
I CSAR Low power initial conditions
I (includes measurement+operational uncer)
s hvdpm=.f.
I restor 'csar'

s kjocor = 33.e3 I Set initial power at 1.e-4
s kwcccs = 2122.56 I Set initial flow at 99%
s ktcon = 45.6 I Control temperature at 101.41%
s kwcccs = 100. I Initial guess for secondary flow
s kfcon = 1.0424 I Control power at 104.24%
I Parameters to agree with s.s. code conservative assumptions
s kpcccs = 2.77e6 I To set P-inlet = 2.85
s kpcon = 1.433e6 I To set P_outlet = 1.61
s kercor = -0.96 I To fudge core dp = 1.25
s kfcor = 0.0315 I To agree on IB limit 329MWth 95/95
end

proc Newrod
s hvdpm=.t.
I Rod worths set to 1 dollar per 50 mm, max -10 dol
s hvdpm=.f.
I Assume 50 mm to insert 1 dol conservative to account for 1-rod failure
I actual 3-rod number vary from 22.3 mm to 36.3 mm
I Assumed criticality at centerline, and linear worth around it
I Not the real total worth, only differential worth relevant

```

```

  s kwnic(1)=20.0,10.0,0,-10.0,-10.0
  s kwnic(5)=-10.0,-10.0,-10.0,-10.0,-10.0
  s kwnic(10)=-10.0,-10.0,-10.0,-10.0,-10.0
  s kwnic(15)=-1.0,-0.5,-0.0,0.5,1.0
  s kwnic(20)= 2.0, 3.0, 4.0, 5.0, 6.0
  s kwnic(25)= 7.0, 8.0, 9.0, 10., 11.

  s lo0der=0.
  end


PROCED h
  set hidpmx,true.

!The following procedures have been defined :
PPSOFF - Plant protection system OFF
RON   - Reactivity ramp ON. Set KARRTA to after
ROFF  - Reactivity ramp OFF
PONY  - Transition to pony motor flow
NATCR - Transition to natural circulation
P2OFF - Trip secondary pumps
NOPRES - Eliminate pressure dynamics
LOAHS - Loss of all heat sinks. Main+Emergency HXs disabled
LONHHS - Loss of normal heat sink. Main HX disabled
LOTOW - Loss of towns heat sink
ISOLAT - Isolate containment. Close all valves
MHXOFF - Isolate main heat exchanger (HT area=0)
EHXOFF - Isolate emergency heat exchanger (HT area=0)
LOOP2 - One loop operation 2 HX
Power Shapes: HBCC, HEOC, H, M1
Uncertainties: U93, UMULT, UPS2, UNO
set hidpmx !.
END

```

Appendix E

NOMINAL ADVANCED NEUTRON SOURCE OPERATING CONDITIONS PREDICTED BY THE ADVANCED NEUTRON SOURCE DYNAMIC MODEL



APPENDIX E. NOMINAL ANS OPERATING CONDITIONS PREDICTED BY ANSDM

----- ANS DYNAMIC MODEL

--- Current Simulation Time : 0.00000E+00 PAGE :
1 / 9

----- Powers (MW)

Nominal Fission : 330.00 Total
Fission : 330.00
Active_Core (Fuel+Cool): 303.01
Active_Core_Fuel : 303.01
Reflector : 15.325 Bypass
: 11.661

----- Mass Flow Rates (Kg/s)

Nominal_Total @Pump	:	2144.0	
Actual_Total @Pump	:	2144.0	
Hot_Channel upper core	:	1543.1	Active Core
	:	1790.2	
Main_HX Secondary	:	2800.0	Hot_Channel
lower core	:	1547.4	
Letdown	:	14.600	Makeup
	:	14.600	
Bypass	:	353.76	Reflector
	:	200.00	

----- Pressures (MPa)

Core Inlet : 3.1991 Core Outlet
: 1.8103
Pressurizer : 1.5864
Letdown/Makup : 1.6904
Main_HX Primary Inlet : 1.6904 Main_HX
Primary Outlet : 1.6702
Pump Inlet : 1.6513 Pump Outlet
: 3.2931
Main HX Secondary Inlet: 0.26209
:

----- Coolant Temperatures (C)

Core Inlet : 44.443
 : 85.645
Hot_Chan Up Core Outlet: 120.84
Core Outlet: 131.14
Bypass Outlet : 52.438
Outlet : 67.597
Main_HX Primary Inlet : 79.623
Primary Outlet : 43.959
Main HX Scdry inlet : 29.930
Scdry outlet : 56.900
Pump Inlet : 43.810
 : 44.484
Pressurizer : 39.687
Temp : 0.00000E+00

Core Outlet
Hot_Chan Lo
Reflector
Main_HX
Main HX
Pump Outlet
Makeup Flow

----- ANS DYNAMIC MODEL

--- Current Simulation Time : 0.00000E+00 PAGE :
2 / 9

----- Fuel Temperatures (C)

Avg_Channel Avg_Temp : 205.38 Avg_Channel
@Wall : 121.58
Hot_Chan Up Core Avg_T : 266.99 Hot_Chan Lo
Core Avg_T : 296.37

----- Fuel Heat Fluxes (MW/m2)

Avg_Channel Actual : 5.7096 Avg_Channel
Critical : 33.257

Hot_Chan Up Core Actual: 9.1369
Core Crit. : 28.004
Hot_Chan Lo Core Actual: 10.425
Core Crit. : 26.277

Hot_Chan Up
Hot_Chan Lo

----- Critical Heat Flux Ratios

Min CFR Upper Core :0.10000E+11 Min CFR
Lower Core :0.10000E+11
Location CFR Upper Core:0.10000E+11 Location
CFR Lower Core:0.10000E+11
Min CSR Upper Core :0.10000E+11 Min CSR
Lower Core :0.10000E+11
Min IBLR Upper Core :0.55555E+34 Min IBLR
Lower Core :0.55555E+34

----- Vessel Inlet (Cold Leg) Coolant

Saturation_Temp (C) : 235.88 Density
(Kg/m3) : 1098.5
Prandtl Number : 4.9956 Reynolds
Number :0.63264E+07
Velocity (m/s) : 21.021 Friction
Coefficient :0.14280E-01

----- Avg_Ch Outlet Coolant Properties

Saturation_Temp (C) : 204.63 Density
(Kg/m3) : 1074.1
Prandtl Number : 2.6009 Reynolds
Number :0.17278E+06
Velocity (m/s) : 25.015 Friction
Coefficient :0.17397E-01

----- Hot_Ch Upper Core Outlet Coolant Prop

Saturation_Temp (C) : 204.61 Density
(Kg/m3) : 1045.9
Prandtl Number : 1.7970 Reynolds
Number :0.21415E+06
Velocity (m/s) : 24.603 Friction
Coefficient :0.16672E-01

```
Saturation_Temp (C) : 236.39 Density
(Kg/m3) : 1094.5 Reynolds
Prandtl Number : 4.2820
Number :0.14760E+07
Velocity (m/s) : 8.9238 Friction
Coefficient :0.11788E-01

---- Current Simulation Time : 0.00000E+00 PAGE :
3 / 9

----- Vessel Outlet (Hot Leg) Coolant
-----
```

```
Saturation_Temp (C) : 208.28 Density
(Kg/m3) : 1077.9 Reynolds
Prandtl Number : 2.7904
Number :0.11541E+08
Velocity (m/s) : 8.0660 Friction
Coefficient :0.82541E-02

----- Hot_Ch Lower Outlet Coolant Prop
-----
```

```
Saturation_Temp (C) : 204.61 Density
(Kg/m3) : 1036.4 Reynolds
Prandtl Number : 1.6483
Number :0.23505E+06
Velocity (m/s) : 24.897 Friction
Coefficient :0.16372E-01

----- Main Heat Exchanger Primary Side Outlet
-----
```

```
Saturation_Temp (C) : 203.55 Density
(Kg/m3) : 1098.7 Reynolds
Prandtl Number : 5.0455
Number : 18767.
Velocity (m/s) :0.78054 Friction
Coefficient :0.31526E-01

----- Bypass Outlet Coolant Properties
-----
```

=====

----- Main Heat Exchanger Secondary Side
Outlet

Saturation_Temp (C) : 176.81 Density
(Kg/m3) : 1092.1
Prandtl Number : 3.9569 Reynolds
Number : 55312.
Velocity (m/s) : 2.3308 Friction
Coefficient : 0.29564E-01

=====

----- ANS DYNAMIC MODEL

---- Current Simulation Time : 0.00000E+00 PAGE :
4 / 9

=====

----- Core Properties

Active Fuel Volume (m3):0.33700E-01 Act Coolant
Volume (m3):0.33700E-01
Active Fuel Height (m) :0.52700 Fuel
Thickness (m) :0.12700E-02
Fuel Density (Kg/m3) : 3870.0 Heat
Capacity (J/Kg/K) :0.52700
Ef Ht Trf Coef (W/K/m2):0.00000E+00 Core Flow
Area (m2) :0.66630E-01
Ch. Equiv. Diameter (m):0.25400E-02 Hot_Ch Eq.
Diameter (m):0.00000E+00
Loc Press Loss (v_head): 1.0000 Channel
Flow Length (m):0.52700
Bypass Volume (m3) :0.33700E-01 Bypass Flow
Area (m2) :0.36220E-01

L-7

----- Core Neutronics

Core react coeff \$/dr/r: 7.4000 Bypass reac
coef \$/dr/r: 9.1000
Fuel Doppler coef (\$/K):-1.2500E-02 Reflec reac
coef \$/dr/r: 29.000
Eff Beta (delayed neut):0.77400E-02 Eff
Generation Time (s):0.50000E-03

---- Delayed Neutron Fractions
0.42748E-03 0.14662E-02 0.13113E-02 0.33248E-02
0.77441E-03 0.27879E-03

---- Delayed Neutron Time Constants (s-1)
0.14300E-01 0.30500E-01 0.11100 0.29600
1.1300 3.0000

----- Decay Heat Model

Fraction in Bypass (%): 26.360 Fraction in
Reflector %: 8.6400

Time (s) = 0.10000E-09 Decay Heat (%) = 5.7544
Time (s) = 1.0000 Decay Heat (%) = 5.7544
Time (s) = 10.000 Decay Heat (%) = 4.7863

Time (s) = 100.00 Decay Heat (%) = 3.2359
Time (s) = 1000.0 Decay Heat (%) = 1.7783
Time (s) = 10000. Decay Heat (%) = 0.87096
Time (s) = 0.10000E+06 Decay Heat (%) = 0.30200
Time (s) = 0.10000E+07 Decay Heat (%) = 0.10233

----- ANS DYNAMIC MODEL

--- Current Simulation Time : 0.00000E+00 PAGE :
5 / 9

----- Hot Leg Riser

Volume (m3) : 3.7582 Flow Area
(m2) : 0.24660
Height (m) : 12.500 Flow Length
(m) : 15.240
Equiv. Diameter (m) : 0.56040 Loc Press
Loss (v_head): 1.0000

----- Hot Leg (Horizontal Run)

Volume (m3) : 3.7631 Flow Area
(m2) : 0.24660
Height (m) : 0.00000E+00 Flow Length
(m) : 15.260
Equiv. Diameter (m) : 0.56040 Loc Press
Loss (v_head): 1.0000

----- Main Heat Exchanger Primary Side

Volume (m3) : 29.100 Flow Area
(m2) : 2.5000
Height (m) : 0.00000E+00 Flow Length
(m) : 40.000
Equiv. Diameter (m) : 0.16000E-01 Loc Press
Loss (v_head): 1.0000
Eff. H.T. coeff (W/K) : 0.17412E+08 Film H.T.
coeff(W/m2/K): 6792.9

----- Main Heat Exchanger Secondary Side

Volume (m3) : 29.100 Flow Area
(m2) : 1.1000
Height (m) : 0.00000E+00 Flow Length
(m) : 12.200
Equiv. Diameter (m) : 0.12700E-01 Loc Press

Loss (v_head): 1.0000
Total foul. res (m²K/W): 0.26000E-03 Film H.T.
coeff(W/m²/K): 10493.

----- Cold Leg (Horizontal Run)

Volume (m³) : 4.7086 Flow Area
(m²) : 0.24966
Height (m) : 0.00000E+00 Flow Length
(m) : 18.860
Equiv. Diameter (m) : 0.32550 Loc Press
Loss (v_head): 1.0000

----- Cold Leg Riser

Volume (m³) : 2.5116 Flow Area
(m²) : 0.24966
Height (m) : -13.570 Flow Length
(m) : 10.060
Equiv. Diameter (m) : 0.32550 Loc Press
Loss (v_head): 1.0000

----- ANS DYNAMIC MODEL

----- Current Simulation Time : 0.00000E+00 PAGE :
6 / 9

----- Pools

RX Pool volume (m³) : 500.00 Heat load
(MW) : 0.12345E+07
Pipe Chase Pool Vol(m³): 300.00 Heat load
(MW) : 0.16143E+07
HX Pool volume (m³) : 1200.0 Heat load
(MW) : 0.21258E+07

----- Main Circulation Pumps

Flow (Kg/s) : 2144.0 Power (MW)
 : 0.00000E+00
Head (MPa) : 1.6418 Coastdown
Tim Const (s): 2.0000

--- Normalized Pump Head vs Flow
Normalized Pump Power vs Head
Flow = 0.00000E+00 Head = 1.1200 Head =
-1.0000 Power = 1.1200
Flow = 0.20000 Head = 1.1500 Head =
0.00000E+00 Power = 1.1200
Flow = 0.40000 Head = 1.1600 Head =
0.84000 Power = 1.0400
Flow = 0.60000 Head = 1.1400 Head =
1.0000 Power = 1.0000
Flow = 0.80000 Head = 1.0900 Head =
1.1000 Power = 0.96000
Flow = 1.0000 Head = 1.0000 Head =
1.1800 Power = 0.93000
Flow = 1.2000 Head = 0.89000 Head =
1.2300 Power = 0.87000
Flow = 1.4000 Head = 0.74000 Head =
1.2600 Power = 0.80000
Flow = 1.6000 Head = 0.59000 Head =
1.2800 Power = 0.72000
Flow = 1.8000 Head = 0.44000 Head =
1.3000 Power = 0.00000E+00
Flow = 2.4000 Head = 0.00000E+00 Head =
2.0000 Power = 0.00000E+00

----- ANS DYNAMIC MODEL

--- Current Simulation Time : 0.00000E+00 PAGE :
7 / 9

----- Reflector Region

Volume (m3) : 15.000 Flow Area
(m2) : 1.0000
Height (m) : 0.00000E+00 Flow Length
(m) : 0.00000E+00
Equiv. Diameter (m) : 0.15000 Loc Press
Loss (v_head) : 0.00000E+00

----- Gas Accumulator

Total Volume (m3) : 21.000 Gas Volume
Fraction : 0.74000E-01
Level (m) : 4.6300 Mass Flow
Rate (Kg/s) : 0.00000E+00
Outlet Pipe Length (m) : 5.0000 Outl Pipe
Flow Area(m2) : 0.24966
Equiv. Diameter (m) : 0.32550 Loc Press
Loss (v_head) : 1.0000
Effective L/A : 10.000
:

----- Leak Effective Diameters (m)

@Core Inlet : 0.00000E+00 @Core
Outlet : 0.00000E+00

=====
----- ANS DYNAMIC MODEL

--- Current Simulation Time : 0.00000E+00 PAGE :
8 / 9

=====
----- Friction Pressure Drops (MPa)

Across Active Core : 1.2130 Across Main
HX : 0.26379E-01
Across Main Pump : 1.6418 Across
Emergency HX : 0.18623E-01

=====
----- Inner Control Rod Scram System

Flux/Flow Setpoint (%) : 115.00 Flux rate
Setpoint : 0.20000
Flow Setpoint (%) : 8.0000 Pressure

Setpoint (MPa): 1.3584
Inlet Temp Setpoint (C): 55.000 Scram Delay
Time (s) : 0.30000E-01
Init C_Rod Position (m): -0.15000 Max. C_Rod
Insertion(m): 0.60000

--- Control Rod Acceleration vs Position (z = 0
==> Top of Active Core)
z = 0.00 m, accel = 58.860 m/s
z = 0.15 m, accel = 9.8100 m/s
z = 1.00 m, accel = 9.8100 m/s


--- Control Rod Worth vs Position (z = 0 ==> Top
of Active Core)

z = 0.00 m,	worth = 9.1900	\$
z = 0.10 m,	worth = 9.1900	\$
z = 0.20 m,	worth = 7.7300	\$
z = 0.30 m,	worth = 6.6100	\$
z = 0.40 m,	worth = 3.6600	\$
z = 0.60 m,	worth = 2.1400	\$
z = 1.00 m,	worth = -0.18000	\$
z = 0.00 m,	worth = -1.5000	\$
z = 0.00 m,	worth = -4.9500	\$
z = -0.25 m,	worth = -8.1500	\$
z = -0.02 m,	worth = -11.580	\$
z = -3.11 m,	worth = -14.030	\$
z = -4.00 m,	worth = -15.210	\$
z = -4.60 m,	worth = -15.210	\$
z = -6.58 m,	worth = -1.0000	\$
z = -8.53 m,	worth = -.60000	\$
z = -8.53 m,	worth = -.50000	\$
z = -1.00 m,	worth = -.40000	\$
z = -0.80 m,	worth = -.30000	\$
z = -0.60 m,	worth = -.20000	\$
z = -0.50 m,	worth = -.10000	\$

```
-----  
----- Detector Time delays (s)  
-----  
-----  
Neutron flux :0.25000E-01 Pressure  
:0.30000E-01  
Temperature : 2.0000 Flow  
:0.25000
```

Appendix F

LIST OF ALL ADVANCED NEUTRON SOURCE DYNAMIC MODEL VARIABLES AND THEIR NOMINAL VALUES



APPENDIX F. LIST OF ALL ANSDM MODEL VARIABLES AND THEIR NOMINAL VALUES

State Variables	Derivatives	HIPCI 187933.000	ZDDIPR-608.837000
Initial Conditions			
DNDET 0.	DDNDET 0.	ZIHIPR 187933.000	ZDDLHL-0.43457300
ZDNDET 0.		HLHLO 333542.000	
ECPG 0.	JCPG 3.3000E+08	ZIHLHL 333542.000	ZDDPCL-0.00150202
ZIECPG 0.		HMCPI 185153.000	
FCNFX 1.00000000	DNCNT-2.7057E-07	ZIHPCL 185153.000	
ZINCNT 1.00000000		HMHLO 333929.000	ZDDMHL-0.25996300
FDET 1.00000000	DFDET 0.	ZIHMHL 333929.000	
ZIFDET 1.00000000		HMHXO 185769.000	ZDDMHP 25.1418000
HACHO 357191.000	ZDDACC 150.256000	ZIHMHP 185769.000	
ZIHACC 357191.000		HMRPO 148200.000	ZDDMRP 0.00579261
HBYPO 220896.000	ZDBYP 14.2309000	ZIHMRP 148200.000	
ZIHBYP 220896.000		HPCHO 148200.000	ZDDPCH 0.01194720
HCLRI 187863.000	ZDDMCL-0.40749600	ZIHPCH 148200.000	
ZIHMCL 187863.000		HREFO 283287.000	ZDDREF-1.5506E-05
HCLRO 187783.000	ZDDCLR-0.50672300	ZIHREF 283287.000	
ZIHCLR 187783.000		HSHLX 239306.000	ZDDSHP 61.9591000
HCORO 357191.000	ZDDOPR 0.	ZIHSHP 239306.000	
ZIHOPR 357191.000		HTCLO 127200.000	ZDDTCL 0.
HCTBO 127200.000	ZDDCTB-1.2745E-06	ZIHTCL 127200.000	
ZIHCTB 127200.000		HTHLO 239306.000	ZDDTHL 0.
HEHXO 185213.000	ZDDEPP 23.7187000	ZIHTHL 239306.000	
ZIHEPP 185213.000		HVESI 187783.000	ZDDIFD 0.
HESHL 155891.000	ZDDESP 0.00466240	ZIHIFD 187783.000	
ZIHESP 155891.000		IPOI 1.00000000	ZDIPOI-1.1830E-12
HHCLO 545474.000	ZDDHLC 2699.44000	ZIIPOI 1.00000000	
ZIHHLC 545474.000		MMCS 0.	ZDMMCS 0.06835940
HHCUO 502162.000	ZDDHUC 238.107000	ZIMMCS 0.	
ZIHHUC 502162.000		PCIL 3.4001E+06	ZDPCIL 0.
HHLRO 334207.000	ZDDHLR-0.46265300	ZIPCIL 3.4001E+06	
ZIHHLR 334207.000		PCOL 1.8414E+06	ZDPCOL 0.
HHXPO 148200.000	ZDDHXP-0.71966300	ZIPCOL 1.8414E+06	
ZIHHXP 148200.000		PDET 1.6980E+06	DPDET 8125.00000
		ZIPDET 1.6980E+06	
		PPOI 1.00000000	ZDPPOI 8.2641E-15

ZIPPOI 1.00000000		ZDPMCP 1.00000000	ZDDMCP-0.15059900
SPOI 1.00000000	ZDSPOI 3.1914E-13	Z99838 1.00000000	
ZISPOI 1.00000000		ZFFGAC 0.	ZDFGAC 0.
TACF 205.381000	ZDTACF 0.10249800	Z99842 0.	
ZITACF 205.381000		ZFFMUS 0.	ZDFMUS 6.8100E-05
TCDET 44.4839000	DTCDET-3.2425E-05	Z99841 0.	
ZTCDET 44.4839000		ZNMCP 1.00000000	ZDNMCP 0.
THDET 80.0271000	DTHDET 0.	ZINMCP 1.00000000	
ZTHDET 80.0271000		ZPCCNT(1) 59.7868000	ZDCCNT(1)-2.4470E-08
THLF 296.366000	ZDTHLF-0.76695700	ZICCNT(1) 59.7868000	
ZITHLF 296.366000		ZPCCNT(2) 96.1457000	ZDCCNT(2) 3.9262E-09
THUF 266.990000	ZDTHUF 0.17215000	ZICCNT(2) 96.1457000	
ZITHUF 266.990000		ZPCCNT(3) 23.6277000	ZDCCNT(3) 9.6127E-08
VICR 0.	ZDVICR 0.	ZICCNT(3) 23.6277000	
ZIVICR 0.		ZPCCNT(4) 22.4650000	ZDCCNT(4) 8.6625E-08
VLGAC 19.4460000	ZDVGAC 0.	ZICCNT(4) 22.4650000	
ZIVGAC 19.4460000		ZPCCNT(5) 1.37064000	ZDCCNT(5)-9.7346E-09
VOCR 0.	ZDVOCR 0.	ZICCNT(5) 1.37064000	
ZIVOOCR 0.		ZPCCNT(6) 0.18585900	ZDCCNT(6) 1.6823E-08
WDET 2144.00000	DWDET-0.27441400	ZICCNT(6) 0.18585900	
ZIWDET 2144.00000		ZPCCNT(7) 2853.59000	ZDCCNT(7)-7.4055E-09
WGAC 0.	DWGAC 0.	ZICCNT(7) 2853.59000	
ZIWGAC 0.		ZPIGAC 0.	ZDPGAC-0.15578700
WMCPI 2144.00000	DWMCPI 0.	Z99843 0.	
ZIWMCP 2144.00000		ZWLCL 0.	DWCILC 0.
WTHLO 2800.00000	ZDWSCC-0.01437500	Z99827 0.	
ZIWSCC 2800.00000		ZWLCOL 0.	DWCOLC 0.
XICR-0.15000000	ZDXICR 0.	Z99844 0.	
ZIXICR-0.15000000		ZXLCON 0.	ZDXCON-0.01537870
XOCR-0.80000000	ZDXOCR 0.	ZIXCON 0.	
ZIXOCR-0.80000000		Algebraic Variables	
XPOI 1.00000000	ZDXPOI 2.4224E-11		
ZIXPOI 1.00000000		Common Block /ZZCOMU	
Z99840 104.000000	Z99839-0.24569400	ABORT F	CFRACF 5.82486000
ZWECCS 104.000000		CFRACH(50)	5.5555E+33
Z99873 1.00000000	Z99872-8.6018E-04	CFRHCL(50)	5.5555E+33 CFRHCU(50) 5.5555E+33
ZINCON 1.00000000			

CFRHLF 2.52038000		CPHXPO 4241.22000	CPIFDI 4225.21000
CFRHUF 3.03794000	CIRACF 3.74292000	CPIPCI 4225.16000	CPMCPI 4226.25000
CIRACH(50) 5.5555E+33		CPLHLO 4176.34000	CPMHLO 4176.24000
CIRHCL(50) 5.5555E+33	CIRHCU(50) 5.5555E+33	CPMCPO 4225.15000	CPMRPO 4241.22000
CIRHLF 1.48056000		CPMHLL 4176.34000	CPSCLX 4249.96000
CIRHUF 1.82997000	CKACHO 0.63335200	CPMHXI 4176.34000	CPTCLO 4249.96000
CKBYPO 0.61842000		CPMHXO 4226.01000	CSRACF 5.82486000
CKCLRI 0.61279700	CKCLRO 0.61278300	CPPCHO 4241.22000	CSRACH(50) 5.5555E+33
CKCORO 0.63335200		CPREFO 4190.84000	CSRHCL(50) 5.5555E+33
CKCTBO 0.60042600	CKEHXO 0.61231200	CPSHLX 4205.75000	CSRHLF 2.52038000
CKESCL 0.60500800		CPTCLO 4249.96000	CSRHCU(50) 5.5555E+33
CKESHL 0.60660700	CKGAC 0.60903800	CPVESI 4225.21000	CSRHUF 3.03794000
CKHCLO 0.63328400		CPVESO 4176.04000	DCFCON 14
CKHCUO 0.63524500	CKHLRI 0.63179500	CSRACH(50) 5.5555E+33	DCPCON 15
CKHLRO 0.63175700		CSRHCL(50) 5.5555E+33	DCTCON 16
CKHXPO 0.60500800	CKIFDI 0.61278300	CSRHLF 2.52038000	DWACHI 0.
CKIPCI 0.61281000		CSRHUF 3.03794000	DWACHO 0.
CKLHLO 0.63170500	CKMCPI 0.61230100	DCPCON 15	DWBYPPI 0.
CKMCPO 0.61281300		DCTCON 16	DWBYPO 0.
CKMHLL 0.63170500	CKMHLO 0.63173500	DWACHO 0.	DWCLRO 0.
CKMHXI 0.63170500		DWBYPO 0.	DWCORO 0.
CKMHXO 0.61241500	CKMRPO 0.60500800	DWCLRI 0.	DWCTBI 0.
CKPCHO 0.60500800		DWCORO 0.	DWEHXO 0.
CKREFO 0.62689800	CKSCLX 0.60042600	DWCTBI 0.	DWESCL 0.
CKSHLX 0.62121300		DWEHXO 0.	DWHCLI 0.
CKTCLO 0.60042600	CKTHLO 0.62121300	DWESCL 0.	DWHCLO 0.
CKVESI 0.61278300		DWHCLI 0.	DWHCUI 0.
CKVESO 0.63179500	CPACHO 4170.62000	DWHCLO 0.	DWHLRI 0.
CPBYPO 4212.49000		DWHCUO 0.	DWHLRO 0.
CPCLRI 4225.18000	CPCLRO 4225.21000	DWHLRI 0.	DWHXPI 0.
CPCORO 4170.62000		DWHLRO 0.	DWHXPO 0.
CPCTBO 4249.96000	CPEHXO 4226.23000	DWHXPI 0.	DWIFDI 0.
CPESCL 4241.22000		DWHXPO 0.	DWLHLO 0.
CPESHL 4238.06000	CPGAC 4233.12000	DWIPCI 0.	DWMCLI 0.
CPHCLO 4159.44000		DWLHLO 0.	DWMHLA 0.
CPHCUO 4155.70000	CPHLRI 4176.04000	DWMHLA 0.	DWMHLL 0.
CPHLRO 4176.17000			

DWMHLO 0.		FVESO 0.00825411	HACF 159027.000
DWMHXI 0.		HACHI 187933.000	
DWMRPI 0.		HBYPI 187933.000	HCILC 187783.000
DWMRPO 0.		HCOLC 334703.000	
DWPCHI 0.		HCTBI 239306.000	HESCL 148200.000
DWPCHO 0.		HFFF 175180.000	
DWREFO 0.		HGAC 168000.000	HHCLI 187933.000
DWSCLX 0.		HHCUI 187933.000	
DWTCLI 0.		HHLF 178292.000	HHLRI 334703.000
DWTCLLO 0.		HHUF 173687.000	
DWVESI 0.		HHXPI 127200.000	HIFDI 187783.000
DWVESO 0.		HLDSI 333542.000	
ESCICR 10	ERROR F	HMCLI 187951.000	HMCPO 187951.000
ESCOCR 11	FACHO 0.01739690	HMHLA 333542.000	
FBYPO 0.01178800	FCLRO 0.01314680	HMHLL 333542.000	HMHXI 333542.000
FCLRI 0.01314660	FCTBO 0.00983458	HMRPI 127200.000	
FCON 1.00000000	FESCL 0.17391900	HMUPI 188065.000	HMUSO 188065.000
FCORO 0.01003460	FHCLO 0.01637210	HPCHI 127200.000	
FDHFX 0.05754400	FHLRO 0.01171570	HREFI 206661.000	HSCLX 127200.000
FEHXO 0.02117430	FIPCI 0.01089630	HTCLI 127200.000	
FESHL 0.03622640	FMCPO 0.01314650	HVESO 334703.000	HWACHO 160305.000
FGAC 941280.000	FMHXI 0.01300280	HWBYP0 37763.6000	
FHCUO 0.01667240	FHLRO 0.01171580	HWCLRI 32469.1000	HWCLRO 32462.8000
FHLRI 0.01171540	FIPCI 0.01089630	HWCORO 60310.8000	
FHXPO 0.02986810	FMCPO 0.01314650	HWCTBO 76.9571000	HWEHXO 9714.27000
FIFDI 0.01314680	FMHXI 0.01300280	HWESCL 5.77484000	
FLHLO 0.01300280	FPCHO 0.03211220	HWESHL 674.460000	HWGAC 8.16541000
FMCPI 0.01315080	FSCLX 0.01281110	HWHCLO 180987.000	
FMHLL 0.01300430	FTHLO 0.01180590	HWHCUO 175784.000	HWHLRI 40872.1000
FMHLO 0.01171580		HWHLRO 40843.6000	
FMHXO 0.03152640		HWHXPO 55.5940000	HWIFDI 32462.8000
FMRPO 0.03454270		HWIPCI 49886.3000	
FREFO 0.02122350		HWLHLO 42465.8000	HWMCPI 32257.0000
FSCISC 2		HWMCPO 32477.0000	
FSHLX 0.02956350		HWMHLL 42179.0000	HWMHLO 40827.6000
FTCLO 0.01228130		HWMHXI 42465.8000	
FVESI 0.01428000		HWMHXO 5234.57000	HWMRPO 36.1514000

HWPCHO 44.5846000		JWESP 0.	JWHLC 0.
HWREFO 1194.22000	HWSCLX 13376.8000	JWHLR-1.0650E+06	
HWSHLX 16484.4000		JWHUC 0.	JWHXP 0.
HWTCL0 6233.71000	HWTHLO 8153.35000	JWIFD 0.	
HWVESI 90958.5000		JWIPIR 0.	JWLHL-830245.000
HWVESO 34308.2000	I 8	JWMCL-190740.000	JWMHP-164595.000
IACH 2		JWMHL-597261.000	
IDVANS 1	IHCL 24	JWMRP 0.	
IHCU 24		JWOPR 0.	JWPCH 0.
ISCISC 7	JACF 3.0301E+08	JWPCL-130555.000	
JACH 3.0301E+08		JWREF 0.	JWSHP 0.
JACHO 3.0301E+08	JBYP 1.1661E+07	JWTCL 0.	
JBYPO 1.1661E+07		JWTHL 0.	KAACHI 0.14800000
JCLRI 0.	JCLRO 0.	KAACHO 0.06663000	
JCORO 0.		KABYPI 0.14800000	KABYPO 0.03622000
JCTBO-3.1387E+08	JEHXO-799926.000	KACLRI 0.24966000	
JESHL 799926.000		KACLRO 0.24966000	KACORO 0.13326000
JHCL 5.5324E+08	JHCLO 5.5330E+08	KACTBI 1.38000000	
JHCU 4.8490E+08		KACTBO 100.000000	KAEEHX 500.000000
JHCUO 4.8489E+08	JHLF 5.5324E+08	KAEHXO 1.06000000	KAESCL 100.000000
JHLRO 0.		KAEMHX 8750.00000	
JHUF 4.8490E+08	JHXPO 1.1746E+06	KAESHL 1.00000000	
JIFDI 0.		KAGAC 0.24966000	KAHCLI 0.14800000
JIPCI 0.	JLHLO 0.	KAHCLO 0.05996700	
JMCP 6.0000E+06		KAHCUI 0.14800000	KAHCUO 0.05996700
JMCPI 0.	JMHLO 0.	KAHLRI 0.24660000	
JMHXO-3.1584E+08		KAHLRO 0.24660000	KAHKPI 10.0000000
JMRPO 1.2377E+06	JPCHO 1.6182E+06	KAHXPO 10.0000000	
JPOI 3.1101E+08		KAIFDI 0.24966000	KAIPCI 0.14800000
JREFC 1.5325E+07	JREFO 1.5325E+07	KALHLO 0.24966000	
JSHLX 3.1584E+08		KAMCLA 0.24966000	KAMCLI 0.24966000
JTCLO 0.	JTHDET 3.1357E+08	KAMCPI 0.24966000	
JTHLO 0.		KAMCPO 0.24966000	KAMHLL 0.24966000
JVESI 0.	JWACC 0.	KAMHLO 0.24660000	
JWBYP 0.		KAMHXI 0.24966000	KAMHXO 2.50000000
JWCLR-172745.000	JWCTB 0.	KAMRPI 10.0000000	
JWEPP-79515.3000		KAMRPO 10.0000000	KAPCHI 10.0000000

KAPCHO 10.0000000		KBCCOR 4.2748E-04	0.00146622
KAREFI 1.000000000		0.00131134	
KARTRA(20) 1.0000E+10	KAREFO 1.000000000	0.00332481	7.7441E-04
Z99997 0.	0.	2.7879E-04	
0.	0.	1.5695E-04	KBCCNT 4.2748E-04
0.	0.	0.00146622	
0.	0.	0.00131134	0.00332481
0.	0.	7.7441E-04	
0.	0.	2.7879E-04	1.5695E-04
1.0000E+10	Z99998 0.	KBDCIL 0.	
1.0000E+10		KBDCOL 0.	KBECOR 0.00774000
1.0000E+10	1.0000E+10	KBECNT 0.00774000	
1.0000E+10		KBEPOI 0.00800000	KBFCOR 0.02140000
1.0000E+10	1.0000E+10	KBFCPG 0.02140000	
1.0000E+10		KBWCOR 0.16500000	KCACHI 0.16000000
1.0000E+10	1.0000E+10	KCACHO 1.00000000	
KASCLX 0.65670000		KCBYPI 0.16000000	KCBYPO 1.00000000
KASHLX 1.10000000	KASICR 58.8600000	KCCANS 0.00100000	
9.81000000		KCCLRI 1.00000000	KCCLRO 1.00000000
9.81000000	0.	KCCORO 1.00000000	
0.15000000		KCCTBI 1.00000000	KCCTBO 0.
1.00000000	Z99991 58.8600000	KCEHXO 1.00000000	
9.81000000		KCESCL 1.00000000	KCESHL 1.00000000
9.81000000	Z99992 0.	KCFACC 0.	
0.15000000		KCFACF 0.	KCFBYP 0.
1.00000000	KASOCR 58.8600000	KCFCLR 0.	
9.81000000		KCFCOR 0.	KCFHCL 0.
9.81000000	0.	KCFHCU 0.	
1.00000000		KCFACH 0.	KCFCTB 0.
10.0000000	Z99987 58.8600000	KCFEPP 0.	
9.81000000		KCFESP 0.	KCFHLC 0.
9.81000000	Z99988 0.	KCFHLF 0.	
1.00000000		KCFHLR 0.	KCFHUC 0.
10.0000000	KATCLI 100.000000	KCFHUF 0.	
KATCLO 1.38000000		KCFHXP 0.	KCFIFD 0.
KATHLO 1.38000000	KAVESI 0.09285000	KCFIPR 0.	
KAVESO 0.24660000		KCFLHL 0.	KCFMCL 0.

KCFMHL 0.			KCTHLO 1.00000000	KCTHLR 0.01000000
KCFMHP 0.			KCTHUC 0.01000000	KCTHXP 0.01000000
KCFOPR 0.			KCTHUF 1.00000000	
KCFPCH 0.			KCTIFD 0.01000000	KCTLHL 0.01000000
KCFREF 0.			KCTIPR 0.01000000	KCTMHP 0.01000000
KCFSHP 0.			KCTMCL 0.01000000	KCTMHP 0.01000000
KCFTHL 0.			KCTMHL 0.01000000	KCTMHP 0.01000000
KCHCLI 0.16000000	KCHCLO 1.00000000		KCTMRP 0.01000000	KCTPCH 0.01000000
KCHCUI 0.16000000	KCHEHX 1.0000E-04		KCTOPR 0.01000000	
KCHCUO 1.00000000			KCTPCL 0.01000000	KCTSHP 0.01000000
KCHLRI 1.00000000	KCHMHX 1.0000E-04		KCTREF 0.01000000	
KCHLRO 1.00000000			KCTTCL 0.01000000	KCVACC 0.03370000
KCHXPI 0.	KCIFDI 0.30000000		KCTTHL 0.01000000	
KCHXPO 0.			KCVCLR 2.51158000	KCVHCL 0.03370000
KCIPCI 0.16000000	KCMCLI 1.00000000		KCVCOR 0.03370000	
KCLHLO 1.00000000	KCMHLO 1.00000000		KCVHCU 0.03370000	KCVACH 0.03370000
KCMCPI 1.00000000			KCVBYP 0.03370000	
KCMCPO 1.00000000	KCMRPI 0.		KCVCTB 4500.00000	
KCMHXI 1.00000000	KCPACF 620.000000		KCVEPP 12.0000000	KCVESI 0.23000000
KCMHXO 1.00000000	KCPCHO 0.		KCVESO 1.00000000	
KCMRPO 0.	KCPHCL 620.000000		KCVESP 12.0000000	KCVHLC 0.03370000
KCPACF 620.000000	KCPHCU 620.000000		KCVHLR 3.75818000	
KCPCHO 0.	KCPHUF 620.000000		KCVHUC 0.03370000	KCVHXP 1200.00000
KCPHCL 620.000000	KCPHUF 620.000000		KCVIFD 0.37140000	
KCPHUF 620.000000	KCREFI 0.		KCVIPR 0.48000000	KCVLHL 3.04336000
KCREFI 0.	KCSCLX 1.00000000		KCVMCL 4.70859000	KCVMHP 29.1000000
KCSCLX 1.00000000	KCSHLX 1.00000000		KCVMHL 3.76312000	
KCTACF 1.00000000	KCTACC 0.01000000		KCVMRP 500.000000	KCVPCH 300.000000
KCTBYP 0.01000000	KCTCLI 0.		KCVOPR 0.48000000	
KCTCLO 1.00000000	KCTCTB 0.01000000		KCVPCL 3.46029000	KCVREF 15.0000000
KCTCLR 0.01000000	KCTEPP 0.01000000		KCVTCL 24.0000000	KCVSHP 29.1000000
KCTEPP 0.01000000	KCTHLC 0.01000000		KCVTHL 24.0000000	KDACHO 0.00254000
KCTESP 0.01000000	KCTHLF 1.00000000		KDBCOR 0.26360000	KDBCPG 0.26360000
			KDCCC 0.00228600	KDBYPO 0.09500000
			KDCLRI 0.32550000	KDCLRO 0.32550000

KDCORO 0.12000000				
KDCTBO 100.000000	KDEACC 0.00254000		2.00000000	3.00000000
KDEBYP 0.09500000			4.00000000	
KDECIL 0.32550000	KDECLR 0.32550000		5.00000000	6.00000000
KDECOL 0.56040000			KDHCL 0.00228600	
KDECOR 0.00254000	KDEACH 0.00254000		KDHCLR-13.5700000	KDHCTB 0.
KDECTB 100.000000	KDEESP 0.05080000		KDHCUO 0.00228600	KDHEPP 0.
KDEEPP 0.05080000	KDEHCU 0.00228600		KDHEHX 2792.00000	
KDEGAC 0.32550000	KDEHUC 0.00228600		KDHESP 3.00000000	
KDEHCL 0.00228600	KDEIFD 0.19850000		KDHGAC 5.00000000	KDHHL 0.52700000
KDEHLC 0.00228600	KDELHL 0.32550000		KDHHLR 12.5000000	KDHXP 0.
KDEHLR 0.56040000	KDEMCL 0.32550000		KDHHUC 0.52700000	
KDEHXO 0.05080000	KDEMCP 0.32550000		KDHIFD 0.	
KDEHXP 1.00000000	KDEMHP 0.01600000		KDHIPR 3.00000000	KDHLHL-1.83000000
KDEIPR 0.12000000	KDEMUS 0.32550000		KDHLR 0.56040000	KDHMCL 0.
KDELDS 0.32550000	KDEPCL 0.32550000		KDHMHL 0.	
KDEMHP 1.00000000	KDEPCH 1.00000000		KDHMH 0.	KDHMHX 2391.00000
KDEOPR 0.12000000	KDEREF 0.15000000		KDHOPR 4.25300000	KDHPCH 0.
KDEPCH 1.00000000	KDESCC 0.45720000		KDHPC 4.88000000	KDHSHP 0.
KDEREF 0.15000000	KDESHL 0.05080000		KDHREF 0.	
KDESCC 0.45720000	KDESHP 0.01270000		KDHCTL-3.00000000	
KDESHL 0.05080000	KDETCL 0.76000000		KDHHTHL 3.00000000	KDHXPO 1.00000000
KDESHP 0.01270000	KDETHL 0.76000000		KDIFDI 0.32550000	KDLHLO 0.32550000
KDETHL 0.76000000	KDEVES 0.56040000		KDIPCI 0.12000000	KDMCPO 0.32550000
KDEVES 0.56040000	KDHACC 0.52700000		KDMCLA 0.32550000	KDMCPI 0.32550000
KDHACC 0.52700000	KDHCDH(16) 6.00000000	299981-1.24000000	KDMHLL 0.32550000	KDMHLO 0.56040000
KDHCDH(16) 6.00000000	-1.24000000		KDMHLO 0.56040000	KDMHXI 0.32550000
-1.24000000	-1.32000000	-1.49000000	KDMHXO 0.01600000	KDMRPO 1.00000000
-1.32000000	-1.75000000		KDMRPO 1.00000000	KDPCHO 1.00000000
-1.75000000	-2.06000000	-2.52000000	KDRCOR 0.08640000	KDRCPG 0.08640000
-2.06000000	-2.99000000		KDRCPG 0.08640000	KDREFO 0.15000000
-2.99000000	299982-10.00000000	0.	KDSCLX 0.45720000	KDSHLX 0.01270000
299982-10.00000000	1.00000000		KDSHLX 0.01270000	KDTCL 0.76000000
1.00000000			KDTCL 0.76000000	KDVESI 0.19850000
			KDVESI 0.19850000	KDVESO 0.56040000

KEACHO 0.		KEROPR 0.	KERPCH 4.5700E-05
KEBYPO 0.	KECLRI 4.5700E-05	KERPCL 4.5700E-05	
KECLRO 4.5700E-05		KERREF 4.5700E-05	KERSCC 4.5700E-05
KECORO 0.	KECTBO 4.5700E-05	KERSHP 4.5700E-05	
KEEHXO 4.5700E-05		KERTCL 4.5700E-05	KERTHL 4.5700E-05
KEESCL 4.5700E-05	KEESHL 4.5700E-05	KERVES 1.5200E-06	
KEFPOI 3.2000E-11		KESCLX 4.5700E-05	KESHLX 4.5700E-05
KEGAC 4.5700E-05	KEHCLO 0.	KETCLO 4.5700E-05	
KEHCUO 0.		KETHLO 4.5700E-05	KEVESI 4.5700E-05
KEHLRI 4.5700E-05	KEHLRO 4.5700E-05	KEVESO 1.5200E-06	
KEHXPO 4.5700E-05	KEIPCI 0.	KEY 0	KFAACC 0.06663000
KEIFDI 4.5700E-05		KFABYP 0.03622000	
KELHLO 4.5700E-05	KEMCPO 4.5700E-05	KFACIL 0.24966000	KFACLR 0.24966000
KEMCPI 4.5700E-05		KFACOL 0.24660000	
KEMHLL 4.5700E-05	KEMHXI 4.5700E-05	KFACOR 0.06663000	KFAACH 0.06663000
KEMHLO 4.5700E-05		KFACTB 100.000000	
KEMHKO 4.5700E-05	KEPCHO 4.5700E-05	KFAEPP 1.06000000	KFAESP 1.00000000
KEMRPO 4.5700E-05		KFAGAC 0.24966000	
KERACC 0.	KERCIL 4.5700E-05	KFAHCL 0.05996700	KFAHCU 0.05996700
KERBYP 0.		KFAHLC 0.05996700	
KERCLR 4.5700E-05	KERCOR 0.	KFAHLR 0.24660000	KFAHUC 0.05996700
KERCOL 4.5700E-05		KFAHXP 10.000000	
KERHCL 0.	KERACH 0.	KFAIFD 0.09285000	KFAIPR 0.14800000
KERHCU 0.		KFALDS 0.24966000	
KERCTB 4.5700E-05	KEREPP 4.5700E-05	KFALHL 0.24966000	KFAMCL 0.24966000
KEREFO 4.5700E-05		KFAMCP 0.24966000	
KERESP 4.5700E-05		KFAMHL 0.24660000	KFAMHP 2.50000000
KERGAC 4.5700E-05	KERHLC 0.	KFAMRP 10.0000000	
KERHLR 4.5700E-05	KERHXP 4.5700E-05	KFAMUS 0.24966000	KFAOPR 0.13326000
KERHUC 0.		KFAPCH 10.0000000	
KERIFD 4.5700E-05	KERLDS 4.5700E-05	KFAPCL 0.24966000	KFAREF 1.00000000
KERIPR 0.		KFASCC 0.65670000	
KERLHL 4.5700E-05	KERMCP 4.5700E-05	KFASHP 1.10000000	KFATCL 1.38000000
KERMCL 4.5700E-05		KFATHL 1.38000000	
KERMHL 4.5700E-05	KERMCP 4.5700E-05	KFAVES 0.24660000	KFCCON 0.
KERMHP 4.5700E-05		KFDACF 3870.00000	
KERMUS 4.5700E-05	KERMCP 4.5700E-05	KFDCOR 3870.00000	KFDHCL 3870.00000

KFDHCU 3870.00000		KFVACF 0.03370000	KFVCOR 0.03370000
KFDACH 3870.00000	KFDHLF 3870.00000	KFVHCL 0.03370000	KFVACH 0.03370000
KFDHUF 3870.00000	KFFISC 1.15000000	KFVHCU 0.03370000	KFWISC 5.3638E-04
KFEDET 1.00000000		KFVHLF 0.03370000	
KFHCOR 0.52700000	KDHHCU 0.52700000	KFVHUF 0.03370000	
KDHHCL 0.52700000		KGBCIL F	
KDHBYP 0.52700000	KFICON 1.05000000	KGBCOL F	KGCGAC 1.00000000
KDHACH 0.52700000	KFLCLR 10.0600000	KGFGAC 0.07400000	KGPPOI 0.01130000
KFLACC 0.52700000	KFLHCU 0.52700000	KGIPOI 0.05600000	
KFLBYP 0.99800000	KFLEPP 24.0000000	KGTCOR 5.0000E-04	KGXPOI 0.00300000
KFLCOR 0.52700000		KGTCNT 5.0000E-04	
KFLHCL 0.52700000		KHOGAC 168000.000	
KFLACH 0.52700000	KFLHLC 0.52700000	KHACOR 0.90000000	KHCCCS 190857.000
KFLCTB 0.	KFLHXP 0.	KHMEHX 188065.000	
KFLESP 6.00000000		KHMMUS 188065.000	KHMMHX 188466.000
KFLGAC 5.00000000	KFLLDS 0.	KHPCCS 148200.000	KHSCCS 127200.000
KFLHLR 15.2400000	KFLMCP 0.	KHSACF 1.00000000	
KFLHUC 0.52700000	KFLMRP 0.	KHSSCC 127200.000	
KFLIFD 4.00000000	KFLPCH 0.	KHSHLF 1.00000000	KHSHUF 1.00000000
KFLIPR 3.00000000	KFLSHP 12.2000000	KHUCOR 1.07400000	
KFLLLHL 12.1900000		KHWACC 0.	KHWBYP 0.
KFLMCL 18.8600000		KHWCLR 600.000000	
KFLMHL 15.2600000		KHWCTB 0.	KHWEPP 350.000000
KFLMHP 40.0000000		KHWESP 0.	
KFLMUS 0.		KHWHLIC 0.	KHWHLR 900.000000
KFLOPR 3.00000000		KHWHUC 0.	
KFLPCL 13.8600000		KHWHXP 0.	KHWIFD 0.
KFLREF 0.	KFPPOI 1.5000E+10	KHWIPR 0.	
KFLTCL 20.0000000		KHWLHL 500.000000	KHWMCL 350.000000
KFLTHL 20.0000000	KFSCON 1.00000000	KHWMHL 500.000000	
KFRCOR 0.04400000	KFTHCL 0.00127000	KHWMHP 500.000000	KHWMRP 0.
KFRCPG 0.04400000	KFTHLF 0.00127000	KHWOPR 0.	
KFTACF 0.00127000		KHWPCCH 0.	KWPCL 350.000000
KFTCOR 0.00127000		KHWREF 0.	
KFTHCU 0.00127000		KHWSHP 0.	KWTCL 0.
KFTACH 0.00127000		KHWTHL 0.	
KFTHUF 0.00127000		KIIPOI 1.00000000	KIPPOI 1.00000000

KISPOI 1.00000000			
KIXPOI 1.00000000	KJOCNT 3.1101E+08	KKFACF 154.600000	KKFCON 1.00000000
KJOCOR 3.3000E+08	KJ0MCP 6.0000E+06	KKFCOR 154.600000	KKFHCU 154.600000
KJ0CPG 3.3000E+08	KJNCNT 3.1101E+08	KKFACH 154.600000	KKFHLF 154.600000
KJNCNT 3.1101E+08	KJNCOR 3.3000E+08	KKFGAC 0.01000000	KKIGAC 1000.000000
KJNCOR 3.3000E+08	KJPMCP(22) 2.00000000	KKFHUF 154.600000	KKIMCP 1000.000000
KJPMCP(22) 2.00000000	Z99953(11) 0.	KKFMUS 0.01000000	KKIMUS 1.00000000
Z99953(11) 0.	Z99954(11) 2.00000000	KKKCON 5.0000E-06	KKISCC 1.00000000
KKAACF 66.0000000	KKAHCL 66.0000000	KKOACF 2.25000000	KKOCOR 2.25000000
KKACOR 66.0000000	KKAHLF 66.0000000	KKOHCL 2.25000000	KKOACH 2.25000000
KKAHCU 66.0000000	KKCBYP 1.00000000	KKOHCU 2.25000000	KKPCIL 1000.000000
KKAAACH 66.0000000	KKCCOL 1.00000000	KKOHLF 2.25000000	KKWCIL 1000.000000
KKAHUF 66.0000000	KKCHCU 1.00000000	KKOHUF 2.25000000	KLACIL 10.0000000
KKCACC 1.000000000	KKCEPP 1.00000000	KKPCOL 1000.000000	KLAMCP 5.00000000
KKCCIL 0.300000000	KKCHILC 1.00000000	KKTCON 1.000000000	KLCCC 0.51700000
KKCCLR 1.000000000	KKCHXP 0.	KKWCOL 1000.000000	KLBYPO 0.99800000
KKCCOR 1.000000000	KKCLDS 1.00000000	KLACOL 10.0000000	KLCCNT 0.01430000
KKCHCL 1.000000000	KKCMCP 1.00000000	KLAGAC 10.0000000	0.03050000
KKCACH 1.000000000	KKCMHS 1.00000000	KLASCC 50.0000000	0.29600000
KKCCTB 0.	KKCMHP 1.00000000	KLBYPO 0.99800000	0.11100000
KKCESP 1.000000000	KKCOPR 1.00000000	KLCCOR 0.01430000	1.13000000
KKCGAC 1.000000000	KKCREF 0.	0.03050000	3.00000000
KKCHLR 1.000000000		0.29600000	1.1000E-04
KKCHUC 1.000000000		KLCCNT 0.01430000	0.03050000
KKCIFD 0.23000000		0.11100000	0.11100000
KKCIPR 0.16000000		0.29600000	0.29600000
KKCLHL 1.000000000		3.00000000	1.13000000
KKCMCL 1.000000000		1.1000E-04	KLCLRI 18.8600000
KKCMCS 1.000000000		KLCLRO 10.0600000	KLCTBO 0.
KKCMHL 1.000000000		KLCORO 3.000000000	
KKCMRP 0.		KLEHXA 24.0000000	
KKCMUS 1.000000000		KLESHL 6.000000000	KLHCLO 0.52700000
KKCPCH 0.			
KKCPCL 1.000000000			
KKCSCC 1.000000000			
KKCSHP 1.000000000			
KKCTHL 1.000000000			

KLHCUO 0.52700000		KPBCCS 150000.000	KPBSCC 150000.000
KLHLRO 15.2400000	KLHXPO 0.	KPCCCS 3.1180E+06	KPCCOL 290000.000
KLIPCI 3.00000000		KPCCIL 350000.000	
LIPOI 2.8750E-05	KLLHLO 12.1900000	KPECCS 0.01000000	KPLCCS 150000.000
KLMCPI 13.8600000		KPFISC 0.80000000	KPLCOR 1.70000000
KLMHLO 15.2600000	KLMHXI 0.	KPLCON 150000.000	KPLMUS 100000.000
KLMHXO 40.0000000		KPLCOR 1.70000000	KPMCOL 1000.00000
KLMRPO 0.	KLPCHO 0.	KPMCIL 1000.00000	KPMCP(18) 2.00000000
KLPOOI 3.5600E-06		KPMCOL 1000.00000	KPMMCS 21000.0000
KLREFO 0.	KLSHLX 12.2000000	Z99951 0.	0.
KLTCL0 20.0000000		3300.00000	
KLTHLO 20.0000000	KLVESI 4.00000000	13000.0000	50000.0000
KLXCON 0.		110000.000	
0.	1.00000000	200000.000	310000.000
5.00000000		310000.000	
5.00000000	-10.0000000	Z99952-1.00000000	0.
-1.00000000		0.10000000	
0.	1.00000000	0.20000000	0.40000000
10.0000000		0.60000000	
Z99993 0.	0.	0.80000000	1.00000000
1.00000000		2.00000000	
5.00000000	5.00000000	KPSACH(50) 1.00000000	KPSCON 1.7011E+06
Z99994-10.000000		KPSHCL(50) 1.00000000	
-1.00000000	0.	KPSHCU(50) 1.00000000	KPSISC 1.3584E+06
1.00000000		KPTMCP 1.50000000	
10.0000000	KLXPOI 2.0920E-05	KPUCOR 1.49000000 KPWMCP(22) 2.40000000	
KNOCON 5.5555E+33		Z99955(11) 0.	
KNOMCP 1.00000000	KNIANS 4.00000000	Z99956(11) 2.40000000	KROCNT 0.
KNNACH 1.00000000		KRACOR 7.40000000	
KNNHCL 23.0000000	KNNHCU 23.0000000	KRBCOR 9.10000000	KRFCOR-0.00125000
KNPISC 0.10000000		KRRREF 29.00000000	
KNPMCP 0.10000000	KNSISC 0.10000000	KRSISC 0.20000000	KSAACC 0.
KNSMCP 0.10000000		KSAACF 2.5400E-04	
KNUPOI 2.43000000	KOCCIL 0.60000000	KSABYP 0.	KSACLR 30.8643000
KOCCOL 0.60000000		KSACOR 2.5400E-04	
KOFMUS F	KOFSCC 1.00000000	KSAHCL 2.5400E-04	KSAHCU 2.5400E-04
KPOMCS 3.2931E+06			

KSAACH 2.5400E-04		KTSMHX 0.	KTTDET 2.00000000
KSACTB 0.	KSAEPP 26.5000000	KTWDET 0.25000000	
KSAESP 0.		KUCACH 1.30500000	KUCCOR 1.30500000
KSAHLC 0.	KSAHLF 2.5400E-04	KUCHCL 1.21508000	
KSAHLR 26.8250000		KUCHCU 1.21508000	KUFCOR 0.03795000
KSAHUC 0.	KSAHUF 2.5400E-04	KUFHCL 0.03795000	
KSAHXP 0.		KUFHCU 0.03795000	KUFACH 0.03795000
KSAIFD 7.48413000	KSAIPR 0.	KUGACH 1.55400000	
KSALHL 37.3991000		KUGCOR 1.55400000	KUGHCL 1.44693000
KSAMCL 57.8628000	KSAMHL 26.8602000	KUGHCU 1.44693000	
KSAMHP 40.0000000		KUWEHX 8.7000E-05	KUWMHX 2.6000E-04
KSAMRP 0.	KSAOPR 0.	KVAGAC 21.0000000	
KSAPCH 0.		KVFICR 0.03000000	KVFOCR 0.
KSAPCL 42.5227000	KSAREF 0.	KVSICR 0.01500000	
KSASHP 0.		KVSOCR 1.0000E+10	KWCCCS 2144.00000
KSATCL 0.	KSATHL 0.	KWOMCP 2144.00000	
KSFACF 7.6240E-04		KWCCOR 2144.00000	KWCCON 2144.00000
KSFCOR 7.6240E-04	KSFHCL 7.6240E-04	KWECCS 104.000000	
KSFHCU 7.6240E-04		KWFISC 0.08000000	KWLCCS 14.6000000
KSFACH 7.6240E-04	KSFHLF 7.6240E-04	KWLMUS 14.6000000	
KSFHUF 7.6240E-04		KWLLDS 14.6000000	KWLCON 14.6000000
KSOACF 2.5000E-05	KSOCOR 2.5000E-05	KWNCON 0.	
KSOACH 2.5000E-05		KWRICR(28) 1.00000000	Z99989(14)-15.2100000
KSOHCL 1.5000E-05	KSOHCU 1.5000E-05	Z99990(14) 1.00000000	
KSOHLF 1.5000E-05		KWROCR(20) 1.00000000	Z99985 0.
KSOHUF 1.5000E-05	KSSISC-1.0000E+10	0.	
KSSPOI 4.0800E-24		-0.25000000	-2.02000000
KSXPOI 2.7200E-22	KTCMCP 2.00000000	-3.11000000	
KTDDET 0.250000000		-4.00000000	-4.60000000
KTDISC 0.030000000	KTDOSC 0.12000000	-6.58000000	
KTFDET 0.025000000		-8.53000000	-8.53000000
KTLCIL 0.250000000	KTLCOL 0.25000000	Z99986-1.00000000	
KTLCON 1.000000000		-0.80000000	-0.60000000
KTLMUS 5.000000000	KTNCON 600.000000	-0.50000000	
KTPDET 0.030000000		-0.40000000	-0.30000000
KTSCON 45.0000000	KTSEHX 0.	-0.25000000	
KTSISC 55.0000000		-0.12500000	0.

1.00000000			
KWSCCS 2800.00000	KWSISC 171.520000	MUMHLO 4.2316E-04	MUMHXI 4.2366E-04
KWXCON 1.20000000		MUMHXO 7.3117E-04	
KXOICR-0.15000000	KXOOCR-0.80000000	MUMRPO 8.7855E-04	MUPCHO 8.7855E-04
KXMICR 0.60000000		MUREFO 4.9822E-04	
KXMOCR 0.	KXNICR-0.60000000	MUSCLX 9.8605E-04	MUSHLX 5.8445E-04
KXNOCR-0.80000000		MUTCLO 9.8605E-04	
KXSICR 0.01700000	KXSOCR 1.0000E+10	MUTHLO 5.8445E-04	MUVESI 7.2451E-04
KZOGAC 5.00000000		MUVESO 4.2217E-04	
LCNT-2.7054E-07	LGAC 4.63000000	MXNERR 100000	NACF 3.00000000
MCRACH 3.81319000		NERROR 0	
MCRCOR 1.99977000	MCRHCL 1.99977000	NHLF 2.00000000	NHUF 3.00000000
MCRHCU 2.25843000		NLL 2.2421E-44	
MIRACH 2.46468000	MIRCOR 1.33148000	NMCP 1.00000000	NPHMCP 7.26493000
MIRHCL 1.33148000		NSPCON 1.00000000	
MIRHCU 1.46455000	MLDSI 0.	ODCCON F	OFFGAC F
MMUSO 0.		OFICON F	
MPRACH 4.85824000	MPRCOR 1.50195000	OFIICR F	OFIOCR F
MPRHCL 1.50195000		OFRCOR F	
MPRHCU 1.73936000	MPRMCP 7.26493000	OMSKER F	OPRINT T
MSRACH 6.27408000		OSCISC F	
MSRCOR 3.17389000	MSRHCL 3.17389000	OSCMCP 5.5555E+33	OSCPPS 9
MSRHCU 3.48308000		OSEISC T	
MUACHO 3.9498E-04	MUBYPO 6.2862E-04	OSEOSC T	OSFISC F
MUCLRI 7.2425E-04		OSFOSC F	
MUCLRO 7.2451E-04	MUCORO 3.9498E-04	OSIISC F	OSIOSC F
MUCTBO 9.8605E-04		PACHI 3.1991E+06	
MUEHXO 7.3303E-04	MUESCL 8.7855E-04	PACHO 1.7083E+06	PBYPI 3.1991E+06
MUESHL 8.4429E-04		PBYPO 3.1469E+06	
MUGAC 7.9493E-04	MUHCLO 2.5096E-04	PCCC 1.7308E+06	PCILC 350000.000
MUHCQU 2.7469E-04		PCLRI 3.2675E+06	
MUHLRI 4.2217E-04	MUHLRO 4.2280E-04	PCLRO 3.4001E+06	PCOLC 290000.000
MUHXPO 8.7855E-04		PCORO 1.8104E+06	
MUIFDI 7.2451E-04	MUIPCI 7.2402E-04	PCTBI 150000.000	PCTBO 150051.000
MULHLO 4.2366E-04		PEHXO 1.6502E+06	
MUMCPI 7.3323E-04	MUMCPO 7.2396E-04	PESCL 150000.000	PESHL 117542.000
MUMHLL 4.2366E-04		PGAC 1.5864E+06	
		PHCLI 3.1991E+06	PHCLO 1.7077E+06

PHCUI 3.1991E+06			PRSHLX 3.95688000	PRTCLO 6.97953000
PHCUO 1.6608E+06			PRTHLO 3.95688000	PRVESI 2.79044000
PHLRO 1.6983E+06	PHLRI 1.8416E+06		PRVESI 4.99561000	
PHXPI 150000.000	PHXPO 150000.000		PSACHO 55645.0000	
PIFDI 3.4001E+06			PSBYPO 12579.6000	PSCISC 6
PIPPI 3.1991E+06	PLDSI 1.6906E+06		PSCLRI 8332.30000	PSCLRO 8323.77000
PLHLO 1.6906E+06			PSCLRO 8323.77000	PSCLX 262089.000
PMCLI 3.2931E+06	PMCPI 1.6516E+06		PSCORO 55645.0000	
PMCPO 3.2931E+06			PSCTBO 3682.75000	PSEHXA 8053.77000
PMHLA 1.6906E+06	PMHLL 1.6906E+06		PSESCL 4930.89000	PSGAC 6434.33000
PMHLO 1.6871E+06			PSESHL 5473.49000	
PMHXI 1.6906E+06	PMHXO 1.6704E+06		PSHCLO 270704.000	PSHLRI 44496.8000
PMRPI 150000.000			PSHCUO 196327.000	
PMRPO 150000.000	PMUPI 100000.000		PSHLRO 44273.9000	
PMUSO 1.6906E+06			PSHLX 181766.000	PSHXPO 4930.89000
PPCHI 150000.000	PPCHO 150000.000		PSIFDI 8323.77000	PSLHLO 43976.6000
PRACHO 2.60095000			PSIPCI 8339.75000	
PRBYPO 4.28197000	PRCLRI 4.99365000		PSMCPI 8047.46000	
PRCLRO 4.99561000			PSMCPO 8341.69000	PSMHLL 43976.6000
PRCORO 2.60095000	PRCTBO 6.97953000		PSMHLO 44149.3000	
PREFI 1.0000E+06			PSMHXI 43976.6000	PSMHXO 8111.53000
PREFO 1000000.00	PREHXO 5.05941000		PSMRPO 4930.89000	
PRESCL 6.15881000			PSPCHO 4930.89000	PSREFO 25867.8000
PRESHL 5.89861000	PRGAC 5.52519000		PSSCLX 3682.75000	
PRHCLO 1.64830000			PSSHGX 15679.3000	PSTCLO 3682.75000
PRHCUO 1.79702000	PRHLRI 2.79044000		PSTHLO 15679.3000	
PRHLRO 2.79490000			PSVESI 8323.77000	PSVESO 44496.8000
PRHXPO 6.15881000	PRIFDI 4.99561000		PTCLI 232037.000	
PRIPCI 4.99193000			PTCLO 262089.000	PTHLO 149999.000
PRLHLO 2.80089000	PRMCP 227334.000		PTMCP 13	
PRMCPI 5.06093000			PVESI 3.1180E+06	PVESO 1.8416E+06
PRMCPO 4.99149000	PRMHLL 2.80089000		PWACF 201030.000	
PRMHLO 2.79741000			PWFF 689249.000	PWHLF 1.2327E+06
PRMHXI 2.80089000	PRMHXO 5.04548000		PWHUF 847871.000	
PRMRPO 6.15881000			QACF 5.7094E+06	QCACF 3.3257E+07
PRPCHO 6.15881000	PRREFO 3.33062000		QCFFF 2.6034E+07	
PRSCLX 6.97953000			QCHLF 2.6277E+07	QCHUF 2.7756E+07

QFFF 5.9333E+06		RERETO 60214.4000	RESCL 1102.80000
QHACF 8.8725E+06	QHHLF 2.0456E+07	RESCLX 1.9768E+06	RESHLX 55311.9000
QHHUF 1.5554E+07	QHUF 9.1366E+06	RESHL 1102.01000	
QHLF 1.0426E+07		RESPOI-0.58127600	
QIACF 2.1370E+07	QIHLF 1.5436E+07	RETCLO 1.5637E+06	RETHLO 2.6384E+06
QIFFF 1.5274E+07		REVESI 6.3262E+06	
QIHUF 1.6720E+07		REVESO 1.1541E+07	REXPOI-2.98575000
QSACF 4.6494E+07	QSFFF 2.8895E+07	RGAC 1100.71000	
QSHLF 2.8642E+07		RHACHO-1.7118E-04	RHBYP0-1.1623E-04
QSHUF 3.1948E+07	RACH 0.	RHCLLI 1098.47000	
RACHI 1098.47000		RHCLRO 1036.40000	RHCLRI-9.6851E-05
RACHO 1074.10000	RAREA 0.	RHCLRO-9.6798E-05	
RBYP 0.		RHCORO-1.7118E-04	RHCTBO-3.7841E-05
RBYPI 1098.47000	RBYPO 1094.48000	RHCUI 187933.000	
RCLRI 1098.48000		RHCUO 1045.93000	RHEHXO-9.5065E-05
RCLRO 1098.49000	RCOR 0.	RHESCL-6.3995E-05	
RCORO 1074.10000		RHESHL-7.1650E-05	RHGAC-8.2256E-05
RCROD 0.	RCTBI 1092.09000	RHHCLCLO-2.2835E-04	
RCTBO 1104.88000		RHHCUO-2.1608E-04	RHHLRI-1.6344E-04
REACHO 172775.000	REBYP0 1.4760E+06	RHHCLRO-1.6326E-04	
RECLRI 3.8594E+06		RHHXPO-6.3995E-05	RHIFDI-9.6798E-05
RECLRO 3.8580E+06	RECORO 4.0813E+06	RHIPCI-9.6898E-05	
RECTBO 2.8394E+06		RHLHLO-1.6303E-04	RHLRI 1077.89000
REEHXO 140173.000	REESCL 541.218000	RHLRO 1077.97000	
REESHIL 6257.58000		RHMCPI-9.5023E-05	RHMCP0-9.6910E-05
REGAC 1.0000E-04	REHCLO 235035.000	RHMHILL-1.6303E-04	
REHCUO 214141.000		RHMHLO-1.6316E-04	RHMHXI-1.6303E-04
REHLRI 1.1541E+07	REHLRO 1.1523E+07	RHMHXO-9.5443E-05	
REHXO 1098.79000		RHMRPO-6.3995E-05	RHPCHO-6.3995E-05
REHXPO 11522.2000	REIFDI 3.8580E+06	RHREFO-1.4430E-04	
REIPCI 2.4009E+06		RHSLCX-3.7841E-05	RHSHLX-1.2535E-04
RELHLO 6.5977E+06	REM CPI 3.8123E+06	RHTCLO-3.7841E-05	
REMCPO 3.8611E+06		RHTHLO-1.2535E-04	RHVESI-9.6798E-05
REM HLL 6.5528E+06	REM HLO 1.1513E+07	RHVESO-1.6344E-04	
REM HXI 6.5977E+06		RHXPI 1100.00000	RHXPO 1102.80000
REM HXO 18766.4000	REM RPO 6691.42000	RICR 0.	
REPCHO 8749.79000		RIFDI 1098.49000	RIPCI 1098.47000

RLHLO 1078.08000		THCUI 44.4794000	THCUO 120.837000
RMCLI 1098.47000	RMCPI 1098.79000	THLRI 80.1483000	
RMCPO 1098.47000		THLRO 80.0271000	THOUR 0.
RMHLL 1078.08000	RMHLO 1078.02000	THSDET 56.8998000	
RMHXI 1078.08000		THWACF 140.472000	THWHLF 200.415000
RMHXO 1098.72000	RMRPI 1100.00000	THWHUF 187.396000	
RMRPO 1102.80000		THXPO 34.9428000	TIFDI 44.4434000
ROCR 0.	RPCHI 1100.00000	TIPCI 44.4794000	
RPCHO 1102.80000		TLHLO 79.8647000	TMCPI 43.8101000
RREFC 0.	RREFI 1100.00000	TMCPO 44.4838000	
RREFO 1085.92000		TMHLL 79.8647000	TMHLO 79.9592000
RSCISC 3	RSCLX 1104.88000	TMHXI 79.8647000	
RSHLX 1092.09000		TMHXO 43.9586000	TMIN 0.
RSPOI-0.58127600	RTCLI 1104.88000	TMRPO 34.9428000	TREFO 67.5966000
RTCLO 1104.88000		TPCHO 34.9428000	
RTHLO 1092.09000	RVESI 1098.49000	TSACHO 204.636000	
RVESO 1077.89000		TSBYPO 236.395000	TSCISC 5
RXESM-3.56703000	RXPOI-2.98575000	TSCLRI 238.518000	
SSCISC 8		TSCLRO 240.786000	TSCLX 29.9297000
TOANS 0.	TACHI 44.4794000	TSCORO 207.452000	
TACHO 85.6446000		TSCTBO 112.703000	TSEHXXO 202.974000
TBYPO 52.4385000	TCACF 214.000000	TSEESCL 112.693000	
TCCC 131.141000		TSESHL 105.558000	TSGAC 201.100000
TCFFF 234.715000	TCHLF 312.079000	TSHCLO 204.618000	
TCHUF 280.782000		TSHCUO 203.282000	TSHLRI 208.289000
TCLRI 44.4626000	TCLRO 44.4434000	TSHLRO 204.352000	
TCORO 85.6446000		TSHLX 56.8998000	TSHXPO 112.693000
TCSDET 29.9297000	TCTBO 29.9297000	TSIFDI 240.786000	
TDAY 0.		TSIPCI 237.321000	TSLHLO 204.136000
TDHCDH 1.0000E+10	TEHKO 43.8247000	TSMCPI 203.015000	
TESCL 34.9428000		TSMCPO 238.960000	TSMHLL 204.136000
TESHL 36.7836000	TFFF 225.170000	TSMHLO 204.035000	
TGAC 39.6870000		TSMHXI 204.136000	TSMHXO 203.558000
TGGAC 39.6870000	THCACF 284.127000	TSMRPO 112.693000	TSREFO 180.355000
THCHLF 426.651000		TSPCHO 112.693000	
THCHUF 365.747000	THCLI 44.4794000	TSSCLX 130.201000	
THCLO 131.141000		TSSHGX 118.528000	TSTCLO 130.201000

TSTHLO 112.693000		UMCPI 7.81555000	UMCPO 7.81784000
TSTOP 0.	TSVESI 235.878000	UMHLL 7.91112000	
TSVESO 208.289000	TTHLO 56.8998000	UMHLO 8.06468000	UMHXI 7.96536000
TTCLO 29.9297000		UMHXO 0.78053300	
TVESI 44.4434000	TWACC 0.	UMRPO 0.00533074	UPCHO 0.00697055
TVESO 80.1483000		UREFO 0.18417500	
TWACF 121.576000	TWCLR 34.9428000	USCLX 3.85871000	USHLX 2.33080000
TWBYP 0.		UTCLO 1.83624000	
TWCTB 0.	TWESP 0.	UTHLO 1.85789000	UVESI 21.0200000
TWEPP 34.9428000		UVESO 8.06563000	
TWFFF 165.013000	TWHLF 189.580000	VCICR 0.	VCOCR 0.
TWHLC 0.	TWHUF 173.423000	VGGAC 1.55400000	
TWHLR 34.9428000		VIRCON 0.	WACHI 1790.16000
TWHUC 0.	TWMHL 34.9428000	WACHO 1790.16000	
TWHXP 0.	TWOPR 85.6446000	WBYPPI 353.744000	WBYPO 353.744000
TWIFD 35.0189000	TWIPR 0.	WCILC 0.	
TWLHL 34.9428000		WCLRI 2143.93000	WCLRO 2143.93000
TWMCL 34.9428000	TWREF 0.	WCOLC 0.	
TWMHP 34.9428000		WCORO 1790.16000	WCTBI 2799.77000
TWMRP 0.		WCTBO 2799.77000	
TWPCH 0.		WEHKO 2144.00000	WESCL 104.000000
TWPCL 34.9428000		WESHL 104.000000	
TWSHP 0.		WHCLI 1547.26000	WHCLO 1547.28000
TWTCL 0.	TWTHL 0.	WHCUI 1543.07000	
UACHO 25.0137000	UCCC 24.8959000	WHCUO 1543.07000	WHLRI 2143.90000
UBYPO 8.92343000		WHLRO 2143.90000	
UCLRI 7.81752000	UCORO 12.5068000	WHXPI 101.284000	WHXPO 101.229000
UCLRO 7.81745000		WIFDI 2143.93000	
UCTBO 0.02534010	UESCL 9.4305E-04	WIPCI 2143.90000	WLDCON 14.6000000
UEHKO 1.84080000	UHCLO 24.8959000	WLDSI 14.6000000	
UESHL 0.09437340		WLHLO 2143.90000	WMCLI 2143.93000
UGAC 0.	UHLRO 8.06502000	WMCPO 2144.00000	
UHCQU 24.6021000	UIPCI 13.1872000	WMHLA 2143.90000	WMHLL 2129.30000
UHLRI 8.06563000		WMHLO 2143.90000	
UHXPO 0.00917924		WMHXI 2143.90000	WMHXO 2143.97000
UIFDI 7.81745000		WMRPI 58.7873000	
ULHLO 7.96536000		WMRPO 58.7875000	WMUSO 14.6000000

WPCHI 76.8711000			Z99869 F	Z99870 5
WPCHO 76.8714000			Z99871 58.8600000	
WREFO 200.000000			Z99874 8	Z99875 1.00000000
WSCISC 4			Z99876-1.0000E+10	
WSDET 2799.77000			Z99877 0	Z99878 8
WSHLX 2800.00000			Z99879 F	
WTCLC 2799.77000			Z99880 F	Z99882-1.0000E+10
WVESI 2143.93000			Z99883 0	
XCRACH 98.1025000			Z99884 7	Z99885 F
XCRHCL 43.7258000		XCRHCU 68.8227000	Z99886 F	
XIRACH 98.1025000		XIRHCU 68.8227000	Z99887 1.0000E+10	Z99888 0
XIRHCL 47.9086000		XPRHCU 68.8227000	Z99889 6	
XPRACH 98.1025000		XSRHCU 68.8227000	Z99890 F	Z99891 F
XPRHCL 47.9086000		Z99830 0	Z99892-339605.000	
XSRACH 98.1025000		Z99831 12	Z99893 0	Z99894 5
XSRHCL 47.9086000		Z99832 F	Z99895 F	
Z99829-5.76493000		Z99833 F	Z99896 F	Z99897-10.5161000
Z99830 0		Z99834 15	Z99898 0	
Z99832 F		Z99835 1.00000000	Z99899 4	Z99900 F
Z99833 F		Z99836 17	Z99901 F	
Z99835 1.00000000		Z99837 1.00000000	Z99902-1972.48000	Z99903 0
Z99836 17		Z99846 10	Z99904 3	
Z99846 10		Z99847-1.24000000	Z99905 F	Z99906 F
Z99847-1.24000000		Z99848-2.2000E+08	Z99907-0.20000000	
Z99849 0		Z99850 11	Z99908 0	Z99909 2
Z99850 11		Z99851 F	Z99910 F	
Z99852 F		Z99854 12	Z99911 F	Z99912-6.9963E-05
Z99854 12		Z99855 0.	Z99913 0	
Z99856-0.80000000		Z99857 0	Z99914 1	Z99915 F
Z99857 0		Z99858 10	Z99916 F	
Z99859 F		Z99860 F	Z99917 12	Z99918 0.
Z99860 F		Z99861 5	Z99919 12	
Z99862 58.8600000		Z99863 21	Z99920 0.	Z99921 12
Z99863 21		Z99864 0.98000000	Z99922 0.	
Z99865-0.75000000		Z99866 0	Z99923 21	Z99924 0.98000000
Z99866 0		Z99867 9	Z99925 21	
Z99868 F			Z99926 0.98000000	Z99979 10

Z99980-1.24000000		ZDHPMRP 0.00579261	ZDHOPR 0.
Z99995 12	Z99996 0.	ZDHPCH 0.01194720	ZDHREF-1.5506E-05
ZAAEEHX 500.000000	ZAUACF 2.5306E+06	ZDHPCL-0.00150202	
ZAEMHX 8750.00000		ZDHSHP 61.9591000	
ZAUHLF 3.3488E+06	ZB2ACC 0.45020300	ZDHTCL 0.	ZDHTHL 0.
ZAUHUF 3.3177E+06		ZDJEHX 7.6076E-05	
ZB2BYP 0.24473000	ZB2COR 0.54038900	ZDJMHX 3.2418E-05	ZDLCON-0.01537870
ZB2CLR 1.00000000		ZDNCON-8.6018E-04	
ZB2CTB 0.01380000	ZB2ESP 0.01000000	ZDPCON 1.5480E+06	ZDRCNT 1.00000000
ZB2EPP 0.42400000		ZDTCON 0.48389100	
ZB2HLC 0.40518200	ZB2HUC 0.40518200	ZDWCCS-0.24569400	ZEIPOI 1.8931E+22
ZB2HLR 1.00000000		ZEPPOI 3.0850E+22	
ZB2HXP 1.00000000	ZB2IPR 0.62736500	ZESPOI 5.7700E+21	ZEXPOI 4.4457E+20
ZB2IFD 0.37190600		ZFAACF 53.0709000	
ZB2LHL 0.98774300	ZB2MHL 1.00000000	ZFAHLF 53.0709000	ZFAHUF 53.0709000
ZB2MCL 1.00000000		ZFEGAC 0.	
ZB2MHP 0.09986400	ZB2OPR 0.50000000	ZFEMUS 0.00681001	ZFEPOI 4.6652E+18
ZB2MRP 1.00000000		ZFPPOI 4.6652E+18	
ZB2PCH 1.00000000	ZB2REF 1.00000000	ZFRCNT 0.	ZFSCON 1.00000000
ZB2PCL 0.23552800		ZHOANS 187933.000	
ZB2SHP 0.59700000	ZB2TCL 0.79710100	ZHOMCP 2798.51000	ZHFACF 159027.000
ZB2TCL 0.01380000		ZHFHLF 178291.000	
ZBDCIL 0.	ZB2THL 0.79710100	ZHFHUF 173687.000	ZHLACF 1980.77000
ZBDCOL 0.		ZHLHLF 2212.85000	
ZCVCIL 0.	ZBTCNT 0.00774000	ZHLHUF 2216.67000	ZHPEHX 10101.1000
ZCVCOL 0.	ZDEC PG 0.05754400	ZHPMCP 0.99990000	
ZDHACC 150.256000		ZHPMHX 6802.45000	ZHSEHX 207.757000
ZDHBYP 14.2309000	ZDHCLR-0.50672300	ZHSMHX 10493.1000	
ZDHCTB-1.2745E-06		ZHTACF 159027.000	ZHTHLF 178291.000
ZDHEPP 23.7187000	ZDHESP 0.00466240	ZHTHUF 173687.000	
ZDHHLCL 2699.44000	ZDHHUC 238.107000	ZIACOR 1074.10000	ZIBCOR 1094.48000
ZDHHLR-0.46265300		ZIICIL 3.4001E+06	
ZDHHXP-0.71966300	ZDHHXP-0.71966300	ZIICOL 1.8414E+06	ZIJSCC-3.1390E+08
ZDHIFD 0.	ZDHIPR-608.837000	ZIPACC 2.9267E+06	
ZDHLHL-0.43457300		ZIPBYP 3.1580E+06	ZIPCLR 3.2675E+06
ZDHMCL-0.40749600	ZDHMHL-0.25996300	ZIPCTB 150051.000	
ZDHMHP 25.1418000		ZIPEPP 1.6688E+06	ZIPESP 149995.000

ZIPGAC 1.6904E+06		ZKCMHL 0.	ZKCMHP 0.81024500
ZIPHLC 2.9253E+06	ZIPHLR 1.8416E+06	ZKCMRP 0.	ZKCPCH 0.
ZIPHUC 2.8828E+06		ZKCOPR 0.25000000	ZKCSHP 0.16240900
ZIPHXP 150000.000	ZIPIFD 3.1879E+06	ZKCPCL 0.38223600	ZKCTCL 0.
ZIPIPR 3.2574E+06		ZKCREF 0.	ZKFACF 1.4683E-05
ZIPLHL 1.6879E+06	ZIPMCL 3.2931E+06	ZKCTHL 0.04116780	ZKFHUF 1.0239E-05
ZIPMHL 1.6983E+06		ZKFHLF 1.0239E-05	ZKGACC 5.16987000
ZIPMHP 1.6968E+06	ZIPMRP 150000.000	ZKGBYP 5.16987000	ZKGCLR-133.122000
ZIPOPR 1.8763E+06		ZKGGEPP 0.	ZKGCTB 0.
ZIPPCH 150000.000	ZIPPCL 1.6178E+06	ZKGESP 29.4300000	ZKGHLC 5.16987000
ZIPREF 1000000.00		ZKGHLR 122.625000	ZKGHUC 5.16987000
ZIPSHP 266012.000	ZIPTCL 230175.000	ZKGIFD 0.	ZKGHXP 0.
ZIPTHL 182725.000		ZKGIPR 29.4300000	ZKGLHL-17.9523000
ZIRREF 1085.92000	ZITGAC 39.6870000	ZKGMCN 0.	ZKGMLH 0.
ZITLDS 0.		ZKGMLP 0.	ZKGMPCH 0.
ZITMUS 0.	ZIWCIL 2144.00000	ZKGOPR 41.7219000	ZKGSPH 0.
ZIWCOL 2144.00000		ZKGPCN-47.8728000	ZKGTHL 29.4300000
ZJDACF 0.	ZJDPCG 1.8990E+07	ZKGREF 0.	ZLAGAC 20.0272000
ZJDHLF 0.		ZKGTCN-29.4300000	ZLACH 0.98102500
ZJDHUF 0.	ZJFACF 3.0301E+08	ZKGTHL 29.4300000	ZLAGAC 20.0272000
ZJFHLF 5.5324E+08		ZLGAC 20.0272000	ZLHCL 0.98102500
ZJFHUF 4.8490E+08	ZJNCPG 3.1101E+08	ZLHCU 1.00000000	ZLHCU 0.98102500
ZJPMCP 1.00000000		ZNOMCP 1.00000000	ZNPCCS 2.00000000
ZJWACF 3.0301E+08	ZJWHLF 5.5330E+08	ZNWMHX 6.00000000	ZNWEHX 35.0000000
ZJWHUF 4.8489E+08		ZOCCIL 0.60000000	ZOCCOL 0.60000000
ZKCACC 0.04398380	ZKCACF 1.6192E-05	ZPOANS 3.1180E+06	ZPOGAC 1.5864E+06
ZKCBYP 0.06042160		ZPACE 1.7083E+06	ZPOMCP 1.6418E+06
ZKCCLR 0.	ZKCCOR 0.21124200	ZPCACH(50) 5.5555E+33	ZPCHCL(50) 5.5555E+33
ZKCCTB 0.97259000		ZPCHCU(50) 5.5555E+33	ZPDACC 336023.000
ZKCEPP 0.28800000	ZKCESP 0.49500000	ZPDBYP 43575.6000	
ZKCHLC 0.04758540			
ZKCHLF 1.1748E-05	ZKCHLR 0.		
ZKCHUC 0.04758540			
ZKCHUF 1.1748E-05	ZKCHXP 0.		
ZKCIFD 0.09421410			
ZKCIPR 0.03193710	ZKCLHL 1.5023E-04		
ZKCMCL 0.			

ZPDCLR 33565.8000		ZPGHLR 132186.000	ZPGHUC 5407.32000
ZPDCTB 0.35473300	ZPDEPP 1861.63000	ZPGHXP 0.	ZPGIPR 32328.1000
ZPDESP 4.90742000	ZPDHLR 35058.0000	ZPGIFD 0.	ZPGMHL 0.
ZPDHLC 321186.000	ZPDIFD 242678.000	ZPGLHL-19354.0000	ZPGMHP 0.
ZPDHUC 316531.000	ZPDML 33566.1000	ZPGMCL 0.	ZPGMRP 0.
ZPDHXP 0.04646020	ZPDMRP 0.01566900	ZPGMHP 0.	ZPGOPR 44813.5000
ZPDIPR 95514.0000	ZPDPC 33558.7000	ZPGPCH 0.	ZPGREF 0.
ZPDLHL 34200.4000	ZPDTC 1862.70000	ZPGPCL-52602.3000	ZPGTHL 32140.3000
ZPDML 35056.5000	ZPFBYP 5396.20000	ZPGSHP 0.	ZPIACC 0.
ZPDMHP 334.688000	ZPFEPP 18623.0000	ZPGTCL-32516.6000	ZPICTB 0.
ZPDOPR 84005.9000	ZPFHLC 1.2123E+06	ZPHLF 1.7077E+06	ZPIHLC 0.
ZDPCH 0.02679180	ZPFHXP 0.	ZPHUF 1.6608E+06	ZPIHXP 0.
ZPDREF 18.4175000	ZPFML 16654.1000	ZPIBYP 0.	ZPIKHL 0.
ZPDSHP 2966.48000	ZPFMHP 26378.7000	ZPICLR 0.	ZPIOPR 0.
ZPDTHL 1884.81000	ZPFMRL 33568.6000	ZPIEPP 0.	ZPIOPCH 0.
ZPFACC 1.2129E+06	ZPFMML 11184.0000	ZPIESP 0.	ZPIREF 0.
ZPFCLR 13638.4000	ZPFMXP 0.	ZPIHLR 0.	ZPIREF 0.
ZPFCTB 0.	ZPFNML 11169.7000	ZPIHUC 0.	ZPLCIL 5.5555E+33
ZPFESP 20.9974000	ZPFNRP 0.	ZPIIFD 0.	ZPPSCC 81985.7000
ZPFGAC 0.	ZPFNTHL 585.577000	ZPIIPR 0.	ZPSACH(50) 5.5555E+33
ZPFHLR 11169.7000	ZPFNTHP 84246.8000	ZPIML 0.	ZPSHCL(50) 5.5555E+33
ZPFHUC 1.2166E+06	ZPFNML 5658.33000	ZPIMHL 0.	ZPSHCU(50) 5.5555E+33
ZPFIFD 69832.9000	ZPFNXP 0.	ZPIMRP 0.	ZPTMCP 1.00000000
ZPFIPR 26018.8000	ZPFNTHC(50) 5.5555E+33	ZPIOPR 0.	ZQCACH(50) 5.5555E+33
ZPFMCL 25568.6000	ZPFNTHP(50) 5.5555E+33	ZPIPCL 0.	ZQCHCL(50) 5.5555E+33
ZPFMHL 11184.0000	ZPFNTHC(50) 5.5555E+33	ZPIREF 0.	ZQSACH(50) 5.5555E+33
ZPFMRP 0.	ZPFNTHP(50) 5.5555E+33	ZPITCL 0.	ZQSHCL(50) 5.5555E+33
ZPFOPR 21074.1000	ZPFNTHC(50) 5.5555E+33	ZPITHL 0.	
ZPFPCL 18791.9000	ZPFNTHP(50) 5.5555E+33	ZPLCOL 5.5555E+33	
ZPFREF 0.	ZPFNTHP(50) 5.5555E+33	ZPPSCC 81985.7000	ZPRMCS 3.2931E+06
ZPFTCL 602.010000	ZPGACC 5552.95000	ZPSACH(50) 5.5555E+33	
ZPFTHL 585.577000	ZPGACTB 0.	ZPSHCL(50) 5.5555E+33	
ZPGBYP 5658.33000	ZPGAC 103984.000	ZPSHCU(50) 5.5555E+33	
ZPGCLR-146233.000	ZPGACTB 0.	ZPTMCP 1.00000000	
ZPGEPP 0.	ZPGAC 103984.000	ZQCACH(50) 5.5555E+33	
ZPGESP 32432.0000	ZPGAC 103984.000	ZQCHCL(50) 5.5555E+33	
ZPGHLC 5358.07000	ZPGAC 103984.000	ZQSACH(50) 5.5555E+33	
		ZQSHCL(50) 5.5555E+33	

ZQSHCU(50)	5.5555E+33	ZTSMCP	5.5555E+33	ZTTCL	29.9297000
ZQWACH(50)	5.5555E+33	ZTTHL	56.8998000	ZTWACH(50)	5.5555E+33
ZQWHCU(50)	5.5555E+33	ZTWHCU(50)	5.5555E+33	ZTXACH(50)	5.5555E+33
ZROCNT-3.56703000	ZROICR 0.98000000	ZTXHCU(50)	5.5555E+33	ZTXHCL(50)	5.5555E+33
ZROOCR 0.	ZRBCOR 0.	ZUEEHX	100014.000	ZUEMHX	1.7420E+07
ZRACOR 0.	ZRBCOR 0.	ZWOANS	2144.00000	ZWLCCON	2144.00000
ZRCACF 80859.8000	ZRCHUF 80859.8000	ZWPMCP	1.00000000	ZWLCCOR	0.86414400
ZRCHLF 80859.8000	ZRCHUF 80859.8000	ZWUCOR	0.84857100	ZZSEED	55555555
ZRFCOR 0.	ZSCNT 0.	ZZWEHX	104.000000	ZZWMHX	2800.00000
ZRMPOI-3.56703000	ZSCNT 0.	ZZZISC 0.			
ZSMACH 1.00000000	ZSMHCU 1.48739000				
ZSMHCL 1.70348000	ZSMHCU 1.48739000				
ZTOACF 121.629000	ZTOHUF 173.482000				
ZTOHLF 189.045000	ZTOHUF 173.482000				
ZTACC 85.6446000					
ZTBYP 52.4385000	ZTCACH(50) 5.5555E+33				
ZTCEHX 8.88197000					
ZTCHCL(50) 5.5555E+33	ZTCHCU(50) 5.5555E+33				
ZTCLR 44.4433000					
ZTCMHX 14.0289000	ZTCTB 29.9297000				
ZTDCDH 0.					
ZTEPP 43.8247000	ZTESP 36.7836000				
ZTFCOR 205.381000					
ZTHEHX 7.17500000	ZTHLC 131.141000				
ZTHLR 80.0268000					
ZTHMHX 22.9649000	ZTHUC 120.837000				
ZTHXP 34.9428000					
ZTIFD 44.4434000	ZTIPIR 44.4794000				
ZTLHL 79.8645000					
ZTMCL 44.4626000	ZTMEHX 7.99815000				
ZTMHL 79.9591000					
ZTMHP 43.9584000	ZTMMHX 18.1314000				
ZTMRP 34.9428000					
ZTOPR 85.6446000	ZTPCH 34.9428000				
ZTPCL 43.8101000					
ZTREF 67.5966000	ZTSHP 56.8998000				
ZTSISC 1.0000E+10					



Internal Distribution

1. R. B. Battle
2. J. E. Cleaves
3. D. N. Fry
4. R. M. Harrington
- 5-7. J. A. March-Leuba
8. D. W. McDonald
9. G. R. McNutt
10. D. L. Moses
11. D. L. Selby
12. C. D. West
13. J. D. White
14. G. L. Yoder
- 15-16. Central Research Library
17. Document Reference Section
18. ORNL Patent Section
- 19-20. Laboratory Records Department
21. Laboratory Records Department, RC
- 22-31. Y-12 Technical Library

External Distribution

32. U.S. Department of Energy, Oak Ridge Operations, FEDC, MS-8218, P.O. Box 2009, Oak Ridge, TN 37831-8218
- 33-34. Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831

