

MAY 21 1997

21

21 ENGINEERING DATA TRANSMITTAL

Page 1 of 1
1. EDT 621459

2. To: (Receiving Organization) Francis W. Moore Facility Cleanup Projects		3. From: (Originating Organization) Fluor Daniel Northwest (FDNW)		4. Related EDT No.: na									
5. Proj./Prog./Dept./Div.: E59214		6. Design Authority/ Design Agent/Cog. Engr.: P. D. Rittmann		7. Purchase Order No.: na									
8. Originator Remarks: The attached report describes the basis for the MCNP Model of KE-Basin used in dose rate projections.													
11. Receiver Remarks: 11A. Design Baseline Document? [] Yes <input checked="" type="checkbox"/> No													
12. Major Assm. Dwg. No.: na													
13. Permit/Permit Application No.: na													
14. Required Response Date: May 15, 1997													
15. DATA TRANSMITTED													
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	(F)	(G)	(H)	(I)					
1	HNF-SD-SNF-CAVR-002, Rev 0			MCNP Model for the Many KE-Basin Radiation Sources	na	1,2							
16. KEY													
Approval Designator (F)		Reason for Transmittal (G)			Disposition (H) & (I)								
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval	4. Review	2. Release	5. Post-Review	3. Information	6. Dist. (Receipt Acknow. Required)	1. Approved	4. Reviewed no/comment	2. Approved w/comment	5. Reviewed w/comment	3. Disapproved w/comment	6. Receipt acknowledged
17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)													
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN		
		Design Authority											
		Design Agent											
1	/	Cog. Eng. P. D. Rittmann	<i>P. D. Rittmann</i>	5-7-97									
1	/	Tech.Rev. H. J. Goldberg	<i>H. J. Goldberg</i>	5/6/97									
1	/	Cog. Mgr. R. J. Puigh	<i>R. J. Puigh</i>	5/6/97									
		Safety	na										
		Env.	na										
18.	<i>Paul Rittmann</i>	5-7-97	19.	<i>W. Moore</i>	<i>W. Moore 5/12/97</i>	20.	<i>R. J. Puigh II</i>	<i>R. J. Puigh II</i>	21. DOE APPROVAL (if required)				
Signature of EDT Originator		Date	Authorized Representative Date for Receiving Organization						Ctrl. No.				
									Approved				
									Approved w/comments				
									Disapproved w/comments				

MCNP Model for the Many KE-Basin Radiation Sources

Paul D. Rittmann, PhD CHP
PO Box 1050, Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 621459 UC: 610
Org Code: 403 Charge Code: E59214
B&R Code: EW7040000 Total Pages: 134

Key Words: MCNP, KE-Basin, Gamma, Dose Rate

Abstract: This document presents a model for the location and strength of radiation sources in the accessible areas of KE-Basin which agrees well with data taken on a regular grid in September of 1996. This modelling work was requested to support dose rate reduction efforts in KE-Basin. Anticipated fuel removal activities require lower dose rates to minimize annual dose to workers. With this model, the effects of component cleanup or removal can be estimated in advance to evaluate their effectiveness. In addition, the sources contributing most to the radiation fields in a given location can be identified and dealt with.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.


Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Karen L. Noland

5/21/97

Release Approval

Date



Approved for Public Release

MCNP Model for the Many KE-Basin Radiation Sources
by Paul D. Rittmann PhD CHP May 7, 1997

The model presented in this document approximates the location and strength of radiation sources in the accessible areas of KE-Basin. This modelling work was requested to support dose rate reduction efforts in KE-Basin. Anticipated fuel removal activities require lower dose rates to minimize annual dose to workers. With this model, the effects of component cleanup or removal can be estimated in advance to evaluate their effectiveness. In addition, the sources contributing most to the radiation fields in a given location can be identified and dealt with.

The MCNP program (Carter 1996) used for these calibration calculations requires input files with three main parts. The first is the geometry of the facility. This includes the sizes and shapes and locations and composition of the various objects in the KE-Basin general area. The second part of the input is the location and strength of the radiation sources. This includes the photon spectrum coming from the source as well. The third part of the input is the location of the detector points. Each of these is described separately below.

Computed dose rates and a comparison with the data are shown in Appendix A. Appendix B contains contour plots of the dose rates from each source. Later appendices give sample MCNP input data and software listings for reference purposes.

MCNP GEOMETRY INPUT

The position, shape, size, and composition of the various objects in KE-Basin was determined from various engineering drawings. In addition, the facility was inspected to verify the drawing information and note any objects that weren't on the drawings we had.

The geometry portion of the MCNP input was developed in a spreadsheet to facilitate unit conversions and other calculations. The spreadsheet took longer to set up initially, but changes to the input file were readily accommodated in the spreadsheet.

Sketches of the geometry model are shown in Appendix C. Also in Appendix C is a listing of the geometry portion of the input file. The coordinate system origin is the northwest corner of the building, corresponding to Column 16 and Column A. The X coordinate increases to the south. The Y coordinate increases to the east. The floor is Z=0. All lengths in the MCNP input have units of centimeters.

Composition of the air, concrete, and wet sand (sand filter media) are shown in Table 1. The air composition comes from ANSI/ANSI-6.4.3-1991. The concrete composition is typical of that used at Hanford (Carter 1983). The wet sand composition is based on the data presented in Wittekind (1994). These assumptions are similar to those used in previous KE-Basin dose rate studies (Simons, 1995).

Table 1. Assumed Composition of Air, Soil, and Concrete

Element	Mass Fractions, percent		
	Air	Sand	Concrete
Hydrogen	0.048	1.741	0.31
Carbon	0.014		
Nitrogen	75.191		
Oxygen	23.464	56.245	44.07
Fluorine		0.009	
Sodium		1.182	1.82
Magnesium		0.094	3.76
Aluminum		3.960	6.07
Silicon		33.036	21.57
Phosphorus		0.035	0.09
Sulfur		0.016	0.09
Chlorine			
Argon	1.282		
Potassium		2.281	
Calcium		0.353	13.06
Titanium		0.005	0.49
Manganese			0.13
Iron		0.370	7.88
Krypton			0.66
Uranium		0.674	
Density:	0.0012 g/cc 100 lb/ft ³	1.60 g/cc 141 lb/ft ³	2.258 g/cc 141 lb/ft ³
Note: Air is at 80°F with a relative humidity of 20%.			

Many structural details were omitted on the basis that they would have little effect on the computed dose rates. For example, the posts that support the grating over the pool were not included. These posts are 5 inch diameter schedule 40 pipe positioned 14 feet apart in the north-south direction, and about 4 feet apart in the east-west direction. Another example is the ion exchange columns. These columns are inside thick concrete containers so the self-absorption characteristics do not matter. However, the activity needed to produce a given MCNP dose rate will differ from what is actually inside the container.

MCNP SOURCE INPUT

The KE-Basin contamination is primarily Cs-137 and Sr-90. Nearly all of the measured dose rates are due to the Cs-137 and its short-lived daughter Ba-137m. The Sr-90 and its daughter Y-90 are strictly beta emitters whose concentration is lower due to the lower solubility of strontium compounds compared to cesium compounds. Thus the source photon energy was assumed to be 0.662 MeV.

Two source shapes were used throughout the KE-Basin model, namely, rectangular boxes and cylinders. The cylinders were of two kinds: uniform throughout, and hollow. Hollow cylinders represent contamination on the inside of the pipes. For large sources (i.e. the sand filter and heat exchanger) hollow

cylinders reduce the execution time since the inside will contribute little to the dose rate outside. A complete listing of all source input for MCNP is found in Appendix D.

The KE-Basin water source was modelled as a layer 8 inches (20 cm) thick on the surface of the pool. Thicker layers did not increase the dose rate significantly but did increase the execution time. Table 2 summarizes the results of these MCNP runs. A fixed water concentration was used to compute dose rates at point 3 feet above the floor grate at various point above the pool. From the table it is clear that the 20 cm layer represents the 200 cm layer far better than the 2 cm layer does. Not only is the dose rate ratio closer to 1.00, but also the variation of the dose rate from location to location is less.

Table 2. Comparison of Pool Water Depth Assumptions

Detector Location	MCNP Dose Rates, mrem/h			Dose Rate Ratios	
	2 cm	20 cm	200 cm	200/2cm	200/20cm
West Pool - N Edge	0.067	0.284	0.339	5.09	1.19
West Pool - W Edge	0.217	1.007	1.213	5.60	1.20
West Pool - Center	0.576	3.126	4.002	6.95	1.28
West Pool - S Edge	0.125	0.526	0.573	4.60	1.09
W Inner Wall - N Edge	0.134	0.490	0.545	4.06	1.11
W Inner Wall - Center	0.397	1.744	2.000	5.04	1.15
W Inner Wall - S Edge	0.144	0.529	0.565	3.93	1.07
Middle Pool - N Edge	0.069	0.296	0.341	4.94	1.15
Middle Pool - Center	0.590	3.157	4.041	6.85	1.28
Middle Pool - S Edge	0.259	1.168	1.309	5.06	1.12
E Inner Wall - N Edge	0.133	0.491	0.520	3.91	1.06
E Inner Wall - Center	0.399	1.751	2.026	5.08	1.16
E Inner Wall - S Edge	0.196	0.793	0.825	4.21	1.04
East Pool - N Edge	0.070	0.298	0.320	4.58	1.07
East Pool - E Edge	0.217	1.004	1.111	5.12	1.11
East Pool - Center	0.577	3.123	3.993	6.92	1.28
East Pool - S Edge	0.291	1.521	1.886	6.48	1.24

Note: Water surface is at 16'10". Detector points are 3 feet above the floor grate. Water concentration is about 15 $\mu\text{Ci/L}$ of Cs-137.

In the present MCNP model for KE-Basin sources, a 8 inch (20 cm) thick layer was used to represent the pool. In addition, the activity in the water was increased by 20 percent over what the assumed concentration would predict. It is also assumed that fuel and sludge materials on the bottom do not contribute significantly to the dose rates above the floor. In addition, to simplify the source definition, the water in the east pits (elevator, weasel, and viewing pits) as well as the discharge chute was input as a single source. The concrete details at these locations reduce the efficiency of the monte carlo source point selection. By using a large number of points this efficiency was found and applied to the source probability (sp) value for these sources. In other words, the activity was reduced by the observed efficiency to adjust for the simplified source input.

Pool wall sources were modelled as slabs 1/4 inch (0.635 cm) thick on the surface of the pool walls. The contamination was assumed to begin at the 16'0" level and go down 90 cm. Contamination below this depth does not contribute significantly to the total dose rate from the walls. The only pit wall found to be contaminated was the elevator pit. The other pits apparently have some type of coating to keep contamination to a minimum.

The hot filter on the north wall a few feet east of column 15 was modelled as a cylinder of water. The contamination was assumed to extend from 1 foot above the floor to 3.5 feet above the floor.

The sand filter was modelled as an upright cylinder full of wet sand (1.60 g/cc). The source region only involved the outer 8 inches of sand, and extends from 16 inches to 80 inches above the floor.

The three ion exchange columns in the concrete box west of the north loadout pit were modelled as upright cylinders full of water. The source region is assumed to extend from floor level to a height of 74 inches.

The number of ion exchange columns in the lead cave could not be determined, so this source was modelled as a rectangular box. The source region was assumed to almost fill the box. In the north-south direction, 4 inches was removed from each side, and in the east-west direction, 2 feet was removed. Vertically, the source region extends from 19 inches to 61 inches above floor level. The source medium was just the air inside the lead cave.

The two ion exchange modules south of the lead cave were modelled as concrete boxes with walls 19 inches thick. The source region was modelled as a rectangular boxes made of iron with a density of 1.573 g/cc. The source region extends from 19 inches to 61 inches above floor level. This iron density is the average density of the floor grate.

The various PVC pipes in the north loadout pit were modelled as a single rectangular box in the air 4 inches below and 1/2 inch above floor level.

The large drip pan located west of the south loadout pit had three hot locations, one at each end and one in the middle. These were modelled as cubes 8 inches on an edge. The source region extends from 61 inches to 68 inches above floor level. The source medium was just the air on the west side of the pool.

Near the intersection of column 10.9 and column C there is a sampling device with elevated dose rates on the west side near the floor. It was assumed that there is a radiation source under the floor grate to cause this increase. This source was modelled as a cube 18 inches on an edge centered on column C and pressing against the west side of the inner pool wall at column 10.9. The source region extends from 10 inches to 28 inches below floor level. The source medium was just the air between the floor grate and the pool water.

On the east side there is a concrete pump platform wrapped in plastic that reads 50 to 100 mR/h on contact. This was modelled as a rectangular box suspended in air. The box is 18 inches square and extends from 4 inches to 10 inches above floor level.

The heat exchanger tubesheet was modelled as a north-south cylinder made of iron with a density of 1.573 g/cc. The cylinder is 15.78 feet long, has a

diameter of 38 inches, and its center is 29 inches above the floor. The inlet and outlet cooling water plenums are cylinders made of water at each end that are 41 inches long. The heat exchanger radioactivity was modelled as a hollow cylinder with inner radius 10.63 inches and outer radius 18.63 inches that extends the entire length of the tubesheet.

The chiller was modelled as a north-south cylinder made of water. The ends are made of iron 2 inches thick. The walls are made of iron 3/8 inch thick. The cylinder has outside dimensions of 13.25 feet long and 30 inches in diameter. The center is 21 inches above the floor. The chiller radioactivity was modelled as a hollow cylinder with inner radius 6.63 inches and outer radius 14.63 inches that is 12 feet long. The source cylinder is 1 inch from the south end and 10 inches from the north end of the chiller.

All other source regions were inside pipes. To simplify modelling, all pipes were assumed to have an 8 inch outside diameter and a wall thickness of 1/4 inch. They are all made of iron and filled with water. The source region is the outer 1/4 inch of water to represent contamination on the walls of the pipe.

The actual amounts of activity in each source are presented with the discussion of how these amounts were determined.

MCNP DETECTOR INPUT

Two types of detector locations were used, near source points and the regular grid. The near source locations were based on field readings taken during KE-Basin inspection trips between August 14, 1996, and October 8, 1996. The 73 near source locations are listed in Table 3. Actual detector coordinates are listed in Appendix D. The first guess at MCNP source strengths was based on the readings shown on Table 3. This table also gives the weighted sums of the MCNP readings and the modified relative error (MRE) for each.

The other group of detector locations was a nearly regular 4' by 4' grid over the entire KE-Basin. This grid was based on locations where health physics technicians took knee and chest level readings. A full listing of the grid locations is also provided in Appendix D, for reference.

Table 3. Near Source Data Versus MCNP

Detector Location	Data (mR/h)	MCNP (mrrem/h)	MRE
Over Elevator Pit NW	15	13	-0.1
Over Elevator Pit E	15	13	-0.1
Over Elevator Pit SW	15	14	-0.1
Pump #2 Pedestal	60	51	-0.2
IXM #1 (G10) Chest	2	2	0.0
IXM #2 (K10) Chest	6	7	0.1
Drip Pan - Pit End	250	144	-0.7
Drip Pan - Middle	100	96	-0.0
Drip Pan - Door End	50	48	-0.0
Sampler at Col 10.9C	8	6	-0.3

Table 3. Near Source Data Versus MCNP

Detector Location	Data (mR/h)	MCNP (mrem/h)	MRE
PVC in N Loadout	150	48	-2.1
PVC in N Loadout - E	35	38	0.1
SF North Wall	6	6	0.0
SF Northwest Corner	6	1	-2.5
SF West Wall	6	7	0.1
Pipe Along IX Box - #3	40	28	-1.6
Pipe Along IX Box	45	38	-1.3
Pipe Along IX Box - #2	50	27	-1.4
Pipe Along IX Box	45	33	-1.1
Pipe Along IX Box - #1	40	60	-1.1
Between HX/Chiller - N	20	6	-2.0
Between HX/Chiller - S	15	18	0.2
E Side HX	7	7	0.0
NW Filter Media	120	109	-0.1
NW Filter Media at 1ft	30	27	-0.1
N Loadout Entry - Pit	50	39	-0.3
N Loadout Entry	30	25	-0.2
N Loadout Entry - Pool	20	18	-0.1
SF Pipes, lower E	110	28	-2.8
SF Pipes, upper E	120	65	-0.8
SF Pipes, lower W	60	51	-0.2
Beam at Col 13B	25	12	-1.0
Column 13D	15	13	-0.1
Col 13D - Above Head	25	14	-0.7
9.5' W Ovrhd - SE	70	54	-0.3
9.5' W Ovrhd - SE	50	46	-0.1
S Loadout Riser	100	90	-0.1
Pipe Along N Load, W	35	28	-0.2
Pipe Along N Load, Mid	40	38	-0.1
Elbow - N Loadout - N	60	27	-1.2
Elbow - N Load - Outer	60	33	-0.8
Elbow - N Load - Inner	60	60	0.0
S Wall Col 12.2	13	10	-0.3
S Wall Col 9.5	16	17	0.1
S Wall Col 7.7	25	25	0.0
E 10' NS Middle	15	14	-0.1
E 10' NS Piece	45	25	-0.8
E 10' NS S Piece @ 2'	32	28	-0.1
View Pit Riser #1	50	33	-0.5
View Pit Riser #2	40	32	-0.2
View Pit Riser #3	30	27	-0.1
View Pit Risers - 1 ft	20	24	0.2

Table 3. Near Source Data Versus MCNP

Detector Location	Data (mR/h)	MCNP (mrem/h)	MRE
Bypass Loop - Inner	40	38	-0.1
Bypass Loop - East	40	36	-0.1
Bypass Loop - Above	100	100	0.0
Valve - S End Chiller	35	29	-0.2
Pump Overhead	45	42	-0.1
Pump #1 Riser	35	34	-0.0
Pump #1 Knee	12	12	0.0
Pump #2 Knee	7	9	0.3
N Wall Valve at Col 12	8	9	0.1
N Wall Valve at Col 10	6	7	0.1
N Wall Valve at Col 8	6	8	0.3
SF Pump Knee	50	28	-0.8
SF Pump Knee	50	27	-0.8
SF Pump	20	38	0.9
PVC Pipe Riser - NL	27	47	0.7
PVC Pipe - W Elbow	250	217	-0.2
PVC Hot Spot - Contact	1200	1067	-0.1
PVC Hot Spot - 6 in	250	291	0.2
PVC Hot Spot - 1 ft	130	143	0.1
PVC Pipe - 6 ft	45	49	0.1
PVC Pipe - S Elbow	20	29	0.4
Note: Detector coordinates are given in Appendix D.			

PREPARING MCNP INPUT FILES

This section summarizes the methods used to generate the hundreds of input files for the MCNP software. Since the activity in all sources except the water was not known, it was necessary to generate MCNP output for each radiation source. These could then be multiplied by a scale factor and added together to give the total dose rates for comparison with the data collected on September 23, 1996. In addition, knowing the relative strength of various radiation sources allows prioritization of cleanup/removal activities.

MCNP input preparation begins with the KE-GEOM.WQ1 spreadsheet. This spreadsheet has surface information in standard units of feet. Conversions to centimeters for input to MCNP are carried out in the spreadsheet. The cell definitions in the spreadsheet reference the surface ID numbers. Source information uses surface definitions. Finally, the location of detector points near sources is another block in the spreadsheet. Output from the spreadsheet is a text file named KE-GEOM.PRN, which has all the input data, but not in a usable order. The program named KE-GEOM.PAS converts the data in KE-GEOM.PRN into the three input parts (geometry, detector, and source).

The KE-GEOM.PAS program is listed in Appendix E. It was tested by comparison with output generated by hand to verify its correct operation in rearranging the KE-GEOM.PRN file. The files generated by KE-GEOM.PAS are listed in Table 4. The GEOM1.L3 file contains 3 lattices regions to represent the floor grate over the pool, the I-beam supports beneath it, and the posts above it. This file was modified by hand to remove the posts above the grate. The new file is named GEOM1.L2. This file was modified one more time to remove all the lattices. The new file is named GEOM1.X.

Lattice regions slow the computations. Therefore, the lattices case (GEOM1.L2) was only used for sources below the floor grate, such as the pool water, walls, and certain pipes. The geometry with no lattices (GEOM1.X) is used for all sources above the floor grate. The GEOM1.L3 file was not used in these MCNP runs.

Table 4. Output from KE-GEOM.PAS

File Name	Explanation
GEOM1.L3	cell and surface and material composition information
PT-NEAR	detector coordinates for the near source locations
S-ALL	source information of all radiation sources
S-WATER.1	pool water source only
S-W01 to S-W24	source information for pool walls only (24 files)
S-001 to S-077	source information for other radiation sources (77 files)

The various parts of the MCNP input files were combined using a batch file named MK-NEAR.BAT. This batch file is listed in Appendix E. Finally, a portion of the UNIX run streams actually used to run MCNP is listed at the end of Appendix E.

To determine the full KE-Basin grid, a spreadsheet named GRID-C.WQ1 was created to facilitate the preparation of the detector coordinate files. This spreadsheet will omit selected X & Y coordinates corresponding to inaccessible locations. A small amount of post-processing is necessary to put the PT-ALL.C (chest level) and PT-ALL.K (knee level) files in proper format for use by MCNP. The MK-NEAR.BAT file was then modified to use the chest level grid rather than the near source detector points. This batch file is called MK-CHST.BAT. Similarly, a batch file named MK-KNEE.BAT was used to generate input files for the knee level grid.

POST-PROCESSING OF MCNP OUTPUT

The point-kernel version of the MCNP software was used for these calculations rather than the full monte-carlo owing to time constraints. Approximately 92 hours of CPU time was needed nevertheless. Basically, the point-kernel calculation proceeds as follows: a point is randomly selected within a source and a line is drawn between this point and the detector location. The attenuation and buildup factors are computed and used for the total dose rate from that source location. This is repeated according to the input value for the number of source particles (nps), and the final total dose rate is computed. The point-kernel approach leads to sharp shadows since scattering off the air and any nearby objects is not considered. Somewhat larger than life volumetric sources were used to offset this effect.

The dose rates computed by MCNP for the unit source concentrations is in the form of MCTAL summary tables. One of these is listed in Appendix F for the PVC hot spot using near source detectors. These are difficult to use directly due to the layout of the numbers in the file. Since there are a total of 102 distinct sources, there are also 204 summary files for knee and chest level cases which must be used. For this reason, the MCNP output was rearranged using software written for this purpose (ALLTBL.PAS and BINCALI.PAS).

The output from the near source cases was rearranged in the form of individual source tables and a combined table for input to a spreadsheet. The program is named ALLTBL.PAS and is listed in Appendix F. A table file generated by ALLTBL.PAS is shown just after the MCTAL file for the same source. The large array for the spreadsheet has 102 rows and 73 columns. Actually, spreadsheets are not able to read lines with more than 250 characters. The combined output file is therefore broken into blocks with 102 rows and 20 columns. The blocks are easily recombined in a spreadsheet to form the needed 73 columns.

The formulas used in the calculations are best represented using matrices. In practice, one selects values for the 102 source strengths (the S vector) and then computes the 73 dose rates (the D vector) using the equation below.

$$\mathbf{D}_{n,1} = \mathbf{M}_{n,s} \mathbf{S}_{s,1}$$

where,

$\mathbf{D}_{n,1}$ = column vector with MCNP dose rates (mrem/h) at n locations

$\mathbf{M}_{n,s}$ = matrix with MCNP dose rates at n locations for s unit sources

$\mathbf{S}_{s,1}$ = column vector with the source strengths for s sources

This spreadsheet with the dose rates near the sources is called NEAR.WQ1. At each detector location the total dose is the weighted sum of the doses from individual sources. The spreadsheet was set up to facilitate trial-and-error estimates of source concentrations (the S vector in the above equation). This iterative process is the simplest way to arrive at a best estimate of the Cs-137 activity present in each source. The resulting source strengths are shown in Table 5 below. Note that the two columns of numbers are nearly the same. Asterisks mark values which differ. The resulting weighted sums of dose rates are shown in Table 3.

Table 5. Source Concentrations from NEAR.WQ1 and SSS.PAS

NEAR.WQ1	Source ID	SSS.PAS
2.70 $\mu\text{Ci}/\text{L}$	Pool Water (16'10")	2.70 $\mu\text{Ci}/\text{L}$
20.0 $\mu\text{Ci}/\text{cm}^2$	West Wall - North	20.0 $\mu\text{Ci}/\text{cm}^2$
23.0 $\mu\text{Ci}/\text{cm}^2$	West Wall - Middle	23.0 $\mu\text{Ci}/\text{cm}^2$
10.0 $\mu\text{Ci}/\text{cm}^2$	West Wall - South	10.0 $\mu\text{Ci}/\text{cm}^2$
25.0 $\mu\text{Ci}/\text{cm}^2$	N Wall - West	25.0 $\mu\text{Ci}/\text{cm}^2$
22.0 $\mu\text{Ci}/\text{cm}^2$	N Wall - Middle	22.0 $\mu\text{Ci}/\text{cm}^2$
20.0 $\mu\text{Ci}/\text{cm}^2$	N Wall - East	20.0 $\mu\text{Ci}/\text{cm}^2$
15.0 $\mu\text{Ci}/\text{cm}^2$	S Wall - West	15.0 $\mu\text{Ci}/\text{cm}^2$
22.0 $\mu\text{Ci}/\text{cm}^2$	S Wall - Discharge	22.0 $\mu\text{Ci}/\text{cm}^2$
20.0 $\mu\text{Ci}/\text{cm}^2$	S Wall - East	20.0 $\mu\text{Ci}/\text{cm}^2$
20.0 $\mu\text{Ci}/\text{cm}^2$	E Wall - North	20.0 $\mu\text{Ci}/\text{cm}^2$
70.0 $\mu\text{Ci}/\text{cm}^2$	E Wall - Middle	70.0 $\mu\text{Ci}/\text{cm}^2$
14.0 $\mu\text{Ci}/\text{cm}^2$	E Wall - Weasel	14.0 $\mu\text{Ci}/\text{cm}^2$
80.0 $\mu\text{Ci}/\text{cm}^2$	E Wall - Tech View	80.0 $\mu\text{Ci}/\text{cm}^2$
63.0 $\mu\text{Ci}/\text{cm}^2$	E Wall - South	63.0 $\mu\text{Ci}/\text{cm}^2$
35.0 $\mu\text{Ci}/\text{cm}^2$	Inner W - West	35.0 $\mu\text{Ci}/\text{cm}^2$
43.0 $\mu\text{Ci}/\text{cm}^2$	Inner W - East	43.0 $\mu\text{Ci}/\text{cm}^2$
33.0 $\mu\text{Ci}/\text{cm}^2$	Inner E - West	33.0 $\mu\text{Ci}/\text{cm}^2$
35.0 $\mu\text{Ci}/\text{cm}^2$	Inner E - East	35.0 $\mu\text{Ci}/\text{cm}^2$
40.0 $\mu\text{Ci}/\text{cm}^2$	Elevator Pit - N	40.0 $\mu\text{Ci}/\text{cm}^2$
40.0 $\mu\text{Ci}/\text{cm}^2$	Elevator Pit - E	40.0 $\mu\text{Ci}/\text{cm}^2$
40.0 $\mu\text{Ci}/\text{cm}^2$	Elevator Pit - SE	40.0 $\mu\text{Ci}/\text{cm}^2$
40.0 $\mu\text{Ci}/\text{cm}^2$	Elevator Pit - F	40.0 $\mu\text{Ci}/\text{cm}^2$
40.0 $\mu\text{Ci}/\text{cm}^2$	Elevator Pit - S	40.0 $\mu\text{Ci}/\text{cm}^2$
40.0 $\mu\text{Ci}/\text{cm}^2$	Elevator Pit - W	40.0 $\mu\text{Ci}/\text{cm}^2$
0.250 Ci/m ³	E Pump #2 Pedestal	0.250 Ci/m ³
2.00 Ci/m ³	Lead Cave	2.00 Ci/m ³
20.0 Ci/m ³	IXM #1 (west)	20.0 Ci/m ³
10.0 Ci/m ³	IXM #2 (east)	* 10.0 Ci/m ³
1.00 Ci/m ³	S Load Drip W	* 2.50 Ci/m ³
2.00 Ci/m ³	S Load Drip Mid	2.00 Ci/m ³
3.00 Ci/m ³	S Load Drip E	* 1.50 Ci/m ³
0.300 Ci/m ³	Sampler 10.9C	0.300 Ci/m ³
0.100 Ci/m ³	PVC Pipes N Load	0.100 Ci/m ³
6.50 Ci/m ³	Sand Filter	6.50 Ci/m ³
25.0 Ci/m ³	IX #3 (west)	25.0 Ci/m ³
30.0 Ci/m ³	IX #2 (middle)	30.0 Ci/m ³
50.0 Ci/m ³	IX #1 (east)	50.0 Ci/m ³
0.180 Ci/m ³	Chiller	0.180 Ci/m ³
0.400 Ci/m ³	Heat Exchanger	0.400 Ci/m ³
0.800 Ci/m ³	NW Filter Media	* 0.600 Ci/m ³
15.0 mCi/m	N Loadout Entry	15.0 mCi/m
10.0 mCi/m	SF to 13B Riser	* 5.00 mCi/m
8.00 mCi/m	Col 13B Riser	8.00 mCi/m
10.0 mCi/m	W 9.5' NS N	10.0 mCi/m
10.0 mCi/m	W 9.5' EW N	10.0 mCi/m
2.00 mCi/m	Col 13D Riser	* 1.00 mCi/m
15.0 mCi/m	W 9.5' NS S	* 5.00 mCi/m
8.00 mCi/m	W 9.5' EW S	* 4.00 mCi/m
30.0 mCi/m	S Loadout Riser	* 25.0 mCi/m
4.00 mCi/m	IX Box Outlet	4.00 mCi/m

Table 5. Source Concentrations from NEAR.WQ1 and SSS.PAS, Continued

NEAR.WQ1	Source ID	SSS.PAS
10.0 mCi/m	IX Box NS	10.0 mCi/m
7.00 mCi/m	N Loadout Chest	* 5.00 mCi/m
9.00 mCi/m	W Ovrhd Riser	9.00 mCi/m
20.0 mCi/m	W 10' NS N	20.0 mCi/m
5.00 mCi/m	W 10' to IXM	5.00 mCi/m
5.00 mCi/m	W 10' NS S	5.00 mCi/m
4.00 mCi/m	South Overhead	4.00 mCi/m
2.00 mCi/m	S Riser 12.2	2.00 mCi/m
4.00 mCi/m	S Riser 9.5	* 7.00 mCi/m
6.00 mCi/m	S Riser 7.7	6.00 mCi/m
3.00 mCi/m	East Ovrhd NS	3.00 mCi/m
10.0 mCi/m	East Ovrhd EW S	10.0 mCi/m
15.0 mCi/m	East Over HX	15.0 mCi/m
10.0 mCi/m	East Ovrhd EW N	10.0 mCi/m
5.00 mCi/m	TV #2 NS N	5.00 mCi/m
10.0 mCi/m	TV #2 NS S	10.0 mCi/m
5.00 mCi/m	Chiller Riser	5.00 mCi/m
5.00 mCi/m	TV #2 Bypass	5.00 mCi/m
2.00 mCi/m	TV Riser #2	2.00 mCi/m
10.0 mCi/m	TV Riser #1	* 6.00 mCi/m
7.00 mCi/m	TV Riser #3	* 3.00 mCi/m
5.00 mCi/m	TV #3 Bypass	* 6.00 mCi/m
30.0 mCi/m	TV #3 NS	30.0 mCi/m
2.00 mCi/m	TV #3 EW	2.00 mCi/m
10.0 mCi/m	E Pumps Ovrhd	* 15.0 mCi/m
7.00 mCi/m	Ovrhd #1 East	* 4.00 mCi/m
5.00 mCi/m	Horiz #1 East	* 6.00 mCi/m
5.00 mCi/m	Pool #1 East	* 8.00 mCi/m
5.00 mCi/m	Ovrhd #2 East	* 3.00 mCi/m
2.00 mCi/m	Horiz #2 East	* 5.00 mCi/m
1.00 mCi/m	Pool #2 East	* 4.00 mCi/m
10.0 mCi/m	E Wall Plenum	10.0 mCi/m
30.0 mCi/m	E Wall North	30.0 mCi/m
20.0 mCi/m	North Wall	20.0 mCi/m
4.00 mCi/m	West Wall	4.00 mCi/m
3.00 mCi/m	Riser N Col 12	* 4.00 mCi/m
3.00 mCi/m	Riser N Col 10	3.00 mCi/m
3.00 mCi/m	Riser N Col 8	3.00 mCi/m
5.00 mCi/m	Horiz N Col 12	* 6.00 mCi/m
2.00 mCi/m	Horiz N Col 10	2.00 mCi/m
4.00 mCi/m	Horiz N Col 8	4.00 mCi/m
10.0 mCi/m	Sand Fltr Riser	10.0 mCi/m
10.0 mCi/m	Sand Fltr Pump	10.0 mCi/m
2.00 mCi/m	PVC Riser in NL	2.00 mCi/m
0.070 Ci	PVC Hot Spot	0.070 Ci
5.00 mCi/m	PVC NS in West	5.00 mCi/m
10.0 mCi/m	SF Pipe #1	10.0 mCi/m
20.0 mCi/m	SF Pipe #2	20.0 mCi/m
10.0 mCi/m	SF Pipe #3	10.0 mCi/m
5.00 mCi/m	SF Pipe #4	5.00 mCi/m
1.00 mCi/m	SF Pipe #5	1.00 mCi/m

Output from the survey grid cases was much larger, with 966 dose rates for both the knee level and the chest level grids. These MCTAL files were read by BINCALI.PAS which stores them in a 2 dimensional array and writes them to a binary format for ease of use by other programs. This program also generates a text file with the dose rates and monte carlo relative errors positioned in a 2 dimensional array for ease of reading. In addition, a text file with the array of dose rates transposed is printed. This transposed array format is able to be read by spreadsheets since the lines are less than 250 characters. Using the standard spreadsheet function to transpose a matrix, the original layout is easily obtained. BINCALI.PAS is listed in Appendix G.

The final problem is to find values for source concentrations that approximate the readings taken by technicians in September, 1996. The calculation is simple enough, as shown in the matrix equation. Multiply the knee and chest level dose rates for each source times the source concentration and add them up. The problem is that 197,064 numbers need to be combined to give a result that is made of 1932 numbers. Initially, it was thought that this could be done in a spreadsheet, as had been done in the past. However, the size of the problem required the writing of another program to work with the numbers.

The program SSS.PAS was written to be the spreadsheet substitute. The program listing for SSS.PAS is in Appendix H. The program reads the source initialization file, (SOURCE.INI), the two MCNP dose rate files (CHST1.BIN and KNEE1.BIN), and finally, the instrument reading files (9CHST.BIN and 9KNEE.BIN). Using the source concentrations in SOURCE.INI, the total dose rates are computed and displayed using a single character to represent each grid location, and coloring that character to represent the dose rate.

The SSS.PAS software also displays a modified relative error (MRE) between the measured values and the computed values. This modified relative difference is computed using the equation below.

$$\text{MRE} = \frac{\text{Data} - \text{Calc}}{1 + \text{Min}(\text{Data}, \text{Calc})}$$

The denominator is increased by 1 to decrease the importance of small dose rates. Neither the Data nor the Calculated dose rates were considered to be suitable reference values, so the minimum of the two was used in the denominator. The sum of the absolute values of the modified relative differences is used as a figure of merit on the closeness of the approximation. The source concentrations were adjusted to minimize this figure of merit.

Having a stand-alone program to compute dose rates also gives more flexibility to apply more advanced numerical methods, such as linear least squares fits. Linear least squares fitting of data can be represented using matrices in the equation below.

$$\mathbf{M}_{s,n} \mathbf{M}_{n,s} \mathbf{S}_{s,1} = \mathbf{M}_{s,n} \mathbf{D}_{n,1}$$

where,

$\mathbf{M}_{s,n}$ = transpose of the matrix with MCNP dose rates

$\mathbf{M}_{n,s}$ = matrix with MCNP dose rates at n locations for s unit sources

$\mathbf{S}_{s,1}$ = column vector with the source strengths for s sources

$\mathbf{D}_{n,1}$ = column vector with MCNP dose rates (mrem/h) at n locations

The above equation is a system of s(=102) equations in s unknowns (the S vector). The only constraint is that n must be larger than s. Since there are n=966 data points and s=102 sources, a solution is typically possible.

Linear least squares fitting (LLSQ) of the data was included in the SSS.PAS utility, but the results include negative source concentrations and are largely useless. The SSS program was modified to improve the LLSQ calculation by allowing the user to select which sources to use for fitting and which data points. This feature was used in debugging the program by selecting a few point near strong sources. It was also used to estimate the source vector by just using data and sources on the west end or east end. Negative sources were still predicted. An iterative procedure was followed in which the reasonable sized sources were fixed and LLSQ was repeated.

The initial approximations using the near source readings were improved by trial and error using SSS.PAS and the MRE figure of merit. The resulting solution was used again in the NEAR.WQ1 spreadsheet to further refine the near-source calculations. This is the approach used to generate the source strengths shown in Table 5.

The last column of Table 5 shows the results of the trial-and-error approach using SSS.PAS and the entire grid of data. Asterisks mark sources whose magnitude changed between the near-source case and the general grid case. For many of the sources, the concentrations decreased. This suggests that the MCNP sources are larger and more uniform than the sources actually present in KE-Basin. The near source locations typically required a higher concentration than the general area grid.

The dose rates from MCNP as well as the measured data are presented in Appendix A. The comparisons between the measured and computed dose rates at various grid locations are also shown in this appendix. The letters across the top and the numbers down the side are the grid reference locations where data was collected. These are about 4 feet apart. The pool lies between columns 0 and AT, and rows 2 to 18. The west inner wall is between columns Y & Z, and the east inner wall is at column AJ.

It must be noted that the trial and error process of improving the MCNP representation of the data could not be automated due to the excessively long computing times needed to complete the optimization. For example, if each source were adjusted upward and downward by 20 percent to find an improved fit to the data, then the number of cases to compute would be 3 raised to the 102 power, which is 4.6E+48. If the figure of merit for one combination of source strengths could be computed in 1 second, then the complete calculation would require 1.5E+41 years! If only 30 sources were optimized in this way, the calculations would still require 6 million years!

Contour plots of the MCNP results are presented in Appendix B. These were generated by Victor Roetman using PVWAVE™ Version 6 software (PVWAVE is a trademark of Visual Numerics Corporation). The sources were grouped to reduce the number of plots needed.

REFERENCES

American National Standard for Gamma-Ray Attenuation Coefficients and Buildup Factors for Engineering Materials, ANSI/ANS-6.4.3-1991, American Nuclear Society, August, 1991.

Carter, L. L., "Bulk Shield Design for Neutron Energies Below 50 MeV", *Nuclear Technology/Fusion*, Vol. 3, pp 165-180, March, 1983.

Carter, L. L., "Certification of MCNP Version 4A for WHC Computer Platforms", WHC-SD-MP-SWD-30001, Rev. 8, May, 1996.

Simons, R. L., "KE-Basin Dose Rate Reduction by Cleaning, Coating, and Raising the Water Level", Internal Memo 8M730-RLS-95-014, December 28, 1995.

Van Riper, K. A., "SABRINA User's Guide", LA-UR-93-3696, Los Alamos National Laboratory, October, 1993.

Wittekind, W. D., "Criticality Safety Evaluation for K Basins Sand Filters", EDT 130158, WHC-SD-NR-CSER-013 Rev 0, April, 1994.

Appendix A. MCNP Dose Rates, Modified Relative Errors, and Data

MCNP Dose Rates (mrem/h) -- Chest Level

	North																				
B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	
1	1.2	2.6	9.4	3.2	1.4	1.0	1.1	1.9	2.5	2.9	2.1	2.9	3.4	3.5	3.3	3.5	4.8	3.1	2.5		
2	0.8	1.2	2.0	3.3	2.7	2.3	1.8	1.2	2.5	5.2	3.8	4.1	6.1	7.2	7.6	6.9	6.6	6.3	6.0	5.8	
3	0.7	0.8	1.1	1.4	1.9	2.4	3.0	4.1	5.1		12.6	11.2	8.5	6.8	5.7	5.0	4.6	4.3	4.3		
4	0.7	0.8	1.0	1.2	1.6	2.4	3.3	4.7	6.1		38.4	13.7	8.6	6.3	4.9	4.2	3.7	3.5	3.5		
5	0.6	0.7	0.8	0.9	1.4	2.5	3.7	5.3	8.2	13.5	17.7	21.2	14.1	9.5	6.5	4.9	3.9	3.4	3.1	3.1	
6	0.8	0.9	1.0	1.1	1.0	2.4	11.1	13.0	18.0		24.5	16.9	10.8	6.7	4.9	3.9	3.3	3.0	3.1		
7	0.8	1.0	1.2	1.6	2.0						27.4	17.2	10.8	6.7	4.8	3.8	3.2	2.9	3.0		
8	0.8	0.9	1.0	1.2	1.4						8.6	12.9	18.7	19.7	14.3	9.9	6.5	4.7	3.6	3.1	2.8
9	0.8	0.9	1.1	1.2	1.1	0.6					5.9	8.9	12.3	14.1	10.7	8.2	6.0	4.4	3.5	3.0	2.7
10	0.8	0.9	1.1	1.5	2.0	2.5					6.3	7.8	9.4	10.7	9.4	7.3	5.6	4.1	3.3	2.8	2.6
11	0.8	1.0	1.4	2.1	2.7	3.0	4.9	4.3	5.5		7.0	8.1	9.4	10.1	9.4	6.9	5.0	3.7	3.0	2.6	2.5
12	0.8	1.1	1.9	4.2	9.4	6.3	9.3	8.6	10.7				10.8	8.4	6.0	4.6	3.5	2.9	2.5	2.4	
13	0.8	1.2	2.0	5.4	22.3	7.7	15.9	11.0	17.8				11.2	7.5	5.2	4.2	3.3	2.8	2.5	2.3	
14	0.9	1.2	1.8	3.0	4.5	4.5	5.2	5.6	6.1				9.2	6.2	4.8	3.9	3.2	2.8	2.5	2.4	
15	0.8	1.0	1.4	1.8	2.3	2.7	3.3	3.4	3.9	4.7	6.3	7.7	7.0	5.4	4.4	3.8	3.2	2.9	2.7	2.6	
16	0.7	0.9	1.1	1.4	1.6	1.9	2.5	2.8	3.4	4.3	5.3	5.5	4.6	4.3	4.0	3.7	3.5	3.4	3.2	3.0	
17	0.6	0.8	0.9	1.1	1.3	1.5	1.7	1.8	2.1	2.5	3.0	3.8	4.2	3.9	3.6	3.4	3.1	3.1	2.9	2.7	
18	0.6	0.7	0.8	0.9	1.0	1.2	1.3	1.5	1.6	1.9	2.1	2.5	2.8	2.8	2.7	2.5	2.3	1.8	0.4	2.2	
19	0.5	0.6	0.7	0.8	1.0	1.1	1.2	1.5	1.6	1.7	1.9	1.9	1.9	1.7	1.5	1.4	1.4	1.2	1.1		
20	0.5	0.5	0.6	0.6	0.7	0.8	0.9	0.9	1.0	1.1	1.2	1.3	1.3	1.4	1.4	1.3	1.2	1.1			

	North												
	AR	AS	AT	AU	AV	AW	AX	AY	AZ	BA	BB	BC	BD
1	2.8	3.2	2.0	1.7	1.1			0.9	0.9				
2	6.3	7.8	4.7	3.9	3.2			2.1	1.4	1.2	1.0		
3	5.3	7.7	5.6					6.5	2.5	1.8	1.4		
4	4.8	8.1	5.1	10.8	11.7	8.7	7.7	4.8	3.2		2.0		
5	4.6	9.1	4.9	6.8	7.6	6.6	6.3	5.9	5.4		3.0		
6	4.6	9.6	5.7	7.9	13.0	8.5	9.0				5.4	3.4	2.4
7	4.5	9.5	6.1	9.0	11.6	10.7	11.6					4.2	2.8
8	4.4	9.2	6.3	10.0	15.1	12.1	12.8					4.3	3.0
9	4.1	8.8	5.7	8.5	11.8	12.5	13.3	17.7					2.8
10	3.9	8.2	5.6	6.9	9.4	11.8	14.5	13.2	9.8	6.4		3.3	2.5
11	3.6	6.8	5.0	5.8	7.4	10.6	22.1	15.0	8.9	5.8	4.0	3.0	2.3
12	3.3	5.5	4.5	6.3	6.7	10.2	16.1	13.8				3.8	
13	3.2	5.1	4.0	4.7	5.7	8.7	16.8	11.1	6.5	4.3	3.1		
14	3.3	5.5	3.8	4.0	4.5	6.2						2.4	
15	3.5	5.6	3.6	3.5	3.5	3.9	4.1	3.8	3.2	2.4	2.0	1.6	
16	4.5	6.6	3.9	3.9	3.2				2.0	1.8	1.6	1.4	
17	4.8	5.6	3.3	2.6	1.9	1.6	1.4	1.4	1.4	1.3			
18	4.3	2.9	2.4	1.3	1.3	1.1	1.0	0.9	0.9	0.9			
19	1.9	1.7	1.0	1.1	0.9			0.7	0.7	0.7			
20	1.3	0.9	1.0	0.9	0.7	0.6	0.6	0.5	0.5	0.5			

MCNP Dose Rates (mrrem/h) -- Knee Level

	North																						
	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V		
1			1.2	3.0	36.9	3.7	1.5	1.0	1.0	1.7	2.1	2.5	2.0	2.9	3.8	3.6	3.4	3.8	10.8	3.4	2.6		
2			0.8	1.2	2.1	3.8	2.8	2.2	1.7	1.1	1.8	3.4	3.0	4.2	5.9	9.4	8.8	8.2	8.0	7.9	7.2	6.9	
3	0.7	0.8	1.1	1.4	1.8	2.3	2.9	3.7	4.0				13.3	16.1	10.2	5.9	4.9	4.5	4.1	3.7	3.6		
4	0.6	0.8	1.0	1.2	1.6	2.3	3.2	4.4	5.2				14.1	11.6	9.9	5.3	4.2	3.7	3.3	2.9	2.8		
5	0.6	0.7	0.8	0.9	1.4	2.4	3.7	5.0	7.3	10.2	12.3	13.2	13.1	10.5	10.1	9.7	4.4	3.6	3.1	2.7	2.6		
6	0.7	0.8	1.0	1.1	1.0	2.2	5.5	7.1	11.7				19.8	15.2	10.6	5.8	4.5	3.7	3.1	2.6	2.7		
7	0.7	0.9	1.1	1.5	1.9								19.0	14.3	10.4	5.8	4.4	3.7	3.0	2.6	2.6		
8	0.7	0.9	1.0	1.1	1.0	0.5							5.4	7.4	10.1	12.0	10.0	9.9	5.6	4.3	3.5	3.1	2.6
9	0.7	0.9	1.0	1.1	1.0								4.8	7.0	9.1	9.8	8.1	9.2	5.3	4.1	3.5	2.9	2.5
10	0.7	0.8	1.1	1.4	1.9	1.9							5.3	6.6	7.5	8.0	7.3	8.6	5.0	3.9	3.3	2.8	2.4
11	0.7	0.9	1.3	1.4	2.4	2.7	4.0	3.5	4.3	5.5	6.2	7.0	7.3	7.8	7.9	4.4	3.5	3.1	2.6	2.3	2.3		
12	0.7	1.0	1.6	3.1	5.0	4.7	5.8	6.0	6.8				7.8	6.7	6.8	4.1	3.4	2.9	2.6	2.2	2.2		
13	0.7	1.0	1.7	3.5	6.4	5.3	6.8	6.9	7.4				7.4	6.0	5.6	3.9	3.2	2.9	2.5	2.2	2.2		
14	0.7	1.0	1.5	2.4	3.3	3.6	4.3	4.7	5.0				6.4	5.0	5.2	3.5	3.1	2.8	2.5	2.2	2.2		
15	0.6	0.9	1.2	1.6	2.0	2.5	2.8	3.2	3.6	4.2	5.2	5.9	5.2	4.4	5.0	3.4	3.0	2.8	2.6	2.3	2.3		
16	0.6	0.8	0.9	1.2	1.6	1.8	2.1	2.4	2.7	3.2	3.7	4.2	4.2	3.7	4.8	3.5	3.4	3.3	3.1	2.8	2.8		
17	0.6	0.7	0.8	1.0	1.2	1.4	1.6	1.8	2.1	2.4	2.6	3.1	3.2	3.2	4.4	3.4	3.2	3.3	3.8	2.9	2.7		
18	0.6	0.6	0.8	0.9	1.0	1.2	1.3	1.5	1.7	1.9	2.0	2.3	2.4	2.4	2.3	2.1	1.9	1.5	0.3	1.8	1.6		
19	0.5	0.6	0.7	0.7	0.8	1.0	1.1	1.2	1.4	1.5	1.6	1.7	1.7	1.7	1.5	1.4	1.3	0.9	1.0	1.0			
20	0.4	0.5	0.6	0.6	0.7	0.8	0.9	1.0	1.1	1.1	1.2	1.2	1.3	1.3	1.3	1.2	1.2	1.1					

	North																					
	W	X	Y	Z	AA	AB	AC	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM	AN	AO	AP	AQ	
1	2.3	2.3	1.9	1.9	1.9	1.9	2.1	2.8	9.4	2.1	1.9	2.0	2.1	1.6	1.7	1.9	2.1	2.4	4.5	6.1	2.6	
2	6.9	8.2	4.3	4.8	6.6	6.0	6.1	6.5	6.6	6.1	6.1	6.4	7.7	3.5	4.5	6.3	6.4	6.7	7.1	7.1	7.0	
3	3.8	6.0	2.5	2.8	3.9	3.0	2.9	3.0	3.0	2.9	3.0	3.0	6.0	1.8	2.6	3.6	3.2	3.3	3.4	3.5	3.8	
4	3.0	5.3	2.0	2.2	3.0	2.2	2.1	2.1	2.0	2.1	2.1	2.6	5.2	1.4	2.0	2.8	2.4	2.4	2.5	2.7	3.1	
5	2.9	5.7	1.9	2.1	2.9	1.9	1.7	1.7	1.7	1.7	1.8	2.3	5.2	1.2	1.8	2.7	2.0	2.0	2.2	2.4	2.9	
6	3.2	7.1	2.0	2.4	2.9	1.8	1.6	1.6	1.5	1.5	1.5	1.7	2.2	5.5	1.1	1.8	2.6	1.9	1.9	2.1	2.3	
7	3.2	8.6	3.1	2.8	2.8	1.7	1.6	1.5	1.5	1.5	1.6	2.1	5.2	1.1	1.8	2.5	1.9	1.9	2.0	2.3	2.8	
8	3.2	8.6	3.0	2.7	2.8	1.7	1.5	1.5	1.5	1.5	1.6	2.1	5.2	1.1	1.8	2.5	1.9	1.9	2.1	2.3	2.8	
9	2.9	6.2	1.8	2.2	2.7	1.7	1.5	1.5	1.5	1.5	1.6	2.1	5.0	1.1	1.8	2.6	1.9	1.9	2.1	2.3	2.8	
10	2.7	5.6	1.7	2.0	2.7	1.7	1.5	1.5	1.5	1.5	1.7	2.2	5.2	1.2	1.8	2.5	1.9	1.9	2.1	2.3	2.7	
11	2.5	5.0	1.7	1.9	2.7	1.7	1.6	1.5	1.5	1.5	1.7	2.2	5.1	1.2	1.9	2.6	1.9	1.9	2.1	2.3	2.7	
12	2.5	5.3	1.8	2.0	2.8	1.8	1.6	1.6	1.6	1.6	1.8	2.3	5.5	1.3	1.9	2.7	2.0	2.0	2.1	2.3	2.6	
13	2.5	5.1	1.8	1.9	2.7	1.8	1.7	1.7	1.7	1.7	1.8	2.4	5.3	1.3	1.9	2.7	2.1	2.1	2.2	2.3	2.6	
14	2.4	4.7	1.8	1.9	2.7	1.8	1.7	1.7	1.8	1.8	1.9	2.4	5.1	1.5	2.0	2.7	2.1	2.1	2.2	2.3	2.6	
15	2.6	5.1	1.9	2.1	2.9	2.0	1.9	1.9	2.0	2.1	2.3	2.8	5.7	1.6	2.2	2.9	2.3	2.2	2.4	2.5	2.8	
16	2.9	4.9	2.1	2.4	3.3	2.5	2.3	2.4	2.6	2.6	3.0	3.4	4.1	5.9	2.1	2.7	3.5	2.9	2.8	2.9	3.1	3.8
17	2.7	3.5	2.0	2.2	2.8	2.4	2.2	2.3	2.5	3.2	3.4	4.4	6.5	4.6	2.4	2.6	3.1	2.9	2.8	2.8	3.3	6.0
18	1.4	0.2	1.1	1.3	1.3	1.2	1.1	1.5	0.6	0.0	0.5	2.1	1.6	1.5	1.0	1.5	1.7					
19	1.0	1.0	0.9	0.9	0.8	0.9	1.2	1.2	1.1	1.2	1.2	1.3	1.3	1.4	1.4	1.5	1.5	1.5	1.3	1.3	1.3	
20	0.7	0.7	0.6	0.7	0.7	0.7	1.1										1.4	1.3	1.0			

	North												
	AR	AS	AT	AU	AV	AW	AX	AY	AZ	BA	BB	BC	BD
1	2.7	3.3	2.3	1.5	1.0			0.9	0.9				
2	7.4	10.0	5.3	2.9	1.5			1.3	1.2	1.1	0.9		
3	4.5	7.8	4.0					6.3	1.8	1.5	1.1		
4	4.0	7.9	3.6	13.3	14.3	7.6	7.3	4.1	2.5				
5	4.1	9.3	4.9	6.3	6.4	5.3	5.1	4.0	3.5				
6	4.2	9.8	6.4	11.8	14.9	7.3	8.0			3.5	2.7	2.1	
7	4.2	9.5	6.5	9.5	10.3	9.0	10.4				3.2	2.5	
8	4.0	8.9	7.1	14.8	15.0	9.9	11.3				3.3	2.6	
9	4.0	8.6	5.4	7.9	9.6	9.8	10.8	9.2					
10	3.8	8.1	5.0	5.9	7.6	9.3	10.6	9.5	7.7	0.2		2.7	2.3
11	3.4	6.2	4.5	5.1	6.5	8.7	16.0	10.8	7.5	4.7	3.4	2.5	2.1
12	3.2	4.9	3.9	4.8	6.0	8.5	11.9	10.0					
13	3.1	4.6	3.7	4.4	5.3	8.0	14.6	9.0	5.9	4.0			
14	3.2	5.4	3.5	3.6	4.2	6.1							
15	3.3	5.4	3.2	3.3	3.3	4.0	4.3	3.9	3.3	2.5	1.9	1.6	
16	4.2	6.3	3.4	2.5					2.1	1.8	1.5	1.3	
17	5.0	6.1	3.2	2.2	1.7	1.5	1.4	1.3	1.3				
18	3.7	2.2	2.0	1.1	1.2	1.0	0.9	0.9					
19	1.7	1.5	0.8	1.1	0.9	0.7	0.7	0.7					
20	1.1	0.8	0.9	0.9	0.7	0.6	0.6	0.5	0.5				

MCNP Compared with Measured Dose Rates -- Chest Level
Modified Relative Differences are Shown (Total MRE is 211)

	North																					
	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	
1				0.4	0.7	0.0	-0.1	0.0	-0.2	0.5	0.2	0.7	-0.3	-0.3	-0.1	-0.1	-0.2	-0.1	-0.0	0.0	-0.4	
2			0.1		0.1	-0.4	0.0	0.3	0.4	0.0	-0.2	-0.1	-0.1	0.8	0.0	-0.1	0.2	0.3	0.5	0.8	0.3	0.1
3	0.1	-0.0	0.0	0.0	-0.1	0.1	-1.5	0.3	0.0				-0.3	-0.4	-0.3	-0.0	0.3	0.2	0.2	0.2	0.1	
4	-0.0	-0.0	0.0	0.0	-0.1	0.1	-0.4	0.1	-0.1				-0.0	-0.4	-0.2	0.2	0.0	0.2	0.2	0.2	0.2	
5	-0.1		0.1	-0.1	-0.1	0.1	0.1	-0.3	-0.4	0.0	0.0	0.1	0.1	-0.4	-0.3	-0.0	-0.1	-0.0	0.0	0.1	0.1	
6	-0.1	0.2	0.2	-0.1	-0.2	-0.1	0.0		-0.3				0.1	-0.0	-0.0	-0.0	-0.2	-0.0	0.1	0.1	0.2	
7	-0.1	-0.0	0.0	0.1	0.2	0.4							0.1	0.1	0.1	-0.2	-0.0	0.2	0.0	0.1	0.1	
8	-0.2	-0.3	0.0	0.1	0.1	0.2							0.2	0.2	-0.0	0.2	0.0	0.1	0.2	0.1	0.1	
9	-0.5	-0.2	-0.1	-0.1	0.6	-0.3							-0.0	-0.0	-0.2	-0.3	-0.2	-0.1	0.0	0.0	0.1	0.1
10		-0.1	-0.3	0.2	0.2	0.1							0.0	-0.1	-0.2	0.3	1.1	-0.1	-0.2	0.0	0.0	0.1
11		-0.1	0.1	-0.1	-0.3	0.2	0.3	0.6	0.1	0.0	-0.1	0.1	0.4	-0.0	-0.0	-0.2	-0.1	0.2	0.1	0.1	0.1	
12	-0.6	-0.1	-0.2	0.2	0.0	-0.6	0.5	0.2	0.5				0.1	0.0	-0.1	-0.1	0.1	0.0	0.0	0.0	0.1	
13	-0.2	-0.2	0.0	-0.1	-0.1	-0.2	-2.0	0.7	-1.1	0.2			0.1	-0.2	-0.1	-0.1	0.1	0.0	0.0	0.1	0.1	
14	-0.1	0.1	0.0	-0.2	-0.1	-0.1	-0.3	-0.2	-0.4				-0.1	-0.3	-0.2	-0.2	-0.2	0.1	0.1	0.1	0.1	
15	-0.1	0.0	-0.0	0.0	0.4	-0.1							-0.4	0.0	0.1	0.1	0.6	-0.3	-0.0	-0.2	0.1	0.1
16	-0.0	-0.0	-0.0	-0.0	0.5	0.5							-0.6	-0.1	0.1	0.3	0.1	-0.3	-0.2	0.1	0.2	0.1
17	-0.2	-0.1	-0.0	0.6	0.2	-0.5	-1.6	-2.2	-2.5	-1.0	-0.3	0.1	0.2	0.4	-0.5	-0.4	-0.7	-0.5	-0.1	-0.0	-0.3	
18	0.0	0.0	0.0	0.0	0.0	0.3	-0.5	-1.0	-1.9	0.9	-0.7	-0.2	0.0	0.3	0.5	-6.0	-0.1	-0.3	-1.5	-2.3	0.1	0.1
19	0.3	0.3	0.2	0.1	0.1	-0.2	-0.4	-0.3		-0.1	0.0	0.1	0.2	0.3	0.1	0.0	-0.4	-0.7	-0.6	-0.1	-3.6	
20	0.2	0.1	0.2	0.2	0.1	0.2	0.3	0.4	0.4	0.1	0.2	0.3	0.4	0.3	-4.1	0.0	-0.1	-0.2				

	North																				
	W	X	Y	Z	AA	AB	AC	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM	AN	AO	AP	AQ
1	-0.2	-0.4	-0.4	-0.8	-0.5	-0.4	-0.4	-0.8	-0.2	-1.0	-1.1	-1.0	-1.1	-0.9	-0.9	-0.9	-0.2	-0.8	-0.3	-0.1	-0.6
2	0.2	0.3	0.0	-0.1	0.0	0.2	0.0	-0.4	0.2	-0.0	-0.2	-0.1	-0.1	0.0	0.0	-0.0	-0.2	-0.1	0.1	0.3	0.5
3	0.1	-0.0	0.0	-0.0	-0.1	0.0	-0.1	0.0	-0.1	-0.0	-0.0	-0.1	-0.0	-0.2	0.0	0.1	0.1	0.2	0.2	0.2	0.2
4	0.2	0.1	0.2	0.0	0.0	0.1	0.1	0.2	0.2	-0.0	0.0	0.0	0.0	0.3	-0.1	0.3	0.1	0.3	0.2	0.1	0.1
5	0.4	-0.1	0.1	0.0	-0.0	0.0	-0.0	-0.1	0.0	0.2	-0.0	-0.0	0.1	0.0	-0.3	0.0	0.1	0.0	0.2	0.1	0.1
6	0.1	0.1	-0.2	-0.4	0.2	-0.0	-0.2	-0.0	0.0	0.0	0.0	0.1	0.4	-0.1	-0.3	0.6	0.1	0.0	0.2	0.1	0.1
7	-0.1	0.0	-0.4	-0.6	-0.4	0.0	-0.1	0.0	-0.0	0.0	0.1	0.1	0.1	-0.0	-0.4	0.1	0.2	0.1	0.2	0.2	0.2
8	0.0	0.2	-0.2	-0.3	-0.2	-0.0	-0.1	0.0	0.0	0.0	0.1	0.1	0.1	0.0	-0.8	0.2	0.2	0.1	0.2	0.2	0.1
9	0.0	-0.1	-0.1	-0.2	-0.2	-0.0	-0.2	0.0	0.1	0.1	0.1	0.1	0.1	0.0	-0.4	0.1	0.1	0.0	0.1	0.0	0.1
10	0.0	0.0	0.0	-0.1	-0.1	-0.0	-0.1	0.0	0.1	0.1	0.2	0.2	0.1	0.1	-0.4	0.0	0.2	0.0	0.2	0.1	0.2
11	0.1	-0.0	-0.5	-0.4	-0.1	0.1	0.0	0.2	0.1	0.1	0.2	0.2	0.1	0.1	-0.1	0.1	0.2	0.1	0.1	0.2	0.2
12	0.1	0.2	-0.0	-0.2	0.1	0.1	-0.0	0.1	0.1	0.0	0.1	0.1	0.1	0.0	-0.1	0.1	0.2	0.0	0.1	0.1	0.2
13	0.1	-0.0	-0.2	-0.1	0.1	0.1	-0.1	0.0	0.0	0.0	0.1	0.1	0.1	0.0	-0.0	0.1	0.2	0.1	0.1	0.1	0.2
14	0.2	-0.0	-1.0	-0.3	-0.1	0.1	-0.0	0.2	0.1	0.1	0.2	0.2	0.1	0.0	-0.0	0.1	0.2	0.0	0.1	0.1	0.3
15	0.2	-0.0	-0.1	-0.1	0.1	0.1	0.2	0.1	0.0	0.1	0.0	0.2	0.0	0.1	0.0	-0.1	0.2	0.0	0.0	0.0	0.2
16	0.0	0.2	-0.0	-0.1	-0.1	0.0	0.1	0.0	0.0	0.0	0.1	-0.2	0.1	-0.1	0.0	-0.0	0.2	0.2	0.1	0.1	0.2
17	-0.0	-0.1	-0.2	-0.1	-0.3	-0.1	-0.1	-0.2	-0.4	-0.4	0.3	0.1	-0.1	-0.3	-0.2	-0.5	-0.1	-0.1	-0.1	-0.1	-0.1
18	0.1	-0.7	0.1	0.1	0.2	0.1	-0.1	-0.3	0.2	-0.3		-2.2	-0.1	-0.2	-0.5	0.1	-0.2	0.0			
19	0.1	0.3	0.1	0.1	0.1	0.1	-0.0	-0.1	-0.3	-0.5	-0.3	-0.1	-0.0	0.1	0.1	0.0	-0.5	-0.3			
20	0.4	0.1	0.0	0.1	0.1	0.0											-0.1	-0.2	-0.0		

	North													
	AR	AS	AT	AU	AV	AW	AX	AY	AZ	BA	BB	BC	BD	
1	-0.9	-0.6	-0.6	0.0	-0.5			-0.3	-0.2					
2	-0.1	0.1	-0.6	-0.2	-0.7			-1.0	-0.2	-0.3	-0.5			
3	0.1	-0.2	-0.2					-0.2	0.0	-0.3	-0.4			
4	0.2	0.0	-0.1	0.1	0.2	0.4	0.6	0.0	0.1					
5	0.2	0.0	-0.2	-0.0	0.1	0.3	0.0	-0.0	-1.0					
6	0.2	0.2	-0.3	-0.2	0.4	0.2	0.4			-0.9	-0.6	0.6		
7	0.2	0.2	-0.1	0.0	0.1	0.2	0.6				-0.2	1.0		
8	0.1	0.1	-0.2	-0.1	-0.4	0.1	0.4				0.1	1.2		
9	0.1	-0.0	-0.3	-0.1	0.0	0.2	0.4	1.1				1.3		
10	0.0	0.0	-0.3	-0.0	-0.2	0.1	0.6	0.4	0.4	0.2		-0.4	1.1	
11	0.1	0.3	-0.0	-0.2	-0.2	-0.3	1.1	0.2	-0.1	-0.3	-0.4	0.1	0.7	
12	0.1	-0.1	0.0	0.3	-0.0	0.1	0.5	0.2						
13	0.1	0.0	-0.0	-0.1	0.1	0.4	0.0	-0.3	-0.3	-0.1				
14	0.1	0.3	-0.0	0.1	-0.1	-0.2					-0.3			
15	0.2	0.1	0.1	-0.0	-0.1	-0.2	-0.6	-0.9	-0.2	-0.2	-0.3	0.5		
16	0.1	0.1	-0.1	0.0					0.4	0.8	0.5	0.8		
17	0.2	-0.1	-0.1	0.2	0.5	0.3	0.3	0.2	0.4					
18	-0.1	-0.1	0.3	0.1	0.3	0.2	0.3	-0.3	0.3					
19	-0.3	0.0	0.0	0.0	0.3	0.2	0.2	-0.4	0.4					
20	-0.2	-0.0		-0.0	0.1	0.3	0.2	0.2	0.4					

MCNP Compared with Measured Dose Rates -- Knee Level
Modified Relative Differences are Shown (Total MRE is 250)

		North																				
B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V		
1			0.2	1.9	0.2	0.1	0.2	-0.1	0.2	0.0	0.2	-0.3	-0.8	-0.3	-0.3	-0.1	-0.0	0.2	-0.3	-0.1		
2		0.2	-0.0	-0.7	0.1	0.2	0.2	-0.2	-0.5	-0.2	-0.5	-0.9	-0.3	0.0	0.4	0.5	0.5	0.7	0.0	-0.1		
3	0.0	0.0	0.0	-0.0	-0.1	-0.1	-0.0	-0.3	0.3	-0.4		-0.4	-0.2	-0.3	-0.2	0.0	-0.1	0.2	0.1	0.1		
4	-0.0	-0.1	0.0	-0.1	-0.1	-0.1	-0.4	0.1	-0.5			-0.7	-0.5	-0.4	-0.3	0.0	-0.1	0.1	0.1	0.1		
5	0.1		-0.0	-0.2	-0.4	-0.6	-0.5	-0.8	-0.3	-0.2	-0.1	-0.1	-0.3	-0.3	0.0	0.1	-0.1	-0.3	0.2	0.1	0.1	
6	0.1	0.1	0.1	-0.1	-0.3	-2.1	-1.2	-0.1	-0.3			0.2	0.0	-0.0	-0.2	-0.3	-0.3	0.1	0.1	0.0		
7	-0.2	0.1	0.1	0.1	1.1							-0.1	0.1	0.0	-0.3	-0.1	-0.1	0.3	0.1	0.1	0.1	
8	-0.4	-0.2	-0.0	0.1	0.8							-0.3	-0.4	-0.2	-0.5	0.4	0.1	-0.2	0.1	0.1	0.1	
9	-0.4	-0.2	-0.2	-0.1	0.4	-0.5						-0.4	-0.4	-0.3	-0.0	0.1	0.0	-0.4	-0.2	0.0	0.1	-0.0
10		-0.1	-0.8	0.0	-0.2							0.0	0.2	-0.3	0.1	0.4	0.1	-0.3	0.0	0.0	0.1	0.1
11		0.1	0.0	-0.8	-0.1							-0.3	-0.1	0.1	0.0	-0.3	0.2	0.5	0.1	-0.3	0.1	0.2
12	-0.7	-0.3	-0.2	0.2	-0.0	-0.4	0.1	0.2	-0.1			-0.0	0.1	0.1	-0.2	-0.1	-0.0	0.0	0.1	0.0	0.2	
13	-0.3	-0.1	-0.2	-0.8	-0.2	-0.3	-0.2	-0.0	-0.2			-0.1	-0.1	-0.1	-0.2	0.1	0.0	0.1	0.1	0.1	0.2	
14	-0.3	-0.0	-0.1	-0.8	-0.8	-0.5	-0.5	-0.2	-0.8			0.1	-0.5	-0.1	-0.3	0.0	0.1	0.1	0.1	0.1	0.1	
15	-0.2	-0.1	-0.2	0.2	0.2	-0.1						-0.4	-0.5	-0.0	-0.1	0.3	0.0	-0.1	-0.5	0.0	0.0	0.0
16	-0.3	-0.0	-0.1	0.2	0.0							-0.7	-0.2	0.0	-0.2	-0.1	-0.2	-0.3	-0.4	0.0	0.0	-0.1
17	-0.1	-0.2	-0.1	0.1	0.6	-0.2	-0.4	-3.9	-3.6	-5.1	-1.1	-0.3	0.0	0.1	0.3	-0.9	-0.4	-0.9	-0.9	-0.1	0.0	-0.2
18	-0.1	-0.0	-0.1	0.6	-0.3	-0.7	-1.0	-1.9	-1.2	-0.8	-0.2	0.0	0.1	0.4	0.3	0.2	-0.1	-1.8	-1.1	0.1	0.2	
19	0.2	0.3	0.2	0.0	0.1	0.0	-0.2	-0.3		-0.1	0.0	0.1	0.1	0.3	0.2	0.1	-0.3	-0.5	-0.3	0.0	0.1	
20	0.2	0.1	0.2	0.3	0.3	0.5	0.2	0.2	0.4	0.4	0.3	0.3	0.4	0.4	0.2	0.1	-0.1	-0.1				

		North																			
W	X	Y	Z	AA	AB	AC	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM	AN	AO	AP	AQ	
1	-0.8	-0.8	-1.1	-1.0	-1.1	-0.4	-0.6	-1.1	-0.1	-1.0	-1.8	-1.4	-1.6	-1.1	-1.1	-1.1	-0.6	-0.7	-0.1	0.0	-1.2
2	-0.0	0.1	-0.1	-0.2	-0.2	-0.1	0.2	0.3	0.3	-0.1	-0.1	-0.3	0.0	0.0	-0.4	-0.1	-0.1	-0.0	0.3	0.4	0.1
3	-0.3	-0.0	-0.1	-0.2	-0.4	-0.1	-0.1	-0.3	-0.1	0.0	-0.2	-0.4	-0.1	-0.0	-0.1	-0.4	-0.7	-0.2	0.0	0.0	-0.1
4	0.0	-0.3	-0.3	-0.2	-0.7	-0.7	-0.2	-0.1	0.1	0.1	-0.1	-0.1	-0.1	0.0	-0.7	-0.4	0.5	0.0	0.1	0.1	0.0
5	-0.1	-0.2	-0.4	-0.4	-1.1	-0.3	-0.1	-0.0	-0.0	-0.1	-0.1	-0.1	0.0	-0.1	-0.8	-0.4	-0.1	-0.1	-0.1	0.0	-0.1
6	-0.1	-0.1	-0.4	-0.8	-1.3	-0.4	-0.1	-0.0	-0.1	-0.1	-0.0	-0.1	-0.1	-0.2	-0.8	-0.4	-0.1	-0.2	-0.1	0.0	-0.1
7	-0.0	-0.2	-0.9	-1.1	-1.4	-0.3	0.0	-0.1	-0.0	-0.0	-0.0	-0.1	-0.1	-0.5	-0.1	-0.4	-0.4	-0.1	0.0	0.0	-0.1
8	-0.0	0.1	-0.3	-0.4	-1.1	-1.4	-0.4	-0.1	-0.0	-0.1	-0.0	-0.1	-0.1	-0.2	-0.8	-0.3	-0.1	-0.0	0.1	0.1	-0.0
9	-0.1	-0.1	-0.3	-0.4	-1.4	-0.3	-0.1	0.1	-0.0	0.0	-0.0	-0.1	-0.1	-0.1	-0.8	-0.4	-0.0	-0.0	0.0	0.0	-0.0
10	0.0	-0.0	-0.1	-0.2	-0.4	-0.9	-0.2	-0.1	0.0	0.0	0.0	0.0	0.0	-0.1	-0.8	-0.4	-0.1	0.0	0.0	0.0	0.0
11	-0.3	0.0	-0.7	1.0	-0.6	-0.2	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	-0.0	-0.4	-0.3	0.0	0.1	0.1	0.0
12	0.0	-0.1	-0.2	-0.3	-0.6	-0.2	-0.1	0.1	0.0	0.0	0.0	0.0	0.1	-0.1	-0.3	-0.3	-0.1	0.0	0.1	0.1	0.1
13	0.0	-0.3	-0.4	-0.4	-0.9	-0.1	-0.1	0.1	0.1	0.0	0.0	0.0	0.1	-0.1	-0.2	-0.4	-0.1	0.0	0.1	0.0	0.0
14	-0.0	-0.6	-2.9	-0.9	-0.6	-0.2	-0.1	0.1	0.1	-0.1	-0.1	-0.1	0.0	-0.0	-0.3	-0.2	-0.1	0.0	0.1	0.0	0.1
15	-0.0	0.0	-0.1	-0.2	-0.5	-0.1	0.0	0.0	-0.0	0.0	0.0	-0.1	-0.1	-0.6	-0.8	-0.1	-0.0	0.0	0.0	0.0	0.0
16	0.0	-0.3	-0.0	-0.3	-0.6	-0.0	0.0	0.0	0.1	0.1	0.0	-0.0	-0.0	-0.2	-0.3	-0.0	0.1	0.0	-0.1	0.0	-0.1
17	-0.3	-0.8	-0.5	-0.3	-1.3	-1.1	-0.4	-0.1	-0.1	-0.4	-0.1	-0.5	-0.1	-0.3	-0.4	-0.5	-1.2	-0.1	-0.2	-0.0	-0.1
18	0.2	-0.6	0.0	0.1	0.2	0.0	-0.1	0.0	0.0	-0.5		-1.2	-0.6	0.5	-0.2	-0.2	-0.1	0.1	0.0	0.0	0.0
19	0.2	0.2	0.1	0.2	-0.1	0.0	-0.0	0.1	0.2	0.1	0.1	-0.1	-0.2	-0.1	0.1	0.1	0.1	-0.2	-0.1	-0.2	-0.1
20	0.3	-0.5	-0.1	-0.0	0.1	-0.0	-0.0	-0.0	-0.1	-0.0	-0.0	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.1	-0.2

		North										
AR	AS	AT	AU	AV	AW	AX	AY	AZ	BA	BB	BC	BD
1	-0.9	-0.6	-0.8	-0.0	-0.1		-0.1	-0.2				
2	-0.2	-0.0	-0.4	0.0	-1.8		-0.8	-0.3	-0.3	-0.4		
3	0.0	-0.0	-0.8				-0.5	-0.4	-0.1	-0.1		
4	0.1	-0.1	-0.7	0.3	0.2	0.4	0.5	-0.2	-0.3	-0.1		
5	0.1	-0.1	-0.5	-0.1	-0.1	-0.3	-0.3	-0.4	-1.9		-0.9	
6	0.1	-0.0	-0.2	0.2	1.0	-0.1	0.3		-0.1	0.0	0.0	0.5
7	0.2	-0.0	-0.2	0.1	0.3	0.2	0.3			-0.0	0.9	
8	0.1	-0.1	-0.2	0.3	0.6	-0.0	0.1			-0.1	1.0	
9	0.2	-0.1	-0.4	-0.2	-0.1	-0.1	-0.2	-0.1		1.3		
10	0.1	-0.2	-0.7	-0.3	-0.2	-0.1	0.2	0.3	0.1	-1.8		-0.9
11	0.1	0.0	0.1	-0.3	-0.3	-0.2	0.3	0.2	0.1	-0.0	-1.7	-0.2
12	0.0	-0.2	0.0	-0.0	-0.1	-0.2	0.3	0.1		-0.3		
13	0.1	-0.1	0.0	-0.1	-0.1	-0.0	0.2	-0.4	-0.0	0.2	0.2	
14	0.1	-0.1	0.0	0.0	-0.2	-0.1			0.1			
15	0.1	0.1	-0.1	0.1	-0.0	0.0	-0.5	-0.8	-0.1	0.1	-0.0	0.3
16	-0.2	0.0	-0.2	0.1					0.2	0.9	0.6	0.6
17	-0.2	0.0	-0.1	0.2	0.4	0.2	0.3	0.2	0.2			
18	0.4	0.1	0.2	0.0	0.2	0.3	0.3	0.2	0.2			
19	-0.0	-0.0	-0.1	0.0	0.2	0.1	0.1	0.2	0.2			
20	-0.0	-0.1	0.0	0.1	0.2	0.2	0.3	0.3	0.3			

105 K East Basin General Area Survey Data - Chest Elevation

	North																				
B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	
1	0.80		1.6	5.0	3.0	1.6	0.90	1.5	0.90	1.9	1.3	3.0	4.0	4.0	4.0	4.0	4.0	5.0	3.0	4.0	
2	0.70		1.7	5.0	2.6	1.6	1.0	1.2	3.1	6.0	4.0	8.0	6.0	8.0	6.0	5.0	4.0	3.1	4.4	5.0	
3	0.60	0.90	1.0	1.3	2.0	2.0	9.0	2.9	5.0			17.0	16.0	11.0	7.0	4.0	4.0	3.5	3.4	3.6	
4	0.70	0.90	0.90	1.2	1.8	2.1	5.0	4.3	7.0			40.0	13.0	12.0	8.0	4.0	4.0	3.0	2.6	2.8	
5	0.80		0.60	1.2	1.6	2.2	5.0	8.0	8.0	13.0	16.0	20.0	29.0	18.0	10.0	7.0	5.0	4.0	2.8	2.6	
6	0.90	0.60	0.70	1.3	1.4	2.7	11.0	13.0	23.0			22.0	17.0	11.0	7.0	6.0	4.0	3.1	2.5	2.5	
7	1.0	1.0	0.90	1.2	1.2							29.0	19.0	10.0	8.0	5.0	3.0	3.0	2.5	2.5	
8	1.1	1.5	1.0	1.1	1.0							6.0	9.0	15.0	19.0	13.0	9.0	7.0	4.0	3.0	2.7
9	1.8	1.4	1.4	1.4	0.30	1.0						6.0	9.0	12.0	14.0	4.0	8.0	7.0	4.0	3.2	2.6
10			1.4	2.2	1.6	2.2						6.0	9.0	12.0	14.0	4.0	8.0	7.0	4.0	3.2	2.6
11			1.6	1.9	3.0	4.4	4.0	3.0	3.0	6.0	8.0	10.0	11.0	7.0	7.0	6.0	4.0	2.5	2.3	2.1	
12	1.9	1.4	2.3	3.2	9.0	11.0	6.0	7.0	7.0			10.0	8.0	7.0	5.0	3.0	2.7	2.5	2.2	2.2	
13	1.2	1.1	2.3	6.0	19.0	25.0	9.0	24.0	15.0			10.0	9.0	6.0	5.0	3.0	2.6	2.4	2.1	2.1	
14	1.0	1.0	1.7	4.0	5.0	5.0	7.0	7.0	9.0			10.0	8.0	6.0	5.0	4.0	2.3	2.3	2.0	2.1	
15	1.0	1.0	1.4	1.1	2.6							7.0	6.0	7.0	6.0	3.0	6.0	4.0	4.0	2.5	2.2
16	0.80	0.90	1.2	0.60	0.80							6.0	4.9	4.7	4.0	4.0	6.0	5.0	4.0	2.7	3.1
17	0.90	0.90	1.0	0.30	1.7	2.6	6.0	8.0	10.0	6.0	4.0	3.5	3.5	2.6	6.0	5.0	6.0	5.0	4.1	3.0	
18	0.50	0.60	0.80	0.80	1.6	2.3	3.6	6.0	4.0	4.0	2.7	2.5	2.0	1.5	25.0	2.7	3.2	6.0	3.5	2.0	
19	0.20	0.20	0.40	0.60	0.70	1.3	1.9	1.8			1.7	1.5	1.5	1.4	1.2	1.5	1.6	2.4	3.0	2.4	
20	0.20	0.40	0.30	0.40	0.50	0.50	0.40	0.40	0.50	0.90	0.90	0.80	0.70	0.80	11.0	1.2	1.5	1.6		8.9	
21	0.20	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.40	0.50	0.60	0.70	0.70	0.70	0.90	1.0	1.0	1.0		

	North																			
W	X	Y	Z	AA	AB	AC	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM	AN	AO	AP	AQ
1	3.0	4.0	3.0	4.0	4.0	3.0	3.0	5.0	4.0	5.0	5.0	6.0	3.8	3.9	5.0	2.8	5.0	5.0	5.0	5.0
2	5.0	5.0	4.0	5.0	5.0	6.0	4.0	5.0	3.0	4.0	5.0	6.0	7.0	3.2	4.0	7.0	6.0	5.0	4.0	3.4
3	4.0	6.0	3.0	3.4	6.0	3.8	4.0	3.4	3.4	3.7	3.8	4.4	6.0	2.7	4.0	5.0	3.8	3.6	3.3	3.4
4	3.1	5.0	2.0	2.9	5.0	3.0	2.4	2.1	2.0	2.7	2.8	3.5	5.0	1.3	3.0	4.6	2.3	2.6	2.2	2.3
5	2.5	6.0	2.0	2.6	5.0	3.0	2.0	2.5	1.5	2.1	2.4	2.7	5.0	1.7	3.0	4.2	2.4	2.4	2.1	2.5
6	3.5	5.0	2.8	4.0	4.0	2.7	2.5	1.9	1.7	1.8	2.1	2.4	3.2	1.8	3.0	2.3	2.3	2.2	2.0	3.3
7	4.1	6.0	4.0	5.0	7.0	2.5	2.0	1.7	1.7	1.8	1.8	2.3	4.0	1.5	3.0	3.6	2.1	2.0	1.8	3.0
8	3.6	5.0	3.0	3.6	6.0	2.5	2.0	1.7			1.6	1.7	2.3	4.0	1.4	4.0	3.4	2.0	2.0	1.9
9	3.6	5.0	2.4	3.0	6.0	2.5	2.2	1.7			1.5	1.8	2.3	4.0	1.3	3.0	3.7	2.1	2.0	2.0
10	3.2	5.0	1.9	2.5	5.0	2.4	2.0	1.6			1.5	1.8	2.2	5.0	1.4	3.0	3.8	1.9	2.0	1.7
11	2.8	5.0	3.3	3.1	5.0	2.0	1.7	1.3	1.3	1.4	1.6	2.2	4.0	1.2	2.2	3.6	1.9	1.9	2.0	
12	2.8	6.0	1.9	2.6	4.0	2.1	1.8	1.4	1.5	1.6	1.8	2.3	4.0	1.4	2.2	3.7	2.0	2.0	2.0	
13	2.7	5.0	2.4	2.4	4.0	2.2	2.0	1.6	1.6	1.7	1.8	2.4	5.0	1.5	2.0	3.7	2.1	2.0	2.0	
14	2.5	5.0	5.0	3.0	5.0	2.3	2.0	1.5	1.7	1.8	2.1	2.4	4.0	1.5	2.1	3.8	2.2	2.2	2.0	
15	2.5	5.0	2.3	2.6	4.0	2.2	2.0	1.8	2.1	2.1	2.5	2.8	5.0	1.8	2.2	5.0	2.4	2.5	2.4	
16	3.4	4.0	2.6	3.2	5.0	2.8	2.6	2.4	2.8	3.3	3.7	5.9	5.0	2.9	3.0	5.0	2.9	2.6	2.9	3.3
17	3.0	4.0	2.8	2.8	5.0	2.9	2.7	3.0	3.8	4.5	6.0	6.0	5.0	3.7	3.3	6.0	3.2	3.3	3.3	7.0
18	1.7	1.2	1.2	1.4	1.4	1.5	1.6	1.5	0.60	0.50		4.1	3.5	2.8	3.4	1.6	2.5	2.2		2.2
19	1.0	0.60	0.80	0.90	0.80	1.0	1.3	1.4	1.3	1.6	1.9	2.5	2.1	1.7	1.6	1.3	1.4	1.5	2.4	2.2
20	0.30	0.70	0.70	0.60	0.70	1.0											1.1	1.0	1.0	4.0
21	0.20	0.50	0.70	0.50	0.50	0.80	1.0	1.0	1.3	1.3	1.3	1.4	2.4	2.1	1.3	1.1	1.1	1.0	1.0	0.70

	North											
AR	AS	AT	AU	AV	AW	AX	AY	AZ	BA	BB	BC	BD
1	6.0	6.0	4.0	1.6	2.2		1.5	1.2				
2	7.0	7.0	8.0	5.0	6.0		5.0	1.8	1.8	2.1		
3	4.8	9.0	7.0				8.0	2.4	2.5	2.3		
4	3.8	8.0	6.0	10.0	10.0	6.0	4.4	5.0	2.8			
5	3.8	9.0	6.0	7.0	7.0	5.0	6.0	6.0	12.0	6.0		
6	3.8	8.0	8.0	10.0	9.0	7.0	6.0			11.0	6.0	1.1
7	3.6	8.0	7.0	9.0	10.0	9.0	7.0				5.0	0.90
8	3.7	8.0	8.0	11.0	21.0	11.0	9.0				4.0	0.80
9	3.8	9.0	8.0	9.0	12.0	10.0	9.0	8.0				0.60
10	3.8	8.0	7.0	7.0	11.0	11.0	9.0	9.0	7.0	5.0		0.70
11	3.1	5.0	5.0	7.0	9.0	14.0	10.0	12.0	10.0	8.0	6.0	2.6
12	3.0	6.0	4.2	4.2	7.0	7.0	9.0	11.0	11.0			
13	2.9	5.0	4.0	4.6	6.0	8.0	12.0	11.0	9.0	6.0	3.7	
14	2.9	4.0	3.8	3.6	5.0	8.0					3.5	
15	2.6	5.0	3.3	3.6	3.8	4.8	7.0	8.0	4.0	3.1	2.8	0.80
16	4.0	6.0	4.2	3.2						1.2	0.50	0.70
17	4.0	6.0	3.6	2.1	0.90	1.0	0.90	1.0	0.70			
18	4.8	3.3	1.3	1.0	0.70	0.70	0.50	1.5	0.50			
19	2.7	1.7	1.0	1.1	0.50		0.40	1.4	0.20			
20	1.7	1.0	1.0	0.90	0.50	0.30	0.30	0.30	0.10			
21	0.50	0.90	0.70	0.50	0.50	0.40	0.30	0.20	0.10			
22										0.30	0.30	
23										0.30	0.30	
24										0.40	0.30	0.10
25										0.40	0.20	0.10

105 K East Basin General Area Survey Data - Knee Elevation

	North																							
	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V			
1	0.40		2.2	12.0	3.0	1.2	0.70	1.3	1.2	2.0	2.0	3.0	6.0	5.0	5.0	4.0	4.0	9.0	4.9	5.0				
2	0.50		2.3	7.0	2.6	1.8	1.3	1.5	3.3	4.5	5.0	9.0	8.0	9.0	6.0	5.0	5.0	4.2	7.0	8.0				
3	0.60	0.80	1.0	1.5	2.0	2.4	4.0	2.6	6.0				19.0	19.0	14.0	7.0	5.0	5.0	3.3	3.2	3.0			
4	0.70	0.90	0.90	1.5	2.0	2.7	5.0	4.0	8.0				24.0	18.0	14.0	7.0	4.0	4.0	2.8	2.4	2.4			
5	0.50		0.80	1.2	2.3	4.5	6.0	10.0	10.0	12.0	13.0	15.0	18.0	14.0	10.0	5.0	5.0	5.0	2.5	2.3	2.2			
6	0.60	0.70	0.80	1.3	1.5	9.0	13.0	8.0	15.0				17.0	15.0	11.0	7.0	6.0	5.0	2.6	2.4	2.5			
7	1.0	0.80	1.0	1.3	0.40								20.0	16.0	10.0	8.0	5.0	5.0	2.7	2.3	2.3			
8	1.4	1.3	1.0	1.0	0.30								7.0	11.0	12.0	19.0	7.0	9.0	7.0	5.0	3.0	2.8	2.3	2.2
9	1.5	1.2	1.4	1.4	0.40	1.3							7.0	10.0	12.0	10.0	7.0	9.0	8.0	5.0	3.5	2.6	2.5	2.2
10			1.4	3.5	1.8	2.4							5.0	8.0	10.0	9.0	5.0	8.0	7.0	4.0	3.3	2.6	2.2	2.0
11			1.1	2.0	5.0	3.1	4.0	5.0	5.0	5.0	6.0	9.0	9.0	5.0	7.0	6.0	4.0	2.8	2.5	2.1	1.8			
12	1.9	1.7	2.3	2.5	5.0	7.0	5.0	5.0	8.0				8.0	6.0	6.0	5.0	4.0	3.0	2.4	2.2	1.8			
13	1.2	1.2	2.2	7.0	8.0	7.0	8.0	7.0	9.0				8.0	7.0	6.0	5.0	3.0	2.8	2.3	2.0	1.8			
14	1.2	1.0	1.8	5.0	7.0	6.0	7.0	6.0	10.0				6.0	8.0	6.0	5.0	3.0	2.6	2.3	2.0	1.8			
15	1.0	1.0	1.5	1.2	2.3								6.0	8.0	6.0	6.0	3.0	5.0	4.0	5.0	2.8	2.4	2.0	2.2
16	1.0	0.80	1.2	1.7	1.5								6.0	4.6	4.0	5.0	4.0	6.0	5.0	5.0	3.2	3.0	3.0	2.4
17	0.80	1.0	1.0	0.30	1.6	2.3	12.0	12.0	18.0	6.0	3.6	3.0	3.0	2.3	9.0	5.0	7.0	7.0	4.5	2.9	3.5			
18	0.70	0.70	0.90	0.20	1.6	2.6	3.6	6.0	5.0	4.0	2.5	2.1	2.2	1.5	1.6	1.6	2.3	6.0	1.8	1.5	1.2			
19	0.20	0.20	0.40	0.70	0.70	0.90	1.5	1.8		1.7	1.6	1.5	1.4	1.1	1.3	1.3	2.0	2.4	1.5	0.90	0.80			
20	0.20	0.40	0.30	0.30	0.30	0.20	0.60	0.70	0.50	0.50	0.70	0.70	0.60	0.60	0.90	1.1	1.3	1.3						
21	0.20	0.30	0.30	0.30	0.30	0.30	0.40	0.40	0.50	0.50	0.50	0.70	0.70	0.60	0.70	0.70	0.80	0.90	0.80					



	North																					
	W	X	Y	Z	AA	AB	AC	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM	AN	AO	AP	AQ	
1	5.0	5.0	5.0	5.0	5.0	3.0	4.0	7.0	11.0	5.0	7.0	6.0	7.0	4.6	4.6	5.0	4.0	5.0	5.0	6.0	7.0	
2	7.0	7.0	5.0	6.0	8.0	7.0	5.0	5.0	4.8	5.0	7.0	7.0	9.0	8.0	3.5	7.0	7.0	7.0	7.0	5.0	4.8	6.0
3	5.0	6.0	3.0	3.6	6.0	3.5	3.5	4.0	3.2	2.8	3.5	4.5	4.0	6.0	2.2	4.0	7.0	4.0	3.2	3.2	3.2	4.0
4	2.9	7.0	3.0	3.0	6.0	2.7	2.4	1.8	1.8	2.3	2.5	2.8	6.0	1.3	4.0	4.3	1.3	2.4	2.3	3.0		
5	3.1	7.0	3.0	3.2	7.0	2.8	2.0	1.8	1.8	1.8	2.0	2.5	5.0	1.5	4.0	4.3	2.4	2.4	2.4	2.3	3.3	
6	3.5	8.0	3.2	5.0	8.0	3.0	2.0	1.6	1.8	1.8	2.5	6.0	1.5	4.0	3.9	2.5	2.2	1.8	2.1	3.0		
7	3.3	7.0	7.0	7.0	8.0	2.6	1.5	1.7	1.6	1.5	1.7	2.4	8.0	1.4	3.0	3.8	2.2	1.8	2.0	2.0	3.0	
8	3.3	8.0	4.0	4.3	7.0	2.8	1.9	1.5		1.6	1.7	2.2	6.0	1.5	4.0	3.5	2.3	2.0	1.9	2.0	3.0	
9	3.2	7.0	2.5	3.5	8.0	2.5	1.5	1.9	1.8		1.5	1.6	2.3	5.0	1.3	4.0	3.9	2.0	2.0	2.0	2.3	2.8
10	2.7	6.0	2.3	3.2	6.0	2.3	1.7	1.5		1.5	1.6	2.3	6.0	1.3	4.0	3.8	2.1	1.9	2.0	2.1	2.7	
11	3.5	5.0	3.6	4.8	5.0	2.3	1.5	1.3	1.2	1.5	1.6	2.2	5.0	1.3	3.0	3.6	2.0	1.7	1.8	2.0	2.5	
12	2.5	6.0	2.3	2.8	5.0	2.2	1.9	1.4	1.5	1.6	1.8	2.4	5.0	1.4	2.7	3.8	2.2	2.0	1.9	2.0	2.4	
13	2.5	7.0	2.8	3.2	6.0	2.2	2.2	1.9	1.4	1.5	1.7	1.9	2.3	5.0	1.5	2.5	4.0	2.3	2.0	2.0	2.5	
14	2.5	8.0	10.0	4.7	5.0	2.3	1.9	1.5	1.6	2.0	2.1	2.5	5.0	1.5	2.8	3.5	2.4	2.0	2.2	2.4	2.5	
15	2.6	5.0	2.3	2.8	5.0	2.4	1.8	1.8	2.0	2.0	2.2	3.1	6.0	1.8	4.0	6.0	2.6	2.4	2.3	2.5	2.7	
16	2.9	7.0	2.2	3.5	6.0	2.6	2.2	2.3	2.3	2.6	3.6	4.2	6.0	2.0	3.5	5.0	3.0	2.5	2.8	3.4	3.6	
17	3.8	7.0	3.4	3.1	7.0	3.8	2.5	2.8	3.8	3.5	7.0	6.0	6.0	3.9	4.4	8.0	3.2	3.7	2.9	3.7	10.0	
18	1.0	0.90	1.0	1.0	0.90	1.2	1.2	1.5	0.60	0.50	2.3	4.0	0.80	1.9	1.5	1.6	1.5					
19	0.70	0.60	0.70	0.60	0.90	0.80	1.3	1.0	0.80	1.0	1.0	1.6	1.8	1.7	1.6	1.3	1.4	1.3	1.8	1.5	1.4	
20	0.30	1.6	0.80	0.80	0.60	1.2												1.6	1.5	1.4		
21	0.20	0.50	0.70	0.60	0.50	0.80	1.0	1.3	1.3	1.5	1.4	1.8	2.3	2.3	1.2	1.1	1.0	1.2	1.0	1.0	0.70	




	North																			
	AR	AS	AT	AU	AV	AW	AX	AY	AZ	BA	BB	BC	BD							
1	6.0	6.0	5.0	1.5	1.2			1.2	1.3											
2	9.0	10.0	8.0	2.8	6.0			3.0	1.8	1.7	1.7									
3	4.4	8.0	8.0					10.0	3.0	3.0	1.8	1.3								
4	3.6	9.0	7.0	10.0	12.0	5.0	4.5	5.0	3.6											
5	3.8	10.0	8.0	7.0	7.0	7.0	7.0	6.0	12.0	3.8										
6	3.6	10.0	8.0	10.0	7.0	8.0	6.0			4.0	2.5	1.1								
7	3.4	10.0	8.0	9.0	8.0	7.0	8.0						3.4	0.80						
8	3.4	10.0	9.0	11.0	9.0	10.0	9.0						3.6	0.80						
9	3.2	10.0	8.0	10.0	9.0	11.0	9.0	10.0						0.50						
10	3.4	10.0	9.0	8.0	9.0	10.0	9.0	7.0	7.0	2.2			7.0	0.70						
11	3.0	6.0	4.1	7.0	9.0	11.0	12.0	9.0	7.0	5.0	11.0	3.2	1.0							
12	3.0	6.0	3.8	5.0	7.0	10.0	9.0	9.0						5.0						
13	2.8	5.0	3.7	4.0	6.0	8.0	8.0	12.0	13.0	6.0	3.1	2.3								
14	2.8	6.0	3.6	3.5	5.0	7.0								2.1						
15	3.0	5.0	3.5	2.9	3.4	3.8	7.0	8.0	3.6	2.2	2.0	1.0								
16	5.0	6.0	4.2	2.1						1.5	0.50	0.60	0.40							
17	6.0	6.0	3.5	1.7	1.0	1.0	0.90	1.0	0.90											
18	2.3	2.0	1.6	1.0	0.80	0.50	0.50	0.60	0.60											
19	1.8	1.5	1.0	1.0	0.50					0.50	0.40	0.40								
20	1.2	1.0	0.80	0.80	0.50	0.30	0.30	0.20	0.20											

Appendix B. Contour Plots of MCNP Dose Rates


List of Contour Plots:

Measured Data (Sept 96)
All Source Regions Combined
Pool Water (20 cm)
West and East Walls of the Pool
West Inner Pool Wall
East Inner Pool Wall
North Walls of the Pool
South Walls of the Pool
Sampler at Column 10.9C & Elevator Pit Walls
East Pump Pedestal & South Loadout Drip Pan
NW Filter Media & Pump #1 on East Side
Lead Cave & Pump #2 on East Side
IX Columns inside Concrete Box
IX Box Outlet & Bypass Pipes Over Weasel Pit
Pipes from IX Box to 10' Overhead
PVC Pipes in North Loadout & Overhead
IX Modules 1 & 2 and Tech View EW Pipe (#3)
Pipe to IXM & East Pumps Overhead
Sand Filter
Riser & Pump to Sand Filter
Upper Line from Sand Filter to North Loadout
Lower Pipes from Sand Filter to Column 13D
Pipes to South Loadout Pit
N Loadout Entry (below floor) & Chiller Riser
Pipes Under Grate from West to East
Risers on North and South Side
South Overhead
Risers in Tech View Pit
Tech View Pit N-S Pipe #2
TV #3 NS
Chiller & Heat Exchanger
Pipes Over Heat Exchanger


Chest Level Dose Rates -- September 1996 Data**Chest Level Dose Rates -- MCNP Dose Rates to Match September 1996 Data**




Dose Rates (mrem/hour): East Inner Pool Wall --- Chest Level




Dose Rates (mrem/hour): North Walls of the Pool --- Chest Level




Dose Rates (mrem/hour): South Walls of the Pool --- Chest Level




Dose Rates (mrem/hour): Sampler at Column 10.9C & Elevator Pit Walls -- Chest Level




Dose Rates (mrem/hour): East Pump Pedestal & South Loadout Drip Pan -- Chest Level




Dose Rates (mrem/hour): NW Filter Media & Pump #1 on East Side -- Chest Level




Dose Rates (mrem/hour): Lead Cave & Pump #2 on East Side -- Chest Level




Dose Rates (mrem/hour): IX Columns inside Concrete Box -- Chest Level




Dose Rates (mrem/hour): IX Box Outlet & Bypass Pipes Over Weasel Pit -- Chest Level




Dose Rates (mrem/hour): Pipes from IX Box to 10' Overhead -- Chest Level




Dose Rates (mrem/hour): PVC Pipes in North Loadout & Overhead -- Chest Level




Dose Rates (mrem/hour): IX Modules 1 & 2 and Tech View EW Pipe (#3) -- Chest Level




Dose Rates (mrem/hour): Pipe to IXM & East Pumps Overhead -- Chest Level






Dose Rates (mrem/hour): Sand Filter -- Chest Level




Dose Rates (mrem/hour): Riser & Pump to Sand Filter -- Chest Level







Dose Rates (mrem/hour): N Loadout Entry (below floor) & Chiller Riser -- Chest Level






Dose Rates (mrem/hour): Pipes Under Grate from West to East -- Chest Level




Dose Rates (mrem/hour): Risers on North and South Side -- Chest Level







Dose Rates (mrem/hour): TV #3 NS -- Chest Level





Dose Rates (mrem/hour): Chiller & Heat Exchanger -- Chest Level




Dose Rates (mrem/hour): Pipes Over Heat Exchanger -- Chest Level




Knee Level Dose Rates -- September 1996 Data**Knee Level Dose Rates -- MCNP Dose Rates to Match September 1996 Data**


Dose Rates (mrem/hour): Pool Water (20 cm) -- Knee Level




Dose Rates (mrem/hour): West and East Walls of the Pool -- Knee Level




Dose Rates (mrem/hour): West Inner Pool Wall -- Knee Level




Dose Rates (mrem/hour): East Inner Pool Wall -- Knee Level.




Dose Rates (mrem/hour): North Walls of the Pool -- Knee Level




Dose Rates (mrem/hour): South Walls of the Pool -- Knee Level




Dose Rates (mrem/hour): Sampler at Column 10.9C & Elevator Pit Walls -- Knee Level




Dose Rates (mrem/hour): East Pump Pedestal & South Loadout Drip Pan -- Knee Level




Dose Rates (mrem/hour): NW Filter Media & Pump #1 on East Side -- Knee Level




Dose Rates (mrem/hour): Lead Cave & Pump #2 on East Side -- Knee Level




Dose Rates (mrem/hour): IX Columns inside Concrete Box -- Knee Level




Dose Rates (mrem/hour): IX Box Outlet & Bypass Pipes Over Weasel Pit -- Knee Level




Dose Rates (mrem/hour): Pipes from IX Box to 10' Overhead -- Knee Level




Dose Rates (mrem/hour): PVC Pipes in North Loadout & Overhead -- Knee Level




Dose Rates (mrem/hour): IX Modules 1 & 2 and Tech View EW Pipe (#3) -- Knee Level




Dose Rates (mrem/hour): Pipe to IXM & East Pumps Overhead --- Knee Level









Dose Rates (mrem/hour): Sand Filter --- Knee Level




Dose Rates (mrem/hour): Riser & Pump to Sand Filter --- Knee Level









Dose Rates (mrem/hour): South Overhead -- Knee Level




Dose Rates (mrem/hour): Risers in Tech View Pit -- Knee Level



Dose Rates (mrem/hour): Tech View Pit N-S Pipe #2 -- Knee Level




Dose Rates (mrem/hour): TV #3 NS -- Knee Level



Dose Rates (mrem/hour): Chiller & Heat Exchanger -- Knee Level




Dose Rates (mrem/hour): Pipes Over Heat Exchanger -- Knee Level




Appendix C. MCNP Geometry Data and Sketches Using SABRINA


View of the West End from the North




View of the West End from the South




View of the West End from the West




View of the East End from the North



View of the East End from the South



View of the East End from the East



Listing of the Geometry Portion of the MCNP Input

```

KE Basin Geometry -- Water Level is 16'10" -- Floor Lattices
 1   0      (-1:79:-80:95:-230:201)      $ Outside world
c Stuff at the West End =-=-=--=-=--=-=--=-=--=-=--=-=-
 2   6   -1.6000  -305  215  -207          $ Sand in Filter
 3   4   -7.8600  -306  216  -206  (305:207:-215)    $ Sand Filter Vessel
 4   2   -0.0012  15  -18  123  -126  219  -205    $ Air around tank
   -125 (306:206:-216)
 5   5   -1.5730  16  -17  127  -128  212  -204    $ Pipe Opening
 6   1   -2.2580  14  -19  122  -128  219  -204  -124 $ Sand Filter Walls
   (-16:17:-127:-212) (-15:18:-123:126:205:125)
 7   2   -0.0012  29  -30  97  -98  222  -217    $ Washing Pit Air
   (-99:-31)
 8   1   -2.2580  28  -27  96  -118  222  -217    $ Wash Pit Concrete
   (-99:-31) (-29:30:-97:98)
 9   3   1.0000  -302  219  -206          $ IX Cell #3
10   3   -1.0000  -303  219  -206          $ IX Cell #2
11   3   -1.0000  -304  219  -206          $ IX Cell #1
12   2   -0.0012  52  -33  100  -101  219  -206  302 $ IX Cell #3 Air
13   2   -0.0012  32  -33  102  -103  219  -206  303 $ IX Cell #2 Air
14   2   -0.0012  32  -33  104  -105  219  -206  304 $ IX Cell #1 Air
15   1   -2.2580  31  -27  99  -118  222  -206    $ IX Box Concrete
   (-32:33:(-100:(101 -102):(103 -104):105):-219:206)
16   2   -0.0012  27  -34  107  -108  219  -209    $ Lead Cave Air
17   8   -11.350  27  -35  106  -109  219  -208  #16 $ Lead Cave
18   5   -1.5730  37  -38  111  -112  214  -211    $ IX #2 Tanks
19   1   -2.2580  36  -39  110  -113  219  -210  #18 $ IX #2 Concrete
20   5   -1.5730  37  -38  115  -116  214  -211    $ IX #1 Tanks
21   1   -2.2580  36  -39  114  -117  219  -210  #20 $ IX #1 Concrete
22   3   -1.0000  21  -26  119  -120  230  -226  317 $ N Loadout Water
23   3   -1.0000  23  -24  120  -121  230  -226  $ N Loadout Water
24   3   -1.0000  22  -25  121  -129  229  -226  $ N Loadout Water
25   2   -0.0012  21  -26  119  -120  228  -213  277 317 355 $ N L Air
26   2   -0.0012  23  -24  120  -121  226  -213  277 $ N Loadout Air
27   2   -0.0012  22  -25  121  -129  226  -219  277 $ N Loadout Air
28   3   -1.0000  119  -129  278  -278          $ Pipe Water
29   4   -7.8600  119  -129  278  -277          $ Pipe in N Loadout
30   1   -2.2580  20  -27  118  -121  230  -213  $ N Loadout Concrete
   (-21:26:-119:120) (-23:24:-120:121:-230)
31   3   -1.0000  41  -46  119  -120  230  -226  325 $ S Loadout Water
32   3   -1.0000  43  -44  120  -121  230  -226  $ S Loadout Water
33   3   -1.0000  42  -45  121  -129  229  -226  $ S Loadout Water
34   2   -0.0012  41  -46  119  -120  226  -213  325 $ S Loadout Air
35   2   -0.0012  43  -44  120  -121  226  -213  $ S Loadout Air
36   2   -0.0012  42  -45  121  -129  226  -219  $ S Loadout Air
37   3   -1.0000  128  198  -268          $ Water - SF Upper
38   4   -7.8600  128  198  -268  -267          $ Pipe - SF Upper
39   3   -1.0000  -198  170  -316          $ Water - SF #2
40   4   -7.8600  -198  170  -316  -315          $ Pipe - SF #2
41   3   -1.0000  -170  -199  -242          $ Water - SF #3
42   4   -7.8600  -170  -199  242  -241          $ Pipe - SF #3
43   3   -1.0000  -200  199  -270          $ Water - SF #4
44   4   -7.8600  -200  199  -270  -269          $ Pipe - SF #4
45   3   -1.0000  -230  200  -318          $ N Load Riser Water
46   4   -7.8600  -230  200  -318  -317          $ N Load Riser Pipe
47   3   -1.0000  -128  169  -280          $ Water - SF Lower
48   4   -7.8600  -128  169  -280  -279          $ Pipe - SF Lower
49   3   -1.0000  -169  170  -322          $ Water - 13B Riser
50   4   -7.8600  -169  170  -322  -321          $ Pipe - 13B Riser
51   3   -1.0000  -170  171  -248          $ Water in N-S Pipe
52   4   -7.8600  -170  171  -248  -247          $ N-S Pipe (9.5 ft)
53   3   -1.0000  -171  172  -282          $ Water Short EW
54   4   -7.8600  -171  172  -282  -281          $ Pipe Short EW
55   3   -1.0000  -229  172  -324          $ Water Riser 13D
56   4   -7.8600  -229  172  -324  -323          $ Pipe Riser 13D
57   3   -1.0000  -64  -173  -248          $ Water S Ovrhd
58   4   -7.8600  -64  -173  248  -247          $ Pipe S Ovrhd
59   3   -1.0000  -174  173  -284          $ Water from S Load
60   4   -7.8600  -174  173  -284  -283          $ Jog Pipe by S Load
61   3   -1.0000  -230  174  -326          $ S Load Riser Water
62   4   -7.8600  -230  174  -326  -325          $ S Load Riser Pipe
63   1   -2.2580  40  -47  118  -121  230  -213  $ S Loadout Concrete
   (-41:46:-119:120) (-43:44:-120:121:-230)

```

64	1	-2.2580	1	-22	121	-129	229	-219	\$ West Wall of Pool	
65	1	-2.2580	25	-42	121	-129	229	-219	\$ West Wall of Pool	
66	1	-2.2580	45	-13	121	-129	229	-219	\$ West Wall of Pool	
67	1	-2.2580	1	-27	120	-121	230	-219	\$ Loadout Floor N (-20:-118) (-28:-96:118:-222)	
68	1	-2.2580	27	-78	80	-121	230	-219	\$ Loadout Floor S (-40:47:-118)	
69	3	-1.0000	219	-211	-301				\$ NW Filter Media	
70	3	-1.0000	128	-175	-272				\$ Water in SF Pump	
71	4	-7.8600	128	-175	272	-271			\$ Sand Fltr Pump	
72	3	-1.0000	100	197	-276				\$ Water IX Box Out	
73	4	-7.8600	100	197	276	-275			\$ IX Box Outlet	
74	3	-1.0000	197	196	-244				\$ Water IX/Loadout	
75	4	-7.8600	197	196	244	-243			\$ IX Box/N Loadout	
76	3	-1.0000	196	195	-274				\$ N Loadout Water	
77	4	-7.8600	196	195	274	-273			\$ N Loadout Pipe	
78	3	-1.0000	195	194	-320				\$ W Riser Water	
79	4	-7.8600	195	194	320	-319			\$ W Riser	
80	3	-1.0000	194	-27	246				\$ W OvrHd Water N	
81	4	-7.8600	194	-27	246	-245			\$ W Overhead N	
82	3	-1.0000	101	193	-288				\$ OvrHd to IXM	
83	4	-7.8600	101	193	286	-285			\$ Pipe to IXM	
84	3	-1.0000	-193	192	-246				\$ W OvrHd Water S	
85	4	-7.8600	-193	192	246	-245			\$ W Overhead S	
86	2	-0.0012	226	-201	-355				\$ PVC Riser in NL	
87	2	-0.0012	1	-8	-264				\$ PVC Pipe NS	
88	2	-0.0012	1	-19	80	-129	219	-201	\$ North Air to SF S (-14:-122:128:204:124) (-128:271) (301:211) (267:-128:-198) (315:198:-170) (241:170) 264 (279:-128:-169) (321:169:-170) (247:170)	
89	2	-0.0012	19	-27	80	-129	219	-201	355 \$ Air SF S to NL S (-20:-118:121:213) (-28:-96:118:217) (317:-200) 247 264 (-31:-99:-118:204) (245:194) (319:-194:195) (273:-195:196) (241:199) (269:200:-199) (243:-196:197) (275:-100:-197)	
90	2	-0.0012	27	-11	80	-129	219	-201	\$ South Air (-36:39:-110:117:210:(113:-114)) (287:192) (285:-101:-193) (245:193:-192) (264:8) (35:-106:109:208) (-40:47:-118:121:213) (-64:173:247) (247:-171) (281:171) (283:174:-173) (-174:325)	
c	Stuff in the Pool Area	---	---	---	---	---	---	---	---	
91	1	-2.2580	2	-4	132	-135	229	-221	\$ NW Gate Conc	
92	3	-1.0000	2	-6	132	-136	229	-226	\$ NW Gate Water (135:(4:-5))	
93	2	-0.0012	2	-6	132	-136	226	-221	\$ NW Gate Air (135:(4:-5)) 265	
94	1	-2.2580	5	-8	132	-136	229	-221	\$ West Inner Wall (6:-135) (-7:133)	
95	2	-0.0012	7	-11	132	-136	226	-221	\$ SW Gate Air (-133:(8:-9))	
96	3	-1.0000	7	-11	132	-136	229	-226	\$ SW Gate Water (-133:(8:-9))	
97	1	-2.2580	9	-11	133	-136	229	-221	\$ SW Gate Conc	
98	1	-2.2580	2	-4	145	-148	229	-221	\$ NE Gate Conc	
99	3	-1.0000	2	-6	145	-149	229	-226	\$ NE Gate Water (148:(4:-5))	
100	2	-0.0012	2	-6	145	-149	226	-221	\$ NE Gate Air (148:(4:-5)) 265	
101	1	-2.2580	5	-8	145	-149	229	-221	\$ East Inner Wall (6:-148) (-7:146)	
102	2	-0.0012	7	-11	145	-149	226	-221	\$ SE Gate Air (-146:(8:-9))	
103	3	-1.0000	7	-11	145	-149	229	-226	\$ SE Gate Water (-146:(8:-9))	
104	1	-2.2580	9	-11	146	-149	229	-221	\$ SE Gate Conc	
105	3	-1.0000	-176	175	-308				\$ W Riser Water	
106	4	-7.8600	-176	175	308	-307			\$ W Riser Upper	
107	3	-1.0000	176	177	-232				\$ W Pipe Water	
108	4	-7.8600	176	177	232	-231			\$ W Pipe Upper	
109	3	-1.0000	(-177	179	-266):	(223	178:(-310:-312:-314))		\$ N Water	
110	4	-7.8600	(-177	179	-265):	(223	178:(-309:-311:-313))	#109		\$ N Upper Pipe
111	3	-1.0000	1	-178	-234				\$ Valve Water	
112	4	-7.8600	1	-178	234	-233			\$ Horiz Col 12	
113	3	-1.0000	1	-178	-236				\$ Valve Water	

114	4	-7.8600	1	-178	236	-235	\$ Horiz Col 10		
115	3	-1.0000	1	-178	-238	\$ Valve Water			
116	4	-7.8600	1	-178	238	-237	\$ Horiz Col 8		
117	3	-1.0000	-179	-58	-240	\$ NE Pipe Water			
118	4	-7.8600	-179	-58	240	-239	\$ NE Pipe		
119	3	-1.0000	(59	-38	-240):	(223 180(-334:-336:-338))	\$ E Pipe Water		
120	4	-7.8600	((59	-38	-239):	(223 180(-333:-335:-337)))	\$ E Pipe Plenum		
						#119	\$ E Pipe Plenum		
c Overhead piping along S Wall									
121	3	-1.0000	-192	191	-288		\$ S Ovrhd Water		
122	4	-7.8600	-192	191	288	-287	\$ S Pipe Ovrhd		
123	3	-1.0000	229	-210	328		\$ S Ovrhd Water W		
124	4	-7.8600	229	-210	328	-327	\$ S Pipe Ovrhd W		
125	3	-1.0000	229	-210	330		\$ S Ovrhd Water Mid		
126	4	-7.8600	229	-210	330	-329	\$ S Pipe Ovrhd Mid		
127	3	-1.0000	229	-210	332		\$ S Ovrhd Water E		
128	4	-7.8600	229	-210	332	-331	\$ S Pipe Ovrhd E		
c Fuel Cannisters and Pool Water									
129	7	-3.0000	18	-65	130	-131	229	-228	\$ West Pool Fuel
130	7	-3.0000	18	-65	137	-144	229	-228	\$ Middle Pool Fuel
131	7	-3.0000	18	-65	150	-157	229	-228	\$ East Pool Fuel
132	3	-1.0000	2	-11	129	-132	229	-226	\$ West Pool Water
						323	327	#129	
133	3	-1.0000	2	-11	136	-145	229	-226	\$ Middle Pool Water
						329	#130		
134	3	-1.0000	2	-11	149	-158	229	-226	\$ East Pool Water
						331	#131		
135	2	-0.0012	2	-11	129	-132	226	-221	327 \$ West Pool Air
						(-223:309)	(265:177)	(176:307)	(-177:-176:231) 327
136	2	-0.0012	2	-11	136	-145	226	-221	329 \$ Middle Pool Air
						(-223:311)		265	
137	2	-0.0012	2	-11	149	-158	226	-221	331 \$ East Pool Air
						(-223:(313 333 335 337))	(-179:265)	(179:58:239)	(-59:38:239)
138	1	-2.2580	1	-2	129	-158	229	-219	\$ North Pool Wall
139	1	-2.2580	1	-79	121	-95	230	-229	\$ Bottom of Pool
						(-78:165)			
c Lead sheets on grating									
140	8	-11.350	2	-3	129	-158	219	-218	\$ Lead North
						309	311	313	
141	8	-11.350	3	-10	129	-130	219	-218	307 323 \$ Lead West
142	2	-0.0012	3	-10	130	-131	219	-218	\$ Air West
143	8	-11.350	3	-10	131	-132	219	-218	\$ Lead Inner W
144	2	-0.0012	3	-10	132	-136	219	-218	\$ Air Inner W
145	8	-11.350	3	-10	136	-137	219	-218	\$ Lead Inner W
146	2	-0.0012	3	-10	137	-144	219	-218	\$ Air Middle
147	8	-11.350	3	-10	144	-145	219	-218	\$ Lead Inner E
148	2	-0.0012	3	-10	145	-149	219	-218	\$ Air Inner E
149	8	-11.350	3	-10	149	-150	219	-218	\$ Lead Inner E
150	2	-0.0012	3	-10	150	-157	219	-218	\$ Air East
151	8	-11.350	3	-10	157	-158	219	-218	\$ Lead East
						333	335	337	
152	8	-11.350	10	-11	129	-158	219	-218	\$ Lead South
						327	329	331	
153	0		2	-11	129	-134	221	-220	309 327 \$ W Supports
			307	323	fill=1	(850.90 2795.27		-25.40)	
154	0		2	-11	134	-147	221	-220	311 329 \$ Mid Supports
			fill=1	(850.90 3694.43		-25.40)			
155	0		2	-11	147	-158	221	-220	313 331 \$ E Supports
			333	335	fill=1	(850.90 4593.59		-25.40)	
156	0		2	-11	129	-158	220	-219	307 \$ Grating
			309	311	313	323	327	329	331 333 335 337
			fill=3	(1064.26 3692.53		-3.18)			
157	2	-0.0012	2	-11	129	-134	218	-201	\$ W Grate Posts
			(178:233)	(-178:309)	(210:327)	287	(-175:307)	(175:271)	
			(-172:323)	(172:281)					
158	2	-0.0012	2	-11	134	-147	218	-201	\$ Mid Grate Posts
			(178:235)	(-178:311)	(210:329)	287			
159	2	-0.0012	2	-11	147	-158	218	-201	\$ E Grate Posts
			(178:237)	(-178:313)	(210:331)	287			
			(180:(291 293 295))	(-180:(333 335 337))					
160	2	-0.0012	1	-2	129	-158	219	-201	233 235 237

c Stuff at the South Side -----
 161 1 -2.2580 11 -13 129 -140 229 -219 \$ South Pool Wall
 (76:-139)
 162 1 -2.2580 13 -78 121 -138 229 -219 \$ South Floor W
 163 1 -2.2580 11 -77 141 -153 229 -219 \$ Discharge Island
 (76:(142 -152)) -143 151
 164 3 -1.0000 13 -78 138 -156 229 -226 \$ Discharge Water
 (77:-141:143:-151:153)
 165 3 -1.0000 11 -13 139 -142 229 -226 \$ Discharge Water
 (-76:(140 -141))
 166 3 -1.0000 11 -13 152 -155 229 -226 \$ Discharge Water
 (-76:(153 -154))
 167 2 -0.0012 13 -78 138 -156 226 -219 \$ Discharge Air
 (77:-141:143:-151:153)
 168 2 -0.0012 11 -13 139 -142 226 -219 \$ Discharge Air
 (-76:(140 -141))
 169 2 -0.0012 11 -13 152 -155 226 -219 \$ Discharge Air
 (-76:(153 -154))
 170 1 -2.2580 13 -79 156 -95 229 -219 \$ South Floor E
 (-78:165)
 171 1 -2.2580 11 -13 154 -158 229 -219 \$ South Pool Wall
 (76:155)
 172 1 -2.2580 11 -13 81 -82 219 -201 \$ Concrete Col 12.2
 173 8 -11.350 11 -12 82 -83 219 -209 \$ Lead at Col 12.2
 174 1 -2.2580 11 -13 84 -85 219 -201 \$ Concrete Col 11.2
 175 1 -2.2580 11 -13 86 -138 219 -201 \$ Concrete Col 10.4
 176 8 -11.350 11 -12 87 -88 219 -209 \$ Lead at Col 9.5
 177 1 -2.2580 11 -13 88 -89 219 -201 \$ Concrete Col 9.5
 178 8 -11.350 11 -12 89 -90 219 -209 \$ Lead at Col 9.5
 179 1 -2.2580 11 -13 91 -92 219 -201 \$ Concrete Col 8.6
 180 1 -2.2580 11 -13 156 -93 219 -201 \$ Concrete Col 7.7
 181 8 -11.350 11 -12 93 -96 219 -209 \$ Lead at Col 7.7
 182 1 -2.2580 11 -13 158 -159 219 -201 \$ Concrete Col 7.1
 183 2 -0.0012 11 -13 79 -80 95 219 -201 \$ Air in South Side
 (-78:165) ((13:((-81:82) (-84:85) (-86:138)))
 ((13:((-88:89) (-91:92) (-156:93) (-158:159)))
 ((12:((-82:83) (-87:88) (-89:90) (-93:94)):209))
 184 1 -2.2580 78 -79 80 -165 230 -201 \$ Reactor Face
 c Stuff at the East End -----
 185 1 -2.2580 59 -64 158 -159 229 -219 \$ East Wall of Pool
 186 1 -2.2580 73 -13 158 -159 229 -219 \$ East Wall of Pool
 187 3 -1.0000 -252 55 -56 \$ Chiller Innards
 188 4 -7.8600 -251 54 -57 ((252:-55:56)) \$ Chiller Vessel
 189 3 -1.0000 -254 49 -50 \$ Heat Exch Water
 190 5 -1.5730 -254 50 -51 \$ Heat Exch Innards
 191 3 -1.0000 -254 51 -52 \$ Heat Exch Water
 192 4 -7.8600 -253 48 -53 ((254:-49:52)) \$ Heat Exch Vessel
 193 8 -11.350 -255 48 -53 253 \$ Heat Exch Lead
 194 3 -1.0000 -180 181 -292 \$ E Pipe Water
 195 4 -7.8600 -180 181 -292 \$ E Pipe #1
 196 3 -1.0000 -180 -159 -294 \$ E Pipe Water
 197 4 -7.8600 -180 -159 294 -293 \$ E Pipe #2
 198 3 -1.0000 -180 181 -296 \$ E Pipe Water
 199 4 -7.8600 -180 181 296 -295 \$ E Pipe #3
 200 3 -1.0000 -181 182 -340 \$ #1/Riser Water
 201 4 -7.8600 -181 182 340 -339 \$ #1/Riser Pipe
 202 3 -1.0000 (219 -203 -342):(-182 183 -263) \$ #2 Riser/Ohd Wrtr
 203 4 -7.8600 ((219 -203 -341):(-182 183 -262)) #202 \$ #2 Pipe
 204 3 -1.0000 -183 184 -290 \$ Over Pump #3 Wrtr
 205 4 -7.8600 -183 184 290 -289 \$ Over Pump #3 Pipe
 206 3 -1.0000 (-184 -185 -261):(217 -203 -346) \$ TV #3 Water
 207 4 -7.8600 (((-184 -185 -260):(217 -203 -345)) #206 \$ TV #3 Pipe
 208 3 -1.0000 229 185 -352 \$ TV Riser #3 Water
 209 4 -7.8600 229 185 352 -351 \$ TV Riser #3 Pipe
 210 3 -1.0000 229 -202 -348 \$ TV Riser #1 Water
 211 4 -7.8600 229 -202 348 -347 \$ TV Riser #1 Pipe
 212 3 -1.0000 229 186 -350 \$ TV Riser #2 Water
 213 4 -7.8600 229 186 350 -349 \$ TV Riser #2 Pipe
 214 3 -1.0000 (187 -186 -259):((217 -202 -344): (-190 189 -298):((219 -202 -354)) \$ Big Cross Water
 215 4 -7.8600 ((187 -186 -258):((217 -202 -343): (-190 189 -297):((219 -202 -353)) #214 \$ Big Cross Pipe
 216 3 -1.0000 -188 -189 -257 \$ Over HX Water
 217 4 -7.8600 -188 -189 257 -256 \$ Over HX Pipe
 218 3 -1.0000 -187 188 -300 \$ To HX Water

219 4 -7.8600 -187 188 300 -299 \$ To HX Pipe
 220 3 -1.0000 190 -191 -250 \$ E Dvrhd Water
 221 4 -7.8600 190 -191 250 -249 \$ E Dvrhd NS
 222 3 -1.0000 58 -61 158 -161 229 -226 \$ Water in Elevator
 (-59:-159) (-60:-160)
 223 2 -0.0012 58 -61 158 -161 226 -219 \$ Air in Elevator
 (-59:-159) (-60:-160)
 224 1 -2.2580 62 -75 162 -168 219 -217 \$ SE Pit's Curb
 (-63:-74:-167)
 225 2 -0.0012 63 -74 162 -167 219 -217 \$ Air over SE Pits
 347 349 351
 226 1 -2.2580 63 -64 162 -163 229 -219 \$ Weasel N Concrete
 227 3 -1.0000 63 -66 158 -167 229 -226 \$ Weasel Pit Water
 ((64 -65:-159) (64:-162:-163) (-65:-162:-165))
 228 2 -0.0012 63 -66 158 -167 226 -219 \$ Weasel Pit Air
 ((64 -65:-159) (64:-162:-163) (-65:-162:-165))
 229 1 -2.2580 65 -68 158 -167 229 -219 \$ Weasel/Viewing
 ((66 -67:-159:-162) (66:-165) (-67:-163))
 230 1 -2.2580 69 -72 158 -163 229 -219 \$ Viewing Pit Wall
 ((70 -71:-159:-162))
 231 3 -1.0000 67 -74 158 -164 229 -226 \$ Viewing Pit Water
 ((68 -73):(-159 -162:-163)) #230 347 349 351
 232 2 -0.0012 67 -74 158 -164 226 -219 \$ Viewing Pit Air
 ((68 -73):(-159 -162:-163)) #230 347 349 351
 233 1 -2.2580 73 -74 162 -163 229 -219 \$ Viewing S Concrete
 234 1 -2.2580 67 -74 164 -167 229 -224 \$ Viewing Pit Floor
 (-166:-225) (-165:-166:-227)
 235 2 -0.0012 67 -74 164 -167 227 -219 \$ Viewing Pit Air
 (-166:-225) (-165:-224)
 236 1 -2.2580 1 -13 158 -95 229 -219 \$ East Floor
 (-58:-61:(60 160:-161)) (-63:-74:-167) (-58:-159)
 237 2 -0.0012 1 -57 158 -95 219 -201 \$ East Air North
 (-54:-251) (-48:-255) ((159:-293))
 (-181:-291) ((181:-182:-339)) ((182:-262)) (203:341)
 (187:-188:-299) (-187:-258) (188:-256)
 238 2 -0.0012 57 -62 158 -95 219 -201 \$ East Air Middle
 (-181:295) ((184:-260) (183:-184:-289)) (-183:262)
 258 (-190:249) (189:256) (-189:190:297)
 (202:353) (53:255)
 239 2 -0.0012 62 -11 158 -95 219 -201 \$ East Air South
 (75:-162:168:217) (-191:287) (191:249)
 (202:343) (-186:-349) (186:-258) (202:347)
 (203:345) (-185:-351) (185:-260)

c Universes to Represent the Grating Supports ==-===-=--=-=--=

240 0 356 -363 364 -369 fill=2 u=1 lat=1 \$ Support Beams
 241 2 -0.0012 (-357 -362 365 -368 370 -371): \$ Air
 (360 -361 366 -367) u=2
 242 4 -7.8600 (-357:362:-365:368:-370:371) \$ Beams
 (-360:361:-366:367) u=2
 243 0 356 -359 fill=4 u=3 lat=1 \$ Grating
 244 2 -0.0012 357 -358 u=4 \$ Air
 245 4 -7.8600 (-357:358) u=4 \$ Grate

c X Coordinates

c PX 0.00 \$ Column A
 c PX 424.18 \$ Column B
 c PX 614.68 \$ Column Bd
 c PX 850.90 \$ Column C
 c PX 1277.62 \$ Column D
 c PX 1704.34 \$ Column E
 c PX 2131.06 \$ Column F
 c PX 2580.64 \$ Column G

c Pool Walls

1 PX -25.40 \$ N Wall Outer
 2 PX 20.32 \$ North Wall
 3 PX 91.44 \$ Lead Boundary
 4 PX 40.64 \$ North Gate N
 5 PX 137.16 \$ North Gate S
 6 PX 157.48 \$ North Indent
 7 PX 1971.04 \$ South Indent
 8 PX 1991.36 \$ South Gate N
 9 PX 2087.88 \$ South Gate S
 10 PX 2037.08 \$ Lead Boundary
 11 PX 2108.20 \$ South Wall
 12 PX 2113.28 \$ S Lead Wall
 13 PX 2153.92 \$ S Wall Outer

c Sand Filter Walls
 14 PX 197.49 \$ N Wall Outer
 15 PX 227.97 \$ N Wall Inner
 16 PX 421.01 \$ Pipe Gap N
 17 PX 441.33 \$ Pipe Gap S
 18 PX 456.57 \$ S Wall Inner
 19 PX 487.05 \$ S Wall Outer

c North Loadout Pit Details
 20 PX 596.90 \$ Outer wall N Curb
 21 PX 637.54 \$ Inner wall N Curb
 22 PX 695.96 \$ N Side Opening to Pool
 23 PX 711.20 \$ Inner Gate N
 24 PX 777.24 \$ Inner Gate S
 25 PX 792.48 \$ S Side Opening to Pool
 26 PX 850.90 \$ Inner wall S Curb
 27 PX 891.54 \$ Outer wall S Curb

c Washing Pit & IX Modules
 28 PX 546.10 \$ Washing Pit N Curb
 29 PX 566.42 \$ Washing Pit N Wall
 30 PX 871.22 \$ Washing Pit S Wall
 31 PX 708.66 \$ IX Box N Wall Outer
 32 PX 754.38 \$ IX Box N Wall Inner
 33 PX 845.82 \$ IX Box S Wall Inner
 34 PX 967.74 \$ Lead Cave S Inner
 35 PX 972.82 \$ Lead Cave S Outer
 36 PX 988.06 \$ IX Modules N Wall
 37 PX 1036.32 \$ IX Modules N Wall Inner
 38 PX 1158.24 \$ IX Modules S Wall Inner
 39 PX 1206.50 \$ IX Modules S Wall

c South Loadout Pit Details
 40 PX 1351.28 \$ Outer wall N Curb
 41 PX 1391.92 \$ Inner wall N Curb
 42 PX 1450.34 \$ N Side Opening to Pool
 43 PX 1465.58 \$ Inner Gate N
 44 PX 1531.62 \$ Inner Gate S
 45 PX 1546.86 \$ S Side Opening to Pool
 46 PX 1605.28 \$ Inner wall S Curb
 47 PX 1645.92 \$ Outer wall S Curb

c Heat Exchanger Equipment
 48 PX 492.76 \$ N end Heat Exchanger
 49 PX 497.33 \$ Inner Heat Exchanger N
 50 PX 601.47 \$ Heat Exchanger Tubesheet N
 51 PX 1082.55 \$ Heat Exchanger Tubesheet S
 52 PX 1186.69 \$ Inner Heat Exchanger S
 53 PX 1191.26 \$ S end Heat Exchanger
 54 PX 614.68 \$ N end Chiller
 55 PX 619.76 \$ Inner Chiller
 56 PX 1013.46 \$ Inner Chiller
 57 PX 1018.54 \$ S end Chiller

c Elevator Pit Walls
 58 PX 256.54 \$ Gate N
 59 PX 347.98 \$ Gate S
 60 PX 408.94 \$ Inner Wall S
 61 PX 454.66 \$ South Wall Inner

c South Pit Walls
 62 PX 1262.38 \$ Weasel Curb N Outer
 63 PX 1292.86 \$ Weasel Pit N Wall
 64 PX 1320.80 \$ Weasel Gate N
 65 PX 1417.32 \$ Weasel Gate S
 66 PX 1460.50 \$ Weasel Pit S Wall
 67 PX 1496.06 \$ Viewing Pit N Wall
 68 PX 1521.46 \$ N Gate to Viewing Pit N
 69 PX 1617.98 \$ N Gate to Viewing Pit S
 70 PX 1658.62 \$ Gate Divider N
 71 PX 1694.18 \$ Gate Divider S
 72 PX 1734.82 \$ S Gate to Viewing Pit N
 73 PX 1831.34 \$ S Gate to Viewing Pit S
 74 PX 1856.74 \$ Viewing Pit S Wall
 75 PX 1887.22 \$ Viewing Curb Outer S

c Reactor Discharge
 76 PX 2131.06 \$ Gate Indent
 77 PX 2260.60 \$ S Island
 78 PX 2557.78 \$ Reactor N Face
 79 PX 2672.08 \$ Reactor N

c Y Coordinates

80	PY	0.00	\$ Column 16	0.00	Column 16
c	Concrete Columns - S Wall			593.09	Column 15
81	PY	2291.08	\$ Col 12.2 W	1172.21	Column 14
82	PY	2336.80	\$ Col 12.2 E	1751.33	Column 13
83	PY	2397.76	\$ Col 12.2 Pb	2391.41	Column 12
84	PY	2879.09	\$ Col 11.2 W	3031.49	Column 10.9
85	PY	2924.81	\$ Col 11.2 E	3694.43	Column 10
86	PY	3458.21	\$ Col 10.4 W	4357.37	Column 8.9
87	PY	3732.53	\$ Col 9.5 Pb	4989.83	Column 8
88	PY	3991.61	\$ Col 9.5 W	5622.29	Column 7.1
89	PY	4037.33	\$ Col 9.5 E	5927.09	Column 6
90	PY	4098.29	\$ Col 9.5 Pb	6292.85	Column 5
91	PY	4570.73	\$ Col 8.6 W	6656.07	Column 4
92	PY	4616.45	\$ Col 8.6 E	7039.61	Column 3
93	PY	5169.85	\$ Col 7.7 E	7265.35	Column 2.3
94	PY	5210.81	\$ Col 7.7 Pb	7832.09	Column 1.5
95	PY	8324.85	\$ Column 1	8324.85	Column 1

c Washing Pit & IX Modules

96	PY	687.07	\$ West Wall, Outer		
97	PY	707.39	\$ West Wall, Inner		
98	PY	1215.39	\$ East Wall, Inner		
99	PY	7715.51	\$ IX Box W Wall Outer		
100	PY	824.23	\$ Cell #3 West Wall		
101	PY	915.67	\$ Cell #3 East Wall		
102	PY	961.39	\$ Cell #2 West Wall		
103	PY	1052.83	\$ Cell #2 East Wall		
104	PY	1098.55	\$ Cell #1 West Wall		
105	PY	1189.99	\$ Cell #1 East Wall		
106	PY	793.75	\$ Lead Cave W Outer		
107	PY	798.83	\$ Lead Cave W Inner		
108	PY	1215.39	\$ Lead Cave E Inner		
109	PY	1220.47	\$ Lead Cave E Outer		
110	PY	831.85	\$ IX Module #2 W Outer		
111	PY	880.11	\$ IX Module #2 W Inner		
112	PY	961.39	\$ IX Module #2 E Inner		
113	PY	1009.65	\$ IX Module #2 E Outer		
114	PY	1070.61	\$ IX Module #1 W Outer		
115	PY	1118.87	\$ IX Module #1 W Inner		
116	PY	1200.15	\$ IX Module #1 E Inner		
117	PY	1248.41	\$ IX Module #1 E Outer		

c Loadout Pits Details

118	PY	1235.71	\$ West Wall, Outer		
119	PY	1280.80	\$ West Wall, Inner		
120	PY	1560.83	\$ East Wall, Inner		
121	PY	1601.47	\$ East Wall, Outer		

c Sand Filter Walls

122	PY	1240.79	\$ West Wall, Outer		
123	PY	1271.27	\$ West Wall, Inner		
124	P	1.5652	-1.0000 0.0000	-580.69	\$ Slanted Wall Outer
125	P	1.5652	-1.0000 0.0000	-637.30	\$ Slanted Wall Inner
126	PY	1499.87	\$ East Wall, Inner		
127	PY	1515.11	\$ Pipe Gap		
128	PY	1530.35	\$ East Wall, Outer		

c Pool Walls

129	PY	1785.62	\$ West Wall of Pool		
130	PY	1842.77	\$ Lead Boundary		
131	PY	2957.83	\$ Lead Boundary		
132	PY	3001.01	\$ Inner Wall West		
133	PY	3021.33	\$ Gate S Indent		
134	PY	3031.49	\$ West Wall Center		
135	PY	3041.65	\$ Gate N Indent		
136	PY	3061.97	\$ Inner Wall West		
137	PY	3105.15	\$ Lead Boundary		
138	PY	3503.93	\$ Discharge W Inner		
139	PY	3521.71	\$ Indent		
140	PY	3542.03	\$ Gate W		
141	PY	3638.55	\$ Island W		
142	PY	3658.87	\$ Indent		
143	P	1.0000	-1.0000 0.0000	-1416.05	\$ SW Slant Line
144	PY	4283.71	\$ Lead Boundary		
145	PY	4326.89	\$ Inner Wall East		
146	PY	4347.21	\$ Gate S Indent		
147	PY	4357.37	\$ East Wall Center		
148	PY	4367.53	\$ Gate N Indent		

149 PY 4387.85 \$ Inner Wall East
 150 PY 4431.03 \$ Lead Boundary
 151 P -1.0000 -1.0000 0.0000 -7146.29 \$ SE Slant Line
 152 PY 4903.47 \$ Indent
 153 PY 4923.79 \$ Island E
 154 PY 5020.31 \$ Gate E
 155 PY 5040.63 \$ Indent
 156 PY 5104.13 \$ Discharge E Inner
 157 PY 5543.55 \$ Lead Boundary
 158 PY 5599.43 \$ East Wall W
 159 PY 5645.15 \$ East Wall E
 c Elevator Pit Walls
 160 PY 5911.85 \$ Corner W Wall
 161 PY 6257.29 \$ East Wall Inner
 c South Pit Walls
 162 PY 5919.47 \$ Gate to Pits
 163 PY 5944.87 \$ Pit West Wall
 164 PY 6290.31 \$ Viewing Dam W
 165 PY 6320.79 \$ Viewing Dam E
 166 PY 6503.67 \$ West Edge Platform
 167 PY 6640.83 \$ Pit East Wall
 168 PY 6671.31 \$ Pit Curb Outer
 c Pipe Elbows (diagonal planes)
 169 P 0.0000 -1.0000 -1.0000 -1824.99 \$ W SF/Riser 13B
 170 P -1.0000 0.0000 -1.0000 -714.38 \$ W Riser/Ovrhd SF
 171 P -1.0000 -1.0000 0.0000 -3013.71 \$ Corner to 13D Riser
 172 P 0.0000 1.0000 -1.0000 1517.65 \$ Knee of 13D Riser
 173 P 1.0000 -1.0000 0.0000 -115.57 \$ S Corner W Ovrhd
 174 P 0.0000 -1.0000 -1.0000 -1752.60 \$ S Loadout Riser
 175 P 0.0000 1.0000 -1.0000 1818.64 \$ W Riser/Pump Upper
 176 P -1.0000 0.0000 -1.0000 -296.55 \$ W Riser/Pipe
 177 P 1.0000 -1.0000 0.0000 -1765.30 \$ NW Corner
 178 P 1.0000 0.0000 -1.0000 -25.40 \$ N Valves
 179 P -1.0000 -1.0000 0.0000 -5637.53 \$ NE Corner
 180 P 0.0000 -1.0000 -1.0000 -5584.19 \$ E Riser/Pumps
 181 P 0.0000 -1.0000 -1.0000 -5863.59 \$ E Pump/Riser
 182 P -1.0000 0.0000 -1.0000 -930.91 \$ Riser/Ovrhd to View
 183 P -1.0000 -1.0000 0.0000 -6986.27 \$ Corner by Pump #3
 184 P -1.0000 -1.0000 0.0000 -7321.55 \$ Corner N of #3
 185 P 1.0000 0.0000 -1.0000 1299.21 \$ Tech View #3
 186 P 1.0000 0.0000 -1.0000 1277.62 \$ Tech View #2
 187 P 1.0000 -1.0000 0.0000 -5510.53 \$ Corner N of #2
 188 P -1.0000 -1.0000 0.0000 -7103.11 \$ Corner N of HX
 189 P 1.0000 -1.0000 0.0000 -5419.09 \$ Corner S of HX
 190 P 1.0000 -1.0000 0.0000 -6608.83 \$ East Corner to HX
 191 P 1.0000 -1.0000 0.0000 -3623.31 \$ SE Corner Ovrhd
 192 P -1.0000 -1.0000 0.0000 -3620.77 \$ SW Corner Ovrhd
 193 P -1.0000 -1.0000 0.0000 -2932.43 \$ Corner to IXM
 194 P -1.0000 0.0000 -1.0000 -891.54 \$ W Riser/Ovrhd IX
 195 P 0.0000 -1.0000 -1.0000 -1687.83 \$ N Loadout/Riser
 196 P 1.0000 -1.0000 0.0000 -633.73 \$ Outlet/N Loadout
 197 P 1.0000 -1.0000 0.0000 -523.24 \$ IX Box Outlet
 198 P 0.0000 -1.0000 -1.0000 -1808.48 \$ SF Pipe 1 & Pipe 2
 199 P 1.0000 -1.0000 0.0000 -967.74 \$ SF Pipe 3 & Pipe 4
 200 P 0.0000 -1.0000 -1.0000 -1818.64 \$ SF Pipe 4 & Pipe 5
 c Z Coordinates
 201 PZ 609.60 \$ Roof
 202 PZ 304.80 \$ Overhead Pipe
 203 PZ 283.21 \$ Height of Lower Overhead
 204 PZ 274.32 \$ Sand Filter & IX Box Top
 205 PZ 259.08 \$ Sand Filter Ceiling
 206 PZ 228.60 \$ Sand Filter Vessel Top
 207 PZ 227.97 \$ Sand Filter Vessel Top
 208 PZ 187.96 \$ Lead Cave Upper
 209 PZ 182.88 \$ Lead Cave Inner
 210 PZ 203.20 \$ Top of IX Modules
 211 PZ 154.94 \$ IX Modules Ceiling
 212 PZ 91.44 \$ Sand Filter Opening
 213 PZ 60.96 \$ Loadout Pit Curbs
 214 PZ 48.26 \$ IX Module Floor
 215 PZ 15.88 \$ Sand Filter Vessel Inner
 216 PZ 15.24 \$ Sand Filter Vessel Bottom
 217 PZ 10.16 \$ Washing Pit Curb
 218 PZ 1.27 \$ Top of Lead Flooring

219	PZ	0.00	\$ Top of Grating
220	PZ	-3.18	\$ Bottom of Grating
221	PZ	-25.40	\$ Top of Pool Inner Walls
222	PZ	-35.56	\$ Washing Pit Floor
223	PZ	-45.72	\$ Piping Under Grate
224	PZ	-91.44	\$ Top of Dam
225	PZ	-152.40	\$ Viewing Platform Upper
226	PZ	-119.86	\$ Water Level is 16'10"
227	PZ	-304.80	\$ Viewing Pit Lower
228	PZ	-541.02	\$ Top of Fuel
229	PZ	-632.46	\$ Bottom of Pool
230	PZ	-779.78	\$ Bottom of Loadout Pits
c Cylinders Along X (NS)			
231	C/X	1831.34	-45.72 10.16 \$ W Wall Upper
232	C/X	1831.34	-45.72 9.53 \$ W Wall Upper
233	C/X	2391.41	91.44 10.16 \$ N Wall Valve 12
234	C/X	2391.41	91.44 9.53 \$ N Wall Valve 12
235	C/X	3694.43	91.44 10.16 \$ N Wall Valve 10
236	C/X	3694.43	91.44 9.53 \$ N Wall Valve 10
237	C/X	4989.83	91.44 10.16 \$ N Wall Valve 8
238	C/X	4989.83	91.44 9.53 \$ N Wall Valve 8
239	C/X	5571.49	-45.72 10.16 \$ Along E Wall
240	C/X	5571.49	-45.72 9.53 \$ Along E Wall
241	C/X	1630.68	283.21 10.16 \$ SF Loop Part 3
242	C/X	1630.68	283.21 9.53 \$ SF Loop Part 3
243	C/X	1220.47	106.68 10.16 \$ to IX Box
244	C/X	1220.47	106.68 9.53 \$ to IX Box
245	C/X	1581.15	304.80 10.16 \$ Overhead - IX
246	C/X	1581.15	304.80 9.53 \$ W Overhead - IX
247	C/X	1705.61	283.21 10.16 \$ W Overhead - SF
248	C/X	1705.61	283.21 9.53 \$ W Overhead - SF
249	C/X	5662.93	304.80 10.16 \$ E Side Overhead
250	C/X	5662.93	304.80 9.53 \$ E Side Overhead
251	C/X	6320.79	53.34 38.10 \$ Chiller
252	C/X	6320.79	53.34 37.15 \$ Chiller
253	C/X	6473.19	73.66 48.26 \$ Heat Exchanger
254	C/X	6473.19	73.66 47.31 \$ Heat Exchanger
255	C/X	6473.19	73.66 49.53 \$ Heat Exchanger Pb
256	C/X	6473.19	304.80 10.16 \$ Pipe Over Heat Ex
257	C/X	6473.19	304.80 9.53 \$ Pipe Over Heat Ex
258	C/X	6140.45	304.80 10.16 \$ E Overhead - View #2
259	C/X	6140.45	304.80 9.53 \$ E Overhead - View #2
260	C/X	6186.17	283.21 10.16 \$ E Overhead - View #3
261	C/X	6186.17	283.21 9.53 \$ E Overhead - View #3
262	C/X	5850.89	283.21 10.16 \$ E Overhead - Pumps
263	C/X	5850.89	283.21 9.53 \$ E Overhead - Pumps
264	C/X	1611.63	304.80 5.08 \$ PVC Overhead, West Side
c Cylinders Along Y (EW)			
265	C/Y	66.04	-45.72 10.16 \$ N Wall Upper
266	C/Y	66.04	-45.72 9.53 \$ N Wall Upper
267	C/Y	431.17	177.80 10.16 \$ SF Loop Part 1
268	C/Y	431.17	177.80 9.53 \$ SF Loop Part 1
269	C/Y	662.94	283.21 10.16 \$ SF Loop Part 4
270	C/Y	662.94	283.21 9.53 \$ SF Loop Part 4
271	C/Y	342.27	12.70 10.16 \$ Pipe to Sand Filter
272	C/Y	342.27	12.70 9.53 \$ Pipe to Sand Filter
273	C/Y	586.74	106.68 10.16 \$ North of N Loadout
274	C/Y	586.74	106.68 9.53 \$ North of N Loadout
275	C/Y	697.23	106.68 10.16 \$ North of IX Box
276	C/Y	697.23	106.68 9.53 \$ North of IX Box
277	C/Y	723.90	-45.72 10.16 \$ N Loadout Below Floor
278	C/Y	723.90	-45.72 9.53 \$ N Loadout Below Floor
279	C/Y	431.17	119.38 10.16 \$ From SF to Col 13B Riser
280	C/Y	431.17	119.38 9.53 \$ From SF to Col 13B Riser
281	C/Y	1308.10	283.21 10.16 \$ From Col 13B Riser
282	C/Y	1308.10	283.21 9.53 \$ From Col 13B Riser
283	C/Y	1590.04	283.21 10.16 \$ South of S Loadout
284	C/Y	1590.04	283.21 9.53 \$ South of S Loadout
285	C/Y	1351.28	304.80 10.16 \$ North of S Loadout
286	C/Y	1351.28	304.80 9.53 \$ North of S Loadout
287	C/Y	2039.62	304.80 10.16 \$ Pipe Above S Wall
288	C/Y	2039.62	304.80 9.53 \$ Pipe Above S Wall

291	C/Y	647.70	12.70	10.16	\$ E Wall Pump #1
292	C/Y	647.70	12.70	9.53	\$ E Wall Pump #1
293	C/Y	891.54	12.70	10.16	\$ E Wall Pump #2
294	C/Y	891.54	12.70	9.53	\$ E Wall Pump #2
295	C/Y	1135.38	12.70	10.16	\$ E Wall Pump #3
296	C/Y	1135.38	12.70	9.53	\$ E Wall Pump #3
289	C/Y	1135.38	283.21	10.16	\$ E Overhead to Pump #3
290	C/Y	1135.38	283.21	9.53	\$ E Overhead to Pump #3
297	C/Y	1054.10	304.80	10.16	\$ Ovrhd to Heat Exchanger
298	C/Y	1054.10	304.80	9.53	\$ Ovrhd to Heat Exchanger
299	C/Y	629.92	304.80	10.16	\$ Ovrhd from Heat Exch
300	C/Y	629.92	304.80	9.53	\$ Ovrhd from Heat Exch
c Cylinders Along Z					
301	C/Z	30.48	684.53	10.16	\$ NW Filter Media
302	C/Z	815.34	854.71	22.86	\$ IX Cell #3
303	C/Z	815.34	991.87	22.86	\$ IX Cell #2
304	C/Z	815.34	1129.03	22.86	\$ IX Cell #1
305	C/Z	342.27	1385.57	98.11	\$ Sand Filter Inner
306	C/Z	342.27	1385.57	99.06	\$ Sand Filter Outer
307	C/Z	342.27	1831.34	10.16	\$ Riser to Sand Filter
308	C/Z	342.27	1831.34	9.53	\$ Riser to Sand Filter
309	C/Z	66.04	2391.41	10.16	\$ N Wall Valve 12
310	C/Z	66.04	2391.41	9.53	\$ N Wall Valve 12
311	C/Z	66.04	3694.43	10.16	\$ N Wall Valve 10
312	C/Z	66.04	3694.43	9.53	\$ N Wall Valve 10
313	C/Z	66.04	4989.83	10.16	\$ N Wall Valve 8
314	C/Z	66.04	4989.83	9.53	\$ N Wall Valve 8
315	C/Z	431.17	1630.68	10.16	\$ SF Loop Part 2
316	C/Z	431.17	1630.68	9.53	\$ SF Loop Part 2
317	C/Z	662.94	1535.43	10.16	\$ SF Loop Part 5
318	C/Z	662.94	1535.43	9.53	\$ SF Loop Part 5
319	C/Z	586.74	1581.15	10.16	\$ W Riser - IX
320	C/Z	586.74	1581.15	9.53	\$ W Riser - IX
321	C/Z	431.17	1705.61	10.16	\$ Riser at Col 13B
322	C/Z	431.17	1705.61	9.53	\$ Riser at Col 13B
323	C/Z	1308.10	1800.84	10.16	\$ Col 13D Riser
324	C/Z	1308.10	1800.84	9.53	\$ Col 13D Riser
325	C/Z	1590.04	1469.39	10.16	\$ Riser in S Loadout
326	C/Z	1590.04	1469.39	9.53	\$ Riser in S Loadout
327	C/Z	2090.42	2382.52	10.16	\$ S Wall Col 12.2
328	C/Z	2090.42	2382.52	9.53	\$ S Wall Col 12.2
329	C/Z	2090.42	4060.19	10.16	\$ S Wall Col 9.5
330	C/Z	2090.42	4060.19	9.53	\$ S Wall Col 9.5
331	C/Z	2090.42	5203.19	10.16	\$ S Wall Col 7.7
332	C/Z	2090.42	5203.19	9.53	\$ S Wall Col 7.7
333	C/Z	647.70	5571.49	10.16	\$ E Wall Riser #1
334	C/Z	647.70	5571.49	9.53	\$ E Wall Riser #1
335	C/Z	891.54	5571.49	10.16	\$ E Wall Riser #2
336	C/Z	891.54	5571.49	9.53	\$ E Wall Riser #2
337	C/Z	1135.38	5571.49	10.16	\$ E Wall Riser #3
338	C/Z	1135.38	5571.49	9.53	\$ E Wall Riser #3
339	C/Z	647.70	5850.89	10.16	\$ E Pump/Ovrdh Riser #1
340	C/Z	647.70	5850.89	9.53	\$ E Pump/Ovrdh Riser #1
341	C/Z	891.54	5850.89	10.16	\$ E Pump/Ovrdh Riser #2
342	C/Z	891.54	5850.89	9.53	\$ E Pump/Ovrdh Riser #2
343	C/Z	1308.10	6140.45	10.16	\$ Riser U - West Leg
344	C/Z	1308.10	6140.45	9.53	\$ Riser U - West Leg
345	C/Z	1308.10	6186.17	10.16	\$ Riser U - East Leg
346	C/Z	1308.10	6186.17	9.53	\$ Riser U - East Leg
347	C/Z	1582.42	6094.73	10.16	\$ Riser #1 from View Pit
348	C/Z	1582.42	6094.73	9.53	\$ Riser #1 from View Pit
349	C/Z	1582.42	6140.45	10.16	\$ Riser #2 from View Pit
350	C/Z	1582.42	6140.45	9.53	\$ Riser #2 from View Pit
351	C/Z	1582.42	6186.17	10.16	\$ Riser #3 from View Pit
352	C/Z	1582.42	6186.17	9.53	\$ Riser #3 from View Pit
353	C/Z	1054.10	6320.79	10.16	\$ Riser from Chiller
354	C/Z	1054.10	6320.79	9.53	\$ Riser from Chiller
355	C/Z	812.80	1550.67	5.08	\$ PVC Riser from N Loadout
c Support Universes - X					
356	PX	0.00			\$ origin
357	PX	0.32			\$ metal half thickness
358	PX	2.86			\$ inner grate
359	PX	3.18			\$ grate spacing
360	PX	5.08			\$ i-beam left
361	PX	421.64			\$ i-beam right
362	PX	426.40			\$ inner beam
363	PX	426.72			\$ beam spacing

```

c Support Universes - Y
364 PY    0.00 $ origin
365 PY    0.32 $ metal half thickness
366 PY    5.08 $ I-beam left
367 PY   101.60 $ I-beam right
368 PY   106.34 $ inner beam
369 PY   106.68 $ beam spacing
c Support Universes - Z
370 PZ   0.64 $ metal thickness
371 PZ   21.59 $ inner upper

m1 $ Hanford Concrete
 1001.01p -0.00310 $ Hydrogen
 8016.01p -0.44070 $ Oxygen
 11023.01p -0.01820 $ Sodium
 12000.01p -0.03760 $ Magnesium
 13027.01p -0.06070 $ Aluminum
 14000.01p -0.21570 $ Silicon
 15031.01p -0.00090 $ Phosphorus
 16032.01p -0.00090 $ Sulfur
 20000.01p -0.13060 $ Calcium
 22000.01p -0.00490 $ Titanium
 25055.01p -0.00130 $ Manganese
 26000.01p -0.07880 $ Iron
 36000.01p -0.00660 $ Krypton
m2 $ Air at 80°F and 20.0% Relative Humidity
 1001.01p -0.00048 $ Hydrogen
 6012.01p -0.00014 $ Carbon
 7014.01p -0.75191 $ Nitrogen
 8016.01p -0.23464 $ Oxygen
 18040.01p -0.01282 $ Argon
m3 $ water
 1001.01p 0.66667 8016.01p 0.33333
m4 $ iron
 26000.01p -1.0
m5 $ iron & air
 26000.01p -1600.0 8016.01p -0.21 7014.01p -0.79
m6 $ Wet Sand (Working Media)
 1001.01p 2.5795E-01 $ H
 8016.01p 5.2496E-01 $ O
 9019.01p 6.8124E-05 $ F
 11023.01p 7.6730E-03 $ Na
 12000.01p 5.7802E-04 $ Mg
 13027.01p 2.1909E-02 $ Al
 14000.01p 1.7560E-01 $ Si
 16032.01p 1.6163E-04 $ S
 17000.01p 6.5711E-05 $ Cl
 19000.01p 8.7112E-03 $ K
 20000.01p 1.3155E-03 $ Ca
 26000.01p 9.8877E-04 $ Fe
 22000.01p 1.6199E-05 $ Ti
 92238.01p 4.2285E-04 $ U238
m7 $ stored fuel
 1001.01p -0.03609 8016.01p -0.28649 92238.01p -0.67742
m8 $ lead
 82000.01p -1.0
mode p
print 40
prdpj j j 1
phys:p j 1
idum 1
imp:p 0 1 243r

```

Appendix D. MCNP Source Descriptions and Detector Locations

Sources for Input to MCNP

```

nps 500000
sdef erg=0.662 cel=d1 x=fcel d2 y=fcel d3 z=fcel d4 wgt=5.36E+11
pos=fcel d5 ext=fcel d6 axs=fcel d7 rad=fcel d8
sc1 Cells With Sources (14.5 Ci Total)
# si1 sp1 sb1
    L      D      S   ID          Volume Concentration
  132 6.09E-02 15226 $ West Pool      5.08E+07 1.20 uCi/L
  133 6.34E-02 15846 $ Middle Pool    5.28E+07 1.20 uCi/L
  134 6.07E-02 15178 $ East Pool     5.06E+07 1.20 uCi/L
  24 4.27E-04   107 $ N loadout entry 3.55E+05 1.20 uCi/L
  22 1.43E-03   358 $ N loadout pit   1.19E+06 1.20 uCi/L
  33 4.27E-04   107 $ S loadout entry 3.55E+05 1.20 uCi/L
  31 1.43E-03   358 $ S loadout pit   1.19E+06 1.20 uCi/L
  222 2.63E-03   658 $ Elevator .841  2.19E+06 1.20 uCi/L
  227 3.66E-03   915 $ Weasel Pit .874  3.05E+06 1.20 uCi/L
  231 5.45E-03  1364 $ Viewing .912  4.55E+06 1.20 uCi/L
  164 1.22E-02  3060 $ Discharge .747  1.02E+07 1.20 uCi/L
  64 6.08E-02 3040 $ West Wall - North 3.86E+04 1.00 uCi/cm2
  65 5.92E-02 2960 $ West Wall - Middle 3.76E+04 1.00 uCi/cm2
  66 5.05E-02 2526 $ West Wall - South 3.21E+04 1.00 uCi/cm2
  138 1.09E-01 5469 $ N Wall - West   6.95E+04 1.00 uCi/cm2
  138 1.14E-01 5692 $ N Wall - Middle 7.23E+04 1.00 uCi/cm2
  138 1.09E-01 5452 $ N Wall - East   6.92E+04 1.00 uCi/cm2
  161 1.56E-01 7812 $ S Wall - West   9.92E+04 1.00 uCi/cm2
  163 1.12E-01 5601 $ S Wall - Discharge 7.11E+04 1.00 uCi/cm2
  171 5.03E-02 2515 $ S Wall - East   3.19E+04 1.00 uCi/cm2
  234 2.13E-02 1063 $ E Wall - North  1.35E+04 1.00 uCi/cm2
  185 8.76E-02 4378 $ E Wall - Middle 5.56E+04 1.00 uCi/cm2
  229 9.37E-03 469 $ E Wall - Weasel  5.95E+03 1.00 uCi/cm2
  230 1.05E-02 526 $ E Wall - Tech View 6.68E+03 1.00 uCi/cm2
  184 2.49E-02 1246 $ E Wall - South  1.58E+04 1.00 uCi/cm2
  94 1.65E-01 8252 $ Inner W - West   1.05E+05 1.00 uCi/cm2
  94 1.65E-01 8252 $ Inner W - East   1.05E+05 1.00 uCi/cm2
  101 1.65E-01 8252 $ Inner E - West   1.05E+05 1.00 uCi/cm2
  101 1.65E-01 8252 $ Inner E - East   1.05E+05 1.00 uCi/cm2
  235 5.92E-02 2960 $ Elevator Pit - N 3.76E+04 1.00 uCi/cm2
  236 1.37E-02 686 $ Elevator Pit - E  8.71E+03 1.00 uCi/cm2
  236 3.11E-02 1554 $ Elevator Pit - SE 1.97E+04 1.00 uCi/cm2
  236 4.11E-03 206 $ Elevator Pit - E  2.61E+03 1.00 uCi/cm2
  236 2.40E-02 1200 $ Elevator Pit - S 1.52E+04 1.00 uCi/cm2
  185 9.60E-03 480 $ Elevator Pit - W  6.10E+03 1.00 uCi/cm2
  237 4.78E-02 1911 $ E Pump #2 Pedestal 4.78E+04 1.00 Ci/m3
  16 1.76E+00 10539 $ Lead Cave 1.76E+06 1.00 Ci/m3
  18 1.06E+00 6343 $ IXM #1 (west) 1.06E+06 1.00 Ci/m3
  20 1.06E+00 6343 $ IXM #2 (east) 1.06E+06 1.00 Ci/m3
  90 8.39E-03 336 $ S Load drip W 8.39E+03 1.00 Ci/m3
  90 8.39E-03 336 $ S Load drip Mid 8.39E+03 1.00 Ci/m3
  90 8.39E-03 336 $ S Load drip E 8.39E+03 1.00 Ci/m3
  135 9.56E-02 3823 $ Sampler 10.9C 9.56E+04 1.00 Ci/m3
  25 1.96E-01 7833 $ PVC Pipes N Load 1.96E+05 1.00 Ci/m3
  2 3.65E+00 21922 $ Sand Filter 3.65E+06 1.00 Ci/m3
  9 2.82E-01 3386 $ IX #3 (west) 2.82E+05 1.00 Ci/m3
  10 2.82E-01 3386 $ IX #2 (middle) 2.82E+05 1.00 Ci/m3
  11 2.82E-01 3386 $ IX #1 (east) 2.82E+05 1.00 Ci/m3
  187 1.25E+00 7509 $ Chiller 1.25E+06 1.00 Ci/m3
  190 2.26E+00 13545 $ Heat Exchanger 2.26E+06 1.00 Ci/m3
  69 2.17E-02 391 $ NW Filter Media 2.17E+04 1.00 Ci/m3
  28 3.47E-03 1734 $ N Loadout Entry 1.27E+04 1.0 mCi/m
  47 1.75E-03 876 $ SF to 13B Riser 6.44E+03 1.0 mCi/m
  49 1.64E-03 819 $ Col 13B Riser 6.02E+03 1.0 mCi/m
  51 8.77E-03 4385 $ W 9.5' NS N 3.22E+04 1.0 mCi/m
  53 9.53E-04 476 $ W 9.5' EW N 3.50E+03 1.0 mCi/m
  53 3.48E-03 1742 $ Col 13D Riser 1.28E+04 1.0 mCi/m
  57 2.69E-03 1346 $ W 9.5' NS S 9.89E+03 1.0 mCi/m
  59 2.36E-03 1181 $ W 9.5' EW S 8.68E+03 1.0 mCi/m
  61 3.48E-03 1742 $ S Loadout Riser 1.28E+04 1.0 mCi/m
  72 3.96E-03 1981 $ IX Box Outlet 1.46E+04 1.0 mCi/m
  74 1.10E-03 552 $ IX Box NS 4.06E+03 1.0 mCi/m
  76 3.61E-03 1803 $ N Loadout Chest 1.33E+04 1.0 mCi/m
  78 1.98E-03 991 $ W Ovrhd Riser 7.28E+03 1.0 mCi/m
  80 3.05E-03 1524 $ W 10' NS N 1.12E+04 1.0 mCi/m
  82 6.65E-03 3327 $ W 10' to IXM 2.44E+04 1.0 mCi/m
  84 6.88E-03 3442 $ W 10' NS S 2.53E+04 1.0 mCi/m
  121 4.08E-02 20409 $ South Overhead 1.50E+05 1.0 mCi/m
  123 3.48E-03 1742 $ S Riser 12.2 1.28E+04 1.0 mCi/m

```

125	3.48E-03	1742	\$ S Riser 9.5	1.28E+04	1.0 mCi/m	
127	3.48E-03	1742	\$ S Riser 7.7	1.28E+04	1.0 mCi/m	
220	9.86E-03	4928	\$ East Ovrhd NS	3.62E+04	1.0 mCi/m	
214	8.10E-03	4051	\$ East Ovrhd EW S	2.98E+04	1.0 mCi/m	
216	4.24E-03	2121	\$ East Over HX	1.56E+04	1.0 mCi/m	
218	3.33E-03	1664	\$ East Ovrhd EW N	1.22E+04	1.0 mCi/m	
214	4.55E-03	2273	\$ TV #2 NS N	1.67E+04	1.0 mCi/m	
214	4.93E-03	2464	\$ TV #2 NS S	1.81E+04	1.0 mCi/m	
214	2.15E-03	1067	\$ Chiller Riser	7.84E+03	1.0 mCi/m	
214	2.15E-03	1067	\$ TV #2 Bypass	7.84E+03	1.0 mCi/m	
212	3.48E-03	1742	\$ TV Riser #2	1.28E+04	1.0 mCi/m	
210	3.48E-03	1742	\$ TV Riser #1	1.28E+04	1.0 mCi/m	
208	3.48E-03	1742	\$ TV Riser #3	1.28E+04	1.0 mCi/m	
205	2.13E-03	1067	\$ TV #3 Bypass	7.84E+03	1.0 mCi/m	
204	4.37E-03	2184	\$ TV #3 NS	1.60E+04	1.0 mCi/m	
204	3.35E-03	1676	\$ TV #3 EW	1.23E+04	1.0 mCi/m	
202	4.88E-03	2438	\$ E Pumps Ovrhd	1.79E+04	1.0 mCi/m	
200	2.71E-03	1353	\$ Ovrhd #1 East	9.94E+03	1.0 mCi/m	
194	2.79E-03	1397	\$ Horiz #1 East	1.03E+04	1.0 mCi/m	
119	5.84E-04	876	\$ Pool #1 East	2.15E+03	1.0 mCi/m	
202	2.71E-03	1353	\$ Ovrhd #2 East	9.94E+03	1.0 mCi/m	
196	7.37E-04	368	\$ Horiz #2 East	2.71E+03	1.0 mCi/m	
119	5.84E-04	876	\$ Pool #2 East	2.15E+03	1.0 mCi/m	
119	5.74E-03	2870	\$ E Wall Plenum	2.11E+04	1.0 mCi/m	
117	1.91E-03	952	\$ E Wall North	7.00E+03	1.0 mCi/m	
109	3.74E-02	16831	\$ North Wall	1.37E+05	1.0 mCi/m	
107	2.76E-03	2762	\$ West Wall	1.01E+04	1.0 mCi/m	
109	1.37E-03	686	\$ Riser N Col 12	5.04E+03	1.0 mCi/m	
109	1.37E-03	686	\$ Riser N Col 10	5.04E+03	1.0 mCi/m	
109	1.37E-03	686	\$ Riser N Col 8	5.04E+03	1.0 mCi/m	
111	9.14E-04	457	\$ Horiz N Col 12	3.36E+03	1.0 mCi/m	
113	9.14E-04	457	\$ Horiz N Col 10	3.36E+03	1.0 mCi/m	
115	9.14E-04	457	\$ Horiz N Col 8	3.36E+03	1.0 mCi/m	
105	5.84E-04	876	\$ Sand Fltr Riser	2.15E+03	1.0 mCi/m	
70	2.10E-03	1048	\$ Sand Fltr Pump	7.70E+03	1.0 mCi/m	
84	2.74E-03	1372	\$ PVC Riser in NL	5.21E+03	1.0 mCi/m	
89	1.00E+00	100	\$ PVC Hot Spot	2.90E+02	1.0 Ci	
87	1.18E-02	5893	\$ PVC NS in West	2.24E+04	1.0 mCi/m	
37	1.00E-03	502	\$ SF Pipe #1	3.69E+03	1.0 mCi/m	
39	1.05E-03	527	\$ SF Pipe #2	3.87E+03	1.0 mCi/m	
41	2.32E-03	1159	\$ SF Pipe #3	8.51E+03	1.0 mCi/m	
43	9.53E-04	476	\$ SF Pipe #4	3.50E+03	1.0 mCi/m	
45	4.03E-03	2015	\$ SF Pipe #5	1.48E+04	1.0 mCi/m	
c	355495 Total Points					
c	Integration Biasing					Breakdown:
c	Pool Water 300 per m ³					53,177
c	Pool Walls 500 per m ²					88,865
c	Pipes: 500 per m					122,149
c	IX/HeatX: 6000 per m ³					76,751
c	Misc Box: 40000 per m ³					14,574
sc2	X ranges					
ds2	S	11 11 11 11 12 13 14 15 16 17 18 19 20				
		21 22 23 23 23 23 24 24 24 25 26 27 28				
		29 30 31 30 31 31 32 33 34 35 36 37 38				
		39 40 40 40 41 41 41 42 43 0 0 0 0				
		0 0 0 0 0 0 0 0 0 0 0 0 0				
		0 0 0 0 0 0 0 0 0 0 0 0 0				
		0 0 0 0 0 0 0 0 0 0 0 0 0				
si11	H	20.32 2108.20	\$ width of pool NS			
sp11		0 1				
si12	H	695.96 792.48	\$ N loadout entry			
sp12		0 1				
si13	H	637.54 850.90	\$ N loadout pit			
sp13		0 1				
si14	H	1450.34 1546.86	\$ S loadout entry			
sp14		0 1				
si15	H	1391.92 1605.28	\$ S loadout pit			
sp15		0 1				
si16	H	256.54 454.66	\$ elevator pit			
sp16		0 1				
si17	H	1292.86 1460.50	\$ weasel pit			
sp17		0 1				
si18	H	1496.04 1856.74	\$ viewing pit			
sp18		0 1				
si19	H	2131.06 2557.78	\$ discharge chute			
sp19		0 1				
si20	H	20.32 695.96	\$ wall contamination W			
sp20		0 1				

si21	H	792.48	1450.34	\$ wall contamination W									
sp21		0	1										
si22	H	1546.80	2108.20	\$ wall contamination W									
sp22		0	1										
si23	H	19.69	20.32	\$ wall contamination N									
sp23		0	1										
si24	H	2108.20	2108.84	\$ wall contamination S									
sp24		0	1										
si25	H	20.32	256.54	\$ wall contamination E									
sp25		0	1										
si26	H	347.98	1320.80	\$ wall contamination E 0.635 cm									
sp26		0	1										
si27	H	1417.32	1521.46	\$ wall contamination E									
sp27		0	1										
si28	H	1617.98	1734.82	\$ wall contamination E									
sp28		0	1										
si29	H	1831.34	2108.20	\$ wall contamination E									
sp29		0	1										
si30	H	137.16	1971.04	\$ wall contam. inner W									
sp30		0	1										
si31	H	157.48	1991.36	\$ wall contam. inner E									
sp31		0	1										
si32	H	255.91	256.54	\$ wall contam. elevator N									
sp32		0	1										
si33	H	256.54	408.94	\$ wall contam. elevator E									
sp33		0	1										
si34	H	408.94	409.58	\$ wall contam. elevator S									
sp34		0	1										
si35	H	408.94	454.66	\$ wall contam. elevator E									
sp35		0	1										
si36	H	454.66	455.30	\$ wall contam. elevator S									
sp36		0	1										
si37	H	347.98	454.66	\$ wall contam. elevator W									
sp37		0	1										
si38	H	868.68	937.26	\$ E Pump #2 Pedestal 45.72 cm									
sp38		0	1										
si39	H	901.70	957.58	\$ lead cave 10.16 cm									
sp39		0	1										
si40	H	1036.32	1158.24	\$ IXM #1 & #2									
sp40		0	1										
si41	H	1488.60	1508.92	\$ S Loadout Drip Pan 20.32 cm									
sp41		0	1										
si42	H	828.04	873.76	\$ Sampler at Col 10.9C 45.72 cm									
sp42		0	1										
si43	H	693.42	789.94	\$ PVC in N Loadout									
sp43		0	1										
sc3				Y ranges									
ds3	S	44	45	46	47	48	47	48	49	50	51	52	53
		53	53	44	45	46	54	55	56	57	57	57	57
		57	58	59	60	61	62	63	64	65	66	67	68
		69	70	71	72	73	74	75	76	0	0	0	0
		0	0	0	0	0	0	0	0	0	0	0	0
		0	0	0	0	0	0	0	0	0	0	0	0
		0	0	0	0	0	0	0	0	0	0	0	0
si44	H	1785.62	3001.01	\$ west bay									
sp44		0	1										
si45	H	3061.97	4326.89	\$ middle bay									
sp45		0	1										
si46	H	4387.85	5599.43	\$ east bay									
sp46		0	1										
si47	H	1601.47	1785.62	\$ loadout entry									
sp47		0	1										
si48	H	1280.80	1560.83	\$ loadout pit									
sp48		0	1										
si49	H	5599.43	6257.29	\$ elevator pit									
sp49		0	1										
si50	H	5599.43	6640.83	\$ weasel pit									
sp50		0	1										
si51	H	5599.43	6290.31	\$ viewing pit									
sp51		0	1										
si52	H	3503.93	5104.13	\$ discharge chute									
sp52		0	1										
si53	H	1784.99	1785.62	\$ wall contamination W									
sp53		0	1										
si54	H	1785.62	3521.71	\$ wall contamination S									
sp54		0	1										
si55	H	3658.87	4903.47	\$ wall contamination S									
sp55		0	1										

si56 H 5040.63 5599.43 \$ wall contamination S
 sp56 0 1
 si57 H 5599.43 5600.07 \$ wall contamination E
 sp57 0 1
 si58 H 3001.01 3001.65 \$ wall contam. inner W
 sp58 0 1
 si59 H 3061.34 3061.97 \$ wall contam. inner W
 sp59 0 1
 si60 H 4326.89 4327.53 \$ wall contam. inner E
 sp60 0 1
 si61 H 4387.22 4387.85 \$ wall contam. inner E
 sp61 0 1
 si62 H 5599.43 6257.29 \$ wall contam. elevator N
 sp62 0 1
 si63 H 6257.29 6257.93 \$ wall contam. elevator E
 sp63 0 1
 si64 H 5911.85 6257.29 \$ wall contam. elevator S
 sp64 0 1
 si65 H 5911.85 5912.49 \$ wall contam. elevator E
 sp65 0 1
 si66 H 5645.15 5911.85 \$ wall contam. elevator S
 sp66 0 1
 si67 H 5644.52 5645.15 \$ wall contam. elevator W
 sp67 0 1
 si68 H 5706.11 5751.83 \$ E Pump #2 Pedestal
 sp68 0 1
 si69 H 859.79 1154.43 \$ lead cave 60.96 cm
 sp69 0 1
 si70 H 880.11 961.39 \$ IXM #1
 sp70 0 1
 si71 H 1118.87 1200.15 \$ IXM #2
 sp71 0 1
 si72 H 666.75 687.07 \$ S Loadout Drip Pan
 sp72 0 1
 si73 H 941.07 961.39 \$ S Loadout Drip Pan
 sp73 0 1
 si74 H 1154.43 1174.75 \$ S Loadout Drip Pan
 sp74 0 1
 si75 H 2955.29 3001.01 \$ Sampler at Col 10.9C
 sp75 0 1
 si76 H 1380.80 1558.29 \$ PVC in N Loadout
 sp76 0 1
 sc4 Z ranges
 ds4 S 77 77 77 77 77 77 77 77 77 77 77 77 77 77 78
 78 78 78 78 78 78 78 78 78 78 78 78 78 78 78
 78 78 78 78 78 78 78 78 78 78 78 78 78 78 79
 80 80 80 80 81 81 81 82 83 0 0 0 0 0 0 0
 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
 si77 H -139.86 -119.86 \$ 20 cm below water surface
 sp77 0 1
 si78 H -234.78 -144.78 \$ wall contam from 16'0" downward
 sp78 0 1
 si79 H 10.16 25.40 \$ E Pump #2 Pedestal
 sp79 0 1
 si80 H 48.26 154.94 \$ Lead Cave and IXM #1 & #2
 sp80 0 1
 si81 H 154.94 175.26 \$ S Loadout Drip Pan
 sp81 0 1
 si82 H -71.12 -25.40 \$ Sampler at Col 10.9C
 sp82 0 1
 si83 H -10.16 1.27 \$ PVC in N Loadout
 sp83 0 1
 sc5 POS ranges
 ds5 S 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
 0 0 84 85 86 87 88 89 90 91 92 93 94
 95 96 97 98 99 100 101 101 102 103 104 105
 106 107 108 109 110 110 111 112 112 113 114 115
 116 117 118 119 120 121 122 123 124 125 126 127
 128 129 130 131 131 132 133 134 135 136 137 138
 139 140 141 142 143 144 145 146 147
 si84 L 342.27 1385.57 121.92 \$ sand filter
 sp84 D 1
 si85 L 815.34 854.71 0.00 \$ IX #3
 sp85 D 1
 si86 L 815.34 991.87 0.00 \$ IX #2

sp86	D	1				
si87	L	815.34	1129.03	0.00	\$ IX #1	
sp87	D	1				
si88	L	647.70	6320.79	53.34	\$ chiller	2.54 cm
sp88	D	1				
si89	L	604.01	6473.19	73.66	\$ heat exchanger	
sp89	D	1				
si90	L	30.48	684.53	30.48	\$ NW hot filter media	
sp90	D	1				
si91	L	723.90	1438.91	-45.72	\$ N Loadout Entry	
sp91	D	1				
si92	L	431.17	1530.35	119.38	\$ from SF to 13B riser	
sp92	D	1				
si93	L	431.17	1705.61	119.38	\$ col 13B riser	
sp93	D	1				
si94	L	431.17	1705.61	283.21	\$ W overhead at 9.5' NS north	
sp94	D	1				
si95	L	1308.10	1705.61	283.21	\$ W overhead to Col 13D riser	
sp95	D	1				
si96	L	1308.10	1800.86	-119.86	\$ riser at column 13D	
sp96	D	1				
si97	L	1320.80	1705.61	283.21	\$ W overhead at 9.5' NS south	
sp97	D	1				
si98	L	1590.04	1469.39	283.21	\$ W overhead at 9.5' EW	
sp98	D	1				
si99	L	1590.04	1469.39	-119.86	\$ riser in S Loadout	
sp99	D	1				
si100	L	697.23	824.23	106.68	\$ from IX box	
sp100	D	1				
si101	L	586.74	1220.47	106.68	\$ NW corner N loadout	
sp101	D	1				
si102	L	586.74	1581.15	106.68	\$ west overhead riser	
sp102	D	1				
si103	L	586.74	1581.15	304.80	\$ NS overhead - north	
sp103	D	1				
si104	L	1351.28	915.67	304.80	\$ EW to IXM	
sp104	D	1				
si105	L	1351.28	1581.15	304.80	\$ NS overhead - south	
sp105	D	1				
si106	L	2039.62	1581.15	304.80	\$ south overhead	
sp106	D	1				
si107	L	2090.42	2382.52	-119.86	\$ south riser at col 12.2	
sp107	D	1				
si108	L	2090.42	4060.19	-119.86	\$ south riser at col 9.5	
sp108	D	1				
si109	L	2090.42	5203.19	-119.86	\$ south riser at col 7.7	
sp109	D	1				
si110	L	1054.10	5662.93	304.80	\$ east overhead NS-EW corner	
sp110	D	1				
si111	L	629.92	6473.19	304.80	\$ 10' level - over heat exchanger	
sp111	D	1				
si112	L	629.92	6140.45	304.80	\$ HX to TV #2 corner	
sp112	D	1				
si113	L	1089.66	6140.45	304.80	\$ TV #2 NS (south piece)	
sp113	D	1				
si114	L	1054.10	6320.79	91.44	\$ chiller riser	
sp114	D	1				
si115	L	1308.10	6140.45	30.48	\$ tech view #2 bypass	
sp115	D	1				
si116	L	1582.42	6140.45	-119.86	\$ tech view riser #2	
sp116	D	1				
si117	L	1582.42	6094.73	-119.86	\$ tech view riser #1	
sp117	D	1				
si118	L	1582.42	6186.17	-119.86	\$ tech view riser #3	
sp118	D	1				
si119	L	1308.10	6186.17	30.48	\$ tech view #3 bypass	
sp119	D	1				
si120	L	1145.54	6186.17	283.21	\$ tech view #3 NS	
sp120	D	1				
si121	L	1135.38	5850.89	283.21	\$ tech view #3 EW to pumps	
sp121	D	1				
si122	L	647.70	5850.89	283.21	\$ east pumps overhead	
sp122	D	1				
si123	L	647.70	5850.89	12.70	\$ riser from pump #1	
sp123	D	1				
si124	L	647.70	5571.49	12.70	\$ pump #1 - E wall	
sp124	D	1				
si125	L	647.70	5571.49	-45.72	\$ riser #1 - E wall	

si172 L 0.00 424.18 \$ 10' level - over heat exchanger
 si173 L 0.00 332.74 \$ HX to TV #2 corner
 si174 L 0.00 454.66 \$ TV #2 NS (north piece)
 si175 L 0.00 492.76 \$ TV #2 NS (south piece)
 si176 L 0.00 213.36 \$ chiller riser and bypass loop
 si177 L 0.00 436.88 \$ tech view #3 NS
 si178 L 0.00 335.28 \$ tech view #3 EW to pumps
 si179 L 0.00 487.68 \$ east pumps overhead
 si180 L 0.00 270.51 \$ risers from pumps
 si181 L 0.00 279.40 \$ pump #1 - E wall
 si182 L 0.00 58.42 \$ risers from below grate to knee
 si183 L 0.00 73.66 \$ pump #2 - E wall
 si184 L 0.00 574.04 \$ pump plenum - E wall
 si185 L 0.00 190.50 \$ north pipe E wall
 si186 L 0.00 3740.15 \$ pipe along N wall
 si187 L 0.00 276.23 \$ pipe along W wall
 si188 L 0.00 137.16 \$ riser N wall
 si189 L 0.00 91.44 \$ valve N wall
 si190 L 0.00 209.55 \$ sand filter pump
 si191 L 0.00 274.32 \$ PVC riser in N Loadout
 si192 L 0.00 15.24 \$ PVC hot spot
 si193 L 0.00 1178.56 \$ PVC NS overhead - W side
 si194 L 0.00 100.35 \$ SF Pipe #1
 si195 L 0.00 105.41 \$ SF Pipe #2
 si196 L 0.00 231.78 \$ SF Pipe #3
 si197 L 0.00 95.25 \$ SF Pipe #4
 si198 L 0.00 403.07 \$ SF Pipe #5
sc7 AXS ranges
 ds7 S 0
 0
 0 0 201 201 201 201 199 199 201 200 200 201 199 200 199
 200 201 199 200 201 200 199 200 201 199 200 199 200 199
 200 201 201 201 199 200 199 200 199 201 199 200 199 201 201
 201 201 201 201 199 200 199 201 201 200 201 201 199 200 201
 201 199 199 200 199 201 201 201 199 200 201 199 199 200 201
 200 201 200 199 200 201 199 200 201 199 200 201 199 200 201
 si199 L 1.00 0.00 0.00 \$ X axis
 sp199 D 1
 si200 L 0.00 1.00 0.00 \$ Y axis
 sp200 D 1
 si201 L 0.00 0.00 1.00 \$ Z axis
 sp201 D 1
sc8 RAD ranges
 ds8 S 0
 0
 0 0 202 203 203 203 204 205 206 207 207 207 207 207 207
 207 207 207 207 207 207 207 207 207 207 207 207 207 207
 207 207 207 207 207 207 207 207 207 207 207 207 207 207
 207 207 207 207 207 207 207 207 207 207 207 207 207 207
 207 208 208 208 207 207 207 207 207 207 207 207 207 207
 si202 L 47.11 97.11 \$ sand filter
 sp202 D -21 1
 si203 L 0.00 21.86 \$ IX in box
 sp203 D -21 1
 si204 L 16.83 37.15 \$ chiller 20.32 cm
 sp204 D -21 1
 si205 L 26.99 47.31 \$ heat exchanger
 sp205 D -21 1
 si206 L 0.00 9.53 \$ 8 inch filter
 sp206 D -21 1
 si207 L 8.89 9.53 \$ 8 inch pipes 0.635 cm
 sp207 D -21 1
 si208 L 4.45 5.08 \$ 4 inch PVC pipes
 sp208 D -21 1

Near Source Detector Locations

fc5 f5:p	Dose Points	Near Sources				
	271.78	5778.50	60.96	1.0 \$ Over Elevator Pit NW	15	
	332.74	6242.05	60.96	1.0 \$ Over Elevator Pit E	15	
	439.42	5778.50	60.96	1.0 \$ Over Elevator Pit SW	15	
	902.97	5728.97	40.64	1.0 \$ Pump #2 Pedestal	60	
	1137.92	797.55	129.54	1.0 \$ IXM #1 (G10) Chest	2.2	
	1137.92	1272.52	129.54	1.0 \$ IXM #2 (K10) Chest	6	
	1498.76	1164.59	139.70	1.0 \$ Drip Pan - Pit End	250	
	1498.76	951.23	139.70	1.0 \$ Drip Pan - Middle	100	
	1498.76	676.91	139.70	1.0 \$ Drip Pan - Door End	50	
	850.90	2978.15	15.24	1.0 \$ Sampler at Col 10.9C	8	
	741.68	1543.05	15.24	1.0 \$ PVC in N Loadout	150	
	741.68	1573.53	2.54	1.0 \$ PVC in N Loadout - E	35	
	167.01	1385.57	121.92	1.0 \$ SF North Wall	6	
	167.01	1210.31	121.92	1.0 \$ SF Northwest Corner	6	
	342.27	1210.31	121.92	1.0 \$ SF West Wall	6	
	681.99	854.71	106.68	1.0 \$ Pipe Along IX Box - #3	40	
	681.99	923.29	106.68	1.0 \$ Pipe Along IX Box	45	
	681.99	991.87	106.68	1.0 \$ Pipe Along IX Box - #2	50	
	681.99	1060.45	106.68	1.0 \$ Pipe Along IX Box	45	
	681.99	1129.03	106.68	1.0 \$ Pipe Along IX Box - #1	40	
	586.74	6396.99	91.44	1.0 \$ Between HX/Chiller - N	20	
	1010.92	6396.99	91.44	1.0 \$ Between HX/Chiller - S	15	
	842.01	6553.20	91.44	1.0 \$ E Side HX	7	
	45.72	684.53	68.58	1.0 \$ NW Filter Media	120	
	71.12	684.53	68.58	1.0 \$ NW Filter Media at 1ft	30	
	723.90	1560.83	15.24	1.0 \$ N Loadout Entry - Pit	50	
	723.90	1665.61	15.24	1.0 \$ N Loadout Entry	30	
	723.90	1770.38	15.24	1.0 \$ N Loadout Entry - Pool	20	
	431.17	1705.61	104.14	1.0 \$ SF Pipes, lower E	110	
	431.17	1690.37	134.62	1.0 \$ SF Pipes, upper E	120	
	446.41	1545.59	119.38	1.0 \$ SF Pipes, lower W	60	
	424.18	1766.57	27.94	1.0 \$ Beam at Col 13B	25	
	1308.10	1816.10	121.92	1.0 \$ Column 13D	15	
	1308.10	1816.10	213.36	1.0 \$ Col 13D - Above Head	25	
	1513.84	1720.85	283.21	1.0 \$ 9.5' W Ovrhd - SE	70	
	1605.28	1644.65	283.21	1.0 \$ 9.5' W Ovrhd - SE	50	
	1605.28	1469.39	106.68	1.0 \$ S Loadout Riser	100	
	571.50	1235.71	106.68	1.0 \$ Pipe Along N Load, W	35	
	571.50	1408.43	106.68	1.0 \$ Pipe Along N Load, Mid	40	
	571.50	1581.15	106.68	1.0 \$ Elbow - N Loadout - N	60	
	586.74	1596.39	106.68	1.0 \$ Elbow - N Load - Outer	60	
	586.74	1565.91	119.38	1.0 \$ Elbow - N Load - Inner	60	
	2075.18	2382.52	91.44	1.0 \$ S Wall Col 12.2	13	
	2075.18	4060.19	91.44	1.0 \$ S Wall Col 9.5	16	
	2075.18	5203.19	91.44	1.0 \$ S Wall Col 7.7	25	
	1546.86	5647.69	304.80	1.0 \$ E 10' NS Middle	15	
	857.25	6125.21	304.80	1.0 \$ E 10' NS N Piece	45	
	1336.04	6140.45	365.76	1.0 \$ E 10' NS S Piece @ 2'	32	
	1567.18	6079.49	152.40	1.0 \$ View Pit Riser #1	50	
	1567.18	6140.45	152.40	1.0 \$ View Pit Riser #2	40	
	1567.18	6201.41	152.40	1.0 \$ View Pit Riser #3	30	
	1536.70	6140.45	152.40	1.0 \$ View Pit Risers - 1 ft	20	
	1308.10	6163.31	121.92	1.0 \$ Bypass Loop - Inner	40	
	1308.10	6201.41	121.92	1.0 \$ Bypass Loop - East	40	
	1308.10	6163.31	289.56	1.0 \$ Bypass Loop - Above	100	
	1069.34	6320.79	182.88	1.0 \$ Valve - S End Chiller	35	
	769.62	5835.65	283.21	1.0 \$ Pump Overhead	45	
	647.70	5835.65	252.73	1.0 \$ Pump #1 Riser	35	
	647.70	5571.49	27.94	1.0 \$ Pump #1 Knee	12	
	891.54	5571.49	27.94	1.0 \$ Pump #2 Knee	7	
	81.28	2391.41	91.44	1.0 \$ N Wall Valve at Col 12	8	
	81.28	3694.43	91.44	1.0 \$ N Wall Valve at Col 10	6	
	81.28	4989.83	91.44	1.0 \$ N Wall Valve at Col 8	6	
	342.27	1831.34	27.94	1.0 \$ SF Pump Knee	50	
	342.27	1846.58	12.70	1.0 \$ SF Pump Knee	50	
	342.27	1637.03	27.94	1.0 \$ SF Pump	20	
	812.80	1565.91	152.40	1.0 \$ PVC Pipe Riser - NL	27	
	812.80	1565.91	274.32	1.0 \$ PVC Pipe - W Elbow	250	
	812.80	1604.01	259.08	1.0 \$ PVC Hot Spot - Contact	1200	
	812.80	1604.01	243.84	1.0 \$ PVC Hot Spot - 6 in	250	
	812.80	1604.01	228.60	1.0 \$ PVC Hot Spot - 1 ft	130	
	995.68	1611.63	320.04	1.0 \$ PVC Pipe - 6 ft	45	
	1991.36	1611.63	320.04	1.0 \$ PVC Pipe - S Elbow	20	

Principle X and Y Coordinates of the KE-Basin Dose Rate Grid

ID	X Coordinates			
	West	Pool	East	
1	5.08	47.06	81.00 (for valves along N wall of pool)	
2	147.32	181.74		
3	299.72	316.43		
4	421.64	424.18		
5	541.02	558.87	546.10	
6	693.42	693.55	668.02	
7	802.64	801.30	789.94	
8	911.86	909.05		
9	1003.30	1043.74	1033.78	
10	1137.92	1151.49	1155.70	
11	1272.54	1286.18	1277.62	
12	1409.70	1420.86	1399.54	
13	1546.86	1528.61	1521.46	
14	1656.08	1663.30	1643.38	
15	1778.00	1771.05	1765.30	
16	1894.84	1905.74	1887.22	
17	2014.22	2013.48	2009.14	
18	2133.60	2131.06		
19	2255.52	2252.98		
20	2377.44	2374.90		

ID	Y Coordinate	ID	Y Coordinate	ID	Y Coordinate
A	not used	T	2366.39	AM	4713.35
B	196.85	U	2518.41	AN	4820.03
C	318.77	V	2625.09	AO	4926.71
D	440.69	W	2731.77	AP	5033.39
E	560.07	X	2889.25	AQ	5185.41
F	678.81	Y	2980.00	AR	5292.09
G	797.55	Z	3112.77	AS	5437.11
H	916.29	AA	3219.45	AT	5542.00 (5540.00)
I	1035.04	AB	3387.47 (3356.99)	AU	5663.92 (5633.44)
J	1153.78	AC	3494.15 (3524.63)	AV	5816.32
K	1272.52	AD	3600.83 (3631.31)	AW	5968.72
L	1391.26	AE	3707.51 (3737.99)	AX	6121.12 (6090.64)
M	1510.00	AF	3859.53 (3890.01)	AY	6273.52
N	1648.92	AG	3966.21 (3996.69)	AZ	6380.20
O	1767.84	AH	4072.89	BA	6486.88
P	1875.79	AI	4240.91	BB	6593.56
Q	2046.35	AJ	4355.00	BC	6700.24
R	2153.03	AK	4438.65	BD	6806.92
S	2259.71	AL	4545.33		

Note: AB to AG differences occur between the south pool wall and the reactor.

Detector Points Used for Chest Level Results
(Knee Level Uses Z-coordinate of 53.34 cm)

fc5	Dose	Points at Chest Level - 4.25 ft	
f5:p	299.72	196.85 129.54	1 \$ B3 Chest Level - 4.25 ft
	421.64	196.85 129.54	1 \$ B4
	541.02	196.85 129.54	1 \$ B5
	693.42	196.85 129.54	1 \$ B6
	802.64	196.85 129.54	1 \$ B7
	911.86	196.85 129.54	1 \$ B8
	1003.30	196.85 129.54	1 \$ B9
	1137.92	196.85 129.54	1 \$ B10
	1272.54	196.85 129.54	1 \$ B11
	1409.70	196.85 129.54	1 \$ B12
	1546.86	196.85 129.54	1 \$ B13
	1656.08	196.85 129.54	1 \$ B14
	1778.00	196.85 129.54	1 \$ B15
	1894.84	196.85 129.54	1 \$ B16
	2014.22	196.85 129.54	1 \$ B17
	2133.60	196.85 129.54	1 \$ B18
	2255.52	196.85 129.54	1 \$ B19
	2377.44	196.85 129.54	1 \$ B20
	147.32	318.77 129.54	1 \$ C2 Chest Level - 4.25 ft
	299.72	318.77 129.54	1 \$ C3
	421.64	318.77 129.54	1 \$ C4
	541.02	318.77 129.54	1 \$ C5
	693.42	318.77 129.54	1 \$ C6
	802.64	318.77 129.54	1 \$ C7
	911.86	318.77 129.54	1 \$ C8
	1003.30	318.77 129.54	1 \$ C9
	1137.92	318.77 129.54	1 \$ C10
	1272.54	318.77 129.54	1 \$ C11
	1409.70	318.77 129.54	1 \$ C12
	1546.86	318.77 129.54	1 \$ C13
	1656.08	318.77 129.54	1 \$ C14
	1778.00	318.77 129.54	1 \$ C15
	1894.84	318.77 129.54	1 \$ C16
	2014.22	318.77 129.54	1 \$ C17
	2133.60	318.77 129.54	1 \$ C18
	2255.52	318.77 129.54	1 \$ C19
	2377.44	318.77 129.54	1 \$ C20
	5.08	440.69 129.54	1 \$ D1 Chest Level - 4.25 ft
	147.32	440.69 129.54	1 \$ D2
	299.72	440.69 129.54	1 \$ D3
	421.64	440.69 129.54	1 \$ D4
	541.02	440.69 129.54	1 \$ D5
	693.42	440.69 129.54	1 \$ D6
	802.64	440.69 129.54	1 \$ D7
	911.86	440.69 129.54	1 \$ D8
	1003.30	440.69 129.54	1 \$ D9
	1137.92	440.69 129.54	1 \$ D10
	1272.54	440.69 129.54	1 \$ D11
	1409.70	440.69 129.54	1 \$ D12
	1546.86	440.69 129.54	1 \$ D13
	1656.08	440.69 129.54	1 \$ D14
	1778.00	440.69 129.54	1 \$ D15
	1894.84	440.69 129.54	1 \$ D16
	2014.22	440.69 129.54	1 \$ D17
	2133.60	440.69 129.54	1 \$ D18
	2255.52	440.69 129.54	1 \$ D19
	2377.44	440.69 129.54	1 \$ D20
	5.08	560.07 129.54	1 \$ E1 Chest Level - 4.25 ft
	147.32	560.07 129.54	1 \$ E2
	299.72	560.07 129.54	1 \$ E3
	421.64	560.07 129.54	1 \$ E4
	541.02	560.07 129.54	1 \$ E5
	693.42	560.07 129.54	1 \$ E6
	802.64	560.07 129.54	1 \$ E7
	911.86	560.07 129.54	1 \$ E8
	1003.30	560.07 129.54	1 \$ E9
	1137.92	560.07 129.54	1 \$ E10
	1272.54	560.07 129.54	1 \$ E11
	1409.70	560.07 129.54	1 \$ E12
	1546.86	560.07 129.54	1 \$ E13
	1656.08	560.07 129.54	1 \$ E14
	1778.00	560.07 129.54	1 \$ E15
	1894.84	560.07 129.54	1 \$ E16

2014.22	560.07	129.54	1	\$ E17
2133.60	560.07	129.54	1	\$ E18
2255.52	560.07	129.54	1	\$ E19
2377.44	560.07	129.54	1	\$ E20
5.08	678.81	129.54	1	\$ F1 Chest Level - 4.25 ft
147.32	678.81	129.54	1	\$ F2
299.72	678.81	129.54	1	\$ F3
421.64	678.81	129.54	1	\$ F4
541.02	678.81	129.54	1	\$ F5
693.42	678.81	129.54	1	\$ F6
802.64	678.81	129.54	1	\$ F7
911.84	678.81	129.54	1	\$ F8
1003.30	678.81	129.54	1	\$ F9
1137.92	678.81	129.54	1	\$ F10
1272.54	678.81	129.54	1	\$ F11
1409.70	678.81	129.54	1	\$ F12
1546.86	678.81	129.54	1	\$ F13
1656.08	678.81	129.54	1	\$ F14
1778.00	678.81	129.54	1	\$ F15
1894.84	678.81	129.54	1	\$ F16
2014.22	678.81	129.54	1	\$ F17
2133.60	678.81	129.54	1	\$ F18
2255.52	678.81	129.54	1	\$ F19
2377.44	678.81	129.54	1	\$ F20
5.08	797.55	129.54	1	\$ G1 Chest Level - 4.25 ft
147.32	797.55	129.54	1	\$ G2
299.72	797.55	129.54	1	\$ G3
421.64	797.55	129.54	1	\$ G4
541.02	797.55	129.54	1	\$ G5
693.42	797.55	129.54	1	\$ G6
1003.30	797.55	129.54	1	\$ G9
1137.92	797.55	129.54	1	\$ G10
1272.54	797.55	129.54	1	\$ G11
1409.70	797.55	129.54	1	\$ G12
1546.86	797.55	129.54	1	\$ G13
1656.08	797.55	129.54	1	\$ G14
1778.00	797.55	129.54	1	\$ G15
1894.84	797.55	129.54	1	\$ G16
2014.22	797.55	129.54	1	\$ G17
2133.60	797.55	129.54	1	\$ G18
2255.52	797.55	129.54	1	\$ G19
2377.44	797.55	129.54	1	\$ G20
5.08	916.29	129.54	1	\$ H1 Chest Level - 4.25 ft
147.32	916.29	129.54	1	\$ H2
299.72	916.29	129.54	1	\$ H3
421.64	916.29	129.54	1	\$ H4
541.02	916.29	129.54	1	\$ H5
693.42	916.29	129.54	1	\$ H6
1272.54	916.29	129.54	1	\$ H11
1409.70	916.29	129.54	1	\$ H12
1546.86	916.29	129.54	1	\$ H13
1656.08	916.29	129.54	1	\$ H14
1778.00	916.29	129.54	1	\$ H15
1894.84	916.29	129.54	1	\$ H16
2014.22	916.29	129.54	1	\$ H17
2133.60	916.29	129.54	1	\$ H18
2255.52	916.29	129.54	1	\$ H19
2377.44	916.29	129.54	1	\$ H20
5.08	1035.04	129.54	1	\$ I1 Chest Level - 4.25 ft
147.32	1035.04	129.54	1	\$ I2
299.72	1035.04	129.54	1	\$ I3
421.64	1035.04	129.54	1	\$ I4
541.02	1035.04	129.54	1	\$ I5
693.42	1035.04	129.54	1	\$ I6
1272.54	1035.04	129.54	1	\$ I11
1409.70	1035.04	129.54	1	\$ I12
1546.86	1035.04	129.54	1	\$ I13
1656.08	1035.04	129.54	1	\$ I14
1778.00	1035.04	129.54	1	\$ I15
1894.84	1035.04	129.54	1	\$ I16
2014.22	1035.04	129.54	1	\$ I17
2133.60	1035.04	129.54	1	\$ I18
2255.52	1035.04	129.54	1	\$ I19
2377.44	1035.04	129.54	1	\$ I20
5.08	1153.78	129.54	1	\$ J1 Chest Level - 4.25 ft
147.32	1153.78	129.54	1	\$ J2
299.72	1153.78	129.54	1	\$ J3
421.64	1153.78	129.54	1	\$ J4

541.02	1153.78	129.54	1	\$ J5
693.42	1153.78	129.54	1	\$ J6
1272.54	1153.78	129.54	1	\$ J11
1409.70	1153.78	129.54	1	\$ J12
1546.86	1153.78	129.54	1	\$ J13
1656.08	1153.78	129.54	1	\$ J14
1778.00	1153.78	129.54	1	\$ J15
1894.84	1153.78	129.54	1	\$ J16
2014.22	1153.78	129.54	1	\$ J17
2133.60	1153.78	129.54	1	\$ J18
2377.44	1153.78	129.54	1	\$ J20
5.08	1272.52	129.54	1	\$ K1 Chest Level - 4.25 ft
147.32	1272.52	129.54	1	\$ K2
541.02	1272.52	129.54	1	\$ K5
911.86	1272.52	129.54	1	\$ K8
1003.30	1272.52	129.54	1	\$ K9
1137.92	1272.52	129.54	1	\$ K10
1272.54	1272.52	129.54	1	\$ K11
1778.00	1272.52	129.54	1	\$ K15
1894.84	1272.52	129.54	1	\$ K16
2014.22	1272.52	129.54	1	\$ K17
2133.60	1272.52	129.54	1	\$ K18
2255.52	1272.52	129.54	1	\$ K19
2377.44	1272.52	129.54	1	\$ K20
5.08	1391.26	129.54	1	\$ L1 Chest Level - 4.25 ft
147.32	1391.26	129.54	1	\$ L2
541.02	1391.26	129.54	1	\$ L5
911.86	1391.26	129.54	1	\$ L8
1003.30	1391.26	129.54	1	\$ L9
1137.92	1391.26	129.54	1	\$ L10
1272.54	1391.26	129.54	1	\$ L11
1778.00	1391.26	129.54	1	\$ L15
1894.84	1391.26	129.54	1	\$ L16
2014.22	1391.26	129.54	1	\$ L17
2133.60	1391.26	129.54	1	\$ L18
2255.52	1391.26	129.54	1	\$ L19
2377.44	1391.26	129.54	1	\$ L20
5.08	1510.00	129.54	1	\$ M1 Chest Level - 4.25 ft
147.32	1510.00	129.54	1	\$ M2
541.02	1510.00	129.54	1	\$ M5
911.86	1510.00	129.54	1	\$ M8
1003.30	1510.00	129.54	1	\$ M9
1137.92	1510.00	129.54	1	\$ M10
1272.54	1510.00	129.54	1	\$ M11
1778.00	1510.00	129.54	1	\$ M15
1894.84	1510.00	129.54	1	\$ M16
2014.22	1510.00	129.54	1	\$ M17
2133.60	1510.00	129.54	1	\$ M18
2255.52	1510.00	129.54	1	\$ M19
2377.44	1510.00	129.54	1	\$ M20
5.08	1648.92	129.54	1	\$ N1 Chest Level - 4.25 ft
147.32	1648.92	129.54	1	\$ N2
299.72	1648.92	129.54	1	\$ N3
421.64	1648.92	129.54	1	\$ N4
541.02	1648.92	129.54	1	\$ N5
693.42	1648.92	129.54	1	\$ N6
802.64	1648.92	129.54	1	\$ N7
911.86	1648.92	129.54	1	\$ N8
1003.30	1648.92	129.54	1	\$ N9
1137.92	1648.92	129.54	1	\$ N10
1272.54	1648.92	129.54	1	\$ N11
1409.70	1648.92	129.54	1	\$ N12
1546.86	1648.92	129.54	1	\$ N13
1656.08	1648.92	129.54	1	\$ N14
1778.00	1648.92	129.54	1	\$ N15
1894.84	1648.92	129.54	1	\$ N16
2014.22	1648.92	129.54	1	\$ N17
2133.60	1648.92	129.54	1	\$ N18
2255.52	1648.92	129.54	1	\$ N19
2377.44	1648.92	129.54	1	\$ N20
47.06	1767.84	129.54	1	\$ O1 Chest Level - 4.25 ft
181.74	1767.84	129.54	1	\$ O2
316.43	1767.84	129.54	1	\$ O3
424.18	1767.84	129.54	1	\$ O4
558.87	1767.84	129.54	1	\$ O5
693.55	1767.84	129.54	1	\$ O6
801.30	1767.84	129.54	1	\$ O7
909.05	1767.84	129.54	1	\$ O8

1043.74	1767.84	129.54	1	\$ 09
1151.49	1767.84	129.54	1	\$ 010
1286.18	1767.84	129.54	1	\$ 011
1420.86	1767.84	129.54	1	\$ 012
1528.61	1767.84	129.54	1	\$ 013
1663.30	1767.84	129.54	1	\$ 014
1771.05	1767.84	129.54	1	\$ 015
1905.74	1767.84	129.54	1	\$ 016
2013.48	1767.84	129.54	1	\$ 017
2131.06	1767.84	129.54	1	\$ 018
2252.98	1767.84	129.54	1	\$ 019
2374.90	1767.84	129.54	1	\$ 020
47.06	1875.79	129.54	1	\$ P1 Chest Level - 4.25 ft
181.74	1875.79	129.54	1	\$ P2
316.43	1875.79	129.54	1	\$ P3
424.18	1875.79	129.54	1	\$ P4
558.87	1875.79	129.54	1	\$ P5
693.55	1875.79	129.54	1	\$ P6
801.30	1875.79	129.54	1	\$ P7
909.05	1875.79	129.54	1	\$ P8
1043.74	1875.79	129.54	1	\$ P9
1151.49	1875.79	129.54	1	\$ P10
1286.18	1875.79	129.54	1	\$ P11
1420.86	1875.79	129.54	1	\$ P12
1528.61	1875.79	129.54	1	\$ P13
1663.30	1875.79	129.54	1	\$ P14
1771.05	1875.79	129.54	1	\$ P15
1905.74	1875.79	129.54	1	\$ P16
2013.48	1875.79	129.54	1	\$ P17
2131.06	1875.79	129.54	1	\$ P18
2252.98	1875.79	129.54	1	\$ P19
2374.90	1875.79	129.54	1	\$ P20
47.06	2046.35	129.54	1	\$ Q1 Chest Level - 4.25 ft
181.74	2046.35	129.54	1	\$ Q2
316.43	2046.35	129.54	1	\$ Q3
424.18	2046.35	129.54	1	\$ Q4
558.87	2046.35	129.54	1	\$ Q5
693.55	2046.35	129.54	1	\$ Q6
801.30	2046.35	129.54	1	\$ Q7
909.05	2046.35	129.54	1	\$ Q8
1043.74	2046.35	129.54	1	\$ Q9
1151.49	2046.35	129.54	1	\$ Q10
1286.18	2046.35	129.54	1	\$ Q11
1420.86	2046.35	129.54	1	\$ Q12
1528.61	2046.35	129.54	1	\$ Q13
1663.30	2046.35	129.54	1	\$ Q14
1771.05	2046.35	129.54	1	\$ Q15
1905.74	2046.35	129.54	1	\$ Q16
2013.48	2046.35	129.54	1	\$ Q17
2131.06	2046.35	129.54	1	\$ Q18
2252.98	2046.35	129.54	1	\$ Q19
2374.90	2046.35	129.54	1	\$ Q20
47.06	2153.03	129.54	1	\$ R1 Chest Level - 4.25 ft
181.74	2153.03	129.54	1	\$ R2
316.43	2153.03	129.54	1	\$ R3
424.18	2153.03	129.54	1	\$ R4
558.87	2153.03	129.54	1	\$ R5
693.55	2153.03	129.54	1	\$ R6
801.30	2153.03	129.54	1	\$ R7
909.05	2153.03	129.54	1	\$ R8
1043.74	2153.03	129.54	1	\$ R9
1151.49	2153.03	129.54	1	\$ R10
1286.18	2153.03	129.54	1	\$ R11
1420.86	2153.03	129.54	1	\$ R12
1528.61	2153.03	129.54	1	\$ R13
1663.30	2153.03	129.54	1	\$ R14
1771.05	2153.03	129.54	1	\$ R15
1905.74	2153.03	129.54	1	\$ R16
2013.48	2153.03	129.54	1	\$ R17
2131.06	2153.03	129.54	1	\$ R18
2252.98	2153.03	129.54	1	\$ R19
2374.90	2153.03	129.54	1	\$ R20
47.06	2259.71	129.54	1	\$ S1 Chest Level - 4.25 ft
181.74	2259.71	129.54	1	\$ S2
316.43	2259.71	129.54	1	\$ S3
424.18	2259.71	129.54	1	\$ S4
558.87	2259.71	129.54	1	\$ S5
693.55	2259.71	129.54	1	\$ S6

801.30	2259.71	129.54	1	\$ S7
909.05	2259.71	129.54	1	\$ S8
1043.74	2259.71	129.54	1	\$ S9
1151.49	2259.71	129.54	1	\$ S10
1286.18	2259.71	129.54	1	\$ S11
1420.86	2259.71	129.54	1	\$ S12
1528.61	2259.71	129.54	1	\$ S13
1663.30	2259.71	129.54	1	\$ S14
1771.05	2259.71	129.54	1	\$ S15
1905.74	2259.71	129.54	1	\$ S16
2013.48	2259.71	129.54	1	\$ S17
2131.06	2259.71	129.54	1	\$ S18
2252.98	2259.71	129.54	1	\$ S19
2374.90	2259.71	129.54	1	\$ S20
81.00	2366.39	129.54	1	\$ T1 Chest Level - 4.25 ft
181.74	2366.39	129.54	1	\$ T2
316.43	2366.39	129.54	1	\$ T3
424.18	2366.39	129.54	1	\$ T4
558.87	2366.39	129.54	1	\$ T5
693.55	2366.39	129.54	1	\$ T6
801.30	2366.39	129.54	1	\$ T7
909.05	2366.39	129.54	1	\$ T8
1043.74	2366.39	129.54	1	\$ T9
1151.49	2366.39	129.54	1	\$ T10
1286.18	2366.39	129.54	1	\$ T11
1420.86	2366.39	129.54	1	\$ T12
1528.61	2366.39	129.54	1	\$ T13
1663.30	2366.39	129.54	1	\$ T14
1771.05	2366.39	129.54	1	\$ T15
1905.74	2366.39	129.54	1	\$ T16
2013.48	2366.39	129.54	1	\$ T17
2131.06	2366.39	129.54	1	\$ T18
2252.98	2366.39	129.54	1	\$ T19
47.06	2518.41	129.54	1	\$ U1 Chest Level - 4.25 ft
181.74	2518.41	129.54	1	\$ U2
316.43	2518.41	129.54	1	\$ U3
424.18	2518.41	129.54	1	\$ U4
558.87	2518.41	129.54	1	\$ U5
693.55	2518.41	129.54	1	\$ U6
801.30	2518.41	129.54	1	\$ U7
909.05	2518.41	129.54	1	\$ U8
1043.74	2518.41	129.54	1	\$ U9
1151.49	2518.41	129.54	1	\$ U10
1286.18	2518.41	129.54	1	\$ U11
1420.86	2518.41	129.54	1	\$ U12
1528.61	2518.41	129.54	1	\$ U13
1663.30	2518.41	129.54	1	\$ U14
1771.05	2518.41	129.54	1	\$ U15
1905.74	2518.41	129.54	1	\$ U16
2013.48	2518.41	129.54	1	\$ U17
2131.06	2518.41	129.54	1	\$ U18
2252.98	2518.41	129.54	1	\$ U19
47.06	2625.09	129.54	1	\$ V1 Chest Level - 4.25 ft
181.74	2625.09	129.54	1	\$ V2
316.43	2625.09	129.54	1	\$ V3
424.18	2625.09	129.54	1	\$ V4
558.87	2625.09	129.54	1	\$ V5
693.55	2625.09	129.54	1	\$ V6
801.30	2625.09	129.54	1	\$ V7
909.05	2625.09	129.54	1	\$ V8
1043.74	2625.09	129.54	1	\$ V9
1151.49	2625.09	129.54	1	\$ V10
1286.18	2625.09	129.54	1	\$ V11
1420.86	2625.09	129.54	1	\$ V12
1528.61	2625.09	129.54	1	\$ V13
1663.30	2625.09	129.54	1	\$ V14
1771.05	2625.09	129.54	1	\$ V15
1905.74	2625.09	129.54	1	\$ V16
2013.48	2625.09	129.54	1	\$ V17
2131.06	2625.09	129.54	1	\$ V18
2252.98	2625.09	129.54	1	\$ V19
47.06	2731.77	129.54	1	\$ W1 Chest Level - 4.25 ft
181.74	2731.77	129.54	1	\$ W2
316.43	2731.77	129.54	1	\$ W3
424.18	2731.77	129.54	1	\$ W4
558.87	2731.77	129.54	1	\$ W5
693.55	2731.77	129.54	1	\$ W6
801.30	2731.77	129.54	1	\$ W7

909.05	2731.77	129.54	1	\$ WB
1043.74	2731.77	129.54	1	\$ W9
1151.49	2731.77	129.54	1	\$ W10
1286.18	2731.77	129.54	1	\$ W11
1420.86	2731.77	129.54	1	\$ W12
1528.61	2731.77	129.54	1	\$ W13
1663.30	2731.77	129.54	1	\$ W14
1771.05	2731.77	129.54	1	\$ W15
1905.74	2731.77	129.54	1	\$ W16
2013.48	2731.77	129.54	1	\$ W17
2131.06	2731.77	129.54	1	\$ W18
2252.98	2731.77	129.54	1	\$ W19
47.06	2889.25	129.54	1	\$ X1 Chest Level - 4.25 ft
181.74	2889.25	129.54	1	\$ X2
316.43	2889.25	129.54	1	\$ X3
424.18	2889.25	129.54	1	\$ X4
558.87	2889.25	129.54	1	\$ X5
693.55	2889.25	129.54	1	\$ X6
801.30	2889.25	129.54	1	\$ X7
909.05	2889.25	129.54	1	\$ X8
1043.74	2889.25	129.54	1	\$ X9
1151.49	2889.25	129.54	1	\$ X10
1286.18	2889.25	129.54	1	\$ X11
1420.86	2889.25	129.54	1	\$ X12
1528.61	2889.25	129.54	1	\$ X13
1663.30	2889.25	129.54	1	\$ X14
1771.05	2889.25	129.54	1	\$ X15
1905.74	2889.25	129.54	1	\$ X16
2013.48	2889.25	129.54	1	\$ X17
2131.06	2889.25	129.54	1	\$ X18
2252.98	2889.25	129.54	1	\$ X19
2374.90	2889.25	129.54	1	\$ X20
47.06	2980.00	129.54	1	\$ Y1 Chest Level - 4.25 ft
181.74	2980.00	129.54	1	\$ Y2
316.43	2980.00	129.54	1	\$ Y3
424.18	2980.00	129.54	1	\$ Y4
558.87	2980.00	129.54	1	\$ Y5
693.55	2980.00	129.54	1	\$ Y6
801.30	2980.00	129.54	1	\$ Y7
909.05	2980.00	129.54	1	\$ Y8
1043.74	2980.00	129.54	1	\$ Y9
1151.49	2980.00	129.54	1	\$ Y10
1286.18	2980.00	129.54	1	\$ Y11
1420.86	2980.00	129.54	1	\$ Y12
1528.61	2980.00	129.54	1	\$ Y13
1663.30	2980.00	129.54	1	\$ Y14
1771.05	2980.00	129.54	1	\$ Y15
1905.74	2980.00	129.54	1	\$ Y16
2013.48	2980.00	129.54	1	\$ Y17
2131.06	2980.00	129.54	1	\$ Y18
2252.98	2980.00	129.54	1	\$ Y19
2374.90	2980.00	129.54	1	\$ Y20
47.06	3112.77	129.54	1	\$ Z1 Chest Level - 4.25 ft
181.74	3112.77	129.54	1	\$ Z2
316.43	3112.77	129.54	1	\$ Z3
424.18	3112.77	129.54	1	\$ Z4
558.87	3112.77	129.54	1	\$ Z5
693.55	3112.77	129.54	1	\$ Z6
801.30	3112.77	129.54	1	\$ Z7
909.05	3112.77	129.54	1	\$ Z8
1043.74	3112.77	129.54	1	\$ Z9
1151.49	3112.77	129.54	1	\$ Z10
1286.18	3112.77	129.54	1	\$ Z11
1420.86	3112.77	129.54	1	\$ Z12
1528.61	3112.77	129.54	1	\$ Z13
1663.30	3112.77	129.54	1	\$ Z14
1771.05	3112.77	129.54	1	\$ Z15
1905.74	3112.77	129.54	1	\$ Z16
2013.48	3112.77	129.54	1	\$ Z17
2131.06	3112.77	129.54	1	\$ Z18
2252.98	3112.77	129.54	1	\$ Z19
2374.90	3112.77	129.54	1	\$ Z20
47.06	3219.45	129.54	1	\$ AA1 Chest Level - 4.25 ft
181.74	3219.45	129.54	1	\$ AA2
316.43	3219.45	129.54	1	\$ AA3
424.18	3219.45	129.54	1	\$ AA4
558.87	3219.45	129.54	1	\$ AA5
693.55	3219.45	129.54	1	\$ AA6

801.30	3219.45	129.54	1	\$ AA7
909.05	3219.45	129.54	1	\$ AA8
1043.74	3219.45	129.54	1	\$ AA9
1151.49	3219.45	129.54	1	\$ AA10
1286.18	3219.45	129.54	1	\$ AA11
1420.86	3219.45	129.54	1	\$ AA12
1528.61	3219.45	129.54	1	\$ AA13
1663.30	3219.45	129.54	1	\$ AA14
1771.05	3219.45	129.54	1	\$ AA15
1905.74	3219.45	129.54	1	\$ AA16
2013.48	3219.45	129.54	1	\$ AA17
2131.06	3219.45	129.54	1	\$ AA18
2252.98	3219.45	129.54	1	\$ AA19
2374.90	3219.45	129.54	1	\$ AA20
47.06	3387.47	129.54	1	\$ AB1 Chest Level - 4.25 ft
181.74	3387.47	129.54	1	\$ AB2
316.43	3387.47	129.54	1	\$ AB3
424.18	3387.47	129.54	1	\$ AB4
558.87	3387.47	129.54	1	\$ AB5
693.55	3387.47	129.54	1	\$ AB6
801.30	3387.47	129.54	1	\$ AB7
909.05	3387.47	129.54	1	\$ AB8
1043.74	3387.47	129.54	1	\$ AB9
1151.49	3387.47	129.54	1	\$ AB10
1286.18	3387.47	129.54	1	\$ AB11
1420.86	3387.47	129.54	1	\$ AB12
1528.61	3387.47	129.54	1	\$ AB13
1663.30	3387.47	129.54	1	\$ AB14
1771.05	3387.47	129.54	1	\$ AB15
1905.74	3387.47	129.54	1	\$ AB16
2013.48	3387.47	129.54	1	\$ AB17
2131.06	3356.99	129.54	1	\$ AB18
2252.98	3356.99	129.54	1	\$ AB19
2374.90	3356.99	129.54	1	\$ AB20
47.06	3494.15	129.54	1	\$ AC1 Chest Level - 4.25 ft
181.74	3494.15	129.54	1	\$ AC2
316.43	3494.15	129.54	1	\$ AC3
424.18	3494.15	129.54	1	\$ AC4
558.87	3494.15	129.54	1	\$ AC5
693.55	3494.15	129.54	1	\$ AC6
801.30	3494.15	129.54	1	\$ AC7
909.05	3494.15	129.54	1	\$ AC8
1043.74	3494.15	129.54	1	\$ AC9
1151.49	3494.15	129.54	1	\$ AC10
1286.18	3494.15	129.54	1	\$ AC11
1420.86	3494.15	129.54	1	\$ AC12
1528.61	3494.15	129.54	1	\$ AC13
1663.30	3494.15	129.54	1	\$ AC14
1771.05	3494.15	129.54	1	\$ AC15
1905.74	3494.15	129.54	1	\$ AC16
2013.48	3494.15	129.54	1	\$ AC17
2131.06	3524.63	129.54	1	\$ AC18
2252.98	3524.63	129.54	1	\$ AC19
2374.90	3524.63	129.54	1	\$ AC20
47.06	3600.83	129.54	1	\$ AD1 Chest Level - 4.25 ft
181.74	3600.83	129.54	1	\$ AD2
316.43	3600.83	129.54	1	\$ AD3
424.18	3600.83	129.54	1	\$ AD4
558.87	3600.83	129.54	1	\$ AD5
693.55	3600.83	129.54	1	\$ AD6
801.30	3600.83	129.54	1	\$ AD7
909.05	3600.83	129.54	1	\$ AD8
1043.74	3600.83	129.54	1	\$ AD9
1151.49	3600.83	129.54	1	\$ AD10
1286.18	3600.83	129.54	1	\$ AD11
1420.86	3600.83	129.54	1	\$ AD12
1528.61	3600.83	129.54	1	\$ AD13
1663.30	3600.83	129.54	1	\$ AD14
1771.05	3600.83	129.54	1	\$ AD15
1905.74	3600.83	129.54	1	\$ AD16
2013.48	3600.83	129.54	1	\$ AD17
2131.06	3631.31	129.54	1	\$ AD18
2252.98	3631.31	129.54	1	\$ AD19
47.06	3707.51	129.54	1	\$ AE1 Chest Level - 4.25 ft
181.74	3707.51	129.54	1	\$ AE2
316.43	3707.51	129.54	1	\$ AE3
424.18	3707.51	129.54	1	\$ AE4
558.87	3707.51	129.54	1	\$ AE5

693.55	3707.51	129.54	1	\$ AE6
801.30	3707.51	129.54	1	\$ AE7
1286.18	3707.51	129.54	1	\$ AE11
1420.86	3707.51	129.54	1	\$ AE12
1528.61	3707.51	129.54	1	\$ AE13
1663.30	3707.51	129.54	1	\$ AE14
1771.05	3707.51	129.54	1	\$ AE15
1905.74	3707.51	129.54	1	\$ AE16
2013.48	3707.51	129.54	1	\$ AE17
2131.06	3737.99	129.54	1	\$ AE18
2252.98	3737.99	129.54	1	\$ AE19
47.06	3859.53	129.54	1	\$ AF1 Chest Level - 4.25 ft
181.74	3859.53	129.54	1	\$ AF2
316.43	3859.53	129.54	1	\$ AF3
424.18	3859.53	129.54	1	\$ AF4
558.87	3859.53	129.54	1	\$ AF5
693.55	3859.53	129.54	1	\$ AF6
801.30	3859.53	129.54	1	\$ AF7
909.05	3859.53	129.54	1	\$ AF8
1043.74	3859.53	129.54	1	\$ AF9
1151.49	3859.53	129.54	1	\$ AF10
1286.18	3859.53	129.54	1	\$ AF11
1420.86	3859.53	129.54	1	\$ AF12
1528.61	3859.53	129.54	1	\$ AF13
1663.30	3859.53	129.54	1	\$ AF14
1771.05	3859.53	129.54	1	\$ AF15
1905.74	3859.53	129.54	1	\$ AF16
2013.48	3859.53	129.54	1	\$ AF17
2131.06	3890.01	129.54	1	\$ AF18
2252.98	3890.01	129.54	1	\$ AF19
47.06	3966.21	129.54	1	\$ AG1 Chest Level - 4.25 ft
181.74	3966.21	129.54	1	\$ AG2
316.43	3966.21	129.54	1	\$ AG3
424.18	3966.21	129.54	1	\$ AG4
558.87	3966.21	129.54	1	\$ AG5
693.55	3966.21	129.54	1	\$ AG6
801.30	3966.21	129.54	1	\$ AG7
909.05	3966.21	129.54	1	\$ AG8
1043.74	3966.21	129.54	1	\$ AG9
1151.49	3966.21	129.54	1	\$ AG10
1286.18	3966.21	129.54	1	\$ AG11
1420.86	3966.21	129.54	1	\$ AG12
1528.61	3966.21	129.54	1	\$ AG13
1663.30	3966.21	129.54	1	\$ AG14
1771.05	3966.21	129.54	1	\$ AG15
1905.74	3966.21	129.54	1	\$ AG16
2013.48	3966.21	129.54	1	\$ AG17
2252.98	3966.69	129.54	1	\$ AG19
47.06	4072.89	129.54	1	\$ AH1 Chest Level - 4.25 ft
181.74	4072.89	129.54	1	\$ AH2
316.43	4072.89	129.54	1	\$ AH3
424.18	4072.89	129.54	1	\$ AH4
558.87	4072.89	129.54	1	\$ AH5
693.55	4072.89	129.54	1	\$ AH6
801.30	4072.89	129.54	1	\$ AH7
909.05	4072.89	129.54	1	\$ AH8
1043.74	4072.89	129.54	1	\$ AH9
1151.49	4072.89	129.54	1	\$ AH10
1286.18	4072.89	129.54	1	\$ AH11
1420.86	4072.89	129.54	1	\$ AH12
1528.61	4072.89	129.54	1	\$ AH13
1663.30	4072.89	129.54	1	\$ AH14
1771.05	4072.89	129.54	1	\$ AH15
1905.74	4072.89	129.54	1	\$ AH16
2013.48	4072.89	129.54	1	\$ AH17
2131.06	4072.89	129.54	1	\$ AH18
2252.98	4072.89	129.54	1	\$ AH19
47.06	4240.91	129.54	1	\$ A11 Chest Level - 4.25 ft
181.74	4240.91	129.54	1	\$ A12
316.43	4240.91	129.54	1	\$ A13
424.18	4240.91	129.54	1	\$ A14
558.87	4240.91	129.54	1	\$ A15
693.55	4240.91	129.54	1	\$ A16
801.30	4240.91	129.54	1	\$ A17
909.05	4240.91	129.54	1	\$ A18
1043.74	4240.91	129.54	1	\$ A19
1151.49	4240.91	129.54	1	\$ A110
1286.18	4240.91	129.54	1	\$ A111

1420.86	4240.91	129.54	1	\$ A112
1528.61	4240.91	129.54	1	\$ A113
1663.30	4240.91	129.54	1	\$ A114
1771.05	4240.91	129.54	1	\$ A115
1905.74	4240.91	129.54	1	\$ A116
2013.48	4240.91	129.54	1	\$ A117
2131.06	4240.91	129.54	1	\$ A118
2252.98	4240.91	129.54	1	\$ A119
47.06	4355.00	129.54	1	\$ A11 Chest Level - 4.25 ft
181.74	4355.00	129.54	1	\$ AJ2
316.43	4355.00	129.54	1	\$ AJ3
424.18	4355.00	129.54	1	\$ AJ4
558.87	4355.00	129.54	1	\$ AJ5
693.55	4355.00	129.54	1	\$ AJ6
801.30	4355.00	129.54	1	\$ AJ7
909.05	4355.00	129.54	1	\$ AJ8
1043.74	4355.00	129.54	1	\$ AJ9
1151.49	4355.00	129.54	1	\$ AJ10
1286.18	4355.00	129.54	1	\$ AJ11
1420.86	4355.00	129.54	1	\$ AJ12
1528.61	4355.00	129.54	1	\$ AJ13
1663.30	4355.00	129.54	1	\$ AJ14
1771.05	4355.00	129.54	1	\$ AJ15
1905.74	4355.00	129.54	1	\$ AJ16
2013.48	4355.00	129.54	1	\$ AJ17
2131.06	4355.00	129.54	1	\$ AJ18
2252.98	4355.00	129.54	1	\$ AJ19
47.06	4438.65	129.54	1	\$ AK1 Chest Level - 4.25 ft
181.74	4438.65	129.54	1	\$ AK2
316.43	4438.65	129.54	1	\$ AK3
424.18	4438.65	129.54	1	\$ AK4
558.87	4438.65	129.54	1	\$ AK5
693.55	4438.65	129.54	1	\$ AK6
801.30	4438.65	129.54	1	\$ AK7
909.05	4438.65	129.54	1	\$ AK8
1043.74	4438.65	129.54	1	\$ AK9
1151.49	4438.65	129.54	1	\$ AK10
1286.18	4438.65	129.54	1	\$ AK11
1420.86	4438.65	129.54	1	\$ AK12
1528.61	4438.65	129.54	1	\$ AK13
1663.30	4438.65	129.54	1	\$ AK14
1771.05	4438.65	129.54	1	\$ AK15
1905.74	4438.65	129.54	1	\$ AK16
2013.48	4438.65	129.54	1	\$ AK17
2131.06	4438.65	129.54	1	\$ AK18
2252.98	4438.65	129.54	1	\$ AK19
47.06	4545.33	129.54	1	\$ AL1 Chest Level - 4.25 ft
181.74	4545.33	129.54	1	\$ AL2
316.43	4545.33	129.54	1	\$ AL3
424.18	4545.33	129.54	1	\$ AL4
558.87	4545.33	129.54	1	\$ AL5
693.55	4545.33	129.54	1	\$ AL6
801.30	4545.33	129.54	1	\$ AL7
909.05	4545.33	129.54	1	\$ AL8
1043.74	4545.33	129.54	1	\$ AL9
1151.49	4545.33	129.54	1	\$ AL10
1286.18	4545.33	129.54	1	\$ AL11
1420.86	4545.33	129.54	1	\$ AL12
1528.61	4545.33	129.54	1	\$ AL13
1663.30	4545.33	129.54	1	\$ AL14
1771.05	4545.33	129.54	1	\$ AL15
1905.74	4545.33	129.54	1	\$ AL16
2013.48	4545.33	129.54	1	\$ AL17
2131.06	4545.33	129.54	1	\$ AL18
2252.98	4545.33	129.54	1	\$ AL19
47.06	4713.35	129.54	1	\$ AM1 Chest Level - 4.25 ft
181.74	4713.35	129.54	1	\$ AM2
316.43	4713.35	129.54	1	\$ AM3
424.18	4713.35	129.54	1	\$ AM4
558.87	4713.35	129.54	1	\$ AM5
693.55	4713.35	129.54	1	\$ AM6
801.30	4713.35	129.54	1	\$ AM7
909.05	4713.35	129.54	1	\$ AM8
1043.74	4713.35	129.54	1	\$ AM9
1151.49	4713.35	129.54	1	\$ AM10
1286.18	4713.35	129.54	1	\$ AM11
1420.86	4713.35	129.54	1	\$ AM12
1528.61	4713.35	129.54	1	\$ AM13

1663.30	4713.35	129.54	1	\$ AM14
1771.05	4713.35	129.54	1	\$ AM15
1995.74	4713.35	129.54	1	\$ AM16
2013.48	4713.35	129.54	1	\$ AM17
2131.06	4713.35	129.54	1	\$ AM18
2252.98	4713.35	129.54	1	\$ AM19
47.06	4820.03	129.54	1	\$ AM1 Chest Level - 4.25 ft
181.74	4820.03	129.54	1	\$ AM2
316.43	4820.03	129.54	1	\$ AN3
424.18	4820.03	129.54	1	\$ AN4
558.87	4820.03	129.54	1	\$ AN5
693.55	4820.03	129.54	1	\$ AN6
801.30	4820.03	129.54	1	\$ AN7
909.05	4820.03	129.54	1	\$ AN8
1043.74	4820.03	129.54	1	\$ AN9
1151.49	4820.03	129.54	1	\$ AN10
1286.18	4820.03	129.54	1	\$ AN11
1420.86	4820.03	129.54	1	\$ AN12
1528.61	4820.03	129.54	1	\$ AN13
1663.30	4820.03	129.54	1	\$ AN14
1771.05	4820.03	129.54	1	\$ AN15
1905.74	4820.03	129.54	1	\$ AN16
2013.48	4820.03	129.54	1	\$ AN17
2131.06	4820.03	129.54	1	\$ AN18
2252.98	4820.03	129.54	1	\$ AN19
47.06	4926.71	129.54	1	\$ A01
181.74	4926.71	129.54	1	\$ A02 Chest Level - 4.25 ft
316.43	4926.71	129.54	1	\$ A03
424.18	4926.71	129.54	1	\$ A04
558.87	4926.71	129.54	1	\$ A05
693.55	4926.71	129.54	1	\$ A06
801.30	4926.71	129.54	1	\$ A07
909.05	4926.71	129.54	1	\$ A08
1043.74	4926.71	129.54	1	\$ A09
1151.49	4926.71	129.54	1	\$ A010
1286.18	4926.71	129.54	1	\$ A011
1420.86	4926.71	129.54	1	\$ A012
1528.61	4926.71	129.54	1	\$ A013
1663.30	4926.71	129.54	1	\$ A014
1771.05	4926.71	129.54	1	\$ A015
1905.74	4926.71	129.54	1	\$ A016
2013.48	4926.71	129.54	1	\$ A017
2374.90	4926.71	129.54	1	\$ A020
47.06	5033.39	129.54	1	\$ AP1 Chest Level - 4.25 ft
181.74	5033.39	129.54	1	\$ AP2
316.43	5033.39	129.54	1	\$ AP3
424.18	5033.39	129.54	1	\$ AP4
558.87	5033.39	129.54	1	\$ AP5
693.55	5033.39	129.54	1	\$ AP6
801.30	5033.39	129.54	1	\$ AP7
909.05	5033.39	129.54	1	\$ AP8
1043.74	5033.39	129.54	1	\$ AP9
1151.49	5033.39	129.54	1	\$ AP10
1286.18	5033.39	129.54	1	\$ AP11
1420.86	5033.39	129.54	1	\$ AP12
1528.61	5033.39	129.54	1	\$ AP13
1663.30	5033.39	129.54	1	\$ AP14
1771.05	5033.39	129.54	1	\$ AP15
1905.74	5033.39	129.54	1	\$ AP16
2013.48	5033.39	129.54	1	\$ AP17
2131.06	5033.39	129.54	1	\$ AP18
2252.98	5033.39	129.54	1	\$ AP19
2374.90	5033.39	129.54	1	\$ AP20
47.06	5185.41	129.54	1	\$ A01 Chest Level - 4.25 ft
181.74	5185.41	129.54	1	\$ A02
316.43	5185.41	129.54	1	\$ A03
424.18	5185.41	129.54	1	\$ A04
558.87	5185.41	129.54	1	\$ A05
693.55	5185.41	129.54	1	\$ A06
801.30	5185.41	129.54	1	\$ A07
909.05	5185.41	129.54	1	\$ A08
1043.74	5185.41	129.54	1	\$ A09
1151.49	5185.41	129.54	1	\$ A010
1286.18	5185.41	129.54	1	\$ A011
1420.86	5185.41	129.54	1	\$ A012
1528.61	5185.41	129.54	1	\$ A013
1663.30	5185.41	129.54	1	\$ A014
1771.05	5185.41	129.54	1	\$ A015

1905.74	5185.41	129.54	1	\$ A016
2013.48	5185.41	129.54	1	\$ A017
2252.98	5185.41	129.54	1	\$ A019
2374.90	5185.41	129.54	1	\$ A020
47.06	5292.09	129.54	1	\$ AR1 Chest Level - 4.25 ft
181.74	5292.09	129.54	1	\$ AR2
316.43	5292.09	129.54	1	\$ AR3
424.18	5292.09	129.54	1	\$ AR4
558.87	5292.09	129.54	1	\$ AR5
693.55	5292.09	129.54	1	\$ AR6
801.30	5292.09	129.54	1	\$ AR7
909.05	5292.09	129.54	1	\$ AR8
1043.74	5292.09	129.54	1	\$ AR9
1151.49	5292.09	129.54	1	\$ AR10
1286.18	5292.09	129.54	1	\$ AR11
1420.86	5292.09	129.54	1	\$ AR12
1528.61	5292.09	129.54	1	\$ AR13
1663.30	5292.09	129.54	1	\$ AR14
1771.05	5292.09	129.54	1	\$ AR15
1905.74	5292.09	129.54	1	\$ AR16
2013.48	5292.09	129.54	1	\$ AR17
2131.06	5292.09	129.54	1	\$ AR18
2252.98	5292.09	129.54	1	\$ AR19
2374.90	5292.09	129.54	1	\$ AR20
47.06	5437.11	129.54	1	\$ AS1 Chest Level - 4.25 ft
181.74	5437.11	129.54	1	\$ AS2
316.43	5437.11	129.54	1	\$ AS3
424.18	5437.11	129.54	1	\$ AS4
558.87	5437.11	129.54	1	\$ AS5
693.55	5437.11	129.54	1	\$ AS6
801.30	5437.11	129.54	1	\$ AS7
909.05	5437.11	129.54	1	\$ AS8
1043.74	5437.11	129.54	1	\$ AS9
1151.49	5437.11	129.54	1	\$ AS10
1286.18	5437.11	129.54	1	\$ AS11
1420.86	5437.11	129.54	1	\$ AS12
1528.61	5437.11	129.54	1	\$ AS13
1663.30	5437.11	129.54	1	\$ AS14
1771.05	5437.11	129.54	1	\$ AS15
1905.74	5437.11	129.54	1	\$ AS16
2013.48	5437.11	129.54	1	\$ AS17
2131.06	5437.11	129.54	1	\$ AS18
2252.98	5437.11	129.54	1	\$ AS19
2374.90	5437.11	129.54	1	\$ AS20
47.06	5542.00	129.54	1	\$ AT1 Chest Level - 4.25 ft
181.74	5542.00	129.54	1	\$ AT2
316.43	5542.00	129.54	1	\$ AT3
424.18	5542.00	129.54	1	\$ AT4
558.87	5542.00	129.54	1	\$ AT5
693.55	5542.00	129.54	1	\$ AT6
801.30	5542.00	129.54	1	\$ AT7
909.05	5542.00	129.54	1	\$ AT8
1043.74	5542.00	129.54	1	\$ AT9
1151.49	5542.00	129.54	1	\$ AT10
1286.18	5542.00	129.54	1	\$ AT11
1420.86	5542.00	129.54	1	\$ AT12
1528.61	5542.00	129.54	1	\$ AT13
1663.30	5542.00	129.54	1	\$ AT14
1771.05	5542.00	129.54	1	\$ AT15
1905.74	5542.00	129.54	1	\$ AT16
2013.48	5542.00	129.54	1	\$ AT17
2131.06	5542.00	129.54	1	\$ AT18
2252.98	5542.00	129.54	1	\$ AT19
2374.90	5542.00	129.54	1	\$ AT20
5.08	5663.92	129.54	1	\$ AU1 Chest Level - 4.25 ft
147.32	5663.92	129.54	1	\$ AU2
424.18	5663.92	129.54	1	\$ AU4
546.10	5663.92	129.54	1	\$ AU5
668.02	5663.92	129.54	1	\$ AU6
789.94	5663.92	129.54	1	\$ AU7
911.86	5663.92	129.54	1	\$ AU8
1033.78	5663.92	129.54	1	\$ AU9
1155.70	5663.92	129.54	1	\$ AU10
1277.62	5663.92	129.54	1	\$ AU11
1399.54	5663.92	129.54	1	\$ AU12
1521.46	5663.92	129.54	1	\$ AU13
1643.38	5663.92	129.54	1	\$ AU14
1765.30	5663.92	129.54	1	\$ AU15

1887.22	5663.92	129.54	1	\$ AU16
2009.14	5633.44	129.54	1	\$ AU17
2131.06	5663.92	129.54	1	\$ AU18
2252.98	5663.92	129.54	1	\$ AU19
2374.90	5663.92	129.54	1	\$ AU20
5.08	5816.32	129.54	1	\$ AV1 Chest Level - 4.25 ft
147.32	5816.32	129.54	1	\$ AV2
424.18	5816.32	129.54	1	\$ AV4
546.10	5816.32	129.54	1	\$ AV5
668.02	5816.32	129.54	1	\$ AV6
789.94	5816.32	129.54	1	\$ AV7
911.86	5816.32	129.54	1	\$ AV8
1033.78	5816.32	129.54	1	\$ AV9
1155.70	5816.32	129.54	1	\$ AV10
1277.62	5816.32	129.54	1	\$ AV11
1399.54	5816.32	129.54	1	\$ AV12
1521.46	5816.32	129.54	1	\$ AV13
1643.38	5816.32	129.54	1	\$ AV14
1765.30	5816.32	129.54	1	\$ AV15
2009.14	5816.32	129.54	1	\$ AV17
2131.06	5816.32	129.54	1	\$ AV18
2252.98	5816.32	129.54	1	\$ AV19
2374.90	5816.32	129.54	1	\$ AV20
424.18	5968.72	129.54	1	\$ AW4 Chest Level - 4.25 ft
546.10	5968.72	129.54	1	\$ AW5
668.02	5968.72	129.54	1	\$ AW6
789.94	5968.72	129.54	1	\$ AW7
911.86	5968.72	129.54	1	\$ AW8
1033.78	5968.72	129.54	1	\$ AW9
1155.70	5968.72	129.54	1	\$ AW10
1277.62	5968.72	129.54	1	\$ AW11
1399.54	5968.72	129.54	1	\$ AW12
1521.46	5968.72	129.54	1	\$ AW13
1643.38	5968.72	129.54	1	\$ AW14
1765.30	5968.72	129.54	1	\$ AW15
2009.14	5968.72	129.54	1	\$ AW17
2131.06	5968.72	129.54	1	\$ AW18
2252.98	5968.72	129.54	1	\$ AW19
2374.90	5968.72	129.54	1	\$ AW20
424.18	6090.64	129.54	1	\$ AX4 Chest Level - 4.25 ft
546.10	6121.12	129.54	1	\$ AX5
668.02	6121.12	129.54	1	\$ AX6
789.94	6121.12	129.54	1	\$ AX7
911.86	6121.12	129.54	1	\$ AX8
1033.78	6121.12	129.54	1	\$ AX9
1155.70	6121.12	129.54	1	\$ AX10
1277.62	6121.12	129.54	1	\$ AX11
1399.54	6121.12	129.54	1	\$ AX12
1521.46	6121.12	129.54	1	\$ AX13
1765.30	6121.12	129.54	1	\$ AX15
2009.14	6121.12	129.54	1	\$ AX17
2131.06	6121.12	129.54	1	\$ AX18
2252.98	6121.12	129.54	1	\$ AX19
2374.90	6121.12	129.54	1	\$ AX20
5.08	6273.52	129.54	1	\$ AY1 Chest Level - 4.25 ft
147.32	6273.52	129.54	1	\$ AY2
299.72	6273.52	129.54	1	\$ AY3
424.18	6273.52	129.54	1	\$ AY4
546.10	6273.52	129.54	1	\$ AY5
1033.78	6273.52	129.54	1	\$ AY9
1155.70	6273.52	129.54	1	\$ AY10
1277.62	6273.52	129.54	1	\$ AY11
1399.54	6273.52	129.54	1	\$ AY12
1521.46	6273.52	129.54	1	\$ AY13
1765.30	6273.52	129.54	1	\$ AY15
2009.14	6273.52	129.54	1	\$ AY17
2131.06	6273.52	129.54	1	\$ AY18
2252.98	6273.52	129.54	1	\$ AY19
2374.90	6273.52	129.54	1	\$ AY20
5.08	6380.20	129.54	1	\$ AZ1 Chest Level - 4.25 ft
147.32	6380.20	129.54	1	\$ AZ2
299.72	6380.20	129.54	1	\$ AZ3
424.18	6380.20	129.54	1	\$ AZ4
546.10	6380.20	129.54	1	\$ AZ5
1155.70	6380.20	129.54	1	\$ AZ10
1277.62	6380.20	129.54	1	\$ AZ11
1521.46	6380.20	129.54	1	\$ AZ13
1765.30	6380.20	129.54	1	\$ AZ15
1887.22	6380.20	129.54	1	\$ AZ16

2009.14	6380.20	129.54	1	\$ A217
2131.06	6380.20	129.54	1	\$ A218
2252.98	6380.20	129.54	1	\$ A219
2374.90	6380.20	129.54	1	\$ A220
147.32	6486.88	129.54	1	\$ BA2 Chest Level - 4.25 ft
299.72	6486.88	129.54	1	\$ BA3
1155.70	6486.88	129.54	1	\$ BA10
1277.62	6486.88	129.54	1	\$ BA11
1521.46	6486.88	129.54	1	\$ BA13
1765.30	6486.88	129.54	1	\$ BA15
1887.22	6486.88	129.54	1	\$ BA16
147.32	6593.56	129.54	1	\$ BB2 Chest Level - 4.25 ft
299.72	6593.56	129.54	1	\$ BB3
424.18	6593.56	129.54	1	\$ BB4
546.10	6593.56	129.54	1	\$ BB5
668.02	6593.56	129.54	1	\$ BB6
1277.62	6593.56	129.54	1	\$ BB11
1399.54	6593.56	129.54	1	\$ BB12
1521.46	6593.56	129.54	1	\$ BB13
1643.38	6593.56	129.54	1	\$ BB14
1765.30	6593.56	129.54	1	\$ BB15
1887.22	6593.56	129.54	1	\$ BB16
668.02	6700.24	129.54	1	\$ BC6 Chest Level - 4.25 ft
789.94	6700.24	129.54	1	\$ BC7
911.86	6700.24	129.54	1	\$ BC8
1155.70	6700.24	129.54	1	\$ BC10
1277.62	6700.24	129.54	1	\$ BC11
1765.30	6700.24	129.54	1	\$ BC15
1887.22	6700.24	129.54	1	\$ BC16
668.02	6806.92	129.54	1	\$ BD6 Chest Level - 4.25 ft
789.94	6806.92	129.54	1	\$ BD7
911.86	6806.92	129.54	1	\$ BD8
1033.78	6806.92	129.54	1	\$ BD9
1155.70	6806.92	129.54	1	\$ BD10
1277.62	6806.92	129.54	1	\$ BD11

Appendix E. Software to Generate MCNP Input

KE-GEOM.PAS Software Listing

```

Program Convert_KEGeom;
{ Author: Paul D. Rittmann, PhD CHP
  Purpose: Reads the KE-GEOM.WQ1 output text file and creates the 3 MCNP
            input file pieces: geometry (cells & surfaces with material lines)
            sources, and near source points. This also breaks the
            source block into individual source pieces.
  Input:  Text file from the KE-GEOM.WQ1 spreadsheet.
}

Uses Crt, DOS, Objects, Utility;

Const Version = 'KE-GEOM Version 1.1 April 10, 1997';
  SrcMax = 180; { limit on the number of distinct radiation sources }
  FileDrive = 'D:\'; { where the files are found }
  EffFile = 'KE-GEOM.EFF'; { MCNP efficiency file list from GREP on output }
  SSFile = 'KE-GEOM.PRN'; { KE-GEOM.WQ1 text file }
  Gfile = 'GEOF'; { geometry surfaces and cells }
  Sfile = 'S-ALL'; { all the source info }
  Pfile = 'PT-NEAR'; { near source locations }
  LstFile = 'SORTSRC'; { list of sources 2 ways }
  MaxLine = 4000; { limit on the number of lines in the input file }
  Gnum = 50; { number of lines of extra geometry information }
  GeomInfo : Array[1..Gnum] of ST66 = (
'm1  $ Hanford Concrete',
'    1001.01p -0.00310 $ Hydrogen',
'    8016.01p -0.44070 $ Oxygen',
'    11023.01p -0.01820 $ Sodium',
'    12000.01p -0.03760 $ Magnesium',
'    13027.01p -0.06070 $ Aluminum',
'    14000.01p -0.21570 $ Silicon',
'    15031.01p -0.00090 $ Phosphorus',
'    16032.01p -0.00090 $ Sulfur',
'    20000.01p -0.13060 $ Calcium',
'    22000.01p -0.00490 $ Titanium',
'    25055.01p -0.00130 $ Manganese',
'    26000.01p -0.07880 $ Iron',
'    36000.01p -0.00660 $ Krypton',
'm2  $ Air at 80°F and 20.0% Relative Humidity',
'    1001.01p -0.00048 $ Hydrogen',
'    6012.01p -0.00014 $ Carbon',
'    7014.01p -0.75191 $ Nitrogen',
'    8016.01p -0.23464 $ Oxygen',
'    18040.01p -0.01282 $ Argon',
'm3  $ water',
'    1001.01p 0.66667 8016.01p 0.33333',
'm4  $ iron,
'    26000.01p -1.0',
'm5  $ iron & air',
'    26000.01p -1600.0 8016.01p -0.21    7014.01p -0.79',
'm6  $ Wet Sand (Working Media),
'    1001.01p 2.5795E-01 $ H',
'    8016.01p 5.2496E-01 $ O',
'    9019.01p 6.8124E-05 $ F',
'    11023.01p 7.6730E-03 $ Na',
'    12000.01p 5.7802E-04 $ Mg',
'    13027.01p 2.1909E-02 $ Al',
'    14000.01p 1.7560E-01 $ Si',
'    16032.01p 1.6163E-04 $ S',
'    17000.01p 6.5711E-05 $ Cl',
'    19000.01p 8.7112E-03 $ K',
'    20000.01p 1.3155E-03 $ Ca',
'    26000.01p 9.8877E-04 $ Fe',
'    22000.01p 1.6199E-05 $ Ti',
'    92238.01p 4.2285E-04 $ U238',
'm7  $ stored fuel,
'    1001.01p -0.03609 8016.01p -0.28649 92238.01p -0.67742',
'm8  $ Lead,
'    82000.01p -1.0',
'mode p',
'print 40',
'prline j j 1',
'phys:p j 1',
'idum 1';

```

```

Type
  SrcSpecPtr = ^SrcSpecType;
  SrcSpecType = Record ( 160+32+640+120*8 = 960 bytes )
    Title : ST25; { title of source }
    ConcAmt : ST19; { concentration and units }
    Fname, { source file name }
    Effic : ST7; { efficiency from MCNP run }
    nps : LongInt; { number of source points in this region }
    wgt : Single; { total source strength, Bq }
    cel : Integer; { Which cell the source region is in }
    Vx,six,spx : Array[1..4] of Integer; { 1,2,3,4=X,Y,Z,0 or =POS,EXT,AXS,RAD }
      { Vx are values in the distribution fcel }
      { six,spx are indices to the AllTxt array }
  End;

Var
  fi,fo : Text; { the KE-GEOM.WQ1 text file and output file }
  Nxz, { number of rectangular box sources }
  SpecNum, { number of sources specified in the source block }
  PartD, { index to current part being read }
  LineD : Integer; { current line in the input file }
  SrcOrd : Array[1..SrcMax] of Integer; { sorted order for SrcSpec }
  SrcSpec : Array[1..SrcMax] of SrcSpecPtr; { info about each source }
  AllTxt : Array[1..MaxLine] of Pstring; { lines from the input file }
  TxtStart, { holds the start and end index to each }
  TxtFini : Array[1..15] of Integer; { block in the AllTxt array:
    1 = X surfaces
    2 = Y surfaces & slant planes
    3 = Z surfaces & cylinders
    4 = importances line
    5 = cell definitions
    6 = source list (cell ID, prob, and bias)
    7 = X coordinate range
    8 = POS coordinates
    9 = Y coordinate range
    10 = EXI coordinates
    11 = near source detector locations
    12 = Z coordinate range
    13 = AXS coordinates
    14 = RAD coordinates }

Procedure New_Screen;
{ Clears the screen and places the distinctive header on the top line }
Begin
  TextAttr:= White; ClrScr;
  TextAttr:= HelpTitle; ClrEol; Write(Space,Version);
  TextAttr:= HelpText; Msg(78-Length(Author),1,Author);
  TextAttr:= TblColor; Writeln;
  Writeln(' Converts KE-GEOM.WQ1 text output into MCNP input pieces.');
  TextAttr:= HlColor; Writeln;
  Writeln(' The KE-GEOM.WQ1 text file is assumed to be named ',FileDrive,SSFile);
  TextAttr:= TblColor; Writeln;
  Writeln(' The geometry (surface & cells) are placed in ',FileDrive,Gfile);
  Writeln(' The radiation sources are placed in ',FileDrive,Sfile);
  Writeln(' The near source dose points are placed in ',FileDrive,Pfile);
  Writeln;
  ScnLine:= 9; TextAttr:= HdrColor;
End;

Procedure Show_Err(MsgST : ST79);
{ Displays error message and quits }
Begin
  If MsgST[0] > #0 Then Begin { error message first }
    TextAttr:= ErrColor; Inc(ScnLine,2); Msg(1,ScnLine,MsgST);
  End;
  Halt;
End;

```

```

Procedure Initialize;
{ Opens the current input and summary files. }
Var I : Integer;
Begin
  New_Screen;
  ST:= FileDrive + SSFile;
{ verify existence of the input file }
  Assignn(fi,ST);      {$(1-)} Reset(fi); {$(1+)}
  If IOResult > 0 Then
    Show_Err('Oops! The file '+ST+' could not be located!');
  For I:= 1 To SrcMax Do SrcOrd[I]:= I;
  LineD:= 0; PartD:= 0;
End;

Procedure Read_Parts;
{ Reads the input file looking for line which begin with a character
  in the first column. Other lines are skipped. Once such a line is
  found, the lines are stored in memory until a blank line is encountered.
  SrcFlag catches some format issues at the beginning of the source list. }
Var K : Integer; Found,SrcFlag : Boolean;
Procedure Show_Where;
Begin
  If PartD > 0 Then TxtFin(PartD):= LineD;
  Inc(PartD);
  TxtStrt(PartD):= Succ(LineD);
  Writeln(PartD:3,TxtStrt(PartD):5: ',Copy(ST,1,69));
End;
Begin
  ST:= '';
  Repeat
    Readln(fi,ST);
    Found:= (Length(ST) > 0) and (ST[1] <> Space);
    Until Eof(fi) or Found;
  SrcFlag:= Copy(ST,1,3) = 'sc1';
  Show_Where;
  Repeat
    Inc(LineD);          AllTxt[LineD]:= NewStr(ST);
    Readln(fi,ST);
    If SrcFlag Then Begin
      K:= Pos('sb1',ST); Delete(ST,K+3,50);
      SrcFlag:= false;
    End Else
      If (PartD = 13) and (Copy(ST,1,3) = 'sc8') Then Show_Where;
    Until (Length(ST) = 0) or (LineD > MaxLine) or Eof(fi);
  End;

Procedure Dump_Block(Blk:Byte);
Var J : Integer;
Begin
  For J:= TxtStrt[Blk] to TxtFin[Blk] Do Writeln(fo,AllTxt[J]^);
End;

Procedure Dump_MCNP_Geom;
Var K : Integer;
Begin
  ST:= AllTxt[TxtStrt[5]]^; TextAttr:= TblColor;
  If Pos('16',ST) > 0 Then CH:= '1' Else CH:= '2';
  ST:= FileDrive + Gfile + CH + '.L3';
  Writeln(' Writing the file ',ST);
  Assignn(fo,ST); Rewrite(fo);
  Dump_Block(5); { cells }
  Writeln(fo);
  Dump_Block(1); { X surfaces }
  Dump_Block(2); { Y surfaces }
  Dump_Block(3); { Z surfaces }
  Writeln(fo);
  For K:= 1 To Gnum Do Writeln(fo,GeomInfo(K));
  Writeln(fo,AllTxt[TxtStrt[4]]); { importances }
  Close(fo);
End;

```

```

Procedure Dump_MCNP_Srcs;
Var J, K : Integer;
Begin
  ST:= FileDrive + Sfile;      TextAttr:= TblColor;
  Writeln(' Writing the file ',ST);
  Assign(fo,ST);      Rewrite(fo);
  WriteLn(fo,'nps 500000');
  ST:= AllTxt[TxtStrt[6]]';      K:= Length(ST);
  While ST[K] = Space Do Dec(K); { skip any trailing blanks }
  While ST[K] <> Space Do Dec(K); { skip over the photons/sec units }
  Dec(K);      J:= K;
  While ST[K] <> Space Do Dec(K); { skip over the number }
  WriteLn(fo,'sdef erg=0.662 cel=d1 xfcel d2 yfcel d3 zfcel d4 wgt=',
  Copy(ST,Succ(K),-K));
  Close(fo);
End;

Procedure Dump_MCNP_NrPt;
Begin
  ST:= FileDrive + Pfile;      TextAttr:= TblColor;
  Writeln(' Writing the file ',ST);
  Assign(fo,ST);      Rewrite(fo);
  Dump_Block(6); { source ID }
  Dump_Block(7); { X ranges }
  Dump_Block(9); { Y ranges }
  Dump_Block(12); { Z ranges }
  Dump_Block(8); { POS ranges }
  Dump_Block(10); { EXT ranges }
  Dump_Block(13); { AXS ranges }
  Dump_Block(14); { RAD ranges }
  Close(fo);
End;

Procedure Check_Memory;
{ Displays the number of bytes available on the heap. }
Begin
  TextAttr:= White;      Writeln;
  Writeln(MaxAvail,' bytes available on heap');
  Writeln;
End;

Procedure Get_Source_Specs;
{ Interprets the fcel blocks and revises them to have the correct
  number of entries. }
Var Err,Lng,Ia,lb,J,Lno,LnA,LnB,Src,Wrk : Integer;
Function Numeric_String : ST15;
{ Uses the global ST, Ia, lb to return a numeric string }
Begin
  Ia:= Ib;  While ST[Ia] = Space Do Inc(Ia); { skip leading spaces }
  Ib:= Ia;  While ST[Ib] <> Space Do Inc(Ib); { find end of number }
  Numeric_String:= Copy(ST,Ia,lb-Ia);
End;
Procedure Identify_Specs(Blk,Coord,Jinit:Integer);
Var N : Integer;  TmpST : ST25;  ZeroX : Boolean;
Begin
  { first, look through the pointer block to find Vx values }
  LnA:= Succ(TxtStrt[Blk]);  Src:= 0;
  If Jinit = 0 Then Lno:= LnA
    Else Lno:= Succ(LnA);{ cylinders have zeros for the first line }
  ST:= AllTxt[Lno]^ + Space;
  Repeat
    Lng:= Length(ST);      Ib:= 10;
    Repeat
      Val(Numeric_String,Wrk,Err);
      If Err > 0 Then Show_Err('invalid: '+ST);
      If wrk > 0 Then Begin
        Inc(Src);      SrcSpec[Src+Jinit]^ .Vx[Coord]:= wrk;
        End;
    Until Ib = Lng;
    Inc(Lno);      ST:= AllTxt[Lno]^ + Space;
  Until Lno = LnB;
End;

```

```

Until ST[1] = 's';
Writeln('Block',Blk:3,' ',Src,' sources');
LnB:= Lno;                                If Blk = 7 Then Nxyz:= Src; { only for X ranges }
{ second, revise the fccl block to add any necessary zeros }
Lno:= LnA;                                 ST:= Copy(AllTxt[Lno]^,1,8);
ZeroX:= Jinit > 0;                         Lng:= Length(AllTxt[Lno]^);
If ZeroX Then wrk:= Lng-3 Else wrk:= Lng-5;
For N:= 1 to SpecNum Do With SrcSpec[N]^ Do Begin
  If Length(ST) > wrk Then Begin
    AllTxt[Lno]:= ST;      Inc(Lno);      ST:= '          ';
  End;
  If ZeroX Then TmpST:= ' 0' Else Str(Vx[Coord]:5,TmpST);
  ST:= ST + TmpST;
  If N = Nxyz Then Begin      ZeroX:= not ZeroX;
    If ZeroX Then wrk:= Lng-3 Else wrk:= Lng-5;
  End;
  End;
  AllTxt[Lno]^:= ST;      Inc(Lno);
{ third, rearrange pointers to eliminate the extra lines }
Lng:= LnB - Lno;                          Dec(TxtFinI[Blk],Lng);
For N:= Lno to TxtFinI[Blk] Do AllTxt[N]:= AllTxt[N-Lng];
{ fourth, look at the distribution lines to locate six & spx }
ST:= AllTxt[Lno]^;
If ST[5] = Space Then Ib:= 2 Else Ib:= 3;
Val(Copy(ST,3,Ib),wrk,Err);
If Jinit = 0 Then Begin Ia:= 1;           Ib:= Nxyz;   End
  Else Begin Ia:= Succ(Nxyz); Ib:= SpecNum; End;
For N:= Ia to Ib Do With SrcSpec[N]^ Do Begin
  Lng:= Vx[Coord] - wrk;
  If Blk = 10 { EXT has no SP lines }
    Then Begin six[Coord]:= Lno + Lng;   spx[Coord]:= 0
  Else Begin six[Coord]:= Lno + 2*Lng;  spx[Coord]:= Succ(six[Coord]) End;
End;
End;
Begin
{ first, create the SrcSpec array with source cell and weight information }
Lno:= TxtStrI[6] + 3;      TextAttr:= HdrColor;
ST:= AllTxt[Lno]^;          Src:= 0;
Repeat
  Inc(Src);   Ib:= 1;      New(SrcSpec[Src]);
  With SrcSpec[Src]^ Do Begin
    Val(Numeric.String.cel,Err);
    If Err > 0 Then Show_Err('cel invalid: '+ST);
    Val(Numeric.String.wgt,Err);
    If Err > 0 Then Show_Err('wgt invalid: '+ST);
    Val(Numeric.String.nps,Err);
    If Err > 0 Then Show_Err('nps invalid: '+ST);
    wgt:= wgt * 3.7E+10; { convert to Bq }
    Title:= Copy(ST,32,18);        Ib:= Length(Title);
    While Title[Ib] = Space Do Dec(Ib); Title[0]:= Chr(Ib);
    Ia:= 60;      While ST[Ia] = Space Do Inc(Ia);
    Concat:= Copy(ST,Ia,15);
    For Ia:= 1 to 4 Do
      Begin Vx[Ia]:= 0; six[Ia]:= 0; spx[Ia]:= 0; End;
    Fname:= ' --- ' ; Effic:= Space;
  End;
  Inc(Lno);                  ST:= AllTxt[Lno]^;
Until ST[1] = 'c';
SpecNum:= Src;
Identify_Specs( 7,1,0); { X coordinate ranges }
Identify_Specs( 9,2,0); { Y coordinate ranges }
Identify_Specs(12,3,0); { Z coordinate ranges }
Identify_Specs( 8,1,Nxyz); { POS coordinates }
Identify_Specs(10,2,Nxyz); { EXT coordinates }
Identify_Specs(13,3,Nxyz); { AXS coordinates }
Identify_Specs(14,4,Nxyz); { RAD coordinates }
End;

Procedure Read_MCNP_Eff;
Var fe : Text;      Wrk,K : Integer;    WrkST : ST;
Begin
  ST:= FileDrive + Efffile;
{ verify existence of the MCNP efficiency file }
Assign(fe,ST);      {$I-} Reset(fe); {$I+}
If IOResult < 0 Then
  Show_Err('Oops! The file '+ST+' could not be located!');
While not Eof(fe) Do Begin

```

```

Readln(fe,ST);    WrkST:= Copy(ST,53,3);
While WrkST[1] = Space Do Delete(WrkST,1,1);
Val(WrkST,Wrk,K); { cell ID number }
WrkST:= Copy(ST,34,7);
For K:= 1 to SpecNum Do With SrcSpec[K]^ Do
  If cel = Wrk Then Effic:= WrkST;
End;
Close(fe);
End;

Procedure Create_Water_Src;
{ pool water only - one source file }
Var J,K,Ka : Integer;      WrkST : ST33;
Begin
  { look through cell region title for water depth }
  ST:= AllTxt[TxtStrt[5]]^;
  If Pos('16',ST) > 0 Then CH:= '1' Else CH:= '2';
  K:= Pos('Water!',ST);           J:= Pos('11',ST);
  ST:= 'sc1  ' +Copy(ST,K,Succ(J-K))+' (20 cm Layer; 1.0 uCi/L)';
  WrkST:= FileDrive + 'S-WATER.' + CH;
  TextAttr:= TblColor;   WriteLn(' Creating source file for pool water: ',WrkST);
  TextAttr:= HdrColor;
  Assign(fo,WrkST);   Rewrite(fo);
  WriteLn(fo,'nps  40000');
  WriteLn(fo,'sdef  erg=0.662 cel=d1 x=fcel d2 y=fcel d3 z=fcel d4 wgt=7.87E+09');
  WriteLn(fo,ST);      Ka:= Succ(TxtStrt[6]);
  For J:= Ka to (Ka+12) Do WriteLn(fo,AllTxt[J]^);
  For K:= 1 to 3 Do Begin
    If K = 1 Then Ka:= 7 Else
    If K = 2 Then Ka:= 9 Else Ka:= 12;
    Ka:= TxtStrt[K];
    WriteLn(fo,AllTxt[Ka]^);
    Write(fo,Copy(AllTxt[Succ(Ka)]^,1,10));
    For J:= 1 to 11 Do Write(fo,SrcSpec[J]^,Vx[K]:5); { fcel info }
    WriteLn(fo,'  ' + Ka-'Pred(SrcSpec[1])^,six[K]');
    For J:= 1 to 2*Succ(SrcSpec[1])-Vx[K] - SrcSpec[1]^,Vx[K] Do
      WriteLn(fo,AllTxt[Ka+J]^);
    End;
  Close(fo);
End;

Procedure Create_Src_Files(Strt:Byte);
{ Skips the sources before Strt and prints all the rest }
Var Src,K,Ka : Integer;      WrkST : ST19;
Begin
  TextAttr:= TblColor;
  WriteLn(' Creating other source files!');  TextAttr:= HdrColor;
  For Src:= Strt to SpecNum Do With SrcSpec[Src]^ Do Begin
    If Src < 36 { 1-11 are the pool, 12-35 are the walls, 36-SpecNum are the rest }
      Then Begin K:= Succ(Src-Strt); CH:= 'W'; End
      Else Begin K:= Src-35;          CH:= '0'; End;
    Str(K:2,ST);
    If ST[1] = Space Then ST[1]:= Zero;
    Fname:= 'S-' + CH + ST;
    ST:= FileDrive + Fname;   Write(ST:10);
    Assign(fo,ST);   Rewrite(fo);
    WriteLn(fo,'nps  ',nps);
    Str(cel,WrkST);  ST:= 'sdef  erg=0.662 cel=' + WrkST + '  ';
    WrkST:= Sc1z(wgt); WrkST[1]:= '=';
    WrkST:= '  wgt' + WrkST;
    If Vx[4] = 0
      Then Begin Ka:= 3;
        WriteLn(fo,ST,'x=d',Vx[1],', y=d',Vx[2],', z=d',Vx[3],WrkST)
      End
      Else Begin Ka:= 4;
        WriteLn(fo,ST,'pos=d',Vx[1],', ext=d',Vx[2],', axs=d',Vx[3],', rad=d',Vx[4],WrkST);
      End;
    WriteLn(fo,'sc1,Vx[1],  ,Title,  ('ConcAmt,')');
    For K:= 1 to Ka Do Begin
      WriteLn(fo,AllTxt[six[K]]^);
      If spx[K] > 0 Then WriteLn(fo,AllTxt[spx[K]]^);
    End;
  Close(fo);
End;
End;

```

```

Procedure QuickSort(L, R: Integer);
{ Uses the QuickSort algorithm to sort the records by cel ID number }
Var
  I, J : Integer;
  X, Y : Integer;
Function Less(a,b:Integer) : Boolean;
Begin
  If SrcSpec[a]^ .cel = SrcSpec[b]^ .cel
    Then Less:= SrcSpec[a]^ .Title < SrcSpec[b]^ .Title
    Else Less:= SrcSpec[a]^ .cel < SrcSpec[b]^ .cel
End;
Begin
  I:= L;
  J:= R;
  X:= SrcOrd[(L + R) div 2];
  Repeat
    While Less(SrcOrd[I],X) Do Inc(I);
    While Less(X,SrcOrd[J]) Do Dec(J);
    If I <= J Then Begin
      Y:= SrcOrd[I];
      SrcOrd[I]:= SrcOrd[J];
      SrcOrd[J]:= Y;
      Inc(I);
      Dec(J);
    End;
  Until I > J;
  If L < J Then QuickSort(L, J);
  If I < R Then QuickSort(I, R);
End;

Procedure Write_Sorted;
Var  Src : Integer;
Begin
  QuickSort(1,SpecNum);
  Assignn(fo,FileDrive+Listfile);  Rewrite(fo);
  Writeln(fo,'Sorted list of Sources in KE-Basin');
  Writeln(fo);
  For Src:= 1 to SpecNum Do With SrcSpec[SrcOrd[Src]]^ Do
    Writeln(fo,cel:4,Space,Effic,' ',Title);
  Writeln(fo);
  Writeln(fo,'List of Sources by File Name');
  Writeln(fo);
  For Src:= 1 to SpecNum Do With SrcSpec[Src]^ Do Begin
    ST:= ' ' + Fname + ' ' + ConcAmt + ' ';
    ST[0]:= #23;
    Writeln(fo,Src:3,ST,Title);
  End;
  Close(fo);
End;

Begin
  Initialize;
  While not Eof(fi) Do Read_Parts;
  Check_Memory;
  Dump_MCNP_Geom;
  Dump_MCNP_NrPt;
  Get_Source_Specs;
  Dump_MCNP_Srcs;
  Read_MCNP_Eff;
  Check_Memory;
  Create_Water_Src; { pool water only - one source file }
  Create_Src_Files(12); { all other sources - beginning with source no. 12 }
  Write_Sorted;
End.

```

MK-NEAR.BAT to Generate MCNP Input for Near Source Points

```

@Echo Off
: creates near source input files
D:
CD \
MD T

: pool water source
Copy Geom1.L2+Pt-NEAR+S-WATER \T\HW00

: pool wall sources
For %%f in (1 2 3 4 5 6 7 8 9) Do Copy Geom1.L2+Pt-NEAR+S-W0%%f \T\HW0%%f
For %%f in (0 1 2 3 4 5 6 7 8 9) Do Copy Geom1.L2+Pt-NEAR+S-W1%%f \T\HW1%%f
For %%f in (0 1 2 3 4) Do Copy Geom1.L2+Pt-NEAR+S-W2%%f \T\HW2%%f
: remove the trailing garbage
For %%f in (0 1 2 3 4 5 6 7 8 9) Do Trim \T\HW0%%f
For %%f in (0 1 2 3 4 5 6 7 8 9) Do Trim \T\HW1%%f
For %%f in (0 1 2 3 4) Do Trim \T\HW2%%f
Move \T\*. C:\MCNP\NEAR

: sources using the entire grid - no lattices
For %%f in (1 2 3 4 5 6 7 9) Do Copy Geom1.X+Pt-NEAR+S-00%%f \T\H00%%f
For %%f in (0 1 2 3 4 5 6 8 9) Do Copy Geom1.X+Pt-NEAR+S-01%%f \T\H01%%f
For %%f in (0 1 3 4 5 6 7 8 9) Do Copy Geom1.X+Pt-NEAR+S-02%%f \T\H02%%f
For %%f in (0 1 2 3 7 8 9) Do Copy Geom1.X+Pt-NEAR+S-03%%f \T\H03%%f
: remove the trailing garbage
For %%f in (1 2 3 4 5 6 7 9) Do Trim \T\H00%%f
For %%f in (0 1 2 3 4 5 6 8 9) Do Trim \T\H01%%f
For %%f in (0 1 3 4 5 6 7 8 9) Do Trim \T\H02%%f
For %%f in (0 1 2 3 7 8 9) Do Trim \T\H03%%f
Move \T\*. C:\MCNP\NEAR

: sources using the entire grid - no lattices
For %%f in (0 1 2 3 4 8 9) Do Copy Geom1.X+Pt-NEAR+S-04%%f \T\H04%%f
For %%f in (0 1 2 3 5 6) Do Copy Geom1.X+Pt-NEAR+S-05%%f \T\H05%%f
For %%f in (5 6 7 9) Do Copy Geom1.X+Pt-NEAR+S-06%%f \T\H06%%f
For %%f in (0 1 2 3 4 5 6 7) Do Copy Geom1.X+Pt-NEAR+S-07%%f \T\H07%%f
: remove the trailing garbage
For %%f in (0 1 2 3 4 8 9) Do Trim \T\H04%%f
For %%f in (0 1 2 3 5 6) Do Trim \T\H05%%f
For %%f in (5 6 7 9) Do Trim \T\H06%%f
For %%f in (0 1 2 3 4 5 6 7) Do Trim \T\H07%%f
Move \T\*. C:\MCNP\NEAR

: sources using the entire grid - floor lattices
For %%f in (008 017 022 034 035 036) Do Copy Geom1.L2+Pt-NEAR+S-%%%f \T\H%%f
For %%f in (045 046 047 054 057 058) Do Copy Geom1.L2+Pt-NEAR+S-%%%f \T\H%%f
For %%f in (059 060 061 062 063 064 068) Do Copy Geom1.L2+Pt-NEAR+S-%%%f \T\H%%f
: remove the trailing garbage
For %%f in (008 017 022 034 035 036) Do Trim \T\H%%f
For %%f in (045 046 047 054 057 058) Do Trim \T\H%%f
For %%f in (059 060 061 062 063 064 068) Do Trim \T\H%%f
Move \T\*. C:\MCNP\NEAR

```

UNIX Script File to Run MCNP Cases

```
#    USER=w67656
#    @$-r mcnp-h1
#    @$-e zerr.h1
#    @$-o zout.h1
#    @$-T 3000:00
#    @$-t 3000:00
#    @$-me
#
#    cd /t/'hostname'          # Change to the /t space on the machine
#    mkdir pdrl                # Create directory to run in
#    cd pdrl                  # Change to the directory you created
#    pwd

rm h001.t h001.sum           # Remove old files if they exist
rcp erpag2:/home/w67656/k-pool/h001 .
/apps/mcnp/mcnph inp=h001 outp=h001.t
rm runtpc
mv mctal h001.sum
rcp h001.t erpag2:/home/w67656/k-pool/h001.t
rcp h001.sum erpag2:/home/w67656/k-pool/h001.sum

rm h002.t h002.sum           # Remove old files if they exist
rcp erpag2:/home/w67656/k-pool/h002 .
/apps/mcnp/mcnph inp=h002 outp=h002.t
rm runtpc
mv mctal h002.sum
rcp h002.t erpag2:/home/w67656/k-pool/h002.t
rcp h002.sum erpag2:/home/w67656/k-pool/h002.sum

rm h003.t h003.sum           # Remove old files if they exist
rcp erpag2:/home/w67656/k-pool/h003 .
/apps/mcnp/mcnph inp=h003 outp=h003.t
rm runtpc
mv mctal h003.sum
rcp h003.t erpag2:/home/w67656/k-pool/h003.t
rcp h003.sum erpag2:/home/w67656/k-pool/h003.sum

rm h004.t h004.sum           # Remove old files if they exist
rcp erpag2:/home/w67656/k-pool/h004 .
/apps/mcnp/mcnph inp=h004 outp=h004.t
rm runtpc
mv mctal h004.sum
rcp h004.t erpag2:/home/w67656/k-pool/h004.t
rcp h004.sum erpag2:/home/w67656/k-pool/h004.sum

.

.

.

etc.
```

Appendix F. Post-processing of MCNP Output

MCTAL Summary File for the PVC Hot Spot Source (H071.SUM)

```

mcnph   4a   04/10/97 10:19:50   2      100      752
  KE Basin Geometry -- Water Level is 16'10" -- No Lattices
  ntal    1
  5
  tally   5   2
        Dose Points Near Sources
f       73
d       2
u       0
s       0
m       0
c       0
e       0
t       0
vals
  1.63276E-01 0.0302  1.14218E-01 0.0370  1.24526E-01 0.0363  8.21117E-02 0.0476
  1.64786E-01 0.0301  1.15420E-01 0.0370  1.84322E-01 0.0135  1.30821E-01 0.0202
  7.64363E-18 0.0596  4.02246E-21 0.0652  1.44501E+01 0.0016  1.39102E+01 0.0016
  4.99304E+00 0.0009  4.68056E+00 0.0009  3.27147E-01 0.0427  3.23790E-02 0.0597
  2.43358E-02 0.1238  1.43368E-03 0.1414  1.72811E+00 0.0006  1.54902E+00 0.0006
  4.52657E+01 0.0023  4.43008E+01 0.0023  4.30286E+01 0.0023  4.20881E+01 0.0023
  7.88742E-12 0.0139  1.83744E-14 0.0155  9.01865E-14 0.0146  1.25197E-16 0.0163
  4.97960E-07 0.0628  4.06648E-09 0.0700  9.64358E-15 0.0624  1.05157E-17 0.0681
  6.05282E-11 0.0584  1.77613E-13 0.0640  4.21358E-07 0.0542  3.36058E-09 0.0595
  3.09089E-03 0.0479  7.60395E-03 0.0546  7.35444E+00 0.0257  2.31378E+00 0.0489
  1.14260E-01 0.0363  7.25491E-01 0.0533  1.14324E-01 0.0563  7.25953E-02 0.0530
  3.82232E-07 0.0522  3.41925E-08 0.0547  2.29603E+00 0.0008  2.08786E+00 0.0007
  2.35773E+00 0.0004  2.14663E+00 0.0007  4.46943E+00 0.0023  4.37356E+01 0.0023
  4.36342E+01 0.0024  4.26871E+01 0.0025  3.34808E+01 0.0023  3.26252E+01 0.0024
  1.85717E+01 0.0017  1.79580E+01 0.0017  1.99022E+01 0.0017  1.92664E+01 0.0018
  2.10093E+01 0.0080  2.02398E+01 0.0120  1.44047E+01 0.0015  1.38657E+01 0.0015
  1.09018E+01 0.0013  1.03434E+01 0.0013  1.16276E+01 0.0013  1.11445E+01 0.0014
  2.20447E-04 0.0433  4.39955E-06 0.0487  2.10666E+00 0.0009  4.79548E-01 0.0009
  1.93533E+00 0.0009  4.40914E-01 0.0009  2.37355E+00 0.0062  4.09234E-01 0.0078
  7.70084E-00 0.0047  1.81705E+00 0.0056  1.15017E+01 0.0027  2.22949E+00 0.0032
  4.34304E+01 0.0024  4.24855E+01 0.0025  4.49600E+01 0.0025  4.39984E+01 0.0025
  5.11123E+00 0.0005  1.34448E+00 0.0005  4.32762E+01 0.0005  3.48519E-01 0.0003
  1.98915E-01 0.0312  1.43469E-01 0.0381  1.09945E-01 0.0515  5.38572E-02 0.1074
  9.23046E-02 0.0505  4.47767E-02 0.1044  8.12652E-02 0.0528  3.53493E-02 0.1194
  1.13218E-01 0.0457  6.77231E-02 0.0711  1.08961E-01 0.0463  6.47709E-02 0.0730
  1.05417E-01 0.0477  6.24378E-02 0.0738  1.09240E-01 0.0663  6.49501E-02 0.0729
  3.89320E-02 0.0496  7.44772E-03 0.0581  8.45244E-01 0.0524  8.26202E-04 0.0590
  2.66614E-02 0.0753  4.64316E-03 0.0985  1.02891E-01 0.0449  5.96415E-02 0.0745
  1.09713E-01 0.0520  5.76619E-02 0.0986  1.16962E-01 0.0487  6.41877E-02 0.0894
  2.05847E-01 0.0002  1.50797E-01 0.0003  2.06127E-01 0.0002  1.51032E-01 0.0003
  2.85914E+00 0.0007  2.62552E+00 0.0008  6.76721E-01 0.0004  5.68757E-01 0.0004
  2.55472E-01 0.0225  1.91262E-01 0.0281  1.02628E+01 0.0013  9.80968E+00 0.0013
  9.82197E+00 0.0013  9.37893E+00 0.0013  1.21023E+01 0.0013  1.16091E+01 0.0014
  2.10616E+02 0.0050  2.08521E+02 0.0050  2.38652E+03 0.0221  2.37928E+03 0.0221
  1.47202E+04 0.0414  1.47030E+04 0.0414  3.70573E+03 0.0210  3.69695E+03 0.0210
  1.64744E+03 0.0140  1.64157E+03 0.0140  9.62653E+01 0.0037  9.48527E+01 0.0038
  2.43579E+00 0.0006  2.22104E+00 0.0006
tfc    1      1      1      1      1      1      1      1      1
      100  1.63276E-01 3.02022E-02 7.93453E+03

```

ALLTBL.PAS Summary File for the PVC Hot Spot Source (H071.TBL)

KE Basin Geometry -- Water Level is 16'10" -- No Lattices

Dose Points Near Sources

PVC Hot Spot (1.0 Ci)

04/10/97 Source Points: 100

X	Y	Z	Dose Rate	RelErr %	Comment
271.78	5778.50	60.96	1.633E-01	3.020E+00	Over Elevator Pit NW
332.74	6242.05	60.96	1.245E-01	3.630E+00	Over Elevator Pit E
439.42	5778.50	60.96	1.648E-01	3.010E+00	Over Elevator Pit SW
902.97	5728.97	40.64	1.843E-01	1.350E+00	Pump #2 Pedestal
1137.92	797.55	129.54	7.644E-18	5.960E+00	IXM #1 (G10) Chest
1137.92	1272.52	129.54	1.445E+01	1.600E-01	IXM #2 (K10) Chest

1498.76	1164.59	139.70	4.993E+00	9.000E-02	Drip Pan - Pit End
1498.76	951.23	139.70	3.271E-01	4.270E+00	Drip Pan - Middle
1498.76	676.91	139.70	2.434E-02	1.238E+01	Drip Pan - Door End
850.90	2978.15	15.24	1.728E+00	6.000E-02	Sampler at Col 10.9C
741.68	1543.05	15.24	4.527E+01	2.300E-01	PVC in N Loadout
741.68	1573.53	2.54	4.303E+01	2.300E-01	PVC in N Loadout - E
167.01	1385.57	121.92	7.887E-12	1.390E+00	SF North Wall
167.01	1210.31	121.92	9.019E-14	1.460E+00	SF Northwest Corner
342.27	1210.31	121.92	4.980E-07	6.280E+00	SF West Wall
681.99	854.71	106.68	9.644E-15	6.240E+00	Pipe Along IX Box - #3
681.99	923.29	106.68	6.053E-11	5.840E+00	Pipe Along IX Box
681.99	991.87	106.68	4.214E-07	5.420E+00	Pipe Along IX Box - #2
681.99	1060.45	106.68	3.091E-03	4.790E+00	Pipe Along IX Box
681.99	1129.03	106.68	7.354E+00	2.570E+00	Pipe Along IX Box - #1
586.74	6396.99	91.44	1.143E-01	3.680E+00	Between HX/Chiller - N
1010.92	6396.99	91.44	1.143E-01	3.680E+00	Between HX/Chiller - S
842.01	6553.20	91.44	3.823E-07	5.220E+00	E Side HX
45.72	684.53	68.58	2.296E+00	6.000E-02	NW Filter Media
71.12	684.53	68.58	2.358E+00	6.000E-02	NW Filter Media at 1ft
723.90	1560.83	15.24	4.469E+01	2.300E-01	N Loadout Entry - Pit
723.90	1665.61	15.24	4.363E+01	2.400E-01	N Loadout Entry
723.90	1770.38	15.24	3.348E+01	2.300E-01	N Loadout Entry - Pool
431.17	1705.61	104.14	1.857E+01	1.700E-01	SF Pipes, lower E
431.17	1690.37	134.62	1.990E+01	1.700E-01	SF Pipes, upper E
446.41	1545.59	119.38	2.101E+01	8.000E-01	SF Pipes, lower W
424.18	1766.57	27.94	1.440E+01	1.500E-01	Beam at Col 13B
1308.10	1816.10	121.92	1.090E+01	1.300E-01	Column 13D
1308.10	1816.10	213.36	1.163E+01	1.300E-01	Col 13D - Above Head
1513.84	1720.85	283.21	2.204E-04	4.330E+00	9.5' W Ovrhd - SE
1605.28	1644.65	283.21	2.105E-05	9.000E-02	9.5' W Ovrhd - SE
1605.28	1469.39	106.68	1.935E+00	9.000E-02	S Loadout Riser
571.50	1235.71	106.68	2.374E+00	6.200E-01	Pipe Along N Load, W
571.50	1408.43	106.68	7.701E+00	4.700E-01	Pipe Along N Load, Mid
571.50	1581.15	106.68	1.150E+01	2.700E-01	Elbow - N Loadout - N
586.74	1596.39	106.68	4.343E+01	2.400E-01	Elbow - N Load - Outer
586.74	1565.91	119.38	4.496E+01	2.500E-01	Elbow - N Load - inner
2075.18	2382.52	91.44	1.511E+00	5.000E-02	S Wall Col 12.2
2075.18	4060.19	91.44	4.328E-01	3.000E-02	S Wall Col 9.5
2075.18	5203.19	91.44	1.989E-01	3.120E+00	S Wall Col 7.7
1546.86	5647.69	304.80	1.099E-01	5.150E+00	E 10' NS Middle
857.25	6125.21	304.80	9.230E-02	5.050E+00	E 10' NS N Piece
1336.04	6140.45	365.76	8.127E-02	5.290E+00	E 10' NS S Piece @ 2'
1567.18	6079.49	152.40	1.132E-01	4.570E+00	View Pit Riser #1
1567.18	6140.45	152.40	1.090E-01	4.650E+00	View Pit Riser #2
1567.18	6201.41	152.40	1.054E-01	4.710E+00	View Pit Riser #3
1536.70	6140.45	152.40	1.092E-01	4.640E+00	View Pit Risers - 1 ft
1308.10	6165.31	121.92	3.893E-02	4.960E+00	Bypass Loop - Inner
1308.10	6201.41	121.92	8.452E-03	5.240E+00	Bypass Loop - East
1308.10	6165.31	289.56	2.666E-02	7.530E+00	Bypass Loop - Above
1069.34	6320.79	182.88	1.029E-01	4.490E+00	Valve - S End Chiller
769.62	5835.65	283.21	1.097E-01	5.200E+00	Pump Overhead
647.70	5835.65	252.73	1.170E-01	4.870E+00	Pump #1 Riser
647.70	5571.49	27.94	2.058E-01	2.000E-02	Pump #1 Knee
891.54	5571.49	27.94	2.061E-01	2.000E-02	Pump #2 Knee
81.28	2391.41	91.44	2.859E+00	7.000E-02	N Wall Valve at Col 12
81.28	3694.43	91.44	6.767E-01	4.000E-02	N Wall Valve at Col 10
81.28	4989.83	91.44	2.555E-01	2.250E+00	N Wall Valve at Col 8
342.27	1831.34	27.94	1.026E+01	1.300E-01	SF Pump Knee
342.27	1846.58	12.70	9.822E+00	1.300E-01	SF Pump Knee
342.27	1637.03	27.94	1.210E+01	1.300E-01	SF Pump
812.80	1565.91	152.40	2.106E+02	5.000E-01	PVC Pipe Riser - NL
812.80	1565.91	274.32	2.386E+03	2.210E+00	PVC Pipe - W Elbow
812.80	1604.01	259.08	1.472E+04	4.140E+00	PVC Hot Spot - Contact
812.80	1604.01	243.84	3.706E+03	2.100E+00	PVC Hot Spot - 6 in
812.80	1604.01	228.60	1.647E+03	1.400E+00	PVC Hot Spot - 1 ft
995.68	1611.63	320.04	9.627E+01	3.700E-01	PVC Pipe - 6 ft
1991.36	1611.63	320.04	2.436E+00	6.000E-02	PVC Pipe - S Elbow

ALLTBL.PAS Software Listing

```

Program Convert_MCTAL;
{ Author: Paul D. Rittmann, PhD CHP
  Purpose: Reads all the MCNP input files and MCTAL summary files, then
            arranges the MCNP output into a usable table, and writes a
            binary files with the source information and detector points.
            Also produces text files for spreadsheet input, and various
            text files (geometry, detector point titles, source titles).
  Input:   The MCNP input files in the user input subdirectory.
}

Uses Crt, DOS;

Const Space = ' '; Zero = '0'; Bslash = '\';
  Ntop = 40; { number of highest DR indices }
  PtMax = 90; { number of near source dose rate points }
  SrcMax = 200; { number of distinct radiation sources }
  { These are the filename extensions. The file names used for the summaries
  is the same as the subdirectory name. }
  SrcFile = '-S.BIN'; SsFile = '-SS'; PtFile = '-P.BIN';
  FileG = '.G'; FileP = '.P'; Files = '.S'; FileD = '.D';
  MCTALExt = '.SUM'; { extension characteristic of MCTAL summary files }
  IntChar : Array[0..15] of Char = '0123456789ABCDEF';

Type
  Str79 = String[79];
  Str19 = String[19];
  Str15 = String[15];
  PtPtr = ^PtDataType;
  PtDataType = Record { 100 bytes }
    DeTitle : Str79; { location description }
    QA_Totl; { measured readings (mR/h) and computed sum (mrem/h) }
    X,Y,Z : Single; { X,Y,Z coordinates }
  End;
  DRarray = Array[1..PtMax] of Single; { 360 bytes }
  SrcPtr = ^Srcdatatype;
  Srcdatatype = Record { 160+32+720+80+8 = 1000 bytes }
    SrcID; { title of source }
    GeomSt : Str79; { title of geometry file }
    FileID; { which input file }
    Units : Str15; { original amount units }
    NearDR; { near source dose rates for Amt=1 }
    RelErr : DRarray; { relative error in NearDR }
    TopN : Array[1..Ntop] of Integer; { indices to highest NearDR values }
    nps : Longint; { number of source particles used }
    Conc : Single; { original concentration used in the MCNP run }
  End;

Var
  MCfile : Array[1..200] of Str19; { names of MCNP input file (XXX), and
                                    MCTAL summary file (XXX.SUM) }
  SubDir, { subdirectory with input & summary files }
  OutFile, { used for output summary file names }
  InFile, { MCNP input file }
  SumFile : Str15; { MCTAL file }
  Title1,Title2,Title3, { geometry, dose points and source title lines }
  RunInfo : Str79;
  Hstr : String[5];
  fg,fp,fs,fd,
  fi,sum : Text;
  Nsrc, { number of sources = number of input files }
  SrcPt,
  Npts,
  KsNs : Integer;
  Xg,Yg, { coordinates of detector point }
  PtData : Array[1..Ptmax] of PtPtr;
  SrcData : Array[1..SrcMax] of SrcPtr;
  First : Boolean;
  SScol : Array[1..PtMax] of String[2];
  LineStr : String[89];

Function Sci3( r:Single ) : Str79;
{ Returns an 11 character string with r in the format ' 1.234E+04' }
Var ST : String[12];
Begin
  Str(r:12,ST);

```

```

Delete(ST,9,2);
Sci3:= ' ' + ST;
End;

Function Sci4( r:Single ) : Str79;
{ Returns an 11 character string with r in the format ' 1.2345E+04' }
Var ST : String[13];
Begin
  Str(r,13,ST);
  Delete(ST,10,2);
  Sci4:= ' ' + ST;
End;

Procedure Show_How(Msg : String);
Begin
  If Msg[0] > #0 Then Begin { error message first }
    TextAttr:= LightMagenta;   Writeln;
    Writeln(Msg);
    End;
  TextAttr:= White;           Writeln;
  Write('ALLTBL.EXE');       TextAttr:= LightCyan;
  Writeln(' - Converts all MCNP input and MCTAL summaries into readable tables.');
  Writeln(' by Paul D. Rittmann, PhD CHP          13-Feb-97');
  TextAttr:= LightGreen;     Writeln;
  Writeln('Execution requires both a subdirectory name and the first characters');
  Writeln(' of the input file names on the command line. Other characters are');
  Writeln(' assumed to be sequential numbers.');
  Writeln(' For example, ALLTBL NEAR H HW will look for H000 H001 etc. and');
  Writeln(' HWO0 HW01 etc. in the NEAR subdirectory.');
  TextAttr:= LightCyan;      Writeln;
  Writeln('The dose rate summary tables are written to the .TBL files.');
  Writeln('Titles used in each MCNP run are listed in ',FileG,', ',FileP,', and ',FileS,'.');
  Writeln('Binary files have source (' ,Srcfile,') and detector (' ,PtFile,') information.');
  Halt;
End;

Procedure Make_Input_File_List(fstr:String);
{ Looks for input files 4 characters long which begin with Fstr. }
Var WrkName : Str19;        fx : Text;
  N,Lng,MaxNum,GrpCount : Integer;
Begin
  Lng:= Length(Fstr);       Writeln;
  For N:= 1 To Lng Do Fstr[N]:= UpCase(Fstr[N]);
  Fstr:= Fstr + '000';       Fstr[0]:= '#';
  If Lng = 1 Then MaxNum:= 999 Else MaxNum:= 99;
  GrpCount:= 0;
  Repeat
    Fstr[4]:= IntChar[GrpCount mod 10];
    If GrpCount > 9 Then Fstr[3]:= IntChar[(GrpCount div 10) mod 10];
    If GrpCount > 99 Then Fstr[2]:= IntChar[GrpCount div 100];
    Infile:= SubDir + Fstr;
    Assign(fx,Infile);        {$I-} Reset(fx);  {$I+}
    If IOResult = 0
      Then Begin Close(fx);
      Inc(Nsrc);             MCfile[Nsrc]:= Fstr;
      WrkName:= InFile + MCTALext;
      Assign(fx,WrkName);    {$I-} Reset(fx);  {$I+}
      If IOResult > 0 Then
        Show_How('Oops! The file '''+WrkName+''' could not be located!');
      Close(fx);
    End
    Else Begin
      If GrpCount > 0 Then Exit;
    End;
    Write(Fstr,' ');
    Inc(GrpCount);
  Until GrpCount = MaxNum;
End;

Procedure Initialize;
Var L,K : Integer;
Begin
  TextAttr:= White;           ClrScr;   Writeln;
  Writeln('ALLTBL by Paul D. Rittmann, PhD CHP');   Writeln;
{ read the command line subdirectory name }
  SubDir:= ParamStr(1);       L:= Length(SubDir);
  For K:= 1 To L Do SubDir[K]:= UpCase(SubDir[K]);
  If SubDir[L] <> Bslash Then SubDir:= SubDir + Bslash;

```

```

TextAttr:= Yellow;           Writeln('Using ',SubDir);
OutFile:= Copy(SubDir,1,Pred(Length(SubDir)));
For K:= 1 to 89 Do LineStr[K]:= '#196';
{ prepare the list of input files to process }
Nsrc:= 0;                   TextAttr:= LightCyan;
For K:= 2 to ParamCount Do Make_Input_File_List(ParamStr(K));
Writeln;
TextAttr:= Yellow;           Writeln('FileCount: ',Nsrc);
Writeln;
{ open text summary files }
Assign(fg,OutFile+fileG); Rewrite(fg); { geometry titles }
Writeln(fg,'Titles of the Geometries');   Writeln(fg);
Writeln(fg);
Writeln(fg,' # File Title of Geometry Block');
LineStr[0]:= '#72;   Writeln(fg,LineStr);
Assign(fp,OutFile+fileP); Rewrite(fp); { detector point titles }
Writeln(fp,'Titles of the Detector Points');   Writeln(fp);
Writeln(fp);
Writeln(fp,' # File Title of Detector Block');
Writeln(fp,LineStr);
Assign(fs,OutFile+fileS); Rewrite(fs); { source ID titles }
Writeln(fs,'Titles of the Radiation Sources');   Writeln(fs);
Writeln(fs);
Writeln(fs,' # File nps Orig Conc Source Location');
Writeln(fs,LineStr);
{ create the spreadsheet column ID letters }
For K:= 1 to PtMax Do Begin
  SScol[K]:= ' ';
  SScol[K][2]:= Chr(65+(Pred(K) mod 26));
  If K > 26 Then SScol[K][1]:= Chr(64+(Pred(K) div 26));
End;
SScol[PtMax]:= ' ';
End;

Procedure Read_MCNPH_Values;
{ Reads the two input files and matches them. }
Var I,J,a,Err : Integer;          zcoord : Single;
  ReadSum,More : Boolean;
  LineI,LineS : String;
Procedure Write_Source_Item(Var f : Text);
{ Writes one line (LineI) to the specified text file }
Begin
  Writeln(f,Src:3,' ',Mcfile[Src],I,LineI);
End;
Procedure Show_Titles(Hdr:Str79);
{ Displays title lines in LineI and LineS on the screen }
Var Lng : Integer;
Begin
  While LineI[I] = Space Do Delete(LineI,1,1);
  While LineS[I] = Space Do Delete(LineS,1,1);
  Lng:= Length(LineS);  While LineS[Lng] = Space Do Dec(Lng);
  LineS[0]:= Chr(Lng);
  If LineI <> LineS Then Begin  TextAttr:= LightMagenta;
    Writeln;  Write('***** ',Hdr,' Don''t Match!!!!');
  End;
End;
Procedure Get_Coord(Var Strt:Integer; Var NewVal:Single;  Msg:Str79);
{ Reads a real number in LineI beginning at Strt.  If the string to real conversion is valid then NewVal is the number, and Strt is at the first blank. Otherwise, Show_How is called with the Msg string. }
Var Fini : Integer;
Begin
  While LineI[Strt] = Space Do Inc(Strt);  { start of X-coordinate }
  Fini:= Succ(Strt);
  While LineI[Fini] <> Space Do Inc(Fini);  { end of number }
  Val(Copy(LineI,Strt,Fini-Strt),NewVal,Err);
  If Err > 0 then Show_How('Invalid '+Msg+' :'+Copy(LineI,Strt,Fini-Strt));
  Strt:= Fini;
End;
Procedure Get_The_Info(Indx:Integer);
{ Reads a single dose rate and relative error from the MCAL file }
Var Tmp : Single;  Found : Boolean;  Ka,Kb : Integer;
Begin
  With PData[Indx]^ Do Begin
    { read the MCNPHE dose rate at this point }
    If ReadSum Then Begin Readln(fsum,LineS); a:= 3; End
      Else a:= 43;
    ReadSum:= not ReadSum;
  End;

```

```

Val(Copy(LineS,a,11),Tmp,Err);
If Err > 0 Then Show_How('!Invalid MCNPHE Dose Rate: '+Copy(LineS,a,11));
With SrcData[Src]^ Do Begin
  NearDR[Indx]:= Tmp;           { add dose rate to SrcData record }
  { insert in the TopN sorting array }
  Ka:= 0;
  Repeat Inc(Ka);
    Found:= (Tmp > NearDR[TopN[Ka]]);
    Until Found or (Ka = Ntop);
    If Found Then Begin
      For Kb:= Ntop downto Succ(Ka) Do TopN[Kb]:= TopN[Pred(Kb)];
      TopN[Ka]:= Indx;
      End;
    End;
  { read the MCNPHE relative error }  a:= a + 13;
  Val(Zero+Copy(LineS,a,5),Tmp,Err);
  If Err > 0 Then Show_How('!Invalid MCNPHE Relative Error: '+Copy(LineS,a,5));
  SrcData[Src]^.RelErr[Indx]:= 100.0*Tmp;
  End;
End;
Procedure Get_nps;
Var K : Integer;
Begin
  Delete(LineI,1,5);
  RunInfo:= RunInfo + ' Source Points: ' + LineI;
  While LineI[1] = Space Do Delete(LineI,1,1); { remove leading blanks }
  K:= Length(LineI);                         While LineI[K] = Space Do Dec(K);
  LineI[0]:= Chr(K);                         Val(LineI,SrcData[Src]^.nps,K);
End;
Procedure First_File;
{ initializes the PtData array using the first input file }
Var N : Integer;
Begin
  N:= 0;                                     First:= false;
  Repeat { loop over dose points in the input file }
    Readln(fi,LineI); More:= Copy(LineI,1,5) = ' ';
    If Copy(LineI,1,4) = 'f5;p' Then More:= true;
    If More Then Begin
      Inc(N); New(PtData[N]);
      With PtData[N] Do Begin
        FillChar(DeTitle,SizeOf(DeTitle),Space);
        QA:= 0; Totl:= 0; X:= 0; Y:= 0; Z:= 0;
        { store the title of this detector point }
        I:= Pos('$',LineI); Inc(I); While LineI[I] = Space Do Inc(I);
        J:= Length(LineI);           While LineI[J] = Space Do Dec(J);
        DeTitle:= Copy(LineI,I,Succ(J-I));
        { find the measured dose rate at this point, mR/h }
        J:= Length(DeTitle);
        While DeTitle[J] < Space Do Dec(J);
        Val(Copy(DeTitle,Succ(J),4),QA,Err);
        If Err < 0 Then Show_How('!Invalid measured DR: '+DeTitle);
        While DeTitle[J] = Space Do Dec(J);
        DeTitle[0]:= Chr(J);
        { find the coordinates of this detector point }
        I:= 6;
        Get_Coord(I,X,'X-coordinate');
        Get_Coord(I,Y,'Y-coordinate');
        Get_Coord(I,Z,'Z-coordinate');
        End;
        Get_The_Info(N);
      End;
    Until not More;
  Npts:= N;
  { read the number of points }
  If Copy(LineI,1,3) = 'nps' Then Get_nps;
End;
Procedure Later_Files;
Var N : Integer;
Begin
  For N:= 1 to Npts Do Get_The_Info(N);
  { read the number of points }
  Repeat Readln(fi,LineI);
  Until Copy(LineI,1,3) = 'nps';
  Get_nps;
End;
Begin { Read_MCNPHE_Values }
  Infile:= SubDir + MCfile[Src]; Assign(fi,InFile); Reset(fi);
  SumFile:= Infile + MCTALext; Assign(fsum,SumFile); Reset(fsum);

```

```

New(SrcData[Src]);
With SrcData[Src]^ Do Begin
  FillChar(SrcID, SizeOf(SrcID), Space);
  FillChar(GeomSt, SizeOf(GeomSt), Space);
  FillChar(FileID, SizeOf(FileID), Space);           FileID:= MCfile[Src];
  FillChar(Units, SizeOf(Units), Space);
  FillChar(NearDR,SizeOf(NearDR), 0);
  FillChar(ReLerr,SizeOf(ReLerr), 0);
  For I:= 1 to Ntop Do TopN[I]:= PtMax;
  Conc:= 0;          nps:= 0;
  End;
TextAttr:= Yellow;   Write('Processing ',InFile,' and ',SumFile,'.  ');
{ read run title Lines }
Readln(fi,Line1); { input file title }
Readln(fsum,RunInfo); Delete(RunInfo,1,18); Delete(RunInfo,9,40);
Readln(sum,Lines);
Show_Titles('Main Titles');           Title1:= Line1;
SrcData[Src]^ .GeomSt:= Title1;      Write_Source_Item(fg);
{ read detector title line }
repeat Readln(fi,Line1);
repeat Readln(fsum,Lines);
Until Copy(Line1,1,3) = 'fc5';
Delete(Line1,1,5);
For I:= 1 to 3 Do Readln(fsum);      Read(fsum,LineS);
Show_Titles('Detector Titles');      Title2:= Line1;
{ read and store the MCNP dose rates }
repeat Readln(fsum,Lines);
Until Copy(Line1,1,4) = 'vals';
ReadSum:= true;
If First Then First_File
  Else Later_Files;
{ read the source comment line }
repeat Readln(fi,Line1);
Until Copy(Line1,1,2) = 'sc';
Delete(Line1,1,5);
While Line1[1] = Space Do Delete(Line1,1,1);
J:= Length(Line1); While Line1[J] = Space Do Dec(J);
{ locate the units for the original activity concentration }
I:= Pred(J);           Title3:= Line1;
If Line1[I] = '?' Then Line1[I]:= '';
While Line1[I] <> Space Do Dec(I);
With SrcData[Src]^ Do Begin
  Units:= Copy(Line1,Succ(I),Pred(J-I));
  If Units[1] = 'u' Then Units[1]:= '#';
  End;
{ find the original amount of the activity concentration }
Dec(I); J:= I;
While (Line1[J] <> '(') and (Line1[J] <> Space) Do Dec(J);
Val(Copy(Line1,Succ(J),I-J),SrcData[Src]^ .Conc,Err);
If Err > 0 then Show_How('Invalid original conc: '+Line1);
Dec(J);
While Line1[J] = Space Do Dec(J);
If Line1[J] = ';' Then Line1[J]:= ')';
With SrcData[Src]^ Do Begin
  SrcID:= Copy(Line1,1,J);
  Str(nps:6,Line1); Str(Conc:3:0,LineS);
  Line1:= Line1 + LineS + Space + Units + '           '; Line1[0]:= #19;
  Line1:= Line1 + SrcID;
  End;
Write_Source_Item(fs);
Close(fi); Close(fsum);
End;

Procedure Write_Table;
{ Creates and writes output tables. }
Var   J : Integer;   FileName : Str79;
Begin
  { open output files }
  FileName:= InFile + '.TBL';
  Assignn(fi,FileName); Rewrite(fi);
  TextAttr:= LightCyan; Writeln(fi,'Writing ',FileName);
  Writeln(fi,Title1); Writeln(fi,Title2); Writeln(fi,Title3);
  Writeln(fi,RunInfo); Writeln(fi);
  Writeln(fi, ' X     Y     Z     Dose Rate    ReLerr %    Comment');
  Writeln(fi, '-----');
  For J:= 1 to Npts Do With Ptdata[J]^ Do With SrcData[Src]^ Do
    Writeln(fi,X:9:2,Y:9:2,Z:9:2,Sci3(NearDR[J]),Sci3(ReLerr[J]),'  ',DeTitle);
  Writeln(fi, '-----');
  Close(fi);

```

```

End;

Procedure Dump_Extra_Files;
{ Creates the two binary files. Additional text files are also output.
  Fpt has the detector information. Fsrc has the source information. }
Var fpt : File of PtDataType;      K,R,Nt : Integer;
  fsrc : File of SrcDataType;     WrkSt : String;
Procedure Dump_Block(A,B:Integer);
Var Ka,Kb : Integer;
Begin
  Writeln(fs);
  For Ka:= 1 to Src Do With SrcData[Ka]^ Do Begin
    Str(Ka:3,WrkSt);           WrkSt:= WrkSt + Space;
    For Kb:= A to B Do WrkSt:= WrkSt + Sci4(NearDR[Kb]);
    Writeln(fs,WrkSt);
  End;
End;
Begin
  LineStr[0]:= #72;
  Writeln(fg,LineStr);           Close(fg);
  Writeln(fp,LineStr);           Close(fp);
  Writeln(fs,LineStr);           Close(fs);
  TextAttr:= White;              Writeln;
  WritelnSrc,' radiation sources were used. Source titles: ',
             OutFile+Files,' Data: ',OutFile+SrcFile);
  Assign(fsrc,OutFile+SrcFile);   Rewrite(fsrc);
  For R:= 1 to Nsrc Do Write(fsrc,SrcData[R]^);
  Close(fsrc);
  WritelnNpts,' detector points were used. Detector titles: ',
             OutFile+FileP,' Data: ',OutFile+PtFile);
  Assign(fpt,OutFile+PtFile);    Rewrite(fpt );
  For R:= 1 to Npts Do Write(fpt,PtData[R]^);
  Close(fpt);
  TextAttr:= Yellow;
  Writeln('Generating a list of detectors: ',OutFile+FileD);
  Assign(fd,OutFile+FileD);    Rewrite(fd);
  Writeln(fd,'List of Detectors with Spreadsheet Column ID');
  Writeln(fd);                 LineStr[0]:= #58;
  Writeln(fd,'Col Xcoord Ycoord Zcoord mm/h Detector Location');
  { AA 1234.56 1234.56 1234.56 100 12345678901234567890123 }
  Writeln(fd,LineStr);          WrkSt:= ' ';
  For R:= 1 to Npts Do With PtData[R]^ Do
    Writeln(fd,Sscol[R].X:9:2,Y:8:2,Z:8:2,OA:6:0,' ',DeTitle);
  Writeln(fd,LineStr);          Close(fd);
  Writeln('Generating a list of useful spreadsheet information: ',SsFile);
  Assign(fs,OutFile+SsFile);    Rewrite(fs);
  Writeln(fs,'List of Dose Rates from Each Source');
  K:= -19; R:= 0;
  Repeat
    Inc(K,20);     Inc(R,20);
    If R > Npts Then R:= Npts;
    Dump_Block(K,R);
  Until R = Npts;
  If Npts > 20 Then Nt:= 20 Else Nt:= Npts;
  Writeln(fs);               Writeln(fs);
  Writeln(fs,'List of Main Targets (highest ',Nt,') for Each Source');
  Writeln(fs);
  For R:= 1 to Nsrc Do With SrcData[R]^ Do Begin
    Str(R:3,WrkSt);           WrkSt:= WrkSt + Space;
    For K:= 1 to Nt Do WrkSt:= WrkSt+' '+Sscol[TopN[K]];
    Writeln(fs,WrkSt);
  End;
  Close(fs);
End;

Begin
  If ParamCount < 2 Then Show_How('');
  Initialize;
  First:= true;
  For Src:= 1 to Nsrc Do Begin
    Read_MCNPH_Values;
    Write_Table;
    End;
  Dump_Extra_Files;
End.

```

Appendix G. Program to Convert MCTAL Files for the Grid into Binary

```

Program Convert_MCTAL;
{ Author: Paul D. Rittmann, PhD CHP
  Purpose: Reads the MCNP input file and MCTAL summary file and arranges
            the MCNP output to match the standard grid. Dose rates are
            stored in the binary file. The first two records of the binary
            file contain the X and Y coordinates of the grid.
  Input:   MCNP input file, MCTAL summary output file, binary file.
           Command line parameters are the names of the input files.
           There are 4 binary files, KNEE & CHST at 2 depths.
  Output:  Text file with MCNP dose rates in the standard grid order (.2D),
           text file suitable for import into a spreadsheet (transposed),
           the updated binary file.
}

Uses Crt, DOS;

Const Space = ' '; Zero = '0'; Colon = '!'; Bslash = '\';

Xmax = 20; { number of points in the NS direction }
Ymax = 56; { number of points in the EW direction }
MCTALExt = '.SUM'; { extension characteristic of MCTAL summary files }

Type
  StdGrid = Array[1..Xmax,1..Ymax] of Single; { 4480 bytes }
  Str79 = String[79];
  Str19 = String[19];
  Str15 = String[15];
  DRRec = Record { 4576 bytes per record }
    Title : Str79;
    FileN : Str15;
    DR : StdGrid;
  End;

Var
  MCfile : Array[1..200] of Str19; { names of MCNP input file (XXX), and
                                    MCTAL summary file (XXX.SUM) }
  MCshrt : Array[1..200] of Str15; { MCfile without path information }
  BinFile, { name of binary file (KNEE1, KNEE2, CHST1, or CHST2) }
  Title1,Title2,Title3,
  RunInfo : Str79;
  HtStr : String[5];
  FileCount,
  F : Integer;
  fb : File of DRRec; { binary file }
  Xg,Yg, { coordinates of detector point }
  DR,RE : StdGrid; { Dose Rate and Relative Error from MCNP }
  OneRec : DRRec;
  Hdr1,Hdr2 : String;

Procedure Show_How(Msg : String);
Begin
  If Msg[0] > #0 Then Begin { error message first }
    TextAttr:= LightMagenta; Writeln;
    Writeln(Msg);
    End;
  TextAttr:= White; Writeln;
  Write('BINCAL1.EXE'); TextAttr:= LightCyan;
  Writeln(' - Converts one or more MCTAL output summary files.');
  Writeln(' by Paul D. Rittmann, PhD CHP April 21, 1997');
  TextAttr:= LightGreen; Writeln;
  Writeln('Command line should have the binary file name followed by one');
  Writeln('or more input file names. If the number is omitted, then all');
  Writeln('input & MCTAL files with that name will be processed.');
  Writeln;
  Writeln('Binary files are either KNEEn or CHSTn, where n is the depth');
  Writeln('of the water in the pool (1=16''10" and 2=17''2")');
  Writeln('Output files are .2D with standard grid, .200 for spreadsheet');
  Writeln('input (transposed), and an updated binary file.');
  Halt;
End;

```

```

Procedure Make_Input_File_List;
{ Reads the command line and prepares a list of file names to use }
Var WrkName, GrpN : Str19;           Morefiles : Boolean;
    N,K,Lng,GrpCount : Integer;
Procedure Verify_Files(Flg:Integer);
{ Looks for WrkName. If WrkName and WrkName.SUM are found then
  FileCount is incremented and MCfile[FileCount]:= WrkName.
  Otherwise what happens depends on Flg. If Flg=0 the program ends
  with an error message. Otherwise Morefiles is made false. }
Var fx : Text;
Begin
  Assign(fx,WrkName);   {$(I-) Reset(fx); $(I+)
  If IOResult > 0 Then Begin
    If Flg = 0 Then Show_How('Oops! The file '+WrkName+' could not be located!')
    Else Begin Morefiles:= false; Exit End
  End;
  Inc(FileCount);
  MCfile[FileCount]:= WrkName;
  Close(fx);
  WrkName:= WrkName + MCTALext;
  Assign(fx,WrkName); {$(I-) Reset(fx); $(I+)
  If IOResult > 0 Then Begin
    If Flg = 0 Then Show_How('Oops! The file '+WrkName+' could not be located!')
    Else Begin Morefiles:= false; Dec(FileCount); Exit End
  End;
  Close(fx);
  { store the simple file name without path information }
  Flg:= Lng;
  While (WrkName[Flg] <> BSlash) and (WrkName[Flg] <> Colon) and (Flg > 0) Do Dec(Flg);
  If Flg = 0 Then MCshrt[FileCount]:= MCfile[FileCount]
    Else MCshrt[FileCount]:= Copy(MCfile[FileCount],Succ(Flg),15);
End;
Begin
  BinFile:= ParamStr(1);
  For K:= 1 To Length(BinFile) Do BinFile[K]:= UpCase(BinFile[K]);
{ find binary file and read the X & Y coordinates }
  Assign(fb,Binfile); {$(I-) Reset(fb); $(I+)
  If IOResult > 0 Then Begin
    K:= Pos('.\',Binfile);
    If K = 0 Then BinFile:= BinFile + '.BIN'
      Else BinFile:= Copy(BinFile,1,K) + 'BIN';
    Assign(fb,Binfile); {$(I-) Reset(fb); $(I+)
    If IOResult > 0 Then Begin
      Rewrite(fb);
      With OneRec Do Begin
        Title:= 'These are the X Coordinates for the data in this file.      ';
        FileName:= 'X-COORD      ';
        FillChar(DR,SizeOf(StdGrid),0);
      End;
      Write(fb,OneRec);
      OneRec.Title:= 'These are the Y Coordinates for the data in this file.      ';
      OneRec.FileName:= 'Y-COORD      ';
      Write(fb,OneRec);
      FillChar(Xg,SizeOf(StdGrid),0);
      FillChar(Yg,SizeOf(StdGrid),0);
    End
    Else Begin
      Read(fb,OneRec); Xg:= OneRec.DR;
      Read(fb,OneRec); Yg:= OneRec.DR;
    End;
  End
  Else Begin
    Read(fb,OneRec); Xg:= OneRec.DR;
    Read(fb,OneRec); Yg:= OneRec.DR;
  End;
End;

```

```

{ assemble the list of input files }
FileCount:= 0;
For N:= 2 to ParamCount Do Begin
  WrkName:= ParamStr(N);           Lng:= Length(WrkName);
  For K:= 1 to Lng Do WrkName[K]:= UpCase(WrkName[K]);
  If WrkName[Lng] = '.' Then Begin
    Delete(WrkName,Lng,1);        Dec(Lng);
  End;
  K:= Pos(Bslash,WrkName);
  If (WrkName[Lng] < 'A') and ((Lng-K) > 2) Then Verify_Files(0)  { check one file }
  Else Begin                      { loop until no more files }
    If WrkName[Succ(K)] = 'W' Then GrpCount:= -1
    Else GrpCount:= 0;
    MoreFiles:= true;
    While MoreFiles Do Begin
      Inc(GrpCount);             Str(GrpCount:2,GrpN);
      If GrpCount < 10 Then GrpN[1]:= '0';
      WrkName:= Copy(WrkName,1,Lng) + GrpN;
      Verify_Files(9);
    End;
  End;
End;
WriteLn;
TextAttr:= White;  Writeln('BINCALI will process the files listed below:');
TextAttr:= Yellow; Writeln('Binary File: ',BinFile);
TextAttr:= LightCyan;
For N:= 1 to FileCount Do Write(Copy(MCfile[N]+          ',1,20));
If WhereX > 61 Then WriteLn;
TextAttr:= Yellow; Writeln('FileCount: ',FileCount);
Writeln;
End;

Procedure Initialize;
Var J : Integer;  WrkStr : Str19;
Begin
  { header line with spreadsheet column ID }
  Hdr1:= ' A'; WrkStr:= '      ';
  For J:= 2 to 26 Do Begin
    WrkStr[5]:= Chr(J+64);
    Hdr1:= Hdr1 + WrkStr;
  End;
  Hdr2:= '';
  For J:= 27 to Ymax Do Begin
    WrkStr[4]:= Chr((Pred(J) div 26)+64);
    WrkStr[5]:= Chr(Succ(Pred(J) mod 26)+64);
    Hdr2:= Hdr2 + WrkStr;
  End;
End;

Procedure Read_MCNPH_Values;
{ Reads the two input files and matches them. }
Var I,J,Err,a,Xc,Yc : Integer;
  Xcoord,Ycoord,Zcoord : Single;
  ReadSum,NeedZ,More : Boolean;    fi,fs : Text;
  Line1,LineS : String;           Xs,Ys : String[2];
Procedure Show_Titles(Hdr:Str79);
{ Displays title lines in Line1 and LineS on the screen }
Var Lng : Integer;
Begin
  TextAttr:= Yellow;  Writeln(Hdr,' from ',MCfile[F],' and ',MCTALext,':');
  TextAttr:= LightCyan;
  While Line1[I] = Space Do Delete(Line1,I,1);
  Writeln('Input: ',Line1);
  While LineS[I] = Space Do Delete(LineS,I,1);
  Lng:= Length(LineS);  While LineS[Lng] = Space Do Dec(Lng);
  LineS[0]:= Chr(Lng);  Writeln('mctal: ',LineS);
  Writeln;
End;

```

```

Procedure Get_Coord(Var Strt:Integer; Var NewVal,OldVal:Single;  Msg:Str79);
{ Reads a real number in Line1 beginning at Strt. If the string to real conversion is valid then NewVal is the number, and Strt is at the first blank. Otherwise, Show_How is called with the Msg string. If OldVal is greater than zero the values are compared and differences reported. OldVal:= NewVal }
Var  Fini : Integer;
Begin
  While Line1[Strt] = Space Do Inc(Strt);    { start of X-coordinate }
  Fini:= Succ(Strt);
  While Line1[Fini] <> Space Do Inc(Fini);   { end of number }
  Val(Copy(Line1,Strt,Fini-Strt),NewVal,Err);
  If Err > 0 then Show_How('Invalid '+Msg+' :'+Copy(Line1,Strt,Fini-Strt));
  Strt:= Fini;
  If (OldVal > 0) and (Abs(OldVal-NewVal) > 0.001*NewVal) Then
    Writeln('Possible grid ',Msg,' error at ('+Xc,Yc+',') New!:',NewVal:8:2,' Old:',OldVal:8:2);
  OldVal:= NewVal;
End;
Begin
  FillChar(DR,SizeOf(DR),0);      FillChar(RE,SizeOf(DR),0);
  Assign(fi,MCfile[F]);          Reset(fi);
  Assign(fs,MCfile[F]+MCTAList);  Reset(fs);
{ read run title lines }
  Readln(fi,Line1); { input file title }
  Readln(fs,RunInfo); Delete(RunInfo,1,18); Delete(RunInfo,9,40);
  Readln(fs,LineS);
  Show_Titles('Main Titles');     Title1:= Line1;
  Writeln(' MCNP run began on ',RunInfo);   Writeln;
{ read detector title line }
  Repeat  Readln(fi,Line1);
  Until Copy(Line1,1,3) = 'fc5';
  Delete(Line1,1,5);
  For I:= 1 to 3 Do Readln(fs);      Read(fs,LineS);
  Show_Titles('Detector Titles');   Title2:= Line1;
{ read and store the MCNP dose rates }
  Repeat  Readln(fs,LineS);
  Until Copy(LineS,1,4) = 'vals';
  ReadSum:= true; NeedZ:= true;
  Repeat { loop over dose points in the input file }
    Readln(fi,Line1); More:= Copy(Line1,1,5) = '      ';
    If Copy(Line1,1,4) = 'f5:p' Then More:= true;
    If More Then Begin
      { find the coordinates of the detector point }
      I:= Pos('$',Line1); Line1:= Line1 + Space;
      Inc(I); While Line1[I] = Space Do Inc(I);
      Ys:= Line1[I]; Inc(I); Xs:= '';
      If Line1[I] > '9' Then Ys:= Ys + Line1[I]
      Else Xs:= Line1[I];
      Inc(I);
      While Line1[I] <> Space Do Begin
        Xs:= Xs + Line1[I]; Inc(I); End;
      Val(Xs,Xc,Err); If Err > 0 Then Show_How('Invalid NS index: '+Xs);
      Yc:= Ord(Ys[1]) - 64;
      If Length(Ys) > 1 Then Yc:= Yc*26 + Ord(Ys[2]) - 64;
{ read the X and Y coordinates of the detector point }
      I:= 6;
      Get_Coord(I,Xcoord,Xg[Xc,Yc],'X-coordinate');
      Get_Coord(I,Ycoord,Yg[Xc,Yc],'Y-coordinate');
      If NeedZ Then Begin
        Xcoordz:= 0;
        Get_Coord(I,Zcoord,Xcoord,'Z-coordinate');
        If Zcoord > 100 Then HtStr:= 'Chest' Else HtStr:= 'Knee';
        NeedZ:= false;
      End;
{ read the MCNP dose rate }
      If ReadSum Then Begin Readln(fs,LineS); a:= 3; End
      Else a:= 43;
      ReadSum:= not ReadSum;
      Val(Copy(LineS,a,11),DR[Xc,Yc],Err);
      If Err > 0 Then Show_How('Invalid MCNP Dose Rate: '+Copy(LineS,a,11));
{ read the MCNP relative error }
      a:= a + 13;
      Val(Zero+Copy(LineS,a,5),RE[Xc,Yc],Err);
      If Err > 0 Then Show_How('Invalid MCNP Relative Error: '+Copy(LineS,a,5));
      RE[Xc,Yc]:= 100.0*RE[Xc,Yc];
    End;
Until not More;

```

```

Readln(fs,LineS);
If Copy(LineS,1,3) <> 'tfc' Then
  Show_How('Input file done but summary file not!!');
{ read the number of points and the source comment line }
If Copy(Line1,1,3) = 'nps' Then Begin Delete(Line1,1,5);
  RunInfo:= RunInfo + ' Source Points: ' + Line1;
End;
Repeat  Readln(f1,Line1);
Until Copy(Line1,1,2) = 'sc';
Delete(Line1,1,5);
While Line1[1] = Space Do Delete(Line1,1,1); Title3:= Line1;
Close(f1); Close(fs);
End;

Procedure Write_Array;
{ Creates and writes output tables. }
Var I,J : Integer;           WrkStr : String[9];
  FileName : Str79;          fo,fs : Text;
Procedure Dump_Table(ID:Integer);
{ Writes a 2 dimensional array to the .2D file.
 ID=1,2,3,4 means arrays for DR,RE,Xg,Yg }
Var P,Q : Integer;
Begin
  If ID = 1
    Then Begin Writeln(fo,Title1); Writeln(fo,Title2);
    Writeln(fo,Title3); Writeln(fo,RunInfo); End Else
  If ID = 2
    Then Writeln(fo,'MCNP Relative Errors (percent) -- '+HtStr+' Level') Else
  If ID = 3
    Then Writeln(fo,'Detector X-coordinate (cm)') Else
  If ID = 4
    Then Writeln(fo,'Detector Y-coordinate (cm)');
Writeln(fo);
Writeln(fo,'West',Space:46,'North',Space:46,'East');
Writeln(fo,Hdr1,Hdr2);
For p:= 1 to Xmax Do Begin
  For q:= 1 to Ymax Do Begin
    If DR[p,q] = 0.0 Then WrkStr:= ' '
    Else Begin
      If ID = 1 Then Begin
        If DR[p,q] < 1.0 Then Str(DR[p,q]:5:2,WrkStr)
          Else Str(DR[p,q]:5:1,WrkStr);
      End Else
      If ID = 2 Then Begin
        If RE[p,q] < 1.0 Then Str(RE[p,q]:5:1,WrkStr)
          Else Str(RE[p,q]:5:0,WrkStr);
      End Else
      If ID = 3 Then Begin Str(Xg[p,q]:5:0,WrkStr);
      End Else
      If ID = 4 Then Begin Str(Yg[p,q]:5:0,WrkStr);
      End;
    End;
    Write(fo,WrkStr);
  End;
  Writeln(fo);
End;
Writeln(fo); Writeln(fo);
End;
Procedure Dump_SSfmt;
{ Writes the dose rate table transposed for input to a spreadsheet }
Var P,Q : Integer; LongST : String;
Begin
  Assign(fs,FileName+Zero); Rewrite(fs);
  Writeln(fs,Title1);
  Writeln(fs);
  For q:= 1 to Ymax Do Begin
    LongST:= '';
    For p:= 1 to Xmax Do Begin
      If DR[p,q] = 0.0 Then WrkStr:= ' 0.0 '
      Else Begin
        If DR[p,q] < 1.0 Then Str(DR[p,q]:7:4,WrkStr)
          Else Str(DR[p,q]:7:3,WrkStr);
      End;
      LongST:= LongST + WrkStr;
    End;
    Writeln(fs,LongST);
  End;

```

```

    End;
    Writeln(fs,Title2);   Writeln(fs,Title3);
    Writeln(fs,'MCNP Dose Rates (mrem/h) at '+HtStr+' Level -- Run on ',RunInfo);
    Close(fs);
End;
Begin
  { open output files }
  FileName:= MCfile[F] + '.2D';
  Assign(f0,FileName);           Rewrite(f0);
  Dump_Table(1);
  Dump_SSumt;
  Dump_Table(2);
  Dump_Table(3);
  Dump_Table(4);
  Close(f0);
End;

Procedure Dump_Binary;
Var  N : LongInt;      Found : Boolean;
Begin
  TextAttr:= lightGreen;   Writeln('Updating ',BinFile,' with ',MCshrt[F]);
  Reset(fb);
  Repeat  Read(fb,OneRec);
  Until Eof(fb) or Found;
  If Found Then Seek(fb,Pred(FilePos(fb)));
  With OneRec Do Begin
    FillChar(title,SizeOf(title),Space);
    FillChar(fileName,SizeOf(fileName),Space);
    Title:= Title3;   fileName:= MCshrt[F];
  End;
  OneRec.DR:= DR;
  Write(fb,OneRec);
  Writeln;
End;

Begin
  If ParamCount < 2 Then Show_How('');
  Make_Input_File_List;
  Initialize;
  For F:= 1 to FileCount Do Begin
    Read_MCNP_Values;
    Write_Array;
    Dump_Binary;
    End;
  TextAttr:= LightCyan;   Writeln('Updating Xg & Yg');
  Reset(fb);
  With OneRec Do Begin
    FillChar(title,SizeOf(title),Space);
    Title:= Title1;       fileName:= 'X-COORD      ';
  End;
  OneRec.DR:= Xg;          Write(fb,OneRec);
  With OneRec Do Begin
    FillChar(title,SizeOf(title),Space);
    Title:= Title2;       fileName:= 'Y-COORD      ';
  End;
  OneRec.DR:= Yg;          Write(fb,OneRec);
  Close(fb);
  TextAttr:= White;        Writeln;
  Writeln('Run Completed!');
End.

```

Appendix H. Program to Compute Weighted Total Dose Rates

```

Program SpreadSheet_Substitute;
{ Author: Paul D. Rittmann, PhD CHP
  Purpose: Reads initial concentrations and the dose rate binary files
            and provides a way to fine-tune the amounts by manual adjustment
            of concentrations or linear least squares fits.
  Input: SOURCE.INI - initial concentrations in each source region.
         SOURCE.CH - path to binary files, conc units & source names.
         CHST1.BIN & KNEE1.BIN with the MCNP dose rates (calibration).
         CHST2.BIN & KNEE2.BIN with the MCNP dose rates (stage 2).
         9CHEST.BIN & 9KNEE.BIN with the measured dose rates.
  Output: SSS-xx.D has the 2D files of total dose rates,
          SSS-xx.S has the corresponding source concentrations,
          SSS-xx.R has the graphics for each source showing its fractional
            contribution to the total dose rate at a point.
          SSS-xx.T has the major source contributors to each point using
            characters found in SOURCE.CH
          SSS-xx.Z has the necessary spreadsheet format for the total
}

```

Uses Crt, DOS, Utility;

```

Const Version = 'SSS Version 1.5 April 30, 1997';
  Chst = false;  Knee = true;
  Watr16 = false; Watr17 = true;
  LevelST : Array[Chst..Knee] of ST7 = ('Chest','Knee');
  Xmax = 20; { number of points in the NS direction }
  Ymax = 56; { number of points in the EW direction }
  MaxProduct = Xmax*Ymax; { total number of array positions }
  SrcPool = 25; { number of water & wall sources }
  SrcOthr = 26; { index to the first non-pool source }
  SrcMax = 102; { number of distinct radiation sources }
  SrcMpl = SrcMax+1; { number of columns in the augmented matrix }
  SumBlk = 6; { number of records lumped together to reduce disk access }
  SumMax = SrcMax div SumBlk; { number of sums }
  SortMax = 9; { number of highest contributors to each dose point }
  Eps = 1.0E-7; { matrix is singular if the largest potential pivot < Eps }
  DRmin = 0.001; { the minimum dose rate shown on 2D plots }
  SrcCharFile = 'SOURCE.CH'; { file with characters representing each source }
  SrcInitFile = 'SOURCE.INI'; { file with the default best guesses }
  RTPfile : Array[Chst..Knee] of ST10 = ('9CHEST.BIN','9KNEE.BIN');
  MCNPfile: Array[Watr16..Watr17,Chst..Knee] of ST9 =
    (((CHST1.BIN,'KNEE1.BIN'),('CHST2.BIN','KNEE2.BIN')));
  DepthST : Array[Watr16..Watr17] of ST9 = ('(16''10')','(17''2)');
  StdFileName = 'SSS'; { file extension will vary: D=2D plot, R=Individual Ratios,
                        S=Source Amounts, T=Main Contributors, Z=SS input }
  ConcUnits : Array[1..5] of ST7 = (' $\mu$ Ci/L ',' $\mu$ Ci/cm2 ','Ci/m3 ',' $\mu$ Ci/m ','Ci ');
  ConcColor : Array[1..5] of Byte = (LightCyan, Cyan, LightRed, LightGreen, Green );
  Spectrum : Array[0..17] of Byte =
    (black,blue,blue,darkgray,cyan,green,magenta,brown,red,
     lightblue,lightgray,lightgreen,lightmagenta,lightcyan,yellow,lightred,white,
     white+blink);
  Roff : Array[Chst..Knee] of Byte = (4,27);
  Cpos : Array[0..2] of Byte = (1,28,54);
  MaxPg = 8; Sg1Pg = 7; MREpg = 6; GrCPg = 5; GrRpg = 4; DatPg = 3;
  Datafile : Array[false..true,1..DatPg] of ST66 = (
  (' There must be an error here somewhere!!',
   'Ratios -- Calibration to Stage 1 Transition',
   'Ratios -- Stage 1 to Stage 2 Transition'),
  ('Concentrations for Calibration Dose Rates',
   'Concentrations for Stage 1 Dose Rates',
   'Concentrations for Stage 2 Dose Rates'));
  HelpCnt = 35; HelpSkip : Set of Byte = [6,8,18,27];
  HelpLines : Array[1..HelpCnt] of ST66 = (
  'SSS allows you to adjust the activity in any of the main',
  'radiation sources and then see the effect that this has on',
  'the combined total dose rate. You can also try linear least',
  'squares fitting to calibrate the MCNP model.',
  'SSS then allows calculation of Stage 1 & Stage 2 dose rates.',
  'There are 8 pages: 3 data entry screens and 5 graphical',
  '(text mode) screens of dose rates.',
  'The following key commands are enabled (both parts):',
  ' Alt-X = exit the SSS.EXE program (return to DOS)',
  ' Cursor keys = move the cursor around the screen',
  ' PgUp,PgDn = move between pages',
  ' F1 = displays this help screen',
  
```

```

' F2 = create files with source fractions & ranking',
' Shift-F2 = same as F2 for Stage 1 & Stage 2 cases',
' F8 = do least squares fit on marked sources & points',
' F9 = compute Calibration dose rates & comparisons',
' F10 = compute Stage 1 & Stage 2 dose rates',

'The following key commands are enabled (source lists only):',
' F3 = restore original value from '+SrcInitfile+' (all=Alt-F3)',
' F4 = restore last grid conc (Alt-F4 does all)',
' F5 = mark/unmark source for least squares fitting',
' F6 = mark group of sources back to the nearest F5',
' Alt-F5,Alt-F6 = mark or unmark all sources',
' F7 = toggle display of concentration or fractions',
' Tab = change columns on screen',
' Home,End = jump to the top or bottom of the list',

'The following key commands are enabled (graphical display only):',
' 1,2,3,0 = which grid to display: RPT, MCNP, ratios, sources',
' Space = mark/unmark an individual grid location for LLsq fitting',
' F4 = mark/unmark a column of points for least square fitting',
' F5 = mark/unmark a row of points for least square fitting',
' F6 = mark/unmark the whole grid for least square fitting',
' Alt-F4, F5, -F6 = mark/unmark every 2, 3, or 4 points',
' Tab = change from chest to knee on screen (& LLsq fit)',
' Home,End = jump to the top or bottom of the grid';

CursCH = #4; { used in the graphical displays }
GrfCH : Array[0..18] of Char = '===== +++++*****';

Type
  { these are used for X & Y coordinates and dose rates }
  StdGrid = Array[1..Xmax,1..Ymax] of Single; { 4480 bytes }
  StdPtr = ^StdGrid;
  StdPtr2 = ^Array[Chest..Knee];
  { these are used for indices to various sources }
  StdgridByte = Array[1..Xmax,1..Ymax] of Byte; { 1120 bytes }
  StdPtrByte = ^StdgridByte;
  StdPtrByte2 = ^Array[Chest..Knee];
  { data as found in the binary files }
  DRptr = ^DRrec;
  DRrec = Record { 4576 bytes per record }
    Title : ST79;
    FileN : ST15;
    DR : StdGrid;
    End;
  DRFileType = File of DRrec;
  { collection of information about the current sources }
  SrcRec = Record
    Name : ST66; { title of this source region }
    UnitID : Integer; { which units for the concentration }
    OrigC,OrigF, { original concentration or factor read from SrcInitFile }
    GridC,GridF, { concentration or factor used in the previous grid plot }
    Conc, { current concentration to be used for next calculation }
    FaCn : Array[1..DatPg] of Single; { scale factors for next calculation }
    { array element 1 = Calibration values (Fctr is always 1.000)
      array element 2 = Stage 1 values (Fctr is ratio of Stage 1 to Calibration)
      array element 3 = Stage 2 values (Fctr is ratio of Stage 2 to Stage 1) }
    DoSrc : Array[1..DatPg] of Boolean; { identifies non-zero sources }
    FitSrc : Boolean; { sources marked for LLsq fitting }
    End;
  { these are used in the simple character graphic displays }
  ScrCharType = Record { screen display at one point }
    Achar : Char;
    Acolor : Byte;
    End;
  WholeGrid = Array[1..Xmax,1..Ymax] of ScrCharType;
  GridRec = Record
    GrdName : ST79; { title of the grid }
    GrfPlot : WholeGrid; { contents of the grid }
    End;
  { these are used for the linear least squares fitting }
  VectPtr = ^SimultVector; { used when solving simultaneous equations }
  SimultVector = Array[1..SrcNpl] of Double; { 824 bytes }
  { these are used for quick rewrites on the number entry screens }
  ScreenBk = Array[1..4000] of Integer;
  ScreenPtr = ^ScreenBk;

Var
  OneSrc, { data for one radiation source, chest & knee }

```

```

RelErr,           { modified relative error between MCNP and RPT data }
RPTdata,         { measured dose rates, mR/h }
SumTotal,        { total dose rate from MCNP }
SumTotS1,        { total dose rate for Stage 1 }
SumTotS2 : StdPtr2; { total dose rate for Stage 2 }
Xg,Yg : StdPtr; { coordinates of detector point }
SumB : Array[1..SumMax] of StdPtr2; { sum of 4 StdGrids }
NewSumB : Array[1..SumMax] of Boolean; { flag sum needing updates }
OneRec : DRRec;
fb : Array[Chst..Knee] of DRFileType; { binary files }
SortDR : Array[1..SortMax] of StdPtr2; { major contributors }
SortID : Array[1..SortMax] of StdPtrByte2; { source indices }
SortNum,        { how many sources are in the sorted index array, SortID }
FileIdx,        { which number to use on next output file }
Na,             { number of sources selected for LLSQ; rows in augmented matrix }
Nap1,           { Nap1=Na+1 }
NumPt,          { number of valid grid points selected for calculation }
WhchPg,Wsv, { which page to show: 0=Calib src; 1=Stg1 src; 2=Stg2 src;
               3=RPT grf; 4=MCNP grf; 5=MRE grf; 6=Stg 1 grf; 7=Stg 2 grf }
Row, Col, Rsave,Csav,
Isrc,Imax,Isave, Ix,Iy,
Msrc,Nsp1 : Integer;
SrcInfo : Array[1..SrcMax1] of SrcRec; { source concentrations }
SrcChar : Array[1..SrcMax] of Char; { characters to represent each source }
RatioST : Array[0..18] of ST15; { ranges for each color }
RatioColor: Array[0..18] of Byte; { colors for display of ratios }
RatioHi,        { for display of ratios }
DRhigh : Array[0..18] of Single; { used in display of dose rates }
HighST : Array[0..16] of ST19; { shows high dose rate cutoffs }
RowID : Array[1..SrcMax] of ST3; { integers for the row display }
ColID : Array[1..Ymax] of ST3; { spreadsheet column headings }
Hdr1,Hdr2 : String; { spreadsheet header columns }
InScreen : Array[1..DatPg] of ScreenPtr; { data entry screens }
GridTitle, { color of title lines on Plot pages }
FITBkgnd : Byte;
ShowMore,        { true if there is something on the command line }
RecomputeCal,   { calculate total dose rates and plots - calibration }
RecomputeStg,   { calculate total dose rates and plots - stage 1 & 2 }
Depth1,          { true if pool depth is 16'10" }
DoFit,           { time to do the LLSQ fit }
DoStatsCal,     { write the ratios & ranking file -- calibration case }
DoStatsStg,     { write the ratios & ranking file -- stages 1 & 2 }
CountSrc,        { signals need to count number of selected sources }
CountPt,        { signals need to count number of valid grid points }
BothGrd,         { update FITpoint info on both grids }
Lower,Lsave,    { which grid the cursor is in }
SwitchPage : Boolean; { signals time to move }
ReDoConc,        { need to display new source amounts }
PressToCalc,    { display the need to recompute dose rates }
ShowC : Array[1..DatPg] of Boolean; { show concentrations or fractions }
FITpoint : Array[1..Xmax,1..Ymax] of Boolean;
GridData : Array[GrPg..MaxPg,Chst..Knee] of GridRec;
A : Array[1..SrcMax] of VectPtr; { the augmented coefficient matrix }
FITorder : Array[1..SrcMpl] of Integer; { order of variable source conc }
FITRelErr,       { sum of relative errors at chosen points only }
TotRelErr : Array[Chst..Knee] of Single; { sum of relative errors }
FileDrive : ST19; { DOS path where the files are found (in SrcCharFile) }
SrcTitle1,
SrcTitle2 : ST66; { title lines from SOURCE.INI }

Procedure New_Screen;
{ Clears the screen and places the distinctive header on the top line }
Begin
  TextAttr:= White; ClrScr;
  TextAttr:= HelpText; ClrEol; Write(Space,Version);
  TextAttr:= HelpText; Msg(78-Length(Author),1,Author);
  ClrMsg(1,50,
  ' AltX:Exit F1:Help F2:Ratios F8:LLSQ F9:Calibration DR F10:Stage 1&2 ');
  TextAttr:= TblColor; GotoXY(1,2); ScnLine:= 2;
End;

Procedure Pause_To_Look;
Begin
  If ShowMore Then Begin
    TextAttr:= HiColor;
    Press_Any_Key(3+ScnLine);
  End;

```

```

    End;
End;

Procedure No_File(Msg:ST79);
{ stops program with an error message }
Begin
  TextAttr:= ErrColor;      Inc(ScnLine,2);
  Msg(6,ScnLine,'Oops! The file '+Msg+' could not be located!');
  Halt;
End;

Procedure Check_Free_Memory(VarST:ST19);
{ terminates execution if there is less than 2*StdGrid available }
Begin
  Inc(ScnLine);
  If MaxAvail < 2*SizeOf(StdGrid) Then Begin
    TextAttr:= ErrColor; Inc(ScnLine); GotoXY(6,ScnLine);
    Writeln('Not enough memory left: ',MaxAvail,' bytes');
    Halt; End;
  GotoXY(6,ScnLine); TextAttr:= HdrColor;
  Write('After ',VarST,MaxAvail:8,' bytes');
End;

Procedure Switch_Assigns(Lvl:Boolean);
Begin
  Close(fb[Lvl]);
  Assign(fb[Lvl],FileDrive+MCNPfile[Depth1,Lvl]);
  Reset(fb[Lvl]);
  Add_Line('Now Using '+FileDrive+MCNPfile[Depth1,Lvl]);
End;

Procedure Initialize;
Var L,K : Integer;      WrkST : ST19;      fi : Text;
Procedure Open_MCNP_Bin(Lvl:Boolean);
{ read the MCNP dose rate file }
Var I : Integer;
Procedure Check_Binary(STR:ST79);
Begin
  Assign(fb[Lvl],STR);  ($1-) Reset(fb[Lvl]); ($1+)
  If IOResult > 0 Then No_File(STR);
  Add_Line('Found the binary file '+STR);
End;
Begin
  Check_Binary(FileDrive+MCNPfile[Watr17,Lvl]);
  Check_Binary(FileDrive+MCNPfile[Watr16,Lvl]); { default is 16'10" level }
  If Lvl Then Begin
    Read(fb[Lvl],OneRec); Xg:= OneRec.DR;
    Read(fb[Lvl],OneRec); Yg:= OneRec.DR;
  End;
  { zero the SumTotal and SumB arrays }
  For I:= 1 to SumMax Do FillChar(SumI[Lvl]^,SizeOf(StdGrid),0);
  FillChar(SumTotal[Lvl]^,SizeOf(StdGrid),0);
  FillChar(SumTotS1[Lvl]^,SizeOf(StdGrid),0);
  FillChar(SumTotS2[Lvl]^,SizeOf(StdGrid),0);
End;
Procedure Full_Screen(Whch:Integer);
Var J,Line : Integer;      Tmp : Single;
Procedure Write_Source(N,Lng:Integer);
Begin
  With SrcInfo[+N*Imax] Do Begin
    If Swhc[Whch] Then Tmp:= Conc[Whch]      Else Tmp:= FcNc[Whch];
    TextAttr:= HiColor;      Msg(Cpos[N].Line,PadNumStr0(Tmp));
    TextAttr:= ConcColor[UnitID]; Write(Copy(Name,I,Lng));
  End;
End;
Begin
  TextMode(Do80+Font8x8);      New_Screen;
  TextAttr:= TbColor;      Msg(2,2,'Page'+RowID[Whch]);      Msg(72,2,'Page'+RowID[Whch]);
  TextAttr:= White;      Center_Msg(3,DataTitle>ShowC[Whch],Whch);
  For J := 1 to Imax Do Begin      Line:= J + 3;
    Write_Source(0,19);      Write_Source(1,18);      Write_Source(2,18);
  End;
  TextAttr:= HelpTitle;      ClrMsg(1,Imax+4,
    '          Colors refer to these concentration units:           ('+RowID[Nsrc]+') Sources)');
End;

```

```

For J:= 1 to 5 Do Begin
  TextAttr:= ConColor[J];  Msg(11*j,imax+5,ConUnits[J]);   End;
TextAttr:= HelpTitle;   ClrMsg(1,imax+6,
  'F3:Restore Original Value   F4:Restore Last Value   Alt-F3,F4:Restore All');
NewInScreen(whch);
Move(Mem[$B800:0],InScreen[whch]^,8000);  { stores the current screen }
ScrLine:= 41;  Pause_To_Look;
End;
Begin
  ShowMore:= ParamCount > 0;
  FITBkgrd:= LightGray;      GridTitle:= Black + 16*Cyan;
  New_Screen;
{ initialize the source data array; also read the characters representing
  each source }
  FileDrive:= blanks;        Depth1:= Water16;
  Assign(f1,SrcCharFile);    ($I-) Reset(f1);  ($I+)
  If IOResult > 0 Then No_File(SrcCharFile);
  Add_Line('Reading the binary file path and source names from '+SrcCharFile);
  Readln(f1,FileDrive);
  L:= 1;  While FileDrive[L] <> Space Do Inc(L);
  FileDrive[0]:= Chr(Pred(L));
  Srcchar[0]:= Space;  Nsrc:= 0;
  While not Eof(f1) Do Begin
    Inc(Nsrc);  With SrcInfo[Nsrc] Do Begin
      Readln(f1,ST);
      Srcchar[Nsrc]:= ST[1];
      WrkST:= Copy(ST,9,7);
      UnitID:= 1;  While WrkST <> ConUnits[UnitID] Do Inc(UnitID);
      Name:= Copy(ST,18,70);
      FITsrc:= true;
    End;
    End;
    Nsp1:= Succ(Nsrc);  Imax:= Nsp1 div 3;
  Close(f1);
{ read the default source concentration file }
  ST:= FileDrive + SrcInitFile;
  Assign(f1,ST);  ($I-) Reset(f1);  ($I+)
  If IOResult > 0 Then No_File(ST);
  Add_Line('Reading the default concentrations from '+ST);
  Readln(f1,SrcTitle1);  Readln(f1,SrcTitle2);
  For L:= 1 to Nsrc Do With SrcInfo[L] Do Begin
    Readln(f1,OrigC[1],OrigF[2],OrigF[3]);
    FaCn[1]:= 1.0;  OrigF[1]:= 1.0;
    FaCn[2]:= OrigF[2];  OrigC[2]:= OrigF[2]*OrigC[1];
    FaCn[3]:= OrigF[3];  OrigC[3]:= OrigF[3]*OrigC[2];
    For K:= 1 to 3 Do Begin
      GridC[K]:= OrigC[K];  GridF[K]:= OrigF[K];  Conc[K]:= OrigC[K];
      DoSrc[K]:= Conc[K] > 0.0;
    End;
  End;
{ header line with spreadsheet column ID for 2D files }
  Hdr1:= ' A';  WrkST:= '   ';  ColID[1]:= ' A';
  For L:= 2 to 26 Do Begin
    WrkST[5]:= Alphabet[L];  Hdr1:= Hdr1 + WrkST;
    ColID[L]:= Space + WrkST[5];
  End;
  Hdr2:= '';
  For L:= 27 to Ymax Do Begin
    WrkST[4]:= Alphabet[Pred(L) div 26];
    WrkST[5]:= Alphabet[Succ(Pred(L) mod 26)];
    Hdr2:= Hdr2 + WrkST;
    ColID[L]:= WrkST[4] + WrkST[5];
  End;
{ definition of RowID }
  For L:= 1 to 2*Imax Do Str(L:2,RowID[L]);
  For L:= Succ(2*Imax) to SrcMax Do Str(L:3,RowID[L]);
{ relative error display arrays }
  RatioHi[ 0]:= -9.0;  RatioColor[ 0]:= White + Blink;
  RatioHi[ 1]:= -5.0;  RatioColor[ 1]:= White;
  RatioHi[ 2]:= -3.0;  RatioColor[ 2]:= LightRed;
  RatioHi[ 3]:= -2.0;  RatioColor[ 3]:= Yellow;
  RatioHi[ 4]:= -1.5;  RatioColor[ 4]:= LightCyan;
  RatioHi[ 5]:= -1.0;  RatioColor[ 5]:= LightMagenta;
  RatioHi[ 6]:= -0.7;  RatioColor[ 6]:= LightBlue;
  RatioHi[ 7]:= -0.4;  RatioColor[ 7]:= Brown;
  RatioHi[ 8]:= -0.2;  RatioColor[ 8]:= LightGray;
  RatioHi[18]:= TopReal;  RatioColor[ 9]:= Black;
  For L:= 10 to 18 Do Begin
    RatioColor[L]:= RatioColor[18-L];
  End;

```

```

    RatioHi[Pred(L)]:= -RatioHi[18-L];
End;
For L:= 1 to 17 Do Begin
  Str(RatioHi[Pred(L)]:5:1,WrkST);   Str(RatioHi[L]:5:1,ST);
  RatioST[L]:= GrfCH[L] + WrkST + ' to' + ST;
End;
{ figure out which number output file to use next }
ST:= FileDrive + StdFileName;      FileIndx:= 0;
Repeat
  Inc(FileIndx);                  Str(FileIndx:2,WrkST);
  If WrkST[1] = Space Then WrkST[1]:= Zero;
  Assign(fi,ST+WrkST+'.');        {$I-} Reset(fi);  {$I+}
  SwitchPage:= IOResult > 0;
Until SwitchPage or (FileIndx > 99);
If FileIndx = 99 Then FileIndx:= 1;
Dec(FileIndx);

{ use the heap space for various dose rate arrays }
Add_Line('Assigning memory space for various arrays');
For L:= 1 to SumMax Do Begin
  New(SumB[L,Chst]);           New(SumB[L,Knee]);
  Check_Free_Memory('SumB['+RowID[L]+']');
  NewSumB[L]:= true;
End;
New(SumTotal[Chst]);              New(SumTotal[Knee]);
Check_Free_Memory('SumTotal ');
New(ReleErr[Chst]);              New(ReleErr[Knee]);
Check_Free_Memory('DR ReleErr');
New(SumTotS1[Chst]);            New(SumTotS1[Knee]);
Check_Free_Memory('SumTotS1 ');
New(SumTotS2[Chst]);            New(SumTotS2[Knee]);
Check_Free_Memory('SumTotS2 ');
New(Xg);                         New(Yg);
Check_Free_Memory('Xg & Yg ');
{ read the MCNP dose rate files to initialize the sums }
Open_MCNP_Bin(Chst);           Open_MCNP_Bin(Knee);
TextAttr:= HiColor;
Pause_To_Look;
{ initial values }
Isrc:= 1;                      WhchPg:= 1;
Row:= 1;                         Col:= 1;
CountSrc:= true;                 DoFit:= false;
CountPtx:= true;                 Lower:= false;
DoStatsCal:= false;              DoStatsStg:= false;
RecomputeCal:= true;             RecomputeStg:= not ShowMore;
For K:= 1 to DatPg Do Begin
  ReboConc[K]:= true;            PressToCalc[K]:= true;
  If K = 1 Then ShowC[1]:= true;
  Else ShowC[K]:= false;
  Full_Screen(K); { show the list on the screen }
End;
End;

Procedure Show_Help_Page;
Var J, K : Integer;      TmpScreen : Array[1..4000] of Integer;
Begin
  Move(Mem[$B800:0],TmpScreen,8000); { stores the current screen }
  TextAttr:= HelpTitle;      ClrScr;
  Center_Msg(3,'Summary of Features for '+Version);
  TextAttr:= HelpText;       Center_Msg(4,Author);
  J:= 6;
For K:= 1 to HelpCnt Do Begin
  Inc(J);
  If K in HelpSkip Then Inc(J);
  Msg(11,J,Helplines[K]);
End;
TextAttr:= HelpTitle;      Press_Any_Key(J + 3);
Move(TmpScreen,Mem[$B800:0],8000); { restores the original screen }
End;

Procedure Source_Info_ST(Sn:Integer);
{ Uses ST to give the source information summary - amount, units & name }
Var WrkST : ST9;
Begin
  With SrcInfo[Sn] Do Begin
    ST:= MinNumStr(GridC[1]);
    While Length(ST) < 7 Do Insert(Space,ST,1);
    WrkST:= MinNumStr(GridF[2]);
  End;
End;

```

```

While Length(WrkST) < 7 Do Insert(Space,WrkST,1);
ST:= ST + Space + WrkST;
WrkST:= MinNumStr(GridF[3]);
While Length(WrkST) < 7 Do Insert(Space,WrkST,1);
ST:= ST + Space + WrkST + ' ' + Name;
End; End;

Procedure Make_Stat_Files(Whch:Integer);
{ Writes a file showing the fractional contribution to the total from each
source at each grid point. Also writes a file showing the major
contributors to the dose rate at each point. Also writes the total dose
rates in a form readable by spreadsheets. Whch is 1, 2, or 3. }
Var I,J,N,Ksrt : Integer; fo : Text; WrkST : ST79;
PP : Pointer; Fctr : Single;
Procedure Do_Ratios(Ptr:StdPtr2; Strt,Fini:Integer);
Var Src : Integer;
Procedure One_Table(Lvl:Boolean);
{ Reads one binary record and writes one table to the output file. }
Var I,J,K,M : Integer; TmpD,TmpT : Single;
Begin
  WriteInfo;
  Write(fo,LevelST[Lvl], ' -- ',ST);
  If Src < 26 Then WriteInfo(fo,DepthST[Depth1]) Else WriteInfo(fo,
  WriteInfo(' ',Alphabet,Alphabet,'ABCD'));
  Seek(fbfLvl1,Succ(Src)); Read(fbfLvl1,OneRec);
  With OneRec Do Begin Msg(70,ScLine,FileN$Space);
  For I:= 1 to Xmax Do Begin
    WrkST:= RowID[I];
    For J:= 1 to Ymax Do Begin
      { insert the individual dose rates on the sorted list of grids }
      TmpD:= Fctr*DR[I,J];
      If TmpD > 1.0E-08 Then Begin
        K:= 1;
        While (K < SortNum) and (TmpD < SortDR[K,Lvl]^I,J] Do Inc(K);
        For M:= Pred(SortNum) downto K Do Begin
          SortDR[Succ(M),Lvl]^I,J]:= SortDR[M,Lvl]^I,J];
          SortID[Succ(M),Lvl]^I,J]:= SortID[M,Lvl]^I,J];
        End;
        SortDR[K,Lvl]^I,J]:= TmpD;
        SortID[K,Lvl]^I,J]:= Src;
      End;
      { determine the ratio character and add to the line }
      TmpT:= Ptr[Lvl]^I,J];
      If TmpT > 0
        Then Begin
          CH:= IntChar(Round(10.0*TmpD / TmpT));
          If CH = Zero Then CH:= Space;
        End
        Else CH:= Space;
      WrkST:= WrkST + CH;
    End;
    WriteInfo(fo,WrkST,Space,RowID[I]);
  End;
End;
Begin
  TextAttr:= HiColor;
  For Src:= Strt to Fini Do With SrcInfo[Src] Do Begin
    Fctr:= SrcInfo[Src].Conc[Whch];
    If Fctr > 0.0 Then Begin
      ST:= MinNumStr(Fctr); While Length(ST) < 7 Do Insert(Space,ST,1);
      ST:= ST + Space + ConcUnits[UnitID] + ' ' + Name;
      inc(Ksrt);
      If Ksrt < SortMax Then SortNum:= Ksrt Else SortNum:= SortMax;
      One_Table(Cshst); One_Table(Knee);
    End;
  End;
End;
Procedure Rank_Table(Lvl:Boolean);
{ Writes one main contributor table to the output file. }
Var I,J : Integer;
Begin
  WriteInfo;
  Write(fo,LevelST[Lvl], ' -- ',ST,DepthST[Whch>1]);
  WriteInfo(' ',Alphabet,Alphabet,'ABCD');
  For I:= 1 to Xmax Do Begin
    WrkST:= RowID[I];
    For J:= 1 to Ymax Do WrkST:= WrkST + SrcChar[SortID[N,Lvl]^I,J];
    WriteInfo(fo,WrkST,Space,RowID[I]);
  End;
End;

```

```

    End;
End;
Procedure SS_Readable(Ptr:StdPtr2; Lvl:Boolean);
Var p,q : Integer;    LongST : String;
    Tmp : Single;      WrkStr : ST15;
Begin
    WriteIn(fo,LevelST[Lvl]),
    ' Level Total Dose Rates (Transposed) from MCNP, mrem/h',DepthST[Whch>1]);
    WriteIn(fo);
    For q:= 1 to Ymax Do Begin
        LongST:= '';
        For p:= 1 to Xmax Do Begin
            Tmp:= Ptr[Lvl]^ [p,q];
            If Tmp = 0.0 Then WrkStr:= ' 0.0 '
            Else Begin
                If Tmp < 1.0 Then Str(Tmp:7:4,WrkStr)
                Else Str(Tmp:7:3,WrkStr);
            End;
            LongST:= LongST + WrkStr;
        End;
        WriteIn(fo,LongST);
    End;
End;
Begin  { Make_Stat_Files }
    New_Screen;
{ use the heap space for the sorted dose rate arrays }
    Add_Line('Assigning memory space for the sorting arrays');
    Mark(PP);
    For N:= 1 to SortMax Do Begin
        New(SortDR[N,Csth]);   New(SortDR[N,Knee]);
        New(SortID[N,Csth]);  New(SortID[N,Knee]);
        Check_Free_Memory('SortDR['+RowID[N]+']');
        FillChar(SortDR[N,Csth],2*SizeOf(StdGrid),0);
        FillChar(SortID[N,Csth],2*SizeOf(StdGridByte),0);
    End;
{ assemble the name of the ratio file }
    Str(FileIndex:2,ST);           If ST[1] = Space Then ST[1]:= Zero;
    ST:= FileDrive + StdFileName + ST + '_R' + IntChar[Whch];
    Add_Line('Writing the ratios from each source to '+ST);
    TextAttr:= HdrColor;          Inc(ScnLine);
    Msg(8,ScnLine,'(from '+DataTitle[true,Whch]+')');
{ compute and write the tables of ratios }
    Assign(fo,ST);               Rewrite(fo); Ksrt:= 0;
    WriteIn(fo,'Fractions That Each Source Contributes to the Total Dose Rate');
    WriteIn(fo,'from ',DataTitle[true,Whch]);
    If Whch = 1 Then Do_Ratios(SumTotal,1,SrcMax)
    Else Begin { start with the water at 17'2" }
        Append(fo); Depth1:= Watr17;
        Switch_Assigns(Csth); Switch_Assigns(Knee);
        If Whch = 2 Then Do_Ratios(SumTotS1,1,SrcPool)
        Else Do_Ratios(SumTotS2,1,SrcMax);
        Depth1:= Watr16;
        Switch_Assigns(Csth); Switch_Assigns(Knee);
        If Whch = 2 Then Do_Ratios(SumTotS1,SrcOthr,SrcMax);
    End;
    Close(fo);
{ assemble the name of the main contributor file }
    Str(FileIndex:2,ST);           If ST[1] = Space Then ST[1]:= Zero;
    ST:= FileDrive + StdFileName + ST + '_T' + IntChar[Whch];
    Add_Line('Writing the grid showing major sources to '+ST);
{ write the main contributor file }
    Assign(fo,ST);               Rewrite(fo);
    WriteIn(fo,'Major Contributors to the Total Dose Rate for ',DataTitle[true,Whch]);
    WriteIn(fo,'');
    WriteIn(fo,'The sources are identified using the key below:');
    For N:= 1 to Imax Do Begin
        ST:= RowID[N] + Space + SrcChar[N] + Space + SrcInfo[N].Name + Blanks;
        ST[0]:= '#27;           Csave:= N + Imax;
        ST:= ST + RowID[Csave] + Space + SrcChar[Csave] + Space + SrcInfo[Csave].Name + Blanks;
        ST[0]:= '#50;           Csave:= N + 2*Imax;
        WriteIn(fo,ST,RowID[Csave],Space,SrcChar[Csave],Space,SrcInfo[Csave].Name);
    End;
    For N:= 1 to Pred(SortNum) Do Begin
        ST:= 'Importance Rank Number '+RowID[N];
        Rank_Table(Csth);       Rank_Table(Knee);
    End;
    Close(fo);
{ assemble the name of the spreadsheet readable file }

```

```

Str(FileIndx:2,ST);           If ST[1] = Space Then ST[1]:= Zero;
ST:= FileDrive + StdFileName + ST + '.Z' + IntChar[Whch];
AddLine('Writing the spreadsheet readable tables to '+ST);
{ write the main contributor file }
Assign(fo,ST);               Rewrite(fo);
If Whch = 1 Then Begin       DoStatsStg:= false;
  SS_Readable(SumTotal,Chest);
  WriteLn(fo);             WriteLn(fo);
  SS_Readable(SumTotal,Knee);
End;                          Else
If Whch = 2 Then Begin       DoStatsStg:= false;
  SS_Readable(SumTotS1,Chest);
  WriteLn(fo);             WriteLn(fo);
  SS_Readable(SumTotS1,Knee);
End;                          Else
If Whch = 3 Then Begin       DoStatsStg:= false;
  SS_Readable(SumTotS2,Chest);
  WriteLn(fo);             WriteLn(fo);
  SS_Readable(SumTotS2,Knee);
End;
Close(fo);
Release(PP);
Pause_To_Look;
End;

Procedure Dump_2D_File(Whch:Integer; Ptr:StdPtr2; IDst:ST79);
{ Writes the DR grid in Ptr for chest & knee level to the next source file.
  Whch=4 is the measured dose rates (RPTdata)
  Whch=5 is the MCNP computed sum for the calibration case (SumTotal)
  Whch=6 is the modified relative error for SumTotal and RPTdata (RelErr)
  Whch=7 is the Stage 1 dose rates (SumTotS1)
  Whch=8 is the Stage 2 dose rates (SumTotS2)  }
Var fo : Text;
Procedure Write_2D(Lvl:Boolean);
Var p,q : Integer;            Tmp : Single;
Begin
  WriteLn(fo,GridData[Whch,Lvl].GrdName);
  WriteLn(fo,'West',Space:46,'North',Space:46,'East');
  WriteLn(fo,Hdr1,Hdr2);
  For p:= 1 to Xmax Do Begin
    For q:= 1 to Ymax Do Begin
      Tmp:= Ptr[Lvl]^ [p,q];
      If Abs(Tmp) > DRmin Then Str(Tmp:5:1,ST)
        Else ST:= '   ';
      WriteLn(fo,ST);
    End;
    WriteLn(fo);
  End;
  If Whch = MREpg Then
    WriteLn(fo,'Sum of Magnitudes of Modified Relative Errors is ',
          MinNumStr(TotRelErr[Lvl]),' at ',LevelST[Lvl],' Level')
  Else WriteLn(fo);
End;
Begin
  If Whch = GrRPg Then ST:= StdFileName+'00.D'
  Else Begin
    Str(FileIndx:2,ST);
    If ST[1] = Space Then ST[1]:= Zero;
    ST:= StdFileName + ST + 'D';
  End;
  AddLine('Adding a 2D '+IDst+' table to '+ST);
  Assign(fo,FileDrive+ST);  { the summary file }
  If Whch < MREpg Then Rewrite(fo)  Else Append(fo);
  Write_2D(Chest);         Write_2D(Knee);
  Close(fo);
End;

Procedure Make_DR_Grid(Whch:Integer; Ptr:StdPtr2; Title:ST79);
{ Stores the current data in GridData[Whch,Lvl]. The 2D file is generated. }
Procedure Put_Grid(Lvl:Boolean);
Var I,J,K : Integer;          Tmp : Single;
Begin
  With GridData[Whch,Lvl] Do Begin
    GrdName:= Title + ' - ' + LevelST[Lvl] + ' Level' + DepthST[Whch>MREpg];
    For I:= 1 to Xmax Do
      For J:= 1 to Ymax Do
        K:= 0;      Tmp:= Ptr[Lvl]^ [I,J];

```

```

      While Tmp > DRhigh[K] Do Inc(K);
      With Grfplot[I,J] Do Begin
        Acolor:= Spectrum[K];      Achar:= #219;
        End;
      End;
    End;
  Begin
    Put_Grid(Chst);           Put_Grid(Knee);
    Dump_2D_File(Whch,Ptr,Title);
  End;

Procedure Make_RPT_Grid;
{ Puts the grid with RPT data into GridData[4]. }
Var I,J,K,l : Integer;          Chk : Boolean;
  GridMin,GridMax,ScaleFactor,Tmp : Single;
Procedure Read_RPT_DR(Lvl:Boolean);
{ read the RPT dose rate file }
Type RPTGrid = Array[1..26,1..56] of Single;
Var RPTin : RPTgrid; { measured dose rates, mR/h }
  fr : File of RPTgrid;       I,J : Integer;
Begin
  ST:= FileDrive+RPTfile[Lvl];
  Assign(fr,ST); { ($1-) Reset(fr); { ($1+)
  If IOResult > 0 Then No_File(ST);
  AddLine('Reading the RPT data in '+ST);
  Read(fr,RPTin);           Close(fr);
  New(RPTdata[Lvl]);
  For I:= 1 to Xmax Do
    For J:= 1 to Ymax Do
      RPTdata[Lvl]^I,J]:= RPTin[I,J];
End;
Begin
  New_Screen;
  Read_RPT_DR(Chst);           Read_RPT_DR(Knee);
{ identify GridMax and GridMin }
GridMin:= TopReal;             GridMax:= 0;      NumPt:= 0;
For I:= 1 to Xmax Do
  For J:= 1 to Ymax Do Begin
    Tmp:= RPTdata[Chst]^I,J;
    F1Point[I,J]:= Tmp > 0;
    If Tmp > 0 Then Begin Inc(NumPt);
      If GridMax < Tmp Then GridMax:= Tmp;
      If GridMin > Tmp Then GridMin:= Tmp;
    End;
    Tmp:= RPTdata[Knee]^I,J;
    If Tmp > 0 Then Begin
      If GridMax < Tmp Then GridMax:= Tmp;
      If GridMin > Tmp Then GridMin:= Tmp;
    End;
  End;
  If GridMin < 0.1 Then GridMin:= 0.1;
{ set the color scale }
ScaleFactor:= Exp((Ln(GridMax/GridMin)/16.0)); { 16 logarithmic steps }
DRhigh[0]:= GridMin;            DRhigh[16]:= GridMax + 0.01;
For K:= 1 to 15 Do DRhigh[K]:= DRhigh[Pred(K)]*ScaleFactor;
DRhigh[17]:= TopReal;
{ show the graphs }
Make_DR_Grid(GrRPg,RPTdata,'Measured Dose Rates (mR/h)');
Inc(ScnLine,2); GotoXY(6,ScnLine);
Write(NumPt,' grid points were found in RPTdata');
End;

Procedure Get_A_Matrix(Lvl:Boolean);
{ Reads the MCNP binary file many times to compute the augmented coefficient
  matrix. Only the selected source and grid points are used. }
Var Irow,Icol,I,J,K,N : Integer;          Sum : Double;
  Determined : Boolean;                  WrkRec : WRRec;
Begin
  AddLine('Computing the augmented coefficient matrix ');
{ read the binary files to generate the full coefficient matrix }
  Inc(ScnLine); GotoXY(6,ScnLine);
  Writeln('Number of sources: ',Ns,' Number of grid points: ',NumPt);
  K:= 0;
  For N:= 1 to Nsrc Do If SrcInfo[N].DoSrc[1] Then Inc(K);
  Write(K:8,' Data Records will be used in the fit');

```

```

Determined:= NumPt = Ns; { just enough data to solve }
For I:= 1 to Xmax Do      { initialize the constant vector }
  For J:= 1 to Ymax Do
    RelErr[Lvl]^ [I,J]:= RPTdata[Lvl]^ [I,J];
  For N:= 1 to Nsrc Do Begin
    New(A[N]);   Fill(Char(A[N])^,SizeOf(SimultVector),0);
  End;
  Irow:= 0;   Inc(ScnLine,4);   TextAttr:= HiColor;
  For N:= 1 to Nsrc Do With SrcInfo[N] Do If DoSrc[N] Then Begin
    GotoXY(60,ScnLine);   Write('Record ',N);
    { read one column of original matrix }
    Seek(fb[Lvl],Succ(N));   Read(fb[Lvl],OneRec);
    If FITsrc
      Then Begin { compute Nth row in the coefficient matrix }
        Write(' - A');
        Inc(Irow);   Icol:= 0;   FITorder[Irow]:= N;
        If Determined
          Then Begin   { assume Irow is actually a column }
            For I:= 1 to Xmax Do
              For J:= 1 to Ymax Do If FITpoint[I,J] Then Begin
                Inc(Icol);   A[Icol]^ [Irow]:= OneRec.DR[I,J];
              End;
            End;
          Else Begin
            For K:= 1 to Nsrc Do If SrcInfo[K].FITsrc Then Begin
              Sum:= 0.0;
              Seek(fb[Lvl],Succ(K));   Read(fb[Lvl],WrkRec);{ column K in A matrix }
              For I:= 1 to Xmax Do
                For J:= 1 to Ymax Do If FITpoint[I,J] Then
                  Sum:= Sum + WrkRec.DR[I,J]*OneRec.DR[I,J];
              Inc(Icol);   A[Irow]^ [Icol]:= Sum;
            End;
          End;
        End;
      Else Begin { update the constant vector }
        Write(' - B');
        For I:= 1 to Xmax Do
          For J:= 1 to Ymax Do If FITpoint[I,J] Then
            RelErr[Lvl]^ [I,J]:= RelErr[Lvl]^ [I,J] - OneRec.DR[I,J]*Conc[I];
        End;
      End;
    End;
    Napt:= Succ(Na);   FITorder[Napt]:= Nsp1;
  { multiply A transpose times the original constant vector }
  Add_Line('Computing the constant vector');
  If Determined
    Then Begin
      Icol:= 0;
      For I:= 1 to Xmax Do
        For J:= 1 to Ymax Do If FITpoint[I,J] Then Begin
          Inc(Icol);   A[Icol]^ [Napt]:= RelErr[Lvl]^ [I,J];
        End;
    End;
  Else Begin
    For Irow:= 1 to Na Do Begin
      Seek(fb[Lvl],Succ(FITorder[Irow]));   Read(fb[Lvl],OneRec);
      Sum:= 0.0;
      For I:= 1 to Xmax Do
        For J:= 1 to Ymax Do If FITpoint[I,J] Then
          Sum:= Sum + OneRec.DR[I,J]*RelErr[Lvl]^ [I,J];
      A[Irow]^ [Napt]:= Sum;
    End;
  End;
End;

Procedure Write_A_Matrix(Lvl:Boolean);
{ Writes the file SSS.Mxx with the values of the augmented matrix. }
Var fo : Text;   LS,WrkST : String;   Tmp : Single;
  I,J,K,N,Strt,Fini : Integer;
Begin
  { assemble the name of the output file }
  Str(FileIdx2,ST);   If ST[1] = Space Then ST[1]:= Zero;
  ST:= FileIdx2 + StdFileName + ST + '_F';
  Add_Line('Writing the '+LevelST[Lvl]+'' level augmented matrix to '+ST);
  { write these computed results to an output file }
  Assign(fo,ST);   Rewrite(fo);
  writeln(fo,LevelST[Lvl],' Level Augmented Coefficient Matrix');
  Fini:= 0;   K:= 0;

```

```

While Fini < Na Do Begin
  WriteInfo();
  Strt:= Succ(15*K); Inc(K); Fini:= 15*K;
  If Fini > Na Then Fini:= Na;
  WrkST:= '';
  For J:= Strt to Fini Do Begin
    Str(FITOrder[J]:8,ST); WrkST:= WrkST + ST; End;
  Delete(WrkST,1,2);
  LS:= LineStr + LineStr; LS[0]:= Chr(8*(Fini-Strt)+10);
  If Fini = Na Then Begin
    WrkST:= WrkST + ' Constants';
    LS[0]:= Chr(8*(Fini-Strt)+22);
  End;
  Writeln(fo,WrkST);
  Writeln(fo,LS);
  For I:= 1 to Na Do Begin
    Str(FITOrder[I]:2,WrkST);
    For J:= Strt to Fini Do Begin
      Tmp:= A[I][J];
      If Tmp > 1.0E-3 Then ST:= Space + MinNumStr(Tmp) + ' '
        Else ST:= Sci1Tmp;
      ST[0]:= '#';
      If J = Na Then WrkST:= WrkST + ' '+PadNumStr0(A[I]^(Nap1));
    End;
    Writeln(fo,WrkST);
  End;
  Writeln(fo,LS);
End;

{ add a grid showing the points used in this fit }
Writeln(fo); Writeln(fo,NumPt,' Points were used in the ',LevelST[Lvl],' Level LLSQ Fit:');
Writeln(fo);
Writeln(fo, ' ,Alphabet,Alphabet,'ABCD');
For I:= 1 to Xmax Do Begin
  WrkST:= RowID[I];
  For J:= 1 to Ymax Do Begin
    If FITpoint[I,J] Then CH:= '+' Else CH:= Space;
    WrkST:= WrkST + CH; End;
  Writeln(fo,WrkST,Space,RowD[I]);
End;

{ add a list of sources used in this fit }
Writeln(fo);
Writeln(fo); Writeln(fo,Na,' Sources were used in the ',LevelST[Lvl],' Level LLSQ Fit:');
Writeln(fo);
For N:= 1 to Nsrc Do With SrcInfo[N] Do If DoSrc[1] Then Begin
  If FITsrc Then ST:= 'Fitted' Else ST:= 'Fixed ';
  Writeln(fo,ST,N:5,' ',Name);
End;
Close(fo);
End;

```

Procedure Simultaneous;

{ Source: Applied Numerical Methods by Brice Carnahan, H.A. Luther, and James O. Wilkes
John Wiley & Sons, Inc., 1969.

Gauss-Jordan complete elimination method with maximum pivot strategy.

The matrix A is inverted and the solution is stored in X. }

```

Var
  Piv, Piv1, { index to pivot ID number and Piv1 = Piv - 1 }
  Row, Col, { array index }
  RowX,ColX, { pointer index }
  Count : Integer; { counts number of interchanges }
  PivOrdR, { array with proper order for pivots }
  RowP,ColP : Array[1..SrcMax] of Integer; { subscripts of pivot elements }
  Aij, { array element being adjusted }
  Deter, { determinant of the coefficient matrix }
  PivotValue : Double; { value of pivot element }

Function Seek_Max : Boolean;
{ Returns true if the current values for Row and Col are not in a
 previous pivot position. }
Var RowS,ColS : Integer; { subset of array index }
Begin
  Seek_Max:= false;
  For RowS:= 1 to Piv1 Do If Row = RowP[RowS] Then Exit;
  For ColS:= 1 to Piv1 Do If Col = ColP[ColS] Then Exit;
  Seek_Max:= true;
End;
Begin
  Add_Line('Attempting to solve the simultaneous equations');
  GotoXY(10,Succ(ScrLine)); Write(' (' ,MaxAvail,' bytes free)');

```

```

{ elimination procedure }
Deter:= 1.0;           TextAttr:= LightGreen;
For Piv:= 1 to Na Do Begin
  { look for pivot element }
  Piv1:= Pred(Piv);      PivotValue:= 0.0;
  For Row:= 1 to Na Do
    For Col:= 1 to Na Do If Seek_Max Then Begin { look for largest value }
      If PivotValue < Abs(A[Row]^*[Col]) Then Begin
        PivotValue:= A[Row]^*[Col];   RowP[Piv]:= Row;  ColP[Piv]:= Col;
      End;
    End;
  RowX:= RowP[Piv];       ColX:= ColP[Piv];
  GotoXY(66,Scnline);    Write('Pivot',Piv:3);
  Msg(65,Succ(Scnline),Sci2(PivotValue));
  { check for large enough pivot }
  If Abs(PivotValue) < Eps Then Begin
    TextAttr:= ErrColor;  Inc(ScnLine,2);
    Msg(6,ScnLine,'Solution is not possible!!');
    Exit;  End;
  { update the determinant }
  Deter:= Deter*PivotValue;
  { normalize pivot row elements }
  For Col:= 1 to Napi Do A[RowX]^*[Col]:= A[RowX]^*[Col] / PivotValue;
  { do elimination and develop inverse }
  A[RowX]^*[ColX]:= 1.0 / PivotValue;
  For Row:= 1 to Na Do If Row <> RowX Then Begin
    Aj:= A[Row]^*[ColX];  A[Row]^*[ColX]:= -Aj / PivotValue;
    For Col:= 1 to Napi Do If Col <> ColX Then
      A[Row]^*[Col]:= A[Row]^*[Col] - Aj*A[RowX]^*[Col];
    End;
  End;
  { order solution values and create the PivOrdr array }
  For Row:= 1 to Na Do Begin
    RowX:= RowP[Row];       ColX:= ColP[Row];
    PivOrdr[RowX]:= ColX;   SrcInfo[FITorder[ColX]].Conc[1]:= A[RowX]^*[Napi];
  End;
  { adjust sign of the determinant }
  Count:= 0;
  For Row:= 1 to Pred(Na) Do Begin
    For Col:= Succ(Row) to Na Do If PivOrdr[Col] < PivOrdr[Row] Then Begin
      RowX:= PivOrdr[Col];  PivOrdr[Col]:= PivOrdr[Row];
      PivOrdr[Row]:= RowX;  Inc(Count);
    End;
  End;
  If Odd(Count) Then Deter:= -Deter;
  Add_Line('Determinant of coefficient matrix is '+PadNumStr0(Deter));
End;

Procedure Do_LLSQ_Fit;
{ Carries out a linear least squares fit to the selected data. The Lower
  variable selects whether the calculation is at chest or knee level. }
Var_PP : Pointer;
Begin
  New_Screen;  Add_Line('Linear Least Squares Fit to the Marked Data');
  Write('  ('';MaxAvail,' bytes free)');
  Mark(PP);
  Get_A_Matrix(Lower);
  Write_A_Matrix(Lower);  Simultaneous;
  Release(PP);
  WhchPg:= 1;           DoFit:= false;
  ReDoConc[1]:= true;
  Pause_To_Look;
End;

{===== Source Concentration Page =====}

Procedure Write_Item( s:integer; c:Byte );
{ Writes current values for SrcInfo[s] on the screen.
  The Conc value is written using the background color c. The Source
  name is written according to the current status of the FITsrc flag. }
Var_Cular : Byte;
Begin
  { find the screen positions of the beginning of the highlighted cell }
  Iy:= 4 + (Pred(s) mod Imax); { specifies row on the screen }
  Ix:= Cpos[Pred(s)] div Imax; { column on the screen }
  { set the color of the source name and write it }
  With SrcInfo[s] Do Begin

```

```

If FITsrc Then TextAttr:= ConcColor[UnitID]
  Else TextAttr:= ConcColor[UnitID]+16*FITBkgrd;
Msg([Ix+8,Iy,Copy(Name,1,18));
{ set the color of the source concentration and write it }
If c = black Then Culur:= HiColor
  Else Culur:= Black;
TextAttr:= Culur + 16*c;
If ShowC[Wsv] Then Msg([Ix,Iy,PadNumStr0(Conc[Wsv]));
  Else Msg([Ix,Iy,PadNumStr0(FaCn[Wsv]));
End;
GotoXY([Ix,Iy);
End;

Procedure Change(D:Integer);
{ Changes Isrc by D subject to the maximum value Nsrc.
  Smallest value is 1. }
Begin  Isrc:= Succ(Pred(Isrc + Nsrc + D) mod Nsrc);           End;

Procedure Down_Page;
Begin  SwitchPage:= true;  WhchPg:= Succ(WhchPg mod 8);      End;

Procedure Up_Page;
Begin  SwitchPage:= true;  WhchPg:= Succ((WhchPg+6) mod 8);  End;

Procedure Process_FuncKey_Src;
Var  L : Integer;
Begin
  CH:= ReadKey;
  Case CH of
    AltX : HellFreezes:= true;
    UP   : Change(-1);
    DN   : Change(+1);
    LFT  : Change(-Imax);
    RT   : Change(Imax);
    F1   : Show_Help_Page;
    F2   : Begin DoStatsCal:= true;      SwitchPage:= true;  End;
    SF2  : Begin DoStatsStg:= true;      SwitchPage:= true;  End;
    F3   : With SrcInfo[IsrC] Do Begin
      Conc[WhchPg]:= OrigC[WhchPg];
      FaCn[WhchPg]:= OrigF[WhchPg];
      End;
    AF3  : For L:= 1 to Nsrc Do With SrcInfo[L] Do Begin
      Conc[WhchPg]:= OrigC[WhchPg];
      FaCn[WhchPg]:= OrigF[WhchPg];
      Write_Item(L,black);
      End;
    F4   : With SrcInfo[IsrC] Do Begin
      Conc[WhchPg]:= GridC[WhchPg];
      FaCn[WhchPg]:= GridF[WhchPg];
      End;
    AF4  : For L:= 1 to Nsrc Do With SrcInfo[L] Do Begin
      Conc[WhchPg]:= GridC[WhchPg];
      FaCn[WhchPg]:= GridF[WhchPg];
      Write_Item(L,black);
      End;
    F5   : With SrcInfo[IsrC] Do Begin
      FITsrc:= not FITsrc;          CountSrc:= true;
      End;
    AF5  : Begin  CountSrc:= true;
      For L:= 1 to Nsrc Do With SrcInfo[L] Do Begin
        FITsrc:= true;  Write_Item(L,black);
        End;
      End;
    F6   : Begin  CountSrc:= true;          L:= Isrc;
      FunctionPressed:= not SrcInfo[IsrC].FITsrc;
      While (L > 1) and (SrcInfo[L].FITsrc xor FunctionPressed) Do
        With SrcInfo[L] Do Begin
          FITsrc:= not FITsrc;  Write_Item(L,black);
          Dec(L);  End;
      End;
    AF6  : Begin  CountSrc:= true;
      For L:= 1 to Nsrc Do With SrcInfo[L] Do Begin
        FITsrc:= false;  Write_Item(L,black);
        End;
      End;
    F7   : If WhchPg = 1 Then Beep
  End;

```

```

      Else Begin
        ShowC[WhchPg]:= not ShowC[WhchPg];
        ReDoConc[WhchPg]:= true;      SwitchPage:= true;
        End;
      F8 : Begin DoIt:= true;      SwitchPage:= true;      End;
      F9 : If PressToCalc[] Then Begin RecomputeCal:= true;
          SwitchPage:= true;      WhchPg:= WhchPg + 5;      End;
      F10 : If (PressToCalc[2] or PressToCalc[3]) Then Begin
          RecomputeStg:= true;      RecomputeCal:= PressToCalc[1];
          SwitchPage:= true;      WhchPg:= WhchPg + 5;      End;
    PgDn : Down_Page;
    PgUp : Up_Page;
    HOM : Isrc:= 1;           { to top of list }
    EndP : Isrc:= Nsrc;       { to bottom of list }
    Else Beep End;
  FunctionPressed:= false;
End;

Procedure Get_Real;
{ reads a real number and updates Conc & NewSumB as needed }
Var NewNumber,OldNo : Single;
Begin
  With SrcInfo[IsrC] Do Begin
    If ShowC[WhchPg] Then NewNumber:= Conc[WhchPg]
                           Else NewNumber:= FaCn[WhchPg];
    OldNo:= NewNumber;
    Read Real(NewNumber,0,10000,8,Ix,Iy);
    If OldNo <> NewNumber Then Begin
      If ShowC[WhchPg]
        Then Begin
          Conc[WhchPg]:= NewNumber;
          If WhchPg = 1 Then Begin
            Conc[2]:= Conc[1]*FaCn[2];
            Conc[3]:= Conc[2]*FaCn[3];
            End
          Else
            If WhchPg = 2 Then Begin
              If Conc[1] = 0.0
                Then Begin
                  Conc[2]:= 0.0; Beep;
                  End
                Else Begin
                  FaCn[2]:= Conc[2]/Conc[1];
                  Conc[3]:= Conc[2]*FaCn[3];
                  End;
                End
              Else Begin
                If Conc[2] = 0.0
                  Then Begin
                    Conc[3]:= 0.0; Beep;
                    End
                  Else FaCn[3]:= Conc[3]/Conc[2];
                End;
              End;
            End
          Else Begin
            FaCn[WhchPg]:= NewNumber;
            If WhchPg = 2 Then Conc[2]:= Conc[1]*FaCn[2];
            Conc[3]:= Conc[2]*FaCn[3];
            End;
          End;
        End;
      End;
    If FunctionPressed Then Process_FuncKey_Src;
  End;

Procedure Show_Source_Page;
Var L : Integer;      Chk : Boolean;
Begin
  Move(inScreen[WhchPg]^,Mem[$8800:01],8000); { restores the previous screen }
  Wsv:= WhchPg;
  If ReDoConc[WhchPg] Then Begin ReDoConc[WhchPg]:= false;
    For L:= 1 to Nsrc Do Write_Item(L,Black);
    End;
  TextAttr:= White;   Center_Msg(3,DataTitle[ShowC[WhchPg],WhchPg]);
  TextAttr:= HiColor; GotoXY(60,48); Write(Space,MaxAvail,' bytes free ');
  If WhchPg = 1 Then Begin GotoXY(6,46); Write(NumPt,' points '); End;
  SwitchPage:= false;
  TextAttr:= TblColor; Msg(60,46,DepthST[WhchPg>1]);

```

```

Repeat
  Isave:= Isrc;
  If CountSrc Then Begin
    Na:= 0;           CountSrc:= false;
    For L:= 1 to Nsrc Do If SrcInfo[L].FITsrc Then Inc(Na);
    TextAttr:= HiColor;
    GotoXY(30,46);  Write(Na,' LLSQ Sources ');
    GotoXY(30,48);  Write(Nsrc-Na,' Fixed Sources ');
    End;
    Write_Item(isrc,BoxBkgrd);
    CH:= UpCase(ReadKey);
    Case CH of
      #0 : Process_FuncKey_Src;
      Space : With SrcInfo[Isrc] Do Begin
        FITsrc:= not FITsrc;   CountSrc:= true;
      End;
      Period,
      '0'..'9' : Get_Real;
      TAB : Change(-max);
      CR : Change(+1);
      Else Beep End;
    Write_Item(Isave,black);
    Until SwitchPage or HellFreezes;
  Move(Mem[$8800:0],InScreen[Wsv])^,8000);  { stores the whole screen }
  { Changes PressToCalc to true if an input changed.
  The NewSum flags are set if Wch=1. }
  Chk:= false;
  For L:= 1 to Nsrc Do With SrcInfo[L] Do Begin
    DoSrc[Wsv]:= FITsrc or (Conc[Wsv] <> 0.0);
    If Conc[Wsv] <> GridC[Wsv] Then Begin          Chk:= true;
      If Wsv = 1 Then NewSumB[Pred(L+SumBlk)] div SumBlk:= true;
      GridCD[Wsv]:= Conc[Wsv]; GridF[Wsv]:= FaCn[Wsv];
    End;
  End;
  If Chk and not PressToCalc[Wsv] Then Begin
    If Wsv = 1 Then Begin
      PressToCalc[1]:= true;
      PressToCalc[2]:= true;
      If not ShowMore Then RecomputeCal:= true;
    End Else
    If Wsv = 2 Then PressToCalc[2]:= true;
    PressToCalc[3]:= true;
    If not ShowMore Then RecomputeStg:= true;
  End;
End;

{===== Graphical (text mode) Page =====}

Procedure Compute_Relative_Errors;
{ Recompute the relative errors between RPTdata and SumTotal }
Var I,J : Integer;
  TotC,TotK,SumC,SumK,WrkC,WrkK : Single;
Function Find_Rel_Err(Lvl:Boolean) : Single;
{ performs calculation for chest or knee }
Var Datm,Calc,Rat : Single;
Begin
  Datm:= RPTdata[Lvl]^I,J;           Calc:= SumTotal[Lvl]^I,J;
  If (Datm > 0.0) and (Calc > 0.0)
    Then Begin
      If Datm < Calc Then Find_Rel_Err:= (Calc-Datm) / (Datm+1.0)
      Else Find_Rel_Err:= (Calc-Datm) / (Calc+1.0)
    End
    Else Begin
      Fitpoint[I,J]:= false;       Find_Rel_Err:= 0.0;
    End;
End;
Begin
  SumC:= 0.0;                      SumK:= 0.0;
  TotC:= 0.0;                      TotK:= 0.0;
  For I:= 1 to Xmax Do
    For J:= 1 to Ymax Do Begin
      WrkC:= Find_Rel_Err(Chest); RelErr[Chest]^I,J:= WrkC;
      WrkK:= Find_Rel_Err(Knee);  RelErr[Knee]^I,J:= WrkK;
      TotC:= TotC + Abs(WrkC);   TotK:= TotK + Abs(WrkK);
      If Fitpoint[I,J] Then Begin
        SumC:= SumC + Abs(WrkC);
      End;
    End;
End;

```

```

FITRelErr[Chst]:= SumC;           FITRelErr[Knee]:= SumK;
TotRelErr[Chst]:= TotC;          TotRelErr[Knee]:= TotK;
End;

Procedure Make_Ratio_Grid;
Procedure Put_Grid(Lvl:Boolean);
{ Computes the dose rate ratios grid, including the title }
Var I,J,K : Integer;   Tmp : Single;
Begin
With GridData[MREpg,Lvl] Do Begin
  GrdName:= 'MCNP Compared with Measurements -- '+LevelSt[Lvl]+ ' Level'+DepthSt[Watr16];
  For I:= 1 to Xmax Do
    For J:= 1 to Ymax Do
      Tmp:= RelErr[Lvl]^I,J;           K:= 0;
      While Tmp > RatioHi[K] Do Inc(K);
      With GrfPlot[I,J] Do Begin
        Acolor:= RatioColor[K];   Achar:= GrfCh[K];
      End;
    End;
  End;
End;
Begin
  Compute_Relative_Errors;
  Put_Grid(Chst);      Put_Grid(Knee);
  Dump_2D_File(MREpg,RelErr,'Modified Relative Error');
End;

Procedure New_Source_File;
{ Writes a listing of the current source assumptions to a file. }
Var fo : Text;   N : Integer;
Begin
  Str(FileIdx:2,ST);  If ST[1] = Space Then ST[1]:= Zero;
  Assign(fo,File@Drive+StdFileName+ST+'.S'); Rewrite(fo);
  Add_Line('Writing the source list to '+ST);
  Writeln(fo,SrcTitle1); Writeln(fo,SrcTitle2);
  For N:= 1 to Nsrc Do Begin
    Source_Info_ST(N); Writeln(fo,ST);
  End;
  Writeln(fo);
  Writeln(fo,'Sum of Magnitudes of Modified Relative Errors:');
  Writeln(fo,MinNumStr(TotRelErr[Chst]),' (chest), and ',MinNumStr(TotRelErr[Knee]),' (knee)');
  Close(fo);
End;

Procedure Read_MCNP_Binary(Blk:Integer; Lvl:Boolean);
{ This updates both SumB[Blk,Lvl] and SumTotal[Lvl]. }
Var I,J,N,Strt : Integer;   Cnc,Tmp : Single;
Begin
  { zero the SumB[Blk,Lvl] array }
  FillChar(SumB[Blk,Lvl]^.SizeOf(StdGrid),0);
  { read in the new values for SumB }
  Strt:= Blk*SumBlk - Pred(SumBlk); { starting index for this group of sources }
  Seek(fb[Lvl],Succ(Strt));
  For N:= Strt to Pred(Strt+SumBlk) Do Begin
    Cnc:= SrcInfo[N].Conc[1];
    Read(fb[Lvl],OneRec); { dose rates from the Nth source }
    If SrcInfo[N].DoSrc[1] Then
      For I:= 1 to Xmax Do
        For J:= 1 to Ymax Do Begin
          Tmp:= OneRec.DR[I,J]*Cnc;
          If Tmp > 1.0E-06 Then Begin
            SumTotal[Lvl]^I,J:= SumTotal[Lvl]^I,J + Tmp;
            SumB[Blk,Lvl]^.I,J:= SumB[Blk,Lvl]^.I,J + Tmp;
          End;
        End;
      End;
    End;
  End;
End;

Procedure Redo_Calibration_Grid;
{ Recomputes the SumB and SumTotal arrays }
Var I,J,K,L : Integer;
Begin
  New_Screen;           Inc(FileIdx); { new set of files }
  RecomputeCal:= false; PressToCalc[1]:= false;

```

```

Add_Line('Computing the new total dose rates -- calibration case');
{ recompute the SumTotal array, updating SumB is needed }
FillChar(SumTotal[Chst]^,2*SizeOf(StdGrid),0);
For L:= 1 to SumMax Do Begin
  If NewSumB[L] Then
    Begin { read the binary files }
      Read_MCNP_Binary(L,Chst);  Read_MCNP_Binary(L,Knee);
      NewSumB[L]:= false;
    End;
  Else Begin { just add SumB to SumTotal }
    For I:= 1 to Xmax Do
      For J:= 1 to Ymax Do Begin
        SumTotal[Chst][I,J]:= SumTotal[Chst][I,J] + SumB[L,Chst][I,J];
        SumTotal[Knee][I,J]:= SumTotal[Knee][I,J] + SumB[L,Knee][I,J];
      End;
    End;
  End;
{ update the graph arrays }
Make_DR_Grid(GrCrg,SumTotal,'MCNP Dose Rates (mrem/h)');
Make_Ratio_Grid; { computes RelErr array & appends to the 2D file }
New_Source_File; { writes the current source file }
Pause_To_Look;
End;

Procedure Redo_Stage_Grids;
{ Recomputes the SumTotS1 and SumTotS2 arrays }
Var K,Whch : Integer;
Procedure Total_Doses(Ptr:StdPtr2; Lvl:Boolean; Strt,Fini:Integer);
Var I,J,N : Integer; Cnc,Tmp : Single;
Begin
  For N:= Strt To Fini Do Begin { water & wall sources }
    Cnc:= SrcInfo[N].Conc[Whch];
    If Cnc > 0.0 Then Begin
      Seek(fb[Lvl],Succ(N)); Read(fb[Lvl],OneRec);
      If SrcInfo[N].DoSrc[Whch] Then
        For I:= 1 to Xmax Do
          For J:= 1 to Ymax Do Begin
            Tmp:= OneRec.DR[I,J]*Cnc;
            If Tmp > 1.0E-06 Then
              Ptr[Lvl]^*[I,J]:= Ptr[Lvl]^*[I,J] + Tmp;
          End;
    End;
  End;
End;
Begin
  New_Screen; PressToCalc[2]:= false;
  RecomputeStg:= false; PressToCalc[3]:= false;
{ Stage 1 dose rates ===== }
Add_Line('Computing the new total dose rates -- Stage 1 case');
Whch:= 2;
{ recompute the SumTotS1 array }
FillChar(SumTotS1[Chst]^,2*SizeOf(StdGrid),0);
Total_Doses(SumTotS1,Chst,SrcOthr,SrcMax);
Total_Doses(SumTotS1,Knee,SrcOthr,SrcMax);
Depth1:= Watr17; { 17'2" depths }
Switch_Assigns(Chst); Switch_Assigns(Knee);
Total_Doses(SumTotS1,Chst,1,SrcPool);
Total_Doses(SumTotS1,Knee,1,SrcPool);
{ update the graph arrays }
Make_DR_Grid(SglPg,SumTotS1,'Stage 1 Dose Rates (mrem/h)');
{ Stage 2 dose rates ===== }
Add_Line('Computing the new total dose rates -- Stage 2 case');
Whch:= 3;
{ recompute the SumTotS2 array }
FillChar(SumTotS2[Chst]^,2*SizeOf(StdGrid),0);
Total_Doses(SumTotS2,Chst,1,SrcMax);
Total_Doses(SumTotS2,Knee,1,SrcMax);
{ update the graph arrays }
Make_DR_Grid(MaxPg,SumTotS2,'Stage 2 Dose Rates (mrem/h)');
Depth1:= Watr16; { 16'10" depths }
Switch_Assigns(Chst); Switch_Assigns(Knee);
Pause_To_Look;
End;

```

```

Procedure Write_Point_Total;
Begin

```

```

TextAttr:= HiColor; GotoXY(65,47); Write(NumPt,' points ');
End;

Procedure Write_Grid;
{ Displays the dose rate grid on the screen, beginning with the title. }
Procedure Put_Grid(Lvl:Boolean);
Var I,J : Integer; Tmp : Single;
Begin
With GridData[WhchPg,Lvl] Do Begin
  Writeln;
  TextAttr:= GridTitle; Write(Space,GrdName);
  TextAttr:= White;
  If WhchPg > MREpg Then Writeln
    Else Begin GotoXY(63,WhereY);
    Writeln('MRE: '+MinNumStr(TotRelErr[Lvl])+'.'+MinNumStr(TotRelErr[Lvl]));
    End;
  Writeln(' ',Alphabet,Alphabet,'ABCD');
  For I:= 1 to Xmax Do Begin
    TextAttr:= White; Write(RowID[I]);
    For J:= 1 to Ymax Do
      If FITpoint[I,J] or (WhchPg > MREpg)
        Then With GrfPlot[I,J] Do Begin
          TextAttr:= Acolor; Write(Achar);
        End
        Else Begin
          TextAttr:= Black; Write(Space);
        End;
    TextAttr:= White; Write(RowID[I]);
  If I > 17 Then Writeln;
  Else Begin
    If WhchPg = 6
      Then Begin
        TextAttr:= RatioColor[I]; Writeln(' ',RatioST[I]);
      End
      Else Begin
        If I = 17 Then Writeln Else Begin
          TextAttr:= Spectrum[I];
          Writeln(' ',#219,'<',MinNumStr(DRhight[I]));
        End;
      End;
    End;
  End;
End;
Begin
  New_Screen;
  Put_Grid(Chest); Put_Grid(Knee);
  TextAttr:= TblColor; Msg(72,2,'Page'+RowID[WhchPg]);
  TextAttr:= HelpTitle;
  ClrMsg(1,48,
    ' F5:Mark Column F6:Mark Row F7:Mark All AltF5-F7:Mark Pattern ');
  ClrMsg(1,49,
    ' PgUp,PgDn,0-3:Page Space:Mark Point Tab:Chest/Knee ');
  Write_Point_Total;
End;

Procedure Write_Grid_Point(x,y:Integer; c:Byte; Lvl:Boolean);
Var TmpC,TmpK : Single; UnitsT : ST9;
Begin
  Iy:= x + Roff[Lvl]; Ix:= y + 2;
  If c = black
    Then Begin If FITpoint[x,y]
      Then With GridData[WhchPg,Lvl].GrfPlot[x,y] Do Begin
        TextAttr:= Acolor; CH:= Achar; End
        Else Begin TextAttr:= black; CH:= Space; End;
      End
      Else Begin
        TextAttr:= TblColor; Msg(67,23,ColID[Col]+RowID[Row]);
        UnitsT:= ' mrem/h'; Msg(67,45,ColID[Col]+RowID[Row]);
        If WhchPg = GRPpg Then Begin
          TmpC:= RPTdata[Chst]^*[x,y]; TmpK:= RPTdata[Knee]^*[x,y];
        End
        Else
          If WhchPg = GRCPg Then Begin
            TmpC:= SumTotal[Chst]^*[x,y]; TmpK:= SumTotal[Knee]^*[x,y];
          End
        Else
          If WhchPg = MREpg Then Begin
            UnitST:= ' ';
          End;
      End;
    End;
  End;

```

```

        TmpC:= RelErr[Chst]^*[x,y];   TmpK:= RelErr[Knee]^*[x,y];
      End Else
    If WhchPg = Sg1Pg Then Begin
      TmpC:= SumTotS1[Chst]^*[x,y];   TmpK:= SumTotS1[Knee]^*[x,y];
    End Else
    If WhchPg = MaxPg Then Begin
      TmpC:= SumTotS2[Chst]^*[x,y];   TmpK:= SumTotS2[Knee]^*[x,y];
    End;
    Msg(65,24,MinNumStr(TmpC)+UnitST);
    Msg(65,46,MinNumStr(TmpK)+UnitST);
    TextAttr:= 16*c; CH:= CursCH;
  End;
  Msg(ix,iy,CH); GotoXY(ix,iy);
End;

Procedure Process_FuncKey_Grid;
Var I,J,L,K,Stp,Stp1 : Integer;   Flg : Boolean;
Begin
  CH:= ReadKey;
  Case CH of
    AltX : HellFreezes:= true;
    UP : Row:= Succ((Row+xmax-2) mod Xmax);
    DN : Row:= Succ(Row mod Xmax);
    LFT : Col:= Succ((Col+ymax-2) mod Ymax);
    RT : Col:= Succ(Col mod Ymax);
    F1 : Show_Help_Page;
    F2 : Begin DoStatsCal:= true;   SwitchPage:= true; End;
    SF2 : Begin DoStatsStg:= true;   SwitchPage:= true; End;
    F5 : Begin
      Flg:= not FITpoint[Row,Col];
      For L:= 1 to Xmax Do Begin
        FITpoint[L,Col]:= Flg;
        Write_Grid_Point(L,Col,black,Lower);
        Write_Grid_Point(L,Col,black,not Lower);
      End;
      CountPt:= true;
    End;
    F6 : Begin
      Flg:= not FITpoint[Row,Col];
      For L:= 1 to Ymax Do Begin
        FITpoint[Row,L]:= Flg;
        Write_Grid_Point(Row,L,black,Lower);
        Write_Grid_Point(Row,L,black,not Lower);
      End;
      CountPt:= true;
    End;
    F7 : Begin
      Flg:= not FITpoint[Row,Col];
      For L:= 1 to Xmax Do
        For K:= 1 to Ymax Do Begin
          FITpoint[L,K]:= Flg;
          Write_Grid_Point(L,K,black,Lower);
          Write_Grid_Point(L,K,black,not Lower);
        End;
      CountPt:= true;
    End;
    AF5,AF6,
    AF7 : Begin
      FillChar(FITpoint,SizeOf(FITpoint),0);
      Stp:= Ord(CH) - 106;           I:= Ymax - (Col mod Stp);
      L:= Xmax - (Row mod Stp);
      While L > 0 Do Begin
        K:= I;
        While K > 0 Do Begin
          FITpoint[L,K]:= true; Dec(K,Stp);
        End;
        Dec(L,Stp);
      End;
      SwitchPage:= true;           CountPt:= true;
    End;
    PgDn : Down_Page;
    PgUp : Up_Page;
    F8 : Begin DoIt:= true;   SwitchPage:= true; End;
    F9 : If PressToCalc[1] Then Begin
      RecomputeCal:= true;   SwitchPage:= true; End;
    F10 : If (PressToCalc[2] or PressToCalc[3]) Then Begin
      RecomputeCal:= PressToCalc[1];
      RecomputeStg:= true;   SwitchPage:= true; End;
    HOM : Row:= 1;   { to top of grid };
    EndP : Row:= Xmax; { to bottom of grid }
    Else Beep End;
  FunctionPressed:= false;
End;

```

```

Procedure Show_Grid_Page;
{ Shows the RPT data, MCNP dose rates, and ratios }
Var CursCh : Char;
Procedure Verify_FITpoint;
{ Checks that invalid points are not marked true. Also counts valid points. }
Var I,J : Integer; Flg : Boolean;
Begin
  NumPt:= 0; CountPt:= false;
  For I:= 1 to Xmax Do
    For J:= 1 to Ymax Do Begin
      Flg:= (SumTotal[Chst]^I,J > 0) and (RPTdata[Chst]^I,J > 0) and FITpoint[I,J];
      FITpoint[I,J]:= Flg; If Flg Then Inc(NumPt);
    End;
  Write_Point_Total;
End;
Begin
  Write_Grid; SwitchPage:= false;
  If PressToCalc[1] and ((WhchPg = GrCpg) or (WhchPg = MREpg))
    Then Begin TextAttr:= HIColor;
    Msg(5,25,'Press F9 to Recalculate Calibration Dose Rates');
    End Else
  If (PressToCalc[2] or PressToCalc[3]) and (WhchPg > MREpg)
    Then Begin TextAttr:= HIColor;
    Msg(5,25,'Press F10 to Recalculate Stage 1 & 2 Dose Rates');
    End;
Repeat
  Rsave:= Row; Csave:= Col; Lsave:= Lower;
  If CountPt and not PressToCalc[1] Then Verify_FITpoint;
  Write_Grid_Point(Row,Col,BoxBgrd,Lower);
  CH:= UpCase(ReadKey);
  Case CH of
    #0 : Process.FuncKey_Grid;
    Space : Begin BothGrd:= true; CountPt:= true;
    FITpoint[Row,Col]:= not FITpoint[Row,Col]; End;
    '1'..'8' : Begin WhchPg:= Ord(CH) - 48; SwitchPage:= true; End;
    Tab : Lower:= not Lower;
    Else Beep End;
  If not SwitchPage Then Write_Grid_Point(Rsave,Csave,black,Lsave);
  If BothGrd Then Begin
    Write_Grid_Point(Rsave,Csave,black,not Lsave);
    BothGrd:= false; End;
  Until SwitchPage or HellFreezes;
End;
{===== Main Program SSS.PAS ======}

Begin
  Initialize;
{ read the RPT dose rate files and prepare the grid }
  Make_RPT_Grid;
Repeat
  If DoStatsCal Then Begin
    If PressToCalc[1] Then Redo_Calibration_Grid;
    Make_Stat_Files(1);
    End Else
  If DoStatsStg Then Begin
    If PressToCalc[1] Then Redo_Calibration_Grid;
    If PressToCalc[2] or PressToCalc[3] Then Redo_Stage_Grids;
    Make_Stat_Files(2); Make_Stat_Files(3);
    End;
  If DoFit and (Na > 0) and (Na <= NumPt) Then Do_LLSQ_Fit;
  If WhchPg < 4 Then Show_Source_Page
  Else Begin
    If RecomputeCal and PressToCalc[1] Then Redo_Calibration_Grid;
    If RecomputeStg and (PressToCalc[2] or PressToCalc[3]) Then Redo_Stage_Grids;
    Show_Grid_Page;
    End;
  Blanks[0]:= #66;
Until HellFreezes;
Close(fb[Chst]); Close(fb[Knee]);
TextMode(ModeSave);
End.

```

DISTRIBUTION SHEET

To F. W. Moore X3-85	From P. D. Rittmann H0-31	Page 1 of 1 Date May 13, 1997		
Project Title/Work Order HNF-SD-SNF-CAVR-002 Rev 0 MCNP Model for the Many KE-Basin Radiation Sources				EDT No. 621459
			ECN No. na	
Name	MSIN	Text With All Attach.	Text Only	Attach./Appendix Only
W. C. Alaconis	R3-85	X		
C. J. Alderman	X3-85	X		
K. H. Bergsman	X3-85	X		
B. S. Carlisle	X3-75	X		
D. R. Duncan	R3-86	X		
D. W. Humphrys	X3-67	X		
P. G. Huntley	X3-72	X		
J. L. Julyk	X3-85	X		
J. E. Kurtz	X3-60	X		
J. S. Lan	H0-35	X		
R. J. Lodwick	X3-78	X		
C. D. Lucas	X3-67	X		
W. J. Millsap	X3-78	X		
F. W. Moore	X3-85	X		
R. J. Puigh II	H0-31	X		
M. A. Reilly	R3-86	X		
P. D. Rittmann	H0-31	X		
D. H. Splett	S7-41	X		
D. S. Takasumi	X3-85	X		
M. J. Wiemers	X3-85	X		
A. H. Ziada	X3-78	X		
Project File A-8	X3-85	X		
Central Files (1+Original)	A3-88	X		