

2. To: (Receiving Organization) Consequence Analysis (8M400)	3. From: (Originating Organization) Consequence Analysis (8M400)	4. Related EDT No.: NA
5. Proj./Prog./Dept./Div.: 8M400	6. Cog. Engr.: A. V. Savino	7. Purchase Order No.: NA
8. Originator Remarks: Calculation notes are used to document the originator's analysis but are not to be used as the final or sole document to authorize activities or justify facility modifications.		9. Equip./Component No.: NA
		10. System/Bldg./Facility: TWRS
11. Receiver Remarks: NA		12. Major Assm. Dwg. No.: NA
		13. Permit/Permit Application No.: NA
		14. Required Response Date: NA

15. DATA TRANSMITTED				(F)	(G)	(H)	(I)	
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	WHC-SD-WM-CN-033	NA	0	MICROSHIELD Dose Rate Calculations for HEPA Filters and Prefilters	NA	1,2	1	1

16. KEY						
Approval Designator (F)		Reason for Transmittal (G)			Disposition (H) & (I)	
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval	4. Review	1. Approved		4. Reviewed no/comment
		2. Release	5. Post-Review	2. Approved w/comment		5. Reviewed w/comment
		3. Information	6. Dist. (Receipt Acknow. Required)	3. Disapproved w/comment		6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G)	(H)	(J) Name	(K) Signature	(L) Date	(M) MSIN	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G)	(H)
1	1	Cog.Eng. A. V. Savino	<i>A. V. Savino</i>	9/24/96							
1	1	Cog. Mgr. D. S. Leach	<i>D. S. Leach</i>	9/24/96							
1	1	Peer Reviewer D. A. Himes	<i>D. A. Himes</i>	9/24/96							

18. Signature of EDT Originator <i>A. V. Savino</i> Date: 9/24/96	19. Authorized Representative Date for Receiving Organization NA	20. Cognizant Manager Date <i>D. S. Leach</i> , 9/24/96	21. DOE APPROVAL (if required) Ctrl. No. <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/comments <input type="checkbox"/> Disapproved w/comments
---	---	--	--

MICROSHIELD Dose Rate Calculations for HEPA Filters and Prefilters

A. V. Savino
Westinghouse Hanford Company, Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-87RL10930

EDT/ECN: EDT-619404 UC: 510
Org Code: 8M400 Charge Code: NIFC3
B&R Code: EW3120071 Total Pages: 36


Key Words: MICROSHIELD, dose rate, HEPA filters, Prefilters

Abstract: This document supports the TWRS Final Safety Analysis Report:

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: WHC/BCS Document Control Services, P.O. Box 1970, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Jamie Bishop 9-27-96
Release Approval Date



Approved for Public Release

1.0 MICROSIELD¹ Dose Rate Calculations for HEPA Filters and Prefilters

One of the tank ventilation system accident scenarios identified in the FSAR is a filter blowout. In order to determine the accident consequences for filter blowout events, it is necessary to know the radioactive loading of the filters as a function of the filter contact dose rate. This calcnote documents the filter dose calculations which will be used in the Tank Farms FSAR. The calculations were done using the MICROSIELD Version 4 computer code (Grove 1992). The BREMCALC computer code (Rittman 1992) was used to determine the bremsstrahlung radiation source term for the important beta emitters (⁹⁰Sr and ⁹⁰Y) as described in Section 1.1.

There are several HEPA filter and prefilter arrangements in the tank farms ventilation systems. The SX Tank Farm ventilation system consists of 3 x 3 arrays of 2 x 2 x 1 ft (0.61 x 0.61 x 0.3 m) filters in series. The passively ventilated SSTs contain either single 1 x 1 x 1 ft (0.3 x 0.3 x 0.3 m) or single 2 x 2 x 1 ft (0.61 x 0.61 x 0.3 m) breather filters in series. The DST ventilation system contains single 2 x 2 x 1 ft (0.61 x 0.61 x 0.61 m) filters in series. The DCRTs contain single 1 x 1 x 1 ft (0.3 x 0.3 x 0.3 m) filters in series. Each of the ventilation systems also contain prefilters, with the exception of the passively ventilated SSTs. The prefilters have the same cross sectional dimensions as the HEPA filters in the direction of airflow, however, the depth of the prefilters are 2.5 in (6.4 cm) versus 1 ft (0.3 m) for the HEPA filters.

Section 1.1 documents the contact dose rate calculation for a 3 x 3 array of 2 x 2 x 1 ft (0.61 x 0.61 x 0.3 m) filters loaded with 1 curie of radioactivity that originated from SST solid waste. Section 1.2 documents the contact dose rate calculation for a single 1 x 1 x 1 ft (0.3 x 0.3 x 0.3 m) breather filter loaded with 1 curie of SST solid waste. Section 1.3 documents the contact dose rate calculation for a single 2 x 2 x 2 ft (0.61 x 0.61 x 0.61 m) breather filter loaded with 1 curie of SST solid waste. Section 1.4 documents the contact dose rate calculation for a single 2 x 2 x 2 ft (0.61 x 0.61 x 0.61 m) filter loaded with 1 curie of DST liquid waste. Section 1.5 documents the contact dose rate calculation for a single 1 x 1 x 1 ft (0.3 x 0.3 x 0.3 m) DCRT filter loaded with 1 curie of SST liquid waste.

Section 1.6 documents the contact dose rate calculation for a 3 x 3 array of 2 ft x 2 ft x 2.5 in (0.61 x 0.61 x 0.064 m) prefilters loaded with 1 curie of SST solid waste. Section 1.7 documents the contact dose rate calculation for a single 2 ft x 2 ft x 2.5 in (0.61 x 0.61 x 0.064 m) prefilter loaded with 1 curie of DST liquid waste. Section 1.8 documents the contact dose rate calculation for a single 1 ft x 1 ft x 2.5 in (0.3 x 0.3 x 0.064 m) prefilter loaded with 1 curie of SST liquid waste.

The following assumptions were made for this analysis:

1) The waste material is assumed to be homogeneously distributed throughout the filter volume.

¹MICROSIELD is a registered trademark of Grove Engineering, Inc.

2) Contact dose rates correspond to the detector locations indicated on Figure 1 (page 8).

3) For the SX Tank Farm 3 by 3 filter configuration, a simplified geometry was used. The 9 filters which make up a 3 x 3 filter bank were modeled as a single rectangular parallelepiped with a height of 1.83 m (6 ft), a width of 1.83 m (6 ft), and a depth of 0.3 m (1 ft). From geometric considerations, on the average, gamma rays pass through about 5 thicknesses of the aluminum frame, or a total of 1.016 cm (0.4 in = 5 x 0.08 in) of aluminum (see Section 1.1).

4) The MICROSIELD runs only included the radionuclides with major contributions to the dose rates. This decision was based on the waste type loaded on the HEPA filter (e.g. , SST Liquids, SST Solids, DST Liquids, etc.) and the radionuclide concentrations associated with that waste type (see Table 1).

1.1 SX Tank Farm Dose Rate Calculation for 3 x 3 HEPA Filter Arrangement (2 x 2 x 1 Filter)

The HEPA filters in the actively ventilated SSTs are 0.61 m (2 ft) long, by 0.61 m (2 ft) wide, and 0.3 m (1 ft) deep in the direction of airflow. The filter consists of a corrugated filter media of borosilicate glass microfibers with aluminum separators attached to the pleats. The filter media is housed in a 0.2 cm (0.08 in) thick aluminum frame. A filter bank in the SST ventilation system consists of an array of 3 x 3 filters. The following describes the MICROSIELD model developed for a single filter.

The borosilicate glass microfibers have an areal density of about 9.7E-03 g/cm² (2.0E-02 lb/ft²). The borosilicate glass material is distributed over an area of about 23.2 m² (250 ft²), which results in about 2.27 kg (5 lb) of borosilicate glass microfibers on each filter. If this material is assumed to be homogeneously distributed throughout the entire filter volume, the density of borosilicate glass is 0.02 g/cc, as shown below.

$$\text{Density of Borosilicate Glass} = \frac{5 \text{ lb} \times 454 \text{ g/lb}}{(2 \times 2 \times 1) \text{ ft}^3 \times 28230 \text{ cc/ft}^3} = 0.02 \text{ g/cc}$$

The areal density of the corrugated aluminum separators is about 1.17E-02 g/cm² (2.39E-02 lb/ft²). The total area of the aluminum separators is 29.8 m² (321 ft²), which results in about 3.48 kg (7.66 lb) of aluminum on each filter. If this material is assumed to be homogeneously distributed throughout the entire filter volume, the density of aluminum is 0.03 g/cc, as shown below.

$$\text{Density of Aluminum} = \frac{7.66 \text{ lb} \times 454 \text{ g/lb}}{(2 \times 2 \times 1) \text{ ft}^3 \times 28230 \text{ cc/ft}^3} = 0.03 \text{ g/cc}$$

The following describes the simplified model developed for the 3 x 3 filter bank arrangement.

The 9 filters which make up a 3 x 3 filter bank were modeled as a single rectangular parallelepiped with a height of 1.83 m (6 ft), a width of 1.83 m (6 ft), and a depth of 0.3 m (1 ft). The radioactive source was assumed to be uniformly distributed throughout the entire volume ($6 \times 6 \times 1 \text{ ft}^3$). From geometric considerations, on the average, gamma rays pass through about 5 thicknesses of the aluminum frame, or a total of 1.016 cm ($0.4 \text{ in} = 5 \times 0.08 \text{ in}$) of aluminum. The "contact" dose rate was assumed to be measured at a location 1 ft from the bottom of the filter bank, 0.15 m (0.5 ft) from the face of the filter in the direction of airflow, and 1.3 cm (0.5 in) off of the side of the filter. Figure 1 illustrates this location, which was identified by the requestor as the location where contact readings are made for a 3 x 3 filter configuration.

Two MICROSIELD runs were made because the source term consisted of gamma emitters along with beta emitters which result in the production of bremsstrahlung radiation. The first run was made to calculate the dose contribution from ^{137}Ba and ^{154}Eu , which are the major gamma emitters in the source term. The second run was made to calculate the dose contribution from bremsstrahlung radiation produced during the decay of $^{90}\text{Sr}/^{90}\text{Y}$. The second run was necessary because MICROSIELD does not generate the bremsstrahlung source term internally. Therefore, the BREMCALC computer code was used to generate the bremsstrahlung source term which was then fed into MICROSIELD to estimate the dose rate. Note that other beta and gamma emitters are present in the source term, however, the 3 radionuclides above are the major dose contributors.

The filter was assumed to be loaded with a total of 1 Ci of SST Solids, which has maximum sample activity concentrations of $1.0\text{E}+11 \text{ Bq/L}$ of ^{137}Cs , $5.8\text{E}+09 \text{ Bq/L}$ of ^{154}Eu , and $1.6\text{E}+12 \text{ Bq/L}$ each of ^{90}Sr and ^{90}Y (see Table 1). The activity concentrations in Table 1 were taken from Van Keuren (1996). As mentioned above, other beta and gamma emitters present in the SST Solids composite have negligible dose contributions and were not included in the model. One curie of SST Solids would therefore contain about 0.4840 Ci each of ^{90}Sr and ^{90}Y , 0.0303 Ci of ^{137}Cs , and 0.0017 Ci of ^{154}Eu . Note that these numbers were slightly adjusted so that the sum for the mixture totalled 1 Ci.

The resulting contact dose rate from MICROSIELD was 0.224 mSv/hr (22.4 mR/hr) from ^{137}Cs and ^{154}Eu , and 0.033 mSv/hr (3.3 mR/hr) from ^{90}Sr and ^{90}Y , or a total of 0.257 mSv/hr (25.7 mR/hr) per Ci of SST Solid waste accumulated on the 3 x 3 filter bank. These calculations assume the filters are uniformly loaded, which introduces some uncertainty in the results because the dose rate at the side of the filters is sensitive to the distribution of radioactive material on the filters contained in the 3 x 3 array. However, this was considered an acceptable approach and within the uncertainty of the overall calculations. The photon fluence-to-dose conversion factors used were the anterior-to-posterior irradiation pattern as outlined in ANSI standard

ANSI/ANS-6.1.1-1991 (ANS 1991). The ISO-PC input deck is included in Attachment 1. The MICROSHIELD output is included in the Appendix.

Note that although the filter media consists of borosilicate glass microfibers and aluminum separators, for simplicity the bremsstrahlung photon production rate used was for ^{90}Sr and ^{90}Y in water. This was done because the bremsstrahlung photon production rate for 1 Ci of ^{90}Sr and ^{90}Y in water was readily available (Savino 1995). The ISO-PC computer code (Rittman 1995) contains a model to approximate the bremsstrahlung radiation source term for a mixture. Using ISO-PC, the photon production rate from bremsstrahlung radiation was found to be slightly higher in the filter media than it was in water for 1 Ci of ^{90}Sr and ^{90}Y . Note that the dose contribution from ^{90}Sr and ^{90}Y is only 13% of the total, and since the end use of these dose rates is to back-calculate the activity on the filter given a contact dose rate, it is conservative to underestimate the bremsstrahlung contribution to the total dose. That is, the amount of material accumulated on the filter for a given contact dose rate will actually be lower than that predicted using the value calculated above (25.7 mR/hr/Ci). The photon production rate from BREMCALC is shown in Table 2 for 0.484 Ci of ^{90}Sr and ^{90}Y .

1.2 Single Breather Filter Dose Rate Calculation for Passively Ventilated SSTs (1 x 1 x 1 ft Filter)

Some of the HEPA filters in the passively ventilated SSTs are 0.3 m (1 ft) long, by 0.3 m (1 ft) wide, and 0.3 m (1 ft) deep in the direction of airflow. Calculations for a single breather filter loaded with 1 Ci of SST solids were performed similarly to those in Section 1.1. In this case the model geometry consisted of a 0.3 x 0.3 x 0.3 m (1 x 1 x 1 ft) filter with a 0.2 cm (0.08 in) thick aluminum shield. Dose rates were calculated at a location 0.15 m (0.5 ft) from the bottom of the filter bank, 0.15 m (0.5 ft) from the face of the filter in the direction of airflow, and 1.3 cm (0.5 in) off of the side of the filter. Figure 1 illustrates this location for a single filter.

Once again, two MICROSHIELD runs were made because the source term consisted of gamma emitters and beta emitters which result in the production of bremsstrahlung radiation. The first run was made to calculate the dose contribution from ^{137}Ba and ^{154}Eu , which are the major gamma emitters, and the second run was made to calculate the dose contribution from bremsstrahlung radiation produced during the decay of $^{90}\text{Sr}/^{90}\text{Y}$. The activities are the same as that described in Section 1.1. The photon production rate from BREMCALC is also the same as that described in Section 1.1 (see Table 2).

The resulting contact dose rate from MICROSHIELD was 4.05 mSv/hr (405 mR/hr) from ^{137}Cs and ^{154}Eu , and 0.694 mSv/hr (69.4 mR/hr) from ^{90}Sr and ^{90}Y , or a total of 4.75 mSv/hr (475 mR/hr) per Ci of SST Solid waste accumulated on the filter. The MICROSHIELD output is included in the Appendix.

1.3 Single Breather Filter Dose Rate Calculation for Passively Ventilated SSTs (2 x 2 x 1 ft Filter)

Some of the HEPA filters in the passively ventilated SSTs are 0.6 x 0.6 x 0.3 m (2 x 2 x 1 ft). Calculations for a single filter loaded with 1 Ci of SST solids were performed similarly to those in Section 1.1. In this case the model geometry consisted of a 0.61 x 0.61 x 0.3 m (2 x 2 x 1 ft) filter with a 0.2 cm (0.08 in) thick aluminum shield. Dose rates were calculated at a location 0.3 m (1 ft) from the bottom of the filter bank, 0.15 m (0.5 ft) from the face of the filter in the direction of airflow, and 1.3 cm (0.5 in) off of the side of the filter.

Once again, two MICROSHIELD runs were made because the source term consisted of gamma emitters and beta emitters which result in the production of bremsstrahlung radiation. The activities are the same as that described in Section 1.1. The photon production rate from BREMCALC is also the same as that described in Section 1.1 (see Table 2).

The resulting contact dose rate from MICROSHIELD was 1.51 mSv/hr (151 mR/hr) from ¹³⁷Cs and ¹⁵⁴Eu, and 0.253 mSv/hr (25.3 mR/hr) from ⁹⁰Sr and ⁹⁰Y, or a total of 1.77 mSv/hr (177 mR/hr) per Ci of SST Solid waste accumulated on the filter. The MICROSHIELD output is included in the Appendix.

1.4 Dose Rate Calculation for DST Single (2 x 2 x 1 ft) Filter

A similar calculation was performed for a single filter loaded with 1 Ci of DST liquids. The model geometry consisted of a 0.61 x 0.61 x 0.3 m (2 x 2 x 1 ft) filter with a 0.2 cm (0.08 in) thick aluminum shield. Dose rates were calculated at a location 0.3 m (1 ft) from the bottom of the filter bank, 0.15 m (0.5 ft) from the face of the filter in the direction of airflow, and 1.3 cm (0.5 in) off of the side of the filter.

By examining the maximum sample activity concentrations for DST liquids (see Table 1) it is evident that only ¹³⁷Cs needs to be accounted for because of the high activity concentration of ¹³⁷Cs relative to other gamma emitters. ⁹⁰Sr and ⁹⁰Y are in low enough concentrations that their contribution to the total dose is negligible. The source activity was then taken to be 1 Ci of ¹³⁷Cs which was distributed uniformly throughout the filter volume.

The resulting contact dose rate from MICROSHIELD was 44.7 mSv/hr (4,470 mR/hr). The MICROSHIELD output is included in the Appendix.

1.5 Single (1 x 1 x 1 ft) DCRT Filter Dose Rate Calculation

The DCRT filters are 0.3 m (1 ft) long, by 0.3 m (1 ft) wide, and 0.3 m (1 ft) deep in the direction of airflow. Calculations for a single filter loaded with 1 Ci of SST liquids were performed similarly to those above. The model geometry consisted of a 0.3 x 0.3 x 0.3 m (1 x 1 x 1 ft) filter with a 0.2 cm (0.08 in) thick aluminum shield. Dose rates were calculated at a location 0.15 m (0.5 ft) from the bottom of the filter bank, 0.15 m (0.5 ft)

from the face of the filter in the direction of airflow, and 1.3 cm (0.5 in) off of the side of the filter.

By examining the maximum sample activity concentrations for SST Liquids (see Table 1) it is evident that only ^{137}Cs and ^{154}Eu need to be accounted for because of the higher activity concentrations of these two nuclides relative to other gamma emitters. ^{90}Sr and ^{90}Y are in low enough concentrations that their contribution to the total dose is negligible. One curie of SST Liquids would therefore contain about 0.9016 Ci of ^{137}Cs and 0.0984 Ci of ^{154}Eu .

The resulting contact dose rate from MICROSHIELD was 130 mSv/hr (1.3 x 10⁴ mR/hr). The MICROSHIELD output is included in the Appendix.

1.6 SX Tank Farm Dose Rate Calculation for 3 x 3 Prefilter Arrangement (2 ft x 2 ft x 2.5 in filter)

The prefilters in the actively ventilated SSTs are 0.61 m (2 ft) long, by 0.61 m (2 ft) wide, and 0.064 m (2.5 in) deep in the direction of airflow. The filter is similar to a common home furnace filter with light-weighted strands of fibrous material. The prefilters will be modeled using the same material constituents as that which was used for the HEPA filters. This is conservative since the prefilters actually have less shielding than the HEPA filters. This results in lower predicted dose rates for the prefilters, which results in a greater amount of radioactive material being predicted to have accumulated on the filter before a certain dose rate is reached.

A filter bank in the SST ventilation system consists of an array of 3 x 3 filters. The dose rate was assumed to be measured at a location 1 ft from the bottom of the filter bank, 0.032 m (1.25 in) from the face of the filter in the direction of airflow, and 1.3 cm (0.5 in) off of the side of the filter.

Once again, two MICROSHIELD runs were made because the source term consisted of gamma emitters and beta emitters which result in the production of bremsstrahlung radiation. The activities are the same as that described in Section 1.1. The photon production rate from BREMCALC is also the same as that described in Section 1.1 (see Table 2).

The resulting contact dose rate from MICROSHIELD was 0.296 mSv/hr (29.6 mR/hr) from ^{137}Cs and ^{154}Eu , and 0.045 mSv/hr (4.5 mR/hr) from ^{90}Sr and ^{90}Y , or a total of 0.34 mSv/hr (34 mR/hr) per Ci of SST Solid waste accumulated on the filter. The MICROSHIELD output is included in the Appendix.

1.7 Dose Rate Calculation - Single DST (2 ft x 2 ft x 2.5 in) Prefilter

A similar calculation was performed for a single prefilter loaded with 1 Ci of DST liquids. The model geometry consisted of a 0.61 x 0.61 x 0.064 m (2 ft x 2 ft x 2.5 in) prefilter with a 0.2 cm (0.08 in) thick aluminum shield. Dose rates were calculated at a location 0.3 m (1 ft) from the bottom of the

filter bank, 0.064 m (1.25 in) from the face of the filter in the direction of airflow, and 1.3 cm (0.5 in) off of the side of the filter.

By examining the maximum sample activity concentrations for DST liquids (see Table 1) it is evident that only ^{137}Cs needs to be accounted for because of the high activity concentration of ^{137}Cs relative to other gamma emitters. ^{90}Sr and ^{90}Y are in low enough concentrations that their contribution to the total dose is negligible. The source activity was then taken to be 1 Ci of ^{137}Cs which was distributed uniformly throughout the filter volume.

The resulting contact dose rate from MICROSIELD was 61.0 mSv/hr (6.1×10^3 mR/hr). The MICROSIELD output is included in the Appendix.

1.8 Single (1 ft x 1 ft x 2.5 in) DCRT Prefilter Dose Rate Calculation

The DCRT prefilters are 0.3 m (1 ft) long, by 0.3 m (1 ft) wide, and 0.064 m (2.5 in) deep in the direction of airflow. Calculations for a single prefilter loaded with 1 Ci of SST liquids were performed similarly to those above. The model geometry consisted of a 0.3 x 0.3 x 0.064 m (1 ft x 1 ft x 2.5 in) prefilter with a 0.2 cm (0.08 in) thick aluminum shield. Dose rates were calculated at a location 0.15 m (0.5 ft) from the bottom of the filter bank, 0.032 m (1.25 in) from the face of the filter in the direction of airflow, and 1.3 cm (0.5 in) off of the side of the filter.

By examining the maximum sample activity concentrations for SST liquids (see Table 1) it is evident that only ^{137}Cs and ^{154}Eu need to be accounted for because of the higher activity concentrations of these two nuclides relative to other gamma emitters. ^{90}Sr and ^{90}Y are in low enough concentrations that their contribution to the total dose is negligible. One curie of SST Liquids would therefore contain about 0.9016 Ci of ^{137}Cs and 0.0984 Ci of ^{154}Eu .

The resulting contact dose rate from MICROSIELD was 2.2×10^2 mSv/hr (2.2×10^4 mR/hr). The MICROSIELD output is included in the Appendix.

2.0 References

ANS, 1991, *Neutron and Gamma-Ray Fluence-to-Dose Factors*, ANSI/ANS-6.1.1-1991, American Nuclear Society, La Grange Park, Illinois.

Grove 1992, *MICROSIELD Version 4*, Grove Engineering, Inc. 15125 Shady Grove Road, Rockville, Maryland.


Rittman, P. D., 1992, *BRENCALC - A Computer Program for Calculating Electron and Positron Bremsstrahlung*, WHC-SA-1435-FP, Westinghouse Hanford Company, Richland, Washington.

Van Keuren, 1996, *Tank Waste Compositions and Atmospheric Dispersion Coefficients*, WHC-SD-WM-SARR-016 Rev. 2, Westinghouse Hanford Company, Richland, Washington.


FIGURE 1

RE 1. p

3 x 3 FILTER CONFIGURATION
DETECTOR LOCATION



SINGLE FILTER
DETECTOR LOCATION



BEST AVAILABLE COPY

WHC-SD-WM-CN-033 REV 0

Table 1 - Tank Waste Maximum Sample Activity Concentrations^a

ISOTOPE	Activity Concentrations, Bq/L			
	SST LIQUID	SST SOLID	DST LIQUID	DST SOLID
C 14	1.0E+05	1.2E+05	2.3E+05	1.6E+05
CO60	9.5E+06	4.2E+08	7.0E+06	1.5E+07
SE79	0.0E+00	1.7E+04	0.0E+00	0.0E+00
SR90	1.1E+10	1.6E+12	4.6E+09	5.2E+10
Y 90	1.1E+10	1.6E+12	4.6E+09	5.2E+10
TC99	1.7E+07	1.2E+10	1.1E+07	6.2E+07
RU106	9.9E+02	7.2E+04	0.0E+00	0.0E+00
SB125	3.4E+04	1.8E+08	0.0E+00	0.0E+00
I 129	1.0E+04	6.4E+06	2.0E+04	2.0E+04
CS134	1.2E+05	1.4E+06	6.1E+06	9.4E+06
CS137	2.2E+10	1.0E+11	5.9E+10	5.9E+10
CE144	9.1E+00	3.4E+02	0.0E+00	0.0E+00
PM147	0.0E+00	0.0E+00	3.6E+07	0.0E+00
EU154	2.4E+09	5.8E+09	4.2E+07	3.0E+08
EU155	5.9E+07	5.0E+06	0.0E+00	0.0E+00
NP237	0.0E+00	3.0E+07	2.3E+05	8.1E+05
PU238	9.2E+04	1.9E+08	1.8E+06	7.2E+07
PU239 ^b	3.6E+07	4.4E+08	7.7E+06	1.6E+09
PU241	2.6E+08	3.2E+09	1.8E+07	3.8E+09
AM241	4.2E+07	2.3E+08	3.4E+07	2.7E+09
CM242	0.0E+00	0.0E+00	1.1E+01	0.0E+00
CM244	4.2E+05	2.3E+06	1.2E+05	1.6E+07
TOTALS	4.6E+10	3.4E+12	6.8E+10	1.7E+11

^a From Van Keuren (1996).

^b Includes ²⁴⁰Pu.

Table 2 - Bremsstrahlung Photon Production Rates from ⁹⁰Sr and ⁹⁰Y in Water

Midpoint Energy, MeV	Photon Production Rates, photon/s	
	1 Ci of ⁹⁰ Sr/ ⁹⁰ Y ^a	0.484 Ci of ⁹⁰ Sr/ ⁹⁰ Y
0.015	7.8E+08	3.8E+08
0.025	4.0E+08	1.9E+08
0.035	2.6E+08	1.2E+08
0.045	1.8E+08	8.8E+07
0.055	1.4E+08	6.7E+07
0.065	1.1E+08	5.3E+07
0.075	8.9E+07	4.3E+07
0.085	7.4E+07	3.6E+07
0.095	6.3E+07	3.0E+07
0.150	3.3E+08	1.6E+08
0.250	1.3E+08	6.4E+07
0.350	6.9E+07	3.3E+07
0.475	5.5E+07	2.7E+07
0.650	3.5E+07	1.7E+07
0.825	1.4E+07	6.6E+06
1.000	9.8E+06	4.8E+06
1.225	5.5E+06	2.7E+06
1.475	2.1E+06	1.0E+06
1.700	5.3E+05	2.6E+05
1.900	1.4E+05	6.6E+04
2.100	1.5E+04	7.2E+03
2.300	8.3E+01	4.0E+01

1 Ci = 3.7 E+10 Bq

^a From Savino (1995).

Appendix

MicroShield 4.00 - Serial #4,00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: 3X3CSEU.MS4
Run Date: May 13, 1996
Run Time: 2:11 p.m. Monday
Duration: 0:00:50

File Ref: _____
Date: / /
By: _____
Checked: _____

Case Title: 3x3 NEPA - Simplified Model - 0.0303 Ci Cs/ 0.0017 Ci Eu154

GEOMETRY 11 - Rectangular Volume

	centimeters	feet	and inches
Dose point coordinate X:	184.404	6.0	.6
Dose point coordinate Y:	30.48	1.0	.0
Dose point coordinate Z:	15.24	0.0	6.0
Rectangular volume width :	30.48	1.0	.0
Rectangular volume length:	182.88	6.0	.0
Rectangular volume height:	182.88	6.0	.0
Shield 1:	1.016	0.0	.4
Air Gap:	0.508	0.0	.2

Source Volume: 1.01941e+6 cm³ 36. cu ft. 62208 cu in.

Material	MATERIAL DENSITIES (g/cm ³)		
	Source Shield	Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	20
Y Direction	20
Z Direction	10

Nuclide	SOURCE NUCLIDES					
	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³	
Ba-137m	2.8660e-002	2.8114e-002	Eu-154	1.7000e-003	1.6676e-003	

WHC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: 3X3CSEU.MS4
 Run Date: May 13, 1996
 Run Time: 2:11 p.m. Monday
 Title : 3x3 NEPA - Simplified Model - 0.0303 Ci Cs/ 0.0017 Ci Eu154

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate		Exposure Rate In Air	
		(MeV/sq	cm/sec)	(mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.1231	2.545e+007	2.169e+001	5.812e+001	3.406e-002	9.128e-002
0.246	4.296e+006	9.008e+000	1.900e+001	1.657e-002	3.496e-002
0.4426	5.850e+005	2.553e+000	4.393e+000	5.000e-003	8.602e-003
0.5907	3.920e+006	2.442e+001	3.832e+001	4.772e-002	7.486e-002
0.6628	9.715e+008	6.969e+003	1.058e+004	1.351e+001	2.050e+001
0.8723	8.825e+006	8.844e+001	1.253e+002	1.664e-001	2.358e-001
1.0024	1.788e+007	2.120e+002	2.914e+002	3.906e-001	5.369e-001
1.2719	2.328e+007	3.673e+002	4.810e+002	6.444e-001	8.440e-001
1.5767	2.217e+006	4.512e+001	5.693e+001	7.488e-002	9.449e-002
TOTAL:	1.058e+009	7.740e+003	1.165e+004	1.489e+001	2.242e+001

WHC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: 3X3SRV.MS4
Run Date: May 13, 1996
Run Time: 2:18 p.m. Monday
Duration: 0:02:04

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 3x3 HEPA - Simplified Model - 0.484 Ci Sr/Y

GEOMETRY 11 - Rectangular Volume

	centimeters	feet	and inches
Dose point coordinate X:	184.404	6.0	.6
Dose point coordinate Y:	30.48	1.0	.0
Dose point coordinate Z:	15.24	0.0	6.0
Rectangular volume width :	30.48	1.0	.0
Rectangular volume length:	182.88	6.0	.0
Rectangular volume height:	182.88	6.0	.0
Shield 1:	1.016	0.0	.4
Air Gap:	0.508	0.0	.2

Source Volume: 1.01941e+6 cm³ 36. cu ft. 62208 cu in.

Material	MATERIAL DENSITIES (g/cm ³)	
	Source Shield	Shield 1 Air Gap Slab
Air		0.00122
Aluminum	0.03	2.702
Glass	0.02	

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	20
Y Direction	20
Z Direction	10

Nuclide	SOURCE NUCLIDES		
	curies	microCi/cm ³	Nuclide curies microCi/cm ³
USER INPUT SOURCE TERM			

WHC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: 3X3SR1.MS4
 Run Date: May 13, 1996
 Run Time: 2:18 p.m. Monday
 Title : 3x3 NEPA - Simplified Model - 0.484 Ci Sr/Y

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate		Exposure Rate In Air	
		No Buildup (MeV/sq cm/sec)	With Buildup	No Buildup (mR/hr)	With Buildup
0.015	3.790e+008	3.452e-011	3.803e-011	2.961e-012	3.262e-012
0.025	1.930e+008	3.502e-002	4.585e-002	6.040e-004	7.909e-004
0.035	1.240e+008	1.938e+000	3.164e+000	1.228e-002	2.005e-002
0.045	8.810e+007	7.021e+000	1.414e+001	2.335e-002	4.702e-002
0.055	6.680e+007	1.176e+001	2.785e+001	2.647e-002	6.269e-002
0.065	5.280e+007	1.480e+001	3.933e+001	2.687e-002	7.140e-002
0.075	4.310e+007	1.652e+001	4.560e+001	2.693e-002	7.432e-002
0.085	3.590e+007	1.736e+001	4.835e+001	2.697e-002	7.510e-002
0.095	3.040e+007	1.768e+001	4.929e+001	2.706e-002	7.544e-002
0.15	1.610e+008	1.791e+002	4.521e+002	2.949e-001	7.444e-001
0.25	6.390e+007	1.368e+002	2.868e+002	2.524e-001	5.291e-001
0.35	3.330e+007	1.086e+002	2.020e+002	2.095e-001	3.896e-001
0.475	2.660e+007	1.267e+002	2.130e+002	2.486e-001	4.179e-001
0.65	1.710e+007	1.198e+002	1.828e+002	2.325e-001	3.548e-001
0.825	6.580e+006	6.163e+001	8.847e+001	1.168e-001	1.677e-001
1.0	4.750e+006	5.615e+001	7.722e+001	1.035e-001	1.423e-001
1.225	2.680e+006	4.043e+001	5.333e+001	7.156e-002	9.440e-002
1.475	9.970e+005	1.876e+001	2.393e+001	3.170e-002	4.044e-002
1.7	2.580e+005	5.735e+000	7.155e+000	9.316e-003	1.162e-002
1.9	6.580e+004	1.665e+000	2.044e+000	2.616e-003	3.211e-003
2.1	7.210e+003	2.048e-001	2.479e-001	3.119e-004	3.775e-004
2.3	3.990e+001	1.259e-003	1.504e-003	1.861e-006	2.225e-006
TOTAL:	1.330e+009	9.427e+002	1.817e+003	1.744e+000	3.323e+000

WHC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: 1X1BRSR.MS4
Run Date: May 13, 1996
Run Time: 2:20 p.m. Monday
Duration: 0:00:34

File Ref: _____
Date: _____
By: _____
Checked: _____

Case Title: 1 x 1 ft Breather Filter - 0.484 Ci Sr/Y90

GEOMETRY 11 - Rectangular Volume

	centimeters	feet	and inches
Dose point coordinate X:	32.004	1.0	.6
Dose point coordinate Y:	15.24	0.0	6.0
Dose point coordinate Z:	15.24	0.0	6.0
Rectangular volume width :	30.48	1.0	.0
Rectangular volume length:	30.48	1.0	.0
Rectangular volume height:	30.48	1.0	.0
Shield 1:	0.2032	0.0	.1
Air Gap:	1.3208	0.0	.5

Source Volume: 28316.8 cm³ 1 cu ft. 1728. cu in.

Material	Source Shield	MATERIAL DENSITIES (g/cm ³)	
		Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP

Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	10
Y Direction	10
Z Direction	10

SOURCE NUCLIDES

Nuclide	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³
USER INPUT	SOURCE TERM				

WMC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: 1X1BRSR.MS4
 Run Date: May 13, 1996
 Run Time: 2:20 p.m. Monday
 Title : 1 x 1 ft Breather Filter - 0.484 Ci Sr/Y90

===== RESULTS =====						
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)		
		No Buildup	With Buildup	No Buildup	With Buildup	
0.015	3.790e+008	4.201e-001	4.483e-001	3.603e-002	3.865e-002	
0.025	1.930e+008	1.457e+002	1.724e+002	2.514e+000	2.974e+000	
0.035	1.240e+008	4.699e+002	6.282e+002	2.977e+000	3.980e+000	
0.045	8.810e+007	6.472e+002	8.917e+002	2.152e+000	2.966e+000	
0.055	6.680e+007	7.103e+002	1.032e+003	1.599e+000	2.324e+000	
0.065	5.280e+007	7.207e+002	1.092e+003	1.308e+000	1.982e+000	
0.075	4.310e+007	7.108e+002	1.046e+003	1.158e+000	1.705e+000	
0.085	3.590e+007	6.905e+002	9.891e+002	1.073e+000	1.536e+000	
0.095	3.040e+007	6.664e+002	9.383e+002	1.020e+000	1.436e+000	
0.15	1.610e+008	5.859e+003	7.668e+003	9.648e+000	1.263e+001	
0.25	6.390e+007	4.021e+003	4.894e+003	7.418e+000	9.030e+000	
0.35	3.330e+007	2.997e+003	3.510e+003	5.780e+000	6.770e+000	
0.475	2.660e+007	3.308e+003	3.762e+003	6.491e+000	7.381e+000	
0.65	1.710e+007	2.962e+003	3.279e+003	5.750e+000	6.365e+000	
0.825	6.580e+006	1.465e+003	1.596e+003	2.776e+000	3.024e+000	
1.0	4.750e+006	1.294e+003	1.394e+003	2.385e+000	2.570e+000	
1.225	2.680e+006	9.031e+002	9.628e+002	1.598e+000	1.704e+000	
1.475	9.970e+005	4.078e+002	4.312e+002	6.893e-001	7.288e-001	
1.7	2.580e+005	1.223e+002	1.286e+002	1.987e-001	2.090e-001	
1.9	6.580e+004	3.502e+001	3.668e+001	5.502e-002	5.763e-002	
2.1	7.210e+003	4.256e+000	4.443e+000	6.482e-003	6.765e-003	
2.3	3.990e+001	2.588e-002	2.693e-002	3.827e-005	3.983e-005	
TOTAL:	1.330e+009	2.814e+004	3.446e+004	5.663e+001	6.941e+001	

WHC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: 1X1BRCS.MS4
Run Date: May 13, 1996
Run Time: 2:24 p.m. Monday
Duration: 0:00:14

File Ref: _____
Date: ____/____/____
By: _____
Checked: _____

Case Title: 1 x 1 ft Breather Filter - 0.0303 Ci Cs-137/0.0017 Ci Eu154

GEOMETRY 11 - Rectangular Volume

	centimeters	feet and inches
Dose point coordinate X:	32.004	1.0 .6
Dose point coordinate Y:	15.24	0.0 6.0
Dose point coordinate Z:	15.24	0.0 6.0
Rectangular volume width :	30.48	1.0 .0
Rectangular volume length:	30.48	1.0 .0
Rectangular volume height:	30.48	1.0 .0
Shield 1:	0.2032	0.0 .1
Air Gap:	1.3208	0.0 .5

Source Volume: 28316.8 cm³ 1 cu ft. 1728. cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	10
Y Direction	10
Z Direction	10

SOURCE NUCLIDES

Nuclide	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³
Ba-137m	2.8664e-002	1.0123e+000	Eu-154	1.7000e-003	6.0035e-002

WHC-SD-WN-CN-033 REV 0

Page : 2
 DOS File: 1X1BRCS.MS4
 Run Date: May 13, 1996
 Run Time: 2:24 p.m. Monday
 Title : 1 X 1 ft Breather Filter - 0.0303 Ci Cs-137/0.0017 Ci Eu154

RESULTS					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.0537	1.187e+008	1.214e+003	1.744e+003	2.841e+000	4.079e+000
0.246	4.296e+006	2.656e+002	3.240e+002	4.887e-001	5.961e-001
0.4426	5.850e+005	6.751e+001	7.728e+001	1.322e-001	1.513e-001
0.5907	3.920e+006	6.139e+002	6.847e+002	1.199e+000	1.338e+000
0.6628	9.717e+008	1.718e+005	1.899e+005	3.330e+002	3.681e+002
0.8723	8.825e+006	2.083e+003	2.261e+003	3.920e+000	4.255e+000
1.0024	1.788e+007	4.884e+003	5.261e+003	8.998e+000	9.693e+000
1.2719	2.328e+007	8.158e+003	8.682e+003	1.431e+001	1.523e+001
1.5767	2.217e+006	9.721e+002	1.025e+003	1.613e+000	1.701e+000
TOTAL:	1.151e+009	1.900e+005	2.099e+005	3.665e+002	4.051e+002

WHC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: 2X2BRSR.MS4
Run Date: May 13, 1996
Run Time: 2:27 p.m. Monday
Duration: 0:00:35

File Ref: _____
Date: ____/____/____
By: _____
Checked: _____

Case Title: 2 x 2 ft Breather Filter - 0.484 Ci Sr/Y90

GEOMETRY 11 - Rectangular Volume

	centimeters	feet	and inches
Dose point coordinate X:	62.484	2.0	.6
Dose point coordinate Y:	30.48	1.0	.0
Dose point coordinate Z:	15.24	0.0	6.0
Rectangular volume width :	30.48	1.0	.0
Rectangular volume length:	60.96	2.0	.0
Rectangular volume height:	60.96	2.0	.0
Shield 1:	0.2032	0.0	.1
Air Gap:	1.3208	0.0	.5

Source Volume: 113267. cm³ 4 cu ft. 6912. cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	10
Y Direction	10
Z Direction	10

SOURCE NUCLIDES

Nuclide	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³
USER INPUT	SOURCE TERM				

WHC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: 2X2BRSR.MS4
 Run Date: May 13, 1996
 Run Time: 2:27 p.m. Monday
 Title : 2 x 2 ft Breather Filter - 0.484 Ci Sr/Y90

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.015	3.790e+008	4.690e-002	5.027e-002	4.023e-003	4.312e-003
0.025	1.930e+008	3.510e+001	4.195e+001	6.053e-001	7.236e-001
0.035	1.240e+008	1.397e+002	1.914e+002	8.850e-001	1.212e+000
0.045	8.810e+007	2.091e+002	3.033e+002	6.953e-001	1.009e+000
0.055	6.680e+007	2.381e+002	3.708e+002	5.359e-001	8.346e-001
0.065	5.280e+007	2.462e+002	4.067e+002	4.469e-001	7.383e-001
0.075	4.310e+007	2.455e+002	3.960e+002	4.001e-001	6.454e-001
0.085	3.590e+007	2.401e+002	3.766e+002	3.730e-001	5.851e-001
0.095	3.040e+007	2.328e+002	3.585e+002	3.563e-001	5.487e-001
0.15	1.610e+008	2.073e+003	2.923e+003	3.414e+000	4.814e+000
0.25	6.390e+007	1.437e+003	1.848e+003	2.651e+000	3.410e+000
0.35	3.330e+007	1.077e+003	1.319e+003	2.078e+000	2.545e+000
0.475	2.660e+007	1.195e+003	1.409e+003	2.345e+000	2.765e+000
0.65	1.710e+007	1.075e+003	1.225e+003	2.087e+000	2.378e+000
0.825	6.580e+006	5.336e+002	5.956e+002	1.011e+000	1.129e+000
1.0	4.750e+006	4.727e+002	5.202e+002	8.713e-001	9.590e-001
1.225	2.680e+006	3.308e+002	3.592e+002	5.854e-001	6.358e-001
1.475	9.970e+005	1.497e+002	1.609e+002	2.531e-001	2.719e-001
1.7	2.580e+005	4.499e+001	4.799e+001	7.307e-002	7.796e-002
1.9	6.580e+004	1.289e+001	1.368e+001	2.026e-002	2.150e-002
2.1	7.210e+003	1.569e+000	1.658e+000	2.389e-003	2.524e-003
2.3	3.990e+001	9.546e-003	1.005e-002	1.412e-005	1.486e-005
TOTAL:	1.330e+009	9.990e+003	1.287e+004	1.969e+001	2.531e+001

WHC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1

DOS File: 2X2BRCS.MS4
Run Date: May 13, 1996
Run Time: 2:28 p.m. Monday
Duration: 0:00:14

File Ref: _____

Date: _____

By: _____

Checked: _____

Case Title: 2 x 2 ft Breather Filter - 0.0303 Ci Cs-137/0.0017 Ci Eu154

GEOMETRY 11 - Rectangular Volume

	centimeters	feet	and inches
Dose point coordinate X:	62.484	2.0	.6
Dose point coordinate Y:	30.48	1.0	.0
Dose point coordinate Z:	15.24	0.0	6.0
Rectangular volume width :	30.48	1.0	.0
Rectangular volume length:	60.96	2.0	.0
Rectangular volume height:	60.96	2.0	.0
Shield 1:	0.2032	0.0	.1
Air Gap:	1.3208	0.0	.5

Source Volume: 113267. cm³ 4 cu ft. 6912. cu in.

Material	Source Shield	MATERIAL DENSITIES (g/cm ³)	
		Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	10
Y Direction	10
Z Direction	10

Nuclide	SOURCE NUCLIDES				
	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³
Ba-137m	2.8664e-002	2.5306e-001	Eu-154	1.7000e-003	1.5009e-002

WHC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: 2X2BRCS.MS4
 Run Date: May 13, 1996
 Run Time: 2:28 p.m. Monday
 Title : 2 x 2 ft Breather Filter - 0.0303 Ci Cs-137/0.0017 Ci Eu154

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate in Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.0537	1.187e+008	4.057e+002	6.227e+002	9.492e-001	1.457e+000
0.246	4.296e+006	9.489e+001	1.224e+002	1.746e-001	2.252e-001
0.4426	5.850e+005	2.436e+001	2.898e+001	4.770e-002	5.674e-002
0.5907	3.920e+006	2.225e+002	2.560e+002	4.347e-001	5.002e-001
0.6628	9.717e+008	6.238e+004	7.095e+004	1.209e+002	1.375e+002
0.8723	8.825e+006	7.594e+002	8.441e+002	1.429e+000	1.588e+000
1.0024	1.788e+007	1.784e+003	1.963e+003	3.287e+000	3.617e+000
1.2719	2.328e+007	2.989e+003	3.239e+003	5.245e+000	5.683e+000
1.5767	2.217e+006	3.572e+002	3.824e+002	5.927e-001	6.346e-001
TOTAL:	1.151e+009	6.902e+004	7.841e+004	1.331e+002	1.513e+002

WHC-SD-WN-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: 2X2DST.MS4
Run Date: May 13, 1996
Run Time: 2:48 p.m. Monday
Duration: 0:00:08

File Ref: _____
Date: ____/____/____
By: _____
Checked: _____

Case Title: DST HEPA Filter - Single 2 x 2 ft Filter - 1 Ci Cs-137

GEOMETRY 11 - Rectangular Volume

	centimeters	feet and inches
Dose point coordinate X:	62.484	2.0 .6
Dose point coordinate Y:	30.48	1.0 .0
Dose point coordinate Z:	15.24	0.0 6.0
Rectangular volume width :	30.48	1.0 .0
Rectangular volume length:	60.96	2.0 .0
Rectangular volume height:	60.96	2.0 .0
Shield 1:	0.2032	0.0 .1
Air Gap:	1.3208	0.0 .5

Source Volume: 113267. cm³ 4 cu ft. 6912. cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	10
Y Direction	10
Z Direction	10

SOURCE NUCLIDES

Nuclide	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³
Ba-137m	9.4594e-001	8.3514e+000	Cs-137	9.9994e-001	8.8281e+000

WHC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: ZX2DST.MS4
 Run Date: May 13, 1996
 Run Time: 2:48 p.m. Monday
 Title : DST HEPA Filter - Single 2 x 2 ft Filter - 1 Ci Cs-137

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate		Exposure Rate in Air	
		No Buildup (MeV/sq cm/sec)	With Buildup	No Buildup (mR/hr)	With Buildup
0.0318	7.246e+008	5.512e+002	7.228e+002	4.591e+000	6.021e+000
0.0322	1.337e+009	1.072e+003	1.413e+003	8.628e+000	1.137e+001
0.0364	4.865e+008	6.310e+002	8.791e+002	3.585e+000	4.994e+000
0.6616	3.149e+010	2.018e+006	2.296e+006	3.912e+003	4.450e+003
TOTAL:	3.404e+010	2.020e+006	2.299e+006	3.929e+003	4.473e+003

WHC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: 1X1DCRT.MS4
Run Date: June 3, 1996
Run Time: 9:51 a.m. Monday
Duration: 0:00:14

File Ref: _____
Date: ____/____/____
By: _____
Checked: _____

Case Title: DCRT HEPA Filter - 1 x 1 ft - 0.9016 Cs-137/0.0984 Ci Eu-154

GEOMETRY 11 - Rectangular Volume

	centimeters	feet	and inches
Dose point coordinate X:	32.004	1.0	.6
Dose point coordinate Y:	15.24	0.0	6.0
Dose point coordinate Z:	15.24	0.0	6.0
Rectangular volume width :	30.48	1.0	.0
Rectangular volume length:	30.48	1.0	.0
Rectangular volume height:	30.48	1.0	.0
Shield 1:	0.2032	0.0	.1
Air Gap:	1.3208	0.0	.5

Source Volume: 28316.8 cm³ 1 cu ft. 1728. cu in.

Material	Source Shield	MATERIAL DENSITIES (g/cm ³)	
		Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	10
Y Direction	10
Z Direction	10

Nuclide	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³
Ba-137m	8.5290e-001	3.0120e+001	Eu-154	9.8400e-002	3.4750e+000

WHC-SD-WN-CN-033 REV 0

Page : 2
 DOS File: 1X1DCRT.MS4
 Run Date: June 3, 1996
 Run Time: 9:51 a.m. Monday
 Title : DCRT HEPA Filter - 1 x 1 ft - 0.9016 Cs-137/0.0984 Ci Eu-154

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate		Exposure Rate In Air	
		No Buildup (MeV/sq cm/sec)	With Buildup	No Buildup (mR/hr)	With Buildup
0.0684	4.046e+009	5.925e+004	8.911e+004	1.027e+002	1.545e+002
0.246	2.486e+008	1.538e+004	1.876e+004	2.829e+001	3.451e+001
0.4426	3.386e+007	3.908e+003	4.473e+003	7.653e+000	8.760e+000
0.5907	2.269e+008	3.553e+004	3.963e+004	6.942e+001	7.742e+001
0.6638	2.940e+010	5.207e+006	5.755e+006	1.009e+004	1.115e+004
0.8723	5.108e+008	1.206e+005	1.309e+005	2.269e+002	2.463e+002
1.0024	1.035e+009	2.827e+005	3.045e+005	5.208e+002	5.611e+002
1.2719	1.347e+009	4.722e+005	5.025e+005	8.285e+002	8.817e+002
1.5767	1.283e+008	5.627e+004	5.933e+004	9.338e+001	9.847e+001
TOTAL:	3.698e+010	6.252e+006	6.904e+006	1.197e+004	1.322e+004

WMC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: PREFSRV.MS4
Run Date: May 22, 1996
Run Time: 10:26 a.m. Wednesday
Duration: 0:02:04

File Ref: _____
Date: ____/____/____
By: _____
Checked: _____

Case Title: 3x3 Prefilter - Simplified Model - 0.484 Ci Sr/Y

GEOMETRY 11 - Rectangular Volume

	centimeters	feet	and inches
Dose point coordinate X:	184.404	6.0	.6
Dose point coordinate Y:	30.48	1.0	.0
Dose point coordinate Z:	3.175	0.0	1.3
Rectangular volume width :	6.35	0.0	2.5
Rectangular volume length:	182.88	6.0	.0
Rectangular volume height:	182.88	6.0	.0
Shield 1:	1.016	0.0	.4
Air Gap:	0.508	0.0	.2

Source Volume: 212376. cm³ 7.5 cu ft. 12960 cu in.

Material	Source Shield	MATERIAL DENSITIES (g/cm ³)	
		Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	20
Y Direction	20
Z Direction	10

Nuclide	SOURCE NUCLIDES			
	curies	microCi/cm ³	Nuclide	curies microCi/cm ³
USER INPUT SOURCE TERM				

WHC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: PREFSRY.MS4
 Run Date: May 22, 1996
 Run Time: 10:26 a.m. Wednesday
 Title : 3x3 Prefilter - Simplified Model - 0.484 Ci Sr/Y

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate in Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.015	3.790e+008	1.852e-010	2.038e-010	1.588e-011	1.748e-011
0.025	1.930e+008	9.326e-002	1.213e-001	1.609e-003	2.092e-003
0.035	1.240e+008	3.771e+000	6.044e+000	2.389e-002	3.829e-002
0.045	8.810e+007	1.199e+001	2.327e+001	3.987e-002	7.738e-002
0.055	6.680e+007	1.889e+001	4.245e+001	4.252e-002	9.555e-002
0.065	5.280e+007	2.302e+001	5.756e+001	4.179e-002	1.045e-001
0.075	4.310e+007	2.521e+001	6.471e+001	4.109e-002	1.055e-001
0.085	3.590e+007	2.617e+001	6.722e+001	4.065e-002	1.044e-001
0.095	3.040e+007	2.642e+001	6.765e+001	4.044e-002	1.035e-001
0.15	1.610e+008	2.616e+002	6.031e+002	4.307e-001	9.931e-001
0.25	6.390e+007	1.962e+002	3.793e+002	3.620e-001	6.998e-001
0.35	3.330e+007	1.541e+002	2.668e+002	2.973e-001	5.146e-001
0.475	2.660e+007	1.781e+002	2.814e+002	3.495e-001	5.521e-001
0.65	1.710e+007	1.668e+002	2.416e+002	3.239e-001	4.690e-001
0.825	6.580e+006	8.527e+001	1.169e+002	1.616e-001	2.216e-001
1.0	4.750e+006	7.728e+001	1.021e+002	1.425e-001	1.881e-001
1.225	2.680e+006	5.535e+001	7.046e+001	9.796e-002	1.247e-001
1.475	9.970e+005	2.556e+001	3.159e+001	4.320e-002	5.340e-002
1.7	2.580e+005	7.789e+000	9.442e+000	1.265e-002	1.534e-002
1.9	6.580e+004	2.256e+000	2.696e+000	3.544e-003	4.236e-003
2.1	7.210e+003	2.770e-001	3.269e-001	4.217e-004	4.978e-004
2.3	3.990e+001	1.699e-003	1.983e-003	2.512e-006	2.933e-006
TOTAL:	1.330e+009	1.346e+003	2.435e+003	2.497e+000	4.468e+000

WHC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: 3X3CSEU.MS4
Run Date: May 22, 1996
Run Time: 10:30 a.m. Wednesday
Duration: 0:00:50

File Ref: _____
Date: ____/____/____
By: _____
Checked: _____

Case Title: 3x3 Prefilter- Simplified Modl 0.0303 Ci Cs/0.0017 Ci Eu154

GEOMETRY 11 - Rectangular Volume

	centimeters	feet and inches
Dose point coordinate X:	184.404	6.0 .6
Dose point coordinate Y:	30.48	1.0 .0
Dose point coordinate Z:	3.175	0.0 1.3
Rectangular volume width :	6.35	0.0 2.5
Rectangular volume length:	182.88	6.0 .0
Rectangular volume height:	182.88	6.0 .0
Shield 1:	1.016	0.0 .4
Air Gap:	0.508	0.0 .2

Source Volume: 212376. cm³ 7.5 cu ft. 12960 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	20
Y Direction	20
Z Direction	10

SOURCE NUCLIDES

Nuclide	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³
Ba-137m	2.8660e-002	1.3495e-001	Eu-154	1.7000e-003	8.0047e-003

WHC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: 3X3CSEU.M54
 Run Date: May 22, 1996
 Run Time: 10:30 a.m. Wednesday
 Title : 3x3 Prefilter- Simplified Modl 0.0303 Ci Cs/0.0017 Ci Eu154

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.1231	2.545e+007	3.194e+001	7.824e+001	5.016e-002	1.229e-001
0.246	4.296e+006	1.293e+001	2.513e+001	2.379e-002	4.624e-002
0.4426	5.850e+005	3.597e+000	5.803e+000	7.045e-003	1.136e-002
0.5907	3.920e+006	3.412e+001	5.064e+001	6.665e-002	9.893e-002
0.6628	9.715e+008	9.702e+003	1.398e+004	1.881e+001	2.710e+001
0.8723	8.825e+006	1.222e+002	1.657e+002	2.299e-001	3.117e-001
1.0024	1.788e+007	2.917e+002	3.851e+002	5.375e-001	7.095e-001
1.2719	2.328e+007	5.023e+002	6.355e+002	8.813e-001	1.115e+000
1.5767	2.217e+006	6.138e+001	7.516e+001	1.019e-001	1.247e-001
TOTAL:	1.058e+009	1.076e+004	1.540e+004	2.070e+001	2.984e+001

WHC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1	File Ref: _____
DOS File: PREFDST.WS4	Date: <u> </u> / <u> </u> / <u> </u>
Run Date: May 22, 1996	By: _____
Run Time: 9:46 a.m. Wednesday	Checked: _____
Duration: 0:00:05	

Case Title: DST Prefilter - 2 x 2 ft Filter - DST Liq - 1 Ci Cs-137

GEOMETRY 11 - Rectangular Volume

	centimeters	feet	and inches
Dose point coordinate X:	62.484	2.0	.6
Dose point coordinate Y:	30.48	1.0	.0
Dose point coordinate Z:	3.175	0.0	1.3
Rectangular volume width :	6.35	0.0	2.5
Rectangular volume length:	60.96	2.0	.0
Rectangular volume height:	60.96	2.0	.0
Shield 1:	0.2032	0.0	.1
Air Gap:	1.3208	0.0	.5

Source Volume: 23597.4 cm³ .833333 cu ft. 1440 cu in.

Material	Source Shield	MATERIAL DENSITIES (g/cm ³)	
		Shield 1 Slab	Air Gap
Air			0.00122
ALuminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	10
Y Direction	10
Z Direction	10

Nuclide	SOURCE NUCLIDES				
	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³
Ba-137m	9.4594e-001	4.0087e+001	Cs-137	9.9994e-001	4.2375e+001

WHC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: PREFDST.WS4
 Run Date: May 22, 1996
 Run Time: 9:46 a.m. Wednesday
 Title : DST Prefilter - 2 x 2 ft Filter - DST Liq - 1 Ci Cs-137

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.0333	1.823e+009	2.871e+003	3.765e+003	2.092e+001	2.744e+001
0.6616	3.149e+010	2.825e+006	3.148e+006	5.477e+003	6.103e+003
TOTAL:	<u>3.332e+010</u>	<u>2.828e+006</u>	<u>3.152e+006</u>	<u>5.498e+003</u>	<u>6.130e+003</u>

WHC-SD-WM-CN-033 REV 0

MicroShield 4.00 - Serial #4.00-00386
Westinghouse Hanford Co.

Page : 1
DOS File: PREFDRT.MS4
Run Date: June 3, 1996
Run Time: 9:52 a.m. Monday
Duration: 0:00:14

File Ref: _____
Date: ____/____/____
By: _____
Checked: _____

Case Title: DCRT Prefilter - 1 x 1 ft - 0.9016 Cs-137/ 0.0984 Ci Eu-154

GEOMETRY 11 - Rectangular Volume

	centimeters	feet and inches
Dose point coordinate X:	32.004	1.0 .6
Dose point coordinate Y:	15.24	0.0 6.0
Dose point coordinate Z:	3.175	0.0 1.3
Rectangular volume width :	6.35	0.0 2.5
Rectangular volume length:	30.48	1.0 .0
Rectangular volume height:	30.48	1.0 .0
Shield 1:	0.2032	0.0 .1
Air Gap:	1.3208	0.0 .5

Source Volume: 5899.34 cm³ .208333 cu ft. 360 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap
Air			0.00122
Aluminum	0.03	2.702	
Glass	0.02		

BUILDUP
Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
X Direction	10
Y Direction	10
Z Direction	10

SOURCE NUCLIDES

Nuclide	curies	microCi/cm ³	Nuclide	curies	microCi/cm ³
Ba-137m	8.5290e-001	1.4458e+002	Eu-154	9.8400e-002	1.6680e+001

WHC-SD-WM-CN-033 REV 0

Page : 2
 DOS File: PREFDCRT.HS4
 Run Date: June 3, 1996
 Run Time: 9:52 a.m. Monday
 Title : DCRT Prefilter - 1 x 1 ft - 0.9016 Cs-137/ 0.0984 Ci Eu-154

===== RESULTS =====						
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate		Exposure Rate In Air		
		No Buildup (MeV/sq cm/sec)	With Buildup	No Buildup (mR/hr)	With Buildup	
0.0684	4.046e+009	1.036e+005	1.437e+005	1.795e+002	2.491e+002	
0.246	2.486e+008	2.600e+004	3.041e+004	4.784e+001	5.595e+001	
0.4426	3.386e+007	6.559e+003	7.295e+003	1.284e+001	1.429e+001	
0.5907	2.269e+008	5.943e+004	6.476e+004	1.161e+002	1.265e+002	
0.6638	2.940e+010	8.696e+006	9.409e+006	1.685e+004	1.824e+004	
0.8723	5.108e+008	2.008e+005	2.142e+005	3.778e+002	4.030e+002	
1.0024	1.035e+009	4.700e+005	4.983e+005	8.660e+002	9.182e+002	
1.2719	1.347e+009	7.833e+005	8.226e+005	1.374e+003	1.443e+003	
1.5767	1.283e+008	9.315e+004	9.712e+004	1.546e+002	1.612e+002	
TOTAL:	5.698e+010	1.044e+007	1.129e+007	1.998e+004	2.161e+004	

033
 WHC-SD-WM-CN-~~Doc~~ REV 0
 CHECKLIST FOR PEER REVIEW

Document Reviewed: "MICROSHIELD Dose Rate Calculation for HEPA Filters and Prefilters," WHC-SD-WM-CN-033 REV 0, by Anthony V. Savino, June 1996.

Scope of Review: Entire document

Yes	No	NA	
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	* Previous reviews complete and cover analysis, up to scope of this review, with no gaps. Problem completely defined.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Accident scenarios developed in a clear and logical manner.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Necessary assumptions explicitly stated and supported.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Computer codes and data files documented.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data used in calculations explicitly stated in document.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data checked for consistency with original source information as applicable.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Mathematical derivations checked including dimensional consistency of results.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Models appropriate and used within range of validity or use outside range of established validity justified.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hand calculations checked for errors. Spreadsheet results should be treated exactly the same as hand calculations.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Software input correct and consistent with document reviewed.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Software output consistent with input and with results reported in document reviewed.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Limits/criteria/guidelines applied to analysis results are appropriate and referenced. Limits/criteria/guidelines checked against references.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Safety margins consistent with good engineering practices. Conclusions consistent with analytical results and applicable limits.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Results and conclusions address all points required in the problem statement.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Format consistent with appropriate NRC Regulatory Guide or other standards
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	* Review calculations, comments, and/or notes are attached.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Document approved.

Dave Himes
 Reviewer (Printed Name and Signature)

6/3/96
 Date

DISTRIBUTION SHEET

To	From	Page 1 of 1
Distribution	A. V. Savino	Date 9/24/96
Project Title/Work Order		EDT No. 619404
MICROSHIELD Dose Rate Calculations for HEPA Filters and Prefilters		ECN No. N/A

Name	MSIN	Text With All Attach.	Text Only	Attach./ Appendix Only	EDT/ECN Only
------	------	-----------------------------	-----------	------------------------------	-----------------

C. Carro	A2-34	X			
D. S. Leach	A3-34	X			
A. V. Savino (3)	G1-11	X			
TWRS S & L Project Files (6)	A2-26	X			
Central Files (Original + 1)	A3-88	X			