

DOE/CH/10407--T1


RECEIVED

MAY 22 1997

OSTI

**Summary, Biomass Gasifier Facility Start-Up Tests —
October and December 1995**

February 1996



MASTER

HAWAII NATURAL ENERGY INSTITUTE

School of Ocean and Earth Science and Technology

University of Hawaii at Manoa

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

h

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, make any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

**Summary, Biomass Gasifier Facility Start-Up Tests —
October and December 1995**

by

**Scott Q. Turn
Darren M. Ishimura
Charles M. Kinoshita
Stephen M. Masutani**

Hawaii Natural Energy Institute
University of Hawaii

Prepared for

The Pacific International Center for High Technology Research

February 1996



Hawaii Natural Energy Institute
School of Ocean and Earth Science and Technology
University of Hawaii at Manoa

Contents

	<u>Page</u>
Executive Summary.....	i
Introduction	1
Methods	1
Results.....	4
Summary and Conclusions	10
Appendix A. Sample Analytical Reports	
Appendix B. Mass Balance Spreadsheet -- Raw Data	
Appendix C. Mass Balance Spreadsheet -- IGT Adjustment	
Appendix D. Mass Balance Spreadsheet -- HNEI Adjustment	

Executive Summary

Shakedown testing of the biomass gasifier facility, located at the Hawaiian Commercial and Sugar Co. factory in Paia on the island of Maui, utilizing sugarcane bagasse, occurred in October 1995. Input and output streams for the process were sampled during three periods of steady-state operation in an air-blown mode. Additional tests were carried out in early December, 1995. Air and a mixture of air and steam were utilized as the fluidizing agent in the December operations, with two sampling periods occurring during air gasification and a single period under air-steam-blown conditions. This summary reports average values for the October test period, the December air-blown tests and the December air-steam tests (see following table). Details of individual tests are presented in the body of this report.

During the October sampling periods, the average reactor temperature and pressure were 1545°F (840°C) and 43 psi (300 kPa), respectively. Bagasse from the sugar factory entered the dryer at a nominal moisture content of 45% and exited at 26%, wet basis. Wet fuel feed rate to the reactor averaged 1.2 ton hr⁻¹ (1.1 tonne hr⁻¹). Average gas composition determined over the sample periods was 4% H₂, 10% CO, 18% CO₂, 3% CH₄, 1% C₂'s and higher hydrocarbons, and the balance N₂. The higher heating value of the gas was 100 Btu ft⁻³ (3.7 MJ m⁻³). Condensable hydrocarbons (C₆ and higher) in the output stream averaged 2.3% of dry fuel feed with benzene (C₆H₆) and naphthalene (C₁₀H₈) being the principal constituents. Carbon conversion efficiency, defined as the percentage of fuel carbon converted into gas or liquids, was estimated to be ~96%.

In December, the reactor was operated in air blown mode with increased wet bagasse feed rate and reactor pressure, 1.9 ton hr⁻¹ (1.7 tonne hr⁻¹) and 61 psi (420 kPa), respectively. Fuel moisture content was roughly 30%. These conditions resulted in improved gas quality with average composition determined as 5% H₂, 12% CO, 19% CO₂, 4% CH₄, 1% C₂'s and higher hydrocarbons, and the balance N₂, with a higher heating value of 121 Btu ft⁻³ (4.5 MJ m⁻³). Condensable hydrocarbons were reduced to 1.3% of dry fuel mass. Carbon conversion efficiency improved to 98%, 2% higher than the tests performed in October.

Near the end of the operational period in December, gasification with air and steam was carried out at a reactor temperature and pressure of 1575°F (860°C) and 73 psi (500 kPa). Wet fuel feed rate was 1.7 ton hr⁻¹ (1.6 tonne hr⁻¹), with a reduced moisture content of 17%. These conditions and the added steam resulted in improved gas quality and increased heating value. Composition was determined as 8% H₂, 12% CO, 18% CO₂, 7% CH₄, 1% C₂'s and higher hydrocarbons, and the balance N₂, with a higher heating value of 156 Btu ft⁻³ (5.8 MJ m⁻³). Carbon conversion efficiency was similar to the earlier runs.

Summary of BGF Test Results.

	October (air)	December (air)	December (air/steam)
Temperature (°F)	1545	1535	1575
Pressure (psi)	43	61	73
Feed-rate (lb/h, wet basis)	2310	3779	3441
Feed moisture content (%)	26	31	17
Dry gas composition (volume %)			
H ₂	4.4	5	8.5
CO	9.9	12	12.1
CO ₂	18.3	18.8	18
CH ₄	3.3	4.3	6.9
C ₂ 's	0.5	0.8	0.7
C ₃ +'s	0.3	0.3	0
O ₂	0	0	0
N ₂	62.5	58.6	49.2
H ₂ S	0	0	0
Heating value (Btu/ft ³ , dry)	100	121	156


Introduction

A primary objective of the biomass gasifier facility (BGF) test program is to obtain technical information on a near-commercial scale biomass gasification system that can be used in projecting the performance of commercial systems under actual operating conditions, formulating and assessing control strategies for commercial gasification systems and identifying optimal operating conditions for electric power generation or for methanol production. Mass and energy balances are two of the technical bases by which the performance of thermochemical conversion processes such as gasification is assessed. The data necessary to perform mass and energy balances on a process are obtained by identifying and quantifying individual input and output streams. To obtain this information, input/output sampling was performed at the BGF during three periods of steady state operation during the shake-down test, which took place October 2 to 9, 1995. Follow-on testing occurred on December 4 through 9, 1995, during which time input/output samples were collected in three steady state periods. This report summarizes the measurements and analyses performed for the six sampling periods and the resulting mass and energy balances.

Methods

The data required to perform mass and energy balances were obtained by measuring input and output streams as shown in Figure 1. Bagasse feedrate into the reactor, steam and air input flowrates and gasifier temperatures and pressure were obtained from the WEStation Data Historian for each of the sample periods. Raw and dried bagasse moisture contents were determined from grab samples taken off the reclaim conveyor and weigh-belt, respectively. In addition, proximate and ultimate analyses and heating values were determined for the samples obtained from the weigh-belt. Ash fusion temperature and inorganic elemental composition were determined for selected weigh-belt samples from the October tests. Char removed from the process stream by the hot gas cyclone was collected and weighed for each sampling period. This char stream was subsampled and subjected to ultimate analysis. A 0.375" diameter probe was installed in the 6" diameter, refractory-lined pipe at the outlet of the hot gas cyclone to extract samples of the process stream. The sample stream was sequentially separated into solid, condensable and gas fractions using the conditioning system shown in Figure 2. Solids were removed in the heated filters. The sample stream was maintained at a temperature of 800 to 900°F prior to this point in order to maintain the condensable species in the vapor phase. After filtration, the sample stream temperature was reduced in two heat exchangers, the first using cold water, the second, cooled to ~32°F using a mechanical refrigeration unit. Resulting condensate was collected in drainpots and removed. The cooled gas passed through a coalescing filter to remove liquid aerosol and then through a pressure reducing valve, resulting in a dry stream at 15 psig. Gas was sampled and analyzed every 28 minutes by an on-line gas chromatograph (GC) utilizing dual thermal conductivity detectors (TCD) and a flame ionization detector (FID). Gas samples were also withdrawn in bombs in the interval between on-line sampling events, allowing for later off-line analyses. A mass flow meter was used to adjust the flow rate through the system, permitting the sample stream to be isokinetically withdrawn at the probe. Finally, the total flow through the sampling system over a given time period was determined by passing the entire flow through a dry test meter.

Although the sampling system was designed to isokinetically extract ~0.4 % of the total product gas flow, isokinetic conditions were never achieved due to restrictive, undersized filters. Sub-isokinetic flow at the probe inlet results in a sample of entrained char and particulate which is not representative of the distribution of particles present in the process stream. Gas and condensate which are separated from the sample stream in the gas conditioning unit are, however, representative of the total product flow.



Legend

<u>Location</u>	<u>Stream</u>	<u>Measurements or Samples Collected</u>
1	Raw bagasse	Grab samples for moisture content determination
2	Dried bagasse	Feed rate; grab samples for bagasse analysis
3	Input air	Flow rate
4	Input steam	Flow rate
5	Raw gas	Averaged temperature, pressure
6	Raw gas	Temperature for determination of hot-gas efficiency
7	Char	Discharge rate; representative samples for char analysis
8	Cleaned gas	Isokinetic sampling for determination of entrained solids, condensables, and gas rates and compositions

Figure 1. Summary of Process Sampling and Sample Locations for BGF.




Figure 2. Sample Extraction and Conditioning System.

At the conclusion of a sampling period, filtered solids were removed, weighed and subjected to proximate analysis. The condenser section of the sample system was flushed to remove any remaining liquids. Gross condensate was separated into aqueous and tar/oil components using CH_2Cl_2 , and each fraction quantified. The aqueous fraction was analyzed for chloride, nitrogen, sulfate, sodium and potassium. Subsamples of the tars and oils dissolved in CH_2Cl_2 were quantified by gas chromatography using a flame ionization detector. Utilizing the disparate boiling point of CH_2Cl_2 compared to the tars and oils in solution, the remainder of the condensate sample was separated. The resulting concentrated tar and oil sample was analyzed for heating value and the elements C, H, O, N, S and Cl.

Results

Material and energy balances for the BGF were performed using data collected during six sampling periods, three each from the October and December 1995 tests. Note that condensate and entrained char samples were not collected during the final sampling period of the December tests (SP-3 – 12/7/95) due to plugging of the sample probe. Bagasse feed rate, air and steam flow rates, fuel moisture content, cyclone char quantity, and gas composition were measured during the period and are reported as such. Results of the material and energy balances are discussed in the following sections and are provided in the attached summary tables and appendices.

Measured input and output parameters and calculated quantities are summarized in Table 1 (Raw Data -- Unadjusted). Data obtained from the WEStation Data Historian for the six sample periods were used to compute an average value and coefficient of variation for each of the measured quantities. Values calculated from measured quantities, with the exception of equivalence ratio and carbon conversion efficiency, were determined using a material balance spreadsheet provided by IGT. Carbon conversion efficiency was determined using only bagasse feed rate, cyclone char quantity, and their respective ultimate analyses. Analytical results for the aforementioned process streams, as well as for entrained char, aqueous condensate, tar/oil in CH_2Cl_2 and rotovaped tars (tars separated from the CH_2Cl_2) are provided in Appendix A.

The coefficients of variation (CV) for the measured quantities are indicative of the degree to which steady state conditions were maintained over the sampling period. The CV's for reactor temperatures and air flow rates were generally less than 4%. Bagasse feed rate and gasifier pressure CV's were higher, ranging between 4 and 10%, with a single sample period, the initial period during the October tests, exhibiting a larger CV for bagasse feed rate of 14%.

A trend of improving gas quality is evident over the course of the successive sampling periods. Higher heating value of the product gas (dry, condensate-free) increases from 85 to 155 Btu scf^{-1} due largely to the increasing H_2 , CO and CH_4 , and reduced N_2 levels.

Balances for the elements C, H, O, N and S and the inorganic ash fraction of the feedstock are summarized in Table 1. Tables used to compute these values are shown in Appendix B. The ability to balance elemental inputs and outputs is directly affected by the absolute amount of each element in the system at any given time, i.e., an element which comprises 50% of the mass in the system is generally easier to quantify than one present at levels below 0.1%, particularly when some material flows are sampled on a discrete rather than continuous basis. For the sampling periods in Table 1, the total mass in the system at any given time is comprised of 35-55% N, 30-40% O, 10-20% C, 2-4% H, 1-2% ash and less than 0.05% S. Nitrogen balances of 100% for all sample periods are a direct result of using the nitrogen contents of the input air stream (78% by volume) and product gas (determined by GC analysis) to compute the product gas flow rate. In effect, this forces N to balance.

Table 1. Raw Data -- Unadjusted.

Test Date Sampling Period	10/6/95	10/7/95	10/8/95	12/6/95	12/7/95	12/7/95	Comments
	SP-3	SP-4	SP-5	SP-1	SP-2	SP-3	
Period Duration, h	0.65	0.70	1.18	1.20	1.12	1.00	
Temperature, °F [CV]	1543 [2%]	1548 [2%]	1543 [2%]	1459 [2%]	1612 [2%]	1575 [2%]	1
Pressure, psi [CV]	41 [13%]	41 [7%]	46 [6%]	35 [10%]	86 [12%]	73 [8%]	1
Bagasse Feedrate (wet), lb/h [CV]	2242 [14%]	2227 [9%]	2460 [6%]	3390 [4%]	4167 [10%]	3441 [5%]	1
Moisture Content, %	25.4	19.5	33.75	31.62	31.33	16.85	
Bagasse Feedrate (dry), lb/h	1673	1793	1630	2318	2861	2861	
Bagasse Composition (dry), wt%							
Carbon	48.27	48.09	48.21	48.75	47.81	47.66	
Hydrogen	5.68	5.67	5.60	5.79	5.67	5.66	
Oxygen	42.33	42.16	42.56	41.64	41.55	41.61	
Nitrogen	0.15	0.14	0.12	0.22	0.27	0.21	
Sulfur	0.12	0.07	0.05	0.03	0.04	0.03	
Ash	3.46	3.89	3.47	3.57	4.66	4.83	
Air to Gasifier Port, scfm [CV]	531 [0%]	457 [3%]	486 [0%]	497 [0%]	513 [4%]	394 [8%]	1
Air to Steam Sparge, scfm [CV]	330 [2%]	378 [1%]	381 [1%]	200	200	0	1,2
Air to Preheater, scfm	200	105	155	0	0	0	
Total Air, scfm	1061	940	1022	697	713	394	
Steam to Steam Sparge, scfm	0	0	0	0	0	200	2
Cyclone Char (dry), lb	68	97	139	108	81	108	
Cyclone Char (dry), lb/h	105	139	117	90	73	108	
Entrained Char (dry), lb/h	8.45	2.16	2.36	1.69	6.06	0	3
Aqueous Condensate, lb/h	1068	810	1295	890	826	0	3
Product Gas (dry), lb/h	6233	5506	6443	4500	4492	2721	
Avg. Gas Comp., vol %							
H ₂	3.83	4.49	4.99	4.28	5.77	8.46	
CO ₂	19.35	18.29	17.30	18.25	19.29	17.99	
C ₂ H ₄	0.44	0.36	0.75	1.17	0.22	0.55	
C ₂ H ₆	0.00	0.01	0.04	0.11	0.02	0.19	
O ₂ /Ar	0.00	0.00	0.00	0.00	0.00	0.00	
N ₂	65.35	64.41	57.87	58.32	58.96	49.20	
CH ₄	2.70	2.98	4.13	4.14	4.39	6.94	
CO	8.33	8.98	12.47	13.51	10.45	12.11	
C ₃ H ₈	0.00	0.00	0.00	0.00	0.00	0.00	
C ₃ H ₆	0.00	0.00	0.00	0.01	0.00	0.00	
C ₆ H ₆	0.29	0.29	0.30	0.24	0.30	0.00	
H ₂ S	0.00	0.00	0.00	0.00	0.00	0.00	
Total	100.29	99.81	97.85	100.03	99.40	95.44	
Equivalence Ratio	0.51	0.43	0.51	0.24	0.19	0.11	
Mass Balances, %							
Carbon	112	94	136	69	49	37	
Hydrogen	107	93	119	59	49	20	
Oxygen	110	100	116	77	66	35	
Nitrogen	100	100	100	100	100	100	
Sulfur	4.8	7.0	8.9	8.2	3.2	2.5	
Ash	129	142	157	74	38	53	
Gas Heating Value, Btu/scf (dry)	85.1	91.1	124.8	129	112.7	155.5	
Gas Yield, scf(dry)/lb feed (dry)	47.2	39.4	51.4	25.0	19.0	12.9	
Carbon Conv. to Gas & Liq., %	108	89.5	132	66.4	47.7	34.7	4
Carbon Conv. Efficiency, %	96.3	95.4	96.3	97.7	98.7	97.4	5

1. Sampling Period Average [Coefficient of Variation]
2. Estimated for December Tests; transmitter at steam sparge ring not operational
3. December SP-3 sample not collected due to plugged sample probe
4. Based on actual measurements
5. Calculated as 100*(Input carbon - Lockhopper carbon)/Input carbon

Carbon, hydrogen, oxygen and ash balances for the October operations generally exceed 100%. The opposite is true for the December sampling periods, where inputs of all elements are consistently in excess of those found in the output. During the December tests, the differential pressure transmitter across the orifice meter in the line to the steam sparge was not functioning. As such, December flow rates for "air to steam sparge" (first two sampling periods) and "steam to steam sparge" (third sampling period) shown in Table 1 were estimated by on-site operations engineers. Another possible explanation for the consistent reversal in the bias of the element balances between the tests in October and those in December is the recalibration of the bagasse weigh belt which occurred during the interim period. The dubious nature of the air or bagasse flow rate measurements in December is supported by equivalence ratio calculations, also shown in the table. The higher bagasse feed rates (compared to October tests), observed reactor temperatures, and corresponding equivalence ratios suggest that the total input air flow rates are too low. It is unlikely that temperatures measured in the gasifier could be attained or maintained at equivalence ratios below 0.25. To investigate potential causes of the poor elemental balances, two adjustment procedures were performed.

The first adjustment procedure was a method prescribed by IGT. Quantities affected by the adjustment and their relative differences compared to the raw data are summarized in Table 2 (Adjusted Data -- IGT Adjustment Procedure). Selected pages from IGT's spreadsheet are included in Appendix C (Mass Balance Spreadsheet -- IGT Adjustment). The procedure employs input and output stream adjustment factors to force elemental balances. More specifically, ash was forced to balance by applying a multiplication factor to adjust the amount of cyclone char collected. A carbon balance was induced by employing a multiplication factor to adjust the input air flow. A sulfur balance was forced by using a multiplication factor to compensate for the loss of H₂S in the aqueous condensate. Similarly, nitrogen was balanced by introducing a multiplication factor to compensate for the loss of NH₃ in the aqueous condensate. The final step of the IGT procedure was to balance hydrogen by adding water to the condensate in the required amount. No direct adjustment procedure was used to force an oxygen balance.

By the nature of the method, results from the IGT adjustment procedure, shown in Table 2, yielded complete closure of elemental balances with the exception of oxygen. According to the adjusted data, char collected from the cyclone exceeded the amount required for complete ash closure by up to 36% during the October campaign. Also, input air flow may have been inaccurately measured by up to 26%. Percent differences between adjusted and raw quantities for the December tests indicate that both cyclone char and input air flow may have been underestimated. Based on the adjusted data, plausible equivalence ratios (ranging from 0.31 to 0.38) were calculated for the December tests.

In a second effort to reconcile the material balances, a "single number adjustment" was sought based on the perceived uncertainties associated with the measured input and output streams. Input air flow rate was identified as being the measurement instilling the least amount of confidence, particularly during the December tests. Based on bagasse ultimate analysis, product gas analysis and stoichiometry, a single correction factor was calculated for the total input air flow which balanced nitrogen and equated fuel carbon with product gas carbon. Results of this adjustment procedure are summarized in Table 3 (Adjusted Data -- HNEI Adjustment Procedure). Selected pages from the same material balance spreadsheet used for the raw data calculations but utilizing the adjusted input air flow rate are provided in Appendix D (Mass Balance Spreadsheet -- HNEI Adjustment). All other input and output streams were assumed to be measured accurately during the tests.

Table 3 summarizes the changes produced by the single air flow adjustment on affected quantities; entrained char, product gas flow rate and aqueous condensate. Each scales directly with air flow rate via the nitrogen balance, and as a result all are changed by the same percentage. Differences in

Table 2. Adjusted Data -- IGT Adjustment Procedure.

Date	10/6/95	10/7/95	10/8/95	12/6/95	12/7/95	12/7/95	
Sampling Period	SP-3	SP-4	SP-5	SP-1	SP-2	SP-3	Comments
Cyclone Char (Raw), lb/h	105	139	117	90	73	108	
Cyclone Char (Adj.), lb/h	81	98	75	121	191	204	
Adjustment Factor	0.774	0.705	0.636	1.352	2.630	1.892	6
% Diff. (Adj. vs. Raw), %	-23	-30	-36	35	163	89	
Entrained Char (Raw), lb/h	8.45	2.16	2.36	1.69	6.06	0	
Entrained Char (Adj.), lb/h	7.57	2.33	1.74	2.47	12.19	0	7
% Diff. (Adj. vs. Raw), %	-10	8	-26	46	101	—	8
Total Input Air (Raw), scfm	1061	940	1022	697	713	394	
Total Input Air (Adj.), scfm	951	1013	752	1016	1433	1080	
Adjustment Factor	0.896	1.078	0.736	1.457	2.010	2.740	9
% Diff. (Adj. vs. Raw), %	-10	8	-26	46	101	174	
Product Gas (Raw), lb/h	6233	5506	6443	4500	4492	2721	
Product Gas (Adj.), lb/h	5584	5936	4742	6556	9028	7455	7
% Diff. (Adj. vs. Raw), %	-10	8	-26	46	101	174	
Aqueous Condensate (Raw), lb/h	1068	810	1295	890	826	0	
Aqueous Condensate (Adj.), lb/h	1078	882	1342	1890	1786	1895	
Adjustment Factor	4.60	0.32	27.20	42.00	8.10	112.30	10
% Diff. (Adj. vs. Raw), %	1	9	4	112	116	—	8
Equivalence Ratio (Raw)	0.51	0.43	0.51	0.24	0.19	0.11	
Equivalence Ratio (Adj.)	0.46	0.46	0.38	0.35	0.38	0.31	
% Diff. (Adj. vs. Raw), %	-10	7	-25	46	100	182	
Mass Balances (Raw), %							
Carbon	112	94	136	69	49	37	
Hydrogen	107	93	119	59	49	20	
Oxygen	110	100	116	77	66	35	
Nitrogen	100	100	100	100	100	100	
Sulfur	4.8	7.0	8.9	8.2	3.2	2.5	
Ash	129	142	157	74	38	53	
Mass Balances (Adj.), %							
Carbon	100	100	100	100	100	100	
Hydrogen	100	100	100	100	100	100	
Oxygen	109	104	113	119	109	133	
Nitrogen	100	100	100	100	100	100	11
Sulfur	100	100	100	100	100	4.8	8,12
Ash	100	100	100	100	100	100	
Gas Yield, scf (dry)/lb feed (dry)	42.3	42.4	37.8	36.4	38.1	35.5	
Carbon Conv. to Gas & Liq., %	96.3	96.5	97.5	96.8	95.9	95.1	
Carbon Conv. Eff. (Raw), %	96.3	95.4	96.3	97.7	98.7	97.4	
Carbon Conv. Eff. (Adj.), %	97.1	96.7	97.6	96.9	96.6	95.1	
% Diff. (Adj. vs. Raw), %	-0.9	-1.4	-1.4	0.8	2.1	2.4	

6. Multiplication factor used to adjust Cyclone Char (forces Ash to balance)
7. Affected by Input Air adjustment
8. December SP-3 not adjustable (sample not collected due to plugged sample probe)
9. Multiplication factor used to adjust Input Air (forces Carbon to balance)
10. Additive term adds or subtracts pounds of hydrogen to adjust water in condensate (forces Hydrogen to balance)
11. Nitrogen forced to balance; multiplication factor used to compensate for the loss of ammonia in aqueous condensate
12. Sulfur forced to balance; multiplication factor used to compensate for the loss of H₂S in aqueous condensate

Table 3. Adjusted Data -- HNEI Adjustment Procedure.

Date	10/6/95	10/7/95	10/8/95	12/6/95	12/7/95	12/7/95	
Sampling Period	SP-3	SP-4	SP-5	SP-1	SP-2	SP-3	Comments
Input Air Adjustment Factor	1.00	1.21	0.78	1.55	2.19	2.99	17
Entrained Char (Raw), lb/h	8.45	2.16	2.36	1.69	6.06	0	
Entrained Char (Adj.), lb/h	8.45	2.62	1.87	2.63	13.28	0	13
% Diff. (Adj. vs. Raw), %	0	21	-21	56	119	—	14
Total Input Air (Raw), scfm	1061	940	1022	697	713	394	
Total Input Air (Adj.), scfm	1061	1137	807	1080	1561	1178	15
% Diff. (Adj. vs. Raw), %	0	21	-21	55	119	199	
Product Gas (Raw), lb/h	6233	5506	6443	4500	4492	2721	
Product Gas (Adj.), lb/h	6233	6662	5090	6975	9837	8136	13
% Diff. (Adj. vs. Raw), %	0	21	-21	55	119	199	
Aqueous Condensate (Raw), lb/h	1068	810	1295	890	826	0	
Aqueous Condensate (Adj.), lb/h	1068	980	1023	1380	1808	0	13
% Diff. (Adj. vs. Raw), %	0	21	-21	55	119	—	14
Equivalence Ratio (Raw)	0.51	0.43	0.51	0.24	0.19	0.11	
Equivalence Ratio (Adj.)	0.51	0.51	0.40	0.37	0.41	0.34	16
% Diff. (Adj. vs. Raw), %	0	19	-22	54	116	209	
Mass Balances (Raw), %							
Carbon	112	94	136	69	49	37	
Hydrogen	107	93	119	59	49	20	
Oxygen	110	100	116	77	66	35	
Nitrogen	100	100	100	100	100	100	
Sulfur	4.8	7.0	8.9	8.2	3.2	2.5	
Ash	129	142	157	74	38	53	
Mass Balances (Adj.), %							
Carbon	112	113	109	105	107	106	
Hydrogen	107	112	94	92	106	60	
Oxygen	110	110	101	104	112	77	
Nitrogen	100	100	100	100	100	100	
Sulfur	4.8	8.1	7.3	11	5.5	2.5	
Ash	129	142	157	74	38	53	
Gas Yield, scf (dry)/lb feed (dry)	47.2	47.6	40.6	38.7	41.5	38.7	
Carbon Conv. to Gas & Liq., %	96.3	108.3	104.6	103.0	104.5	103.8	

13. Affected by Input Air adjustment
14. December SP-3 not adjustable (sample not collected due to plugged sample probe)
15. Total Input Air adjusted by using adjusted Equivalence Ratio
16. Equivalence Ratio adjustment based on stoichiometry and nitrogen and carbon balances
17. Ratio of Adjusted Equivalence Ratio and Raw Equivalence Ratio; i.e., ER(Adj.)/ER(Raw)

these quantities are less than ~22% for the October tests. Substantially larger differences in these quantities for the December tests suggest that air flow was indeed underestimated. Elemental balances for all sampling periods generally improved with the application of the single adjustment factor, the exception being the second sampling period in the October tests.

Energy balances around the reactor for the six sampling periods were performed to yield cold and hot gas thermal efficiencies. Efficiencies on a N₂-free, dry basis are included in Table 4 (Energy Balance Results). Cold gas thermal efficiency is defined as the chemical energy of the product gas divided by the chemical energy of the bagasse. Hot gas thermal efficiency includes the sensible enthalpy component of the product gas, with the temperature of the product stream taken at the exit of the gasifier (Nozzle 21). Although the temperature at the exit of the hot gas cyclone where the product gas was sampled would have been the most appropriate for use in this calculation, the exit of the gasifier was the closest temperature measurement which was recorded on the WEStation Data Historian. Cold and hot gas efficiencies calculated using the raw unadjusted data ranged from 25 to 85%. The IGT adjustment procedure resulted in hot and cold gas efficiencies ranging from 45 to 77%, whereas the HNEI adjustment methodology produced a range from 50 to 85%. Because IGT's method forces closure on all balances except oxygen, efficiencies computed using the resulting inputs and outputs are in keeping with laws of energy conservation.

Limited comparison of the results presented above with those obtained from bagasse fueled tests performed using the RENUGAS[®] process development unit (PDU) at IGT has been undertaken due to obvious differences in operating conditions. IGT test reports for bagasse are at elevated pressure (~300 psig) and with steam and oxygen input flows preheated in excess of 700°F. Gas composition comparisons are only valid on a dry, N₂-free basis due to IGT's individual metering of fluidizing gases. Averaged BGF results and data reported as part of the test program conducted by IGT to provide engineering design information for the BGF are shown in Table 5. The data for the December air/steam sampling period for the BGF compares well with the data from the PDU tests. Major gas components differ by less than 3% (absolute) and higher heating values by ~10% (absolute).

Table 4. Energy Balance Results.

Date Sampling Period	10/6/95	10/7/95	10/8/95	12/6/95	12/7/95	12/7/95	Comments
	SP-3	SP-4	SP-5	SP-1	SP-2	SP-3	
Raw Data							
Cold Gas Thermal Efficiency, %	50.4	43.0	76.9	40.3	27.2	25.5	18
Hot Gas Thermal Efficiency, %	58.2	49.2	85.9	44.7	30.9	28.2	18,19
IGT Adjustment							
Cold Gas Thermal Efficiency, %	45.1	46.3	56.6	58.7	54.7	69.9	18
% Diff. (Adj. vs. Raw), %	-11	8	-26	46	101	174	
Hot Gas Thermal Efficiency, %	52.2	53.0	63.2	65.2	62.1	77.4	18,19
% Diff. (Adj. vs. Raw), %	-10	8	-26	46	101	174	
HNEI Adjustment							
Cold Gas Thermal Efficiency, %	50.4	51.1	60.7	62.4	59.6	76.3	18
% Diff. (Adj. vs. Raw), %	0	19	-21	55	119	199	
Hot Gas Thermal Efficiency, %	58.2	58.5	67.9	69.3	67.6	84.4	18,19
% Diff. (Adj. vs. Raw), %	0	19	-21	55	119	199	

18. N₂ free, dry basis

19. Temperature of product gas measured by thermocouple located at gasifier exit (Nozzle 21)

Table 5. Comparison of BGF and PDU Test Results.

	BGF October (air)	BGF December (air)	BGF December (air/steam)	IGT PDU* 1992 March (O ₂ /N ₂ /steam)
Temperature (°F)	1545	1535	1575	1568
Pressure (psig)	43	61	73	310
Feed-rate (lb/h, wet basis)	2310	3779	3441	560
Feed moisture content (%)	26	31	17	18
Gas Composition, dry, N ₂ -free basis (volume %)				
H ₂	12.0	12.1	18.4	18.1
CO	27.0	29.1	26.2	26.1
CO ₂	49.9	45.6	39.0	37.6
CH ₄	9.0	10.4	14.9	17.3
C ₂ 's	1.4	1.9	1.5	0.5
C ₃ + 's	0.8	0.7	0.0	0.3
Heating value (Btu/ft ³ , dry, N ₂ free)	267	292	307	338

* Source: Carty, R.H., M. Onischak, J. Gissy. 1992. "Biomass gasifier scale-up demonstration facility: Progress Report for the Period 2/28/92 through 5/27/92." pp. 24-25. Work performed for PICHTR by IGT. Contract No. DE-FC02-91CH10407.

Summary and Conclusions

Testing at the BGF occurred over two periods in October and December of 1995. Complete sampling of the process's input and output streams was conducted for three steady state periods of air-blown operation during the October tests with two additional sampling periods obtained in the December effort. Near the conclusion of the December test, during a period of air-steam gasification, a sixth sampling period was used to collect input/output information on all but the condensate and entrained char streams.

Information concerning input quantities, with the exception of bagasse moisture content, was obtained from the WEStation Data Historian. Gas, condensable species and entrained char samples were extracted from the process flow using an isokinetic sampling system and gas conditioning unit. Char removed by the hot gas cyclone was quantified gravimetrically.

In general, gas quality improved over successive sampling periods -- higher heating values increased from 85 to 155 Btu scf⁻¹. Hydrogen, carbon monoxide and methane levels increased and diluent nitrogen levels were reduced. Interpretation of the data beyond the gas analyses is hampered by poor closure of elemental balances for the raw data collected during the sampling periods, particularly those in December which result primarily from inaccurate or unavailable air and steam input flowrates and possibly from erroneous values for bagasse feedrates to the reactor. These deficiencies should be addressed before additional testing is attempted. Furthermore, the isokinetic sampling/sample conditioning system should be modified to permit adequate flowrates to be attained at the sample probe inlet.

Two methods for varying input/output streams to the process were pursued in order to gain better elemental closures. The first, IGT's procedure, utilized five factors to sequentially adjust cyclone char weight, input air flowrate, aqueous condensate H_2S and NH_3 levels, and mass of aqueous condensate weight. By design, this method assures closure of all elemental balances except oxygen.

HNEI devised an alternative, single factor adjustment to arrive at a more plausible input air flow rate since the measurement of this quantity was deemed to have the greatest error. The adjustment resulted in elemental closure to within 13% for the major constituents present in the system, C, H, O and N.

Appendix A
Sample Analytical Reports

BGF Sample List — October Tests

No.	Samp. Per.	Sample	Date	Time	Comments	Analysis	Lab.	I.D.	Date Sent	Total	Sent	Kept
1	—	bagasse	10/6/95	400	dried	—	—	—	—	69.0	0.0	69.0
2	SP3	bagasse	10/6/95	2200	MC=26.3%; tare=9.55	Ult; Prox; Btu; Fus. temp & comp*	1	2-SP3	10/24/95	74.6	26.4	48.2
3	SP3	bagasse	10/6/95	2240	MC=24.5%	Ult; Prox; Btu	1	3-SP3	10/24/95	76.2	26.9	49.3
4	SP4	bagasse	10/7/95	1445	MC=23%	Ult; Prox; Btu; Fus. temp & comp*	1	4-SP4	10/24/95	117.6	45.6	72.0
5	SP4	bagasse	10/7/95	1542	MC=16%	Ult; Prox; Btu	1	5-SP4	10/24/95	89.3	34.6	54.7
6	SP5	bagasse	10/8/95	130	MC=33%; dried	Ult; Prox; Btu; Fus. temp & comp*	1	6-SP5	10/24/95	65.2	18.9	46.3
7	SP5	bagasse	10/8/95	200	MC=34.5%; dried	Ult; Prox; Btu	1	7-SP5	10/24/95	66.9	26.6	40.4
8	SP3	char; ash lockhop.	10/6/95	2215-2254	2305; 68 lb dump; SJW	Ultimate analysis	1	8-SP3	10/24,13	246.3	18.0	228.2
9	SP4	char; ash lockhop.	10/7/95	1430	steady state; tare=113.95	Ultimate analysis	1	9-SP4	10/24,13	297.1	15.1	282.0
10	SP5	char; ash lockhop.	10/8/95	0134-0245	cylone fines	Ultimate analysis	1	10-SP5	10/24,13	375.4	17.8	357.7
11	SP3	char; isokin. S.S.	10/6/95	2215-2254	tare=27.0	Proximate analysis	1	11-SP3	10/24/95	2.2	2.2	0.0
12	SP4	char; isokin. S.S.	10/7/95	1445	gross=27.6; tare=26.7	Proximate analysis	1	12-SP4	10/24/95	0.9	0.9	0.0
13	SP5	char; isokin. S.S.	10/8/95	0134-0245	gross=27.5; tare=26.5	Proximate analysis	1	13-SP5	10/24/95	1.0	1.0	0.0
14	SP3	aqueous condensate	10/6/95		tare=26.4	N, S, Cl, Na, K	1	14-SP3	10/24/95	35.7	20.3	15.4
15	SP4	aqueous condensate	10/7/95		tare=26.4	N, S, Cl, Na, K	1	15-SP4	10/24/95	35.7	21.0	14.7
16	SP5	aqueous condensate	10/8/95			N, S, Cl, Na, K	1	16-SP5	10/24/95	28.0	19.9	8.1
17	SP3	tars/oils in MeCl2	10/6/95		tare=26.0	Composition (GC/FID)	2	17-SP3	—	49.7	0.0	49.7
18	SP4	tars/oils in MeCl2	10/7/95		tare=26.0	Composition (GC/FID)	2	18-SP4	—	46.0	0.0	46.0
19	SP5	tars/oils in MeCl2	10/8/95			Composition (GC/FID)	2	19-SP5	—	47.3	0.0	47.3
20	SP3	rotovaped tars/oils	10/6/95		tare=26.3	Ultimate; Btu; Cl; comp.(GC/FID)	1,2	20-SP3	10/24/95	14.4	7.2	7.1
21	SP4	rotovaped tars/oils	10/7/95		tare=26.6	Ultimate; Btu; Cl; comp.(GC/FID)	1,2	21-SP4	10/24/95	17.8	9.9	8.0
22	SP5	rotovaped tars/oils	10/8/95		tare=26.9	Ultimate; Btu; Cl; comp.(GC/FID)	1,2	22-SP5	10/24/95	14.2	7.5	6.7
26	All	deposits from flare	10/10/95	—		Elemental analysis of ash	1	26-SPA	10/24/95	—	—	—

* fusion temperature and elemental analysis of ash; I.D.'s are 2-3-SP3, 4-5-SP4, and 6-7-SP5

SP3: 10/6/95 (22:15 to 22:54)

SP4: 10/7/95 (14:50 to 15:32)

SP5: 10/8/95 (1:34 to 2:45)

Lab 1 — Hazen

Lab 2 — HNEI

Tars/Oils Analysis (GC/FID) — October Tests

Sample ID Compound Name	MeCl2 Wash			Rotovaped Tars		
	17-SP3 mg/ml	18-SP4 mg/ml	19-SP5 mg/ml	20-SP3 mg/g	21-SP4 mg/g	22-SP5 mg/g
Benzene, C6H6	0.390	0.482	0.445	127.27	28.23	8.09
Toluene, C7H8	0	0	0	0	0	0
Styrene, C8H8	0	0	0	0	0	0
Xylene, C8H10	0	0	0	0	0	0
Phenol, C6H6O	0	0	0	0	0	0
a-Methylstyrene, C9H10	0	0	0	0	0	0
Benzofuran, C8H6O	0	0	0	0	0	0
Indene, C9H8	0.063	0.284	0.227	0	0	0
o-Cresol, C7H8O	0	0	0	0	0	0
Naphthalene, C10H8	1.016	2.466	2.182	225.81	218.93	272.96
1-Methylnaphthalene, C11H10	0.011	0.029	0.022	2.34	2.37	2.68
Internal Standard (2-Ethyl-naphthalene)	0.762	0.537	0.551	75.74	69.67	76.94
Acenaphthylene, C12H8	0.288	0.738	0.542	60.32	59.43	66.58
Acenaphthene, C12H10	0.012	0.025	0.023	4.01	2.51	2.97
Fluorene, C13H10	0.057	0.150	0.109	14.24	11.17	13.59
Phenanthrene, C14H10	0.535	1.274	0.866	117.13	77.04	104.26
Anthracene, C14H10	0.087	0.215	0.146	25.33	13.13	17.59
Fluoranthene, C16H10	0.258	0.581	0.365	56.45	32.93	42.77
Pyrene, C16H10	0.255	0.561	0.348	55.57	31.86	41.40
Chrysene, C18H12	0.071	0.118	0.039	18.99	9.73	11.32
Benzo(k)fluoranthene, C20H12	0.039	0.082	0.003	11.88	6.74	8.40
di-Benzoanthracene, C22H14	0.263	0.418	0.000	35.50	0	35.29
Indenopyrene, C22H12	0.000	0.024	0.000	2.80	1.39	1.62

Notes: 1) mg/ml = mg of compound per ml of MeCl2 Wash
 2) mg/g = mg of compound per g of rotovaped tar



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-1
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 2-SP3

Reporting Basis > As. Rec'd Dry Air Dry

Proximate (%)

Moisture	6.69	0.00	3.53
Ash	3.72	3.99	3.85
Volatile	78.52	84.15	81.18
Fixed C	11.07	11.86	11.44
	-----	-----	-----
Total	100.00	100.00	100.00

Sulfur	0.15	0.16	0.15
Btu/lb (HHV)	7381	7911	7631
MMF Btu/lb	7689	8266	
MAF Btu/lb		8240	
Air Dry Loss (%)		3.28	

Ultimate (%)

Moisture	6.69	0.00	3.53
Carbon	44.61	47.81	46.12
Hydrogen	5.27	5.64	5.44
Nitrogen	0.14	0.15	0.14
Sulfur	0.15	0.16	0.15
Ash	3.72	3.99	3.85
Oxygen*	39.42	42.25	40.77
	-----	-----	-----
Total	100.00	100.00	100.00

Chlorine**

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
	-----	-----
Total	0.15	0.16

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 5.04
 Lb. SO₂/MM Btu= 0.39
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Edward H. Cunningham
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na₂O
 K₂O

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-2
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 3-SP3

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	5.69	0.00	2.80
Ash	2.77	2.93	2.85
Volatile	79.71	84.52	82.15
Fixed C	11.83	12.55	12.20
	-----	-----	-----
Total	100.00	100.00	100.00
Sulfur	0.08	0.08	0.08
Btu/lb (HHV)	7566	8022	7797
MMF Btu/lb	7798	8284	
MAF Btu/lb		8264	
Air Dry Loss (%)		2.97	
Ultimate (%)			
Moisture	5.69	0.00	2.80
Carbon	45.96	48.73	47.37
Hydrogen	5.38	5.71	5.55
Nitrogen	0.14	0.14	0.14
Sulfur	0.08	0.08	0.08
Ash	2.77	2.93	2.85
Oxygen*	39.98	42.41	41.21
	-----	-----	-----
Total	100.00	100.00	100.00
Chlorine**			

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
	-----	-----
Total	0.08	0.08

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 3.66
 Lb. SO₂/MM Btu= 0.21
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Edward H. ...
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na₂O
 K₂O

* Oxygen by Difference.

**Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-3
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 4-SP4

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	20.10	0.00	3.81
Ash	4.05	5.06	4.87
Volatile	66.40	83.11	79.94
Fixed C	9.45	11.83	11.38
Total	100.00	100.00	100.00

Sulfur	0.05	0.06	0.06
Btu/lb (HHV)	6333	7927	7625
MMF Btu/lb	6622	8385	
MAF Btu/lb		8349	
Air Dry Loss (%)	16.94		

Ultimate (%)

Moisture	20.10	0.00	3.81
Carbon	38.09	47.68	45.86
Hydrogen	4.50	5.64	5.42
Nitrogen	0.12	0.15	0.14
Sulfur	0.05	0.06	0.06
Ash	4.05	5.06	4.87
Oxygen*	33.09	41.41	39.84
Total	100.00	100.00	100.00
Chlorine**			

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.05	0.06

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 6.39
 Lb. SO2/MM Btu= 0.16
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Edward H. Cunniff
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na2O
 K2O

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-4
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 5-SP4

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	13.96	0.00	3.57
Ash	2.33	2.71	2.61
Volatile	73.75	85.71	82.65
Fixed C	9.96	11.58	11.17
	-----	-----	-----
Total	100.00	100.00	100.00
Sulfur	0.06	0.07	0.07
Btu/lb (HHV)	6936	8061	7773
MMF Btu/lb	7114	8304	
MAF Btu/lb		8285	
Air Dry Loss (%)		10.77	
Ultimate (%)			
Moisture	13.96	0.00	3.57
Carbon	41.73	48.50	46.77
Hydrogen	4.90	5.69	5.49
Nitrogen	0.12	0.13	0.13
Sulfur	0.06	0.07	0.07
Ash	2.33	2.71	2.61
Oxygen*	36.90	42.90	41.36
	-----	-----	-----
Total	100.00	100.00	100.00
Chlorine**			

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
	-----	-----
Total	0.06	0.07

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 3.36
 Lb. SO₂/MM Btu= 0.18
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Guard H. Luning
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na₂O
 K₂O

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-5
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 6-SP5

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	6.55	0.00	3.27
Ash	3.37	3.61	3.49
Volatile	79.18	84.73	81.96
Fixed C	10.90	11.66	11.28
Total	100.00	100.00	100.00

Sulfur	0.04	0.04	0.04
Btu/lb (HHV)	7485	8010	7748
MMF Btu/lb	7768	8335	
MAF Btu/lb		8310	
Air Dry Loss (%)		3.39	

Ultimate (%)

Moisture	6.55	0.00	3.27
Carbon	45.12	48.28	46.70
Hydrogen	5.26	5.63	5.44
Nitrogen	0.12	0.12	0.12
Sulfur	0.04	0.04	0.04
Ash	3.37	3.61	3.49
Oxygen*	39.54	42.32	40.94
Total	100.00	100.00	100.00
Chlorine**			

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.04	0.04

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 4.50
 Lb. SO2/MM Btu= 0.10
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Water Soluble Alkalies (%)

Na2O
 K2O

Gerard H. Conway
 Fuels Laboratory Supervisor

* Oxygen by Difference.
 ** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-6
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 7-SP5

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	6.70	0.00	3.00
Ash	3.11	3.33	3.23
Volatile	79.17	84.86	82.31
Fixed C	11.02	11.81	11.46
Total	100.00	100.00	100.00
Sulfur	0.06	0.06	0.06
Btu/lb (HHV)	7512	8051	7810
MMF Btu/lb	7772	8351	
MAF Btu/lb		8328	
Air Dry Loss (%)		3.81	

Ultimate (%)

Moisture	6.70	0.00	3.00
Carbon	44.91	48.13	46.69
Hydrogen	5.20	5.57	5.40
Nitrogen	0.12	0.12	0.12
Sulfur	0.06	0.06	0.06
Ash	3.11	3.33	3.23
Oxygen*	39.90	42.79	41.50
Total	100.00	100.00	100.00
Chlorine**			

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.06	0.06

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 4.14
 Lb. SO2/MM Btu= 0.15
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

David H. ...
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na2O
 K2O

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-7
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 8-SP3

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	0.73	0.00	0.73
Ash	70.56	71.08	70.56
Volatile			
Fixed C			

Total

Sulfur	0.02	0.02	0.02
Btu/lb (HHV)			
MMF Btu/lb			
MAF Btu/lb			
Air Dry Loss (%)			

Ultimate (%)

Moisture	0.73	0.00	0.73
Carbon	28.60	28.81	28.60
Hydrogen	0.47	0.47	0.47
Nitrogen	0.14	0.14	0.14
Sulfur	0.02	0.02	0.02
Ash	70.56	71.08	70.56
Oxygen*	<0.01	<0.01	<0.01

Chlorine**

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.02	0.02

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO₂/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Gerard H. Curry
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na₂O
 K₂O

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-8
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 9-SP4

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	0.75	0.00	0.75
Ash	70.71	71.24	70.71
Volatile			
Fixed C			
	-----	-----	-----
Total			
Sulfur	0.02	0.02	0.02
Btu/lb (HHV)			
MMF Btu/lb			
MAF Btu/lb			
Air Dry Loss (%)			
Ultimate (%)			
Moisture	0.75	0.00	0.75
Carbon	28.52	28.74	28.52
Hydrogen	0.41	0.41	0.41
Nitrogen	0.13	0.13	0.13
Sulfur	0.02	0.02	0.02
Ash	70.71	71.24	70.71
Oxygen*	<0.01	<0.01	<0.01
	-----	-----	-----

Chlorine**

Forms of Sulfur (as S,%)

Sulfate
 Pyritic
 Organic

Total 0.02 0.02

Water Soluble Alkalies (%)

Na2O
 K2O

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO2/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Edward H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-9
 Date Rec'd. 10/21/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 10-SP5

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	0.66	0.00	0.66
Ash	75.13	75.63	75.13
Volatile			
Fixed C			
	-----	-----	-----
Total			
Sulfur	0.01	0.01	0.01
Btu/lb (HHV)			
MMF Btu/lb			
MAF Btu/lb			
Air Dry Loss (%)			
Ultimate (%)			
Moisture	0.66	0.00	0.66
Carbon	24.61	24.77	24.61
Hydrogen	0.41	0.41	0.41
Nitrogen	0.12	0.12	0.12
Sulfur	0.01	0.01	0.01
Ash	75.13	75.63	75.13
Oxygen*	<0.01	<0.01	<0.01
	-----	-----	-----

Chlorine**

Forms of Sulfur (as S,%)

Sulfate
 Pyritic
 Organic

Total 0.01 0.01

Water Soluble Alkalies (%)

Na2O
 K2O

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO2/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Frank H. Cunniff
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-10
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 11-SP3

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	0.52	0.00	0.52
Ash	3.76	3.78	3.76
Volatile	5.38	5.41	5.38
Fixed C	90.34	90.81	90.34
	-----	-----	-----
Total	100.00	100.00	100.00

Sulfur
 Btu/lb (HHV)
 MMF Btu/lb
 MAF Btu/lb
 Air Dry Loss (%)

Ultimate (%)

Moisture
 Carbon
 Hydrogen
 Nitrogen
 Sulfur
 Ash
 Oxygen*

Total
 Chlorine**

Forms of Sulfur (as S,%)

Sulfate
 Pyritic
 Organic

Total

Water Soluble Alkalies (%)

Na2O
 K2O

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO2/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Edward H. Conroy
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-11
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 12-SP4

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	0.82	0.00	0.82
Ash	7.12	7.18	7.12
Volatile	6.64	6.69	6.64
Fixed C	85.42	86.13	85.42
Total	100.00	100.00	100.00

Sulfur
 Btu/lb (HHV)
 MMF Btu/lb
 MAF Btu/lb
 Air Dry Loss (%)

Ultimate (%)

Moisture
 Carbon
 Hydrogen
 Nitrogen
 Sulfur
 Ash
 Oxygen*

Total
 Chlorine**

Forms of Sulfur (as S,%)

Sulfate
 Pyritic
 Organic

Total

Water Soluble Alkalies (%)

Na2O
 K2O

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO2/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Edward H. Curving
 Fuels Laboratory Supervisor

* Oxygen by Difference.
 **Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-12
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 13-SP5

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	0.36	0.00	0.36
Ash	11.63	11.67	11.63
Volatile	13.06	13.11	13.06
Fixed C	74.95	75.22	74.95
	-----	-----	-----
Total	100.00	100.00	100.00

Sulfur
 Btu/lb (HHV)
 MMF Btu/lb
 MAF Btu/lb
 Air Dry Loss (%)

Ultimate (%)

Moisture
 Carbon
 Hydrogen
 Nitrogen
 Sulfur
 Ash
 Oxygen*

Total
 Chlorine**

Forms of Sulfur (as S,%)

Sulfate
 Pyritic
 Organic

Total

Water Soluble Alkalies (%)

Na2O
 K2O

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO2/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Edward H. Cunniff
 Fuels Laboratory Supervisor

* Oxygen by Difference.
 ** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date November 8, 1995
HRI Project 002-1F
HRI Series No. J470/95
Date Rec'd 10/27/95
Cust. P.O. # 8574015


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road, Crawford 315
Honolulu, Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. J470/95-17
SAMPLE IDENTIFICATION: 14-SP3

Chloride, mg/l	300
Nitrogen, mg/l	1800
Sulfate as SO ₄ , mg/l	154
Sodium, mg/l	16.0
Potassium, mg/l	0.4

By:


Gerard H. Cunningham
Fuel Laboratory Manager



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date November 8, 1995
HRI Project 002-1F
HRI Series No. J470/95
Date Rec'd 10/27/95
Cust. P.O. # 8574015


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road, Crawford 315
Honolulu, Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. J470/95-18
SAMPLE IDENTIFICATION: 15-SP4

Chloride, mg/l	267
Nitrogen, mg/l	2000
Sulfate as SO ₄ , mg/l	164
Sodium, mg/l	11.4
Potassium, mg/l	0.2

By:


Gerard H. Cunningham
Fuel Laboratory Manager

HAZEN

Hazen Research, Inc.

4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date November 8, 1995
HRI Project 002-1F
HRI Series No. J470/95
Date Rec'd 10/27/95
Cust. P.O. # 8574015


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road. Crawford 315
Honolulu. Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. J470/95-19
SAMPLE IDENTIFICATION: 16-SP5

Chloride, mg/l	157
Nitrogen, mg/l	1300
Sulfate as SO ₄ , mg/l	126
Sodium, mg/l	11.4
Potassium, mg/l	0.2

By:


Gerard H. Cunningham
Fuel Laboratory Manager



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date November 8, 1995
HRI Project 002-1F
HRI Series No. J470/95
Date Rec'd 10/27/95
Cust. P.O. # 8574015


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road, Crawford 315
Honolulu, Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. J470/95-20
SAMPLE IDENTIFICATION: 20-SP3

Water. %	0.60
Ash. %	<0.001
Sulfur. %	0.037
Carbon. %	74.36
Hydrogen. %	4.70
Nitrogen. %	0.65
Oxygen, %*	19.65
Calorific Value. BTU/lb (HHV)	14338
Chlorine. %	13.70

By:


Gerard H. Cunningham
Fuel Laboratory Manager

* Oxygen by difference



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date November 8, 1995
HRI Project 002-1F
HRI Series No. J470/95
Date Rec'd 10/27/95
Cust. P.O. # 8574015


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road, Crawford 315
Honolulu, Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. J470/95-21
SAMPLE IDENTIFICATION: 21-SP4

Water, %	0.59
Ash, %	<0.001
Sulfur, %	0.034
Carbon, %	79.05
Hydrogen, %	4.81
Nitrogen, %	0.16
Oxygen, %*	15.36
Calorific Value, BTU/lb (HHV)	14587
Chlorine, %	10.48

By:


Gerard H. Cunningham
Fuel Laboratory Manager

* Oxygen by difference



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date November 8, 1995
HRI Project 002-1F
HRI Series No. J470/95
Date Rec'd 10/27/95
Cust. P.O. # 8574015


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road. Crawford 315
Honolulu, Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. J470/95-22
SAMPLE IDENTIFICATION: 22-SP5

Water. %	0.37
Ash. %	<0.001
Sulfur. %	0.019
Carbon. %	76.16
Hydrogen. %	4.75
Nitrogen. %	0.04
Oxygen. %*	18.66
Calorific Value. BTU/lb (HHV)	14363
Chlorine. %	11.44

By:


Gerard H. Cunningham
Fuel Laboratory Manager

* Oxygen by difference



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date November 7 1995
HRI Project 002-1F
HRI Series No. J470/95-16
Date Rec'd. 10/27/95
Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Rd, Crawford 315
Honolulu, Hawaii 96822

Sample Identification:
26-SPA
-

Elemental Analysis of Ash (%)

Ash Fusion Temperatures (Deg F)


SI02	43.76
AL2O3	20.70
TI02	5.03
FE2O3	23.93
CAO	2.76
MGO	1.29
NA2O	0.21
K2O	2.05
P2O5	0.99
SO3	0.03
CL	
CO2	

Total 100.75

Oxidizing Atmosphere	Reducing Atmosphere
-------------------------	------------------------

Initial
Softening
Hemispherical
Fluid

Report Prepared By:


Fuels Laboratory Supervisor

Note: The ash was calcined @ 1110 deg F (600 C) prior to analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-13
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification:
 2-3-SP3

Elemental Analysis of Ash (%)

Ash Fusion Temperatures (Deg F)

SiO2	40.37
Al2O3	22.26
TiO2	4.44
Fe2O3	21.78
CaO	3.73
MgO	1.31
Na2O	0.24
K2O	2.53
P2O5	1.12
SO3	0.63
CL	
CO2	

Total 98.41

	Oxidizing Atmosphere	Reducing Atmosphere
Initial	2341	2035
Softening	2456	2062
Hemispherical	2464	2071
Fluid	2470	2085

Report Prepared By:

Frank H. Cunningham
 Fuels Laboratory Supervisor

Note: The ash was calcined @ 1110 deg F (600 C) prior to analysis.



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date November 7 1995
HRI Project 002-1F
HRI Series No. J470/95-14
Date Rec'd. 10/27/95
Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Rd, Crawford 315
Honolulu, Hawaii 96822

Sample Identification:
4-5-SP4

Elemental Analysis of Ash (%)


Ash Fusion Temperatures (Deg F)

SiO2	40.31
Al2O3	23.31
TiO2	4.12
Fe2O3	22.57
CaO	3.47
MgO	1.26
Na2O	0.25
K2O	2.12
P2O5	1.07
SO3	0.52
CL	
CO2	

Total 99.00

	Oxidizing Atmosphere	Reducing Atmosphere
Initial	2405	2025
Softening	2462	2045
Hemispherical	2465	2060
Fluid	2467	2095

Report Prepared By:


Fuels Laboratory Supervisor

Note: The ash was calcined @ 1110 deg F (600 C) prior to analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date November 7 1995
 HRI Project 002-1F
 HRI Series No. J470/95-15
 Date Rec'd. 10/27/95
 Cust. P.O.# 8574015

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification:
 6-7-SP5

Elemental Analysis of Ash (%)

Ash Fusion Temperatures (Deg F)

SI02	44.94
AL2O3	21.19
TI02	3.05
FE2O3	18.36
CAO	3.31
MGO	1.79
NA2O	0.29
K2O	3.11
P2O5	1.21
SO3	1.55
CL	
CO2	
Total	98.80

	Oxidizing Atmosphere	Reducing Atmosphere
Initial	2270	2000
Softening	2418	2027
Hemispherical	2432	2050
Fluid	2465	2075

Report Prepared By:

Frank H. Cunningham
 Fuels Laboratory Supervisor

Note: The ash was calcined @ 1110 deg F (600 C) prior to analysis.

BGF Sample List — December Tests

No.	Samp. Per.	Sample	Date	Time	Comments	Analysis	Lab	I.D.	Date Sent	Quantity		
										Total	Sent	Kept
1	SP1	Bagasse	12/6/95	8:58	Dried		—	1-SP1-2	—	209.35	52.75	156.6
2	SP1	Bagasse	12/6/95	9:25	Dried		—	2-SP1-2	—	184.45	52.05	132.4
3	SP1	Bagasse	12/6/95	10:00	Dried		—	3-SP1-2	—	197.65	71.35	126.3
4	SP1	Bagasse	12/6/95	8:58-10:00	Combined sample	Ult, Prox, Btu	1	4-SP1-2	12/21/95	175.8	175.8	0
5	SP2	Bagasse	12/7/95	11:10	Dried		—	5-SP2-2	—	200.75	67.95	132.8
6	SP2	Bagasse	12/7/95	11:38	Dried		—	6-SP2-2	—	214.75	62.05	152.7
7	SP2	Bagasse	12/7/95	12:00	Dried; MC=34.59%		—	7-SP2-2	—	229.15	59.55	169.6
8	SP2	Bagasse	12/7/95	11:10-12:00	Combined sample	Ult, Prox, Btu	1	8-SP2-2	12/21/95	189.2	189.2	0
9	SP3	Bagasse	12/7/95	19:15-19:24	Dried		—	9-SP3-2	—	208.65	89.45	119.2
10	SP3	Bagasse	12/7/95	19:25-19:30	Dried		—	10-SP3-2	—	207.05	89.85	117.2
11	SP3	Bagasse	12/7/95	19:15-19:30	Combined sample	Ult, Prox, Btu	1	11-SP3-2	12/21/95	181.7	181.7	0
12	SP1	Char; ash lockhop.	12/6/95	9:00-10:12		Ultimate	1	12-SP1-2	12/21/95	746.91	314.8	432.11
13	SP2	Char; ash lockhop.	12/7/95	11:08-12:15		Ultimate	1	13-SP2-2	12/21/95	423.11	204.6	218.51
14	SP3	Char; ash lockhop.	12/7/95	18:30-19:30		Ultimate	1	14-SP3-2	12/21/95	455.01	202.9	252.11
15	SP1	Char; isokin. S.S.	12/6/95	9:00-10:12	tare=26.4 g	Proximate	1	15-SP1-2	12/21/95	0.8	0.8	0
16	SP2	Char; isokin. S.S.	12/7/95	11:08-12:15	tare=26.8 g	Proximate	1	16-SP2-2	12/21/95	4.1	4.1	0
17	SP1	Aqueous cond.	12/6/95			N, S, Cl, Na, K	1	17-SP1-2	12/21/95	79.1	48.55	48.55
18	SP2	Aqueous cond.	12/7/95			N, S, Cl, Na, K	1	18-SP2-2	12/21/95	79.8	48.55	48.55
19	SP1	MeCl ₂ Wash	12/6/95	9:10-10:12	tare=26.7 g	Composition	2	19-SP1-2	—	49.7	0	49.7
20	SP2	MeCl ₂ Wash	12/7/95	11:08-12:15	tare=26.7 g	Composition	2	20-SP2-2	—	47.7	0	49.7
21	SP1	Rotovaped tars	12/6/95			Ult, Btu, Cl; comp.	1, 2	21-SP1-2	12/21/95	8.8	4.88	3.92
22	SP2	Rotovaped tars	12/7/95			Ult, Btu, Cl; comp.	1, 2	22-SP2-2	12/21/95	19.8	8.65	11.15

SP1: 12/6/95 (9:00 to 10:12)

SP2: 12/7/95 (11:08 to 12:15)

SP3: 12/7/95 (18:30 to 19:30)

Lab 1 — Hazen

Lab 2 — HNEI

Tars/Oils Analysis (GC/FID) — December Tests

Sample ID	Rotovaped Tars				MeCl2 Wash	
	21-SP1-2		22-SP2-2		19-SP1-2	20-SP2-2
	mg/ml	mg/g	mg/ml	mg/g	mg/ml	mg/ml
Benzene, C6H6	0	0	0	0	0.284	0.577
Toluene, C7H8	0	0	0	0	0.03	0.034
Xylene, C8H10	0	0	0	0	0.009	0.006
a-Methylstyr, C9H10	0	0	0	0	0.263	0
Indene, C9H8	0.348	52.66	0	0	0.389	0.14
Naphthalene, C10H8	1.769	267.9	1.803	271.9	1.675	3.679
1-Methylnaph, C11H10	0.046	6.905	0.013	2.028	0.041	0.032
Internal Standard	0.63	95.38	0.549	82.74	0.644	0.817
Acenaphthylene, C12H8	0.436	66.02	0.299	45.11	0.389	0.721
Acenaphthene, C12H10	0.013	2.013	0.026	3.849	0.013	0.059
Fluorene, C13H10	0.119	17.96	0.043	6.527	0.104	0.1
Phenanthrene, C14H10	0.366	55.49	0.594	89.52	0.335	1.348
Anthracene, C14H10	0.073	11.13	0.058	8.7	0.066	0.136
Fluoranthene, C16H10	0.108	16.28	0.405	61.03	0.091	0.928
Pyrene, C16H10	0.082	12.41	0.325	49.00	0.067	0.761
Chrysene, C18H12	0.004	0.624	0.009	1.328	0	0.02
Benzo(k)fluor, C20H12	0	0	0.004	0.593	0	0.124
di-Benzoanthr, C22H14	0	0	0	0	0	1.99
Indenopyrene, C22H12	0	0	0.03	4.519	0	0.078

Notes: 1) mg/ml = mg of compound per ml of MeCl2 Wash

2) mg/g = mg of compound per g of rotovaped tar



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date January 10 1996
 HRI Project 002-14G
 HRI Series No. L391/95-1
 Date Rec'd. 12/27/95
 Cust. P.O.# 8574020

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 4-SP1-2

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	4.20	0.00	2.20
Ash	3.42	3.57	3.49
Volatile	81.79	85.37	83.49
Fixed C	10.59	11.06	10.82
Total	100.00	100.00	100.00
Sulfur	0.03	0.03	0.03
Btu/lb (HHV)	7670	8005	7829
MMF Btu/lb	7963	8326	
MAF Btu/lb		8302	
Air Dry Loss (%)		2.04	
Ultimate (%)			
Moisture	4.20	0.00	2.20
Carbon	46.71	48.75	47.68
Hydrogen	5.55	5.79	5.66
Nitrogen	0.22	0.22	0.22
Sulfur	0.03	0.03	0.03
Ash	3.42	3.57	3.49
Oxygen*	39.87	41.64	40.72
Total	100.00	100.00	100.00
Chlorine**			

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.03	0.03

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 4.46
 Lb. SO₂/MM Btu= 0.08
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Gerard M. Conroy
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na₂O
 K₂O

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date January 10 1996
 HRI Project 002-14G
 HRI Series No. L391/95-2
 Date Rec'd. 12/27/95
 Cust. P.O.# 8574020

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 8-SP2-2

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	4.91	0.00	2.02
Ash	4.44	4.66	4.57
Volatile	81.57	85.78	84.05
Fixed C	9.08	9.56	9.36
	-----	-----	-----
Total	100.00	100.00	100.00

Sulfur	0.04	0.04	0.04
Btu/lb (HHV)	7474	7860	7701
MMF Btu/lb	7850	8277	
MAF Btu/lb		8244	
Air Dry Loss (%)		2.95	

Ultimate (%)

Moisture	4.91	0.00	2.02
Carbon	45.46	47.81	46.84
Hydrogen	5.39	5.67	5.55
Nitrogen	0.25	0.27	0.26
Sulfur	0.04	0.04	0.04
Ash	4.44	4.66	4.57
Oxygen*	39.51	41.55	40.72
	-----	-----	-----
Total	100.00	100.00	100.00
Chlorine**			

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
	-----	-----
Total	0.04	0.04

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 5.93
 Lb. SO2/MM Btu= 0.10
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

David H. Curig
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na2O
 K2O

* Oxygen by Difference.
 ** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date January 10 1996
 HRI Project 002-14G
 HRI Series No. L391/95-3
 Date Rec'd. 12/27/95
 Cust. P.O.# 8574020

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 11-SP3-2

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	3.33	0.00	1.72
Ash	4.67	4.83	4.75
Volatile	80.50	83.27	81.84
Fixed C	11.50	11.90	11.69
	-----	-----	-----
Total	100.00	100.00	100.00

Sulfur	0.03	0.03	0.03
Btu/lb (HHV)	7622	7885	7749
MMF Btu/lb	8027	8319	
MAF Btu/lb		8285	
Air Dry Loss (%)		1.64	

Ultimate (%)

Moisture	3.33	0.00	1.72
Carbon	46.07	47.66	46.84
Hydrogen	5.48	5.66	5.57
Nitrogen	0.21	0.21	0.21
Sulfur	0.03	0.03	0.03
Ash	4.67	4.83	4.75
Oxygen*	40.21	41.61	40.88
	-----	-----	-----
Total	100.00	100.00	100.00
Chlorine**			

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
	-----	-----
Total	0.03	0.03

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 6.13
 Lb. SO2/MM Btu= 0.08
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

David H. Luning
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na2O
 K2O

* Oxygen by Difference.
 **Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date January 10 1996
 HRI Project 002-14G
 HRI Series No. L391/95-4
 Date Rec'd. 12/27/95
 Cust. P.O.# 8574020

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 12-SP1-2

Reporting Basis >	As Rec'd	Dry	Air Dry
-------------------	----------	-----	---------

Proximate (%)

Moisture	0.42	0.00	0.42
Ash	74.93	75.25	74.93
Volatile			
Fixed C			

Total

Sulfur	0.02	0.02	0.02
Btu/lb (HHV)			
MMF Btu/lb			
MAF Btu/lb			
Air Dry Loss (%)			

Ultimate (%)

Moisture	0.42	0.00	0.42
Carbon	22.21	22.30	22.21
Hydrogen	0.36	0.36	0.36
Nitrogen	0.26	0.26	0.26
Sulfur	0.02	0.02	0.02
Ash	74.93	75.25	74.93
Oxygen*	1.80	1.81	1.80

Total	100.00	100.00	100.00
Chlorine**			

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.02	0.02

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO₂/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Gerard H. Loring
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na₂O
 K₂O

* Oxygen by Difference.
 ** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date January 10 1996
 HRI Project 002-14G
 HRI Series No. L391/95-5
 Date Rec'd. 12/27/95
 Cust. P.O.# 8574020

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 13-SP2-2

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	0.58	0.00	0.58
Ash	74.15	74.58	74.15
Volatile			
Fixed C			
Total	-----	-----	-----
Sulfur	0.02	0.02	0.02
Btu/lb (HHV)			
MMF Btu/lb			
MAF Btu/lb			
Air Dry Loss (%)			
Ultimate (%)			
Moisture	0.58	0.00	0.58
Carbon	26.10	26.25	26.10
Hydrogen	0.32	0.32	0.32
Nitrogen	0.27	0.27	0.27
Sulfur	0.02	0.02	0.02
Ash	74.15	74.58	74.15
Oxygen*	<0.01	<0.01	<0.01

Chlorine**

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	-----	-----
	0.02	0.02

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO₂/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Quandt L. Loring
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na₂O
 K₂O

* Oxygen by Difference.

**Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date January 10 1996
 HRI Project 002-14G
 HRI Series No. L391/95-6
 Date Rec'd. 12/27/95
 Cust. P.O.# 8574020

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 14-SP3-2

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	0.73	0.00	0.73
Ash	67.13	67.62	67.13
Volatile Fixed C	-----	-----	-----
Total			
Sulfur	0.02	0.02	0.02
Btu/lb (HHV)			
MMF Btu/lb			
MAF Btu/lb			
Air Dry Loss (%)			
Ultimate (%)			
Moisture	0.73	0.00	0.73
Carbon	32.39	32.63	32.39
Hydrogen	0.40	0.40	0.40
Nitrogen	0.35	0.35	0.35
Sulfur	0.02	0.02	0.02
Ash	67.13	67.62	67.13
Oxygen*	<0.01	<0.01	<0.01

Chlorine**

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.02	0.02

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO₂/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Frank H. Conz
 Fuels Laboratory Supervisor

Water Soluble Alkalies (%)

Na₂O
 K₂O

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana St. • Golden, Colo. 80403
 Tel: (303) 279-4501 • Telex 45-860
 FAX: (303) 278-1528

Date January 10 1996
 HRI Project 002-14G
 HRI Series No. L391/95-7
 Date Rec'd. 12/27/95
 Cust. P.O.# 8574020

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
 Darren Ishimura
 2550 Campus Rd, Crawford 315
 Honolulu, Hawaii 96822

Sample Identification
 15-SP1-2 - Insufficient
 sample to analyze moisture
 in this sample. - GHC

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture			
Ash	35.73	35.73	35.73
Volatile	13.33	13.33	13.33
Fixed C	50.94	50.94	50.94
	<hr/>	<hr/>	<hr/>
Total	100.00	100.00	100.00

Sulfur
 Btu/lb (HHV)
 MMF Btu/lb
 MAF Btu/lb
 Air Dry Loss (%)

Ultimate (%)

Moisture
 Carbon
 Hydrogen
 Nitrogen
 Sulfur
 Ash
 Oxygen*

Total
 Chlorine**

Forms of Sulfur (as S,%)

Sulfate
 Pyritic
 Organic

Total

Water Soluble Alkalies (%)

Na₂O
 K₂O

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu=
 Lb. SO₂/MM Btu=
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=

Report Prepared By:

Guartha. Currij
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.

4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date January 10 1996
HRI Project 002-14G
HRI Series No. L391/95-8
Date Rec'd. 12/27/95
Cust. P.O.# 8574020

REPORT OF ANALYSIS

Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Rd, Crawford 315
Honolulu, Hawaii 96822

Sample Identification
16-SP2-2

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	0.34	0.00	0.34
Ash	6.24	6.26	6.24
Volatile	4.06	4.07	4.06
Fixed C	89.36	89.67	89.36
Total	100.00	100.00	100.00

Sulfur
Btu/lb (HHV)
MMF Btu/lb
MAF Btu/lb
Air Dry Loss (%)

Ultimate (%)

Moisture
Carbon
Hydrogen
Nitrogen
Sulfur
Ash
Oxygen*

Total
Chlorine**

Forms of Sulfur (as S,%)

Sulfate
Pyritic
Organic

Total

Water Soluble Alkalies (%)

Na2O
K2O

Lb. Alkali/MM Btu=
Lb. Ash/MM Btu=
Lb. SO2/MM Btu=
HGI= @ % Moisture
As Rec'd. Sp.Gr.=
Free Swelling Index=

Report Prepared By:

Edward H. Curry
Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date January 21, 1996
HRI Project 002-14G
HRI Series No. L391/95
Date Rec'd 12/27/95
Cust. P.O. # 8574020


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road, Crawford 315
Honolulu, Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. L391/95-9
SAMPLE IDENTIFICATION: 17-SP1-2

Chloride, mg/l	26
Nitrogen, mg/l	1100
Sulfur, mg/l	50
Sodium, mg/l	3.5
Potassium, mg/l	<0.2

By:


Gerard H. Cunningham
Fuel Laboratory Manager

NA = Analysis not available.



HAZEN

Hazen Research, Inc.

4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date January 21, 1996
HRI Project 002-14G
HRI Series No. L391/95
Date Rec'd 12/27/95
Cust. P.O. # 8574020


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road, Crawford 315
Honolulu, Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. L391/95-10
SAMPLE IDENTIFICATION: 18-SP2-2

Chloride, mg/l	366
Nitrogen, mg/l	1600
Sulfur, mg/l	40
Sodium, mg/l	2.5
Potassium, mg/l	<0.2

By:


Gerard H. Cunningham
Fuel Laboratory Manager

NA = Analysis not available.



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date January 11, 1996
HRI Project 002-14G
HRI Series No. L391/95
Date Rec'd 12/27/95
Cust. P.O. # 8574020


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road, Crawford 315
Honolulu, Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. L391/95-11
SAMPLE IDENTIFICATION: 21-SP1-2

Water. %	0.18
Ash. %	<0.001
Sulfur, %	0.064
Carbon, %	81.62
Hydrogen, %	5.00
Nitrogen, %	0.52
Oxygen. %*	12.62
Calorific Value, BTU/lb (HHV)	14888
Chlorine. %	12.63

By:


Gerard H. Cunningham
Fuel Laboratory Manager

* Oxygen by difference



Hazen Research, Inc.
4601 Indiana St. • Golden, Colo. 80403
Tel: (303) 279-4501 • Telex 45-860
FAX: (303) 278-1528

Date January 11, 1996
HRI Project 002-14G
HRI Series No. L391/95
Date Rec'd 12/27/95
Cust. P.O. # 8574020


Hawaii Natural Energy Institute
Darren Ishimura
2550 Campus Road. Crawford 315
Honolulu, Hawaii 96822

REPORT OF ANALYSIS

SAMPLE NO. L391/95-12
SAMPLE IDENTIFICATION: 22-SP2-2

Water, %	0.63
Ash, %	<0.001
Sulfur, %	0.039
Carbon, %	74.51
Hydrogen, %	4.40
Nitrogen, %	0.18
Oxygen, %*	20.24
Calorific Value, BTU/lb (HHV)	13855
Chlorine, %	12.89

By:


Gerard H. Cunningham
Fuel Laboratory Manager

* Oxygen by difference

Appendix B
Mass Balance Spreadsheet -- Raw Data

Biomass Gasifier Facility

PROJECT NUMBER.....
 TEST NUMBER..... BGE1/SP3
 DATE OF TEST..... 10/6/95
 Latest file update: 2/14/96 1:51 PM

Reactor I.D., inches.... 37.00

Sampling period..... 22:15 to 22:54
 Sampling basis..... 0.650 hours

TEST CONDITIONS:
 Temperature, °F..... 1543.00
 Pressure, psig..... 41.2

TEST DESCRIPTION:

MATERIAL INPUT DATA:

	Steady-state period				
	lb/h	SCF/h	lb	SCF	Vol%
Biomass feed (as rec'd)	2242.0	--	1457.3	--	--
Steam to nozzle.....	0.0	0.00	0.00	0.00	--
Steam to ring.....	0.0	0.00	0.00	0.00	--
Total steam.....	0.0	0.00	0.0	0.00	0.0%
Air to nozzle.....	2434.5	31860.00	1582.41		
Air to ring.....	1512.9	19800.00	983.42		
Air to burner.....	916.9	12000.00	596.01		
Total air.....	4864.4	63660.00	1579.4	0.00	0.0%
Oxygen (calc).....	1019.1	12069.78	662.40	7845.35	19.0%
Nitrogen (calc).....	3798.1	51391.57	2468.76	33404.52	81.0%
Argon (calc).....	45.4	431.02	29.53	280.16	0.7%
CO2 (calc).....	1.6	13.82	1.04	8.99	0.0%
Neon, etc. (calc).....	0.1	1.3	0.09	0.82	0.0%
DRY gas input.....	4864.4	63907.45	3131.2	41249.88	100.0%
WET gas input.....	4864.4	63907.45	7872.4	41249.88	100.0%

MATERIAL OUTPUT DATA:

	lb/h	SCF/h	lb	SCF	Vol%
Char (cyclone discharge)....	104.6	--	68.0	--	--
Char (entrained).....	8.4	--	5.5	--	--
Total char (filter+cyc)	113.1	--	73.5	--	--
Condensate.....	1114.9	--	724.7	--	--
AQUEOUS phase.....	1067.9	22460.38	694.1	14599.25	--
OIL phase.....	47.0	--	30.5	--	--
N2 (as tracer).....	3798.1	51391.57	2468.8	33404.52	50.7%
DRY product gas.....	6232.7	78892.54	4051.2	51280.15	77.8%
WET product gas.....	7300.3	101352.93	4745.2	65879.40	100.0%
DRY N2-FREE product gas.	2434.6	27500.97	1582.5	17875.63	27.1%

SAMPLE SYSTEM DATA:

	Comments
Gas meter initial reading, cu ft.	6316.30
Gas meter final reading, cu ft...	6353.00
Gas meter temperature, °F.....	80.00
Gas meter pressure, psig.....	5.00
Meter correction factor.....	1.000
Total DRY gas sampled, SCF.....	47.36
% of reactor gas flow.....	0.09%
Char fines collected, g.....	2.30
Char carryover, lb/MSCF (wet)....	0.083
Condensate collected, g.....	303.59
AQUEOUS condensate, g.....	290.80
OIL in condensate, g.....	12.79
C6H6 in condensate OIL, g.....	1.35
Equiv C6H6 volume, SCF.....	0.014
Equiv steam volume, SCF.....	13.48
Total WET gas sampled, SCF....	60.84
Steam in wet product gas, vol%...	22.16

SOLID ANALYSES:

PROXIMATE, wt%	-----Feed-----		----Char (cyclone)----			---Char (entrained)---			
	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)
Moisture.....	25.40	0.00	0.00	0.73	0.00	0.00	0.52	-0.85	-1.22
V. M.....	62.92	84.34	87.36		0.00	0.00	5.38	5.42	18.74
Ash.....	2.58	3.46	0.00	70.56	71.08	0.00	3.76	3.79	1.00
Fixed carbon..	9.10	12.20	12.64				90.34	91.64	81.48
ULTIMATE, wt%									
C.....	36.01	48.27	50.00	28.60	28.81	99.62	90.15	90.81	314.00
H.....	4.23	5.68	5.88	0.47	0.47	1.63	2.68	2.70	9.34
N.....	0.11	0.15	0.15	0.14	0.14	0.48	0.00	0.00	0.00
S.....	0.09	0.12	0.12	0.02	0.02	0.07	0.00	0.00	0.00
O (by diff)...	31.58	42.33	43.85	-0.52	-0.52	-1.80	2.69	2.71	9.37
Ash.....	2.58	3.46	---	70.56	71.08	---	3.75	3.78	---
HHV, Btu/lb....	5942.64	7966.00	8251.50	0.00		0.00	0.00		0.00
C/ash ratio....	13.95			0.41			24.02		
INPUT, lb.....	1457.30	1087.15	1049.55	---	---	---			
OUTPUT, lb.....	---	---	---	73.49	72.95	21.10			

OIL ANALYSES:

ULTIMATE, dry wt%

C.....	86.80
H.....	5.20
N.....	0.78
S.....	0.04
O (by diff).....	7.17
Ash.....	0.00
HHV, Btu/lb.....	15303.82
H/C ratio.....	0.714

AQUEOUS CONDENSATE ANALYSES:

	wt% dry feed	Comments
TC, mg/L.....	0.000	
TOC, mg/L.....	0.000	
S, mg/L.....	51.00	0.003
N, mg/L.....	1800.00	0.115
equiv lb NH3.....	1.52	0.140
Cl, mg/L.....	300.00	0.019
equiv lb HCl.....	0.21	0.020
CN, mg/L.....		0.000
equiv lb HCN.....	0.00	0.000

MATERIAL BALANCE -- raw data

TEST BGF1/SP3

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	524.77	61.70	1.58	1.305	460.19	37.62	1087.15
Moisture	---	41.42	---	---	328.72	---	370.14
Air	0.28	---	2468.76	---	692.69	---	3161.74
Steam	---	0.00	---	---	0.00	---	0.00
Total	525.05	103.12	2470.34	1.305	1481.61	37.62	4619.03

OUTPUT, lb							
Char, cyc (dry)	19.59	0.32	0.10	0.014	-0.35	48.33	68.00
Moisture	---	0.06	---	---	0.44	---	0.50
Char, entr (dry)	4.99	0.15	0.00	0.000	0.15	0.21	5.49
Moisture	---	0.00	---	---	0.03	---	0.03
Product gas(dry)	537.50	30.10	2468.76	0.000	1014.88	---	4051.25
Oils/tars	26.50	1.59	0.24	0.014	2.19	0.00	30.53
Condensate water	0.00	77.75	1.25	0.035	615.30	---	694.34
Total	588.58	109.97	2470.35	0.063	1632.64	48.54	4850.13

Out/In	112.1%	106.6%	100.0%	4.8%	110.2%	129.0%	105.0%
--------	--------	--------	--------	------	--------	--------	--------

MATERIAL BALANCE -- adjusted data

TEST BGF1/SP3

 Adjustments:

1.00000	1.00000	1.00000	1.0000	0.00
---------	---------	---------	--------	------

x cc out	x air in	x acu S	x acu N	+ lb H
----------	----------	---------	---------	--------

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	524.77	61.70	1.58	1.30	460.19	37.62	1087.15
Moisture	---	41.42	---	---	328.72	---	370.14
Air	0.28	---	2468.76	---	692.69	---	3161.74
Steam	---	0.00	---	---	0.00	---	0.00
Total	525.05	103.12	2470.34	1.30	1481.61	37.62	4619.03

OUTPUT, lb							
Char, cyc (dry)	19.59	0.32	0.10	0.01	-0.35	48.33	68.00
Moisture	---	0.06	---	---	0.44	---	0.50
Char, entr (dry)	4.99	0.15	0.00	0.00	0.15	0.21	5.49
Moisture	---	0.00	---	---	0.03	---	0.03
Product gas(dry)	537.50	30.10	2468.76	0.00	1014.88	---	4051.25
Oils/tars	26.50	1.59	0.24	0.01	2.19	0.00	30.53
Condensate water	0.00	77.75	1.25	0.04	615.30	---	694.34
Total	588.58	109.97	2470.35	0.06	1632.64	48.54	4850.13

Out/In	112.1%	106.6%	100.0%	4.8%	110.2%	129.0%	105.0%
--------	--------	--------	--------	------	--------	--------	--------

ENGINEERING DATA -- unadjusted

TEST BGF1/SP3

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	2242.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	1019.08
Nitrogen, lb/h.....	3798.09
Air, scfm	1060.97
Oxygen, lb/lb feed (wet).....	0.45
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	2.41
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft ³	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	104.62
Entrained Char (dry), lb/h	8.45
Condensate, lb/h.....	1115.18
Aqueous Phase, lb/h.....	1068.21
Oil Phase, lb/h.....	46.97
Dry Product Gas, lb/h.....	6232.69

ENGINEERING DATA, continued

TEST BGF1/SP3

Gas Yield, SCF (wet)/lb feed (wet).....	45.2
Gas Yield, SCF (dry)/lb feed (dry).....	47.2
Gas Heating Value, Btu/SCF (dry).....	85.1
Gas Heating Value, Btu/scf (dry N2-free).....	244.1
Cold Gas Thermal Efficiency (dry N2-free).....	0.504
Carbon Conversion to Gases and Liquids, %.....	107.5
Gas Heating Value, Btu/scf (dry incl oil).....	94.2
Cold Gas Thermal Efficiency (dry N2-free).....	0.504
Hot Gas Thermal Efficiency (dry N2-free).....	0.582

Biomass Gasifier Facility

PROJECT NUMBER.....
 TEST NUMBER..... BGF1/SP4
 DATE OF TEST..... 10/7/95
 Latest file update: 2/14/96 2:11 PM

Reactor I.D., inches.... 37.00

Sampling period..... 14:50:00 to 15:32:00
 Sampling basis..... 0.700 hours

TEST CONDITIONS:
 Temperature, °F..... 1548.00
 Pressure, psig..... 41.0

TEST DESCRIPTION:

MATERIAL INPUT DATA:

	Steady-state period				
	lb/h	SCF/h	lb	SCF	Vol%
Biomass feed (as rec'd)	2227.0	--	1558.9	--	--
Steam to nozzle.....	0.0	0.00	0.00	0.00	--
Steam to ring.....	0.0	0.00	0.00	0.00	--
Total steam.....	0.0	0.00	0.0	0.00	0.0%
Air to nozzle.....	2095.2	27420.00	1466.64		
Air to ring.....	1733.0	22680.00	1213.11		
Air to burner.....	481.4	6300.00	336.98		
Total air.....	4309.6	56400.00	1550.1	0.00	0.0%
Oxygen (calc).....	902.9	10693.30	632.01	7485.31	19.0%
Nitrogen (calc).....	3364.9	45530.70	2355.46	31871.49	81.0%
Argon (calc).....	40.3	381.86	28.18	267.30	0.7%
CO2 (calc).....	1.4	12.25	1.00	8.57	0.0%
Neon, etc. (calc).....	0.1	1.1	0.09	0.78	0.0%
DRY gas input.....	4309.6	56619.23	2987.5	39356.80	100.0%
WET gas input.....	4309.6	56619.23	7554.3	39356.80	100.0%

MATERIAL OUTPUT DATA:

	lb/h	SCF/h	lb	SCF	Vol%
Char (cyclone discharge)....	138.6	--	97.0	--	--
Char (entrained).....	2.2	--	1.5	--	--
Total char (filter+cyc)	140.7	--	98.5	--	--
Condensate.....	850.1	--	595.1	--	--
AQUEOUS phase.....	809.7	17030.19	566.8	11921.13	--
OIL phase.....	40.4	--	28.3	--	--
N2 (as tracer).....	3364.9	45530.70	2355.5	31871.49	52.0%
DRY product gas.....	5506.2	70570.18	3854.3	49399.13	80.6%
WET product gas.....	6315.7	87600.37	4421.0	61320.26	100.0%
DRY N2-FREE product gas.	2141.2	25039.48	1498.9	17527.63	28.6%

SAMPLE SYSTEM DATA:

	Comments
Gas meter initial reading, cu ft.	384.22
Gas meter final reading, cu ft...	434.35
Gas meter temperature, °F.....	80.00
Gas meter pressure, psig.....	5.00
Meter correction factor.....	1.000
Total DRY gas sampled, SCF.....	64.69
% of reactor gas flow.....	0.13%
Char fines collected, g.....	0.90
Char carryover, lb/MSCF (wet)....	0.025
Condensate collected, g.....	353.49
AQUEOUS condensate, g.....	336.70
OIL in condensate, g.....	16.79
C6H6 in condensate OIL, g.....	1.01
Equiv C6H6 volume, SCF.....	0.011
Equiv steam volume, SCF.....	15.61
Total WET gas sampled, SCF....	80.30
Steam in wet product gas, vol%...	19.44

SOLID ANALYSES:

	-----Feed-----			----Char (cyclone)----			---Char (entrained)---		
	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)
PROXIMATE, wt%									
Moisture.....	19.50	0.00	0.00	0.75	0.00	0.00	0.82	-0.85	-1.22
V. M.....	68.00	84.47	87.84		0.00	0.00	6.64	6.69	23.27
Ash.....	3.09	3.84	0.00	70.71	71.24	0.00	7.12	7.17	1.00
Fixed carbon..	9.41	11.69	12.16				85.42	86.99	76.95
ULTIMATE, wt%									
C.....	38.71	48.09	50.04	28.52	28.74	99.93	87.67	88.33	307.13
H.....	4.56	5.67	5.90	0.41	0.41	1.43	2.18	2.20	7.65
N.....	0.11	0.14	0.15	0.13	0.13	0.45	0.00	0.00	0.00
S.....	0.06	0.07	0.07	0.02	0.02	0.07	0.00	0.00	0.00
O (by diff)...	33.92	42.14	43.85	-0.54	-0.54	-1.88	2.27	2.29	7.96
Ash.....	3.13	3.89	---	70.71	71.24	---	7.13	7.18	---
HHV, Btu/lb....	6716.92	8344.00	8681.72	0.00		0.00	0.00		0.00
C/ash ratio....	12.36			0.40			12.30		
INPUT, lb.....	1558.90	1254.91	1206.74	---	---	---			
OUTPUT, lb.....	---	---	---	98.52	97.78	28.12			

OIL ANALYSES:

ULTIMATE, dry wt%

C.....	88.97
H.....	5.20
N.....	0.18
S.....	0.04
O (by diff).....	5.61
Ash.....	0.00
HHV, Btu/lb.....	15695.66
H/C ratio.....	0.696

AQUEOUS CONDENSATE ANALYSES:

	wt% dry feed	Comments
TC, mg/L.....	0.000	
TOC, mg/L.....	0.000	
S, mg/L.....	55.00	0.002
N, mg/L.....	2000.00	0.090
equiv lb NH3.....	1.38	0.110
Cl, mg/L.....	267.00	0.012
equiv lb HCl.....	0.16	0.012
CN, mg/L.....	0.000	
equiv lb HCN.....	0.00	0.000

MATERIAL BALANCE -- raw data

TEST BGF1/SP4

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	603.49	71.15	1.76	0.878	528.82	48.82	1254.91
Moisture	---	34.02	---	---	269.96	---	303.98
Air	0.27	---	2355.46	---	660.91	---	3016.64
Steam	---	0.00	---	---	0.00	---	0.00
Total	603.76	105.17	2357.22	0.878	1459.69	48.82	4575.53

OUTPUT, lb	C	H	N	S	O+Ar	Ash	Total
Char, cyc (dry)	27.88	0.40	0.13	0.019	-0.52	69.10	97.00
Moisture	---	0.08	---	---	0.65	---	0.73
Char, entr (dry)	1.34	0.03	0.00	0.000	0.03	0.11	1.52
Moisture	---	0.00	---	---	0.01	---	0.01
Product gas(dry)	515.14	31.93	2355.46	0.000	951.79	---	3854.32
Oils/tars	25.15	1.47	0.05	0.011	1.59	0.00	28.26
Condensate water	0.00	63.50	1.13	0.031	502.33	---	566.99
Total	569.50	97.41	2356.77	0.062	1455.87	69.21	4548.83

Out/In	94.3%	92.6%	100.0%	7.0%	99.7%	141.8%	99.4%
--------	-------	-------	--------	------	-------	--------	-------

MATERIAL BALANCE -- adjusted data

TEST BGF1/SP4

 Adjustments:

1.00000	1.00000	1.00000	1.0000	0.00
---------	---------	---------	--------	------

x cc out	x air in	x aqu S	x aqu N	+ lb H
----------	----------	---------	---------	--------

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	603.49	71.15	1.76	0.88	528.82	48.82	1254.91
Moisture	---	34.02	---	---	269.96	---	303.98
Air	0.27	---	2355.46	---	660.91	---	3016.64
Steam	---	0.00	---	---	0.00	---	0.00
Total	603.76	105.17	2357.22	0.88	1459.69	48.82	4575.53

OUTPUT, lb	C	H	N	S	O+Ar	Ash	Total
Char, cyc (dry)	27.88	0.40	0.13	0.02	-0.52	69.10	97.00
Moisture	---	0.08	---	---	0.65	---	0.73
Char, entr (dry)	1.34	0.03	0.00	0.00	0.03	0.11	1.52
Moisture	---	0.00	---	---	0.01	---	0.01
Product gas(dry)	515.14	31.93	2355.46	0.00	951.79	---	3854.32
Oils/tars	25.15	1.47	0.05	0.01	1.59	0.00	28.26
Condensate water	0.00	63.50	1.13	0.03	502.33	---	566.99
Total	569.50	97.41	2356.77	0.06	1455.87	69.21	4548.83

Out/In	94.3%	92.6%	100.0%	7.0%	99.7%	141.8%	99.4%
--------	-------	-------	--------	------	-------	--------	-------

ENGINEERING DATA -- unadjusted

TEST BGF1/SP4

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	2227.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	902.86
Nitrogen, lb/h.....	3364.95
Air, scfm	939.97
Oxygen, lb/lb feed (wet).....	0.41
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	2.15
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft ³	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	138.57
Entrained Char (dry), lb/h	2.16
Condensate, lb/h.....	850.36
Aqueous Phase, lb/h.....	809.98
Oil Phase, lb/h.....	40.38
Dry Product Gas, lb/h.....	5506.18

ENGINEERING DATA, continued

TEST BGF1/SP4

Gas Yield, SCF (wet)/lb feed (wet).....	39.3
Gas Yield, SCF (dry)/lb feed (dry).....	39.4
Gas Heating Value, Btu/SCF (dry).....	91.1
Gas Heating Value, Btu/scf (dry N ₂ -free).....	256.7
Cold Gas Thermal Efficiency (dry N ₂ -free).....	0.430
Carbon Conversion to Gases and Liquids; %.....	89.5
 Gas Heating Value, Btu/scf (dry incl oil).....	 100.1
 Cold Gas Thermal Efficiency (dry N ₂ -free).....	 0.430
Hot Gas Thermal Efficiency (dry N ₂ -free).....	0.492

Biomass Gasifier Facility

PROJECT NUMBER.....

TEST NUMBER.....

BGE1/SP5

DATE OF TEST.....

10/8/95

Latest file update:

2/12/96 12:11 PM

Reactor I.D., inches....

37.00

Sampling period.....

1:34:00

to

2:45:00

Sampling basis.....

1.183 hours

TEST CONDITIONS:

Temperature, °F.....

1543.00

Pressure, psig.....

46.0

TEST DESCRIPTION:

MATERIAL INPUT DATA:

	Steady-state period				
	lb/h	SCF/h	lb	SCF	Vol%
Biomass feed (as rec'd)	2460.0	--	2911.0	--	--
Steam to nozzle.....	0.0	0.00	0.00	0.00	--
Steam to ring.....	0.0	0.00	0.00	0.00	--
Total steam.....	0.0	0.00	0.0	0.00	0.0%
Air to nozzle.....	2228.2	29160.00	2636.66		
Air to ring.....	1746.8	22860.00	2067.01		
Air to burner.....	710.6	9300.00	840.91		
Total air.....	4685.6	61320.00	2907.9	0.00	0.0%
Oxygen (calc).....	981.6	11626.12	1161.59	13757.57	19.0%
Nitrogen (calc).....	3658.5	49502.53	4329.21	58577.99	81.0%
Argon (calc).....	43.8	415.17	51.79	491.29	0.7%
CO2 (calc).....	1.5	13.32	1.83	15.76	0.0%
Neon, etc. (calc).....	0.1	1.2	0.17	1.43	0.0%
DRY gas input.....	4685.6	61558.35	5490.8	72335.57	100.0%
WET gas input.....	4685.6	61558.35	13943.3	72335.57	100.0%

MATERIAL OUTPUT DATA:

	lb/h	SCF/h	lb	SCF	Vol%
Char (cyclone discharge)....	117.5	--	139.0	--	--
Char (entrained).....	2.4	--	2.8	--	--
Total char (filter+cyc)	119.8	--	141.8	--	--
Condensate.....	1326.9	--	1570.2	--	--
AQUEOUS phase.....	1294.7	27230.59	1532.1	32222.87	--
OIL phase.....	32.2	--	38.1	--	--
N2 (as tracer).....	3658.5	49502.53	4329.2	58577.99	44.6%
DRY product gas.....	6442.9	83713.27	7624.1	99060.70	75.5%
WET product gas.....	7737.4	110943.86	9155.9	131283.57	100.0%
DRY N2-FREE product gas.	2784.4	34210.74	3294.9	40482.71	30.8%

SAMPLE SYSTEM DATA:

	Comments
Gas meter initial reading, cu ft.	434.35
Gas meter final reading, cu ft...	494.88
Gas meter temperature, °F.....	80.00
Gas meter pressure, psig.....	5.00
Meter correction factor.....	1.000
Total DRY gas sampled, SCF.....	78.11
% of reactor gas flow.....	0.08%
Char fines collected, g.....	1.00
Char carryover, lb/MSCF (wet)....	0.021
Condensate collected, g.....	561.64
AQUEOUS condensate, g.....	548.00
OIL in condensate, g.....	13.64
C6H6 in condensate OIL, g.....	0.98
Equiv C6H6 volume, SCF.....	0.010
Equiv steam volume, SCF.....	25.41
Total WET gas sampled, SCF....	103.52
Steam in wet product gas, vol%...	24.54

SOLID ANALYSES:

	-----Feed-----		----Char (cyclone)----			---Char (entrained)---			(maf)
	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	
PROXIMATE, wt%									
Moisture.....	33.75	0.00	0.00	0.73	0.00	0.00	0.36	-0.85	-1.22
V. M.....	56.18	84.80	87.85		0.00	0.00	13.06	13.16	45.49
Ash.....	2.30	3.47	0.00	70.56	71.08	0.00	11.63	11.72	1.00
Fixed carbon..	7.77	11.73	12.15				74.95	75.98	54.73
ULTIMATE, wt%									
C.....	31.94	48.21	49.94	24.59	24.77	101.64	74.40	74.95	307.55
H.....	3.71	5.60	5.80	0.41	0.41	1.68	0.00	0.00	0.00
N.....	0.08	0.12	0.12	0.12	0.12	0.49	0.00	0.00	0.00
S.....	0.03	0.05	0.05	0.01	0.01	0.04	0.00	0.00	0.00
O (by diff)...	28.19	42.55	44.08	-0.93	-0.94	-3.86	21.11	21.27	87.28
Ash.....	2.30	3.47	---	75.08	75.63	---	3.75	3.78	---
HHV, Btu/lb.....	5527.24	8343.00	8642.91	0.00		0.00	0.00		0.00
C/ash ratio.....	13.89			0.33			19.83		
INPUT, lb.....	2911.00	1928.54	1861.58	---	---	---			
OUTPUT, lb.....	---	---	---	141.80	140.76	40.71			

OIL ANALYSES:

ULTIMATE, dry wt%

C.....	86.34
H.....	5.15
N.....	0.05
S.....	0.02
O (by diff).....	8.44
Ash.....	0.00
HHV, Btu/lb.....	15153.01
H/C ratio.....	0.711

AQUEOUS CONDENSATE ANALYSES:

	wt% dry feed	Comments
TC, mg/L.....	0.000	
TOC, mg/L.....	0.000	
S, mg/L.....	42.00	0.003
N, mg/L.....	1300.00	0.106
equiv lb NH3.....	2.42	0.126
Cl, mg/L.....	157.00	0.013
equiv lb HCl.....	0.25	0.013
CN, mg/L.....		0.000
equiv lb HCN.....	0.00	0.000

MATERIAL BALANCE -- raw data

TEST BGF1/SP5

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	929.75	108.00	2.31	0.964	820.59	66.92	1928.54
Moisture	---	109.94	---	---	872.50	---	982.43
Air	0.50	---	4329.21	---	1214.71	---	5544.41
Steam	---	0.00	---	---	0.00	---	0.00
Total	930.25	217.93	4331.52	0.964	2907.80	66.92	8455.38
OUTPUT, lb							
Char, cyc (dry)	34.43	0.57	0.17	0.014	-1.31	105.13	139.00
Moisture	---	0.11	---	---	0.90	---	1.01
Char, entr (dry)	2.10	0.00	0.00	0.000	0.59	0.11	2.80
Moisture	---	0.00	---	---	0.01	---	0.01
Product gas(dry)	1198.39	85.13	4329.21	0.000	2011.43	---	7624.16
Oils/tars	32.92	1.96	0.02	0.008	3.22	0.00	38.13
Condensate water	0.00	171.56	1.99	0.064	1358.77	---	1532.38
Total	1267.84	259.34	4331.39	0.086	3373.62	105.23	9337.50
Out/In	136.3%	119.0%	100.0%	8.9%	116.0%	157.2%	110.4%

MATERIAL BALANCE -- adjusted data

TEST BGF1/SP5

Adjustments:							
	1.00000	1.00000	1.00000	1.0000	0.00		
	x cc out	x air in	x acu S	x acu N	+ lb H		
INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	929.75	108.00	2.31	0.96	820.59	66.92	1928.54
Moisture	---	109.94	---	---	872.50	---	982.43
Air	0.50	---	4329.21	---	1214.71	---	5544.41
Steam	---	0.00	---	---	0.00	---	0.00
Total	930.25	217.93	4331.52	0.96	2907.80	66.92	8455.38
OUTPUT, lb							
Char, cyc (dry)	34.43	0.57	0.17	0.01	-1.31	105.13	139.00
Moisture	---	0.11	---	---	0.90	---	1.01
Char, entr (dry)	2.10	0.00	0.00	0.00	0.59	0.11	2.80
Moisture	---	0.00	---	---	0.01	---	0.01
Product gas(dry)	1198.39	85.13	4329.21	0.00	2011.43	---	7624.16
Oils/tars	32.92	1.96	0.02	0.01	3.22	0.00	38.13
Condensate water	0.00	171.56	1.99	0.06	1358.77	---	1532.38
Total	1267.84	259.34	4331.39	0.09	3373.62	105.23	9337.50
Out/In	136.3%	119.0%	100.0%	8.9%	116.0%	157.2%	110.4%

ENGINEERING DATA -- unadjusted

TEST BGF1/SP5

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	2460.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	981.62
Nitrogen, lb/h.....	3658.49
Air, scfm	1021.97
Oxygen, lb/lb feed (wet).....	0.40
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	2.14
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft ³	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	117.46
Entrained Char (dry), lb/h	2.36
Condensate, lb/h.....	1327.20
Aqueous Phase, lb/h.....	1294.97
Oil Phase, lb/h.....	32.23
Dry Product Gas, lb/h.....	6442.95

ENGINEERING DATA, continued

TEST BGF1/SP5

Gas Yield, SCF (wet)/lb feed (wet).....	45.1
Gas Yield, SCF (dry)/lb feed (dry).....	51.4
Gas Heating Value, Btu/SCF (dry).....	124.8
Gas Heating Value, Btu/scf (dry N ₂ -free).....	305.5
Cold Gas Thermal Efficiency (dry N ₂ -free).....	0.769
Carbon Conversion to Gases and Liquids, %.....	132.4
Gas Heating Value, Btu/scf (dry incl oil).....	130.7
Cold Gas Thermal Efficiency (dry N ₂ -free).....	0.769
Hot Gas Thermal Efficiency (dry N ₂ -free).....	0.859

Biomass Gasifier Facility

PROJECT NUMBER.....
 TEST NUMBER..... BGF2/SP1
 DATE OF TEST..... 12/6/95
 Latest file update: 2/14/96 3:09 PM

Reactor I.D., inches.... 37.00

Sampling period..... 9:00:00 to 10:12:00
 Sampling basis..... 1.200 hours

TEST CONDITIONS:

Temperature, °F..... 1459.00
 Pressure, psig..... 35.0

TEST DESCRIPTION:

MATERIAL INPUT DATA:

	Steady-state period				
	lb/h	SCF/h	lb	SCF	Vol%
Biomass feed (as rec'd)	3390.0	--	4068.0	--	--
Steam to nozzle.....	0.0	0.00	0.00	0.00	--
Steam to ring.....	0.0	0.00	0.00	0.00	--
Total steam.....	0.0	0.00	0.0	0.00	0.0%
Air to nozzle.....	2278.6	29820.00	2734.31		
Air to ring.....	916.9	12000.00	1100.33		
Air to burner.....	0.0	0.00	0.00		
Total air.....	3195.5	41820.00	1100.3	0.00	0.0%
Oxygen (calc).....	669.5	7928.97	803.36	9514.76	19.0%
Nitrogen (calc).....	2495.1	33760.53	2994.09	40512.64	81.0%
Argon (calc).....	29.8	283.15	35.82	339.78	0.7%
CO2 (calc).....	1.1	9.08	1.27	10.90	0.0%
Neon, etc. (calc).....	0.1	0.8	0.12	0.99	0.0%
DRY gas input.....	3195.5	41982.55	3797.4	50027.40	100.0%
WET gas input.....	3195.5	41982.55	8732.4	50027.40	100.0%

MATERIAL OUTPUT DATA:

	lb/h	SCF/h	lb	SCF	Vol%
Char (cyclone discharge)....	89.7	--	107.6	--	--
Char (entrained).....	1.7	--	2.0	--	--
Total char (filter+cyc)	91.3	--	109.6	--	--
Condensate.....	908.5	--	1090.2	--	--
AQUEOUS phase.....	890.0	18718.39	1068.0	22462.07	--
OIL phase.....	18.5	--	22.2	--	--
N2 (as tracer).....	2495.1	33760.53	2994.1	40512.64	44.1%
DRY product gas.....	4499.9	57910.73	5399.9	69492.87	75.6%
WET product gas.....	5389.7	76629.11	6467.7	91954.94	100.0%
DRY N2-FREE product gas.	2004.8	24150.19	2405.8	28980.23	31.5%

SAMPLE SYSTEM DATA:

	Comments
Gas meter initial reading, cu ft.	495.14
Gas meter final reading, cu ft...	541.86
Gas meter temperature, °F.....	80.00
Gas meter pressure, psig.....	5.00
Meter correction factor.....	1.000
Total DRY gas sampled, SCF.....	60.29
% of reactor gas flow.....	0.09%
Char fines collected, g.....	0.80
Char carryover, lb/MSCF (wet)....	0.022
Condensate collected, g.....	429.04
AQUEOUS condensate, g.....	420.30
OIL in condensate, g.....	8.74
C6H6 in condensate OIL, g.....	0.48
Equiv C6H6 volume, SCF.....	0.005
Equiv steam volume, SCF.....	19.49
Total WET gas sampled, SCF....	79.78
Steam in wet product gas, vol%...	24.43

SOLID ANALYSES:

	-----Feed-----			----Char (cyclone)----			---Char (entrained)---		
	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)
PROXIMATE, wt%									
Moisture.....	31.62	0.00	0.00	0.42	0.00	0.00	0.00	-0.85	-1.22
V. M.....	58.38	85.38	88.54		0.00	0.00	13.33	13.39	41.27
Ash.....	2.44	3.57	0.00	67.28	67.56	0.00	35.73	35.88	1.00
Fixed carbon..	7.56	11.06	11.46				50.94	51.58	58.95
ULTIMATE, wt%									
C.....	33.34	48.75	50.55	29.11	29.23	90.10	55.15	55.38	170.72
H.....	3.96	5.79	6.00	0.47	0.47	1.45	4.42	4.44	13.69
N.....	0.15	0.22	0.23	0.34	0.34	1.05	0.00	0.00	0.00
S.....	0.02	0.03	0.03	0.03	0.03	0.09	0.00	0.00	0.00
O (by diff)...	28.47	41.64	43.18	2.36	2.37	7.31	4.43	4.45	13.72
Ash.....	2.44	3.57	---	67.28	67.56	---	35.58	35.73	---
HHV, Btu/lb.....	5473.82	8005.00	8301.36	0.00		0.00	0.00		0.00
C/ash ratio....	13.66			0.43			1.55		
INPUT, lb.....	4068.00	2781.70	2682.44	---	---	---			
OUTPUT, lb.....	---	---	---	109.61	109.15	35.40			

OIL ANALYSES:

ULTIMATE, dry wt%

C.....	93.83
H.....	5.48
N.....	0.61
S.....	0.08
O (by diff).....	0.00
Ash.....	0.00
HHV, Btu/lb.....	16813.52
H/C ratio.....	0.696

AQUEOUS CONDENSATE ANALYSES:

	wt% dry feed	Comments
TC, mg/L.....	0.000	
TOC, mg/L.....	0.000	
S, mg/L.....	17.00	0.001
N, mg/L.....	1100.00	0.042
equiv lb NH3.....	1.43	0.051
Cl, mg/L.....	26.00	0.001
equiv lb HCl.....	0.03	0.001
CN, mg/L.....		0.000
equiv lb HCN.....	0.00	0.000

MATERIAL BALANCE -- raw data

TEST BGF2/SP1

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	1356.08	161.06	6.12	0.835	1158.30	99.31	2781.70
Moisture	---	143.93	---	---	1142.33	---	1286.26
Air	0.35	---	2994.09	---	840.09	---	3834.53
Steam	---	0.00	---	---	0.00	---	0.00
Total	1356.42	304.99	3000.21	0.835	3140.72	99.31	7902.49

OUTPUT, lb	C	H	N	S	O+Ar	Ash	Total
Char, cyc (dry)	31.45	0.51	0.37	0.032	2.55	72.68	107.58
Moisture	---	0.05	---	---	0.40	---	0.45
Char, entr (dry)	1.13	0.09	0.00	0.000	0.09	0.73	2.03
Moisture	---	0.00	---	---	0.00	---	0.00
Product gas(dry)	880.10	59.14	2994.09	0.000	1466.60	---	5399.92
Oils/tars	20.84	1.22	0.14	0.018	0.00	0.00	22.21
Condensate water	0.00	119.58	1.17	0.018	947.39	---	1068.16
Total	933.51	180.59	2995.76	0.068	2417.03	73.41	6600.36

Out/In 68.8% 59.2% 99.9% 8.2% 77.0% 73.9% 83.5%

MATERIAL BALANCE -- adjusted data

TEST BGF2/SP1

Adjustments: 1.00000 1.00000 1.00000 1.0000 0.00

x cc out x air in x acu S x acu N + lb H

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	1356.08	161.06	6.12	0.83	1158.30	99.31	2781.70
Moisture	---	143.93	---	---	1142.33	---	1286.26
Air	0.35	---	2994.09	---	840.09	---	3834.53
Steam	---	0.00	---	---	0.00	---	0.00
Total	1356.42	304.99	3000.21	0.83	3140.72	99.31	7902.49

OUTPUT, lb	C	H	N	S	O+Ar	Ash	Total
Char, cyc (dry)	31.45	0.51	0.37	0.03	2.55	72.68	107.58
Moisture	---	0.05	---	---	0.40	---	0.45
Char, entr (dry)	1.13	0.09	0.00	0.00	0.09	0.73	2.03
Moisture	---	0.00	---	---	0.00	---	0.00
Product gas(dry)	880.10	59.14	2994.09	0.00	1466.60	---	5399.92
Oils/tars	20.84	1.22	0.14	0.02	0.00	0.00	22.21
Condensate water	0.00	119.58	1.17	0.02	947.39	---	1068.16
Total	933.51	180.59	2995.76	0.07	2417.03	73.41	6600.36

Out/In 68.8% 59.2% 99.9% 8.2% 77.0% 73.9% 83.5%

ENGINEERING DATA -- unadjusted

TEST BGF2/SP1

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	3390.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	669.46
Nitrogen, lb/h.....	2495.07
Air, scfm	696.98
Oxygen, lb/lb feed (wet).....	0.20
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	1.70
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft ³	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	89.65
Entrained Char (dry), lb/h	1.69
Condensate, lb/h.....	908.64
Aqueous Phase, lb/h.....	890.13
Oil Phase, lb/h.....	18.51
Dry Product Gas, lb/h.....	4499.94

ENGINEERING DATA, continued

TEST BGF2/SP1

Gas Yield, SCF (wet)/lb feed (wet).....	22.6
Gas Yield, SCF (dry)/lb feed (dry).....	25.0
Gas Heating Value, Btu/SCF (dry).....	129.0
Gas Heating Value, Btu/scf (dry N ₂ -free).....	309.3
Cold Gas Thermal Efficiency (dry N ₂ -free).....	0.403
Carbon Conversion to Gases and Liquids, %.....	66.4
Gas Heating Value, Btu/scf (dry incl oil).....	134.4
Cold Gas Thermal Efficiency (dry N ₂ -free).....	0.403
Hot Gas Thermal Efficiency (dry N ₂ -free).....	0.447

Biomass Gasifier Facility

PROJECT NUMBER.....
 TEST NUMBER..... BGF2/SP2
 DATE OF TEST..... 12/7/95
 Latest file update: 2/12/96 12:28 PM

Reactor I.D., inches.... 37.00

Sampling period..... 11:08:00 to 12:15:00
 Sampling basis..... 1.117 hours

TEST CONDITIONS:

Temperature, °F..... 1612.00
 Pressure, psig..... 86.0

TEST DESCRIPTION:

MATERIAL INPUT DATA:

	Steady-state period				
	lb/h	SCF/h	lb	SCF	Vol%
Biomass feed (as rec'd)	4167.0	--	4653.2	--	--
Steam to nozzle.....	0.0	0.00	0.00	0.00	--
Steam to ring.....	0.0	0.00	0.00	0.00	--
Total steam.....	0.0	0.00	0.0	0.00	0.0%
Air to nozzle.....	2351.9	30780.00	2626.34		
Air to ring.....	916.9	12000.00	1023.92		
Air to burner.....	0.0	0.00	0.00		
Total air.....	3268.9	42780.00	1023.9	0.00	0.0%
Oxygen (calc).....	684.8	8110.98	764.73	9057.26	19.0%
Nitrogen (calc).....	2552.3	34535.52	2850.12	38564.67	81.0%
Argon (calc).....	30.5	289.65	34.09	323.44	0.7%
CO2 (calc).....	1.1	9.29	1.20	10.37	0.0%
Neon, etc. (calc).....	0.1	0.8	0.11	0.94	0.0%
DRY gas input.....	3268.9	42946.29	3614.9	47621.93	100.0%
WET gas input.....	3268.9	42946.29	8289.0	47621.93	100.0%

MATERIAL OUTPUT DATA:

	lb/h	SCF/h	lb	SCF	Vol%
Char (cyclone discharge)....	72.5	--	81.0	--	--
Char (entrained).....	6.1	--	6.8	--	--
Total char (filter+cyc)	78.6	--	87.8	--	--
Condensate.....	852.7	--	952.2	--	--
AQUEOUS phase.....	825.6	17363.27	921.9	19388.98	--
OIL phase.....	27.1	--	30.3	--	--
N2 (as tracer).....	2552.3	34535.52	2850.1	38564.67	45.7%
DRY product gas.....	4491.7	58229.83	5015.7	65023.31	77.0%
WET product gas.....	5317.0	75593.10	5937.4	84412.30	100.0%
DRY N2-FREE product gas.	1939.3	23694.31	2165.6	26458.65	31.3%

SAMPLE SYSTEM DATA:

	Comments
Gas meter initial reading, cu ft.	541.91
Gas meter final reading, cu ft...	609.17
Gas meter temperature, °F.....	80.00
Gas meter pressure, psig.....	5.00
Meter correction factor.....	1.000
Total DRY gas sampled, SCF.....	86.80
% of reactor gas flow.....	0.13%
Char fines collected, g.....	4.10
Char carryover, lb/MSCF (wet)....	0.080
Condensate collected, g.....	576.55
AQUEOUS condensate, g.....	558.20
OIL in condensate, g.....	18.35
C6H6 in condensate OIL, g.....	0.94
Equiv C6H6 volume, SCF.....	0.010
Equiv steam volume, SCF.....	25.88
Total WET gas sampled, SCF....	112.68
Steam in wet product gas, vol%...	22.97

SOLID ANALYSES:

PROXIMATE, wt%	-----Feed-----			----Char (cyclone)----			---Char (entrained)---		
	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)
Moisture.....	26.30	0.00	0.00	0.42	0.00	0.00	0.34	-0.85	-1.22
V. M.....	63.22	85.78	89.97		0.00	0.00	4.06	4.08	16.04
Ash.....	3.43	4.65	0.00	74.27	74.58	0.00	6.24	6.27	1.00
Fixed carbon..	7.05	9.57	10.03				89.36	90.51	84.18
ULTIMATE, wt%									
C.....	35.24	47.81	50.15	26.14	26.25	103.27	90.64	91.02	358.06
H.....	4.18	5.67	5.95	0.32	0.32	1.26	1.34	1.35	5.31
N.....	0.20	0.27	0.28	0.27	0.27	1.06	0.00	0.00	0.00
S.....	0.03	0.04	0.04	0.02	0.02	0.08	0.00	0.00	0.00
O (by diff)...	30.62	41.55	43.58	-1.43	-1.44	-5.66	1.36	1.37	5.39
Ash.....	3.43	4.66	---	74.27	74.58	---	6.23	6.26	---
HHV, Btu/lb....	5792.82	7860.00	8244.18	0.00		0.00	0.00		0.00
C/ash ratio....	10.26			0.35			14.54		
INPUT, lb.....	4653.15	3429.37	3269.77	---	---	---			
OUTPUT, lb.....	---	---	---	87.77	87.40	22.21			

OIL ANALYSES:

ULTIMATE, dry wt%

C.....	86.16	
H.....	4.81	
N.....	0.21	
S.....	0.05	
O (by diff).....	8.77	
Ash.....	0.00	
HHV, Btu/lb.....	14933.64	
H/C ratio.....	0.665	

AQUEOUS CONDENSATE ANALYSES:

	wt% dry feed	Comments
TC, mg/L.....	0.000	
TOC, mg/L.....	0.000	
S, mg/L.....	13.00	0.000
N, mg/L.....	1600.00	0.043
equiv lb NH3.....	1.79	0.052
Cl, mg/L.....	366.00	0.010
equiv lb HCl.....	0.35	0.010
CN, mg/L.....		0.000
equiv lb HCN.....	0.00	0.000

MATERIAL BALANCE -- raw data

TEST BGF2/SP2

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	1639.58	194.45	9.26	1.372	1424.90	159.81	3429.37
Moisture	---	136.94	---	---	1086.80	---	1223.74
Air	0.33	---	2850.12	---	799.70	---	3650.15
Steam	---	0.00	---	---	0.00	---	0.00
Total	1639.91	331.38	2859.38	1.372	3311.41	159.81	8303.26

OUTPUT, lb							
Char, cyc (dry)	21.26	0.26	0.22	0.016	-1.17	60.41	81.00
Moisture	---	0.04	---	---	0.30	---	0.34
Char, entr (dry)	6.16	0.09	0.00	0.000	0.09	0.42	6.77
Moisture	---	0.00	---	---	0.02	---	0.02
Product gas(dry)	756.11	55.61	2850.12	0.000	1353.86	---	5015.71
Oils/tars	26.11	1.46	0.06	0.015	2.66	0.00	30.31
Condensate water	0.00	103.25	1.47	0.012	817.37	---	922.11
Total	809.65	160.71	2851.88	0.043	2173.14	60.83	6056.26

Out/In	49.4%	48.5%	99.7%	3.2%	65.6%	38.1%	72.9%
--------	-------	-------	-------	------	-------	-------	-------

MATERIAL BALANCE -- adjusted data

TEST BGF2/SP2

Adjustments:

1.00000	1.00000	1.00000	1.0000	0.00
---------	---------	---------	--------	------

x cc out	x air in	x agu S	x agu N	+ lb H
----------	----------	---------	---------	--------

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	1639.58	194.45	9.26	1.37	1424.90	159.81	3429.37
Moisture	---	136.94	---	---	1086.80	---	1223.74
Air	0.33	---	2850.12	---	799.70	---	3650.15
Steam	---	0.00	---	---	0.00	---	0.00
Total	1639.91	331.38	2859.38	1.37	3311.41	159.81	8303.26

OUTPUT, lb							
Char, cyc (dry)	21.26	0.26	0.22	0.02	-1.17	60.41	81.00
Moisture	---	0.04	---	---	0.30	---	0.34
Char, entr (dry)	6.16	0.09	0.00	0.00	0.09	0.42	6.77
Moisture	---	0.00	---	---	0.02	---	0.02
Product gas(dry)	756.11	55.61	2850.12	0.00	1353.86	---	5015.71
Oils/tars	26.11	1.46	0.06	0.02	2.66	0.00	30.31
Condensate water	0.00	103.25	1.47	0.01	817.37	---	922.11
Total	809.65	160.71	2851.88	0.04	2173.14	60.83	6056.26

Out/In	49.4%	48.5%	99.7%	3.2%	65.6%	38.1%	72.9%
--------	-------	-------	-------	------	-------	-------	-------

ENGINEERING DATA -- unadjusted

TEST BGF2/SP2

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	4167.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	684.83
Nitrogen, lb/h.....	2552.35
Air, scfm	712.98
Oxygen, lb/lb feed (wet).....	0.16
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	0.93
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	72.54
Entrained Char (dry), lb/h	6.06
Condensate, lb/h.....	852.91
Aqueous Phase, lb/h.....	825.77
Oil Phase, lb/h.....	27.14
Dry Product Gas, lb/h.....	4491.68

ENGINEERING DATA, continued

TEST BGF2/SP2

Gas Yield, SCF (wet)/lb feed (wet).....	18.1
Gas Yield, SCF (dry)/lb feed (dry).....	19.0
Gas Heating Value, Btu/SCF (dry).....	112.7
Gas Heating Value, Btu/scf (dry N2-free).....	277.1
Cold Gas Thermal Efficiency (dry N2-free).....	0.272
Carbon Conversion to Gases and Liquids, %.....	47.7
Gas Heating Value, Btu/scf (dry incl oil).....	119.7
Cold Gas Thermal Efficiency (dry N2-free).....	0.272
Hot Gas Thermal Efficiency (dry N2-free).....	0.309

Biomass Gasifier Facility

PROJECT NUMBER.....
 TEST NUMBER..... BGF2/SP3
 DATE OF TEST..... 12/7/95
 Latest file update: 2/14/96 3:28 PM

Reactor I.D., inches.... 37.00

Sampling period..... 18:30:00 to 19:30:00
 Sampling basis..... 1.000 hours

TEST CONDITIONS:
 Temperature, °F..... 1575.00
 Pressure, psig..... 73.0

TEST DESCRIPTION:

MATERIAL INPUT DATA:

	Steady-state period				
	lb/h	SCF/h	lb	SCF	Vol%
Biomass feed (as rec'd)	3441.0	--	3441.0	--	--
Steam to nozzle.....	0.0	0.00	0.00	0.00	--
Steam to ring.....	200.0	4206.44	200.00	4206.44	--
Total steam.....	200.0	4206.44	200.0	4206.44	15.1%
Air to nozzle.....	1806.4	23640.00	1806.37		
Air to ring.....	0.0	0.00	0.00		
Air to burner.....	0.0	0.00	0.00		
Total air.....	1806.4	23640.00	0.0	0.00	0.0%
Oxygen (calc).....	378.4	4482.08	378.43	4482.08	16.1%
Nitrogen (calc).....	1410.4	19084.15	1410.41	19084.15	68.7%
Argon (calc).....	16.9	160.06	16.87	160.06	0.6%
CO2 (calc).....	0.6	5.13	0.60	5.13	0.0%
Neon, etc. (calc).....	0.1	0.5	0.05	0.47	0.0%
DRY gas input.....	1806.4	23731.89	1788.8	23566.23	84.9%
WET gas input.....	2006.4	27938.33	3795.2	27772.67	100.0%

MATERIAL OUTPUT DATA:

	lb/h	SCF/h	lb	SCF	Vol%
Char (cyclone discharge)....	108.0	--	108.0	--	--
Char (entrained).....	0.0	--	0.0	--	--
Total char (filter+cyc)	108.0	--	108.0	--	--
Condensate.....	0.0	--	0.0	--	--
AQUEOUS phase.....	0.0	0.00	0.0	0.00	--
OIL phase.....	0.0	--	0.0	--	--
N2 (as tracer).....	1410.4	19084.15	1410.4	19084.15	51.6%
DRY product gas.....	2720.9	37020.14	2720.9	37020.14	100.0%
WET product gas.....	2720.9	37020.14	2720.9	37020.14	100.0%
DRY N2-FREE product gas.	1310.5	17935.99	1310.5	17935.99	48.4%

SAMPLE SYSTEM DATA:

	Comments
Gas meter initial reading, cu ft.	0.00
Gas meter final reading, cu ft...	1.00
Gas meter temperature, °F.....	80.00
Gas meter pressure, psig.....	5.00
Meter correction factor.....	1.000
Total DRY gas sampled, SCF....	1.29
% of reactor gas flow.....	0.00%
Char fines collected, g.....	0.00
Char carryover, lb/MSCF (wet)....	0.000
Condensate collected, g.....	0.00
AQUEOUS condensate, g.....	0.00
OIL in condensate, g.....	0.00
C6H6 in condensate OIL, g.....	0.00
Equiv C6H6 volume, SCF.....	0.000
Equiv steam volume, SCF.....	0.00
Total WET gas sampled, SCF....	1.29
Steam in wet product gas, vol%...	0.00

SOLID ANALYSES:

PROXIMATE, wt%	-----Feed-----		---Char (cyclone)---			---Char (entrained)---			(maf)
	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	(maf)	(rec'd)	(dry)	
Moisture.....	16.85	0.00	0.00	0.73	0.00	0.00	0.34	-0.85	-1.22
V. M.....	69.24	83.27	87.50	0.77	0.78	2.43	4.06	4.09	12.83
Ash.....	4.02	4.83	0.00	67.62	68.12	0.00	6.24	6.29	1.00
Fixed carbon..	9.89	11.89	12.50	30.88	31.11	97.57	89.36	90.48	87.39
ULTIMATE, wt%									
C.....	39.63	47.66	50.08	32.39	32.63	100.77	90.36	91.02	281.10
H.....	4.71	5.66	5.95	0.40	0.40	1.24	1.34	1.35	4.17
N.....	0.17	0.21	0.22	0.35	0.35	1.08	0.00	0.00	0.00
S.....	0.02	0.03	0.03	0.02	0.02	0.06	0.00	0.00	0.00
O (by diff)...	34.60	41.61	43.72	-1.01	-1.02	-3.15	1.36	1.37	4.23
Ash.....	4.02	4.83	---	67.13	67.62	---	6.21	6.26	---
HHV, Btu/lb.....	6556.38	7885.00	8285.17	0.00		0.00	0.00		0.00
C/ash ratio....	9.87			0.48			14.54		
INPUT, lb.....	3441.00	2861.19	2722.86	---	---	---			
OUTPUT, lb.....	---	---	---	108.00	107.21	34.18			

OIL ANALYSES:

ULTIMATE, dry wt%

C.....	0.00	
H.....	0.00	
N.....	0.00	
S.....	0.00	
O (by diff).....	100.00	
Ash.....	0.00	
HHV, Btu/lb.....	-4438.50	
H/C ratio.....	#DIV/0!	

AQUEOUS CONDENSATE ANALYSES:

	wt% dry feed	Comments
TC, mg/L.....	0.000	
TOC, mg/L.....	0.000	
S, mg/L.....	0.00	0.000
N, mg/L.....	0.00	0.000
equiv lb NH3.....	0.00	0.000
Cl, mg/L.....	#VALUE!	
equiv lb HCl.....	#VALUE!	#VALUE!
CN, mg/L.....		0.000
equiv lb HCN.....	0.00	0.000

MATERIAL BALANCE -- raw data

TEST BGF2/SP3

INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	1363.64	161.94	6.01	0.858	1190.54	138.20	2861.19
Moisture	---	64.88	---	---	514.91	---	579.79
Air	0.16	---	1410.41	---	395.74	---	1806.32
Steam	---	22.38	---	---	177.61	---	199.99
Total	1363.81	249.20	1416.42	0.858	2278.81	138.20	5447.29
OUTPUT, lb							
Char, cyc (dry)	35.24	0.43	0.38	0.022	-1.10	73.03	108.00
Moisture	---	0.09	---	---	0.70	---	0.79
Char, entr (dry)	0.00	0.00	0.00	0.000	0.00	0.00	0.00
Moisture	---	0.00	---	---	0.00	---	0.00
Product gas(dry)	473.48	49.54	1410.41	0.000	787.49	---	2720.92
Oils/tars	0.00	0.00	0.00	0.000	0.00	0.00	0.00
Condensate water	0.00	0.00	0.00	0.000	0.00	---	0.00
Total	508.72	50.06	1410.79	0.022	787.09	73.03	2829.70
Out/In	37.3%	20.1%	99.6%	2.5%	34.5%	52.8%	51.9%

MATERIAL BALANCE -- adjusted data

TEST BGF2/SP3

Adjustments:							
	1.00000	1.00000	1.00000	1.0000	0.00		
	x cc out	x air in	x acu S	x acu N	+ lb H		
INPUT, lb	C	H	N	S	O+Ar	Ash	Total
Biomass (dry)	1363.64	161.94	6.01	0.86	1190.54	138.20	2861.19
Moisture	---	64.88	---	---	514.91	---	579.79
Air	0.16	---	1410.41	---	395.74	---	1806.32
Steam	---	22.38	---	---	177.61	---	199.99
Total	1363.81	249.20	1416.42	0.86	2278.81	138.20	5447.29
OUTPUT, lb							
Char, cyc (dry)	35.24	0.43	0.38	0.02	-1.10	73.03	108.00
Moisture	---	0.09	---	---	0.70	---	0.79
Char, entr (dry)	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Moisture	---	0.00	---	---	0.00	---	0.00
Product gas(dry)	473.48	49.54	1410.41	0.00	787.49	---	2720.92
Oils/tars	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Condensate water	0.00	0.00	0.00	0.00	0.00	---	0.00
Total	508.72	50.06	1410.79	0.02	787.09	73.03	2829.70
Out/In	37.3%	20.1%	99.6%	2.5%	34.5%	52.8%	51.9%

ENGINEERING DATA -- unadjusted

TEST BGF2/SP3

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	3441.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	200.00
Oxygen, lb/h.....	378.43
Nitrogen, lb/h.....	1410.41
Air, scfm	393.99
Oxygen, lb/lb feed (wet).....	0.11
Steam, lb/lb feed (wet).....	0.06
Superficial Gas Velocity, ft/s...	0.68
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft ³	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	108.00
Entrained Char (dry), lb/h	0.00
Condensate, lb/h.....	0.00
Aqueous Phase, lb/h.....	0.00
Oil Phase, lb/h.....	0.00
Dry Product Gas, lb/h.....	2720.92

ENGINEERING DATA, continued

TEST BGF2/SP3

Gas Yield, SCF (wet)/lb feed (wet).....	10.8
Gas Yield, SCF (dry)/lb feed (dry).....	12.9
Gas Heating Value, Btu/SCF (dry).....	155.5
Gas Heating Value, Btu/scf (dry N2-free).....	320.9
Cold Gas Thermal Efficiency (dry N2-free).....	0.255
Carbon Conversion to Gases and Liquids, %.....	34.7
Gas Heating Value, Btu/scf (dry incl oil).....	155.5
Cold Gas Thermal Efficiency (dry N2-free).....	0.255
Hot Gas Thermal Efficiency (dry N2-free).....	0.282

Appendix C
Mass Balance Spreadsheet -- IGT Adjustment

ENGINEERING DATA -- adjusted

TEST BGF1/SP3

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	2242.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	913.10
Nitrogen, lb/h.....	3403.09
Air, scfm	950.63
Oxygen, lb/lb feed (wet).....	0.41
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	2.41
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	80.97
Entrained Char (dry), lb/h	7.57
Condensate, lb/h.....	1120.54
Aqueous Phase, lb/h.....	1078.45
Oil Phase, lb/h.....	42.08
Dry Product Gas, lb/h.....	5584.49

ENGINEERING DATA, continued

TEST BGF1/SP3

Gas Yield, SCF (wet)/lb feed (wet).....	41.3
Gas Yield, SCF (dry)/lb feed (dry).....	42.3
Gas Heating Value, Btu/SCF (dry).....	85.1
Gas Heating Value, Btu/scf (dry N2-free).....	244.1
Cold Gas Thermal Efficiency (dry N2-free).....	0.451
Carbon Conversion to Gases and Liquids, %.....	96.3
Gas Heating Value, Btu/scf (dry incl oil).....	94.2
Cold Gas Thermal Efficiency (dry N2-free).....	0.451
Hot Gas Thermal Efficiency (dry N2-free).....	0.522

ENGINEERING DATA -- adjusted

TEST BGF1/SP4

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	2227.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	973.29
Nitrogen, lb/h.....	3627.41
Air, scfm	1013.29
Oxygen, lb/lb feed (wet).....	0.44
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	2.15
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	97.69
Entrained Char (dry), lb/h	2.33
Condensate, lb/h.....	925.57
Aqueous Phase, lb/h.....	882.05
Oil Phase, lb/h.....	43.53
Dry Product Gas, lb/h.....	5935.66

ENGINEERING DATA, continued

TEST BGF1/SP4

Gas Yield, SCF (wet)/lb feed (wet).....	42.5
Gas Yield, SCF (dry)/lb feed (dry).....	42.4
Gas Heating Value, Btu/SCF (dry).....	91.1
Gas Heating Value, Btu/scf (dry N2-free).....	256.7
Cold Gas Thermal Efficiency (dry N2-free).....	0.463
Carbon Conversion to Gases and Liquids, %.....	96.5
Gas Heating Value, Btu/scf (dry incl oil).....	100.1
Cold Gas Thermal Efficiency (dry N2-free).....	0.463
Hot Gas Thermal Efficiency (dry N2-free).....	0.530

ENGINEERING DATA -- adjusted

TEST BGF1/SP5

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	2460.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	722.48
Nitrogen, lb/h.....	2692.65
Air, scfm	752.17
Oxygen, lb/lb feed (wet).....	0.29
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	2.14
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	74.71
Entrained Char (dry), lb/h	1.74
Condensate, lb/h.....	1365.42
Aqueous Phase, lb/h.....	1341.70
Oil Phase, lb/h.....	23.72
Dry Product Gas, lb/h.....	4742.01

ENGINEERING DATA, continued

TEST BGF1/SP5

Gas Yield, SCF (wet)/lb feed (wet).....	35.5
Gas Yield, SCF (dry)/lb feed (dry).....	37.8
Gas Heating Value, Btu/SCF (dry).....	124.8
Gas Heating Value, Btu/scf (dry N2-free).....	305.5
Cold Gas Thermal Efficiency (dry N2-free).....	0.566
Carbon Conversion to Gases and Liquids, %.....	97.5
Gas Heating Value, Btu/scf (dry incl oil).....	130.7
Cold Gas Thermal Efficiency (dry N2-free).....	0.566
Hot Gas Thermal Efficiency (dry N2-free).....	0.632

ENGINEERING DATA -- adjusted

TEST BGF2/SP1

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	3390.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	975.41
Nitrogen, lb/h.....	3635.32
Air, scfm	1015.50
Oxygen, lb/lb feed (wet).....	0.29
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	1.70
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	121.21
Entrained Char (dry), lb/h	2.47
Condensate, lb/h.....	1916.77
Aqueous Phase, lb/h.....	1889.81
Oil Phase, lb/h.....	26.96
Dry Product Gas, lb/h.....	6556.41

ENGINEERING DATA, continued

TEST BGF2/SP1

Gas Yield, SCF (wet)/lb feed (wet).....	35.4
Gas Yield, SCF (dry)/lb feed (dry).....	36.4
Gas Heating Value, Btu/SCF (dry).....	129.0
Gas Heating Value, Btu/scf (dry N2-free).....	309.3
Cold Gas Thermal Efficiency (dry N2-free).....	0.587
Carbon Conversion to Gases and Liquids, %.....	96.8
Gas Heating Value, Btu/scf (dry incl oil).....	134.4
Cold Gas Thermal Efficiency (dry N2-free).....	0.587
Hot Gas Thermal Efficiency (dry N2-free).....	0.652

ENGINEERING DATA -- adjusted

TEST BGF2/SP2

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	4167.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	1376.51
Nitrogen, lb/h.....	5130.22
Air, scfm	1433.09
Oxygen, lb/lb feed (wet).....	0.33
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	0.93
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	190.77
Entrained Char (dry), lb/h	12.19
Condensate, lb/h.....	1840.79
Aqueous Phase, lb/h.....	1786.25
Oil Phase, lb/h.....	54.55
Dry Product Gas, lb/h.....	9028.28

ENGINEERING DATA, continued

TEST BGF2/SP2

Gas Yield, SCF (wet)/lb feed (wet).....	36.9
Gas Yield, SCF (dry)/lb feed (dry).....	38.1
Gas Heating Value, Btu/SCF (dry).....	112.7
Gas Heating Value, Btu/scf (dry N2-free).....	277.1
Cold Gas Thermal Efficiency (dry N2-free).....	0.547
Carbon Conversion to Gases and Liquids, %.....	95.9
Gas Heating Value, Btu/scf (dry incl oil).....	119.7
Cold Gas Thermal Efficiency (dry N2-free).....	0.547
Hot Gas Thermal Efficiency (dry N2-free).....	0.621

ENGINEERING DATA -- adjusted

TEST BGF2/SP3

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	3441.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	200.00
Oxygen, lb/h.....	1036.91
Nitrogen, lb/h.....	3864.53
Air, scfm	1079.53
Oxygen, lb/lb feed (wet).....	0.30
Steam, lb/lb feed (wet).....	0.06
Superficial Gas Velocity, ft/s...	0.68
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	204.34
Entrained Char (dry), lb/h	0.00
Condensate, lb/h.....	1894.84
Aqueous Phase, lb/h.....	1894.84
Oil Phase, lb/h.....	0.00
Dry Product Gas, lb/h.....	7455.31

ENGINEERING DATA, continued

TEST BGF2/SP3

Gas Yield, SCF (wet)/lb feed (wet).....	37.0
Gas Yield, SCF (dry)/lb feed (dry).....	35.5
Gas Heating Value, Btu/SCF (dry).....	155.5
Gas Heating Value, Btu/scf (dry N2-free).....	320.9
Cold Gas Thermal Efficiency (dry N2-free).....	0.699
Carbon Conversion to Gases and Liquids, %.....	95.1
Gas Heating Value, Btu/scf (dry incl oil).....	155.5
Cold Gas Thermal Efficiency (dry N2-free).....	0.699
Hot Gas Thermal Efficiency (dry N2-free).....	0.774

Appendix D
Mass Balance Spreadsheet -- HNEI Adjustment

ENGINEERING DATA -- adjusted

TEST BGF1/SP4

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	2227.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	1092.47
Nitrogen, lb/h.....	4071.59
Air, scfm	1137.37
Oxygen, lb/lb feed (wet).....	0.49
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	2.60
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	138.57
Entrained Char (dry), lb/h	2.62
Condensate, lb/h.....	1028.94
Aqueous Phase, lb/h.....	980.08
Oil Phase, lb/h.....	48.86
Dry Product Gas, lb/h.....	6662.47

ENGINEERING DATA, continued

TEST BGF1/SP4

Gas Yield, SCF (wet)/lb feed (wet).....	47.6
Gas Yield, SCF (dry)/lb feed (dry).....	47.6
Gas Heating Value, Btu/SCF (dry).....	91.1
Gas Heating Value, Btu/scf (dry N2-free).....	256.7
Cold Gas Thermal Efficiency (dry N2-free).....	0.520
Carbon Conversion to Gases and Liquids, %.....	108.3
Gas Heating Value, Btu/scf (dry incl oil).....	100.1
Cold Gas Thermal Efficiency (dry N2-free).....	0.520
Hot Gas Thermal Efficiency (dry N2-free).....	0.595

ENGINEERING DATA -- adjusted

TEST BGF1/SP5

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	2460.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	775.48
Nitrogen, lb/h.....	2890.20
Air, scfm	807.36
Oxygen, lb/lb feed (wet).....	0.32
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	1.69
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	117.46
Entrained Char (dry), lb/h	1.87
Condensate, lb/h.....	1048.49
Aqueous Phase, lb/h.....	1023.03
Oil Phase, lb/h.....	25.46
Dry Product Gas, lb/h.....	5089.93

ENGINEERING DATA, continued

TEST BGF1/SP5

Gas Yield, SCF (wet)/lb feed (wet).....	35.6
Gas Yield, SCF (dry)/lb feed (dry).....	40.6
Gas Heating Value, Btu/SCF (dry).....	124.8
Gas Heating Value, Btu/scf (dry N2-free).....	305.5
Cold Gas Thermal Efficiency (dry N2-free).....	0.607
Carbon Conversion to Gases and Liquids, %.....	104.6
Gas Heating Value, Btu/scf (dry incl oil).....	130.7
Cold Gas Thermal Efficiency (dry N2-free).....	0.607
Hot Gas Thermal Efficiency (dry N2-free).....	0.679

ENGINEERING DATA -- adjusted

TEST BGF2/SP1

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	3390.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	1037.67
Nitrogen, lb/h.....	3867.36
Air, scfm	1080.32
Oxygen, lb/lb feed (wet).....	0.31
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	2.64
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	89.65
Entrained Char (dry), lb/h	2.63
Condensate, lb/h.....	1408.40
Aqueous Phase, lb/h.....	1379.71
Oil Phase, lb/h.....	28.69
Dry Product Gas, lb/h.....	6974.90

ENGINEERING DATA, continued

TEST BGF2/SP1

Gas Yield, SCF (wet)/lb feed (wet).....	35.0
Gas Yield, SCF (dry)/lb feed (dry).....	38.7
Gas Heating Value, Btu/SCF (dry).....	129.0
Gas Heating Value, Btu/scf (dry N2-free).....	309.3
Cold Gas Thermal Efficiency (dry N2-free).....	0.624
Carbon Conversion to Gases and Liquids, %.....	103.0
Gas Heating Value, Btu/scf (dry incl oil).....	134.4
Cold Gas Thermal Efficiency (dry N2-free).....	0.624
Hot Gas Thermal Efficiency (dry N2-free).....	0.693

ENGINEERING DATA -- adjusted

TEST BGF2/SP2

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	4167.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	0.00
Oxygen, lb/h.....	1499.78
Nitrogen, lb/h.....	5589.64
Air, scfm	1561.42
Oxygen, lb/lb feed (wet).....	0.36
Steam, lb/lb feed (wet).....	0.00
Superficial Gas Velocity, ft/s...	2.04
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	72.54
Entrained Char (dry), lb/h	13.28
Condensate, lb/h.....	1867.86
Aqueous Phase, lb/h.....	1808.43
Oil Phase, lb/h.....	59.43
Dry Product Gas, lb/h.....	9836.78

ENGINEERING DATA, continued

TEST BGF2/SP2

Gas Yield, SCF (wet)/lb feed (wet).....	39.7
Gas Yield, SCF (dry)/lb feed (dry).....	41.5
Gas Heating Value, Btu/SCF (dry).....	112.7
Gas Heating Value, Btu/scf (dry N2-free).....	277.1
Cold Gas Thermal Efficiency (dry N2-free).....	0.596
Carbon Conversion to Gases and Liquids, %.....	104.5
Gas Heating Value, Btu/scf (dry incl oil).....	119.7
Cold Gas Thermal Efficiency (dry N2-free).....	0.596
Hot Gas Thermal Efficiency (dry N2-free).....	0.676

ENGINEERING DATA -- adjusted

TEST BGF2/SP3

MATERIAL INPUT DATA

Biomass (wet), lb/h.....	3441.00
Steam to Nozzle, lb/h.....	0.00
Steam to Ring, lb/h.....	200.00
Oxygen, lb/h.....	1131.52
Nitrogen, lb/h.....	4217.14
Air, scfm	1178.02
Oxygen, lb/lb feed (wet).....	0.33
Steam, lb/lb feed (wet).....	0.06
Superficial Gas Velocity, ft/s...	1.83
Fluidized Bed Height, ft.....	
Fluidized Bed Density, lb/ft3....	

MATERIAL OUTPUT DATA

Cyclone Char (dry), lb/h.....	108.00
Entrained Char (dry), lb/h	0.00
Condensate, lb/h.....	0.00
Aqueous Phase, lb/h.....	0.00
Oil Phase, lb/h.....	0.00
Dry Product Gas, lb/h.....	8135.54

ENGINEERING DATA, continued

TEST BGF2/SP3

Gas Yield, SCF (wet)/lb feed (wet).....	32.2
Gas Yield, SCF (dry)/lb feed (dry).....	38.7
Gas Heating Value, Btu/SCF (dry).....	155.5
Gas Heating Value, Btu/scf (dry N2-free).....	320.9
Cold Gas Thermal Efficiency (dry N2-free).....	0.763
Carbon Conversion to Gases and Liquids, %.....	103.8
Gas Heating Value, Btu/scf (dry incl oil).....	155.5
Cold Gas Thermal Efficiency (dry N2-free).....	0.763
Hot Gas Thermal Efficiency (dry N2-free).....	0.844