

RMIS View/Print Document Cover Sheet

This document was retrieved from the Documentation and Records Management (DRM) ISEARCH System. It is intended for Information only and may not be the most recent or updated version. Contact a Document Service Center (see Hanford Info for locations) if you need additional retrieval information.

Accession #: D196229548

Document #: WHC-SA-3024-FP

Title/Desc:

REPORT ON THE DESIGN OF FREEZE PROTECTION FOR  
HANFORD NUCLEAR RESERVATION FIRE SUPPRESSION SYS

Pages: 35

# Report on the Design of Freeze Protection for Hanford Nuclear Reservation Fire Suppression Systems

S. M. Korslund

Date Published  
February 1996

To Be Presented at  
DOE Fire Protection Conference  
Chicago, Illinois  
April 29-May 2, 1996

Prepared for the U.S. Department of Energy  
Assistant Secretary for Environmental Management



**Westinghouse**  
**Hanford Company**

P.O. Box 1970  
Richland, Washington

Management and Operations Contractor for the  
U.S. Department of Energy under Contract DE-AC06-87RL10930

---

Copyright License By acceptance of this article, the publisher and/or recipient acknowledges the U.S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper.

Approved for public release; distribution is unlimited

THIS PAGE INTENTIONALLY  
LEFT BLANK

2/28/96

# INFORMATION RELEASE REQUEST - (Long Form)

(GRAY SHADED AREAS NOT TO BE FILLED IN BY INITIATOR)

### 1. COMPLETE THIS SECTION FOR ALL DOCUMENTS

A. Information Category		B. Document ID Number (include rev., vol., etc.)
Speech or Presentation <input checked="" type="checkbox"/> Full Paper <input type="checkbox"/> Summary <input type="checkbox"/> Abstract <input type="checkbox"/> Visual Aid <input type="checkbox"/> Other _____	<input type="checkbox"/> Journal Article <input type="checkbox"/> Multimedia Presentation <input type="checkbox"/> Software	WHC-SA-3024-FP, REV. 0
		C. List attachments (i.e., copyright permission, copyright transfer)
		DATA SHEET FOR RTD-G ROOM TEMPERATURE DETECTOR DATA SHEET FOR RTD SERIES ROOM TEMPERATURE DETECTOR DATA SHEET FOR RTS ROOM TEMPERATURE DETECTOR FS-0025; PROCEDURE FOR PROGRAMMING AND TESTING, BILL OF MATERIAL, CVI 12244, SHEET 69

D. Document Title	E. WHC Project or Program
REPORT ON THE DESIGN OF FREEZE PROTECTION FOR THE HANFORD NUCLEAR RESERVATION FIRE SUPPRESSION SYSTEMS	PSS/HFD/FP

F. New or novel (patentable) subject matter? If "Yes", has disclosure been submitted by WHC? <input type="checkbox"/> No or Yes If "Yes", Disclosure No(s): _____	<input checked="" type="checkbox"/> No or Yes	G. Information received from others in confidence, such as proprietary data, and/or inventions? <input checked="" type="checkbox"/> No or Yes If "Yes", contact WHC General Counsel.
H. Copyrights? <input checked="" type="checkbox"/> No or Yes If "Yes", attach permission.	I. Trademarks? <input checked="" type="checkbox"/> No or Yes If "Yes", identify in document.	

### 2. COMPLETE THIS SECTION FOR ALL DOCUMENTS REQUIRING SUBMISSION TO OSTI

A. Unclassified Category	B. Budget & Reporting Code
UC - 630	B&R - YN0100000

### 3. COMPLETE THIS SECTION ONLY FOR A JOURNAL SUBMISSION

A. Title of Journal
---------------------

### 4. COMPLETE THIS SECTION ONLY FOR A SPEECH OR PRESENTATION

A. Title for Conference or Meeting	B. Group or Society Sponsoring
DOE FIRE PROTECTION CONFERENCE	DOE FIRE PROTECTION GROUP
C. Date(s) of Conference or Meeting	D. City/State
4/29/96-5/02/96	CHICAGO, ILLINOIS
E. Will material be published in proceedings? <input checked="" type="checkbox"/> No or Yes	
Will material be handed out? <input checked="" type="checkbox"/> No or Yes	

### 5. REVIEWS

Reviewers	Yes	Signature indicates Approval as Requested unless otherwise indicated	Limited-Use Info.
		Name (print)	Signature/Date
General Counsel	<input checked="" type="checkbox"/>	A.M. Schreiber	A.M. Schreiber 02/14/96
DOE-RL	<input checked="" type="checkbox"/>	Craig P. Christensen	Craig P. Christensen 2/22/96
Communications	<input type="checkbox"/>		
Applied Technology-Export Controlled Information or International Program	<input type="checkbox"/>		
Other	<input type="checkbox"/>		
Other	<input type="checkbox"/>		

6. Applied Technology Material Referenced	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes
-------------------------------------------	---------------------------------------------------------------------


7. Release Level	<input checked="" type="checkbox"/> Public <input type="checkbox"/> Limited Distribution
------------------	------------------------------------------------------------------------------------------

B. Author/Requestor	STEVEN M KORSLUND <i>Steven M Korslund</i> 2/28/96 (Print and Sign) Date
---------------------	-----------------------------------------------------------------------------

9. Responsible Manager	W (MAC) KNIGHT <i>W.M. Knight</i> 2/28/96 (Print and Sign) Date
------------------------	--------------------------------------------------------------------

**INFORMATION RELEASE ADMINISTRATION APPROVAL**

IRA Approval is required before release. Release is contingent upon resolution of mandatory comments. NOTE: This block for IRA use only.



Date Cancelled \_\_\_\_\_ Date Disapproved \_\_\_\_\_

10. LEGENDS/NOTICES/MARKINGS (Required by WHC-CM-3-4 or Reviewer). Reviewer indicates applicable markings to be affixed or removed.

	Affix	Remove	Initials		Affix	Remove	Initials
Applied Technology	<input type="checkbox"/>	<input type="checkbox"/>	_____	Official Use Only	<input type="checkbox"/>	<input type="checkbox"/>	_____
Availability - OSTI	<input type="checkbox"/>	<input type="checkbox"/>	_____	Patent Status	<input type="checkbox"/>	<input type="checkbox"/>	_____
Availability - ESTSC	<input type="checkbox"/>	<input type="checkbox"/>	_____	Predecisional Information	<input type="checkbox"/>	<input type="checkbox"/>	_____
Availability - NTIS	<input type="checkbox"/>	<input type="checkbox"/>	_____	Programmatic Notice	<input type="checkbox"/>	<input type="checkbox"/>	_____
Business-Sensitive Information	<input type="checkbox"/>	<input type="checkbox"/>	_____	Proprietary Information	<input type="checkbox"/>	<input type="checkbox"/>	_____
Computer Software Notice	<input type="checkbox"/>	<input type="checkbox"/>	_____	Purpose and Use	<input type="checkbox"/>	<input type="checkbox"/>	_____
Copyright License Notice	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Arms	Thesis/Dissertation	<input type="checkbox"/>	<input type="checkbox"/>	_____
Export Controlled Information	<input type="checkbox"/>	<input type="checkbox"/>	_____	Trademark Disclaimer	<input type="checkbox"/>	<input type="checkbox"/>	_____
Legal Disclaimer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Arms	Other: _____	<input type="checkbox"/>	<input type="checkbox"/>	_____
Limited Disclosure	<input type="checkbox"/>	<input type="checkbox"/>	_____				

11. MANDATORY COMMENTS (List only mandatory comments here. All other comments shall be made on the document and returned to the author.)

	Reviewer (Print & Sign)	Date	Resolved by Author/Requestor (Print & Sign)	Date
Any trademarked item must be: 1) replaced by a generic equivalent; 2) noted as a trademark the first time used, e.g., "Trademark of _____" either in the text or as a footnote; or 3) listed elsewhere in the document, e.g., "_____ is a trademark of _____."	A.M. Schreiber <i>A.M. Schreiber</i>	02/14/1976	S.M. Korklund <i>S.M. Korklund</i> See block 12	2/28/76

12. ADDITIONAL INFORMATION/COMMENTS:

Material NOT copyrighted, and trade marks identified by equipment manufacturer.

U.S. DEPARTMENT OF ENERGY  
RECOMMENDATIONS FOR THE ANNOUNCEMENT AND DISTRIBUTION  
OF DEPARTMENT OF ENERGY (DOE) SCIENTIFIC AND TECHNICAL INFORMATION (STI)

(See instructions on reverse side. Use plain bond paper if additional space is needed for explanations.)

**PART I** (DOE, DOE Contractors, Grantees, and Awardees complete)

**A. Product/Report Data**

1. (Award) Contract No. DE-AC06-87RL10930

2. Title Report on the Design of Freeze Protection for Hanford Nuclear Reservation Fire Suppression Systems

3. Product/Report Description

a. Report (Complete all that apply)

- (1)  Print  Nonprint (specify) \_\_\_\_\_
- (2)  Quarterly  Semiannual  Annual  Final
- Topical  Phase I  Phase II
- Other (specify) \_\_\_\_\_

Dates covered \_\_\_\_\_ thru \_\_\_\_\_

b. Conference/Meeting/Presentation (Complete all that apply)

- (1)  Print  Nonprint (specify) \_\_\_\_\_
- Published proceedings
- Other (specify) \_\_\_\_\_

(2) Conference Title (no abbreviations) DOE Fire Protection Conference

Location (city/state/country) Chicago, IL

Date(s) (m/d/y) 4/29/96 thru (m/d/y) 5/2/96

Sponsor DOE

c. Software - Additional forms are required. Follow instructions on the back of this form.

d. Other (Provide complete description) \_\_\_\_\_

**B. Patent Information**

Yes No

Is any new equipment, process, or material disclosed?  
If yes, identify page numbers \_\_\_\_\_

Has an invention disclosure been submitted?  
If yes, identify the disclosure number and to whom it was submitted.  
Disclosure number \_\_\_\_\_  
Submitted to \_\_\_\_\_

Are there patent-related objections to the release of this STI product?  
If so, state the objections. \_\_\_\_\_

**C. Contact** (Person knowledgeable of content)

Name S. M. Korlund

Phone 509-373-1639

Position Author

Organization Westinghouse Hanford Company

**PART II** (DOE/DOE Contractors complete/or as instructed by DOE contracting officer)

**A. DOE Identifiers**

1. Product/Report Nos. WHC-SA-3024-FP

2. Funding Office(s) (NOTE: Essential data) EM

**B. Copies for Transmittal to AD-21 (OSTI)**

(STI must be of sufficient quality for microfilming/copying.)

1. One for classified processing

2. \_\_\_\_\_ (number) for standard classified distribution

3. Two unclassified for processing

4. \_\_\_\_\_ (number) for program unclassified distribution

5. UC/C Category UC-630

B&R CODE - YN0100000

6. Additional instructions/explanations \_\_\_\_\_

(Do not identify Sigma categories for Nuclear Weapons Data reports, and do not provide additional instructions that are inconsistent with C below.)

**C. Recommendation** ("X" at least one)

1. Program/Standard Announcement/Distribution (Available to U.S. and foreign public)

2. Classified (Standard Announcement only)

3. Special Handling (Legal basis must be noted below)

a. Unclassified Controlled Nuclear Information (UCNI)

b. Export Control/ITAR/EAR

c. Temporary hold pending patent review

d. Translations of copyrighted material

e. Small Business Innovation Research (SBIR)

f. Commercializable information

(1) Proprietary

(2) Protected CRADA information

Release date \_\_\_\_\_

(3) Other (explain) \_\_\_\_\_

4. Program Directed Special Handling (copy attached)

**D. Releasing Official**

A. Patent Clearance ("X" one)

Has been submitted for DOE patent clearance

DOE patent clearance has been granted

B. Released by

(Name) Kaya Broz

(Signature) [Signature]

(Phone) 509-373-3151

(Date) 11-25-96

THIS PAGE INTENTIONALLY  
LEFT BLANK

## **REPORT ON THE DESIGN OF FREEZE PROTECTION FOR HANFORD NUCLEAR RESERVATION FIRE SUPPRESSION SYSTEMS**

S. M. Korslund  
Fire Systems Administrator, Hanford Fire Department

### **BACKGROUND**

The National Fire Protection Association (NFPA) 72 (1993) requires using temperature sensing equipment to monitor water supplies for fire suppression and water-based fire extinguishing systems for freezing temperatures based on the requirements of NFPA 13 (1994). NFPA 72 also requires that testing of freezing temperature detection equipment to verify that the sensor causes a supervisory signal at 40 degrees Fahrenheit (°F) ( $\pm 5$  °F). The required test method must ensure operation of the device at 40 °F. NFPA 72 requirements and test methods cannot reasonably be interpreted to allow an unmeasured temperature lowering agent to cause operation of the device as a valid test of the device.

Commercial Equipment supplied as cold temperature sensors includes a variety of single-point spot detectors described as actuating at 40 °F. However, there is no manufacturer-recommended, field-usable procedure compliant with NFPA 72 that can provide proper actuation point verification within the test method requirements of NFPA 72. The manufacturer does not recommend a suitable test to verify point of actuation, except to place the detector in a temperature controlled environment and verify that it trips at or higher than 40 °F. This test, which consumes time, manpower, equipment and money, is less than satisfactory.

Cold temperature detection at the Hanford Site is used to monitor the temperature in riser rooms for dry sprinkler systems and to monitor portions of wet sprinkler systems that pass through unheated areas.

### **TEST METHODS**

The current, widely used test method is to apply a freezing spray of canned "air" to the device. The "air" consists of 100 percent chlorodifluoromethane, an inert gas. By inverting the can and releasing the gas propellant, temperatures as low as  $-30$  °F can be obtained. Although this method actuates the device, the extremely low temperature and rapid rate of descent do not prove the device actuated at 40 °F. In addition, the possible ill effects of the extreme cold temperature on the device have not been ascertained. These shortcomings have been issued as an audit finding by the Department of Energy-Richland Operations. The finding cites that NFPA 72 requires room temperature switches be tested to verify that the device operates and results in a signal that indicates the room temperature decrease to 40 °F and restoration to above 40 °F. The Fire Protection Manual (WHC-CM-4-41) for the



Westinghouse Hanford Company specifies that testing activities for high and low temperature switches verify that an alarm occurs within  $\pm 7$  percent or 5 °F, whichever is greater, of the desired setpoint in the direction that the switch would alarm.

It is important to note that single-point devices currently available to the industry are not Underwriters Laboratory (UL) listed for freeze protection for fire suppression systems. They may, however, contain UL listed components.

## **EXISTING TYPES OF FREEZING TEMPERATURE DETECTORS**

The main supplier of freezing temperature detectors has provided three types of devices in recent years.

The first type was the Model RTD-G, a mercury-thermometer type not available in a normally open configuration to comply with NFPA 72 (1993). For this reason, apparently they were discontinued. (ATT. 5)

The second type, designated Model RTD-N.O. or RTD-N.C., operated on the thermistor semi-conductor principle. The operation of this model partially depended on the control equipment. Because the electrical resistance of the device lowers as the sensed temperature decreases, the control panel determines the point of actuation. It is possible that one manufacturer or type of control panel would trip at 50 °F while another would not trip until 30 °F. (The data sheet for this specific device refers to it as a bimetallic disk, but field tests indicate otherwise.) This potential controversy introduces quality control questions. These devices are no longer available through the fire systems component distributor. (ATT. 7)

The third and currently available type is a simple bimetallic strip, Model RTS-0 or RTS-C. (ATT. 9)

There is no apparent consensus on the construction or mode of operation of these devices.

## **RECENT TECHNOLOGY**

An exception to the poor test ability of cold temperature devices is the recent development of analog systems which use linear temperature sensors to supply the control panel with temperature information. The control panel is programmed to determine whether the condition sensed is a heat increase within the parameters of a fire alarm device or a temperature decrease within the parameters of an incipient freeze condition. These sensors (detectors) are UL listed for freeze protection for fire alarm suppression systems, but they must be used with their specific control panel thus precluding universal application.

The lack of UL listed equipment, which can be readily tested to verify the actual point of actuation has become a nationwide end user concern.

## **NEW EQUIPMENT AT THE HANFORD SITE**

The Hanford Fire Department Fire Systems Testing and Maintenance Engineering Division has adapted an application using a currently manufactured industrial process temperature controller which fully complies with the intent of NFPA requirements including the following:

Supervision of the power supply

Monitoring of sensing circuits

Tests to verify the point of actuation

Programmable to a single point of actuation, with the set point protected from unauthorized alteration

Readily visible local annunciation with a digital readout of actual detected or monitored temperature and local indication of off-normal condition

This controller is a Red Lion Model TCU temperature controller with an optional relay output that connects to a local fire alarm control panel. The relay provides normally open contacts for systems in compliance with NFPA 72 (1993) and normally closed contacts for systems complying with earlier codes of record.

A supervisory (off-normal) signal is generated when there is an open circuit or shorted circuit for the sensing element, loss of primary power, or a temperature lower than device set point.

The Hanford Fire Department Fire Systems Testing and Maintenance Engineering Division wrote procedure FS-0025 to program and test the unit. This procedure is attached to this article for information purposes.

The controller can be installed in approximately four hours. The cost of materials is approximately \$275.

The temperature controller includes a 5 amp fuse housed in a safe electrical inline fuse holder. The fuse holder pulls apart with the energized portion insulated and shielded from accidental contact in compliance with 29 CFR 1910 for personnel protection during maintenance.

The Hanford Nuclear Reservation has installed 70 of these systems in 55 locations with a zero failure rate during the first six months of operation. The ability of these systems to detect a failure in the area or pipe heating system prior to dropping to 40 °F is an added benefit. A surveillance program can monitor and track the sensed temperature during inclement weather as it continually displays on the digital readout.

The Red Lion Company has been contacted about submitting the Model TCU unit to UL for listing for freeze protection for fire suppression systems. The high quality unit is UL listed as a temperature monitor and controller for industrial and process control applications. Another model, whose design is under consideration, would receive power directly from a fire control panel and could operate as a supervisory initiating device. This would be similar to operating an alarm initiator that requires separately derived 24 vdc power, such as a duct smoke detector.

### **NEW TEST METHOD**

The Hanford procedure for testing the Red Lion unit compares the sensed temperature reading with the programmed set point. Both temperature readings display, one above the other in a digital format. A front panel button is used to raise the set point to .2 °F above the sensed temperature, at which time the receipt of the supervisory signal is verified. Therefore, by interference, the sprinkler system is protected at the set point level of 40 °F. The set point is programmed to prevent the temperature from being lowered below 40 °F, and it can be password protected. Leaving the set point raised provides a higher degree of protection. See Attachment 11 for the formal programming and testing procedure.

### **COMPARING TEST COSTS**

The previous test method required two persons: one to monitor the control panel for the supervisory signal, the other to apply the canned "air" to the temperature sensor. Because the device is frozen to -30 °F, the reset is delayed until the unit warms to more than 40 °F. It also may be necessary to remove insulation thereby adding personnel and costs to the testing. Therefore, in addition to being inefficient and inaccurate in certifying that a system is actually protected from freezing temperatures, the old method also waste manpower.

The test procedure associated with the Red Lion equipment can be performed by a single person in less than two minutes.

Costs associated with testing are reduced to a fraction because only one person is required and a shorter test time is required. This depends on specific application circumstances, but in no case is it less than half again. Thus, testing costs are reduced by 75 percent, or one quarter of the original cost. Recovery of procurement and installation costs is recovered in one or two test cycles.

In this case, meeting the code requirements is less expensive than not.

**REFERENCES**

29 CFR 1910, "Occupational Safety and Health Standards," *Code of Federal Regulations*, as amended.

NFPA 1994, *Standards for the Installation of Sprinkler Systems*, NFPA 13, National Fire Protection Association, Quincy, Massachusetts.

NFPA 1993, *National Fire Alarm Code*, NFPA 72, National Fire Protection Association, Quincy, Massachusetts

WHC-CM-4-41, *Fire Protection Program Manual*, Westinghouse Hanford Company, Richland, Washington.

This page intentionally left blank.

**ATTACHMENTS**

This page intentionally left blank.

**CONTENTS**

1	Data sheet for RTD-G room temperature detector . . . . .	5
2	Data sheet for RTD series room temperature detector . . . . .	7
3	Data sheet for RTS room temperature detector . . . . .	9
4	FS-0025 Procedure for programming and testing . . . . .	11
5	Bill of Material . . . . .	19
6	CVI 12244 (sheet 69), a typical wiring diagram . . . . .	21



This page intentionally left blank.



**RTS-G**  
**ROOM TEMPERATURE SWITCH**  
**GLASS**

Potter Electric Signal Company  
2081 Craig Rd., P.O. Box 28480  
St. Louis, MO 63146  
(314)878-4321 / (800) 325-3936


Potter Electric Signal & Mfg. LTD  
1967 Leslie Street  
Don Mills, Ontario, Canada M3B2M3  
(416) 441-1833

**Temperature Setting:** 40°F

**Accuracy:** ± 1.5°F

**Contacts:** S.P.S.T. rated 100 MA 24V  
AC OR 24V DC  
Opens on temperature drop  
Closes on temperature rise

**Dimensions:** 4 3/4"L x 1"W x 1 1/4"D



STK. NO. 1010036

The Model RTS-G is a mercury column type switch designed for use with a supervisory transmitter to monitor temperature. The unit is normally used in areas where there are wet sprinkler systems, so that an indication is given before the temperature drops to the freezing point.

This page intentionally left blank.



**RTD SERIES**  
**ROOM TEMPERATURE DEVICE**

Potter Electric Signal Company  
2081 Craig Rd./P.O. Box 28480  
St. Louis, MO 63146-4161  
(314)878-4321 / (800) 325-3936

Potter Electric Signal & Mfg. LTD  
1967 Leslie Street  
Don Mills, Ontario, Canada M3B2M3  
(416) 441-1833



**Base:** Molded White plastic

**Dimensions:** 1 7/8" diameter, 7/8" high

**Sensor:** Stainless steel cap, compression welded to brass shell with bimetallic operating mechanism nested within.

**Contacts:** Silver clad phosphor bronze, (normally open or normally closed)

**Electrical Rating:** 3A @ 125VAC, 1A @ 6 to 24VDC

**Temperature Setting:** 40° F fixed

**Terminals:** Dual brass screw terminals

**Mounting:** Semi-flush on standard electric box

RTD-N.O. STK #1010108  
RTD-N.C. STK #1010109

The RTD Series Room Temperature Detectors are precision engineered, designed and manufactured for commercial or residential use.

Each unit consists of a bi-metal operating mechanism, featuring hermetically sealed precious metal contacts, N.O. or N.C., which automatically reset for repetitive operation, eliminating the need for sensing element replacement.

Small compact design, highly resistant to vibration and corrosion. Easily installed on standard electrical outlet boxes.

Available at factory preset temperature rating of 40° F. Designed to warn of potential sprinkler pipe freezing or other cold detection applications.

Dual screw terminals permit easy installation in single or multiple detector circuits.

**ACCESSORY ITEMS:** Protective covers for use where mechanical protection required.

**FEATURES:**

- Easily installed
- Completely sealed, moisture and vapor resistant
- Highly resistant to vibration and corrosion
- Highly sensitive to temperature changes
- No sensitivity loss due to aging
- Repetitive operation without the need to replace sensing elements
- Small compact design
- Precision and quality at low cost


Manufactured for Potter Electric Signal Co. by Therm-L-Matic, Hatboro, PA.



**RTD SERIES  
ROOM TEMPERATURE DEVICE**

**INSTALLATION**

OPERATION: When the temperature at the detector drops to 40° the normally open contacts close and the normally closed contacts will open. The detector will automatically reset to the normal state when the temperature rises above 40°.



**ORDERING INFORMATION**

**OPTIONAL EQUIPMENT:**

Mounting plate, metal	1010109
Protective Cap	1010112
RTD-N.C.	1010108
RTD-N.O.	1010109
Mounting plate, plastic	1010110

PRINTED IN U.S.A.

MKT. #8820008 - REV A  
MFG. #5-900537



**RTS-O / RTS-C**  
ROOM TEMPERATURE SWITCH

Potter Electric Signal Company  
2081 Craig Rd., P.O. Box 28480  
St. Louis, MO 63146-4161  
(314) 878-4321 • (800) 325-3936

Potter Electric Signal & Mfg. LTD  
1967 Leslie Street  
Don Mills, Ontario, Canada M3B2M3  
(416) 441-1833

**Enclosure:** White ABS

**Dimensions:** 2 1/16"W x 3 7/16"L x 1 1/4"H

**Sensor:** Epoxy sealed stainless steel case, bi-metallic operating mechanism.

**Contacts:** Silver clad, available normally open or normally closed.

**Electrical Rating:** 1A @ 24VDC

**Temperature Setting:** 40°±5°F, 5°±3°C

**Terminals:** Screw Terminals

**Mounting:** Surface

RTS-O STK. #1010108  
RTS-C STK. #1010109

The RTS Series Room Temperature Sensors are precision engineered, designed and manufactured for commercial or residential use.

Available at factory preset temperature rating of 40° F. Designed to warn of potential sprinkler pipe freezing or other cold detection applications.

Each unit consists of a bi-metal operating mechanism, featuring hermetically sealed precious metal contacts, N.O. or N.C., which automatically reset for repetitive operation, eliminating the need for sensing element replacement.

Small compact design, highly resistant to vibration and corrosion. Easily installed using the enclosed hardware or adhesive mounting pad.

Screw terminals permit easy installation in single or multiple detector circuits.

**FEATURES:**

- Easily installed
- Completely sealed sensor, moisture and vapor resistant
- Highly resistant to vibration and corrosion
- Highly sensitive to temperature changes
- No sensitivity loss due to aging
- Repetitive operation without the need to replace sensing elements
- Small compact design
- Precision and quality at low cost

**OPERATION**

The normally open detector, RTS-O, will close the contact when the temperature drops below 40°F. The normally closed detector, RTS-C, will open the contact when the temperature drops below 40°F. The detector will automatically reset to the normal state when the temperature rises above 40°F.

**This page intentionally left blank.**

**FIRE SYSTEMS TESTING AND MAINTENANCE**

(FST&M)

**SITE-WIDE  
TEST AND MAINTENANCE PROCEDURE**

**FS0025**

Revision 0

Change 0

**PERFORM COLD TEMPERATURE DETECTOR  
PROGRAMMING AND TESTING**

Approval Level S

Prepared by:	FST&M	K.M Pittman, Engineer	
Validated by:	FS Maintenance	E. Blankingship, Manager	DATE 08/03/95
Approved by:	Safety	P.J. McKenna, Engineer	08/08/95
	FST&M Manager	W.M. Knight, Manager	08/10/95
	Cog. Engineer	S.M. Korslund	08/03/95
Released by:	Procedure Coordinator	K.M. Pittman	

Release Date: 08/15/95

Page 1 of 8



FST&M TEST & MAINTENANCE PROCEDURE PERFORM COLD TEMPERATURE DETECTOR PROGRAMMING AND TESTING	APPROVAL LEVEL 5	PROC. NO. FS0025 REV. 0, CHG. 0 PAGE 2 OF 8
----------------------------------------------------------------------------------------------------	------------------	---------------------------------------------------

Change Record

<u>Change Number</u>	<u>Date</u>	<u>Document</u>	<u>Page(s)</u>	<u>Description</u>
Rev. 0	08/03/95	950060	ALL	New procedure.

<----- Nonford Fire Department Testing and Maintenance Procedures ----->

**FST&M TEST & MAINTENANCE PROCEDURE  
PERFORM COLD TEMPERATURE DETECTOR  
PROGRAMMING AND TESTING**

**APPROVAL LEVEL 5**

**PROC. NO. FS0025  
REV. 0, CHG. 0  
PAGE 3 OF 8**

**1.0 PURPOSE AND SCOPE**

1.1 This procedure provides instructions for a safe, uniform method to perform Cold Detector programming and testing.

**2.0 REFERENCES**

None.

**3.0 PERSONNEL REQUIREMENTS**

3.1 Hanford Fire Department (HFD) Testing and Services Personnel.

3.2 Health Physics Technician (HPT), as required.

3.3 FSM Electricians.

**4.0 PRECAUTIONS AND LIMITATIONS**

4.1 If abnormal conditions occur, or deviation from specified work is required, stop all work and immediately notify Person-In-Charge (PIC). **DO NOT** go on without authorization from PIC.

4.2 If performance of any steps in this procedure is not required for procedure completion, steps not performed shall be shown as such by entering "N/A" in appropriate Data Sheet space and explained in COMMENTS/REMARKS section of Data Sheet.

4.3 Sections or steps within sections of this procedure may be done out of sequence, as required for testing or plant conditions.

4.4 HFD shall bypass all fans, dampers, interlocks, and accessories required to do maintenance and testing of system

----- Hanford Fire Department Testing and Maintenance Procedures -----

FST&M TEST & MAINTENANCE PROCEDURE  
PERFORM COLD TEMPERATURE DETECTOR  
PROGRAMMING AND TESTING

APPROVAL LEVEL 5

PROC. NO. FS0025  
REV. 0, CHG. 0  
PAGE 4 OF 8

5.0 TOOLS, EQUIPMENT AND MATERIALS

NOTE

All M&TE used for this working-level procedure shall meet the following requirements:

- a. Be within its current calibration cycle, as evidence by an affixed calibration label.
- b. Be capable of desired range and within input tolerance specified by Calibration Control authority.

5.1 Temperature probe for Multi Meter with 5% tolerance.

5.2 Calibrated Digital Multi Meters (DMM) with 5% tolerance.

6.0 PREREQUISITES

6.1 Notify Operations Manager/Building Administrator of intent to complete this Maintenance and Test Procedure (M&TP).

6.2 Notify all locations to which remote annunciators transmit.

6.3 HFD set the Fire Alarm System for Building/Zones tested in test form. Bypass functions necessary for test. List bypassed functions on Data Sheet in space provided in Prerequisites Section. Initial Data Sheet when functions are bypassed.

6.4 Comply with building specific Lock and Tag requirements.

FST&M TEST & MAINTENANCE PROCEDURE  
 PERFORM COLD TEMPERATURE DETECTOR  
 PROGRAMMING AND TESTING

APPROVAL LEVEL 5

PROC. NO. FS0025  
 REV. 0, CHG. 0  
 PAGE 5 OF 8

7.0 INSTRUCTIONS

NOTE

- a. IF concurrent procedures existed, THEN system charging and restoration sections should be adjusted/performed when needed to setup for concurrent jobs or at their completion.
- b. HFD shall verify all Fire Alarm Control Panel's (FACP) zone alarms generated by doing this procedure correspond with proper zone in Radio Fire Alarm Repeater (RFAR) Box, and first alarm per zone received at the Fire Station.
- c. Capitalized abbreviations used after RECORD shows where to enter data on Data Sheet like (FNC).

7.1. Program Cold Temperature Detector for Installation/Replacement

- 7.1.1 PROGRAM the TCU by operating the control buttons. "PAR" will initiate and step through the parameter function. "Arrow Up" and "Arrow Down" will select the proper setting.
- 7.1.2 SET the programming per the following Table.
- 7.1.3 CHECK OFF the following programming information:

Table 1

PAR	PROP	0.0	
PAR	CNFP	NO	ARROW UP
	I-IN		PAR
	TYPE	TC-E	PAR
	SCAL	F	PAR
	DCPT	0.0	PAR
	FLTR	1	PAR
	SPAN	1.000	PAR
	SHIFT	0.0	PAR
	SPLO	40.0	PAR
	SPHI	100.0	PAR

FST&M TEST & MAINTENANCE PROCEDURE  
 PERFORM COLD TEMPERATURE DETECTOR  
 PROGRAMMING AND TESTING

APPROVAL LEVEL 5

PROC. NO. FS0025  
 REV. 0, CHG. 0  
 PAGE 6 OF 8

	SPRP	0.0	PAR
	CNFP		ARROW UP
	1-IN		ARROW UP
	2-OP		PAR
	CYCLE	0	PAR
	OPAC	DRCT	PAR
	OPLO	100	PAR
	OPHI	0	PAR
	OPFL	0	PAR
	CHYS	.1	PAR
	TCOD	0	PAR
	CNFP		PAR
	END		

7.2 Testing

- 7.2.1 PRESS the "Arrow Up" button until the setpoint temperature exceeds the control temperature by .2 to .5 degrees.
- 7.2.2 VERIFY receipt of trouble signal.
- 7.2.3 RESTORE the setpoint temperature to 40 degrees F. by pressing "Arrow Down".
- 7.2.4 RECORD results on the Data Sheet.
- 7.2.5 VERIFY trouble signal clears on FACP.
- 7.2.6 RESET FACP and verify normal supervisory service condition.

FST&M TEST & MAINTENANCE PROCEDURE  
PERFORM COLD TEMPERATURE DETECTOR  
PROGRAMMING AND TESTING

APPROVAL LEVEL 5

PROC. NO. FS0025  
REV. 0, CHG. 0  
PAGE 7 OF 8

8.0 RESTORATION

- 8.1 Restore system to normal.
- 8.2 Reset and restore building alarm bell switch and all applicable fans, dampers, interlocks and accessory functions to normal position; record restoration of equipment on Data Sheet under PREREQUISITES FUNCTIONS (RESTORED).
- 8.3 If RFAR box has Bell Card Module, reset and restore bell silence switch to normal position.
- 8.4 Verify no abnormal conditions exist inside RFAR box; shut and lock RFAR box.
- 8.5 Ensure no alarm or trouble LED's are lit on FACP.
- 8.6 Notify building personnel that HFD and Maintenance have completed testing and have returned alarm system to normal operation.
- 8.7 Notify HFD dispatcher testing has been completed and request all zones be restored, identify building and RFAR box number.
- 8.8 Request HFD dispatcher to bypass front button alarm on RFAR box.
- 8.9 After acknowledgement, press front button on RFAR box and verify three rounds of fire front button are received at fire stations. Initial Data Sheet (RESTORATIONS 1).
- 8.10 Notify HFD dispatcher RFAR box is restored and the test has been completed.
- 8.11 Remain at RFAR box until light goes out on front of RFAR and initial Data Sheet (RESTORATIONS 2).

9.0 TESTING AND ACCEPTANCE

None.

FST&M TEST & MAINTENANCE PROCEDURE  
PERFORM COLD TEMPERATURE DETECTOR  
PROGRAMMING AND TESTING

APPROVAL LEVEL 5

PROC. NO. FSO025  
REV. 0, CHG. 0  
PAGE 8 OF 8

10.0 **DISPOSITION**

- 10.1 Advise Building Manager/Administrator of any system impairments or abnormal conditions, Initial Data Sheet (RESTORATIONS 3).
- 10.2 HFD personnel complete and return all Fire System Alarm Test Report forms to Fire Station #2 for file.
- 10.3 Report deficiencies or cause of early failure to Supervision.
- 10.4 Return Data Sheet(s) to Supervision and inform Supervision preventive maintenance is complete.

11.0 **BIBLIOGRAPHY**

- 11.1 WHC-CM-4-3, Industrial Safety Manual, Section TE, "Tools and Equipment", Standard No. PP-7, "Personal Protective Equipment", and Standard G-1, "Lock and Tag".
- 11.2 HSRCM-1, Hanford Site Radiological Control Manual, Chapter 2, Part 3, "Posting", and Chapter 3, Part 2, "Work Preparation."
- 11.3 WHC-CM-4-3, Vol. 1, Standard FS-2, "Fire Protection System Inspection, Testing, and Maintenance".

BILL OF MATERIAL		Title/End Use: FREEZING TEMPERATURE DETECTION	Wk. Pkg. No.: 2G-95-550	ECN No.: 614272					
Date: 09/01/95		Requestor: SM KORSLUND			Priority: 3				
Item No.	Quantity	Material Description	Estimated Cost	Req./Store No.	Safety Class	Approval Designator	QC Approval	Ordered	Stock No.
	Unit			Exp. Delivery Date				Received	Storage Location
1	70	RED LION TEMPERATURE CONTROL UNIT (TCU) P/N	186.00		3	S			
	EA	TCU0000.							
2	56	HOFFMAN ENCLOSURE, NEMA 4, 6X6X12	45.00		4	NA			
	ea								
3	70	TYPE "E" THERMOCOUPLE P/N AX1008808	13.00		3	S			
	EA								
4	70	FUSE HOLDERS; In-line Breakaway; p/n 6F453;	20.00		3	S			
	EA	with Insulating Boot; p/n 6F454							
5	70	RELAY MODULE FOR RED LION MODEL TCU; P/N	9.30		3	S			
	EA	OMD00000							
6	1000	THERMOCOUPLE EXTENSION CABLE, TYPE E; P/N	.27		4	NA			
	FT	E20-5-502							

Date Required: 09/01/95	Suggested Vendor: BRANOM INSTRUMENTS PO BOX 80307 SEATTLE, WA 98108	Emergency Justification:	
<input type="checkbox"/> Mandatory <input checked="" type="checkbox"/> Desired			
Delivery Location: 2721EA	Special Instructions		
QA Clause: E14, E22, C02		Org Code/Cost Code 3C600/MFMPH	

Material Coordinator	Date	MSIN	Phone No.
Cognizant Engineer (if applicable)	Date	MSIN	Phone No.
Cognizant Manager (if applicable)	Date	MSIN	Phone No.
Planner	Date	MSIN	Phone No.
Quality Assurance	Date	MSIN	Phone No.

ATT-19


WHC-SA-3024-FP Rev. 0

Material Released To and Received By: \_\_\_\_\_ Date \_\_\_\_\_



Item No.	Quantity	Unit	Material Description	Estimated Cost	Req./Store No.	Safety Class	Design Approval	DC Approval	Ordered	Received	Storage Location	Page _____ of _____	
												Work Request No.	S.O. M. Suppl.
7	EA	70	CONNECTOR, THERMOCOUPLE, MALE AND FEMALE MALE	5.00		4	NA					Continuation Sheet	
	EA	70	P/N 900E; FEMALE P/N 901E; TYPE E										
8	EA	70	CABLE CLAMP, P/N 921	.85		4	NA					BILL OF MATERIAL	
	EA	70											

TYPICAL CONNECTION DIAGRAM FOR FIRE SYSTEMS



This page intentionally left blank.