

DOE/FETC/C--98/7293

Reducing the Manufacturing Cost of Tubular SOFC Technology

Raymond A. George^{a1} and Norman F. Bessette^{b2}

CONF-9709197--

^aSOFC Power Generation, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania 15235

^bSOFC Power Generation, Cell Manufacturing Development, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania 15235.

RECEIVED

DEC 08 1997

OSTI

Abstract

In recent years, Westinghouse Electric Corporation has made great strides in advancing tubular solid oxide fuel cell (SOFC) technology towards commercialization by the year 2001. In 1993, Westinghouse initiated a program to develop a "MWe-Class" (1-3 MWe) pressurized SOFC (PSOFC)/gas turbine (GT) combined cycle power system for distributed power applications because of its 1) ultra-high efficiency (~63% net AC/LHV CH₄), 2) its compatibility with a factory packaged, minimum site work philosophy, and 3) its cost effectiveness. Since then two cost studies on this market entry product performed by consultants to the U.S. Department of Energy have confirmed Westinghouse cost studies that fully installed costs of under \$1300/kWe can be achieved in the early commercialization years for such small PSOFC/GT power systems. The paper will present the results of these cost studies in the areas of cell manufacturing cost, PSOFC generator

19980406 169

¹ Corresponding author. Fax: (412) 256-2012, e-mail: georgera@westinghouse.com
Present address, Westinghouse Electric Corporation, Science and Technology Center, 1310 Beulah Road, Pittsburgh, Pennsylvania 15235, USA.

² Co-author. Fax: (412) 256-5504, e-mail: bessetnf@westinghouse.com
Present address, Westinghouse Electric Corporation, Science and Technology Center, 1310 Beulah Road, Pittsburgh, Pennsylvania 15235, USA.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MASTER

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

manufacturing cost, balance-of-plant (BOP) cost, and system installation cost. In addition, cost of electricity calculations will be presented.

Keywords: SOFC; SOFC/GT; Manufacturing Cost

1. Introduction

Over the past 10 years the Westinghouse SOFC development team has made major progress towards reducing SOFC manufacturing costs (\$/kWe). This paper describes the important technology breakthroughs, presents the results of a cost study of a 3 MWe pressurized SOFC (PSOFC)/gas turbine (GT) power system performed in 1996 by Westinghouse and two consultants (A. D. Little and Spencer Management) to the U.S. Department of Energy and updated by Westinghouse in 1997, and compares the cost of electricity (COE) of such a system with that of the most advanced small (<5 MWe) gas turbine generator currently under development.

2. SOFC Technology Status

Over the past 10 years, the Westinghouse tubular SOFC design has evolved from a zirconia porous support tube (PST) type with an active length of 30 cm and active area of 113 cm² to an air electrode supported (AES) type with an active length of 150 cm and active area of 834 cm². Figure 1 illustrates these two design types and Table 1 presents a comparison of their design parameters. As can be seen from Table 1 the cell power output has been increased by an order of magnitude over the last 10 years, resulting in one-tenth the number of cells needed for a given cell stack power output. Furthermore, the zirconia PST has been eliminated resulting in a

lower cost and more reliable cell design. The 150 cm AES cell is now a proven design with over 60 cells tested including a 48-cell bundle test, and over 1300 cells manufactured in our \$13 million Pilot Manufacturing Facility (PMF). The cell stack for the EDB/ELSAM (a Dutch and Danish Utility Consortium) 100 kWe field unit contains 1152 of these cells. The unit factory test is expected to begin in early October, 1997 and the site test in Arnhem, The Netherlands is expected to begin in December 1997.




Fig. 1. Tubular SOFC Design Evolution.

	1987 PST Type	1997 AES Type
Cell OD (cm)	1.52	2.23
Cell active length (cm)	30	150
Cell total length (cm)	42	168
Cell active area (cm ²)	113	834
PST ID/OD (cm)	0.89/1.29	N.A./N.A.*
AE ID/OD (cm)	1.29/1.49	1.76/2.20
IC length/width (cm)	30/1.1	150/1.1
IC thickness (μm)	40	100
EL thickness (μm)	40	40
FE thickness (μm)	100	100
Max. power @ 1 atm (watts)	20	210
*Not applicable		

Table 1. Tubular SOFC Design Parameter Comparison

The cell scale-up to commercial size has been completed, and the emphasis is now on materials cost reduction, development of low cost manufacturing processes, and supplier development. Since the air electrode tube constitutes 92% of the weight of the finished cell, the material cost reduction program is focused on the air electrode precursor materials (i.e., the raw materials which are used for synthesizing doped LaMnO₃). In particular, the focus is on qualifying lower purity precursor materials, which will reduce the air electrode precursor materials cost in large volume from \$25/cell to \$6/cell. Concerning the development of low cost manufacturing processes, the focus over the last 5 years has been the substitution of lower cost ceramic processes, such as plasma spray and sintering, for

electrochemical vapor deposition (EVD). Five years ago, all three thin film layers (interconnection, electrolyte and fuel electrode) were deposited by EVD. Since 1992 the interconnection has been deposited by plasma spray in production (over 2500 cells produced with plasma sprayed interconnections). In addition, over 20 cells have been made in the laboratory with sintered fuel electrodes, and Westinghouse expects to initiate production of sintered fuel electrode cells in the PMF by June, 1998. It is anticipated that the first production line in the Commercial Manufacturing Facility (CMF) will consist of the following thin film deposition processes: plasma spray for the interconnection, EVD for the electrolyte and slurry dipping/sintering for the fuel electrode. Finally, for the last 2 years, Westinghouse has been developing strategic partners for the supply of ceramic materials and components. Praxair Surface Technologies, for example, is collaborating with Westinghouse to produce 1) doped LaCrO_3 powder for plasma spraying the interconnection, 2) doped LaMnO_3 powder for air electrode tubing making, and 3) sintered air electrode tubes.

3. 3 MWe PSOFC/GT Power System Description

For the purpose of the cost study performed by Westinghouse, A. D. Little, and Spencer Management, Westinghouse performed a conceptual design of a 3 MWe PSOFC/GT power system. Table 2 presents the top level system design parameters and Figure 2 presents the system schematic. As shown in Figure 2, the turbine compressor provides the pressurized air to the PSOFC generator (in this case three 600 kWe modules). Pressurized natural gas is also delivered to the PSOFC generator where it first undergoes reformation to H_2 and CO within the cell stack,

and then is electrochemically reacted with oxygen ions from the pressurized air producing DC electricity and pressurized, high temperature exhaust gas. The exhaust gas is then directed to the turbine expander which drives the turbine and the AC generator. As shown in Table 2, 60% of the electrical power is produced by the SOFC generator and 40% by the turbine generator. Therefore, a SOFC generator costing \$500 per kWe of SOFC output, costs only \$300 per kWe of total system output; similarly a gas turbine generator costing \$800 per kWe of turbine generator output, costs only \$320 per kWe of total system output.




Fig. 2. 3 MWe PSOFC/GT Power System Schematic

System Power Output (MWe AC)	3.0
System Electrical Efficiency (AC/LHV, %)	63
PSOFC Power Output (MWe DC/AC)	1.88/1.80
GT Power Output (MWe AC)	1.2
GT Pressure Ratio	6:1
Number of PSOFC Modules	3
PSOFC Module Output (MWe DC/AC)	0.63/0.60
Number of Cells per Module	2496
Cell Diameter (cm)	2.2
Cell Active Length (cm)	150
Cell Power Output @ 6 atm (watts DC)	250

Table 2. 3 MWe PSOFC/GT Power System Design Parameters

Westinghouse intends to commercialize PSOFC/GT power systems initially in the power range 500 kWe to 5 MWe because of its unique advantages. Most significantly, such combined cycle systems can achieve electrical efficiencies in the range 62-72% unmatched by any other technology especially in the above power range. This is a direct result of the synergism between PSOFC technology and gas turbine technology. The PSOFC generator basically replaces the turbine combustor function during steady state operation because its exhaust gas temperature (850°C or 1560°F) is a very acceptable turbine inlet temperature. In addition, pressurization significantly enhances cell performance (e.g., cell power output increases from 210 watts @ 1 atm to 250 watts @ 6 atm), resulting in reduced stack cost on a \$/kWe basis.

4. 3 MWe PSOFC/GT Power System Cost Study

4.1 Commercial Manufacturing Facility

As part of the commercialization plan for SOFC, a Commercial Manufacturing Facility (CMF) was sized and a conceptual design was performed. The CMF design consists of three duplicate production lines, each with an annual capacity of 100 MWe of SOFCs (~150 MWe of systems) assuming 3 shifts per day and 330 production days per year. The process flow diagram shown in Figure 3, the "1997 AES Type" cell as specified in Table 1, and the above production rates are the basis for the CMF manufacturing equipment selection and sizing. The manufacturing equipment cost estimates were based upon quotations from equipment suppliers and scale-up of known PMF equipment costs accounting for size and cost savings associated with the purchase of multiple machines. In addition, no credit was taken for ongoing work to reduce the capital cost of the EVD process while maintaining its high levels of product quality and equipment reliability. The equipment costs for the first 100 MWe per year cell production line was estimated at \$45 million while the second and third production lines were estimated at \$40 million each.




Fig. 3 SOFC Process Flow Diagram.

In order to determine the building size, a layout of the three cell production lines was performed. In addition, space was allocated for SOFC module assembly and system assembly assuming the output of the CMF to be skid-mounted, fully packaged 3 MWe PSOFC/GT Power Systems requiring a minimum of site installation. The cost of the manufacturing building and property was estimated assuming both new construction and the purchase of an existing building. It was concluded that utilizing an existing building was advantageous to minimize the initial capital investment for the CMF as well as take advantage of an abundance of vacant sites. Preliminary estimates require approximately 250,000 ft² of 35 ft high bay space per production line of 150 MWe per year of 3 MWe power systems for a total floor space of 750,000 ft². The building purchase price for an existing building of this size was estimated at \$45 per ft² or \$35 million.

For the purpose of this cost study, a capital investment of \$80 million (\$45 million for the first production line and \$35 million for the building) was used for an annual production rate of 150 MWe of 3 MWe PSOFC/GT power systems. The manufacturing equipment was depreciated over 10 years and the building was depreciated over 20 years. These annual costs were included as part of the cell manufacturing cost discussed in Section 4.3.

In 1998, Westinghouse plans to perform a detailed design and cost estimate of the CMF as input to the decision making process in 1999 concerning construction of the CMF. Assuming a positive decision to proceed with the construction of the CMF, plant commissioning should occur in the year 2001.

4.2 Cell Manufacturing Process Description

4.2.1 Air Electrode Fabrication

Air electrodes, which form the basic building block of the tubular SOFC, are manufactured from a mixture of base carbonates which form the doped LaMnO_3 giving the cell its excellent durability, thermal cycle ability, and electrical performance. The base carbonates are first weighed and ball milled and subsequently calcined to provide a homogeneous material. The calcined material is then crushed and milled to provide the correct particle size distribution. This material is then mixed with water and binders to form a paste capable of being extruded. The paste is first extruded into a hemispherical mold to form the closed end of the tube, the mold removed, and the extrusion continues in a smooth fashion allowing for the formation of the remaining cylindrical section with a finished length of 181 cm. Through this technique the closed end and cylinder remain a homogeneous material significantly improving quality and yield of the finished product. The extruded tube section is then sintered at approximately 1500°C to form the tubular building block.

4.2.2 Interconnection Deposition by Plasma Spray

The interconnection is deposited on the air electrode tube using an atmospheric plasma spray process to obtain a gas tight positive (+) contact stable in a dual atmosphere. The interconnection material is a doped LaCrO_3 made from base carbonates much in the same manner as the air electrode powder. The powder is fed to a plasma spray gun where in combination with hydrogen and electricity, a plasma

is formed which is sprayed onto the air electrode tube through a 150 cm by 1.1 cm window defined by a metal mask. The cell is held vertically while the gun traverses axially. Application requires approximately 4 minutes and lends itself well to automation through the use of multiple guns. This material and manufacturing process have been successfully demonstrated in two 25 kWe generators of 576 cells each, which operated for greater than 5,000 and 13,000 hours, respectively. No significant voltage degradation was observed in either generator and the tests were ended because all the contractual commitments were fully satisfied.

4.2.3 Electrolyte Deposition by Electrochemical Vapor Deposition

To deposit a perfectly gas tight uniform layer over greater than 1000 cm² with an exceptionally high yield, the Westinghouse design has relied on the electrochemical vapor deposition (EVD) process. At temperatures near 1200°C and vacuum pressures near 1 mmHg, anhydrous mixtures of yttrium trichloride and zirconium tetrachloride are sublimed and passed over the exterior of the air electrode-interconnection assembly. Oxygen is provided to the tube interior. The chlorides react chemically and electrochemically with the oxygen passing through the tube wall to form the zirconium oxide layer on the tube exterior. Since the film growth is partially governed by the mixed conductivity of the material and electrical path resistance, thin portions grow faster than thicker portions resulting in a uniform film of nominally 40 μm in thickness.

4.2.4 Application of a Nickel Contact by Electroplating

The other advantage of the Westinghouse tubular SOFC besides its seal-less design is the metallic connections made between cells through the use of nickel felt or nickel wool. This electrical integration is made possible by nickel electroplating of the interconnection to provide the metallic surface for nickel felt bonding. Cells are placed in a nickel sulfamate bath containing a sacrificial nickel anode while a cathode is inserted into the cell tube. Since yttria stabilized zirconia (YSZ) is an insulator at room temperature, only the doped LaCrO_3 material will carry electricity thereby defining its own mask. Current is passed through the system resulting in a 5-10 μm thick nickel layer on the interconnection. Both capital and material cost are small. A reliable contact has been achieved on all generators used in the field to date.

4.2.5 Fuel Electrode Application by Slurry Dipping

The fuel electrode, or anode, of the cell is deposited through a slurry dip process. A mixture of nickel and yttria stabilized zirconia (YSZ) powders having the proper thermal expansion match with the rest of the cell components is first blended and then mixed with water and binders in the proper ratio to achieve a highly viscous slurry. The material is then circulated through a number of vertical 2 inch diameter, 70 inch long acrylic tubes with a diaphragm pump to a void slurry stratification. Cells from electrolyte EVD have a vinyl tape placed over the interconnection and are dipped in the slurry containers. Cells are then extracted at a slow rate allowing for flash drying to avoid slurry sagging which results in

excessive thickness non-uniformities adversely impacting cell performance and structural integrity. Through this process a uniform 100 μm thick layer can be maintained with a standard deviation of less than 10 μm . The vinyl tape is subsequently removed and the cell is prepared for the sinter step. This slurry application process has been utilized in the previous and the present Westinghouse manufacturing facility for both 50 and 150 cm active length cells with high reliability, high yield, and low material waste. With only ball mills and small pumps, the capital cost component and plant footprint requirement are minimal.

4.2.6 Fuel Electrode Sintering

To complete the fuel electrode application step the cell is sintered at approximately 1300°C in a dual atmosphere furnace for two hours. During this process air is delivered to the cell interior while a reducing atmosphere is provided on the fuel electrode side to avoid nickel oxidation. In a high volume facility a continuous furnace system would be utilized to decrease capital and operational costs. Fuel electrodes sintered in this manner have been shown to have the same or better performance than the EVD applied fuel electrode and have been thermal cycled from operating temperature (1000°C) to room temperature over 30 times with no deleterious impact.

4.3 Cell Manufacturing Cost

Table 3 shows the breakdown of cell costs in 1997 dollars based upon materials, labor, capital depreciation, and CMF maintenance costs. Capital equipment was depreciated over a ten year period and the building cost was depreciated over twenty

years. Even though the building was sized and costed for 3 production lines or 450 MWe/year of system capacity, the entire depreciation for the building was included in the cell cost for the first production line (under the capital column of Table 3), which burdened the cell cost by an extra \$3/cell. The material costs are based upon supplier quotations for large volumes equivalent to 100 MWe of SOFCs per year. Labor and maintenance costs are based upon extrapolations from our PMF experience.

Process Step	Material (\$/cell)	Labor (\$/cell)	Capital (\$/cell)	Maintenance (\$/cell)	Total (\$/cell)
Air Electrode	5.97	2.28	2.08	0.27	10.60
Interconnection	0.21	0.75	1.47	0.15	2.58
Electrolyte	9.28	5.94	7.91	2.95	26.08
Nickel Contact	0.45	1.22	0.96	0.01	2.64
Fuel Electrode	2.39	5.66	3.22	0.64	11.91
Total	18.30	15.85	15.64	4.02	53.81

Table 3. Breakdown of Cell Cost.

As seen in Table 3 the cell cost in large volume is only \$53.81 or \$224 per kWe of SOFC output (= \$53.81/cell × 3 × 2496 cells ÷ 1800 kWe). On a total system output basis this reduces to \$134/kW (= 224 × .60). As expected, the electrolyte is the highest cost layer. Interestingly, the fuel electrode has the second highest cost at slightly less than half the cost of electrolyte. A simple comparison of the electrolyte and fuel electrode costs shows that the elimination of an EVD step in favor of a sintering step reduces the cell cost by approximately \$14 (the four cost categories of EVD are comparable whether for electrolyte or fuel electrode). Therefore, changing

the electrolyte deposition process from EVD to sintering would save \$14/cell if a sintered electrolyte could provide the electrical performance and process yield of an electrolyte EVD process.

4.4 PSOFC Generator Manufacturing Cost

For the purpose of this cost study, a conceptual design was performed of a 1.8 MWe PSOFC generator, consisting of three, 600 kWe modules contained within a common pressure vessel as illustrated in Figure 4. Each module consists of 2496 SOFCs arranged in 26 bundle rows, each consisting of 96 cells, as shown in Figures 5 and 6, 16 air plenum assemblies which include 2496 alumina air feed tubes, 24 stack reformer sections which are sandwiched between bundle rows, 1 spent fuel recirculation loop and pre-reformer, insulation, instrumentation, and 1 stack container. Finished cells are assembled into bundle rows with the use of nickel felts and nickel paste. The stack is then assembled by arranging the bundle rows and stack reformer sections in an alternating pattern on a support board assembly which also distributes the reformed fuel to each cell. The spent fuel recirculation loop and the air plenum assemblies are then installed. The stack is then surrounded by insulation and inserted into the stack container completing the 600 kWe module assembly. Three of these modules are inserted into the pressure vessel as shown in Figure 4 forming the 1.8 MWe PSOFC generator.




Fig. 4 1.8 MWe PSOFC Generator




Fig. 5 Cell Bundle Row




Fig. 6 600 kWe Cell Stack

The results of the 1.8 MWe PSOFC generator cost study are given in Table 4. The cost of each component in Table 4 was determined either 1) from quotations by suppliers (e.g., for pressure vessel) or 2) by cost buildup studies of material costs, machining costs, and assembly costs. The cost for "Cell Bundle Rows" includes the cell cost from Section 4.3 plus the value added in going from finished cells to bundle rows. It is important to remember that the total cost of \$539/kWe (SOFC) is the cost per kW of SOFC output only and does not consider the turbine generator output. The PSOFC generator cost per kW of system output equals 60% of 539 or \$323/kW (SYS).

Item	\$/kWe (SOFC)
Cell Bundle Rows	246
Pressure Vessel and Insulation	166
Stack Insulation	49
Stack Reformers	33
Support Board Assembly	18
Air Plenum Assemblies	18
Stack Container	7
Recirculation Loop	2
Total	539

Table 4 1.8 MWe PSOFC Generator Cost Estimate

4.5 PSOFC/GT Power System Cost

The mature installed cost to the customer for a 3 MWe PSOFC/GT Power System is the sum of the PSOFC generator cost (Section 4.4), the balance-of-plant equipment and packaging cost, shipping and site installation cost, and the appropriate markup of these costs to account for supplier's indirect costs and profit. The balance-of-plant is divided into a number of systems:

- Thermal Management System which consists of the gas turbine-generator, recuperator, piping and valves, startup air heater, and skid and enclosure;
- Fuel Supply System which consists of the natural gas desulfurization and delivery system, the purge gas system, and skid and enclosure;
- Instrumentation & Control;
- Power Conditioning System which consists of the DC buss, DC-to-AC inverter, the AC switchgear, and skid and enclosure; and

- Electrical Distribution System which distributes electrical power to equipment within the system (e.g., valve actuators, instruments, control computer, etc.)

Table 5 presents the results of the system cost study. The recuperated turbine-generator subsystem is the major cost item under the Thermal Management System. Cost estimates from small gas turbine manufacturers range from \$600 to \$800 per kWe of T-G output. Since the T-G output is only 40% of the total system output, the cost of the turbine-generator subsystem should not exceed \$320 per kWe of system output ($= 800 \times 0.4$), which constitutes 89% of the cost of the Thermal Management System.

Item	\$/kWe (SYS)
PSOFC Generator	323
Thermal Management System	360
Fuel Supply System	15
Instrumentation & Control	30
Power Conditioning System	110
Electrical Distribution System	10
Sub-Total	848
Shipping & Installation	130
Sub-Total	978
Total Installed Cost (Including 30% Markup)	1271

Table 5. 3 MWe PSOFC/GT Power System Cost Estimate

The conclusion of this cost study is that in large volume production (e.g., >50 units per year), a turnkey price (in 1997 dollars) of \$1300/kWe (SYS) for a 3 MWe

PSOFC/GT Power System should be readily achievable with attractive margins remaining for the supplier.

5. Cost of Electricity Analysis

A cost of electricity (COE) analysis was performed comparing the COE of the 3 MWe PSOFC/GT Power System with that of the most advanced small gas turbine generator system. The latter system called the Advanced Turbine System or ATS is currently under development in the United States and has a target turbine inlet temperature of 2200°F. This ATS has a power output of about 4 MWe, a projected electrical efficiency of 42%, and a projected total installed cost of about \$800/kWe. For comparison, the PSOFC/GT system described herein has a power output of 3 MWe, a projected electrical efficiency of 63%, and a projected total installed cost of \$1300/kWe. The major COE assumptions are 1) a 15% capital charge rate, 2) \$3/MBTU natural gas cost, a plant capacity factor of 85% and 4) replacement of SOFC bundle rows every 10 years at a cost in 1997 dollars of \$250/kWe (SOFC). The COE analyses resulted in the same COE (within 1%) for both systems (4.8 cents/kWh). The relatively high capital cost of the PSOFC/GT system is offset by its relatively low fuel cost. For conservatism, a high capital charge rate and low natural gas cost were used in this analysis, which favor the economics of the ATS. Under expected conditions of lower capital charge rates and/or higher natural gas costs, the PSOFC/GT system would have a lower COE relative to the 4 MWe ATS.

6. Summary and Conclusions

The PSOFC/GT Power System is the most fuel efficient electrical power generation system ever conceived with efficiencies in the range 62-72% depending upon the

ratio of SOFC-to-GT power output, and the type of GT selected. The broad application of this technology will significantly extend the use of our fossil fuel resources. For a 3 MWe PSOFC/GT Power System with an electrical efficiency of 63%, a total installed cost of \$1300/kWe should be readily achievable after 2 to 3 years of commercial production. The projected cost of electricity (COE) for this machine compares very favorably with the projected COE for the most advanced small gas turbine system (ATS), which is also under development. In addition, the PSOFC/GT power system offers lower CO₂ emissions by virtue of its higher efficiency (33% less CO₂ emitted per kWh compared to the small ATS), NO_x emissions of about 1 ppm compared to >10 ppm for the ATS, and no SO_x emissions since sulfur compounds are removed from the natural gas.

M98051181



Report Number (14) DOE/FETC/C -- 98/7293
CONF-9709197 --

Publ. Date (11) 199711

Sponsor Code (18) DOE/FE, XF

UC Category (19) UC-101, DOE/ER

DOE