- U	8 19	3P (5)	ENGINE	ERING	<b>DATA ΤΙ</b>	RANSN	IITTAL	•		1. ED	r 606	° <u>−</u> 348
2. To	: (Rec	eiving Org	anization)		3 From-	(Ociainat	ing Orga	nization)	1 ( 0-1			
G. A	Me	/er			Dlant S	vetome	Techn	ical Racic	4. Relate	CIEUINO.	.:	
Retr	ieva	Progra	ms		i ranc 5	ystems	recim	ical Dasis		11/	А	
5. Pr	oj./Pro	g./Dept./D	iv.:		6. Cog. En	gr.:			7. Purcha	se Order	No :	<u> </u>
Wast	e Mar	nagement			D. F. I	watate				N/	Δ	
8. Or	iginato	r Remarks:							9. Equip.	/Componer	t No :	
Seco	ond to	ransmitt	al for a	approva	1 and re	lease.	Draft	t document		N /	Δ	
revi	ew co	ompleted	and con	nments	incorpor	ated.			10. Syste	m/Bidg./f	acility:	
										N/	A	
11. R	eceiver	Remarks:							12. Major	Assm. Dr	g. No.:	
										N/	Ā	
									13. Permi	t/Permit	Applicati	on No.
										N/	A	
									14. Requi	red Respo	nse Date:	
										N/	A	
15.				DATA	TRANSMITTE	D			(E)	(6)	(#)	(1)
(A)				(C)	(D)	(E) T	fitle or Des	cription of Data	Approval	Reason	Origi-	Receiv
No.	(B)	Document/Dra	awing No.	No.	Hev. No.		Trans	mitted	Desig- nator	for Trans-	nator Dispo-	er Dispo
	<u> </u>							····		mittal	sition	sition
1	WHC	-SD-WM-E	S-392		0	LDMM	Criter	ia for	N/A	1		
						Deter	mining	j Allowable				
·····	İ					Leaka	iye					
						+			+			
6	L									l		
Appr	oval Des	ignator (F)		Reason	for Transmitta	il (G)			Dispositio	n (H) & (l)		
, s, a	, D or N/	A	1. Approva	4. Re	view			1. Approved	4	Reviewed	no/commer	nt
see Wi Sec.12	нс-см-з .7)	-5.	<ol> <li>Release</li> <li>Informati</li> </ol>	5.Pos ion 6.Dis	st-Review it. (Receipt Ack	now. Requi	red)	<ol> <li>Approved w/co</li> <li>Disapproved w/</li> </ol>	mment 5 comment 6	<ol> <li>Reviewed</li> <li>Receipt a</li> </ol>	w/commen	t ri
(G)	(H)	17.			SIG	NATURE/DI	STRIBUTIO	N N			(0)	
					(See Approval	Designator	for require	d signatures)				
son	Disp.	(J) Nam	ne (K)S	igneture (	L)Date (M)M	VISIN	(J) Na	me (K) Signat	ure (L) Date	(M) MSIN	Rea	Disp
1	1	Eng. DF I	watate //-	hiath	1 7-2-9h	H5-09						
1	1	Mgr. JL	Homan	ton	7-2-9	GH5-09						
		QA	1	()	-				President and the second s			
		Safety										
		Env.										
1	1	RP Marsha	all MA	Varch	el J/2/12	H5-61				•		
	1	JS Hertze	1/50	Al	7-7-5	/ H5-61						1
1 1		6	19.	Leve	/ . //	20.			21. DOE A	PROVAL (	if requir	ed)
8.				1 1 5 4		1			Ctal			
1 8. s H <b>4</b> 4	ot	An	GAM	JP4	.1.1	po	Marchall	1 00 11		ND.		
1 8. s.	Hu	Al 7-2	- 54 GA M	who I	- 7/3/4		Man	hell 1/2/16	[] Approve	no. ed ed w∕comm	ents	

BD-7400-172-2 (04/94) GEF097

# Leak Detection, Monitoring, and Mitigation (LDMM) Criteria for Determining Allowable Leakage

#### D. F. Iwatate

Westinghouse Hanford Company, Richland, WA 99352 U.S. Department of Energy Contract DE-AC06-87RL10930

EDT/ECN:	606481	UC: 721	
Org Code:	73530	Charge Code:	D2046
B&R Code:	EW3130010	Total Pages:	-39 40

Key Words: Single-Shell Tanks, waste, leak, detection, monitoring, mitigation

Abstract: This document proposes criteria and measures for leak detection, monitoring, and mitigation (of Hanford single-shell tanks during waste retrieval by sluicing) to support fulfillment of TPA Milestone M45-08-T02. This milestone specifies that, "...criteria for determining allowable leakage volumes..." will be presented to Washington State Dept of Ecology for approval. This document presents candidate criteria statements, including summary of issues and recommended resolution.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: WHC/BCS Document Control Services, P.O. Box 1970, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

4. Noland



**Approved for Public Release** 



# FOSTER WHEELER ENVIRONMENTAL CORPORATION

# LDMM Criteria for Determining Allowable Leakage

WHC-SD-WM-ES-392, REV. 0

May 24, 1996

Prepared for

Westinghouse Hanford Company Tank Waste Remediation System Task 021 of Order No. MGK-SVV-186918

Prepared by

Foster Wheeler Environmental Corporation 1981 Snyder Road, Suite 3 Richland, WA 99352

# ACRONYMS AND ABBREVIATIONS

COC	constituents of concern
DOE	U.S. Department of Energy
DST	double-shell tank
Ecology	Washington State Department of Ecology
EIS	Environmental Impact Statement
ERT	electrical resistivity tomography
ILCR	incremental lifetime cancer risk
LDMM	leakage detection, monitoring, and mitigation
MCL	Maximum Contaminant Level
MEI	maximally exposed individual
RCRA	Resource Conservation and Recovery Act
SST	single-shell tank
Tri-Party	-
Agreement	Hanford Federal Facility Agreement and Consent Order
TWRS	Tank Waste Remediation System

# WHC-SD-WM-ES-392 REV. 0

This page intentionally left blank.

# TABLE OF CONTENTS

1.0	INTRODUCTION AND BACKGROUND	1-1
2.0	SUMMARY OF ALLOWABLE LEAKAGE DETERMINATION STRATEGY	2-1
	2.1 TIER 1: SOIL CAPACITY VALUE	2-1
	2.1.1 Fate of Leakage From SSTs	2-2
	2.1.2 Calculation of Soil Capacity Value	2-2
	2.2 TIER 2: MAXIMUM POTENTIAL LEAKAGE	2-3
	2.2.1 Calculation of Maximum Potential Leakage	2-3
	2.3 TIER 3: MINIMUM PRACTICABLE ACHIEVABLE LEAKAGE	2-4
3.0	ALLOWABLE LEAKAGE CRITERIA	3-1
	3.1 CRITERION 1 - CONTROLLING RISK SCENARIO	3-2
	3.1.1 Importance of Criterion	3-2
	3.1.2 Criterion Recommendation	3-2
	3.2 CRITERION 2 - RISK MODELS AND DATA	3-3
	3.2.1 Importance of Criterion	3-3
	3.2.2 Criterion Recommendation	3-3
	3.3 CRITERION 3 - POINT OF COMPLIANCE	3-4
	3.3.1 Importance of Criterion	3-4
	3.3.2 Criterion Recommendation	3-4
	3.4 CRITERION 4 - PERIOD OF COMPLIANCE	3-5
	3.4.1 Importance of Criterion	3-5
	3.4.2 Criterion Recommendation	3-5
	3.5 CRITERION 5 - CONSTITUENTS OF CONCERN	3-6
	3.5.1 Importance of Criterion	3-6
	3.5.2 Criterion Recommendation	3-6
	3.6 CRITERION 6 - VADOSE ZONE FLUX DISTRIBUTION	3-7
	3.6.1 Importance of Criterion	3-7
	3.6.2 Criterion Recommendation	3-7
	3.7 CRITERION 7 - ALLOWABLE RISK	3-8
	3.7.1 Importance of Criterion	3-8
	3.7.2 Criterion Recommendation	3-8
	3.8 CRITERION 8 - TANK SOURCES OF RISK	3-9
	3.8.1 Importance of Criterion	3-9
	3.8.2 Criterion Recommendation	3-9
	3.9 CRITERION 9 - LEAKAGE CONCENTRATIONS	-10
	3.9.1 Importance of Criterion	-10
	3.9.2 Criterion Recommendations	-10
	3.10 CRITERION 10 - ACCEPTABLE CLOSURE OPTIONS 3	-11
	3.10.1 Importance of Criterion 3	-11
	3.10.2 Criterion Recommendation 3	-11

# TABLE OF CONTENTS (cont'd)

	3.11 (	CRITERIO	N 11 - LEAKAGE VOLUMES	3-12
		3.11.1 Im	portance of Criterion	3-12
		3.11.2 Cr	iterion Recommendations	3-12
	3.12 (	CRITERIO	N 12 - ALIGNED WASTE SOURCES	3-13
		3.12.1 Im	portance of Criterion	3-13
		3.12.2 Cr	iterion Recommendation	3-13
	3.13 (	CRITERIO	N 13 - RISK APPORTIONMENT	3-14
		3.13.1 In	portance of Issue	3-14
		3.13.2 Cr	iterion Recommendation	3-14
	3.14 (	CRITERIO	N 14 - LEAKAGE DETECTION TECHNOLOGY	3-15
		3.14.1 In	portance of Criterion	3-15
		3.14.2 Cr	iterion Recommendation	3-15
	3.15 (	CRITERIO	N 15 - LEAKAGE MITIGATION TECHNOLOGY	3-16
		3.15.1 Im	portance of Criterion	3-16
		3.15.2 Cr	iterion Recommendations	3-16
	3.16 (	CRITERIO	N 16 - INDIVIDUAL TANK CHARACTERISTICS	3-17
		3.16.1 In	portance of Criterion	3-17
		3.16.2 Cr	iterion Recommendation	3-17
	3.17 (	CRITERIO	N 17 - EXCEEDANCE OF ALLOWABLE LEAKAGE	
		VALUES	· · · · · · · · · · · · · · · · · · ·	3-18
		3.17.1 In	portance of Criterion	3-18
		3.17.2 Cr	iterion Recommendation	3-18
	3.18 (	CRITERIO	N 18 - EXCEEDANCE OF LEAKAGE CEILINGS	3-19
		3.18.1 In	portance of Criterion	3-19
		3.18.2 Ci	iterion Recommendation	3-19
	3.19 (	CRITERIO	N 19 - ABSOLUTE LIMIT ON ALLOWABLE LEAKAGE	3-20
		3.19.1 In	portance of Criterion	3-20
		3.19.2 Ci	riterion Recommendation	3-20
40	EXAMP	LE PROCE	SS FOR DERIVING ALLOWABLE LEAKAGE VALUES	. 4-1
	4 1 P	RELIMINA	RY ALLOWABLE LEAKAGE VALUES	. 4-1
	4.2 A	DJUSTED	ALLOWABLE LEAKAGE VALUES	. 4-3
5.0	SUMMA	RY OF CF	ATTERIA RECOMMENDATIONS REQUIRING	E 1
	APPR	JVAL		. 5-1
6.0	REFERE	NCES		. 6-1

# LIST OF TABLES

3-1	Allowable Leakage Criteria and Associated Issues	3-1
4-1	Hypothetical Preliminary Allowable Leakage Criteria	4-3
5-1	Summary of Criteria Recommendations	5-1

# WHC-SD-WM-ES-392 REV. 0

### **1.0 INTRODUCTION AND BACKGROUND**

The M-45 series of *Hanford Federal Facility Agreement and Consent Order* (Tri-Party Agreement) milestones address leakage from single-shell tanks (SSTs) during waste retrieval. Tri-Party Agreement milestone M-45-08-T02 specifies that, "criteria for determining allowable leakage volumes, and acceptable leakage monitoring, detection, and mitigation measures necessary to permit slucing operations" be approved by the Washington State Department of Ecology (Ecology). To meet this milestone, the U.S. Department of Energy (DOE) and its contractors will (1) develop the background and basis for a criteria decision, (2) propose appropriate criteria and measures for leakage detection, monitoring, and mitigation (LDMM), and (3) establish an agreement with Ecology regarding the issues and recommendations. This document addresses item 2, propose appropriate criteria and measures for LDMM.

The allowable leakage from a single-shell tank during new sluicing operations should be based on relevant regulatory, policy, and technical criteria. These criteria are measures or approaches (to resolve questions/issues) that will provide a basis for making decisions regarding LDMM and allowable leakage during SST waste retrieval. The criteria should be supported by accepted and/or approved enabling assumptions and data. There are significant issues, assumptions, and data related to each criterion. Resolution of issues will require policy decisions or guidance, and improved data in some cases. The following sections identify the larger issues and make recommendations regarding reasonable assumptions and data needs.

Section 2 provides a summary of the LDMM operational strategy and introduces a graded or tiered approach to establish allowable leakage values. Section 3 identifies preliminary criteria and recommendations for resolving issues that may impact the level of allowable leakage. Section 4 gives an example of a proposed process for determining preliminary allowable leakage values for planning purposes and a hypothetical example of how these values would change as tank waste retrieval proceeds. The key criteria and recommendations are summarized in Section 5.

# WHC-SD-WM-ES-392 REV. 0

This page intentionally left blank.

# 2.0 SUMMARY OF ALLOWABLE LEAKAGE DETERMINATION STRATEGY

Past-practice sluicing has been selected as the method that will be used to remove saltcake and sludge waste from Hanford Site SSTs. Three LDMM concerns during sluicing are (1) determining when a leakage "event" has occurred, (2) ensuring adequate surveillance of existing or new leak plumes, and (3) taking responsible retrieval actions that minimize the potential for leakage to occur. These concerns will be addressed through appropriate operational responses and the use of devices for leakage detection, leakage plume monitoring, and leakage mitigation. Retrieval operations will apply current LDMM measures to maintain leakage at the lowest levels practicable and below allotted leakage ceilings. Establishment of [allowable] operational leakage parameters will be achieved by risk-based decision making applied to a set of criteria. Allowable leakage criteria have been identified and prioritized for consideration within the decision-making process. All of the criteria fall into a sequence or path to establishing the allowable leakage volume. This path consists of the following steps:

- Enabling assumptions are made
- Required data are obtained and reviewed
- Issues are addressed to a "concluding point"
- Decisions are made
- Criteria are developed to a clear statement and are closed
- The criteria are sequentially addressed, resulting in preliminary allowable leakage volumes
- The assumptions and data are reviewed and the allowable leakage volumes revised as waste retrieval proceeds.

Three major tiers have been recommended to establish allowable leakage values: (1) site-specific soil moisture retention capacity, (2) maximum potential leakage due to retrieval by sluicing, and (3) leakage constraints that will be imposed upon operations during actual retrieval/sluicing activities. This three-tiered approach to defining leakage boundaries is discussed in the following sections.

#### 2.1 TIER 1: SOIL CAPACITY VALUE

At Tier 1 a combination of historical and theoretical data will be evaluated and compared with vadose zone modeling data to produce a bounding value for the retention capacity of leakage in the soil beneath a target tank and/or tank farm. This value represents the highest volume of liquid waste (maximum tolerable leakage) that could be expected to penetrate into the surrounding soil to a depth that would not render impractical the remediation of unacceptable contamination resulting from the leakage. The modeling applied for this decision would include consideration of existing leakage plumes, and local soil and hydrology characteristics. This volume provides the first level of maximum tolerable leakage volume. Leakage of this magnitude would have a high potential to impact the groundwater within several decades if not remediated, and would substantially contaminate the soil in and around the target tank.

#### 2.1.1 Fate of Leakage From SSTs

Leakage that occurs from SSTs will pass through the pore spaces between soil particles and migrate laterally and downward due to the force of gravity and the stratigraphic, anisotropic, and other physical characteristics of the soils. The resulting plumes will generally be ellipsoidal and elongated in the horizontal direction. A newly created plume will spread in the soil rather quickly when leakage first occurs. Its growth will diminish when the water has spread to the point that the plume water becomes restrained in the soil capillaries. The plume will then migrate very slowly toward the water table. Downward plume migration rates depend on (1) recharge (the amount of precipitation that infiltrates the soil after subtracting evaporation and transpiration by plant roots) and (2) the physical characteristics of the soil that control the ability of the soil to retain water. These rates can vary from about 1 in. per year to more than 35 ft per year for the different water contents and soil types found beneat the Hanford Site 200 Areas tank farms.

An example of the fate of leakage from an SST is Tank 241-T-106, which leaked 115,000 gal in 1973. This is the largest tank leakage experienced to date at the Hanford Site. The leakage from this tank formed a generally static plume about 180 ft long, 160 ft wide, and 70 to 90 ft deep. Leakage investigations in 1979 indicated that the leakage was located at least 95 ft above the water table. Later monitoring in 1993 and 1994 indicated that the base of the plume was about 75 ft above the water table. These results cannot be directly compared because they are based on monitoring of different radionuclides; however, they do provide support to the concept of a relatively large soil leakage retention capacity and a relatively slow migration rate.

#### 2.1.2 Calculation of Soil Capacity Value

Tank razing and soil excavation are the assumed remedial actions that would be taken for mitigating leakage when the leakage ceiling established to enable the most cost-effective closure approach is exceeded. There are practical limits to these actions, based on worker risk and cost, number of tanks razed, soil volume excavated, and depth of soil excavation. The moisture retention capacity of the soil and the leakage plume's rate of downward movement are dependent on the properties of the soil. The allowable time period from the original leak until mitigative actions are completed must be established.

Based on a cursory review of data on site soil beneath the Hanford Grout Facility, it is estimated that the soil can hold an additional 8 vol% or more of moisture before its matric potential would increase to a level above -10 cm water. Water will freely drain in soil at a matric potential of about zero or higher. The base of many of the SSTs are approximately 150 ft above the aquifer. If the plume cross-section is assumed to be equal to the tank footprint and to extend halfway to the aquifer, the soil leakage capacity value is 200,000 gal or larger, based on a minimum moisture increase of 8 vol%. This is in rough agreement with the Tank 241-T-106 leakage data described in Section 2.1.1. This value is compared with the maximum potential leakage volume (Tier 2) described in Section 2.2.

#### 2.2 TIER 2: MAXIMUM POTENTIAL LEAKAGE

A comparison between the volume of a maximum potential leakage that could occur from a target tank due to a retrieval action such as sluicing (Tier 2), and the Tier 1 soil capacity value should be made. The Tier 2 maximum potential leakage would occur if the leakage detection and response system failed to detect and mitigate catastrophic leakage that occurred near the beginning of retrieval operations. The difference between Tier 1 and Tier 2 leakage values provides a measure of the effectiveness of the soil beneath the tank to ensure interim protection of the groundwater, if the maximum leakage were to occur. Even though the potential for the occurrence of maximum volume leakage (Tier 2) is very small, there is no way to guarantee against it. This is due to the lack of significant and absolute control over leakage once it occurs, and the inaccuracy with which leakage can be detected using currently available technology. Therefore, the risks associated with this maximum volume of leakage must be judged "acceptable" before proceeding with sluicing.

#### 2.2.1 Calculation of Maximum Potential Leakage

The SST slurry pump and the double-shell tank (DST) sluice pump flow rates will be matched during sluicing to continually maintain a head of liquid over the slurry pump intake. A major leak in the SST in this case would lower the head in the slurry pump and cause the pump to cavitate, signalling potential leakage to the operators. The sluicing system would be shut down with no further liquid added to the SST. The volume of liquid that could leak if a catastrophic leak were to occur at this point is the liquid head at the pump intake plus the drainable liquid contained in the waste. The maximum leakage would occur if the catastrophic leak happened near the beginning of the retrieval operation when the waste volume is at a maximum and when the pump intake is submerged in liquid.

Two cases of maximum potential leakage were evaluated based on data from the *Waste Tank Summary Report for the Month Ending October 31, 1995* (Hanlon 1995). These include an upper bounding case and an average case. The upper bounding case is a tank nearly full of saltcake waste (i.e., Tank 241-A-101, which contains 950,000 gal of saltcake). Much of the liquid held in the saltcake waste can be assumed to drain, whereas sludge waste has small particle sizes and will tend to hold the interstitial liquid tightly (i.e., it has a high capillarity). The average SST contains 156,000 gal of saltcake waste and 79,000 gal of sludge waste.

A reasonable assumption is that the retrieval system is operated to maintain a 2-ft head of liquid above the SST slurry pump intake. This equates to 66,000 gal of liquid in a 75-ft diameter tank. The volume of drainable liquid for the Tank 241-A-101 upper bounding case is given in Hanlon (1995). The ratios of drainable liquid to total waste for saltcake and sludge waste can be derived from Tank 241-A-101 data in Hanlon (1995). Applying these ratios to the average case and adding the 66,000 gal from the assumed liquid head gives the following result. The potential upper bounding case leakage is provided for comparison.

Average Case	140,000 gai
Upper Bounding Case (Tank 241-A-101)	480,000 gal.

# 2.3 TIER 3: MINIMUM PRACTICABLE ACHIEVABLE LEAKAGE

The Tier 1 analysis established the maximum volumes of leakage allowable to ensure interim protection of the groundwater. In most cases the maximum potential leakage determined in the Tier 2 analyses will be less than Tier 1 levels. Lower levels of allowable leakage (Tier 3) will be imposed to create an even greater degree of protection. The Tier 3 levels serve as constraints within which retrieval actions can proceed. Tier 3 leakage limits will be imposed as a means of optimizing potential for cost-effective and compliant closure of the tanks following sluicing. Actions that will help attain these limits and the goal of minimum practicable achievable leakage of pre-approved operational leakage response actions, enhancing design of the sluicing equipment, modifying current operations procedures and decision-making plans, and making maximum use of currently available technologies and methods.

The allowable leakage criteria associated with the three-tiered approach to defining leakage boundaries are discussed in greater detail in Section 3.

# 3.0 ALLOWABLE LEAKAGE CRITERIA

The allowable leakage from an SST during new sluicing operations should be based on relevant regulatory, policy, and technical/operational criteria. The criteria should be supported by accepted and/or approved enabling assumptions and data. There are significant issues associated with the criteria and the assumptions and data. Resolution of issues will require policy decisions, guidance, and improved data. This will lead to clarification and closure of the criteria. This section identifies 19 important allowable leakage criteria and includes recommendations for the quantification and justification of each. A summary of the leakage criteria and related issues is provided in Table 3-1.

# Table 3-1. Allowable Leakage Criteria and Associated Issues.

			1	DECI	SION LEVEL
			1	là.	Jai s
		/			
NO.	ALLOWABLE LEAKAGE CRITERIA	$\int_{\mathcal{A}}$	NIN C		
1	Controlling Risk Scenario (T3)	×			
2	Risk Models and Data (T3)	×		×	
3	Point of Compliance (T3)	×			
4	Period of Compliance (T3)	×			
5	Constituents of Concern (T3)	×		×	
6	Vadose Zone Flux Distribution (T3)			×	
7	Allowable Risk (T3)	×			
8	Tank Sources of Risk (T3)			×	
9	Leakage Concentrations (T3)			×	
10	Acceptable Closure Options (T1, T3)	×	×		
11	Leakage Volumes (T3)			×	
12	Aligned Waste Sources (T3)	×			
13	Risk Apportionment (T3)	×	×	×	
14	Leakage Detection Technology (T2, T3)		×		
15	Leakage Mitigation Technology (T1, T2, T3)		×		
16	Individual Tank Characteristics (T2, T3)			×	
17	Exceedance of Allowable Leakage Values (T1, T3)		×		
18	Exceedance of Leakage Ceilings (T1, T3)	×			
19	Absolute Limit on Allowable Leakage (T1)	×	×	×	

T1 = Applicable to Tier 1 T2 = Applicable to Tier 2 T3 = Applicable to Tier 3

# 3.1 CRITERION 1 - CONTROLLING RISK SCENARIO

Establish the controlling risk scenario to determine how much leakage is harmful.

# 3.1.1 Importance of Criterion

The controlling risk scenario must be established to provide the basis for making defensible risk-based decisions regarding potential impacts of waste leakage. Various risk scenarios are evaluated under the National Environmental Policy Act, the Comprehensive Environmental Response, Compensation, and Liability Act, the Resource Conservation and Recovery Act (RCRA), and DOE guidance to support remedial action decision making. Common risk scenarios include those that adversely impact worker health and safety, degrade short- and long-term public health, and damage the ecology. The primary objective of most cleanup actions is to ensure long-term protection of human health. Most long-term risk analyses focus on the impacts to a maximally exposed individual (MEI) who uses contaminated groundwater or surface water. The draft Tank Waste Remediation System (TWRS) Environmental Impact Statement (EIS) focused its evaluation on the health risk to a maximally exposed onsite farmer who uses contaminated groundwater under the Hanford Site. Regulatory limits exist to protect the groundwater and users of groundwater (e.g., Maximum Contaminant Levels [MCLs]). The draft TWRS-EIS also evaluated an intruder risk scenario that showed significantly higher risks to the intruder; however, no regulatory limit is known to exist for the protection of intruders. The existence of regulatory limits for protection of groundwater supports selection of the onsite MEI farmer using contaminated Hanford groundwater as the controlling risk scenario.

#### 3.1.2 Criterion Recommendation

The controlling risk scenario for SST leakage should be exposure of the MEI (onsite farmer) to contaminated drinking water from a well and to farm products grown with the same well water. The same risk exposure pathways and parameters used in the draft TWRS-EIS should be used for preliminary evaluations of allowable leakage. This will enhance comparability to the TWRS analyses and promote better understanding and approval by the sponsoring agencies (Ecology and DOE). The intruder scenario should not be selected as the controlling risk scenario because no regulatory limits exist for protecting intruders.

# 3.2 CRITERION 2 - RISK MODELS AND DATA

Establish the mathematical models, boundary conditions, and input data to be used to simulate the controlling risk scenario.

### 3.2.1 Importance of Criterion

It is necessary to establish a consistent, approved approach for using specific models, data, and boundary conditions to increase acceptance of the modeling results. Large differences in calculated risks can result when different contaminant fate and transport models and assumptions are used. The draft TWRS-EIS used (1) a congruent dissolution model to simulate release of contaminants from the tanks to the vadose zone, (2) a one-dimensional advective-dispersion (no diffusion) model to simulate transport of contaminants through the vadose zone, and (3) a one-dimensional advective-dispersion model to simulate transport of contaminants in the aquifer to the Columbia River. Adjacent tank farms were grouped into source areas in the draft TWRS-EIS. The contaminant flux from each source area was assumed to be uniformly released into a vadose-zone cell with surface dimensions of 0.6 by 0.6 mi. The flux entering the groundwater was assumed to be dispersed uniformly and vertically in the groundwater to a depth of 20 ft. The resulting groundwater plume was assumed to disperse laterally and horizontally within the constraints of established Hanford Site aquifer boundary conditions. This model is appropriate for far-field projections of risk to the MEI (onsite farmer).

Other refinements, such as (1) including past leakage in the analysis, (2) including a diffusion algorithm in the vadose zone transport model, (3) using solubility-limited release algorithms, and (4) reducing the dimensions of the vadose zone flow cells to correspond to the footprints of individual tank farms have been used in previous modeling efforts.

### 3.2.2 Criterion Recommendation

Simple one-dimensional release algorithms and transport models should be used for preliminary evaluations of allowable leakage. The same or equivalent algorithms and models used in the draft TWRS-EIS should be employed. Boundary conditions and input data should be identical. Future refinements to models and data should be clearly described and rationale for the changes should be provided. A consistent modeling approach will facilitate comparison of results and enhance defensibility of allowable leakage analyses.

# 3.3 CRITERION 3 - POINT OF COMPLIANCE

Establish the point of compliance following closure of a tank farm.

#### 3.3.1 Importance of Criterion

The point of compliance for a closed waste site is defined in a RCRA closure plan and is usually near the boundary of the waste site. Future Hanford land-use planning efforts may result in establishing a long-term waste disposal site or exclusion area that encompasses both the 200 East and 200 West Areas. The boundaries of the long-term waste site may be a mile or more downgradient from the nearest tank. Groundwater plumes generally increase in width and depth as a function of distance from the contributing waste sources. The increasing plume size is primarily caused by advective dispersion, and results in diluting the contaminant concentrations in the plume. Lower concentrations in the plume equate to lower risk. Thus, the nearer the tank farm, the higher the risk. Assumptions should be made about possible locations of boundaries and compliance points to estimate potential groundwater concentrations of constituents of concern (COCs) and associated risks.

## 3.3.2 Criterion Recommendation

The risk impacts at several potential compliance points should be evaluated to establish the sensitivity of waste site boundary locations. The risk impacts associated with residual waste in the tanks following sluicing and other significant sources such as leakage, should be added to determine cumulative risk. The cumulative risk should be compared to potential risk threshold(s) in the closure plan(s) to determine if compliance can be achieved. These risk analyses will demonstrate the relationship between compliance points and retrieval actions that impact the amount of residual tank waste and amount of leakage (and associated risk) that may occur.

# 3.4 CRITERION 4 - PERIOD OF COMPLIANCE

Establish the period of time over which compliance must be assured.

#### 3.4.1 Importance of Criterion

The COCs in Hanford Site tanks pose different risks due to differing toxicities and mobilities. Certain COCs move with the speed of water because they do not chemically sorb onto soil. Other COCs sorb to varying degrees. If a Hanford Barrier is used over tank farms as part of the closure plan, the barrier will significantly restrict water recharge. Precipitation that penetrates the barrier will not reach the water table for thousands of years. Thus, only the most mobile COCs will reach the groundwater within the 10,000-year period of regulatory interest. If the Hanford Barrier limits recharge to less than 0.05 cm/yr, the peak flux of contaminated water to the water table may be delayed to a time after 10,000 years. For all practical purposes, the delay is not dependent on the amount of residual waste in the tanks, nor on the amount of leakage that has occurred. In theory, the Hanford Barrier can eliminate all risks to the MEI within the 10,000 year timeframe, regardless of whether waste removal actions have been taken.

#### 3.4.2 Criterion Recommendation

The Hanford Barrier is a key element of the overall strategy for remediating tank farms and its effectiveness must be evaluated. Physical evidence and continuing studies may show that the barrier can limit recharge to less than 0.05 cm/yr for more than 10,000 years, assuming barrier maintenance will be performed over that time period as necessary to ensure effective performance. The impacts to risk and compliance for this case should be evaluated over a period that captures the peak risks associated with mobile COCs. This approach is justified if future land-use decisions result in creating a secure, long-term waste disposal area that encompasses the 200 Areas. The assumption is that a secure waste disposal area is considered a threat to human intrusion and maintained for as long as the disposal area is considered a threat to human health. Thus, the period of compliance should be 10,000 years, but longer if required to capture peak COC groundwater concentrations.

### 3.5 CRITERION 5 - CONSTITUENTS OF CONCERN

Determine the components of SST waste that should be considered COCs.

#### 3.5.1 Importance of Criterion

Risk analyses performed at the Hanford Site repeatedly identify the same COCs when the Hanford Barrier is employed and when the period of compliance is less than 50,000 years. The identified COCs are mobile and nonsorbing, and include <sup>99</sup>Tc, <sup>129</sup>I, <sup>14</sup>C, uranium, and nitrate (including nitrite). These COCs typically contribute to greater than 95% of the cumulative carcinogenic and noncarcinogenic risks.

#### 3.5.2 Criterion Recommendation

The recommended COCs are <sup>99</sup>Tc, <sup>129</sup>I, <sup>14</sup>C, uranium, and nitrate. Analyzing only the most significant contributors to risk reduces cost without compromising defensibility of the analysis.

# 3.6 CRITERION 6 - VADOSE ZONE FLUX DISTRIBUTION

Establish whether the flux of COCs released into the vadose zone from tank farm groupings should be assumed uniformly distributed within a 0.6- by 0.6-mi cell as in the draft TWRS-EIS, or be assumed as released from individual tank farms into cells approximately equal to the footprints of the individual farms.

## 3.6.1 Importance of Criterion

The radius of influence of a well sufficient to meet the drinking water and irrigation needs of a residential farm is about the width of a typical tank farm footprint (e.g., approximately 400 ft). Thus, if the point of compliance is near the farm, the well can theoretically capture the entire COC flux as it enters the groundwater. The cells evaluated in the draft TWRS-EIS are about eight times the width of a tank farm. Each tank farm cell in the draft TWRS-EIS contains two or more tank farms. Therefore, the draft TWRS-EIS approach will yield lower risk results by up to a factor of four when the point of compliance is near the tank farm. At distances of several miles, the individual plumes will converge and mix due to the effects of advective dispersion. The draft TWRS-EIS approach yields the most defensible risk values when the point of compliance is a substantial distance from the tank farms.

#### 3.6.2 Criterion Recommendation

A vadose zone modeling approach should be selected that is technically consistent with assumed point(s) of compliance. Several points of compliance should be evaluated pending definition of the boundaries of a future waste disposal zone(s) that includes the tank farms. An appropriate modeling approach is warranted for near-field points of compliance.

### 3.7 CRITERION 7 - ALLOWABLE RISK

Establish the allowable risk to the MEI (onsite farmer).

# 3.7.1 Importance of Criterion

Drinking water typically is the primary source of risk to the MEI. The generally accepted upper limits of risks following cleanup of waste sites are an incremental lifetime cancer risk (ILCR) of  $10^{-4}$  and a hazard index of 1.0. Washington State's Model Toxic Control Act sets an upper limit of  $10^{-5}$  (ILCR) for Level B cleanups. The limit of 4 mrem/y for consumption of drinking water containing radionuclides is equivalent to an ILCR of 1.2 x  $10^{-4}$ .

The preferred alternative identified in the draft TWRS-EIS yields a peak risk of  $3 \times 10^4$ . Thus, the combined risk impacts of the two sources analyzed in the draft TWRS-EIS, residual tank waste following retrieval and the 4,000 gal assumed to have leaked from each tank, exceed all regulatory cleanup limits. Previous work performed by Foster Wheeler Environmental indicates that the risks associated with leakage of this magnitude are relatively small in comparison to the risks associated with 1% residual waste in the tanks. Therefore, the risks associated with the residual waste in the tanks alone are only somewhat less than  $3 \times 10^4$ . Thus, no leakage from tanks can be allowed unless regulatory limits are raised, unless alternate modeling assumptions are made, unless the level of residual waste in the tanks is reduced, or unless a decision is made that the tanks should be razed and contaminated soil and debris removed.

#### 3.7.2 Criterion Recommendation

The effects of alternate modeling assumptions and greater than 99% cleanup effectiveness should be evaluated against cleanup limits of  $10^4$  and  $10^5$  ILCR, and a hazard index of 1.0. This evaluation is needed to define conditions that would allow for leakage within acceptable risk constraints, and permit cost-effective closure using backfilling and the Hanford Barrier.

# 3.8 CRITERION 8 - TANK SOURCES OF RISK

Establish the risk impacts of other sources, e.g., past leakage into the ground and into tank concrete, that should be considered in addition to the risk impacts of residual tank waste and new leakage.

#### 3.8.1 Importance of Criterion

Consideration of the risks associated with past leakage may be important for establishing allowable leakage thresholds where high leakage or high-risk leakage has occurred in the past, e.g., in T Tank Farm. Neither past leakage nor contaminated concrete was specifically addressed in the draft TWRS-EIS, although it may have been assumed that these sources are included in the 1% residual waste source following retrieval operations. The combined effect of these two sources on risk is smaller than the effect of 1% residual waste remaining in the tanks.

#### 3.8.2 Criterion Recommendation

The cumulative risk impacts of all tank sources should be considered, especially if alternate modeling assumptions do not significantly reduce apparent risk and/or if relief in regulatory risk limits cannot be considered or granted at this time. This outcome would drive the need to achieve greater retrieval effectiveness (e.g., 0.1% residual waste in the tanks). The relative contribution of past leakage into the ground and into concrete would then become significant.

# 3.9 CRITERION 9 - LEAKAGE CONCENTRATIONS

Determine the methods that should be used to estimate the concentrations of COCs in leakage and the residual tank waste.

# 3.9.1 Importance of Criterion

The concentrations of soluble COCs in the tank liquid, especially <sup>99</sup>Tc, should be better estimated to determine the risks due to tank leakage and residual tank waste. There is evidence that <sup>99</sup>Tc, the primary contributor to carcinogenic risk, concentrates in the interstitial liquid that occupies the pore spaces between sludge particles. When an increased hydraulic head of standing sluicing liquid exists in a tank, interstitial liquid may preferentially be driven from the tank through leaks in the tank steel. Improved sluicing methods that would minimize such leakage are under consideration. These methods involve sluicing in the core area of the tank waste in order to retain a layer of waste over holes that may exist in the wall of the tank. When the protective layer of saltcake or sludge on the wall is subsequently removed by sluicing, the concentrations of <sup>99</sup>Tc and the other soluble COCs in the sluicing liquid would be in approximate proportion to their average compositions in the tank.

A small sludge heel is likely to remain when sluicing a tank is completed. The heel material in some tanks has agglomerated and thus, probably has a smaller pore volume than sludge that has not agglomerated. A smaller pore volume would yield a lower fraction of interstitial liquid containing soluble <sup>99</sup>Tc and other COCs. However, the sludge particles may contain higher relative amounts of uranium and associated COCs if relatively large particles of undissolved fuel were transferred to the tank. Little information exists on the concentrations of COCs in heels relative to their concentrations in sludge that exists above it.

#### 3.9.2 Criterion Recommendations

Average relative concentrations of COCs in sluicing liquid and in sludge should be used until better data are obtained through tank characterization efforts. Concentrations of <sup>99</sup>Tc and other COCs proportioned to the saturated concentration of nitrate in interstitial liquid should be used for estimating leakage risks. This approach represents a balance between the higher relative concentrations of <sup>99</sup>Tc observed in interstitial liquid and the below-saturated conditions that will probably exist in sluicing waters at the time tank holes are exposed.

#### WHC-SD-WM-ES-392 REV. 0

# 3.10 CRITERION 10 - ACCEPTABLE CLOSURE OPTIONS

Identify and establish the acceptability of closure options.

#### 3.10.1 Importance of Criterion

There are two basic options for closing tank farms following retrieval of tank wastes: (1) fill the tanks with gravel or grout and cover with a Hanford Barrier (Option 1) or (2) raze the tanks, and retrieve and decontaminate tank debris and contaminated soil (Option 2). Foster Wheeler evaluated in situ washing of contaminated soil as a third option (Option 3), but concluded that the technology would be relatively ineffective and costly. Option 1 is preferred for Hanford Site Tank closure because it involves proven and relatively safe technology. Option 2 is feasible, but is likely to be very expensive pose high worker risks.

#### 3.10.2 Criterion Recommendation

Option 1, filling the tanks following sluicing and covering with a Hanford Barrier, is the preferred option due to its relatively low cost, low risk to workers, and use of simple, easily implemented technology. Sluicing can probably be augmented with other tank waste retrieval technologies, such as robotic excavation, as necessary to achieve final cleanup objectives and allow implementation of Option 1 as a compliant alternative. Option 2 should be avoided, wherever possible, by employing optimized sluicing and other effective means to retrieve tank waste and limit leakage. Options 2 or 3 should be exercised only if no other cost-effective supporting technology exists to retrieve waste and limit leakage to levels that would ensure compliance using Option 1. Planning for Options 2 or 3 may be necessary if compliance limits are restrictive and if limits cannot be met with Option 1.

# 3.11 CRITERION 11 - LEAKAGE VOLUMES

Establish the best method for quantifying the volumes of past and future leakage.

# 3.11.1 Importance of Criterion

Past and future leakage are two contributors to cumulative risk. The volumes of leakage are multiplied by the associated concentrations of COCs in the leakage to establish the source terms used for risk modeling. Hanlon 1995 reports 67 tanks have leaked a total of 600,000 to 900,000 gal of liquid waste during past sluicing and waste storage periods.

The amount of new leakage expected during new sluicing operations has been estimated at between 4,000 and 40,000 gal per leaking tank. Past leakage volumes averaged 11,000 gal per leaking tank. Foster Wheeler assumed that 42% of all tanks would leak, averaging 40,000 gal apiece during new sluicing operations. These assumptions were based on historical tank failure rates and an estimate of potential leakage from Tank 241-C-106 provided by Westinghouse Hanford Company. Average new leakage of 4,000 gal was assumed for each of the tanks in the draft TWRS-EIS. The assumptions made in the draft TWRS-EIS would result in a factor of four lower overall new leakage, compared to the Foster Wheeler analysis. However, most of the cumulative risk is attributable to the 1% residual tank waste. Thus, the overall effects of the different leakage assumptions are relatively small. However, the overall effects would be substantial if the residual waste goal were reduced to 0.1%.

#### 3.11.2 Criterion Recommendations

Actual leakage volumes during sluicing are expected to vary over a fairly wide range depending on tank conditions and the methods of leak detection and mitigation technologies employed. Improved sluicing techniques (i.e., sluicing the core area of the tank first to retain a layer of waste over holes that may exist in the tank wall) should reduce the potential for and quantity of leakage. This benefit may be offset by the effects of tank aging, which may increase rates of leakage due to creation of cracks and holes caused by tank settling and corrosion.

Longer sluicing durations than in the past may also be required due to the presence of thick saltcake layers and the increased potential for agglomeration of sludge particles, both of which would increase the difficulty of sluicing. An increased sluicing time equates to a longer hydraulic head time. The volume of leakage is directly proportional to both the magnitude of head and the time period of applying the head above a leak. Pending a more rigorous analysis, the average leakage from tanks in the past (11,000 gal) is preliminarily recommended for each tank assumed to leak during new sluicing operations. If re-examination of historical tank failure rates, conditions of individual tanks, and current sluicing schedules continues to support the 11,000 gal leakage volume and the 42% leakage frequency used by Foster Wheeler, then the average SST leakage would be 4,600 gal. This is similar to the value used in the draft TWRS-EIS.

# 3.12 CRITERION 12 - ALIGNED WASTE SOURCES

Establish whether the impacts of upgradient and downgradient groundwater contamination should be included in risk estimates.

#### 3.12.1 Importance of Criterion

Two or more tank farms and other types of waste sites often will be aligned with future groundwater flow directions. The maximally exposed onsite farmer will be subjected to risks from overlapping plumes produced by aligned sources. Appropriate limits for protecting the health of the farmer from the cumulative effects of overlapping plumes need to be defined.

#### 3.12.2 Criterion Recommendation

Cumulative risks from all aligned sources should be less than  $1.2 \times 10^4$  ILCR through the drinking water pathway (equivalent to 4 mrem/y) and less than 1.0 hazard index (including not exceeding the MCL for nitrate). These values are based on regulatory limits for protecting drinking water.

### 3.13 CRITERION 13 - RISK APPORTIONMENT

Determine the apportionment of allowable cumulative risk among the contributing sources when two or more plumes will overlap.

#### 3.13.1 Importance of Issue

Without careful planning and analysis, a potential exists for conducting cleanup actions that are not cost-effective. It may be cheaper, for example, to retrieve extra tank waste than to prevent leakage of equivalent risk, or vice versa. Also, two waste sources, one with and one without the Hanford Barrier, are unlikely to produce significantly overlapping plumes, even when they are aligned. In this event, the period of groundwater contamination in the no-barrier case would be completed well before the first contamination occurs in the barrier case.

# 3.13.2 Criterion Recommendation

If safe groundwater conditions can be assured, the mobile COCs in low-risk sites such as certain cribs and trenches should be allowed to be flushed naturally to the groundwater at the higher recharge rates that occur when no closure barrier is used. This approach avoids the costs of Hanford Barriers for some of the waste sources and creates more flexibility for accommodating the risks associated with aligned sources. The levels of risk reduction required for each of the remaining aligned sources should be based on the alternative that provides for the most cost-effective remediation and closure of all of the aligned sources as a system. Costs in the cost-effectiveness calculation should include all life-cycle costs. Effectiveness should be based primarily on cleanup effectiveness but should be tempered with consideration of worker safety and technical feasibility. Incremental cost-effectiveness analyses should be made to determine if later stages of cleanup action are worthwhile.

Thus, evaluating the aligned sources as a system is recommended to enable definition of the appropriate remedial actions and residual risks for each source. Several iterations may be necessary to identify the most cost-effective cleanup actions that are expected to yield cumulative risks that are in compliance with closure plan limits.

# 3.14 CRITERION 14 - LEAKAGE DETECTION TECHNOLOGY

Determine the impact of leakage detection and response technology on reducing the amount of new leakage that may occur during sluicing.

#### 3.14.1 Importance of Criterion

Currently available leakage detection technology consists of sensitive liquid level measuring devices, flow meters, and visual estimates of remaining solid waste in the tank at various intervals during the tank sluicing cycle. Foster Wheeler estimated the sensitivity of leakage detection by this method at between 6,000 and 20,000 gal after establishing the base sluicing conditions. The establishment of base conditions includes adding sufficient water to replace liquid removed by previous salt well pumping and immerse the intake of the new slurry pump. On average, an addition of about 140,000 gal of water may be required to establish these base conditions before initiating sluicing. Detection of leakage with currently available technology is not possible when base conditions are being established. A potentially promising leakage detection alternative, electric resistance tomography (ERT) may be capable of detecting a 1,000- to 8,000-gal leak during sluicing as well as during establishment of base conditions. However, the ERT technology is not proven at this time.

After detection of a leak by any method, leakage will continue until the drainable liquid level is pumped down to a level below the level of the leak. Salt well pumping may be required to augment the sluice liquid recovery pump when a leak is suspected on the bottom of a tank or low on the tank's wall. The time required to draw down the drainable liquid level in a tank may be days or weeks depending on the permeability of the waste. A one-day response time for draining a tank may result in 40 to 2,400 gal of additional leakage, based on the range of historic leakage rate data. A two-week response time may result in 600 to 34,000 gal of additional leakage. Thus, for the response times considered, the total leakage that may occur before and after detection may range from about 6,000 to 54,000 gal with currently available technology, and from about 1,000 to 47,000 gal with the unproven ERT technology. Leakage of these levels may have significant impacts on risk in certain tanks. Only a fraction of the tanks are expected to leak at upper elevations on the tank wall where the amount of leakage will be minimized.

# 3.14.2 Criterion Recommendation

The range and maximum levels of leakage that may occur before and after leakage detection are high. However, the probability of a large amount of leakage is low due to the expected benefits of core sluicing, the low incidence of large amounts of leakage in the past, and the use of leakage detection technology. The use of ERT technology, if and when it is proven, may reduce the magnitude of leakage by providing earlier detection when the tank is being filled to establish base sluicing conditions. The effectiveness of salt well pumping as a leakage response action should be better quantified.

# 3.15 CRITERION 15 - LEAKAGE MITIGATION TECHNOLOGY

Determine which leakage mitigation technologies are viable and how much impact will they have on reducing leakage.

# 3.15.1 Importance of Criterion

Various methods of mitigating leakage are available and have potential to limit the risks associated with leakage. These methods include using subsurface barriers, sluicing with liquids containing entrained sludge particles, sluicing the core area of the tank first, and using salt well pumping to reduce the heal of liquid in the leaking tank. Foster Wheeler evaluated subsurface barrier technologies as a means of containing leakage from tanks, and concluded that all of the technologies evaluated would pose significant technical and worker safety risks and exhibit low cost-effectiveness in general-use applications. Foster Wheeler also proposed limiting the sludge settling time in the sluicing receiver tank in order to entrain the slowest settling sludge particles in the sluicing stream as a means of plugging small leaks with particles. Sluicing the core area of the tank first in order to retain a layer of waste as a seal over leaks that may exist in the wall of the tank was proposed in the draft *Single-Shell Tank Closure Work Plan* (WHC 1994). Salt-well pumping is a proven technology for minimizing the level of drainable liquid in a tank, and could be used following detection of leakage.

# 3.15.2 Criterion Recommendations

Cost-effective leakage mitigation technologies should be used to limit leakage to the minimum practicable achievable level. Subsurface barriers do not appear to be cost-effective in general-use applications, but may prove to be useful for limiting leakage from tanks that have experienced high leakage rates. Sluicing the core of the tank waste first is recommended as part of the tank waste retrieval baseline. Using entrained fine sludge particles in the sluicing stream may be effective, especially during the later stages of sluicing when most of the easily suspended finer particles have been removed from the tank, leaving coarser, highly permeable sludge to be removed. Salt-well pumping should be used where feasible following detection of leakage.

### 3.16 CRITERION 16 - INDIVIDUAL TANK CHARACTERISTICS

Consider the design and physical characteristics of individual tanks when defining allowable leakage.

#### 3.16.1 Importance of Criterion

Hanford Site tanks vary significantly in design, physical integrity, and characteristics of the waste they contain. The capacities of the tanks range from 50,000 to 1,000,000 gal. Some tanks are highly congested with failed pumps, sluicers, air-lift circulators, and instrumentation; the head space in other tanks is highly restricted. Some tanks have several available pump and sluicer pits, whereas some have none. Some tank farms are cluttered with essential service and monitoring equipment. The tanks contain varying quantities of waste exhibiting different retrieval difficulties. Some tanks have leaked in the past, and some contain potentially flammable and explosive materials. All of these factors may restrict the ability to use specific waste retrieval, leakage detection, and leakage mitigation technologies in individual tanks or tank farms. These factors may also impact the rate of sluicing and head of sluicing liquid in the tanks. Thus, design and operating latitudes and constraints are likely to be imposed for individual tanks to ensure safe and efficient retrieval operations. These latitudes and constraints may directly impact the allowable leakage from those tanks.

#### 3.16.2 Criterion Recommendation

Allowable leakage for individual tanks should be based in part on estimates of the probabilities and amounts of leakage derived from evaluation of (1) the specific characteristics of the tanks and (2) the retrieval, leakage detection, and leakage mitigation technologies likely to be best suited to individual tank characteristics. This will provide a basis for a balanced, cost-effective approach to the design and operation of waste retrieval and LDMM equipment.

# 3.17 CRITERION 17 - EXCEEDANCE OF ALLOWABLE LEAKAGE VALUES

Determine the consequences of exceeding an allowable leakage value.

# 3.17.1 Importance of Criterion

Exceeding an allowable leakage value can be accommodated by reducing the allowable leakage values of other aligned waste sources. It can also be accommodated by increasing the tank's cleanout objective from 99% to 99.5%, for example, or allocating higher cleanup objectives among several aligned tanks.

#### 3.17.2 Criterion Recommendation

Authority should be granted to exceed an allowable leakage value up to a predetermined ceiling. Retrieval operations should be allowed to continue to the ceiling level. An exceedance of the allowable leakage value up to the ceiling level should be accommodated by modifying the cleanup objectives of other aligned sources. Similarly, achieving a degree of leakage below the allowable leakage value can increase flexibility, e.g., by enabling higher allowable leakage values in other aligned tanks. Immediate cessation of sluicing operations should be required when a leakage ceiling is exceeded. Re-evaluation of waste retrieval plans should then occur. Revised plans may dictate the use of dry retrieval methods to prevent any additional leakage, or razing the tanks and exhuming contaminated debris and soils.

#### 3.18 CRITERION 18 - EXCEEDANCE OF LEAKAGE CEILINGS

Establish whether sluicing should be allowed when there is a likelihood of exceeding a leakage ceiling.

#### 3.18.1 Importance of Criterion

Previous analyses conducted by Boomer et al. (1994) and Foster Wheeler indicated that alternate tank waste retrieval options, including dry and semi-dry retrieval options pose high costs and worker risks. Very high costs and worker risks were attributed to tank razing and debris/soil excavation and treatment.

# 3.18.2 Criterion Recommendation

Plans should be made to maximize use of sluicing with the ultimate objective of achieving compliance with the requirements of the closure plan. Dry or semi-dry retrieval should be planned as the first contingency if leakage ceilings are exceeded. Razing the tanks and excavating the contaminated debris and soil should be considered the last resort.

# 3.19 CRITERION 19 - ABSOLUTE LIMIT ON ALLOWABLE LEAKAGE

Establish whether an absolute limit should be imposed on the amount of leakage allowable to ensure protection of the groundwater.

### 3.19.1 Importance of Criterion

A very high level of leakage could conceivably penetrate to and contaminate the groundwater. The highly drained nature of Hanford Site soils creates a sponge-like effect that would significantly retard the flow of leaked liquid waste to the water table. Preliminary calculations performed by Foster Wheeler indicate that at least 200,000 gal of leakage below individual tanks would be bound in the soil well above the water table. The water would travel vertically toward the water table at sufficiently low rates to allow excavation of the contaminated soil, if necessary. Another evaluation performed by Foster Wheeler indicate that up to 480,000 gal of liquid could leak from a Tank 241-A-101, including the water added to the tank to create base conditions before initiating sluicing. A maximum of 140,000 gal could leak in the typical case based on average drainable liquid data and volumes of water required to submerge the head of the slurry removal pump. Thus, maximum levels of leakage from individual tanks would not pose environmental threats in most cases if excavation and treatment of the soil, or a similarly effective technology is planned as a mitigating action.

#### 3.19.2 Criterion Recommendation

Individual tank conditions and soil conditions at the tank farm should be used to model the spread of the maximum potential leakage to verify that the leakage can be dealt with within the limits of feasibility of available mitigation technologies. The probability of maximum leakage should also be considered before imposing an absolute limit on allowable leakage.

#### 4.0 EXAMPLE PROCESS FOR DERIVING ALLOWABLE LEAKAGE VALUES

Criteria established in Section 3 were used, with a few noted exceptions, to derive allowable leakage values for a hypothetical tank farm containing six tanks. The process used to develop preliminary allowable leakage values is described in the order of the criteria previously presented. The process used to adjust allowable leakage values during a sequenced hypothetical cleanup of the six tanks is also described.

#### 4.1 PRELIMINARY ALLOWABLE LEAKAGE VALUES

The preliminary allowable leakage values are calculated for this hypothetical case to support retrieval planning decisions and establish the operational leakage limit for the first tank retrieved. The final criteria used to establish the preliminary allowable leakage values are shown below.

- **Criterion 1** The maximally exposed onsite residential farmer scenario was used as the controlling risk basis.
- Criterion 2 The Multimedia Environmental Pollutant Assessment System was used to model the risk scenario. Typical Hanford Site environmental modeling conditions and input data were used. The model conditions and input data are similar to those used in the draft TWRS-EIS.
- Criterion 3 The point of compliance was assumed to be immediately downgradient of the tank farm.
- Criterion 4 Compliance risks were modeled over a 30,000-year period.
- Criterion 5 The primary COCs evaluated were <sup>99</sup>Tc, <sup>129</sup>I, <sup>14</sup>C, uranium, and nitrate.
- Criterion 6 The flux from the tank farm was assumed to be released into a vadose zone cell with surface dimensions equal to that of the tank farm.
- Criterion 7 The allowable incremental lifetime cancer risk was assumed to be 10<sup>4</sup> in one case and 10<sup>5</sup> in a second case.
- Criterion 8 The risk impacts of past leakage and waste contaminated concrete were considered in addition to the risk impacts associated with residual waste in the tank and new leakage.
- Criterion 9 The concentrations of COCs were based on the assumptions made in *Functions and Requirements for Hanford Single Shell Tank Leakage Detection and Monitoring* (Cruse et al. 1995). These assumptions are somewhat conservative compared to the recommended approach.

- Criterion 10 The selected closure approach was backfilling the tanks with gravel following nominal retrieval of 99% of the waste and capping with a Hanford Barrier.
- Criterion 11 The volume of assumed leakage in the tank farm in the past was 285,000 gal based on historical data.
- Criterion 12 No other tank farms or waste sites that contribute COCs were assumed aligned with the hypothetical tank farm. Carcinogenic risk limits assumed for the single tank farm were 10<sup>4</sup> and 10<sup>5</sup> as in Criterion 7.
- Criterion 13 There was no need to divide risk limits between other aligned farms and contributing waste sites.
- Criteria 14 and 15 Currently available leakage detection and mitigation technology were assumed to be able to limit total new leakage in the tank farm to a maximum of 60,000 gal.
- Criterion 16 The design and physical characteristics of the tanks in the farm were assumed not to restrict the use of sluicing and the application of currently available leakage detection and mitigation technologies.
- Criterion 17 Modeling showed that the planned actions for the tank farm could not satisfy the 10<sup>-5</sup> risk limit. More efficient sluicing would be required to accommodate a reasonable level of leakage and comply with the 10<sup>-5</sup> risk limit. However, the planned actions would satisfy the 10<sup>4</sup> risk limit.
- Criterion 18 Dry and semi-dry retrieval methods were planned as possible contingencies.
- Criterion 19 The tank and soil conditions indicated that the maximum potential leakage would penetrate to a depth that could be accessed using current excavation technology. Thus, no absolute limit on leakage was established.

Based on application of the criteria, the preliminary allowable leakage values shown in Table 4-1 were determined. As can be seen, the soil capacity (Tier 1) exceeds the maximum potential leak (Tier 2) in all cases. Additionally, the preliminary allowable leakage values (Tier 3) are all large enough to be above the leakage detection limit of 6,000 to 20,000 gal. On the basis of this planning exercise, it was assumed that remediation of the tank farm using sluicing was authorized and to be conducted under the  $10^4$  risk limit.

Tank	Tier 1 (gal)	Tier 2 (gal)	Tier 3 (gal)
1	200,000	180,000	46,000
2	200,000	77,000	38,000
3	200,000	90,000	66,000
4	200,000	68,000	38,000
5	200,000	67,000	100,000
6	200,000	74,000	80,000

Table 4-1.	Hypothetical	Preliminary	Allowable	Leakage	Criteria.
------------	--------------	-------------	-----------	---------	-----------

### 4.2 ADJUSTED ALLOWABLE LEAKAGE VALUES

The following is a hypothetical example of how the preliminary allowable leakage values would be applied and updated as retrieval of each of the tanks in the tank farm was concluded.

When the first tank was sluiced, the operations personnel were granted an operational leakage limit of 46,000 gal (the Tier 3 allowable leakage value). During retrieval of this tank no leakage was detected and the 99% retrieval objective for the tank was met. A small level of leakage (3,000 gal) was attributed to the tank, however, as a function of the probability for and volume of the average nondetectable leakage. The difference between the allowed volume of leakage and the assumed nondetectable leakage was converted to a risk credit. This risk credit was evenly apportioned to the remaining tanks in terms of additional allowable leakage volume. An updated operational leakage limit was established for the second tank was successfully sluiced. The same risk credit was again distributed to the remaining tanks in terms of increased allowable leakage volumes.

The third tank was also sluiced without detectable leakage, but only 98% of the waste was retrieved rather than the goal of 99%. Because no leakage was observed, the tank farm was debited for the risk associated with the assumed 3,000 gal nondetectable leak. The risk associated with the shortfall in waste retrieval was then subtracted from the remaining risk allowance for leakage from the three tanks that had not yet been sluiced. The difference was evenly divided between the three tanks. This resulted in reducing the original allowable leakage values assigned to the tanks to a small fraction of their original levels.

The fourth and fifth tanks were sluiced, and although retrieval goals were met, the tanks leaked above their reduced allowable leakage values, consuming the leakage risk allocation associated with leakage from the sixth tank. The sixth tank had been scheduled as the last tank in the farm to be retrieved because the integrity of the tank was suspect. Had sufficient leakage and/or residual waste risk credit been built up during cleanout of the first five tanks, the sixth tank would have been sluiced. Thus the sixth tank was cleaned out instead using a dry retrieval method. The tank farm was then closed by backfilling each tank

with gravel and capping the farm with a Hanford Barrier to achieve a predicted cumulative ICLR of 9 x  $19^{-5}$ .

# 5.0 SUMMARY OF CRITERIA RECOMMENDATIONS REQUIRING APPROVAL

A summary of the allowable leakage criteria recommendations requiring approval is provided in Table 5-1.

Number	Allowable Leakage Criteria	Recommendations
1	Controlling Risk Scenario	<ul> <li>Maximally Exposed Individual</li> <li>Groundwater use pathway</li> <li>Onsite farmer</li> <li>Consistent with TWRS-EIS</li> </ul>
2	Risk Models and Data	<ul> <li>One-dimensional release algorithms and transport models</li> <li>Consistent with TWRS-EIS</li> </ul>
3	Point of Compliance	<ul><li>Several compliance points for sensitivity</li><li>Based on future land use planning</li></ul>
4	Duration of Compliance	• Establish effectiveness of Hanford Surface Barrier
5	Constituents of Concern	• <sup>99</sup> Tc, <sup>129</sup> I, <sup>14</sup> C, uranium, and nitrate
6	Vadose Zone Flux Distribution	Consistent with points of compliance
7	Allowable Risk	<ul> <li>10<sup>-4</sup> or 10<sup>-5</sup> incremental lifetime cancer risk</li> <li>Hazard index of 1.0</li> </ul>
8	Tank Sources of Risk	Cumulative risk impacts of all tank sources should be considered
9	Leakage Concentrations	• Use average relative concentrations of COCs in sluicing liquid and in sludge
10	Acceptable Closure Options	<ul> <li>Assume the tanks are filled with gravel or grout and covered with a Hanford Barrier following waste retrieval as the preferred option</li> <li>Plan for tank razing and soil excavation or in situ soil washing as contingency</li> </ul>
11	Leakage Volumes	<ul> <li>Initially assume the historical average of 11,000 gal</li> <li>Perform a more rigorous analysis</li> </ul>
12	Aligned Waste Sources	<ul> <li>Exclude unimportant sources that will not be capped</li> <li>All other aligned waste sources should be considered in calculation of cumulative risk</li> </ul>

Table 5-1. Summary of Criteria Recommendation
---

Number	Allowable Leakage Criteria	Recommendations			
13	Risk Apportionment	<ul> <li>Don't cover low-risk sites (such as some cribs and trenches) where safe groundwater conditions can be ensured</li> <li>Evaluate risk reduction levels based on cost-effectiveness of feasible options for entire system</li> </ul>			
14	Leakage Detection Technology	<ul> <li>The current baseline detection technology is adequate to support retrieval</li> <li>The use of ERT technology, if proven, should provide earlier leak detection</li> </ul>			
15	Leakage Mitigation Technology	<ul> <li>Sluice the core of the tank waste first</li> <li>Salt-well pumping should be used where practical following leak detection</li> <li>Use of entrained fine sludge particles may prove effective</li> <li>Subsurface barriers generally are not cost-effective</li> </ul>			
16	Individual Tank Characteristics	<ul> <li>Base allowable leakage in part on tank design, physical integrity, and waste characteristics</li> </ul>			
17	Exceedance of Allowable Leakage Values	• Authority should be granted to exceed an allowable leakage value up to a predetermined cap			
18	Exceedance of Leakage Ceilings	<ul> <li>Maximize use of sluicing</li> <li>Plan as a first contingency, use of dry or semi-dry retrieval</li> <li>Tank razing and soil excavation should be a last resort</li> </ul>			
19	Absolute Limit on Allowable Leakage	• Use tank-specific models to verify that the maximum potential leakage (Tier 2) can be dealt with within the limits of available mitigation technology			

#### WHC-SD-WM-ES-392 REV. 0

#### 6.0 REFERENCES

- Boomer, K.D., S.K. Baker, A.L. Boldt, J.D. Galbraith, J.S. Garfield, C.E. Golberg, B.A. Higley, L.J. Johnson, M.J. Kupfer, R.M. Marusich, R.J. Parazin, A.N. Praga, G.W. Reddick, J.A. Reddick, E.J. Slaathaug, L.M. Swanson, T.L. Waldo, and C.E. Worcester, 1994, *Tank Waste Technical Options*, WHC-EP-0616, Rev. 1, Westinghouse Hanford Company, Richland, Washington.
- Cruse, J.M., D.F. Iwatate, K.S. Tollefson, R.L. Treat, T.L. Trenkler, R.E. Lewis, 1995, Functions and Requirements for Hanford Single-Shell Tank Leakage Detection and Monitoring, WHC-SD-WM-FRD-021, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- Hanlon, B.M., 1995, Waste Status Summary Report for the Month Ending October 31, 1995, WHC-EP-0182-91, Westinghouse Hanford Company, Richland, Washington.
- WHC, 1994, Single-Shell Tank Closure Work Plan, DOE/RL-89-16, Rev. A, Westinghouse Hanford Company, Richland, Washington.

# WHC-SD-WM-ES-392 REV. 0

This page intentionally left blank.

DISTRIBUTION SHEET								
То	From			Page 1 of 1				
DISTRIBUTION	R. P. Marshall Jr.			Date 7/2/96				
Project Title/Work Order				EDT No. 606481				
Leak Detection, Monitoring, and Determining Allowable Leakage (	Mitigation (LD WHC-SD-WM-ES-3	ation (LDMM) Criteria for D-WM-ES-392, Rev 0)			ECN No. N/A			
Name	MSIN	Text With All Attach.	Text Onl	y Attach./ Appendix Only	EDT/ECN Only			
J. K. Bajwa	A2-25	Х						
L. R. Burk	B4-55	х						
J. C. Conner	A2-25	X						
J. D. Davis	H5-61	х						
E. A. Fredenburg	H5-61	х						
J. S. Hertzel	H5-61	х						
J. J. Huston	S2-48	х						
D. F. Iwatate	H5-09	х						
E. J. Kosiancic	H5-61	Х						
R. P. Marshall Jr.	H5-61	х						
G. A. Meyer	S2-48	х						
R. J. Swan	H6-21	X						
Central Files	A3-88	X						