

**This document was too large to scan
as a single document. It has
been divided into smaller sections.**

Section 2 of 3

Document Information			
Document #	SNF-6315	Revision	0
Title	CSB MCH CGI DEDICATIONS		
Date	05/17/2000		
Originator	CE SWENSON	Originator Co.	FH
Recipient		Recipient Co.	
References	EDT-629027, USQ-LIKE-CSB-0-0030		
Keywords			
Projects	W-379, SNF		
Other Information			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 2 of 8

ECN No. **N/A** CGI No. **CGI-SNF-D-MHM-047**
Title **Various P06, 07, 21, and 26 Interlocks-Siemens Contactor #3TF4422-0AK6**

Section 2d Reason for Dedication

The above Commercial Grade (CG) described Item is being Dedicated for use in the application cited for the following reason(s):

<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input checked="" type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:
1. Isolates line power from the Turret Rotate Drive motor when permissives are not met.

1. Part/Component Functional Mode:	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function
Safety Function #1: <input checked="" type="checkbox"/> Active [] Passive	Passive - Change of state is not required for the component to perform its safety function
Safety Function #2: [] Active [] Passive	
Safety Function #3: [] Active [] Passive	

C. Host Component Safety Function (if applicable):
1. N/A

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

- Contact resistance out of spec results in overheating and welding of contacts**
- Hot short across contacts results in failure to open the circuit**
- Binding of contacts results in failure to open/close circuit**

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required: Yes [] No <input checked="" type="checkbox"/>	If yes: Environmental Qualification Requirements Limiting Environmental Conditions: Required Safety Functions: Qualification Period:
Natural Phenomena Hazard (NPH) Design Required: Yes [] No <input checked="" type="checkbox"/>	If yes: NPH Design Requirements Performance Category: NPH Design Req'ts.: Required Safety Functions:

Section 5 Component Functional Classification

<input checked="" type="checkbox"/> Safety Class (SC)	<input type="checkbox"/> General Service (GS)	<input type="checkbox"/> Safety Significant (SS)
---	---	--

If part/component classification is different from host component/system, document basis. **N/A**

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: **N/A**
 Safety Analysis Report (SAR): **HNF-3672, Rev. 0**
 Drawings: **Ederer, Inc. EB-33056, Sheets 25, 27**
 Vendor Manual/Manufacturer/Supplier Information: **Siemens Industrial Control Products, World Series Contactors, 3TF4 3-Pole with AC coil**
 Other: **ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 3 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-047
Title Various P06, 07, 21, and 26 Interlocks-Siemens Contactor #3TF4422-0AK6

Section 9 Critical Characteristics

Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Siemens	1, IN	X	
Model Number	3TF44	1, IN	X	
Coil	K6	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Contact configuration	3 pole NO main contacts, 2 NO and 2 NC Aux Contacts	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Current carrying capability	0.5V max. voltage drop across closed contacts at 25 amps resistive on main contacts and at 10 amps, resistive on auxiliary contacts	1, T		X
Insulation resistance	10 Megohm min across open contact terminals and terminals to ground (500 VDC meggar)	1, T		X
Operation	Contacts open/close at maximum pick-up (96 VAC) and minimum drop-out (36 VAC) voltages	1, T		X
4. Notes and Legend: Notes and Legend: Siemens Number 3TF4422-0AK6 is a catalogue ordering number. 3TF44 is the model number of the contactor, the next two numbers are the style and number of auxiliary contacts, and the last two digits is the type of coil (e.g. K6 is a 120VAC, 60 hz coil). Typically the aux contacts do not have a designator on them so visual verification is used.			Acceptance Method (Acc Meth): 1. Special Test and Inspection: 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 1. Vendor/Item History	

Section 10 Initial Review and Approval

Approvals:
 Designated Engineer: ERK [Signature] 4/6/00
 Design Authority: Wang [Signature] 4-6-00
 Quality Assurance: Steph [Signature] 4-6-2000

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 4 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-047
Title Various P06, 07, 21, and 26 Interlocks-Siemens Contactor #3TF4422-0AK6

WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Failure to open the circuit by contact welding or hot short across the contact base.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Results in failure of contacts to open
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

Page 310

SNF-6315, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-047
 Title Various P06, 07, 21, and 26 Interlocks-Siemens Contactor #3TF4422-0AK6

Page 5 of 8

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1

Item Description: **Siemens Contactor**
 System #: **Turret Rotate**

Equip #: **TRLC**
 Model #: **3TF4422-0AK6**

Manufacturer (Address/Phone):
Siemens Industrial Control Products
1-800-964-4114

Supplier (Address/Phone):
Ederer, Inc.

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	PIT	
X			1. Manufacturer
X			2. Contactor Model Number
X			3. Coil Model Number
X			4. Contact Configuration
	X		5. Contact Rating
	X		6. Insulation Resistance
	X		7. Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic: **Manufacturer** Sample Size*: **100%**

Acceptance Criteria: **Siemens**

Receipt Inspection Plan / Report #: CGI-SNF-D-MHM-047-TP-047

Characteristic: **Contactor Model Number** Sample Size*: **100%**

Acceptance Criteria: **3TF44**

Receipt Inspection Plan / Report #: TP-047*

Characteristic: **Coil Model Number** Sample Size*: **100%**

Acceptance Criteria: **K6**

Receipt Inspection Plan / Report #: TP-047*

Characteristic: **Contact Configuration** Sample Size*: **100%**

Acceptance Criteria: **3 Pole NO Main Contacts and 2 NO and 2 NC auxiliary contacts**

Receipt Inspection Plan / Report #: TP-047*

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 6 of 8

ECN No. NA CGI No. CGI-SNF-D-MHM-047
 Title Various P06, 07, 21, and 26 Interlocks-Siemens Contactor #3TF4422-0AK6

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)	
Characteristic for Test: Current carrying capability Acceptance Criteria: 0.5V max. voltage drop across closed contacts at 25 amps resistive on main contacts and at 10 amps, resistive on auxiliary contacts Actual Test Value: <i>See Procedure</i>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <i>TP-047*</i>
Characteristic for Test: Insulation Resistance Acceptance Criteria: 10 Megohms min across open contact terminals and terminals to ground, with 500 vdc megger. Actual Test Value: <i>See Procedure</i>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <i>TP-047*</i>
Characteristic for Test: Operation Acceptance Criteria: Contacts change state at max. pickup voltage of 96VAC and at min. drop-out voltage of 36VAC Actual Test Value: <i>See Procedure</i>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <i>TP-047*</i>

* Full no. is: CGI-SNF-D-MHM-047-TP-047

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A

CGI No. CGI-SNF-D-MHM-047

Page 7 of 8

Title: Various P06, 07, 21, and 26 Interlocks-Siemens Contactor #3TF4422-0AK6

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Contactor

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Siemens	X		1, IN	TP-047*	N/A	1	0	KWEST	LARRY PERIS	4/11/00
Contactor Model Number	3TF44	X		1, IN							
Coil Model Number	K6	X		1, IN							
Contact Configuration	3 Pole NO Main Contacts and 2 NO and 2 NC auxiliary contacts	X		1, IN							
Current Carrying Capability	0.5V max voltage drop across closed terminals, 25 amps on main contacts and at 10 amps on aux. contacts, resistive		X	1, T							
Insulation Resistance	10 Megohms min across open contact terminals and terminals to ground (500VDC megger)		X	1, T							
Operation	Contacts change state at max pick-up voltage of 96VAC and at min drop-out voltage of 36VAC		X	1, T							

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-047 cited above. CES 4/11/00
 Testing Agency Approval: NR CES 4/11/00 Date _____
 Testing Agency QA Engineer: NR CES 4/11/00 Date _____

BUYER VERIFICATION
 CES
 Design Authority: Wraig Anderson Date 4-11-00
 QA Engineer: Stephen Scott Moss Date 4-24-2000

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/ACGI No. CGI-SNF-D-MHM-047

Page 8 of 8

Title: Various P06, 07, 21, and 26 Interlocks-Siemens Contactor #3TF4422-0AK6

SECTION 6 CONTACTS / PHONE NUMBERS	
Name	Phone
Design Authority <u>CRAIG SWENSON</u>	() <u>376-0288</u>
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()
SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST	
Initial Procurement Documents	For Critical Characteristics
Drawings:	
<input checked="" type="checkbox"/> Manuals (specify type & number): <u>Siemens Industrial Control Products, Contactor, 3TF4 3-Pole</u>	<u>All</u>
Design Calculations	
Installation Instructions	
Operation Instructions	
Calibration Instructions	
Manufacturer's Recommended Spare Parts List	
Other:	
Procurement Documents:	For Critical Characteristics
Certificate of Conformance/Compliance	
Seismic Qualification Certificate	
Environmental Qualification Certificate	
Test Report (s):	
Inspection Report (s):	
CMTRs for ASME Pressure Retaining Materials	
Valve Seat Leakage Report	
Weld Records	
Material Traceability Record	
Other:	

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-047-TP-047


Test Specimen: Siemens 3TF4422, Eqmt. No.: TRLC

ORIGINAL

Rev. No. 0

Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
						 3/24/00 NO CHANGE

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST
 Test Plan No.: CGI-SNF-D-MHM-047-TP-047
 Test Specimen: Siemens 3TF4422, Eqmt. No.: TRLC

Rev. No. 0

Page 2 of 7

ORIGINAL

In-Situ Test Procedure

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *JWP Larry W. Price* Date: 3/16/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MRC
Electrician	JW EBERHART	PCE	<i>JW Eberhart</i>	JWE
Electrician Quality Control	Stephen R. Couley	RE	<i>Stephen R. Couley</i>	SRC
Design Authority Representative	LARRY W. PRICE	KWEST	<i>JWP</i>	JWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current Source capable of 10 amps and 25 amps
 Megger Instrument capable of 500 VDC Test Voltage
 Adjustable Voltage Power supply capable of 0 to 120 VAC minimum
 MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
 Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo 3480/2 I.D.: 6410-889 Calib. Due date: 02-09-01
 Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00
 Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00
 Test Instrument type: PROTO 6106 I.D.: 020E/009 Calib. Due date: 01-13-01
 Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-047-TP-047

Test Specimen: Siemens 3TF4422, Eqmt. No.: TRLC

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TRLC	TRLC	Acc.
Manufacturer:	SIEMENS	Siemens	Acc.
Model:	3TF44	3TF44	Acc.
Contact Configuration:	YES	3 pole Main Contacts and 2 NO & 2 NC auxiliary contacts	Acc.
Serial No./Lot No./Date Code:	OK	N/A	Acc.
Coil:	K6	K6	Acc.

2.0 Perform the following testing steps:

03-16-00

2:00 p.m.

2.1 Record:

Date /Time of Test Beginning:

~~03-17-00~~

MRC

2.2 Operation

JWZES

2.2.1 Regulate voltage to the coil of the contactor and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	98.853 VAC	102 VAC maximum	Acc.
Drop-out Voltage	45.173 VAC	36 VAC minimum	Acc.

2.2.2 De-energize and remove test equipment.**2.3 Insulation Resistance Test****2.3.1 Setup the test equipment and contactor specimen for insulation resistance testing.**

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-047-TP-047

Test Specimen: Siemens 3TF4422, Eqmt. No.: TRLC

Page 4 of 7

2.3.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Record data below.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
L1	T1	>100Gohm	> 10 Megohms	Acc
L2	T2	>100Gohm	> 10 Megohms	Acc
L3	T3	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
43	44	>100Gohm	> 10 Megohms	Acc
L1	Ground	>100Gohm	> 10 Megohms	Acc
L2	Ground	>100Gohm	> 10 Megohms	Acc
L3	Ground	>100Gohm	> 10 Megohms	Acc
T1	Ground	>100Gohm	> 10 Megohms	Acc
T2	Ground	>100Gohm	> 10 Megohms	Acc
T3	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc
43	Ground	>100Gohm	> 10 Megohms	Acc
44	Ground	>100Gohm	> 10 Megohms	Acc
21 or 22	Ground	>100Gohm	> 10 Megohms	Acc
31 or 32	Ground	>100Gohm	> 10 Megohms	Acc
A1 or A2 (coil)	Ground	>100Gohm	> 10 Megohms	Acc

2.4 Contact Rating Test

2.4.1 Setup the test equipment and contactor specimen for contact rating testing.

2.4.2 Manually adjust the contactor or apply 120 VAC to the coil to close the normally open contacts

2.4.3 Apply a nominal 25 amps VAC, resistive, across closed main contacts of the test specimen

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO auxiliary contacts of the test specimen.

Caution: Do not change state of contacts while energized.

2.4.5 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Main Contacts L1 Closed	.0355 vac	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L2 Closed	.0351 vac	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L3 Closed	.0401 vac	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 13-14 (closed)	.0998 vac	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 43-44 (closed)	.1042 vac	< 0.5 ± 10% Volts AC drop	Acc

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-047-TP-047

Test Specimen: Siemens 3TF4422, Eqmt. No.: TRLC

Page 5 of 7

2.4.6 De-energize and remove test equipment.

2.4.7 Apply a nominal 10 amps VAC, resistive, across the normally closed auxiliary contacts of the test specimen.

2.4.8 Record the following data.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Auxiliary NC 21-22 Contacts	.1270 VAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NC 31-32 Contacts	.1284 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.9 De-energize and remove the test equipment.

2.5 Terminate the test.

2.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.5.2 Retorque the terminals to 12 in-pounds.

2.5.3 Record: Date /Time of Test End: 03-17-00 9:00 a.m.

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 25A

3.2 Y-Channel Main Power Panel Wiring Diagram: ED-33069 Sheet 1

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-047-TP-047

Test Specimen: Siemens 3TF4422, Eqmt. No.: TRLC

Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met

Michael Cram
03-17-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-17-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) JW Craig Swenson Date: 3/20/00

QA/QC (signature) Stephen Scott Mose Date: 3-22-2000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
FB-33056		25A28Y	TRLC	A-1	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00
		Black	RCSA-6	A-1	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00
		Grey		A-2	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00
		2) 102 Y		A-2	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00
		TRX 1	TRLC	L-1	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00
		TRX 2		L-2	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00
		TRX 3		L-3	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00
		TRM-1		T-1	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00
		TRM-2		T-2	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00
		TRM-3		T-3	QWE	3/16/00	SRC	3-16-00	QWE	3/17/00	SRC	3-17-00

Remarks:


SNF-6315, Rev. 0

Page 320

World Series Contactors

Selection

3TF4 3-Pole with AC Coil

 <p>3TF43 3TF48</p>	Ordering Information ▶ Select Contactor from table below. ▶ Complete Catalog Number from coil code table. Example: 3TF4010-0AK6	Additional References ● Overload Relays see pages 361-363. ▶ Accessories see pages 357-360. ▶ Replacement Parts see pages 912-913. ▶ Technical Data see pages 378-379. ▶ Electrical Life Curves see page 381. ▶ Dimensions see page 394. ▶ Wiring Diagrams see page 302.	Coil Voltage Codes		
			AC Voltage 60Hz 50Hz Code	24 24 C2 120 110 K6 208 208 M2 277 220 U1 240 220 P6 480 380-415 V0 600 500 S0	

Ampere Rating Enclosed		1 Phase HP Ratings		3 Phase HP Ratings				Auxiliary Contacts Type		Catalog No	Price \$
IEC AC-3	UL	115V	230V	200V	230V	460V	575V	NO	NC		
9	20	1/2	1 1/2	2	3	5	7 1/2	1	0	3TF4010-0A1T	105.
12	20	1	2	3	3	7 1/2	10	1	0	3TF4110-0A1T	135.
16	30	1	3	5	5	10	15	1	0	3TF4210-0A1T	150.
22	30	2	3	7 1/2	7 1/2	15	20	1	0	3TF4310-0A1T	159.
32	55	3	5	10	10	25	30	1	1	3TF4411-0A1T	180.
38	55	3	7 1/2	10	15	25	30	1	1	3TF4511-0A1T	206.
Auxiliary Contacts may be added to 3TF46-3TF56 for maximum 4 NO and 4 NC [Ⓞ]											
45	80	5	10	15	20	40	50	1	1	3TF4611-0A1T	276.
63	80	5	15	20	25	50	60	1	1	3TF4711-0A1T	348.
75	100	7 1/2	15	25	30	60	75	1	1	3TF4811-0A1T	420.
85	105	—	—	30	40	75	100	1	1	3TF4911-0A1T	520.

3TF Contactors—Auxiliary Contact

Replace 6th (NO Aux. Contact) and 7th (NC Aux. Contact) digit in Catalog Number per chart. Example: 3TF4411-0AK6.

Contactors	Auxiliary Contacts		
	NO 6th Digit	NC 7th Digit	Price Adder \$
3TF40-3TF43	1	0	STD
	0	1	No Adder
	1	1	12.
	2	2	24.
3TF44-3TF45	1	1	STD
	2	2	24.
3TF46-3TF49	1	1	STD
	2	2	24.
	4 [Ⓞ]	4 [Ⓞ]	48.

Ⓞ See Auxiliary Contact table for standard and optional Auxiliary Contact Configurations.

Ⓞ Field assembled kit.

IEC Control

3TF3, 3TF4, CRLOF3 and CRLOF4

Technical Data

NEMA Size			00				0		1	
Contactor	Type	Units of Measure	3TF30/40 CRLOF30/40	3TF31/41 CRLOF31/41	3TF32/42 CRLOF32/42	3TF33/43 CRLOF33/43	3TF34/44 CRLOF34/44	3TF35/45 CRLOF35/45		
Mechanical life	make/break operations	Mil	15				15		10	
Insulation rating		V	690							
Ambient temperature range		°C	-25 to +55 in operation, -55 to +80 when stored							
Coil ratings (cold coil $1.0 \times U_c$)		Hz	50		60		50		60	
AC operation	Inrush	VA	68	75			87	115		
	p.f.		0.82	0.76			0.82	0.75		
	Sealed	VA	10	9.4			13	13		
	p.f.		0.29	0.29			0.27	0.27		
DC operation	Inrush = Sealed	W	6.5				11.7			
Coil voltage range:	AC at DC 24V		0.85 to $1.1 \times U_c$ 0.8 to $1.2 \times U_c$				0.85 to $1.1 U_c$ 0.8 to $1.1 U_c$			
Operating times ^① (Valid for 20% undervoltage to 10% overvoltage cold or warm coil)			(Values are applicable up to and including 20% undervoltage, 10% overvoltage as well as with the coil in cold state and operating temperature)							
AC operation	closing delay	ms	8-35		10-35		13-57			
	opening delay	ms	4-18		5-20		5-10			
DC operation	closing delay	ms	20-170		35-180		54-182			
	opening delay	ms	10-25		10-25		13-17			
Operating times at $1.0 \times U_c$ ^②										
AC operation	closing delay	ms	10-15		10-25		13-32			
	opening delay	ms	4-18		5-20		5-10			
DC operation	closing delay	ms	30-70		40-80		58-107			
	opening delay	ms	12-20		10-25		13-17			
Resistance to shock (rectangular pulse)	AC	g/ms	7.7/5, 4.4/10			5.8/5, 3.4/10		6.2/5, 3.6/10		
Conductor sizes										
For contactors without overload relay	main	AWG	(2) 18-12		(2) 18-12		(2) 14-10		(2) 14-10	
main conductor, solid or stranded	aux.	AWG	(2) 18-12		(2) 18-12		(2) 18-12		(2) 18-12	
auxiliary conductor, solid or stranded									(1) 14-3 or (2) 16-6	
Switching frequency in make/break operations per hour										
Contactors without overload relay										
	to AC-1	ops./h	1500		1500		1200		1200	
	to AC-2	ops./h	1000		750		750		600	
	to AC-3	ops./h	1000		750		750		600	
	to AC-4	ops./h	250		250		250		200	
Contactor with overload relay (avg. value)		1/h	15		15		15		15	
Auxiliary contacts										
①. Δ and ratings ② for auxiliary contacts										
Auxiliary Contacts within 3TF30 and 3TF31 and 3TF40 through 3TF45	Rated voltage switching capacity continuous current 10 Amp (AC/DC)	AC 600V max NEMA A600		24V	120V	240V	480V	600V		
		Make	A	60	60	30	15	12		
		Break	A	6	6	3	1.5	1.2		
		DC 600V max. NEMA P600		24V	125V	250V	500V	600V		
		Make	A	1.1	1.1	0.55	0.20	0.20		
		Break	A	1.1	1.1	0.55	0.20	0.20		
Auxiliary contact blocks for 3TF30 to 3TF35, Cat. 3TX40		AC 600V max NEMA A600		24V	125V	200V	300V	600V		
		DC 600V max. NEMA Q600		24V	125V	200V	300V	600V		
		Make	A	0.55	0.55	0.27	0.10	0.10		
		Break	A	0.55	0.55	0.27	0.10	0.10		

Load/Life Curves shown with 3TF contactor technical data page XXX

① The opening time delay is increased when the contactor coil is protected against voltage peaks (diode 6 to 9 times; diode combination 2 to 6 times; varistor + 2 to 6 ms).

1031004-021

World Series Contactors
 SNF-6315, Rev. 0
 31F4 and CRL0F4

NEMA Size	3	2
Unit of Measure	31F48 CRL0F48	31F47 CRL0F47
Contactor Type	31F48 CRL0F48	31F47 CRL0F47
Mechanical life make/break operations	10	10
Insulation rating	V	V
Ambient temperature range	-25 to +55 in operation, -50 to +80 when stored	-25 to +55 in operation, -50 to +80 when stored
Coil ratings (cold coil, 1.0 x U ₁)	H7 50	H7 50
AC operation	Insush VA 183	Insush VA 185
p.f.	0.5	0.54
Sealed	VA 17	VA 15
p.f.	0.29	0.29
Insush	W 400	W 420
Sealed	W 2.1	W 2.7
Closing = Closed	W 15	W 15
Coil voltage range AC	0.85 to 1.1 x U ₁	0.85 to 1.1 x U ₁
Operating times (valid for 20% undervoltage to 10% overvoltage)	ms 15-40	ms 20-50
AC operation	ms 5-25	ms 5-30
Total break time = opening delay + arcing time	ms 10-15	ms 10-15
AC operation	ms 17-30	ms 22-35
Operating times at 10 x U ₁	ms 5-25	ms 5-30
AC operation	ms 17-30	ms 22-35
Resistance to shock (rectangular pulse)	g/ms 11 2/5	g/ms 6 6/10
Conductor sizes	max 1/0	max 1/0
For contactors without overload relay	AWG 2 x (18 to 12)	AWG 2 x (18 to 12)
main conductor, solid or stranded		
auxiliary conductor, solid or stranded		
Switching frequency in make/break operations per hour (1/h)	1/h 1000	1/h 1000
1/h	1/h 600	1/h 400
duty AC-2	1/h 1200	1/h 400
duty AC-3	1/h 400	1/h 1000
duty AC-4	1/h 1200	1/h 1000
Coil voltage range AC	1/h 900	1/h 900
Coil ratings (cold coil, 1.0 x U ₁)	1/h 250	1/h 250
AC operation	1/h 850	1/h 850
Sealed	1/h 350	1/h 350
p.f.	1/h 900	1/h 900
Insush		
Sealed		
Closing = Closed		

Rated voltage	AC 600V maximum NEMA A600	24V	120V	240V	480V	600V
switching capacity	AC 600V maximum NEMA A600	60	60	30	15	12
Continuous current	DC 600V maximum NEMA F600	24V	150V	250V	300V	600V
10A (AC/DC)	Break Make NEMA F600	1.1	1.1	0.55	0.20	0.20
31F40 thru 31F57	Break Make NEMA A600	1.1	1.1	0.55	0.20	0.20

⑨ and ⑩ ratings for auxiliary contacts


Auxiliary contacts

⑪ The opening delay can increase if the coils have voltage spike protection. Diodes may only be attached to contactors up to 31F44.


Bope 324
 Technical

Non-Reversing Starters — Type 3TF

Without Control Power Transformer




With Control Power Transformer



Standard Pilot Control

Wire "C" omitted on starters with coils rated 120V or less.



Note: Starters with Contactor Sizes 3TF40 through 3TF44 are provided with the overload relays which mount directly to the contactor. These overload relays are provided with a contactor coil A2 repeat terminal. Wire "D" is integral with the overload relay. Jumper wire "E" is provided on the overload relay.

3

302

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. **N/A** CGI No. **CGI-SNF-D-MHM-037**

Page 1 of 8

Title: **Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000**

Section 1 Part Information

Item No.: **N/A** Manufacturer: **N/A** Supplier: **N/A**

Mfg. Part/Model No.: **N/A** Supplier's P/N: **N/A**

Part Description: **N/A** **ORIGINAL**

End Use Description: **N/A**

Section 2a Component Information

Equipment No.: **BSPGE, BSPGW** Specification No.: **None** Manufacturer: **Ashcroft** Past P.O. No.: **N/A**

Manufacturer's Part/Model No.: **45-1009S-02L-2000** Equipment Supplier (if different from manufacturer): **None RICHLAND IND, YND LES 4/11/00** Equip. Supplier's Part No.: **N/A**

Component Description: **4-1/2" dial and 0-2000 psig range hydraulic pressure 316 SS gauge has a 1/4" process connection and is mounted near the seismic restraints.**

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)? YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate w/ project CGI interface Engineer or BTR) YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)

2. List of Candidate qualified suppliers or ISO 9000 suppliers **N/A**

3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): **N/A**

Section 2c CGI Determination

CGI Determination Questions:
#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)
#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)
#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)
[X] All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. **N/A**

CGI No. **CGI-SNF-D-MHM-037**

Page 2 of 8

Title: **Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000**

Section 2d Reason for Dedication

The above described item is being Dedicated for use in the application cited for the following reason(s):

<input checked="" type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. **Provided visual indication of seismic restraints status.**

B. Part/Component Functional Mode:

Safety Function #1: Active Passive

Safety Function #2: Active Passive

Safety Function #3: Active Passive

Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function

Passive - Change of state is not required for the component to perform its safety function

C. Host Component Safety Function (if applicable): **N/A**

1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

1. **Failure of pressure gauge, i.e. rupture results in rapid pressure reduction.**

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required:

Yes

No

If yes: Environmental Qualification Requirements

Limiting Environmental Conditions:

Required Safety Functions:

Qualification Period:

Natural Phenomena Hazard (NPH) Design Required:

Yes

No

If yes: NPH Design Requirements

Performance Category:

NPH Design Req'ts.:

Required Safety Functions:

Section 5 Component Functional Classification

Safety Class (SC)

General Service

Safety Significant (SS)

If part/component classification is different from host component/system, document basis. **N/A**

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: **N/A**

Safety Analysis Report (SAR): **HNF-3672 Rev. 0**

Drawings: **Hanford H-2-830016**

Vendor Manual/Manufacturer/Supplier Information: **Ashcroft Hydraulic Gauges Catalog Cut Sheet Reference Bulletin IG-1**

Other: **ALSTROM ESL/R (96) 065-Rev. D, 100% Design Submittal, June 1998.**

Commercial Grade Item Upgrade Dedication Form		Rev. No. 1
ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-MHM-037</u>	Page 3 of 8
Title: <u>Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000</u>		

Section 9 Critical Characteristics

Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Ashcroft	1, IN	X	
Model Number	45-1009S-02L-2000	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Dial Size	4-1/2" Nominal	1, IN	X	
Process Connection	1/4" Nominal	1, IN	X	
Indicator Range, Figure Interval, Minor Graduation	0-2000 psi, 200, 20	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Pressure Boundary Integrity	No leakage at test pressure of 1980 psig for minimum of 10 minutes. Note 1	1, T		X
Operating Range Accuracy	± 1% full scale at pressure range of 1300-1600 psig	1, T		X
4. Notes and Legend:		Acceptance Method (Acc Meth):		
<p>Note 1: Pressure Boundary Integrity test at 110% of design pressure of 1800 psig.</p> <p>Model Number Breakdown: 45-1009S-02L-2000, 45 = 4.5" Dial Size; 1009 = Gauge Type; S = 316 SS Tube & Socket Material; 02 = 1/4" Connection; L = Connection Location is Lower; 2000 = Standard Pressure Range is 0-2000 psi</p> <p>Rev. 1: Pages 3,5,7: Deleted Physical CC of Material-Bourdon tube, Tip, Socket: 316SS; Pages 3,6,7: Changes Performance CC of Pressure Boundary Integrity of (No Bubbles) to "for minimum of 10 minutes"</p>		<p>1. Special Test and Inspection:</p> <p>1, IN for Inspection</p> <p>1, T for Test</p> <p>2. Commercial Grade Survey</p> <p>3. Source Verification</p> <p>3. Vendor/Item History</p>		

Section 10 Initial Review and Approval

Approvals:

Designated Engineer: [Signature]

Design Authority: [Signature]

QA Engineer: [Signature] 2/100

TZ ANDERSON

Commercial Grade Item Upgrade Dedication Form		Rev. No. 1
ECN No. NA	CGI No. CGI-SNF-D-MHM-037	Page 4 of 8
Title: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000		

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.		
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.		
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.	X	Rupture of pressure gauge will cause rapid reduction of hydraulic pressure.
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2: Additional Failure Modes Applicable to the Component Under Evaluation			
1.			
2.			
3.			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A CGI No. CGI-SNF-D-MHM-037

Page 5 of 8

Title: **Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000**

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1

Item Description: Ashcroft Hydraulic Pressure Gauge System #: MHM	Equip #: BSPGE, BSPGW Model #: 45-1009S-02L-2000
Manufacturer (Address/Phone): Ashcroft 203-378-8281 Fax: 203-385-0499	Supplier (Address/Phone):

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	Item
X			1. Manufacturer
X			2. Model
X			3. Dial Size
X			4. Process Connection
X			5. Indicator Range, Figure Interval, Minor Graduation
	X		6. Pressure Boundary Integrity
	X		7. Operating Range Accuracy

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size. References (See Section 7)

Characteristic: Manufacturer Acceptance Criteria: Ashcroft Receipt Inspection Plan / Report #: <i>TP037*</i>	Sample Size*: 100%
Characteristic: Model Acceptance Criteria: 45-1009S-02L-2000 Receipt Inspection Plan / Report #: <i>TP037*</i>	Sample Size*: 100%
Characteristic: Dial Size Acceptance Criteria: 4-1/2" Nominal Receipt Inspection Plan / Report #: <i>TP037*</i>	Sample Size*: 100%
Characteristic: Process Connection Acceptance Criteria: 1/4" Nominal Receipt Inspection Plan / Report #: <i>TP037*</i>	Sample Size*: 100%
Characteristic: Indicator Range, Figure Interval, Minor Graduation Acceptance Criteria: 0-2000 psi, 200, 20 Receipt Inspection Plan / Report #: <i>TP037*</i>	Sample Size*: 100%

Commercial Grade Item Upgrade Dedication Form

Page 331

Rev. No. 1

ECN No. N/A

CGI No. CGI-SNF-D-MHM-037

Page 6 of 8

Title: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

SNF-6315, Rev. 0

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic for Test: **Pressure Boundary Integrity**

Sample Size: Normal Reduced Tightened

Acceptance Criteria: **No leakage at test pressure of 1980 psig for minimum of 10 minutes**

Actual Test Value:

*See TP037**

Test Plan and Report #:

*TP037**

Characteristic for Test: **Operating Range Accuracy**

Sample Size: Normal Reduced Tightened

Acceptance Criteria: **± 1% full scale at pressure range of 1300-1600 psig**

Actual Test Value:

*See TP037**

Test Plan and Report #:

*TP037**

* Full no. is: CGI-SNF-D-MHM-037-TP-037

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A

CGI No. CGI-SNF-D-MHM-037

Page 7 of 8

Title: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Hydraulic pressure gauge

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Ashcroft	X		1, IN	TP037	NA	2	0	KWEST	<i>LAURENCE PRICE</i>	4/10/00
Model	45-1009S-02L-2000	X		1, IN							
Dial Size	4-1/2" Nominal	X		1, IN							
Process Connection	Nominal 1/2"	X		1, IN							
Indicator Range, Figure Interval, Minor Graduation	0-2000 psi, 200, 20	X		1, T							
Pressure Boundary Integrity	No leakage at test pressure of 1980 psig for minimum of 10 minutes.		X	1, T							
Operating Range Accuracy	± 1% full scale at pressure range of 1300-1600 psig		X	1, T							

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

Testing Agency Approval: <u>NR CES 4/11/00</u> Date: <u>4/11/00</u> Testing Agency QA Engineer: <u>NR CES 4/11/00</u> Date: _____			BUYER VERIFICATION Design Authority: <u>CES Craig Johnson</u> Date: <u>4-13-00</u> QA Engineer: <u>Stephen Scott Mason</u> Date: <u>4-24-2000</u>		
--	--	--	---	--	--

SNF-6315, Rev. 0

Page 332

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. NA

CGI No. CGI-SNF-D-MHM-037

Page 8 of 8

Title: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

SNF-6315, Rev. 0

Section 6 Contacts/Phone Numbers

Name	Phone
Design Authority <u>CRAIG SWENSON</u>	<u>376-0288</u>
QA	
QC	
Cog - Engineer	
CGI Engineer	
Procurement Engineer	
Other	

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents		For Critical Characteristics
<input checked="" type="checkbox"/>	Drawings: SBC100X2 Rail Clamp Dwg. A3826-02.0, 12.0, 22.0, P3.0	Those pertaining to operating and limiting pressures
	Manuals (specify type & number):	
	Design Calculations	
	Installation Instructions	
	Operation Instructions	
	Calibration Instructions	
	Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/>	Other: Ashcroft Hydraulic Gauges Catalog Cut Sheet Reference Bulletin IG-1	All, except as noted above
Procurement Documents		For Critical Characteristics
	Certificate of Conformance/Compliance	
	Seismic Qualification Certificate	
	Environmental Qualification Certificate	
	Test Report (s):	
	Inspection Report (s):	
	CMTRs for ASME Pressure Retaining Materials	
	Valve Seat Leakage Report	
	Weld Records	
	Material Traceability Record	

Dedication Test Plan – PG-1

Test Plan No.: CGI-SNF-D-MHM-037-TP-037

Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

ORIGINAL

Rev. No. 0

Page 1 of 4

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature)

JWP Wang Swenson Date: 3/24/00

RECOMMENDED EQUIPMENT:

Helium supply

Pressure regulator – to hydrostatically test the specimen to 2000+ psig

Pressure regulator – helium supply to 2000+ psig

Peak Pressure indicator 0-2000+ psig

Test jig to mount Pressure Gauge vertically with port at bottom of switch

Personnel protection panel

Snoop or equivalent

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) serial numbers and calibration due

Test Instrument type: ~~BAROMETRIC~~ ^{ANALOG} I.D.: BAT-035 Calib. Due date 11-6-02

Test Instrument type: _____ I.D.: _____ Calib. Due date _____

Test Instrument type: _____ I.D.: _____ Calib. Due date _____

Test Instrument type: _____ I.D.: _____ Calib. Due date _____

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)Test Specimen Description: Pressure Gauge

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>ASHCROFT</u>	Ashcroft	<u>ACC.</u>
Model:	<u>45-1009S-02L-2K</u>	45-1009S-02L-2000	<u>ACC.</u>
Dial Size:	<u>4.5" ϕ</u>	4-1/2" Nominal	<u>ACC.</u>
Pressure Connection:	<u>1/4"</u>	1/4" Nominal	<u>ACC.</u>
Indicator Range, figure Interval, Minor Graduation	<u>YES</u>	0-2000, 200, 20	<u>ACC.</u>

ORIGINAL

Dedication Test Plan - PG-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-037-TP-037

Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

Page 2 of 4

Description	Record Data	Acceptance Criteria	Comments/Deviations
Serial No.:	# 1	N/A	MARKED #1

Perform the following tests:

Record: Date /Time of Test Beginning: 3-24-00, 2:41 PMRecord: Room Temperature: 68 °F. Room Barometric Pressure: .7528 mmHg.

Perform steps below:

1. Pressure Boundary Integrity Test

Setup the Pressure Gauge specimen for pressure testing with water on the wetted surfaces of the gauge. Attach a sketch of test circuit with all test instrumentation used.

Apply a water pressure to the test specimen, gradually building up the pressure to 110% of design pressure of 1800 psig = 1980 psig.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pressure Boundary Integrity Test:	1999.729 PSI	No leakage at test pressure of 1980 psig +1 %, - zero for minimum of 10 minutes	NO LEAK DOWN ACC.

2. Calibration and Operating Range Accuracy Test

With water on the wetted surfaces of the pressure gauge specimen, apply hydrostatic pressure to the specimen and perform calibration and operating range accuracy testing. Attach a sketch of test circuit with all test instrumentation used.

Calibrate the gauge on a five point calibration throughout the 0-1800 range and within the operating range (1300-1600 psig). Record the data below:

Pressure Point	As-Found Record Data	Acceptance Criteria	Comments/Deviations
5 Point Calibration			
0 PSIG	0 PSIG	± 1% full scale	ACC.
249.992 PSIG	250 PSIG	± 1% full scale	ACC.
599.551 PSIG	600 PSIG	± 1% full scale	ACC.
999.715 PSIG	1000 PSIG	± 1% full scale	ACC.
1349.732 PSIG	1350 PSIG	± 1% full scale	ACC.
1599.552 PSIG	1600 PSIG	± 1% Full Scale	ACC.
0 PSIG	0 PSIG	± 1% Full Scale	ACC.

Dedication Test Plan – PG-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-037-TP-037

Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

Page 3 of 4

Pressure Point	As-Found Record Data	Acceptance Criteria	Comments/Deviations
Operating Range Calibration			
1249.987 PSIG	1250 PSIG	± 1% full scale	ACC.
1349.782 PSIG	1350 PSIG	± 1% full scale	ACC.
1499.771 PSIG	1500 PSIG	± 1% full scale	ACC.
1599.552 PSIG	1600 PSIG	± 1% full scale	ACC.

1. De-pressurize equipment.
2. End test.
3. Carefully disassemble pressure connection to pressure gauge and drain the water from the gauge.
4. Clean, label w/calibration sticker, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 3-24-00, 3:15 PM

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

*Pressure gauge meets all requirements of this
Test Plan along with 74% accuracy.
S. Caduto 3/24/00*

Dedication Test Plan - PG-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-037-TP-037

Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

Page 4 of 4

Notes:

Lined area for notes.

Test Engineer/Technician (Printed Name) JEFF CROCK

Test Engineer/Technician (signature) J. Crock Date: 3/24/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 3/28/00

QA/QC (signature) Stephen Scott Moore Date: 3-28-2000

Belhaven

Applied Technologies

Customer FDH Contract # 2717-3

Certificate of Calibration

Tag BEL00-188 Model 45-1009S-02L- Manufacturer Ashcroft
2000

Instrument Pressure Gauge Serial No Marked "1"

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68F
Accuracy of Instrument 1%
Calibrated Range: 2000 PSIG

Calibration Report No. 00-188

Date Due: 3-24-2001

Test Equipment

Ametek Deadweight Tester, S/N: 16132 (BAT-035)

Calibrated by: *J. Coakley 3-24-00*

Certified by: *[Signature]*
Quality Assurance Manager

ORIGINAL

Tag No BEL00-188
Instrument Type Pressure Gauge
Manufacturer Ashcroft
Serial No Marked "1"
Model 45-1009S-02L-
Cal Due Date 3-24-2001
System
Special Instructions Procedure Used: NA17-20MP-41

		Cal Point	As Found	As Left	% Full Scale Accuracy
Units:	PSIG	249.992	250	250	0.0004
F.S. Accuracy	1%	599.551	600	600	0.0225
F.S. Accuracy		999.715	1000	1000	0.0143
Full Scale	2000	1349.732	1350	1350	0.0134
Permitted Variation	20.0000 PSIG	1599.552	1600	1600	0.0224
Cal Temp	68F				

Test Equipment Ametek Deadweight Tester, S/N: 16132 (BAT-035)

Calibration Performed By J. C. [Signature]

Date 3/24/00

ORIGINAL

Dedication Test Plan – PG-1

Test Plan No.: CGI-SNF-D-MHM-037-TP-037

Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

ORIGINAL

Rev. No. 0

Page 1 of 4

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature)

JWP *Wang Swenson*

Date: 3/24/00

RECOMMENDED EQUIPMENT:

Helium supply

Pressure regulator – to hydrostatically test the specimen to 2000+ psig

Pressure regulator – helium supply to 2000+ psig

Peak Pressure indicator 0-2000+ psig

Test jig to mount Pressure Gauge vertically with port at bottom of switch

Personnel protection panel

Snoop or equivalent

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) serial numbers and calibration due

Test Instrument type: Ashcroft Dial Weight I.D.: BAT-035 Calib. Due date 11/6/02

Test Instrument type: _____ I.D.: _____ Calib. Due date _____

Test Instrument type: _____ I.D.: _____ Calib. Due date _____

Test Instrument type: _____ I.D.: _____ Calib. Due date _____

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Pressure Gauge

Record the following Identification Information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>ASHCROFT</u>	Ashcroft	<u>ACC.</u>
Model:	<u>45-1009S-02L-2K</u>	45-1009S-02L-2000	<u>ACC.</u>
Dial Size:	<u>4.5 Ø</u>	4-1/2" Nominal	<u>ACC.</u>
Pressure Connection:	<u>1/4 NPT</u>	1/4" Nominal	<u>ACC.</u>
Indicator Range, figure Interval, Minor Graduation	<u>OK</u>	0-2000, 200, 20	<u>ACC.</u>

ORIGINAL

Dedication Test Plan – PG-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-037-TP-037	
Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000	Page 2 of 4

Description	Record Data	Acceptance Criteria	Comments/Deviations
Serial No.:	#2	N/A	MARKED # 2

Perform the following tests:

Record: Date /Time of Test Beginning: 9-24-00, 11:30 AM

Record: Room Temperature: 68 °F. Room Barometric Pressure: .7052 mmHg.

Perform steps below:

1. Pressure Boundary Integrity Test

Setup the Pressure Gauge specimen for pressure testing with water on the wetted surfaces of the gauge. Attach a sketch of test circuit with all test instrumentation used.

Apply a water pressure to the test specimen, gradually building up the pressure to 110% of design pressure of 1800 psig = 1980 psig.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pressure Boundary Integrity Test:	1999.724 PSIG	No leakage at test pressure of 1980 psig +1 %, - zero for minimum of 10 minutes	NO LEAK DOWN ACC.

2. Calibration and Operating Range Accuracy Test

With water on the wetted surfaces of the pressure gauge specimen, apply hydrostatic pressure to the specimen and perform calibration and operating range accuracy testing. Attach a sketch of test circuit with all test instrumentation used.

Calibrate the gauge on a five point calibration throughout the 0-1800 range and within the operating range (1300-1600 psig). Record the data below:

Pressure Point	As-Found Record Data	Acceptance Criteria	Comments/Deviations
5 Point Calibration			
0 PSIG	0	± 1% full scale	ACC.
249.992 PSIG	260 PSIG	± 1% full scale	ACC
599.551 PSIG	580.5 PSIG	± 1% full scale	ACC. * CLOSE TO TOL.
999.715 PSIG	1000 PSIG	± 1% full scale	ACC.
1349.732 PSIG	1350 PSIG	± 1% full scale	ACC.
1599.552 PSIG	1600 PSIG	± 1% Full Scale	ACC.
0 PSIG	0 PSIG	± 1% Full Scale	ACC.

OK JHP

Dedication Test Plan - PG-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-037-TP-037

Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

Page 3 of 4

Pressure Point	As-Found Record Data	Acceptance Criteria	Comments/Deviations
Operating Range Calibration			
1249.937 psig	1250 psig	± 1% full scale	ACC.
1349.732 psig	1350 psig	± 1% full scale	ACC.
1499.771 psig	1500 psig	± 1% full scale	ACC.
1599.552 psig	1600 psig	± 1% full scale	ACC.

1. De-pressurize equipment.
2. End test.
3. Carefully disassemble pressure connection to pressure gauge and drain the water from the gauge.
4. Clean, label w/calibration sticker, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 3-24-00 , 1:45 PM

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Gauge meets the requirement of this Test Plan along with mfg. accuracies.

J. Casati

3/24/00

Dedication Test Plan - PG-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-037-TP-037

Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

Page 4 of 4

Notes:

Lined area for notes, currently blank.

Test Engineer/Technician (Printed Name) JEFF CADICK

Test Engineer/Technician (signature) J. Cadick Date: 3/24/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) JWP Larry Swenson Date: 3/28/00

QA/QC (signature) Stephen Scott Mon Date: 3-29-2000

Belhaven

Applied Technologies

Customer FDH Contract # 2717-3

Certificate of Calibration

Tag BEL00-187 Model 45-1009S-02L- Manufacturer Ashcroft
2000

Instrument Pressure Gauge Serial No Marked "2"

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68F
Accuracy of Instrument 1%
Calibrated Range: 2000 PSIG

Calibration Report No. 00-187

Date Due: 3-24-2001

Test Equipment

Ametek Deadweight Tester, S/N: 16132 (BAT-035)

Calibrated by: *J. Caswell 3-24-00*

Certified by: *[Signature]*
Quality Assurance Manager

ORIGINAL

Tag No BEL00-187
Instrument Type Pressure Gauge
Manufacturer Ashcroft
Serial No Marked "2"
Model 45-1009S-02L-2000
Cal Due Date 3-24-2001
System
Special Instructions Procedure Used: NA17-20MP-41

		Cal Point	As Found	As Left	% Full Scale Accuracy
Units:	PSIG	249.992	260	260	0.5004
F.S. Accuracy	1%	599.551	580.5	580.5	-0.9526
F.S. Accuracy		999.715	1000	1000	0.0143
Full Scale	2000	1349.732	1350	1350	0.0134
Permitted Variation	20.0000 PSIG	1599.552	1600	1600	0.0224
Cal Temp	68F				

Test Equipment Ametek Deadweight Tester, S/N: 16132 (BAT-035)

Calibration Performed By A. Caswell

Date 3-24-00

ORIGINAL

Dedication Test Plan - PG-1
 Test Plan No.: CGI-SNF-D-MHM-037-TP-037
 Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

ORIGINAL Rev. No. 0
 Page 1 of 4

Test Procedure Approval (Obtain prior to testing):
 This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) JWP Wang Date: 3/24/00

RECOMMENDED EQUIPMENT:

- Helium supply
- Pressure regulator - to hydrostatically test the specimen to 2000+ psig
- Pressure regulator - helium supply to 2000+ psig
- Peak Pressure Indicator 0-2000+ psig
- Test jig to mount Pressure Gauge vertically with port at bottom of switch
- Personnel protection panel
- Snoop or equivalent

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) serial numbers and calibration due

Test Instrument type: <u>Ametek</u>	I.D.: <u>BAT-035</u>	Calib. Due date: <u>11/16/02</u>
Test Instrument type: <u>Dats</u>	I.D.: _____	Calib. Due date: _____
Test Instrument type: _____	I.D.: _____	Calib. Due date: _____
Test Instrument type: _____	I.D.: _____	Calib. Due date: _____

SAFETY INSTRUCTIONS: PERSONNEL SAFETY - personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Pressure Gauge

Record the following Identification Information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>ASHCROFT</u>	Ashcroft	<u>ACC.</u>
Model:	<u>45-1009S-02L-2K</u>	45-1009S-02L-2000	<u>ACC.</u>
Dial Size:	<u>4.5 Ø</u>	4-1/2" Nominal	<u>ACC.</u>
Pressure Connection:	<u>1/4 NPT</u>	1/2" Nominal	<u>ACC.</u>
Indicator Range, Figure Interval, Minor Graduation	<u>OK</u>	0-2000, 200, 20	<u>ACC.</u>

ORIGINAL

Dedication Test Plan - PG-1 Test Plan No.: CGI-SNF-D-MHM-037-TP-037 Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000	Rev. No. 0 Page 2 of 4
---	-------------------------------

Description	Record Data	Acceptance Criteria	Comments/Deviations
Serial No.:	#3	N/A	MARKED #3

Perform the following tests:

Record: Date /Time of Test Beginning: 4-17-00, 8:41 AM

Record: Room Temperature: 68 °F. Room Barometric Pressure: -14.7199 mmHg.

Perform steps below:

1. Pressure Boundary Integrity Test

Setup the Pressure Gauge specimen for pressure testing with water on the wetted surfaces of the gauge. Attach a sketch of test circuit with all test instrumentation used.

Apply a water pressure to the test specimen, gradually building up the pressure to 110% of design pressure of 1800 psig = 1980 psig.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pressure Boundary Integrity Test:	<u>1999.729 PSIG</u>	No leakage at test pressure of 1980 psig +1 %, - zero for minimum of 10 minutes	<u>NO LEAK DOWN ACC.</u>

2. Calibration and Operating Range Accuracy Test

With water on the wetted surfaces of the pressure gauge specimen, apply hydrostatic pressure to the specimen and perform calibration and operating range accuracy testing. Attach a sketch of test circuit with all test instrumentation used.

Calibrate the gauge on a five point calibration throughout the 0-1800 range and within the operating range (1300-1600 psig). Record the data below:

Pressure Point	As-Found Record Data	Acceptance Criteria	Comments/Deviations
5 Point Calibration			
<u>0 PSIG</u>	<u>0</u>	± 1% full scale	<u>ACC.</u>
<u>249.992 PSIG</u>	<u>245 PSIG</u>	± 1% full scale	<u>ACC.</u>
<u>599.537 PSIG</u>	<u>600.5 PSIG</u>	± 1% full scale	<u>ACC.</u>
<u>999.715 PSIG</u>	<u>1000 PSIG</u>	± 1% full scale	<u>ACC.</u>
<u>1349.732 PSIG</u>	<u>1360 PSIG</u>	± 1% full scale	<u>ACC.</u>
<u>1599.552 PSIG</u>	<u>1600 PSIG</u>	± 1% Full Scale	<u>ACC.</u>
<u>0 PSIG</u>	<u>0 PSIG</u>	± 1% Full Scale	<u>ACC.</u>

ORIGINAL

Dedication Test Plan - PG-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-037-TP-037	
Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000	Page 3 of 4

Pressure Point	As-Found Record Data	Acceptance Criteria	Comments/Deviations
Operating Range Calibration			
1249.937 psig	1260 psig	± 1% full scale	Acc.
1349.732 psig	1360 psig	± 1% full scale	Acc.
1499.771 psig	1500 psig	± 1% full scale	Acc.
1599.552 psig	1600 psig	± 1% full scale	Acc.

1. De-pressurize equipment.
2. End test.
3. Carefully disassemble pressure connection to pressure gauge and drain the water from the gauge.
4. Clean, label w/calibration sticker, box (In original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 4-17-00, 9:07 AM

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Gauge meets the requirement of this Test Plan along with mfg. accuracies.
J. Coakley
4/17/00

ORIGINAL

Dedication Test Plan - PG-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-037-TP-037

Test Specimen: Ashcroft Hydraulic Pressure Gauge #45-1009S-02L-2000

Page 4 of 4

Notes:

[Empty lined area for notes]

This test plan was approved prior to testing on 3/24/00 for 2 devices (pressure gauges). A third identical pressure gauge needed to be tested based on same approved test plan but testing lab (Belhaven) did not have an approved blank (unexecuted) test plan to record data. So, an executed test plan was copied, data removed, and used to record new data.

Test Engineer/Technician (Printed Name) JEFF CHAIK

Test Engineer/Technician (signature) [Signature]

Date: 4/17/00

used to record new data.
Lynn
Dixon
4/27/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 4/27/00

QA/QC (signature) [Signature] Date: 5-3-2000

ORIGINAL

Belhaven

Applied Technologies

Customer Fluor Daniel PO# 2717-3

Certificate of Calibration

Tag BEL00-214 Model 45-1009S-02L-2 Manufacturer Ashcroft
K

Instrument Pressure Gauge Serial No Marked #3

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68F
Accuracy of Instrument 1%
Calibrated Range: 2000 PSIG

Calibration Report No. 00-214

Date Due: 4/17/2001

Test Equipment

Ametek Deadweight Tester, S/N: 16132

Calibrated by: *S. Casper* 4-17-00

Certified by: *[Signature]*
Quality Assurance Manager

ORIGINAL

**THIS PAGE INTENTIONALLY
LEFT BLANK**

SNF-6315, Rev. 0

Page 351

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-032
 Title: MHM Interlock P2 & P6 - MHM Mode Select Switch w/Solenoid Interlock

Page 1 of 7

Section 1 Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
ORIGINAL		
Part Description: <u>N/A</u>		
End Use Description: <u>N/A</u>		

Section 2a Component Information

Equipment No.: MHM Mode Select Switch	Specification No.: Ederer F-2566, Foster Wheeler MJX-SDX 452656	Manufacturer: Fortress Interlocks	Past P.O. No.: <u>N/A</u>
Manufacturer's Part/Model No.: H31SS	Equipment Supplier (if different from manufacturer): ALSTROM, Foster Wheeler	Equip. Supplier's Part No.: <u>N/A</u>	
Component Description: Mode selector switch for interlock P2 & P6. This switch with its integral solenoid selects the operation of the MHM in one of three modes: MCO, Impact Absorber Exchange Mode (IAXM), or Tube Plug Exchange Mode (TPXM). Through this switch, the correct set of interlocks for each operating mode sequence is selected.			

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
 YES (go to #2 below) NO (go to procedure step 6.3.2-dedicate Item)
 If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier?
 YES (go to #2 below, procedure step 6.3.2, & dedicate Item) NO (procedure step 6.3.2-dedicate Item)

2. List of Candidate qualified NQA1 suppliers or ISO 9000 suppliers, if used: N/A

1. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)

All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

ECN No. N/A	CGI No. CGI-SNF-D-MHM-032	Rev. No. 1	Page 2 of 7
Title: MHM Interlock P2 & P6 - MHM Mode Select Switch w/Solenoid Interlock			

Section 2d Reason for Dedication	
The above Commercial Grade (CG) described Item is being Dedicated for use in the application cited for the following reason(s):	
	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
X	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
Other ('like-for-like', similar, substitution, replacement evaluation)	

Section 3 Failure Effects Evaluation	
A. Part/Component Safety Function:	
1. This selector switch's interlocking is provided to ensure that the operating mode may only be changed when the MHM is positioned at the Exchange Facility with its Plug Cask and MCO Cask both empty and the Shield Skirt seated.	
B. Part/Component Functional Mode:	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function Passive - Change of state is not required for the component to perform its safety function
Safety Function #1: <input checked="" type="checkbox"/> Active <input type="checkbox"/> Passive	
Safety Function #2: <input type="checkbox"/> Active <input type="checkbox"/> Passive	
Safety Function #3: <input type="checkbox"/> Active <input type="checkbox"/> Passive	
C. Host Component Safety Function (if applicable): N/A	
1.	
D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):	
1. Failure of switch contacts to open upon demand results in potential override of interlock channel.	
2. Selector switch inoperative results in failure to provide interlock function at correct demand position.	

Section 4 Environmental & Natural Phenomena Hazard Design	
Environmental Qualification Required:	If yes: Environmental Qualification Requirements
Yes <input type="checkbox"/>	Limiting Environmental Conditions:
No <input checked="" type="checkbox"/>	Required Safety Functions:
	Qualification Period:
Natural Phenomena Hazard (NPH) Design Required:	If yes: NPH Design Requirements
Yes <input type="checkbox"/>	Performance Category:
No <input checked="" type="checkbox"/>	NPH Design Req'ts.:
	Required Safety Functions:

Section 5 Component Functional Classification			
X	Safety Class (SC)	General Service (GS)	Safety Significant (SS)
If part/component classification is different from host component/system, document basis. N/A			

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: **N/A**

Safety Analysis Report (SAR): **HNF-3672 Rev. 0**

Drawings: **Ederer, Inc. EB-33056, Sheet 4**

Vendor Manual/Manufacturer/Supplier Information: **Cut Sheet - Fortress Keygard H31SS Solenoid Controlled Interlock Unit**

Other: **ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1988**

98 JPC 8/11/00

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 3 of 7

ECN No. N/A CGI No. CGI-SNF-D-MHM-032
Title: MHM Interlock P2 & P6 - MHM Mode Select Switch w/Solenoid Interlock

SNF-6315, Rev. 0

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acc Meth	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Fortress	1, IN	X	
Model	H31SS	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Contact Rating	Nominal 16 amps VAC, resistive, less than 0.5 V drop across contacts	1, T		X
Insulation Resistance (includes solenoid leads)	≥10 megohm resistance, terminal to terminal and terminal to ground at 500 V for contacts and solenoid.	1, T		X
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation	1, T		X
4. Notes: 10 AMPS IS ADEQUATE FOR TESTING - TYPICAL FOR MOST COMPONENTS. <i>JWP CBS 4/16/00</i>		Acceptance Method (Acc Meth): 1. Special Test and Inspection: 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 2. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:
 Designated Engineer: *[Signature]* 4/6/00
 Design Authority: *[Signature]* 4-6-00
 QA Engineer: *[Signature]* 4-6-2000

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-032

Page 4 of 7

Title MHM Interlock P2 & P6 - MHM Mode Select Switch w/Solenoid Interlock

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	X	Switch contacts corrode closed and fail to open upon demand
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Switch contacts fuse closed and fail to open upon demand
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Switch mechanism jams and contacts fail to open upon demand.
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
3. Switch contacts are closed to permit equipment movement. Contacts open for the interlock function. Any failure, which prevents contacts to open, inhibits the particular switch interlock function.			
4. Selector switch seizure or break renders the contact opening inoperable.			
5. Short circuit could give false signal to energize interlock function.			

Commercial Grade Item Upgrade Dedication Form

Rev No 0
Page 5 of 7

ECN No. N/A CGI No. CGI-SNF-D-MHM-032
Title: MHM Interlock P2 & P6 - MHM Mode Select Switch w/Solenoid Interlock

SNF-6315, Rev. 0

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1			
Item Description: MHM Mode Select Switch		Equip #:	
System #: MHM		Model #: KGRSS H31SS <i>YWP 4/10/00</i>	
Manufacturer (Address/Phone): Fortress Interlocks Ltd. 148 Birmingham New Road, Wolverhampton, WV4 6NT P.O. #		Supplier (Address/Phone): Castell Interlocks, Inc. (Laurie Wallace) P.O. Box 18485, 21 Kenton Lands Road Erlanger, Kentucky 41018 USA Ph: 606-341-3075; Fax: 606-341-2302	
SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.			
Insp	Test	Post-Test	Item
[X]	[]	[]	1. Manufacturer
[X]	[]	[]	2. Model
[]	[X]	[]	3. Contact Rating
[]	[X]	[]	4. Insulation Resistance
[]	[X]	[]	5. Mechanical Operation
SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)			
Characteristic: Manufacturer *		Sample Size*: 100%	
Acceptance Criteria: Fortress			
Receipt Inspection Plan / Report #:			
Characteristic: Model Number *		Sample Size*: 100%	
Acceptance Criteria: H31SS			
Receipt Inspection Plan / Report #:			
SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)			
Characteristic for Test: Contact Rating		Samp Size*: [X]Normal []Reduced []Tightened	
Acceptance Criteria: Nominal 10¹⁰ amps, resistive, @ 120 VAC, less than 0.5 V drop across contacts			
Actual Test Value: <i>See TP</i>		Test Plan and Report #: CGI-SNF-D-MHM-032-TP-032	
Characteristic for Test: Insulation Resistance (incls. Solenoid leads)		Samp Size*: [X]Normal []Reduced []Tightened	
Acceptance Criteria: ≥10 megohm resistance, terminal to terminal and terminal to ground at 500 V for contacts and solenoid.			
Actual Test Value: <i>See TP</i>		Test Plan and Report #: TP-032	
Characteristic for Test: Mechanical Operation		Samp Size*: [X]Normal []Reduced []Tightened	
Acceptance Criteria: Cycle switch - confirm contacts open and close with smooth operation.			
Actual Test Value: <i>See TP</i>		Test Plan and Report #: TP-032	

*SWITCH WAS TAKEN APART - THERE WERE NO MARKINGS EXCEPT ON THE CONTACT BLOCKS - MFG: CRAIG-DERRICOTT
 EDERER'S AS-BUILT LIST SAYS THIS IS A FORTRESS, MODEL # H31SS.
(see wtsheet attached to Test Plan TP-032)
YWP 4/10/00
 CES
 4-11-00
 04/06/00 5

Commercial Grade Item Upgrade Dedication Form

Rev No 0

ECN No. N/A

CGI No. CGI-SNF-D-MHM-032

Page 6 of 7

Title: MHM Interlock P2 & P6 – MHM Mode Select Switch w/Solenoid Interlock

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: MHM Mode Select Switch w/Solenoid Interlock

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-ist ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Fortress Interlocks	X		1, IN	See * 5/2/00						
Model	H31SS	X		1, IN							
Contact Rating	Nominal 16 amps, resistive, @ 120 VAC, less than 0.5 V drop across contacts		X	1, T	TP02	NA	1	0	XWEST	LARRY W PRICE <i>[Signature]</i>	4/10/00
Insulation Resistance (includes solenoid leads)	≥10 megohm resistance, terminal to terminal and terminal to ground at 500 V for contacts and solenoid.		X	1, T	↓	↓	↓	↓	↓	↓	↓
Mechanical Operation	Cycle switch – confirm contacts open and close with smooth operation.		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-032 cited above. CES 4/11/00				BUYER VERIFICATION			
Testing Agency Approval: <u>NR CES 4/11/00</u>	Date: _____	Design Authority: <u>[Signature]</u>	Date: <u>4-11-00</u>	Testing Agency QA Engineer: <u>NR CES 4/21/00</u>	Date: _____	QA Engineer: <u>[Signature]</u>	Date: <u>4-20-2000</u>

SNF-6315, Rev. 0

Page 356

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-032

Page 7 of 7

Title MHM Interlock P2 & P6 - MHM Mode Select Switch w/Solenoid Interlock

SNF-6315, Rev. 0

Section 6 Contacts/Phone Numbers	
Name	Phone
Design Authority <u>CRAIG SWENSON</u>	() <u>376-0288</u>
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents	For Critical Characteristics
<input type="checkbox"/> Drawings:	
<input type="checkbox"/> Manuals (specify type & number):	
<input type="checkbox"/> Design Calculations	
<input type="checkbox"/> Installation Instructions	
<input type="checkbox"/> Operation Instructions	
<input type="checkbox"/> Calibration Instructions	
<input type="checkbox"/> Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/> Other: <u>Cut Sheet - Fortress Keygard-KGRSS Solenoid Controlled Interlock Unit</u> <u>H3135</u>	<u>All</u>
Procurement Documents	
<input type="checkbox"/> Certificate of Conformance/Compliance	
<input type="checkbox"/> Seismic Qualification Certificate	
<input type="checkbox"/> Environmental Qualification Certificate	
<input type="checkbox"/> Test Report (s)	
<input type="checkbox"/> Inspection Report (s):	
<input type="checkbox"/> CMTRs for ASME Pressure Retaining Materials	
<input type="checkbox"/> Valve Seat Leakage Report	
<input type="checkbox"/> Weld Records	
<input type="checkbox"/> Material Traceability Record	
<input checked="" type="checkbox"/> Other: <u>Hanford MCO Handling Machine (MHM) Operations & Maintenance Manual, Section 3.1.7.1</u>	

Dedication Test Plan – IST-SELsw-2
 Test Plan No.: CGI-SNF-D-MHM-032-TP-032
 Test Specimen: Fortress Selector Switch H31SS; Eqmt. No.: Mode Selector Switch Page 1 of 8

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
						130 3/12/00 NO CHANGES

* QA Post Review of Individual Revisions is allowed

This will be the original Test Plan

J. Casado 3/2/00

Dedication Test Plan – IST-SELsw-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-032-TP-032


Test Specimen: Fortress Selector Switch H31SS; Eqmt. No.: Mode Selector Switch

Page 2 of 8

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date: 2/29/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician (CIT)	Michael Cream	Beithaven	Michael Cream	MC
Electrician	J W EBERHART	PCE	J W Eberhart	JWE
Electrician Quality Control (QC)	Stephen R. Conley	PCE	Stephen R Conley	SPC
Design Authority Representative (DA)	LARRY W. PRICE	XNEST	Larry W Price	YMP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being verified unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP3457 I.D.: BAT-123 Calib. Due date: 7-29-00

Test Instrument type: HP3457 I.D.: BAT-124 Calib. Due date: 7-30-00

Test Instrument type: AUO BM 80-2 I.D.: 6410-889/000100/5245 Calib. Due date: 2-9-01

Test Instrument type: FLUKE 787 I.D.: BAT-107 Calib. Due date: 5-28-00

Test Instrument type: Proto 6106 I.D.: 029E/009 #2 Calib. Due date: 1-14-2001

Torque screw driver

Dedication Test Plan – IST-SELsw-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-032-TP-032

Test Specimen: Fortress Selector Switch H31SS; Eqmt. No.: Mode Selector Switch

Page 3 of 8

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.

2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	FORTRESS	Fortress	Acc
Model:	N/A	N/A	Acc
Type:	YES	3 Position Selector, 2 NC, 4 NO	Acc
Serial No.:	N/A	N/A	Acc

2.1 Perform the following testing steps:

2.2 Record: Date /Time of Test Beginning: 3-01-00 11:00 a.m.

Record: Room Temperature: 63 °F.

2.3 Mechanical Operation

Cycle the switch - confirm contacts open and close with smooth operation and spring return from right to center.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Describe Operation:	YES	Contacts open and close with smooth operation.	Acc

Note: 2.5 may be performed before 2.4

2.4 Contact Rating Test

2.4.1 Setup the Selector Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used. See drawing on page 6 for circuit nos.

Dedication Test Plan – IST-SEL-SW-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-032-TP-032

Test Specimen: Fortress Selector Switch H31SS; Eqmt. No.: Mode Selector Switch

Page 4 of 8

2.4.2 Place selector switch in the "TPXM" Mode position. Apply a nominal 10 amps VAC, resistive, across the closed contacts of the test specimen. First apply the current to Contact Circuit #1 and record the readings, then Contact Circuit #2 and record the readings.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #1 (Terminals 101X-404X)	.1 VAC	< 0.5 Volts AC drop	ACC
Contact Circuit #2 (Terminals 101Y-407Y)	.07 VAC	< 0.5 Volts AC drop	ACC

2.4.3 Move the switch to the "IAXM" Mode position to close the NO contacts. Apply a nominal 10 amps VAC, resistive, across the now closed contacts of the test specimen. First apply the current to Contact Circuit #3 and record the readings, then Contact Circuit #4 and record the readings.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #3 (Terminals 101X - 405X)	.12 VAC	< 0.5 Volts AC drop	ACC
Contact Circuit #4 (Terminals 101Y - 408Y)	.14 VAC	< 0.5 Volts AC drop	ACC

2.4.4 Move the switch to the "MCO" Mode position to close the NO contacts. Apply a nominal 10 amps VAC, resistive, across the now closed contacts of the test specimen. First apply the current to Contact Circuit #5 and record the readings, then Contact Circuit #6 and record the readings.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #5 (Terminals 101X - 406X)	.07 VAC	< 0.5 Volts AC drop	ACC
Contact Circuit #6 (Terminals 101Y - 409Y)	.10 VAC	< 0.5 Volts AC drop	ACC

2.4.5 De-energize equipment and determinate test leads.

2.5 Insulation Resistance Test

2.5.1 Setup the Selector Switch specimen for insulation resistance testing. Attach Selector Switch in its normal mounting configuration to grounded fixture.

Dedication Test Plan – IST-SELsw-2	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-032-TP-032	
Test Specimen: Fortress Selector Switch H31SS; Eqmt. No.: Mode Selector Switch	Page 5 of 8

2.5.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground						
Selector Switch Position	Contact Circuit No.*	Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
TPXM	1	101X	Ground	> 100 Gohm	> 10 Megohms	Acc
TPXM	2	101Y	Ground	> 100 Gohm	> 10 Megohms	Acc
TPXM	3	101X	405X	> 100 Gohm	> 10 Megohms	Acc
TPXM	4	101Y	408Y	> 100 Gohm	> 10 Megohms	Acc
TPXM	5	101X	406X	> 100 Gohm	> 10 Megohms	Acc
TPXM	6	101Y	409Y	> 100 Gohm	> 10 Megohms	Acc
IAXM	1	101X	404X	> 100 Gohm	> 10 Megohms	Acc
IAXM	2	101Y	407Y	> 100 Gohm	> 10 Megohms	Acc
IAXM	3	101X	Ground	> 100 Gohm	> 10 Megohms	Acc
IAXM	4	101Y	Ground	> 100 Gohm	> 10 Megohms	Acc
MCO	5	101X	Ground	> 100 Gohm	> 10 Megohms	Acc
MCO	6	101Y	Ground	> 100 Gohm	> 10 Megohms	Acc

* Refer to drawing on page 6

MSSS Solenoid terminals 402X and LO(2):

N/A	N/A	402X or LO(2)	Ground	> 100 Gohm	> 10 Megohms	Acc
-----	-----	---------------	--------	------------	--------------	-----

2.6 De-energize test equipment.

2.7 Terminate the test.

2.7.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.7.2 Retorque the terminals to 7-9 in-pounds.

2.7.3 Remove lockout/tagout and restore system to normal.

2.7.4 Record: Date /Time of Test End: 2:00 PM 3-2-00

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 4

Dedication Test Plan - IST-SELsw-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-032-TP-032

Test Specimen: Fortress Selector Switch H31SS; Eqmt. No.: Mode Selector Switch

Page 6 of 8

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Component meets all of this test plan requirements.
M. Cram 3/2/00

Notes:

Certified Instrumentation Technician (signature) M. Cram Date: 3-2-00
Received by: JTC 3/2/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 3/2/00

QA/QC (signature) [Signature] Date: 3/13/00


Dedication Test Plan - IST-SELsw-2

Rev. No. 0


Test Plan No.: CGI-SNF-D-MHM-032-TP-032

Test Specimen: Fortress Selector Switch H31SS; Eqmt. No.: Mode Selector Switch

Page 7 of 8



MHM Mode Selector Switch - Wiring



LIFTED LEAD LOG

Junction Box: MHM Control Console - Left Side

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-33056	4	101X	Mode Sel Sw	NC	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	404X	Mode Sel Sw	NC	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	101Y	Mode Sel Sw	NC	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	407Y	Mode Sel Sw	NC	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	101X	Mode Sel Sw	NO	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	405X	Mode Sel Sw	NO	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	101Y	Mode Sel Sw	NO	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	408Y	Mode Sel Sw	NO	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	101X	Mode Sel Sw	NO	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	406X	Mode Sel Sw	NO	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	101Y	Mode Sel Sw	NO	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	409Y	Mode Sel Sw	NO	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	403X	Solenoid	N/A	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00
EB-33056	4	LO(2)	Solenoid	N/A	JWE	3/2/00	SRL	3-2-00	JWE	3/2/00	SRL	3-2-00


Remarks:

SNF-6315, Rev. 0

Page 365

Data Sheet

Ref. B2

**FORTRESS
INTERLOCKS**

H31SS Solenoid Controlled Interlock Unit

Description

A range of key operated rotary switch units, with additional solenoid control. Variations including up to 7 locks are available, in both panel (BOB) and surface (FOB) mounting forms. Normally supplied for vertical mounting; horizontal mounting units available on request.

Application

As part of an interlock system, the units are used for control or isolation of control or power circuits operating plant or machinery, and the solenoid facility allows for integration with other electronic control processes within the system.

(e.g a machine may come to end of cycle, before the power can be isolated.)

Operation

The solenoid holds the primary key in the trapped position (normally power ON), and must be energised by receipt of a remote electrical signal, before the key can be operated and released. Removal of the key isolates the power or control circuits. In multiple lock units, the primary key is released first, followed by the others in sequence. All keys must be replaced in the correct order before the primary key can be returned and the equipment re-energised.

Construction

Lock mechanism - Brass, with nickel-chrome finish to lock casing and hinged dustcover. *Enclosure* - (FOB) or mounting plate (BOB) - Mild Steel with polyester/epoxy finish.

Solenoids - Standard 110V AC continuously rated Consumption 20VA

Switches - Standard 16A 250V (Max.) DC
4 Pole N/O or 2 N/O, 2 N/C

Other ratings available on request

Options (See Options Data Sheet)
Part/All Stainless Steel Basic Locks.
Stainless Steel dustcover
Screw-on dustcover
Additional locks (Max total 7)
Horizontal mounting
Optional solenoid ratings
Special switch contact configurations
Supplied without switch
'Special' units (details on application)

Keys

Keys are ordered separately.

See reverse for Technical Data and ordering details


FORTRESS

A Division of Fortress Interlocks Ltd



FM1737

Technical Data (all dimensions in mm)



H31SS1/FOB
Front view

H31SS1/BOB
Front view

Side view

Ordering Information

1. Type	H31SS/(1,2,3,4,5,6,7)
2. Mounting	Panel (BOB) Surface (FOB)
3. Solenoid	110V AC 24V DC Other (Specify)
4. Switch	16A 4 N/O 16A 2 N/O, 2N/C Other (Specify)
5. Construction	Standard Part Stainless Steel (Basic Lock(s))
6. Dustcover	Standard Stainless Steel Screw-on None
7. Coding Details	Specify Coding required- 1/4" Characters - Max 11 Characters 6 top row; 5 bottom row Longer codes using 1/8" Characters - on request
8. Keys	Standard Indicator Large 'T' (7081) type
Finish	Brass Stainless Steel

Order Example


1. Type	- H31SS2
2. Mounting	- FOB
3. Solenoid	- 24V DC
4. Switch	- 16A 4 N/O
5. Construction	- Standard
6. Dustcover	- Standard
7. Coding	- Top lock ACCESS - Bottom lock ISOL
8. Keys	- Standard Codes 1 - ISOL 1 - ACCESS

FORTRESS

A Division of Fortress Interlocks Ltd

148 Birmingham New Road, Wolverhampton WV4 6NT
tel (01902) 403546 fax (01902) 353003 telex 339193

A
HALMA
GROUP
COMPANY



MCC#15

HANFORD DWG # H-2-826710 SHT 9 OF 97

REV	DATE	BY	CHK	E/C	APPD	APPD	DESCR	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
0	7/15/97	JBR	JMH	TJM	JUN		GEN																			
1	8/18/97	JRS	AH	TJM	JUN	LLA	MODIFY SELECTOR SWITCH																			
2	9/1/97	JBR	AH	TJM	JUN	EU	MODIFY LOCATION ADDRESS: ADD PUSH-TO-TEST																			
3	10/25/97	JRS	DM	TJM	JUN	EU	MODIFY LOCATORS																			
4	3/9/98	CSO	SCD	CSJ			DE-INCREASING & SIMPLIFICATION																			
5	7/20/98	CSH	SCD	CSH			GENERAL REVISION																			
6	3/9/99	CSO	SCD	CSO			REVISED PER INSTALLATION MARK-UPS																			

EB-3305G

Ederer Job No. F-2566
Bill of Material

A-242408LP	NEMA Type 12, 13 Enclosure, single door, 24"x24"x8"	Hoffman	TB-P-JBOX	8626	1	EL-35935
tbd-2566t	Motor, 15HP, 1200RPM, 480VAC, suitable for VFD operation to 2000RPM continuous duty, Class F Insul, class B rise, NEMA design B, FOC Amps 4000 A	General Electric	TRMTR	10060	2	EL-35935
H31SS/LESS BASIC/	H31SS/less basic/replace with switch knob/16A/6 pole 3 position/ ul rated/110 VAC solenoid/bob/ solenoid is energised to allow switch to move from all 3 positions/with	Fortress	3POS	13008	1	EL-35936
66X12-4000-116	Alarm Display, 6 x 6 LEDs,, 120 VAC power, w/integral pushbuttons per drawing ED-35900 rev. - sht 1	Ronan	ALARM	13370	1	EL-35936
CR104PSK21A 91L	2-Position Selector Switch, Maintained, Cylinder Lock, Remove Key from Left Only, 1N.O.-1N.C., N.C. Left Position	General Electric	ANTI-COLLISION	1875	1	EL-35936
CR104PSG34B 91	3-Position Selector Switch, Maintained, Standard Knob, Black, 1 NO 1 NC	General Electric	BRIDGE SEISMIC CLAMPS	13721	1	EL-35936
CR104PSG21B 91	2-Position Selector Switch, Maintained, Standard Knob, Black, 1N.O.-1N.C.	General Electric	BRIDGE SLOW	1855	1	EL-35936
CR104PSG94B 91	3-Position Selector Switch, Spring Return Right To Center, Key Lever, Chrome, 2N.O.-2N.C.	General Electric	CAMERA FOCUS	13579	1	EL-35936
			CAMERA LIGHTING DIMMER		1	EL-35936
CR104PSG94B 91	3-Position Selector Switch, Spring Return Right To Center, Key Lever, Chrome, 2N.O.-2N.C.	General Electric	CAMERA ZOOM	13579	1	EL-35936
EC-35937	Console Phenolic Labels	Ederer	CONSOLE LABELS	13599	1	EL-35936

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A CGI No. CGI-SNF-D-MHM-023

Page 1 of 8

Title: P02, 06, 61, 63 and P65 Interlocks - Siemens Relay #3TH4310-0AK6

Section 1 Part Information

Item No.: N/A Manufacturer: N/A Supplier: N/A

Mfg. Part/Model No.: N/A Supplier's P/N: N/A

Part Description: N/A ORIGINAL

End Use Description: N/A

Section 2a Component Information

Equipment No.: MCO, TPXM, IAXM Specification No.: Ederer F-2566, Foster Wheeler MJX-SDX 452656 Manufacturer: Siemens Past P.O. No.: N/A

Manufacturer's Part/Model No.: 3TH4310-0AK6 Equipment Supplier (if different from manufacturer): ALSTROM, Foster Wheeler Equip. Supplier's Part No.: N/A

Component Description: 120 VAC Fixed Contact Type Control Relay with 10 NO contacts. Located on the MHM. Used to prevent lifting an MCO when in the impact absorber or tube plug exchange mode.

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)? [] YES (go to #2 below) [X] NO (go to procedure step 6.3.2, proceed to dedicate Item) If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate with project CGI Interface Engineer or BTR) [] YES (go to #2 below, procedure step 6.3.2, dedicate Item) [X] NO (procedure step 6.3.2, dedicate Item)

2. List of Candidate qualified NQA1 suppliers or ISO 9000 suppliers, if used: N/A

3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

CGI Determination Questions: #1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities? [] YES (the Item is not commercial grade) [X] NO (continue) #2: Is the Item used in applications other than nuclear facilities or activities? [] NO (the item is not commercial grade) [X] YES (continue) #3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog? [] NO (the item is not commercial grade) [X] YES (continue) [X] All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 2 of 8

ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-MHM-023</u>
Title. P02, 06, 61, 63 and P65 Interlocks – Siemens Relay #3TH4310-0AK6	

Section 2d Reason for Dedication

The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):

4/20/00

	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input checked="" type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input checked="" type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input checked="" type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. Relay contacts must remain open to prevent operation when NOT in the MCO Mode.

<p>1. Part/Component Functional Mode:</p> <p>Safety Function #1: <input checked="" type="checkbox"/> Active [] Passive</p> <p>Safety Function #2: [] Active [] Passive</p> <p>Safety Function #3: [] Active [] Passive</p>	<p>Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function</p> <p>Passive - Change of state is not required for the component to perform its safety function</p>
---	--

C. Host Component Safety Function (if applicable):

1. Relay is used in control circuits providing interlocks that ensure proper MCO grapple and hoist operation for protection against events that could result in an MCO drop, P63 and P65.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

- 1. Contact resistance out of spec results in overheating and welding of contacts**
- 2. Hot short across contacts results in failure to open the circuit**
- 3. Binding of contacts results in failure to open circuit**

Section 4 Environmental & Natural Phenomena Hazard Design

<p>Environmental Qualification Required:</p> <p>Yes []</p> <p>No <input checked="" type="checkbox"/></p>	<p>If yes: Environmental Qualification Requirements</p> <p>Limiting Environmental Conditions:</p> <p>Required Safety Functions:</p> <p>Qualification Period:</p>
---	--

<p>Natural Phenomena Hazard (NPH) Design Required:</p> <p>Yes []</p> <p>No <input checked="" type="checkbox"/></p>	<p>If yes: NPH Design Requirements</p> <p>Performance Category:</p> <p>NPH Design Req'ts.:</p> <p>Required Safety Functions:</p>
---	--

Section 5 Component Functional Classification

Safety Class (SC)	General Service (GS)	<input checked="" type="checkbox"/>	Safety Significant (SS)
-------------------	----------------------	-------------------------------------	-------------------------

If part/component classification is different from host component/system, document basis. **N/A**

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: **N/A**

Safety Analysis Report (SAR): **HNF-3672, Rev. 0**

Drawings: **Ederer, Inc. EB-33056, Sheet 4**

Vendor Manual/Manufacturer/Supplier Information: **Siemens Industrial Control Products, Control Relays, 3TH4 Fixed Contact Type**

Other: **ALSTOM ESL/R (96) 065 – Rev. D, 100% Design Submittal – June 1998**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A CGI No. CGI-SNF-D-MHM-023

Page 3 of 8

Title: P02, 06, 61, 63 and P65 Interlocks - Siemens Relay #3TH4310-0AK6

Section 9 Critical Characteristics

Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Siemens	1, IN	X	
Model Number	3TH4310-0AK6	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Contact configuration	10 Normally Open (NO) contacts	1, IN	X	
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Current carrying capability	0.5V max. voltage drop across closed contacts at 10 amps VAC, resistive	1, T		X
Insulation resistance	10 Megohm min across open contact terminals and terminals to ground (500vdc)	1, T		X
Operation	Contacts open/close at maximum pick-up (102 VAC) and minimum drop-out (36 VAC) voltages	1, T		X
4. Notes and Legend:		Acceptance Method (Acc Meth):		
Rev 1: Page 1: Added Equipment Nos.; General New Forms		1. Special Test and Inspection:		
Rev. 2: Pages 3, 6, 7: revised Current carrying capability acceptance criteria to "0.5V max. voltage drop across closed contacts at 10 amps VAC, resistive"; Pages 3, 6, 7: revised Operation acceptance criteria to " Contacts open/close at maximum pick-up (102 VAC) and minimum drop-out (36 VAC) voltages"		1, IN for Inspection 1, T for Test		
		2. Commercial Grade Survey		
		3. Source Verification		
		1. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:

Designated Engineer: [Signature]

Design Authority: DW [Signature] 2/10/00

QA Engineer: [Signature]
TZ ANDERSON 2/10/00

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 4 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-023
Title: P02, 06, 61, 63 and P65 Interlocks - Siemens Relay #3TH4310-0AK6

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Failure to open the circuit by contact welding or hot short across the contact base.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Results in failure of contacts to open
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 5 of 8

ECN No. NA CGI No. CGI-SNF-D-MHM-023
Title: P02, 06, 61, 63 and P65 Interlocks - Siemens Relay #3TH4310-0AK6

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1

Item Description: Siemens relay System #: MHM	Equip #: MCO, TPXM, IAXM Model #: 3TH4310-0AK6
Manufacturer (Address/Phone): Siemens Industrial Control Products 1-800-964-4114	Supplier (Address/Phone): Ederer

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	PIT	
X			1. Manufacturer
X			2. Model Number
X			3. Actuator
	X		4. Contact Rating
	X		5. Insulation Resistance
	X		6. Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size, References (See Section 7)

Characteristic: Manufacturer Acceptance Criteria: Siemens Receipt Inspection Plan / Report #: CGI-SNF-D-MHM-023-TP-023 A,B,C	Sample Size*: 100%
Characteristic: Model Number Acceptance Criteria: 3TH4310-0AK6 Receipt Inspection Plan / Report #: TP-023 A,B,C	Sample Size*: 100%
Characteristic: Contact Configuration Acceptance Criteria: 10 NO contacts Receipt Inspection Plan / Report #: TP-023 A,B,C	Sample Size*: 100%

Commercial Grade Item Upgrade Dedication Form		Rev. No: 2
ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-MHM-023</u>	Page 6 of 8
Title: <u>P02, 06, 61, 63 and P65 Interlocks - Siemens Relay #3TH4310-0AK6</u>		

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)	
Characteristic for Test: Current carrying capability Acceptance Criteria: 0.5V max. voltage drop across closed contacts at 10 amps VAC, resistive Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP023 A, B</u>
Characteristic for Test: Insulation Resistance Acceptance Criteria: 10 Megohms min across open contact terminals and terminals to ground, with 500 vdc megger. Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP023 A, B</u>
Characteristic for Test: Operation Acceptance Criteria: Contacts open/close at maximum pick-up (102 VAC) and minimum drop-out (36 VAC) voltages Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP023 A, B</u>

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A

CGI No. CGI-SNF-D-MHM-023

Page 7 of 8

Title: P02, 06, 61, 63 and P65 Interlocks - Siemens Relay #3TH4310-0AK6

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Contactors

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Siemens	X		1, IN	TP-023ABC	NA	2	0	XWEST	<i>Larry Pries</i>	4/10/00
Model Number	3TH4310-0AK6	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Terminal Configuration	10 NO contacts	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Current Carrying Capability	0.5V max. voltage drop across closed contacts at 10 amps VAC, resistive		X	1, T	TP-023A,B	↓	↓	↓	↓	↓	↓
Insulation Resistance	10 Megohms min across open contact terminals and terminals to ground (500VDC megger)		X	1, T	↓	↓	↓	↓	↓	↓	↓
Operation	Contacts open/close at maximum pick-up (102 VAC) and minimum drop-out (36 VAC) voltages		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-023 A, B, C cited above CES Testing Agency Approval: <u>NA CES 4/11/00</u> Date: <u>4/11/00</u>				BUYER VERIFICATION Design Authority: <u>Larry Pries</u> Date: <u>4-11-00</u>			
Testing Agency QA Engineer: <u>NA CES 4/11/00</u> Date: _____				QA Engineer: <u>Stephen Scott</u> Date: <u>4-20-2000</u>			

SNF-6315, Rev. 0

Page 376

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 8 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-023
Title: P02, 06, 61, 63 and P65 Interlocks - Siemens Relay #3TH4310-0AK6

SECTION 6 CONTACTS / PHONE NUMBERS

Name	Phone
Design Authority <u>CRAIG SWENSON</u>	() <u>376-0288</u>
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents		For Critical Characteristics
	Drawings:	
X	Manuals (specify type & number): <u>Siemens Industrial Control Products, Control Relays, 3TH4 Fixed Contact Type</u>	All
	Design Calculations	
	Installation Instructions	
	Operation Instructions	
	Calibration Instructions	
	Manufacturer's Recommended Spare Parts List	
	Other:	
Procurement Documents:		For Critical Characteristics
	Certificate of Conformance/Compliance	
	Seismic Qualification Certificate	
	Environmental Qualification Certificate	
	Test Report (s):	
	Inspection Report (s):	
	CMTRs for ASME Pressure Retaining Materials	
	Valve Seat Leakage Report	
	Weld Records	
	Material Traceability Record	
	Other:	

ORIGINAL

Dedication Test Plan - IST
Test Plan No.: CGI-SNF-D-MHM-023-TP-023A
Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: IAXM

Rev. No. 0

Page 1 of 8

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI. Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023A

Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: IAXM

Page 2 of 8

ORIGINAL

In-Situ Test Procedure**Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

JWP Langlois Date: 3/16/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	MICHAEL CRAM	Bellhaven	<i>Michael Cram</i>	MCC
Electrician	DAN K. YORK	P.C.E	<i>Dan K. York</i>	D.K.Y.
Electrician Quality Control	Stephen R Cowley	PCE	<i>Stephen R Cowley</i>	SKC
Design Authority Representative	LARRY W. PRICE	KWST	<i>Larry W. Price</i>	LWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current Source capable of 10 amps

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO BUBO/2 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023A

Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: IAXM

Page 3 of 8

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	IAXM	IAXM	Acc
Manufacturer:	SIEMENS	Siemens	Acc
Model:	3TH4310	3TH4310 (on side of relay)	Acc
Contact Configuration:	OK	10 Normally Open Contacts	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc
Coil	K6	K6 (near terminal A1)	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-22-00

11:20 a.m
acc
10:20 a.m 03-27-00

2.1.1 Complete the Lifted Lead Log prior to lifting leads.

2.1.2 Lift all leads

2.2 Operation

2.2.1 Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	87.376VAC	96 VAC maximum	Acc
Drop-out Voltage	43.867VAC	36 AC minimum	Acc

2.2.2 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023A

Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: IAXM

Page 4 of 8

2.3 Insulation Resistance Test

1 Setup the test equipment and relay specimen for insulation resistance testing.

2.3.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Record data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc
23	Ground	>100Gohm	> 10 Megohms	Acc
24	Ground	>100Gohm	> 10 Megohms	Acc
33	Ground	>100Gohm	> 10 Megohms	Acc
34	Ground	>100Gohm	> 10 Megohms	Acc
43	Ground	>100Gohm	> 10 Megohms	Acc
44	Ground	>100Gohm	> 10 Megohms	Acc
53	Ground	>100Gohm	> 10 Megohms	Acc
54	Ground	>100Gohm	> 10 Megohms	Acc
63	Ground	>100Gohm	> 10 Megohms	Acc
64	Ground	>100Gohm	> 10 Megohms	Acc
73	Ground	>100Gohm	> 10 Megohms	Acc
74	Ground	>100Gohm	> 10 Megohms	Acc
83	Ground	>100Gohm	> 10 Megohms	Acc
84	Ground	>100Gohm	> 10 Megohms	Acc
93	Ground	>100Gohm	> 10 Megohms	Acc
94	Ground	>100Gohm	> 10 Megohms	Acc
03	Ground	>100Gohm	> 10 Megohms	Acc
04	Ground	>100Gohm	> 10 Megohms	Acc
A1 or A2 (coil)	Ground	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
23	24	>100Gohm	> 10 Megohms	Acc
33	34	>100Gohm	> 10 Megohms	Acc
43	44	>100Gohm	> 10 Megohms	Acc
53	54	>100Gohm	> 10 Megohms	Acc
63	64	>100Gohm	> 10 Megohms	Acc
73	74	>100Gohm	> 10 Megohms	Acc
83	84	>100Gohm	> 10 Megohms	Acc
93	94	>100Gohm	> 10 Megohms	Acc
03	04	>100Gohm	> 10 Megohms	Acc

2.4 Contact Rating Test

2.4.1 Setup the test equipment and relay specimen for contact rating testing.

2.4.2 Manually adjust the relay or apply 120 VAC to the coil to close the normally open contacts

2.4.3 Apply a nominal 10 amps, resistive, across closed normally open contacts of the test specimen

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023A

Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: IAXM

Page 5 of 8

Caution: Do not change state of contacts while energized.

2.4.5 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contacts 13-14	.0683 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 23-24	.0621 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 33-34	.1227 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 43-44	.1073 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 53-54	.1176 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 63-64	.0910 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 73-74	.0707 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 83-84	.0732 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 93-94	.0881 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 03-04	.0891 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.6 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.

2.5.2 Retorque the terminals to 12 in-pounds.

2.5.3 Record: Date /Time of Test End: 03-22-00 12:50 p.m.

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 4

3.2 Y-Channel Main Power Panel Wiring Diagram: ED-33069 Sheet 1

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met.Michael Cram03-22-00

Dedication Test Plan - IST Test Plan No.: CGI-SNF-D-MHM-023-TP-023A Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: IAXM	Rev. No. 0 Page 6 of 8
--	-------------------------------

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-22-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) YAD Wang Swenson Date: 3/24/00

QA/QC (signature) Stephen Scott Moss Date: 3-27-0000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
		1) 5702X	IAXM	63	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		5701X		64	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		5705X		73	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		5709X		74	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		5100X		83	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		5101X		84	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		1) 6002X		93	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		2) 6003X		94	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		2) 101X		03	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		56A05X		04	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		1) 5702X		13	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		2) 5704X		14	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		2) 101X		23	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00
		714X		24	D.K.Y	3-22-00	SRL	3-22-00	D.K.Y	3-22-00	SRL	3-22-00

Remarks:

SNF-6315, Rev. 0

Page 384


LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
		2) 101X	IAXM	33	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		5811 X		34	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		2) 101X		43	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		5140X		44	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		2) 101X		53	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		6004X		54	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		2) 405X		A-1	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		Black	PCS24-6	A-1	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		Grey	"	A-2	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		2) 102 X	IAXM	A-2	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00

Remarks:

SNF-6315, Rev. 0

Page 385



MCC#15

HANFORD DWG # H-2-828710 SHT 9 OF 97¹⁹

REV	DATE	DESCRIPTION	BY	CHK	ENG	APPD	APPO	DRWN	J. B. HOSP	4/23/77
0	7/25/77	GENERAL REVISIONS	JBR	JWH	TVM	JWH		DEC	T. M. HEALONS	4/21/77
E	8/19/77	MODE SELECTION SWITCH	JRS	AH	TVM	JWH	LLA	DEC	T. M. HEALONS	4/21/77
F	9/1/77	MODIFY LOCATION ADDRESS; ADD PUSH-TO-TEST	JBR	AH	TVM	JWH	EV	APR	J. M. HANSEN	4/29/77
G	10/23/77	MODIFY LOCATORS	JRS	IMU	TVM	JWH	EU	APR	L. L. ANDERSON	4/29/77
H	3/9/78	DE-INTERLOCK & SIMPLIFICATION	CSO	SED	C. D.					
J	7/20/78	GENERAL REVISION	CSO	SED	CSH					
K	3/3/79	REVISED PER INSTALLATION MARK-UPS	CSO	SED	CSH					

EDGER
INCORPORATED
ELECTRICAL
EQUIPMENT
DIVISION
CHAMBERLAIN, MISSOURI

SCALE: N/A
FORM 443-01 F-2566


EB-3305G

REV 5


Control Relays

Selection

3TH4 Fixed Contacts Type



3TH4040-0AK6



3TH4022-0BB4

Ordering Instructions

- ▶ Determine the number of contacts, AC or DC, then select Catalog Number.
- Complete Catalog Number by adding Coil suffix from table below e.g.

3TH40	2	2	0	A	K6
-------	---	---	---	---	----

Relay Type ————
 2 NO ————
 2 NC ————
 Terminals ————
 AC ————
 Coil ————
 Voltage 120V AC

Additional References

- ▶ Technical Data see page 614.
- ▶ Dimensions see page 617.
- ▶ Wiring Diagrams see page 616.
- ▶ Accessories, Varistors, RC Elements and Suppressors see page 613.
- ▶ Replacement Parts see page 923.

Relays With Screw Terminals for DIN Rail and Screw Mounting

AC Operation									
No of Contacts	Code	Contact Type		Early Make		Late Break		Catalog No (Coil Suffix required from table below)	Price \$
		NO	NC	NO	NC	NO	NC		
Relay With 4 Fixed Contacts									
4	40E	4	—	—	—	—	—	3TH4040-0A††	72.
	31E	3	1	—	—	—	—	3TH4031-0A††	72.
	22E	2	2	—	—	—	—	3TH4022-0A††	72.
	13E	1	3	—	—	—	—	3TH4013-0A††	72.
	04E	—	4	—	—	—	—	3TH4004-0A††	72.
Relay with 4 Contacts, Early Make/Late Break									
	31E, U	2	—	1	1	1	1	3TH4095-0A††	89.
	22E, U	1	1	1	1	1	1	3TH4096-0A††	182.
	22E, 2U	—	—	2	2	—	—	3TH4092-0A††	132.
Relay With 8 Fixed Contacts									
8	80E	8	—	—	—	—	—	3TH4280-0A††	120.
	71E	7	1	—	—	—	—	3TH4271-0A††	120.
	62E	6	2	—	—	—	—	3TH4262-0A††	120.
	53E	5	3	—	—	—	—	3TH4253-0A††	120.
	44E	4	4	—	—	—	—	3TH4244-0A††	120.
Relay With 8 Contacts, Early Make/Late Break									
	44E, U	3	3	1	1	1	1	3TH4293-0A††	150.
Relay With 10 Fixed Contacts									
10	100E	10	—	—	—	—	—	3TH4310-0A††	144.
	91E	9	1	—	—	—	—	3TH4391-0A††	144.
	82E	8	2	—	—	—	—	3TH4382-0A††	144.
	73E	7	3	—	—	—	—	3TH4373-0A††	144.
	64E	6	4	—	—	—	—	3TH4364-0A††	144.
	55E	5	5	—	—	—	—	3TH4355-0A††	144.
Relay With 10 Contacts With Early Make/Late Break									
	55E, U	4	4	1	1	1	1	3TH4394-0A††	174.
Mechanically Latched Relay With 9 Contacts									
9	54	5	4	—	—	—	—	3TH4454-0A††	201.

DC Operation									
No of Contacts	Code	Contact Type		Early Make		Late Break		Catalog No (Coil Suffix required from table below)	Price \$
		NO	NC	NO	NC	NO	NC		
Relay With 4 Fixed Contacts									
4	40E	4	—	—	—	—	—	3TH4040-0B††	117.
	31E	3	1	—	—	—	—	3TH4031-0B††	117.
	22E	2	2	—	—	—	—	3TH4022-0B††	117.
	13E	1	3	—	—	—	—	3TH4013-0B††	117.
	04E	—	4	—	—	—	—	3TH4004-0B††	117.
Relay With 4 Contacts, Early Make/Late Break									
	31E, U	2	—	1	1	1	1	3TH4095-0B††	147.
	22E, U	1	1	1	1	1	1	3TH4096-0B††	147.
	22E, 2U	—	—	2	2	—	—	3TH4092-0B††	177.
Relay With 8 Fixed Contacts									
8	80E	8	—	—	—	—	—	3TH4280-0B††	162.
	71E	7	1	—	—	—	—	3TH4271-0B††	162.
	62E	6	2	—	—	—	—	3TH4262-0B††	162.
	53E	5	3	—	—	—	—	3TH4253-0B††	162.
	44E	4	4	—	—	—	—	3TH4244-0B††	162.
Relay With 8 Contacts, Early Make/Late Break									
	44E, U	3	3	1	1	1	1	3TH4293-0B††	192.
Relay With 10 Fixed Contacts									
10	100E	10	—	—	—	—	—	3TH4310-0B††	186.
	91E	9	1	—	—	—	—	3TH4391-0B††	186.
	82E	8	2	—	—	—	—	3TH4382-0B††	186.
	73E	7	3	—	—	—	—	3TH4373-0B††	186.
	64E	6	4	—	—	—	—	3TH4364-0B††	186.
	55E	5	5	—	—	—	—	3TH4355-0B††	186.
Relay With 10 Contacts With Early Make/Late Break									
	55E, U	4	4	1	1	1	1	3TH4394-0B††	216.
Mechanically Latched Relay With 9 Contacts									
9	54	5	4	—	—	—	—	3TH4454-0B††	231.

Coil Suffix

AC Volts 50/60Hz							
24	110/120	173/208	220/277	208	220/240	380/460	500/600
C2	K6	M1	U1	M2	P6	Q0	S0

Coil Suffix

DC Volts				
12	24	48	125	240
A4	B4	W4	G4	O4

For other Coil Voltages see page 911.

Logic Control

612


Control Relays

Wiring Diagrams


3TH4 Fixed Contacts Type

Terminal Designations According to DIN EN 50011


3TH40, AC and DC Operation




3TH42, AC and DC Operation




3TH43, AC and DC Operation




3TH44, Internal Connection Diagram, AC and DC Operation



3TH44, Schematic Diagrams, AC and DC Operation




Do not operate S2 while S1 is closed.




Contact Life Curve

Permitted inclination	(α) of the mounting surface to the vertical	any
Coil voltage tolerance	max $\times U_n$	0.8 to 1.1
min $\times U_n$		0.85 to 1.1
		0.9 to 1.1



The AC operated relays preferably should be mounted on a vertical surface in any desired position.



The DC operated relays preferably should be mounted on a vertical surface in the position as shown in the drawing.

The relation between the permitted inclination to the mounting surface to the vertical and the coil voltage tolerance is as follows:

Type	3TH40, 3TH42, 3TH43
Mechanical Life	30 Million Operations
Permissible Ambient Temperature Range	-25 to +55°C
Coil Ratings	(Cold coil and $1.0 \times U_n$)
AC Operation	Inrush: 75 VA, 88 VA; Sealed: 9.4 VA, 10 VA; p f: 0.29
DC Operation	Inrush: 0.76, 0.82; Sealed: 0.29; p f: 0.29
DC Voltage Tolerances	AC: 0.8 to $1.1 \times U_n$; DC (except 24V): 0.8 to $1.2 \times U_n$; DC 24V: 0.8 to 1.0 $\times U_n$
Operation Times	Total Break Time = $1.1 \times U_n, 1.0 \times U_n$
AC Closing Delay	NC: 8-35 ms; NO: 4-18 ms
Opening Delay + Closing Time	NC: 6-20 ms; NO: 4-18 ms
Opening Time	NC: 5-30 ms; NO: 4-18 ms
Arcing Time	10 ms

Mounting

For snap-on and screw mounting, snapping onto 35 mm standard mounting rail in accordance with DIN EN 50 022.

Type	3TH40, 3TH42, 3TH43
Resistance to Shock	AC: 7.75 and 4.4/10 g/ms; DC: 9.3/5 and 5.4/10 g/ms
(Rectangular Flts)	
Rated currents	18A
at U_n	4/A-12 (AC-1); 4/A-15/AC-14 (AC-11); 120/230/220V 10A
Current Paths in Series	1
at U_n	24V 10A; 48V 10A; 110V 2.7A; 220V 0.8A; 440V 0.6A; 600V 0.5A
at U_n	24V 10A; 48V 5A; 110V 0.9A; 220V 0.45A; 440V 0.25A; 600V 0.2A
4/DC-12 (DC-1)	
4/DC-13 (DC-11)	

When 3TH AC-operated control relays are mounted in rows, the minimum gap between them must be 0.19 (5) when the voltage is likely to reach $1.1 \times U_n$ and the ambient temperature $\geq 45^\circ\text{C}$ and the duty factor of all relays is 100%.

Type	3TH40, 3TH42, 3TH43
Switching Frequency 2 in make/break operations per hour at rated operation for duty	AC-12: 1,000/h; AC-2: 500/h; AC-3: 1,000/h; AC-15/AC-14: 3,600/h; DC-13: 10,000/h
Conductor Sizes	Terminal Wire Size: AWG(2) #18-12
Rated Control Supply Voltage	AC: Max 800V; DC: Max 230V
Rated Voltage	AC 600V, DC 600V
Making and Breaking Capacity	A800, P600
Continuous Current Rating	10A

Control Relays

3TH4 Fixed Contacts Type

Page 387

Control Relays

3TH44 Mechanically Latched Type

Design and Mode of Operation

3TH44 mechanical latch relays latch upon closing. The contacts open either electrically by energizing the release coil or manually, by moving the release switch.

The release coil must not be energized continuously.

A PTC thermistor is connected in series with the tripping solenoid in order to prevent damage to the coil in the event of simultaneous maintained-contact signals being applied. The maximum delay before resetting after the thermistor has operated by double command is 5 minutes.

Specifications

3TH44 mechanical latch relays are suitable for use in industrial environments. They meet or exceed the requirements of NEMA, UL, CSA, IEC, VDE and other international standards.

Contacts

The contacts are not replaceable.

Coils


The main coil of the control relays, with mechanical latch, is replaceable. The release coil is not replaceable. The voltage of the tripping coil will be found under the marking tag.

ⓄAny technical data not given here is identical to that of the 3TH43 relays.

Technical Data[Ⓞ]

Mechanical Life	10 Million Make/Break Operations	
Coil Ratings		
AC Operation up to 240V	Inrush Release coil	77VA, p.f. = 0.81 (Contactor Coil) 110VA, p.f. = 0.86 (Unlatching Coil)
DC Operation up to 230V	Inrush Release coil	6.5W (Contactor Coil) 130W (Unlatching Coil)
Control Signal Duration	Minimum	
AC Operation	Closing Opening	40 ms 30 ms
DC Operation	Closing Opening	170 ms 30 ms
Rated Operational Current at Rated Voltage	Volts AC/DC	Amps
AC-15/AC-14 (AC-11)	230/220V 380/400V 500V 660V/690V	10 A 6 A 4 A 2 A

Permitted Mounting Positions



ⓄFor internal connection diagrams and schematic diagrams see page 616.


Dedication Test Plan – IST
 Test Plan No.: CGI-SNF-D-MHM-023-TP-023B
 Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: TPXM

ORIGINAL

Rev. No. 0

Page 1 of 8

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI. Eng	DA	QA Post Review*
						 3/16/00 NO CAPMB8

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023B

Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: TPXM

Page 2 of 8

ORIGINAL

In-Situ Test Procedure

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) JWP Larry W. Price Date: 3/16/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	Michael Cram	MRC
Electrician	DAN K. YORK	P.C.E	Dan K. York	D.Y
Electrician Quality Control	Stephen R Conley	PCE	Stephen R Conley	SRC
Design Authority Representative	LARRY W. PRICE	XWEST	Larry W. Price	JWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current Source capable of 10 amps

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: HP3457A I.D.: BAT 124 Calib. Due date: 07-30-00

Test Instrument type: AUBIM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: PROSD 6106 I.D.: 029E/039 Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023B

Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: TPXM

Page 3 of 8

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TPXM	TPXM	Acc
Manufacturer:	SIEMENS	Siemens	Acc
Model:	3TH4310	3TH4310 (on side of relay)	Acc
Contact Configuration:	OK	10 Normally Open Contacts	Acc
Serial No./Lot No./Date Code:	N/A OK	N/A	Acc
Coil	K6	K6 (near terminal A1)	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-17-00 12:45 p.m.

2.1.1 Complete the Lifted Lead Log prior to lifting leads.

2.1.2 Lift all leads

2.2 Operation

2.2.1 Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	73.655 VAC	96 VAC maximum	Acc
Drop-out Voltage	43.862 VAC	36 AC minimum	Acc

2.2.2 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023B

Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: TPXM

Page 4 of 8

2.3 Insulation Resistance Test

1 Setup the test equipment and relay specimen for insulation resistance testing.

2.3.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Record data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
13	Ground	> 100 Gohm	> 10 Megohms	Acc
14	Ground	> 100 Gohm	> 10 Megohms	Acc
23	Ground	> 100 Gohm	> 10 Megohms	Acc
24	Ground	> 100 Gohm	> 10 Megohms	Acc
33	Ground	> 100 Gohm	> 10 Megohms	Acc
34	Ground	> 100 Gohm	> 10 Megohms	Acc
43	Ground	> 100 Gohm	> 10 Megohms	Acc
44	Ground	> 100 Gohm	> 10 Megohms	Acc
53	Ground	> 100 Gohm	> 10 Megohms	Acc
54	Ground	> 100 Gohm	> 10 Megohms	Acc
63	Ground	> 100 Gohm	> 10 Megohms	Acc
64	Ground	> 100 Gohm	> 10 Megohms	Acc
73	Ground	> 100 Gohm	> 10 Megohms	Acc
74	Ground	> 100 Gohm	> 10 Megohms	Acc
83	Ground	> 100 Gohm	> 10 Megohms	Acc
84	Ground	> 100 Gohm	> 10 Megohms	Acc
93	Ground	> 100 Gohm	> 10 Megohms	Acc
94	Ground	> 100 Gohm	> 10 Megohms	Acc
03	Ground	> 100 Gohm	> 10 Megohms	Acc
04	Ground	> 100 Gohm	> 10 Megohms	Acc
A1 or A2 (coil)	Ground	> 100 Gohm	> 10 Megohms	Acc
13	14	> 100 Gohm	> 10 Megohms	Acc
23	24	> 100 Gohm	> 10 Megohms	Acc
33	34	> 100 Gohm	> 10 Megohms	Acc
43	44	> 100 Gohm	> 10 Megohms	Acc
53	54	> 100 Gohm	> 10 Megohms	Acc
63	64	> 100 Gohm	> 10 Megohms	Acc
73	74	> 100 Gohm	> 10 Megohms	Acc
83	84	> 100 Gohm	> 10 Megohms	Acc
93	94	> 100 Gohm	> 10 Megohms	Acc
03	04	> 100 Gohm	> 10 Megohms	Acc

2.4 Contact Rating Test

2.4.1 Setup the test equipment and relay specimen for contact rating testing.

2.4.2 Manually adjust the relay or apply 120 VAC to the coil to close the normally open contacts

2.4.3 Apply a nominal 10 amps, resistive, across closed normally open contacts of the test specimen

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023B

Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: TPXM

Page 5 of 8

Caution: Do not change state of contacts while energized.

2.4.5 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contacts 13-14	.0710 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 23-24	.0899 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 33-34	.0953 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 43-44	.1114 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 53-54	.0617 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 63-64	.0641 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 73-74	.0687 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 83-84	.0731 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 93-94	.0743 VAC	< 0.5 ± 10% Volts AC drop	Acc
Contacts 03-04	.0849 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.6 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.5.2 Retorque the terminals to 12 in-pounds.

2.5.3 Record: Date /Time of Test End: 03-17-00 1:00 P.M.

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 4

3.2 X Channel Main Power Panel Wiring Diagram: ED-33065 Sheet 1

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

*Acceptance Criteria has been met**Michael Gram**03-17-00*

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023B

Test Specimen: Siemens 3TH4310-0AK6, Eqmt. No.: TPXM

Page 6 of 8

Notes:

Certified Instrumentation Technician (signature) Michael O'Connell Date: 03-17-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied

Design Authority (signature) JWP Craig Swenson Date: 3/20/00

QA/QC (signature) Stephen Scott Mohr Date: 3-22-2000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
		6002X	TPXM	63	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		2) 6001X		64	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		2) 5100X		73	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		5104X		74	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		2) 5702X		83	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		2) 5701X		84	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		5713X		93	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		2) 5710X		94	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		2) 101X		23	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		2) 101X		33	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		1) 101X		43	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		2) 101X		53	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		404X		A-1	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
		Black	KS2A-6	A-1	D.Y	3-17-00	SRC	3-17-00	D.Y	3-17-00	SRC	3-17-00
					RE							

Remarks:


SNF-6315, Rev. 0

Page 397

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date	Remarks:
		2) 4004X	TPXM	24	O.Y	3-17-00	SJC	3-17-00	O.Y	3-17-00	SJC	3-17-00	
		5142X		34	O.Y	3-17-00	SJC	3-17-00	O.Y	3-17-00	SJC	3-17-00	
		715X		44	O.Y	3-17-00	SJC	3-17-00	O.Y	3-17-00	SJC	3-17-00	
		56A11X		54	O.Y	3-17-00	SJC	3-17-00	O.Y	3-17-00	SJC	3-17-00	
		102X		A-2	O.Y	3-17-00	SJC	3-17-00	O.Y	3-17-00	SJC	3-17-00	
		6500	RCS2A-6	A-2	O.Y	3-17-00	SJC	3-17-00	O.Y	3-17-00	SJC	3-17-00	

LIFTED LEAD LOG

SNF-6315, Rev. 0



MCC#15

HANFORD DWG # H-2-826710 SHT 9 OF 97


LTR	DESCRIPTION	DATE	BY	CHK	ENG	APPO	APPO	DRWN	J.B. RUTY	DATE
D	GENERAL REVISIONS	7/23/97	JBR	JMH	TMM	JMH		DRN	J.B. RUTY	7/23/97
E	MODIFY SELECTOR SWITCH	8/15/97	JRS	AI	TMM	JMH	LLA	DRN	J.B. RUTY	8/15/97
F	MODIFY LOCATION ADDRESS; ADD PUSH-TO-TEST	9/4/97	JBR	JMH	TMM	JMH	EV	DRN	J.B. RUTY	9/4/97
G	MODIFY LOCATORS	10/23/97	JRS	TMM	TMM	JMH	EV	DRN	J.B. RUTY	10/23/97
H	DE-INERTING & SIMPLIFICATION	3/9/98	CSU	SED	CSU			DRN	J.B. RUTY	3/9/98
J	GENERAL REVISION	7/20/98	CSU	SED	CSU			DRN	J.B. RUTY	7/20/98
K	REVISED PER INSTALLATION MARK-UPS	3/5/99	CSU	H.R.Z.	CSU			DRN	J.B. RUTY	3/5/99

COOPER
 INSTRUMENTS
 MODE SELECTOR SWITCH CONTROL ELEMENTARY
 EB-33056
 SCALE: N/A
 SHEET 4 OF 5
 REV. 5


Control Relays

Selection

3TH4 Fixed Contacts Type



3TH4040-0AK6



3TH4022-0BB4

Ordering Instructions

- ▶ Determine the number of contacts, AC or DC, then select Catalog Number.
- ▶ Complete Catalog Number by adding Coil suffix from table below e.g.

3TH40 2 2 0 A K6

Relay Type ———
 2 NO ———
 2 NC ———
 Terminals ———
 AC ———
 Coil ———
 Voltage 120V AC

Additional References

- ▶ Technical Data see page 614.
- ▶ Dimensions see page 617.
- Wiring Diagrams see page 616.
- ▶ Accessories, Varistors, RC Elements and Suppressors see page 613.
- ▶ Replacement Parts see page 923.

Relays With Screw Terminals for DIN Rail and Screw Mounting

AC Operation							
No of Contacts	Code	Contact Type		Early Make		Catalog No (Coil Suffix required from table below)	Price \$
		NO	NC	NO	NC		
Relay With 4 Fixed Contacts							
4	40E	4	—	—	—	3TH4040-0A††	72.
	31E	3	1	—	—	3TH4031-0A††	72.
	22E	2	2	—	—	3TH4022-0A††	72.
	13E	1	3	—	—	3TH4013-0A††	72.
	04E	—	4	—	—	3TH4004-0A††	72.
Relay With 4 Contacts, Early Make/Late Break							
	31E, U	2	—	1	1	3TH4095-0A††	69.
	22E, U	1	1	1	1	3TH4096-0A††	102.
	22E, 2U	—	—	2	2	3TH4092-0A††	132.
Relay With 8 Fixed Contacts							
8	80E	8	—	—	—	3TH4280-0A††	120.
	71E	7	1	—	—	3TH4271-0A††	120.
	62E	6	2	—	—	3TH4262-0A††	120.
	53E	5	3	—	—	3TH4253-0A††	120.
	44E	4	4	—	—	3TH4244-0A††	120.
Relay With 8 Contacts, Early Make/Late Break							
	44E, U	3	3	1	1	3TH4293-0A††	150.
Relay With 10 Fixed Contacts							
10	100E	10	—	—	—	3TH4310-0A††	144.
	91E	9	1	—	—	3TH4391-0A††	144.
	82E	8	2	—	—	3TH4382-0A††	144.
	73E	7	3	—	—	3TH4373-0A††	144.
	64E	6	4	—	—	3TH4364-0A††	144.
	55E	5	5	—	—	3TH4355-0A††	144.
Relay With 10 Contacts With Early Make/Late Break							
	55E, U	4	4	1	1	3TH4394-0A††	174.
Mechanically Latched Relay With 9 Contacts							
9	54	5	4	—	—	3TH4454-0A††	201.

DC Operation							
No of Contacts	Code	Contact Type		Early Make		Catalog No (Coil Suffix required from table below)	Price \$
		NO	NC	NO	NC		
Relay With 4 Fixed Contacts							
4	40E	4	—	—	—	3TH4040-0B††	117.
	31E	3	1	—	—	3TH4031-0B††	117.
	22E	2	2	—	—	3TH4022-0B††	117.
	13E	1	3	—	—	3TH4013-0B††	117.
	04E	—	4	—	—	3TH4004-0B††	117.
Relay With 4 Contacts, Early Make/Late Break							
	31E, U	2	—	1	1	3TH4095-0B††	147.
	22E, U	1	1	1	1	3TH4096-0B††	147.
	22E, 2U	—	—	2	2	3TH4092-0B††	177.
Relay With 8 Fixed Contacts							
8	80E	8	—	—	—	3TH4280-0B††	162.
	71E	7	1	—	—	3TH4271-0B††	162.
	62E	6	2	—	—	3TH4262-0B††	162.
	53E	5	3	—	—	3TH4253-0B††	162.
	44E	4	4	—	—	3TH4244-0B††	162.
Relay With 8 Contacts, Early Make/Late Break							
	44E, U	3	3	1	1	3TH4293-0B††	192.
Relay With 10 Fixed Contacts							
10	100E	10	—	—	—	3TH4310-0B††	186.
	91E	9	1	—	—	3TH4391-0B††	186.
	82E	8	2	—	—	3TH4382-0B††	186.
	73E	7	3	—	—	3TH4373-0B††	186.
	64E	6	4	—	—	3TH4364-0B††	186.
	55E	5	5	—	—	3TH4355-0B††	186.
Relay With 10 Contacts With Early Make/Late Break							
	55E, U	4	4	1	1	3TH4394-0B††	216.
Mechanically Latched Relay With 9 Contacts							
9	54	5	4	—	—	3TH4454-0B††	231.

Coil Suffix

AC Volts 50/60Hz							
24	110/120	175/208	220/277	208	220/240	380/460	500/600
C2	K6	M1	U1	M2	P6	Q0	SC

For other Coil Voltages see page 911.

Coil Suffix

DC Volts				
12	24	48	125	240
A4	B4	W4	G4	Q4

10

Logic Control

612

Discount Schedule AC-10 (CMKT)


Siemens & Furnas Control Products

Control Relays


3TH4 Fixed Contacts Type

Terminal Designations According to DIN EN 50011


3TH40, AC and DC Operation




3TH42, AC and DC Operation




3TH43, AC and DC Operation



3TH44, Internal Connection Diagram, AC and DC Operation



3TH44, Schematic Diagrams, AC and DC Operation



Do not operate S2 while S1 is closed.

10

616

Control Relays

Technical

3TH4 Fixed Contacts Type

Type	3TH40, 3TH42, 3TH43	
Mechanical Life	30 Million Operations	
Permissible Ambient Temperature Range	-25 to +55°C	
Coil Ratings	[Cold Coil and 1.0 × U _s]	
AC Operation	60Hz 50Hz	
	Inrush	75 VA 68 VA
	p f	0.76 0.82
	Sealed p f	9.4 VA 10 VA
DC Operation	Inrush =	6.2 W
	Sealed	
Coil Voltage Tolerances		
AC	0.8 to 1.1 × U _s	
DC (except 24V)	0.8 to 1.1 × U _s	
DC 24V	0.8 to 1.2 × U _s	
Operation Times	0.80 to	
Total Break Time =	1.1 × U _s , 1.0 × U _s	
Opening Delay + Arcing Time		
AC Closing Delay	NO	8-35 ms 10-25 ms
	NC	6-20 ms 7-20 ms
Operation Opening Delay	NO	4-18 ms 5-18 ms
	NC	5-30 ms 7-20 ms
Arcing Time	10 ms	

Type	3TH40, 3TH42, 3TH43		
Resistance to Shock (Rectangular Plus)	AC	7.7/5 and 4.4/10 g/ms	
	DC	9.3/5 and 5.4/10 g/ms	
Rated currents at U _s	4/AC-12 (AC-1)	16A	
	4/AC-15/AC-14 (AC-11)	120/230/220V 10A	
		400/380V	6A
		500V	4A
	650/660V	2A	
4/DC-12 (DC-1) at U _s	Current Paths in Series		
		1	3
4/DC-13 (DC-11) U _s	24V	10A	10A
	48V	10A	10A
	110V	2.1A	10A
	220V	0.8A	10A
	440V	0.6A	1.3A
	600V	0.6A	1A
	24V	10A	10A
	48V	5A	10A
110V	0.9A	10A	
220V	0.45A	2A	
440V	0.25A	0.9A	
600V	0.2A	0.8A	

Type	3TH40, 3TH42, 3TH43	
Switching Frequency z in make/break operations per hour at rated operation for duty	AC-12	1,000/h
	AC-2	500/h
	AC-3	1,000/h
	AC-15/AC-14 resp	
	DC-13	3,600/h
No-load switching frequency	10,000/h	
Conductor Sizes		
Terminal Wire Size	AWG(2) #16-12	
UL ratings		
Rated Control Supply Voltage	AC	Max 600V
	DC	Max 230V
Rated Voltage	AC 600V, DC 600V	
Making and Breaking Capacity	A600, P600	
Continuous Current Rating	10A	


Permitted Mounting Positions

The relation between the permitted inclination to the mounting surface to the vertical and the coil voltage tolerance is as follows:

Permitted inclination (α) of the mounting surface to the vertical	Coil voltage tolerance	
	min × U _s	max × U _s
-22.5 to +202.5°	0.8 to	1.1
-50 to +230°	0.85 to	1.1
any	0.9 to	1.1


Mounting

For snap-on and screw mounting, snapping onto 35 mm standard mounting rail in accordance with DIN EN 50 022.




The AC operated relays preferably should be mounted on a vertical surface in any desired position.

When 3TH AC-operated control relays are mounted in rows, the minimum gap between them must be 0.19 (5) when the voltage is likely to reach 1.1 × U_s, the ambient temperature ≥45°C and the duty factor of all relays is 100%.



The DC operated relays preferably should be mounted on a vertical surface in the position as shown in the drawing.

Contact Life Curve



10 Logic Control

614

3TH44 Mechanically Latched Type

Design and Mode of Operation

3TH44 mechanical latch relays latch upon closing. The contacts open either electrically by energizing the release coil or manually, by moving the release switch.

The release coil must not be energized continuously.

A PTC thermistor is connected in series with the tripping solenoid in order to prevent damage to the coil in the event of simultaneous maintained-contact signals being applied. The maximum delay before resetting after the thermistor has operated by double command is 5 minutes.

Specifications

3TH44 mechanical latch relays are suitable for use in industrial environments. They meet or exceed the requirements of NEMA, UL, CSA, IEC, VDE and other international standards.

Contacts

The contacts are not replaceable.

Coils


The main coil of the control relays, with mechanical latch, is replaceable. The release coil is not replaceable. The voltage of the tripping coil will be found under the marking tag.

ⓄAny technical data not given here is identical to that of the 3TH43 relays.

Technical Data^{ⓄⓄ}

Mechanical Life	10 Million Make/Break Operations	
Coil Ratings		
AC Operation up to 240V	Inrush Release coil	77VA, p.f. = 0.81 (Contactor Coil) 110VA, p.f. = 0.86 (Unlatching Coil)
DC Operation up to 230V	Inrush Release coil	6.5W (Contactor Coil) 130W (Unlatching Coil)
Control Signal Duration	Minimum	
AC Operation	Closing Opening	40 ms 30 ms
DC Operation	Closing Opening	170 ms 30 ms
Rated Operational Current at Rated Voltage	Volts AC/DC	Amps
AC-15/AC-14 (AC-11)	230/220V	10 A
	380/400V	6 A
	500V	4 A
	660V/690V	2 A

Permitted Mounting Positions



The relays must be mounted on a vertical surface in the position shown in the dimension drawings.

ⓄFor internal connection diagrams and schematic diagrams see page 615.

Dedication Test Plan – IST
 Test Plan No.: CGI-SNF-D-MHM-023-TP-023C
 Test Specimen: Siemens 3TF4310-0AK6, Eqmt. No.:MCO

ORIGINAL

Rev. No. 0

Page 1 of 4

In-Situ Inspection Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI. Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023C

Test Specimen: Siemens 3TF4310-0AK6, Eqmt. No.:MCO

Page 2 of 4

ORIGINAL

In-Situ Inspection Procedure**Inspection Procedure Approval (Obtain prior to inspection):**

This procedure documents the visual verification of the identification critical characteristics of the remaining specimen which were in-situ tested on a sampling basis as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *Larry W. Price* Date: 4-6-00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Electrician	N/A	N/A	N/A	N/A
Electrician Quality Control	N/A	N/A	N/A	N/A
Design Authority Representative	LARRY W. PRICE	KWEST	<i>Larry W. Price</i>	<i>LWP</i>

SAFETY INSTRUCTIONS: PERSONNEL SAFETY - personnel shall exercise caution around energized electrical equipment.

INSPECTION PROCEDURE:**1.0 Record the following Test Specimen identification information:**

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MCO	MCO	
Manufacturer:	SIEMENS <i>JWP</i>	Siemens	
Model:	3TH43 3TH43	3TR43 <i>JWP</i>	
Contact Configuration:	3P MC & 10NO	3 pole Main Contacts and 10 NO auxiliary contacts	100E
Serial No./Lot No./Date Code:	6/9722	N/A	
Coil:	K6	K6	

2.0 Record:

Date /Time of Test Beginning:

4/7/00 8:14 AM

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023C

Test Specimen: Siemens 3TF4310-0AK6, Eqmt. No.: MCO

Page 3 of 4

2.1 Record: Date /Time of Test End: 4/7/00 8:15AM

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 4


Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

ACCEPTANCE CRITERIA MET

Notes:

NA

Design Authority Representative (signature)



Date:

4/7/00

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-023-TP-023C

Test Specimen: Siemens 3TF4310-0AK6, Eqmt. No.:MCO

Page 4 of 4

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.


Design Authority (signature)



Date:

4-7-00

QA/QC (signature)



Date:

4-7-2000

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 1 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-022
Title P2 & P61 - Honeywell Limit Switch LSYAC3K

Section 1 Part Information

Item No.: N/A	Manufacturer: N/A	Supplier: N/A
Mfg. Part/Model No.: N/A	Supplier's P/N: N/A	
Part Description: N/A		ORIGINAL
End Use Description: N/A		

Section 2a Component Information

Equipment No.: LFMJLY	Specification No.: Ederer F-2566, Foster Wheeler MJX-SDX 452656	Manufacturer: Honeywell	Past P.O. No.: N/A
Manufacturer's Part/Model No.: LSYAC3K	Equipment Supplier (if different from manufacturer): ALSTOM, Foster Wheeler	Equip. Supplier's Part No.: N/A	

Component Description: Limit Switch for Interlock P2 & P61, LFMJLY limit switch is located on the MCO grapple assembly. When the MCO Grapple Jaws become locked, the limit switches senses position of the locking ring, is actuated and indicates MCO GRAPPLE JAWS LOCKED and prevents raising a load, when the jaws are not locked. It also indicates MCO GRAPPLE JAWS NOT LOCKED.

Section 2b Commercial Availability of the Item

- Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
 YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
 If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate with project CGI Interface Engineer or BTR)
 YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)
- List of Candidate qualified NQA1 suppliers or ISO 9000 suppliers, if used: N/A
- Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)

All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 2 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-022
Title P2 & P61 - Honeywell Limit Switch LSYAC3K

Section 2d Reason for Dedication

The above Commercial Grade (CG) described Item is being Dedicated for use in the application cited for the following reason(s):

<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input checked="" type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application. (Controller) <i>JW CES 4/14/00</i>
<input type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. **These limit switches sense the position of the jaws locking ring and are actuated when the MCO Grapple Jaws are locked. Interlock P2 inhibits Bridge operation, Trolley operation, and shield skirt jack raising. Interlock P61 automatically stops the MCO hoist from raising when loaded when the Grapple Jaws are not locked.**

B. Part/Component Functional Mode:

Safety Function #1: <input checked="" type="checkbox"/> Active [] Passive	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function Passive - Change of state is not required for the component to perform its safety function
Safety Function #2: [] Active [] Passive	
Safety Function #3: [] Active [] Passive	

C. Host Component Safety Function (if applicable): N/A

1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

1. **Failure of switch contacts to open upon demand results in potential override of interlock channel.**

2. **Plunger/arm inoperative results in failure to provide interlock function at correct demand position.**

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required: Yes [] No <input checked="" type="checkbox"/>	If yes: Environmental Qualification Requirements Limiting Environmental Conditions: Required Safety Functions: Qualification Period:
Natural Phenomena Hazard (NPH) Design Required: Yes [] No <input checked="" type="checkbox"/>	If yes: NPH Design Requirements Performance Category: NPH Design Req'ts.: Required Safety Functions:

Section 5 Component Functional Classification

<input checked="" type="checkbox"/> Safety Class (SC)	<input type="checkbox"/> General Service (GS)	<input type="checkbox"/> Safety Significant (SS)
---	---	--

If part/component classification is different from host component/system, document basis. N/A

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: N/A
 Safety Analysis Report (SAR): HNF-3672, Rev. 0
 Drawings: Ederer, Inc. EB-33056, Sheet 13B
 Vendor Manual/Manufacturer/Supplier Information: Honeywell Series LS heavy duty rotary actuated limit switch
 Other: ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 3 of 8

SNF-6315, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-022
Title P2 & P61 - Honeywell Limit Switch LSYAC3K

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Honeywell	1, IN	X	
Model Number	LSYAC3K	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Actuator (Note 1)	Standard Side Rotary	1, IN	X	
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Contact Rating	Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts	1, T		X
Insulation Resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v.	1, T		X
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring.	1, T		X
4. Notes and Legend:		Acceptance Method (Acc Meth):		
Rev. 1: Page 7: added data to "Method T/IN" Column; General: new forms		1. Special Test and Inspection		
Rev. 2: Pages 3, 5, 7: added Note 1		1, IN for Inspection		
Note 1: This actuator is installed with the limit switch - replacement limit switches will not include an actuator - the existing actuator will be placed on the replacement switch. Therefore, the physical CC specified for the actuator lever need not be performed on the replacement limit switch.		1, T for Test		
Rev. 3: Pages 3, 6 & 7: Rev'd Contact Rating Criteria to "Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts" from 10 amps for prevention of equipment damage due to excessive current; Pages 1, 2 & 5: Rev'd equipment ID Nos., and the component description per SEL changes.		2. Commercial Grade Survey		
		3. Source Verification		
		4. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:
 Designated Engineer: [Signature]
 Design Authority: [Signature] 3/29/00
 QA Engineer: [Signature] 3-30-2000

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 4 of 8

SNF-6315, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-022
Title P2 & P61 - Honeywell Limit Switch LSYAC3K

WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	X	Switch contacts corrode closed and fail to open upon demand.
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Switch contacts fuse closed and fail to open upon demand.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Switch mechanism jams and contacts fail to open upon demand.
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
1. Switch contacts are closed to permit equipment movement. Contacts open for the interlock function. Any failure which prevents contacts to open inhibits the particular switch interlock function.			
2. Actuator plunger/arm seizure or break renders the contact opening inoperable.			
3. Short circuit could give false signal to energize interlock function.			
4.			
5.			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

Page 412

ECN No. **N/A**

CGI No. **CGI-SNF-D-MHM-022**

Page 5 of 8

Title **P2 & P61 - Honeywell Limit Switch LSYAC3K**

SNF-6315, Rev. 0

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1	
Item Description: P-61 interlock limit switch	Equip #: LFMJLX; LFMJLY
System #: MHM	Model #: LSYAC3K
Manufacturer (Address/Phone): Honeywell 1-800-537-6945 P.O. #	Supplier (Address/Phone):

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Model Number
X			3. Actuator (Note 1)
	X		4. Contact Rating
	X		5. Insulation Resistance
	X		6. Mechanical Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic: Manufacturer	Sample Size*: 100%
Acceptance Criteria: Honeywell	
Receipt Inspection Plan / Report #: CGI-SNF-D-MHM-022-TP-022B	
Characteristic: Model Number	Sample Size*: 100%
Acceptance Criteria: LSYAC3K	
Receipt Inspection Plan / Report #: TP-022B	
Characteristic: Actuator (Note 1)	Sample Size*: 100%
Acceptance Criteria: Standard Side Rotary	
Receipt Inspection Plan / Report #: TP-022B	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A CGI No. CGI-SNF-D-MHM-022

Page 6 of 8

Title **P2 & P61 - Honeywell Limit Switch LSYAC3K**

SNF-6315, Rev. 0

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk instruction for Sampling Size; References (See Section 7)

Characteristic for Test: **Contact Rating** Samp Size*: Normal Reduced Tightened

Acceptance Criteria: **Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts**

Actual Test Value: See TP Test Plan and Report #: TP-022B

Characteristic for Test: **Insulation Resistance** Samp Size*: Normal Reduced Tightened

Acceptance Criteria: **Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v.**

Actual Test Value: See TP Test Plan and Report #: TP-022B

Characteristic for Test: **Mechanical Operation** Samp Size*: Normal Reduced Tightened

Acceptance Criteria: **Cycle switch - confirm contacts open and close with smooth operation and free release of spring**

Actual Test Value: See TP Test Plan and Report #: TP-022B

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A

CGI No. CGI-SNF-D-MHM-022

Page 7 of 8

Title: P2 & P61 - Honeywell Limit Switch LSYAC3K

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Limit Switch

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-ist ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Honeywell	X		1, IN	TP-022B	NA	1	0	XWEST	<i>Gregory W. Price</i>	4/10/00
Model Number	LSYAC3K	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Actuator (Note 1)	Standard Side Rotary	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Contact Rating	Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts.		X	1, T	↓	↓	↓	↓	↓	↓	↓
Insulation Resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v.		X	1, T	↓	↓	↓	↓	↓	↓	↓
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-022B cited above. CES 4/11/00

Testing Agency Approval: <u>NR CES 4/11/00</u>	Date: _____	Design Authority: <u><i>Gregory W. Price</i></u>	Date: <u>4-11-00</u>
Testing Agency QA Engineer: <u>NR CES 4/11/00</u>	Date: _____	QA Engineer: <u><i>Stephen Scott Moran</i></u>	Date: <u>4-20-2000</u>

SNF-6315, Rev. 0

Page 4/4

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 8 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-022
Title P2 & P61 - Honeywell Limit Switch LSYAC3K

Section 6 Contacts/Phone Numbers

Name	Phone
Design Authority <u>CRAIG SWENSON</u>	() <u>376-0288</u>
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents	For Critical Characteristics
<input type="checkbox"/> Drawings:	
<input type="checkbox"/> Manuals (specify type & number):	
<input type="checkbox"/> Design Calculation	
<input type="checkbox"/> Installation Instructions	
<input type="checkbox"/> Operation Instructions	
<input type="checkbox"/> Calibration Instructions	
<input type="checkbox"/> Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/> Other: <u>Honeywell Series LS heavy duty rotary actuated limit switch</u>	<u>All</u>
Procurement Documents	For Critical Characteristics
<input type="checkbox"/> Certificate of Conformance/Compliance	
<input type="checkbox"/> Seismic Qualification Certificate	
<input type="checkbox"/> Environmental Qualification Certificate	
<input type="checkbox"/> Test Report (s):	
<input type="checkbox"/> Inspection Report (s):	
<input type="checkbox"/> CMTRs for ASME Pressure Retaining Materials	
<input type="checkbox"/> Valve Seat Leakage Report	
<input type="checkbox"/> Weld Records	
<input type="checkbox"/> Material Traceability Record	
<input checked="" type="checkbox"/> Other: <u>Component Test Package CSB(W379)-015-11-1042</u>	

ORIGINAL

Dedication Test Plan - IST-LS-1
 Test Plan No.: CGI-SNF-D-MHM-022-TP-022B
 Test Specimen: Honeywell LSYAC3K Limit Switch, Eqmt. No.: LFMJLY

Rev. No. 1
 Page 1 of 7

SNF-6315, Rev. 0

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
1	Avoid equipment damage	3.4.3 3.4.10	Lower current from 10 amps to 5 amps		UES 3/29/00	SSW 4-3-2000

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST-LS-1
Test Plan No.: CGI-SNF-D-MHM-022-TP-022B
Test Specimen: Honeywell LSYAC3K Limit Switch, Eqmt. No.: LFMJLY

ORIGINAL

Rev. No. 1

Page 2 of 7

SNF-6315, Rev. 0

In-Situ Test Procedure

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *[Signature]* Craig Swanson Date: 3/28/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>[Signature]</i>	MRC
Electrician	DAN K. YORK	P.C.E	<i>[Signature]</i>	D.K.Y
Electrician Quality Control	Stephen R. Conley	PCE	<i>[Signature]</i>	SRC
Design Authority Representative	<i>[Signature]</i>	XWEST	<i>[Signature]</i>	<i>[Signature]</i>
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A
Design Authority	Craig Swanson	PHH	<i>[Signature]</i>	CS

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC
Megger Instrument capable of 1000 VDC Test Voltage
MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type:	<u>FLOKE 757</u>	I.D.:	<u>107</u>	Calib. Due date:	<u>05-23-00</u>
Test Instrument type:	<u>HA C BM3012</u>	I.D.:	<u>6410-857</u>	Calib. Due date:	<u>02-09-01</u>
Test Instrument type:	<u>HP 3457A</u>	I.D.:	<u>BAT123</u>	Calib. Due date:	<u>07-29-00</u>
Test Instrument type:	_____	I.D.:	_____	Calib. Due date:	_____
Test Instrument type:	_____	I.D.:	_____	Calib. Due date:	_____

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-022-TP-022B

Test Specimen: Honeywell LSYAC3K Limit Switch, Eqmt. No.: LFMJLY

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.

2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFMJLY	LFMJLY	Acc
Manufacturer:	HONEYWELL	Honeywell	Acc
Model:	LSYAC3K	LSYAC3K	Acc
Actuator:	OK	Standard Side Rotary	Acc
Serial No./Lot No./Date Code:	N/A	N/A	Acc

3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 05 29-00 9:30 am

3.2 Mechanical Operation

3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	6	> 5 times	Acc
Describe Operation:	SMOOTH	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	FREE	Free release of spring.	Acc

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-022-TP-022B

Test Specimen: Honeywell LSYAC3K Limit Switch, Eqmt. No.: LFMJLY

Page 4 of 7

3.3 Insulation Resistance Test

- 3.3.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing. Remove the amphenol connector at the grapple housing.
- 3.3.2 Apply a nominal 1000 VDC via Megger device between non-continuity terminals on the limit switch side of the amphenol connector nos. 18 and 27 (Common - Across NO Contact) and then between terminal 27 and ground. Record the resistances.
- 3.3.3 Remove the Megger device.
- 3.3.4 Manually adjust the limit switch actuator to open the normally closed (NC) contacts.
- 3.4.5 Apply a nominal 1000 VDC via Megger device between non-continuity terminals on the the limit switch side of the amphenol connector nos. 18 and 26 (Common - Across open NC Contact) and then between terminal 26 and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
18 and 27	Common to NO	> 9.96 Gohm	> 10 Megohms	Acc
27 and Ground	NO to Ground	> 7.26 Gohm	> 10 Megohms	Acc
18 and 26	Common to open NC*	> 8.1 Gohm	> 10 Megohms	Acc
26 and ground	Open NC to Ground*	> 32.5 Gohm	> 10 Megohms	Acc

* Normally closed contacts are open.

- 3.3.6 De-energize and remove the test equipment.

3.4 Contact Rating Test

- 3.4.1 Setup the test equipment and Limit Switch specimen for contact rating testing.
- 3.4.2 At grapple mounted amphenol connector, disconnect the connector and input test leads onto the limit switch side of the connector terminal no. 18 (Common) and terminal 26 (LFMJLY Normally Closed Contact).
- 3.4.3 Apply a nominal ^{5 1/2 329100 CES} 40 amps, resistive, across the normally closed contacts of the test specimen.

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-022-TP-022B

Test Specimen: Honeywell LSYAC3K Limit Switch, Eqmt. No.: LFMJLY

Page 5 of 7

Caution: Do not change state of contacts while energized.

3.4.4 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit 18 and 26 (Terminals COM-NC)	. 463 VAC	< 0.5 Volts AC drop	Acc

3.4.6 Reduce the current source to zero amps.

3.4.7 Disconnect the power supply from terminals 18 and 26.

3.4.8 Manually adjust the limit switch actuator to close the normally open contacts.

3.4.9 Connect the power supply to terminals 18 and 27.

3.4.10 Apply a nominal ~~10~~ ^{5 amp 3/29/00 CB} amps, resistive, across the closed normally open contacts of the test specimen.

3.4.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit 18 and 27 (Terminals COM- Closed NO Contact):	. 474 VAC	< 0.5 Volts AC drop	Acc

3.4.12 Reduce the current source to zero amps and remove the power supply from terminals 18 and 27.

3.4.13 Manually adjust the limit switch actuator to close the normally closed contacts.

3.5 Terminate the test.

3.5.1 Reconnect the Amphenol connector and tighten hand tight.

3.5.2 Remove lockout/tagout and restore system to normal.

3.5.4 Record: Date /Time of Test End: 03-29-00 10:24 a.m.

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-022-TP-022B

Test Specimen: Honeywell LSYAC3K Limit Switch, Eqmt. No.: LFMJLY

Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met.

Michael O'Casey

03-29-00

Notes:

Certified Instrumentation Technician (signature) Michael O'Casey Date: 03-29-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 3/29/00

QA/QC (signature) [Signature] Date: 3-3-2000

Dedication Test Plan - IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-022-TP-022B

Test Specimen: Honeywell LSYAC3K Limit Switch, Eqmt. No.: LFMJLY

Page 7 of 7

LIFTED LEAD LOG

Junction Box: Grapple Amphenol Connector

Drawing #	Sheet #	Wire #	Device #	Amphenol Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	11	N/A	LFMJLY	Connector	DKY	3-29-00	SRL	3-29-00	DKY	3-29-00	SRL	3-29-00

Remarks:

SNF-6315, Rev. 0


Page 422

Limit and Enclosed Switches

Rotary Actuated Switches

SNF-6315, Rev. 0

HDSL Series *Page 423*



Order guides below and on page A35 provide specification and pricing information for side and top rotary switches.

Plug-in body style catalog listings consist of the complete plug-in base receptacle. Levers are ordered separately. See pages A37-A39 for lever selection.

For rapid response - off the shelf service, all bold face listings are normally stocked items.

For low temperature, high temperature or preleading see page A42.

ASSEMBLED CONDITIONS

Catalog listings in order guide below are factory assembled with:

- Shaft of side rotary heads facing front of switch (label side).
- Head adjusted for both clockwise and counterclockwise operation.
- Light on indicator versions wired to N.O. circuit.

Refer to facing page to specify modifications to these assembled conditions.

PRELEADED OR CONNECTORIZED VERSIONS

Refer to page A42.

Limit/Enclosed

ORDER GUIDE (Momentary action. UL listed, CSA certified, CE approved. Levers not included. Order separately pages A37-A39.)

Circuitry	Electrical Rating	Body** Style	Catalog Listings:					Top Rotary High Overtravel
			Standard	Low Differential	5 Pretravel	Low Torque	Low Differential Low Torque	
Silver contacts	A	Plug-in 1/2" Conduit	LSA1A	LSP1A	LSU1A	LSR1A	LSH1A	LSB1A
Gold cross point contacts	C	Plug-in 1/2" Conduit	LSA1J		LSU1J	---	---	LSB1J
Gold plated contacts	C		LSA1E	LSP1E	---	LSR1E	LSH1E	---
 SPDT Double Break	A*	120 V Ind. lite Plug-in* 1/2" Conduit	LSA5A	LSP5A	LSU5A	LSR5A	LSH5A	LSB5A
	A*	240 V Ind. lite Plug-in 1/2" Conduit	LSA8A	LSP8A	LSU8A	LSR8A	LSH8A	LSB8A
	A*	24 V LED lite 1.5mA max. Auto polarity Plug-in 1/2" Conduit	LSA9A	LSP9A	LSU9A	LSR9A	LSH9A	LSB9A
 DPDT Double Break	A	Non plug-in 1/2" Conduit	LSA3K	LSP3K	LSU3K	LSR3K	LSH3K	LSB3K
	B	Plug-in 3/4" Conduit	LSA2B	LSP2B	LSU2B	LSR2B	LSH2B	LSB2B
	B	Plug-in 1/2" Conduit	LSA6B	LSP6B	LSU6B	LSR6B	LSH6B	LSB6B
	B	120 V Ind. lite Plug-in 3/4" Conduit	LSA2R	LSP2R	LSU2R	LSR2R	LSH2R	LSB2R
	B	Non plug-in 3/4" Conduit	LSA4L	LSP4L	LSU4L	LSR4L	LSH4L	LSB4L
 SPNC Direct Acting	D	Non plug-in 1/2" Conduit	LSA7L	LSP7L	LSU7L	LSR7L	LSH7L	LSB7L
		Non plug-in 1/2" Conduit	LSA3N			LSR3N		LSB3N

*Use at voltage indicated for light. Wired to N.O. circuit. Upper temperature limit for lighted units is 200°F (93°C). **Plug-in listings include base receptacle.


OPERATING CHARACTERISTICS

Pretravel (degrees max.)		15	9	5	15	9	25
Differential Travel (degrees max.)	SPDT	5	3	3	5	3	10
	DPDT	7	4	4	7	4	12
Overtravel (degrees min.)		60	66	70	60	66	110
Operating Torque (max.)		0.45 Nm	0.45 Nm	0.45 Nm	0.19 Nm	0.19 Nm	0.28 Nm
	NM = Newton meters	4 in. lbs.	4 in. lbs.	4 in. lbs.	1.7 in. lbs.	1.7 in. lbs.	2.5 in. lbs.
Operating Temperature Range***		10°F to 250°F			30°F to 250°F		
		12° to 121°C			-1° to 121°C		

***Completely fluorocarbon-sealed switches are preferred for use in temperatures above 200°F (93°C). Refer to page A42.

LSYAC3K

FLUORO-CARBON SEALED VERSION OF LSA3K



CONTROLLED COPY
MCC #15

M.H.M. - FC2-087
5-12-99

M.H.M. - FC2-093
5-21-99

M.H.M. - FC2-087
5-12-99

U.S. DEPARTMENT OF ENERGY
WESTINGHOUSE HAWFORD COMPANY
HFC-5-0488

H-2-827169

GEC ALSTROM ENERGENS SYSTEMS LTD
Waltham, Lincoln, UK England

363A0033

WED. INTERCONNECTION DIAGRAM - 384007Y SHEET 4

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR CONSTRUCTION	12/12/98	M.H.M.
2	REVISED		
3	REVISED		
4	REVISED		
5	REVISED		

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR CONSTRUCTION	12/12/98	M.H.M.
2	REVISED		
3	REVISED		
4	REVISED		
5	REVISED		

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR CONSTRUCTION	12/12/98	M.H.M.
2	REVISED		
3	REVISED		
4	REVISED		
5	REVISED		

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR CONSTRUCTION	12/12/98	M.H.M.
2	REVISED		
3	REVISED		
4	REVISED		
5	REVISED		

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR CONSTRUCTION	12/12/98	M.H.M.
2	REVISED		
3	REVISED		
4	REVISED		
5	REVISED		

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR CONSTRUCTION	12/12/98	M.H.M.
2	REVISED		
3	REVISED		
4	REVISED		
5	REVISED		

NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR CONSTRUCTION	12/12/98	M.H.M.
2	REVISED		
3	REVISED		
4	REVISED		
5	REVISED		

12/12/98

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

ECN No. N/A CGI No. CGI-SNF-D-MHM-019
 Title: Various P02,03,05,09,10,21,26,57,61,62,63&99 Interlocks *ES & PS JWP CES 4/14/10*
 -Siemens Contactor #3TF4611-0AK6

Section 1: Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
Part Description: <u>N/A</u>		
ORIGINAL		
End Use Description: <u>N/A</u>		

Section 2a: Component Information

Equipment No.: <u>MHLCX/11/00</u> <u>MHLCX-TLCX-BLCX-ES</u> <u>TLC, BLC ERK</u>	Specification No.: <u>Ederer F-2566, Foster Wheeler MJX-SDX 452656</u>	Manufacturer: <u>Siemens</u>	Past P.O. No.: <u>N/A</u>
Manufacturer's Part/Model No.: <u>3TF4611-0AK6</u>	Equipment Supplier (if different from manufacturer): <u>ALSTROM, Foster Wheeler</u>	Equip. Supplier's Part No.: <u>N/A</u>	

Component Description: 3-Pole contactor with 120 VAC coil with 1 NO and 1 NC auxiliary contacts. Located on the MHM. The 3-pole 480 VAC 3PH/60HZ main contacts are used to provide line power from the circuit breaker to the MCO hoist line motor when the permissive control circuit requirements are met.

Section 2b: Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
 YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
 If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate with project CGI Interface Engineer or BTR)
 YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)

2. List of Candidate qualified NQA1 suppliers or ISO 9000 suppliers, if used: N/A

3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c: CGI Determination

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)

All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

Page 426

SNF-6315, Rev. 0

ECN No. <u>N/A</u> CGI No. <u>CGI-SNF-D-MHM-019</u>	Rev. No. 2
Title: Various <u>P02,03,05,09,10,21,26,57,61,62,63&99 Interlocks</u> -Siemens Contactor #3TF4611-0AK6	Page 2 of 8

Section 2d Reason for Dedication	
The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):	
	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
X	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation	
A. Part/Component Safety Function:	
1. Isolates line power from the MCO Hoist motor when any 1 of 15 permissives are not met.	
1. Part/Component Functional Mode: Safety Function #1: <input checked="" type="checkbox"/> Active <input type="checkbox"/> Passive Safety Function #2: <input type="checkbox"/> Active <input type="checkbox"/> Passive Safety Function #3: <input type="checkbox"/> Active <input type="checkbox"/> Passive	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function Passive - Change of state is not required for the component to perform its safety function
C. Host Component Safety Function (if applicable):	
1. <u>N/A</u>	
D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):	
1. <u>Contact resistance out of spec results in overheating and welding of contacts</u>	
2. <u>Hot short across contacts results in failure to open the circuit</u>	
3. <u>Binding of contacts results in failure to open/close circuit</u>	

Section 4 Environmental & Natural Phenomena Hazard Design	
Environmental Qualification Required: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	If yes: Environmental Qualification Requirements Limiting Environmental Conditions: Required Safety Functions: Qualification Period:
Natural Phenomena Hazard (NPH) Design Required: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	If yes: NPH Design Requirements Performance Category: NPH Design Req'ts.: Required Safety Functions:

Section 5 Component Functional Classification		
X Safety Class (SC)	General Service (GS)	Safety Significant (SS)

If part/component classification is different from host component/system, document basis. N/A

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: N/A
 Safety Analysis Report (SAR): HNF-3672, Rev. 0
 Drawings: Ederer, Inc. EB-33056, Sheets 5, 8, 21, 24, 25A
 Vendor Manual/Manufacturer/Supplier Information: Siemens Industrial Control Products, World Series Contactors, 3TF4 3-Pole with AC coil
 Other: ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998

Commercial Grade Item Upgrade Dedication Form

ECN No. N/A CGI No. CGI-SNF-D-MHM-019
 Title: Various P02,03,05,09,10,21,26,57,61,62,63&99 Interlocks
-Siemens Contactor #3TF4611-0AK6

Rev. No. 2
 Page 3 of 8

Section 9 Critical Characteristics

Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Siemens	1, IN	X	
Model Number	3TF4611-0AK6	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Contact configuration	3 pole NO main contacts, 1 NO & 1 NC Aux Contacts	1, IN	X	
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Current carrying capability	0.5V max. voltage drop across closed contacts at 40 amps VAC resistive on main contacts and 10 amps VAC, resistive on auxilliary contacts	1, T		X
Insulation resistance	10 Megohm min across open contact terminals and terminals to ground (500 VDC megger)	1, T		X
Operation	Contacts open/close at maximum pick-up (102 VAC) and minimum drop-out (36 VAC) voltages	1, T		X
4. Notes and Legend:		Acceptance Method (Acc Meth):		
Rev. 1: Heading: revised interlocks; Page 1 & 3: revised equipment nos.; Page 2: revised drawing sheet nos.; General: new forms Rev. 2: Pages 3, 6, 7: revised Current carrying capability acceptance criteria to "0.5V max. voltage drop across closed contacts at 40 amps VAC resistive on main contacts and 10 amps VAC, resistive on auxilliary contacts"; Pages 3, 6, 7: revised Operation acceptance criteria to "Contacts open/close at maximum pick-up (102 VAC) and minimum drop-out (36 VAC) voltages"		1. Special Test and Inspection: 1, IN for inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 1. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:

Designated Engineer: [Signature]

Design Authority: [Signature] 2/10/00

Quality Assurance: [Signature]
 T. Z. ANDERSON
 2/10/00

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 4 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-019
Title: Various P02,03,05,09,10,21,26,57,61,62,63&99 Interlocks
-Siemens Contactor #3TF4611-0AK6

WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Failure to open the circuit by contact welding or hot short across the contact base.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Results in failure of contacts to open
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2: Additional Failure Modes Applicable to the Component Under Evaluation			

Commercial Grade Item Upgrade Dedication Form		Rev. No. 2
ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-MHM-019</u>	Page 5 of 8
Title: Various <u>P02,03,05,09,10,21,26,57,61,62,63&99 Interlocks</u> -Siemens Contactor #3TF4611-0AK6		

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1	
Item Description: Siemens Contactor System #: MHM	Equip #: MHLC, MHLCX, TLOX, BLCX JLC, BLC Model #: 3TF4611-0AK6 <i>4/11/00</i>
Manufacturer (Address/Phone): Siemens Industrial Control Products 1-800-964-4114	Supplier (Address/Phone): Ederer, Inc.

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

insp	Test	PIT	
X			1. Manufacturer
X			2. Model Number
X			3. Actuator
	X		4. Contact Rating
	X		5. Insulation Resistance
	X		6. Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size, References (See Section 7)

Characteristic: Manufacturer	Sample Size*: 100%
Acceptance Criteria: Siemens	
Receipt Inspection Plan / Report #: CGI-SNF-D-MHM-019-TP-019 A, B, C	
Characteristic: Model Number	Sample Size*: 100%
Acceptance Criteria: 3TF4611-0AK6	
Receipt Inspection Plan / Report #: TP 019 A, B, C	
Characteristic: Contact Configuration	Sample Size*: 100%
Acceptance Criteria: 3 Pole NO Main Contacts and 1 NO & 1 NC auxiliary contacts	
Receipt Inspection Plan / Report #: TP 019 A, B, C	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 6 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-019
 Title: Various P02,03,05,09,10,21,26,57,61,62,63&99 Interlocks
-Siemens Contactor #3TF4611-0AK6

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size, References (See Section 7)

Characteristic for Test: **Current carrying capability** Samp Size*: Normal Reduced Tightened
 Acceptance Criteria: **0.5V max. voltage drop across closed contacts at 40 amps VAC resistive on main contacts and 10 amps VAC, resistive on auxiliary contacts**
 Actual Test Value: TP019 A, B Test Plan and Report #:

Characteristic for Test: **Insulation Resistance** Samp Size*: Normal Reduced Tightened
 Acceptance Criteria: **10 Megohms min across open contact terminals and terminals to ground, with 500 vdc megger.**
 Actual Test Value: TP019 A, B Test Plan and Report #:

Characteristic for Test: **Operation** Samp Size*: Normal Reduced Tightened
 Acceptance Criteria: **Contacts open/close at maximum pick-up (102 VAC) and minimum drop-out (36 VAC) voltages**
 Actual Test Value: TP019 A, B Test Plan and Report #:

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A CGI No. CGI-SNF-D-MHM-019
 Title: Various P02,03,05,09,10,21,26,57,61,62,63&99 Interlocks
 -Siemens Contactor #3TF4611-0AK6

Page 7 of 8

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Contactor

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Siemens	X		1, IN	TP019A,B,C	NA	23	0	XWEST	Larry W. Price	4/10/00
Model Number	3TF4611-0AK6	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Contact Configuration	3 Pole NO Main Contacts and 1 NO & 1 NC auxiliary contacts	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Current Carrying Capability	0.5V max. voltage drop across closed contacts at 40 amps VAC resistive on main contacts and 10 amps VAC, resistive on auxiliary contacts		X	1, T	TP019B	↓	23	0	↓	↓	↓
Insulation Resistance	10 Megohms min across open contact terminals and terminals to ground (500VDC megger)		X	1, T	↓	↓	↓	↓	↓	↓	↓
Operation	Contacts open/close at maximum pick-up (102 VAC) and minimum drop-out (36 VAC) voltages		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-019A, B, C cited above CES 4/11/00				BUYER VERIFICATION			
Testing Agency Approval: <u>NA CES 4/11/00</u>	Date: <u>4/11/00</u>	Design Authority: <u>Wing Anderson</u>	Date: <u>4-11-00</u>	QA Engineer: <u>Stephen Scott Moore</u>	Date: <u>4-24-2000</u>		
Testing Agency QA Engineer: <u>NA CES 4/11/00</u>	Date:	QA Engineer:	Date:	QA Engineer:	Date:		

02/10/00

SNF-6315, Rev. 0

Page 431

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/ACGI No. CGI-SNF-D-MHM-019

Page 8 of 8

Title: Various P02,03,05,09,10,21,26,57,61,62,63&99 Interlocks

-Siemens Contactor #3TF4611-0AK6

SECTION 6 CONTACTS / PHONE NUMBERS

Name	Phone
Design Authority <u>CRALG SWENSON</u>	() <u>376-0288</u>
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents	For Critical Characteristics
Drawings:	
<input checked="" type="checkbox"/> Manuals (specify type & number): <u>Siemens Industrial Control Products, Contactor, 3TF4 3-Pole</u>	<u>All</u>
Design Calculations	
Installation Instructions	
Operation Instructions	
Calibration Instructions	
Manufacturer's Recommended Spare Parts List	
Other:	
Procurement Documents:	For Critical Characteristics
Certificate of Conformance/Compliance	
Seismic Qualification Certificate	
Environmental Qualification Certificate	
Test Report (s):	
Inspection Report (s):	
CMTRs for ASME Pressure Retaining Materials	
Valve Seat Leakage Report	
Weid Records	
Material Traceability Record	
Other:	


Dedication Test Plan – IST
 Test Plan No.: CGI-SNF-D-MHM-019-TP-019A
 Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: BLC

ORIGINAL

Rev. No. 0

Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
						 3/24/00 NO CHANGES

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019A


Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: BLC

Page 2 of 7

ORIGINAL**In-Situ Test Procedure****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date: 3/16/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Behaven	Michael Cram	MCRC
Electrician	J WEBERHART	PCE	JW Weberhart	JWE
Electrician Quality Control	Stephen R. Conley	PCE	Stephen R. Conley	SRC
Design Authority Representative	LARRY W PRICE	XUBST	JWP	JWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current Source capable of 10 amps and 40 amps

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00

Test Instrument type: AUC BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: PROTO G106 I.D.: 029E/009 Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019A

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: BLC

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	BLC	BLC	Acc
Manufacturer:	SIEMENS	Siemens	Acc
Model:	3TF46	3TF46	Acc
Contact Configuration:	YES	3 pole Main Contacts and 1 NO & 1 NC auxiliary contacts	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc
Coil:	K6	K6	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-16-00 2:20 p.m.

2.2 Operation

2.2.1 Regulate voltage to the coil of the contactor and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	74.562 VAC	102 VAC maximum	Acc
Drop-out Voltage	49.829 VAC	36 VAC minimum	Acc

2.2.2 De-energize and remove test equipment.

2.3 Insulation Resistance Test

2.3.1 Setup the test equipment and contactor specimen for insulation resistance testing.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019A

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: BLC

Page 4 of 7

2.3.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Record data below.

Terminal to Terminal / Ground				
Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
L1	T1	>1000Gohm	> 10 Megohms	Acc
L2	T2	>1000Gohm	> 10 Megohms	Acc
L3	T3	>1000Gohm	> 10 Megohms	Acc
13	14	>1000Gohm	> 10 Megohms	Acc
L1	Ground	>1000Gohm	> 10 Megohms	Acc
L2	Ground	>1000Gohm	> 10 Megohms	Acc
L3	Ground	>1000Gohm	> 10 Megohms	Acc
T1	Ground	>1000Gohm	> 10 Megohms	Acc
T2	Ground	>1000Gohm	> 10 Megohms	Acc
T3	Ground	>1000Gohm	> 10 Megohms	Acc
13	Ground	>1000Gohm	> 10 Megohms	Acc
14	Ground	>1000Gohm	> 10 Megohms	Acc
21 or 22	Ground	>1000Gohm	> 10 Megohms	Acc
A1 or A2 (coll)	Ground	>1000Gohm	> 10 Megohms	Acc

2.4 Contact Rating Test

2.4.1 Setup the test equipment and contactor specimen for contact rating testing.

2.4.2 Manually adjust the contactor or apply 120 VAC to the coil to close the normally open contacts

2.4.3 Apply a nominal 40 amps VAC, resistive, across closed main contacts of the test specimen

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO auxiliary contacts of the test specimen.

Caution: Do not change state of contacts while energized.

2.4.5 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Main Contacts L1 Closed	.0516 VAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L2 Closed	.0498 VAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L3 Closed	.0549 VAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 13-14 (closed)	.1526 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.6 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019A

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: BLC

Page 5 of 7

2.4.7 Apply a nominal 10 amps VAC, resistive, across the normally closed auxiliary contacts of the test specimen.

2.4.8 Record the following data.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Auxiliary NC 21-22 Contacts	1442 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.9 De-energize and remove the test equipment.

2.5 Terminate the test.

2.5.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.

2.5.2 Retorque the terminals to 12 in-pounds.

2.5.3 Record: Date /Time of Test End: 03-17-00 0:910 a.m.

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 24A

3.2 Y-Channel Main Power Panel Wiring Diagram: ED-33069 Sheet 1

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019A

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: BLC

Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met
Michael Chan
03-17-00

Notes:

Certified Instrumentation Technician (signature) Michael Chan Date: 03-17-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) JP Kevin Swenson Date: 3/20/00

QA/QC (signature) Stephen Scott Moss Date: 3-22-2000


LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
E3-33056		24ACRY	BLC	A-1	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00
		Black	RCSA-6	A-1	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00
		Grey		A-2	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00
		2) 102Y	BLC	A-2	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00
		Bx-11		L-1	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00
		Bx-12		L-2	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00
		Bx-13		L-3	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00
		Bm-1		T1	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00
		Bm-2		T2	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00
		Bm-3		T3	JWE	3/16/00	SRL	3-16-00	JWE	3/17/00	SRL	3-17-00

Remarks:

SNF-6315, Rev. 0

Page: 439




REV	DESCRIPTION	DATE	BY	CHK	ENG	APP'D	APP'D	CHK'D	DATE
A	MODIFY CONTROL CIRCUITRY	6/20/97	JDR	TUM	TUM	JDR		JDR	6/21/97
B	GENERAL REVISIONS	4/23/97	JDR	JMH	TUM	JDR		JDR	5/1/97
C	ADD PLY DELTE PLY	6/20/97	JDR	JMH	TUM	JDR	LLA	JDR	6/16/97
D	CHANGED DSOZY TO SO	9/15/97	JRS	AHM	TUM	JDR	CU	JDR	9/16/97
E	CORRECT SPELLING OF DSOZY	10/3/97	JRS	AHM	TUM	JDR	LLA	JDR	10/1/97
F	DE-INVERTING & SIMPLIFICATION	3/3/98	CSB	SED	CSB				
G	GENERAL REVISION	7/29/97	CSB	SED	CSB				

SCALE	1/4"	
PAGE USED ON	F-25CC	
REV	DATE	BY
24A	24A	G

World Series Contactors

Selection

3TF4 3-Pole with AC Coil

 <p>3TF43 3TF46</p>	Ordering Information ▶ Select Contactor from table below. ▶ Complete Catalog Number from coil code table. Example: 3TF4010-0AK6	Additional References ● Overload Relays see pages 361-363. ▶ Accessories see pages 357-360. ▶ Replacement Parts see pages 912-913. ▶ Technical Data see pages 378-379. ● Electrical Life Curves see page 381. ● Dimensions see page 394. ▶ Wiring Diagrams see page 302.	Coil Voltage Codes		
			AC Voltage 60Hz 50Hz Code	24 24 C2 120 110 K6 208 208 M2 277 220 U1 240 220 P8 480 380-415 V0 600 500 S0	

Ampere Rating Enclosed		1 Phase HP Ratings		3 Phase HP Ratings				Auxiliary Contacts Type		Catalog No	Price \$
IEC AC-3	UL	115V	230V	200V	230V	460V	575V	NO	NC		
9	20	1/4	1/4	2	3	5	7 1/2	1	0	3TF4010-0A??	105.
12	20	1	2	3	3	7 1/2	10	1	0	3TF4150-0A??	135.
16	30	1	3	5	5	10	15	1	0	3TF4210-0A??	150.
22	30	2	3	7 1/2	7 1/2	15	20	1	0	3TF4310-0A??	169.
32	55	3	5	10	10	25	30	1	1	3TF4411-0A??	186.
38	55	3	7 1/2	10	15	25	30	1	1	3TF4511-0A??	206.
Auxiliary Contacts may be added to 3TF46-3TF56 for maximum 4 NO and 4 NC [Ⓞ]											
45	80	5	10	15	20	40	50	1	1	3TF4811-0A??	276.
63	80	5	15	20	25	50	60	1	1	3TF4711-0A??	348.
75	100	7 1/2	15	25	30	60	75	1	1	3TF4811-0A??	420.
85	105	—	—	30	40	75	100	1	1	3TF4911-0A??	520.

3TF Contactors—Auxiliary Contact

Replace 6th (NO Aux. Contact) and 7th (NC Aux. Contact) digit in Catalog Number per chart. Example: 3TF4411-0AK6.

Contactors	Auxiliary Contacts		
	NO 6th Digit	NC 7th Digit	Price Adder \$
3TF40-3TF43	1	0	STD
	0	1	No Adder
	1	1	12.
	2	2	24.
3TF44-3TF45	1	1	STD
	2	2	24.
3TF46-3TF49	1	1	STD
	2	2	24.
	4 [Ⓞ]	4 [Ⓞ]	48.

Ⓞ See Auxiliary Contact table for standard and optional Auxiliary Contact Configurations.

Ⓞ Field assembled kit.

IEC Control 4

352

Discount Schedule AC-10 (WS)

Siemens & Furnas Control Products

World Series Contactors

Technical

3TF3, 3TF4, CRLOF3 and CRLOF4

Technical Data

NEMA Size			00				0		1	
Contactor	Type	Units of Measure	3TF30/40 CRLOF30/40	3TF31/41 CRLOF31/41	3TF32/42 CRLOF32/42	3TF33/43 CRLOF33/43	3TF34/44 CRLOF34/44	3TF35/45 CRLOF35/45		
Mechanical life	make/break operations	Mil	15				15		10	
Insulation rating		V	690							
Ambient temperature range		°C	-25 to +55 in operation, -55 to +80 when stored							
Coil ratings (cold coil $1.0 \times U_c$)	AC operation	Hz	50	60					50	60
		VA	68	75					87	115
DC operation	Inrush = Sealed	p.f.	0.82	0.76					0.82	0.75
		VA	10	9.4					13	13
		W	0.29	0.29					0.27	0.27
Coil voltage range:	AC		0.85 to $1.1 \times U_c$				0.85 to $1.1 U_c$			
	at DC 24V		0.8 to $1.2 \times U_c$				0.8 to $1.1 U_c$			
Operating times [Ⓞ] (Valid for 20% undervoltage to 10% overvoltage cold or warm coil)			(Values are applicable up to and including 20% undervoltage, 10% overvoltage as well as with the coil in cold state and operating temperature)							
AC operation	closing delay	ms	8-35			10-35		13-57		
	opening delay	ms	4-18			5-20		5-10		
DC operation	closing delay	ms	20-170			35-180		54-182		
	opening delay	ms	10-25			10-25		13-17		
Operating times at $1.0 \times U_c$ [Ⓞ]	AC operation	closing delay	10-15			10-25		13-32		
		opening delay	4-18			5-20		5-10		
DC operation	closing delay	ms	30-70			40-80		58-107		
	opening delay	ms	12-20			10-25		13-17		
Resistance to shock (rectangular pulse)	AC	g/ms	7.7/5, 4.4/10			5.8/5, 3.4/10		6.2/5, 3.6/10		
Conductor sizes			For contactors without overload relay							
main conductor; solid or stranded	main	AWG	(2) 18-12		(2) 18-12		(2) 14-10		(2) 14-10	
auxiliary conductor; solid or stranded	aux.	AWG	(2) 18-12		(2) 18-12		(2) 18-12		(2) 18-12	
Switching frequency in make/break operations per hour Contactors without overload relay	to AC-1 to AC-2 to AC-3 to AC-4	ops./h	1500			1500		1200		1200
		ops./h	1000			750		750		600
		ops./h	1000			750		750		600
		ops./h	250			250		250		200
		1/h	15			15		15		15
Auxiliary contacts										
Ⓞ, Ⓜ and ratings Ⓞ for auxiliary contacts										
Auxiliary Contacts within 3TF30 and 3TF31 and 3TF40 through 3TF45	Rated voltage switching capacity continuous current: 10 Amp (AC/DC)	AC 600V max. NEMA A600		24V	120V	240V	480V	600V		
		Make	A	60	60	30	15	12		
		Break	A	6	6	3	1.5	1.2		
		DC 600V max. NEMA P600		24V	125V	250V	300V	600V		
Auxiliary contact blocks for 3TF30 to 3TF35, Cat. 3TX40		AC 600V max. NEMA A600		24V	125V	200V	300V	600V		
		Make	A	1.1	1.1	0.55	0.20	0.20		
		Break	A	1.1	1.1	0.55	0.20	0.20		
		DC 600V max. NEMA Q600		24V	125V	200V	300V	600V		
Make	A	0.55	0.55	0.27	0.10	0.10				
Break	A	0.55	0.55	0.27	0.10	0.10				
Load/Life Curves shown with 3TF contactor technical data page XXX										

ⓄThe opening time delay is increased when the contactor coil is protected against voltage peaks (diode 6 to 9 times; diode combination 2 to 6 times; varistor + 2 to 6 ms).

1E3 60X701

378

World Series Contactors

3TF4 and CRLOF4


NEMA Size			2		3	
Contactor	Type	Unit of Measure	3TF46 CRLOF46	3TF47 CRLOF47	3TF48 CRLOF48	3TF49 CRLOF49
Mechanical life	make/break operations	Mil	10	10	10	10
Insulation rating		V	1000	1000	1000	1000
Ambient temperature range		°C	-25 to +55 in operation, -50 to +80 when stored			
Coil ratings (cold coil, $1.0 \times U_c$)		Hz	50	60	50	60
AC operation	Inrush	VA	183	185	345	360
	p.f.		0.5	0.54	0.5	0.4
	Seated	VA	17	15	35	31
	p.f.		0.29	0.29	0.23	0.24
DC economy circuit	Inrush	W	400	—	420	—
	Seated	W	2.1	—	2.7	—
DC solenoid system	Closing = Closed	W	15	—	—	—
Coil voltage range	AC		0.85 to $1.1 \times U_c$			
Operating times (valid for 20% undervoltage to 10% overvoltage, cold or warm coil)						
Total break time = opening delay + arcing time						
AC operation	closing delay	ms	15-40		20-50	
	opening delay ^①	ms	5-25		5-30	
	arcing time	ms	10-15		10-15	
Operating times at $1.0 \times U_c$						
AC operation	closing delay	ms	17-30		22-35	
	opening delay ^①	ms	5-25		5-30	
Resistance to shock (rectangular pulse)		g/ms	11.2/5	6.6/10	8.6/5	4.8/10
Conductor sizes						
For contactors without overload relay						
main conductor: solid or stranded	AWG		max. 1/0		max. 1/0	
auxiliary conductor: solid or stranded	AWG		2 × (18 to 12)		2 × (18 to 12)	
Switching frequency in make/break operations per hour (1/h)						
Contactors without overload relay						
	duty AC-1	1/h	1000	1000	900	900
	duty AC-2	1/h	600	400	400	350
	duty AC-3	1/h	1200	1000	1000	850
	duty AC-4	1/h	400	300	300	250
Contactors with overload relay (average value)		1/h	15	15	15	15

Auxiliary contacts								
①, ② and ③ ratings for auxiliary contacts								
3TF40 thru 3TF57	Rated voltage switching capacity	AC 600V maximum NEMA A600		24V	120V	240V	480V	600V
	Continuous current 10A (AC/DC)	Make	A	60	60	30	15	12
		Break	A	6	6	3	1.5	1.2
		DC 600V maximum NEMA P600		24V	150V	250V	300V	600V
		Make	A	1.1	1.1	0.55	0.20	0.20
		Break	A	1.1	1.1	0.55	0.20	0.20


① The opening delay can increase if the coils have voltage spike protection. Diodes may only be attached to contactors up to 3TF44.

ILL. CONTACT


Note: Starters with Contactor Sizes 3TF40 through 3FA4 are provided with the overload relays which mount directly to the contactor. These overload relays are provided with a contactor coil A2 repeat terminal. Wire "D" is integral with the overload relay. Jumper wire "E" is provided on the overload relay.



Standard Pilot Control
Wire "C" omitted on starters with coils rated 120V or less.



Without Control Power Transformer



With Control Power Transformer

Non-Reversing Starters — Type 3TF

Page 11/14

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-019-TP-019B

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: TLC

ORIGINAL

Rev. No. 0

Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST

Rev. N6. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019B

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: TLC

Page 2 of 7

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) [Signature] Date: 3/16/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Behaven	[Signature]	MCC
Electrician	J WEBERHART	PCE	[Signature]	JWB
Electrician Quality Control	Stephen P. Conley	PCE	[Signature]	SEC
Design Authority Representative	LARRY W. PRICE	M&E	[Signature]	LWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current Source capable of 10 amps and 40 amps

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00

Test Instrument type: AVO BM050/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: PRUO 6106 I.D.: B29E Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019B

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: TLC

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TLC	TLC	Acc
Manufacturer:	SIEMENS	Siemens	Acc
Model:	3TF46	3TF46	Acc
Contact Configuration:	YES	3 pole Main Contacts and 1 NO & 1 NC auxiliary contacts	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc
Coil:	K6	K6	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-16-00 12:45 p.m.

2.2 Operation

2.2.1 Regulate voltage to the coil of the contactor and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	79.556 VAC	102 VAC maximum	Acc
Drop-out Voltage	71.561 VAC	36 VAC minimum	Acc

2.2.2 De-energize and remove test equipment.

2.3 Insulation Resistance Test

2.3.1 Setup the test equipment and contactor specimen for insulation resistance testing.

Dedication Test Plan – IST

Rev.No. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019B

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: TLC

Page 4 of 7

- 2.3.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Record data below.

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
L1	T1	>100Gohm	> 10 Megohms	Acc
L2	T2	>100Gohm	> 10 Megohms	Acc
L3	T3	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
L1	Ground	>100Gohm	> 10 Megohms	Acc
L2	Ground	>100Gohm	> 10 Megohms	Acc
L3	Ground	>100Gohm	> 10 Megohms	Acc
T1	Ground	>100Gohm	> 10 Megohms	Acc
T2	Ground	>100Gohm	> 10 Megohms	Acc
T3	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc
21 or 22	Ground	>100Gohm	> 10 Megohms	Acc
A1 or A2 (coil)	Ground	>100Gohm	> 10 Megohms	Acc

2.4 Contact Rating Test

- 2.4.1 Setup the test equipment and contactor specimen for contact rating testing.
- 2.4.2 Manually adjust the contactor or apply 120 VAC to the coil to close the normally open contacts
- 2.4.3 Apply a nominal 40 amps VAC, resistive, across closed main contacts of the test specimen
- 2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO auxiliary contacts of the test specimen.

Caution: Do not change state of contacts while energized.

- 2.4.5 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Main Contacts L1 Closed	.0582 VAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L2 Closed	.0676 VAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L3 Closed	.0635 VAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 13-14 (closed)	.0989 VAC	< 0.5 ± 10% Volts AC drop	Acc

- 2.4.6 De-energize and remove test equipment.

Dedication Test Plan – IST**Rev. No. 0****Test Plan No.: CGI-SNF-D-MHM-019-TP-019B****Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: TLC****Page 5 of 7**

2.4.7 Apply a nominal 10 amps VAC, resistive, across the normally closed auxiliary contacts of the test specimen.

2.4.8 Record the following data.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Auxiliary NC 21-22 Contacts	.0994 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.9 De-energize and remove the test equipment.

2.5 Terminate the test.

2.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.5.2 Retorque the terminals to 12 in-pounds.

2.5.3 Record: Date /Time of Test End: 03-16-00 1:54 p.m.

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 21

3.2 Y-Channel Main Power Panel Wiring Diagram: ED-33069 Sheet 1

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019B

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.: TLC

Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met.

Michael Cran

03-06-00

Notes:

Certified Instrumentation Technician (signature)

Michael Cran
J. Casals 3/16/00

Date: 03-16-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature)

Jeffrey Hansen

Date: 3/16/00

QA/QC (signature)

Stephen Brett Moss

Date: 3-27-2000


LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-33256		2120Y	TLC	A-1	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
		Black	RCS2A-6	A-1	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
		Gray	"	A-2	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
		(2) 102Y	TLC	A-2	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
		TX-11		L-1	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
		TX-12		L-2	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
		TX-13		L-3	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
		TM-1 (R)		T-1	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
		TM-2 (Y)		T-2	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
		TM-3 (B)		T-3	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00

Remarks:

SNF-6315, Rev. 0

Page 451



THE FOLLOWING CHANGES AFFECT THIS DOCUMENT.		
MIN. REV. 075	4-27-99	3
MIN. REV. 020	4-27-99	4

UCC #15

HANFORD DWG # H-2-828710 SHT 32 OF 97

REVISIONS									
LTR	DESCRIPTION	DATE	BY	CHK	ENG	APPD	APPD	DRWN	J B RUPP
E	MODIFY END-OF-TRAVEL DESIGNATIONS	8/20/97	JON	JMH	THM	JAH	LLA	OCG	T M MADDYS
F	MODIFIED LOCATION ADDRESSES	9/1/97	JON	AJH	THM	JAH	ELU	OCG	T M MADDYS
C	REMOVE FESTOON SYMBOLS	10/2/97	JMS	AJH	THM	JAH	ELU	MPS	J M HANCOCK
H	CHANGE TOL TO N.C.	10/25/97	JM1	THM	THM	JAH	EM	APP	L S ANDERSON
J	DE-BURRING & SIMPLIFICATION	3/9/98	CSD	SEG	CSH				
K	GENERAL REVISION	7/20/98	CSD	SEG	CSH				
L	REVISED PER INSTALLATION MARK-UPS	3/6/99	CSH						

EOERER
INCORPORATED
CONCRETE CRANES WASHINGTON CRANES SEA CRANES

TROLLEY CONTROL ELEMENTARY


SCALE: N/A

REV. NO. 21

World Series Contactors

Selection

3TF4 3-Pole with AC Coil

 <p>3TF43 3TF48</p>	Ordering Information <ul style="list-style-type: none"> Select Contactor from table below. Complete Catalog Number from coil code table. Example: 3TF4010-0AK6 	Additional References <ul style="list-style-type: none"> Overload Relays see pages 361-363. Accessories see pages 357-360. Replacement Parts see pages 912-913. Technical Data see pages 378-379. Electrical Life Curves see page 381. Dimensions see page 394. Wiring Diagrams see page 302. 	Coil Voltage Codes																										
			<table border="1"> <thead> <tr> <th colspan="2">AC Voltage</th> <th>Code</th> </tr> <tr> <th>60Hz</th> <th>50Hz</th> <th></th> </tr> </thead> <tbody> <tr> <td>24</td> <td>24</td> <td>C2</td> </tr> <tr> <td>120</td> <td>110</td> <td>K6</td> </tr> <tr> <td>208</td> <td>208</td> <td>M2</td> </tr> <tr> <td>277</td> <td>220</td> <td>U1</td> </tr> <tr> <td>240</td> <td>220</td> <td>P6</td> </tr> <tr> <td>480</td> <td>380-415</td> <td>V0</td> </tr> <tr> <td>600</td> <td>500</td> <td>S0</td> </tr> </tbody> </table>	AC Voltage		Code	60Hz	50Hz		24	24	C2	120	110	K6	208	208	M2	277	220	U1	240	220	P6	480	380-415	V0	600	500
AC Voltage		Code																											
60Hz	50Hz																												
24	24	C2																											
120	110	K6																											
208	208	M2																											
277	220	U1																											
240	220	P6																											
480	380-415	V0																											
600	500	S0																											

Ampere Rating Enclosed		1 Phase HP Ratings						3 Phase HP Ratings				Auxiliary Contacts Type		Catalog No.	Price \$
IEC AC-3	UL	115V	230V	200V	230V	460V	575V	NO	NC						
9	20	1/2	1 1/2	2	3	5	7 1/2	1	0			3TF4010-0ATT	105.		
12	20	1	2	3	3	7 1/2	10	1	0			3TF4110-0ATT	135.		
16	30	1	3	5	5	10	15	1	0			3TF4210-0ATT	150.		
22	30	2	3	7 1/2	7 1/2	15	20	1	0			3TF4310-0ATT	159.		
32	55	3	5	10	10	25	30	1	1			3TF4411-0ATT	180.		
38	55	3	7 1/2	10	15	25	30	1	1			3TF4511-0ATT	206.		
Auxiliary Contacts may be added to 3TF46-3TF56 for maximum 4 NO and 4 NC [Ⓞ]															
45	80	5	10	15	20	40	50	1	1			3TF4611-0ATT	276.		
63	80	5	15	20	25	50	60	1	1			3TF4711-0ATT	348.		
75	100	7 1/2	15	25	30	60	75	1	1			3TF4811-0ATT	420.		
85	105	—	—	30	40	75	100	1	1			3TF4911-0ATT	520.		

3TF Contactors—Auxiliary Contact
 Replace 6th (NO Aux. Contact) and 7th (NC Aux. Contact) digit in Catalog Number per chart. Example: 3TF4411-0AK6.

Contactors	Auxiliary Contacts		
	NO 6th Digit	NC 7th Digit	Price Adder \$
3TF40-3TF43	1	0	STD
	0	1	No Adder
	1	1	12.
	2	2	24.
3TF44-3TF45	1	1	STD
	2	2	24.
3TF46-3TF49	1	1	STD
	2	2	24.
	4 [Ⓞ]	4 [Ⓞ]	48.

Ⓞ See Auxiliary Contact table for standard and optional Auxiliary Contact Configurations. Ⓞ Field assembled kit.

IEC Control 4

World Series Contactors

Technical

3TF3, 3TF4, CRLOF3 and CRLOF4

Technical Data

NEMA Size			00		0		1	
Contactor	Type	Units of Measure	3TF30/40 CRLOF30/40	3TF31/41 CRLOF31/41	3TF32/42 CRLOF32/42	3TF33/43 CRLOF33/43	3TF34/44 CRLOF34/44	3TF35/45 CRLOF35/45
Mechanical life	make/break operations	Mil	15		15		10	
Insulation rating		V	690					
Ambient temperature range		°C	-25 to +55 in operation, -55 to +80 when stored					
Coil ratings (cold coil $1.0 \times U_L$) AC operation	Inrush	Hz	50	60			50	60
		VA	68	75			87	115
	Sealed	p.f.	0.82	0.76			0.82	0.75
		VA	10	9.4			13	13
DC operation	Inrush = Sealed	p.f.	0.29	0.29			0.27	0.27
		W	6.5				11.7	
Coil voltage range:	AC at DC 24V		0.85 to $1.1 \times U_L$ 0.8 to $1.2 \times U_L$			0.85 to $1.1 U_L$ 0.8 to $1.1 U_L$		
Operating times [Ⓢ] (Valid for 20% undervoltage to 10% overvoltage cold or warm coil)			(Values are applicable up to and including 20% undervoltage, 10% overvoltage as well as with the coil in cold state and operating temperature)					
AC operation	closing delay	ms	8-35		10-35		13-57	
		ms	4-18		5-20		5-10	
DC operation	closing delay	ms	20-170		35-180		54-182	
		ms	10-25		10-25		13-17	
AC operation	opening delay	ms	10-15		10-25		13-32	
		ms	4-18		5-20		5-10	
DC operation	closing delay	ms	30-70		40-80		58-107	
		ms	12-20		10-25		13-17	
Resistance to shock (rectangular pulse)	AC	g/ms	7.7/5, 4.4/10		5.8/5, 3.4/10		6.2/5, 3.6/10	
Conductor sizes For contactors without overload relay								
main conductor, solid or stranded		main	(2) 18-12		(2) 18-12		(1) 14-3 or (2) 16-6	
auxiliary conductor, solid or stranded		aux.	(2) 18-12		(2) 18-12		(2) 18-12	
Switching frequency in make/break operations per hour Contactors without overload relay								
to AC-1		ops./h	1500		1500		1200	
to AC-2		ops./h	1000		750		750	
to AC-3		ops./h	1000		750		750	
to AC-4		ops./h	250		250		250	
Contactors with overload relay (avg. value)		1/h	15		15		15	
Auxiliary contacts								
Ⓢ and ratings Ⓢ for auxiliary contacts								
Auxiliary Contacts within 3TF30 and 3TF31 and 3TF40 through 3TF45	Rated voltage switching capacity continuous current. 10 Amp (AC/DC)	AC 600V max NEMA A600		24V	120V	240V	480V	600V
		Make	A	60	60	30	15	12
		Break	A	6	6	3	1.5	1.2
		DC 600V max NEMA P600		24V	125V	250V	300V	600V
Auxiliary contact blocks for 3TF30 to 3TF35, Cat. 3TX40		Make	A	1.1	1.1	0.55	0.20	0.20
		Break	A	1.1	1.1	0.55	0.20	0.20
		DC 600V max. NEMA O600		24V	125V	200V	300V	600V
		Make	A	0.55	0.55	0.27	0.10	0.10
Break	A	0.55	0.55	0.27	0.10	0.10		

Ⓢ The opening time delay is increased when the contactor coil is protected against voltage peaks (diode 6 to 9 times; diode combination 2 to 6 times; varistor + 2 to 6 ms).

125 6315 (3/71)

World Series Contactors

3TF4 and CRL0F4

NEMA Size			2		3	
Contactor	Type	Unit of Measure	3TF48 CRL0F48	3TF47 CRL0F47	3TF48 CRL0F48	3TF49 CRL0F49
Mechanical life	make/break operations	Mil	10	10	10	10
Insulation rating		V	1000	1000	1000	1000
Ambient temperature range		°C	-25 to +55 in operation, -50 to +80 when stored			
Coil ratings (cold coil, $1.0 \times U_c$)		Hz	50	60	50	60
AC operation	Inrush	VA	183	185	345	360
	p.f.		0.5	0.54	0.5	0.4
	Sealed	VA	17	15	35	31
DC economy circuit	p.f.		0.29	0.29	0.23	0.24
	Inrush	W	400	—	420	—
DC solenoid system	Sealed	W	2.1	—	2.7	—
	Closing = Closed	W	15	—	—	—
Coil voltage range	AC		0.85 to $1.1 \times U_c$			
Operating times (valid for 20% undervoltage to 10% overvoltage, cold or warm coil)						
Total break time = opening delay + arcing time						
AC operation	closing delay	ms	15-40		20-50	
	opening delay [Ⓢ]	ms	5-25		5-30	
	arcing time	ms	10-15		10-15	
Operating times at $1.0 \times U_c$						
AC operation	closing delay	ms	17-30		22-35	
	opening delay [Ⓢ]	ms	5-25		5-30	
Resistance to shock (rectangular pulse)		g/ms	11.2/5	6.6/10	8.6/5	4.8/10
Conductor sizes						
For contactors without overload relay						
main conductor: solid or stranded	AWG		max. 1/0		max. 1/0	
auxiliary conductor: solid or stranded	AWG		2 × (18 to 12)		2 × (18 to 12)	
Switching frequency in make/break operations per hour (1/h)						
Contactors without overload relay						
duty AC-1	1/h		1000	1000	900	900
duty AC-2	1/h		600	400	400	350
duty AC-3	1/h		1200	1000	1000	850
duty AC-4	1/h		400	300	300	250
Contactors with overload relay (average value)	1/h		15	15	15	15


Auxiliary contacts								
Ⓢ, Ⓜ and Ⓠ ratings for auxiliary contacts								
3TF40 thru 3TF57	Rated voltage switching capacity	AC 600V maximum NEMA A600		24V	120V	240V	480V	600V
				Make	A	60	60	30
		Break	A	6	6	3	1.5	1.2
	Continuous current 10A (AC/DC)	DC 600V maximum NEMA P600		24V	150V	250V	300V	600V
		Make	A	1.1	1.1	0.55	0.20	0.20
		Break	A	1.1	1.1	0.55	0.20	0.20

Ⓢ The opening delay can increase if the coils have voltage spike protection. Diodes may only be attached to contactors up to 3TF44.


4
LEU CONTACT

Non-Reversing Starters ----- Type 3TF


Without Control Power Transformer



With Control Power Transformer



Standard Pilot Control
Wire "C" omitted on starters with coils rated 120V or less.



Note: Starters with Contactor Sizes 3TF40 through 3TF44 are provided with the overload relays which mount directly to the contactor. These overload relays are provided with a contactor coil A2 repeat terminal. Wire "D" is integral with the overload relay. Jumper wire "E" is provided on the overload relay.

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-019-TP-019C Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.:MHLC	Rev. No. 0 ORIGINAL Page 1 of 4
---	--

In-Situ Inspection Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI. Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-019-TP-019C

Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.:MHLC

ORIGINAL

Page 2 of 4

In-Situ Inspection Procedure**Inspection Procedure Approval (Obtain prior to inspection):**

This procedure documents the visual verification of the identification critical characteristics of the remaining specimen which were in-situ tested on a sampling basis as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *Larry W. Pake* Date: 4-6-00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Electrician	N/A	N/A	N/A	NA
Electrician Quality Control	N/A	N/A	N/A	NA
Design Authority Representative	LARRY W. PAKE	KUST	<i>Larry W. Pake</i>	YWP

SAFETY INSTRUCTIONS: PERSONNEL SAFETY - personnel shall exercise caution around energized electrical equipment.

INSPECTION PROCEDURE:**1.0 Record the following Test Specimen identification information:**

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MHLC	MHLC	
Manufacturer:	SIEMENS	Siemens	SIZE 2
Model:	3TF46	3TF46	
Contact Configuration:	3PMC 2 Aux cont	3 pole Main Contacts and 1 NO and 1 NC auxiliary contacts	
Serial No./Lot No./Date Code:	N/A	N/A	
Coil:	K6	K6	

2.0 Record: Date /Time of Test Beginning: 4/7/00 8:18 AM

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-019-TP-019C	
Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.:MHLC	Page 3 of 4

2.1 Record: Date /Time of Test End: 4/17/00 8:20AM

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 4

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

ACCEPTANCE CRITERIA MET.

Notes:

NA

Design Authority Representative (signature)

[Handwritten Signature]

Date: 4/17/00

[Handwritten Signature] 4/17/00 *LES*

Dedication Test Plan – IST**Rev. No. 0****Test Plan No.: CGI-SNF-D-MHM-019-TP-019C****Test Specimen: Siemens 3TF4611-0AK6, Eqmt. No.:MHLC****Page 4 of 4****Completed Test Evaluation Approval:**

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Wayne Swenson Date: 4/7/00

QA/QC (signature) Stephen Scott Mason Date: 4-7-2000

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 1 of 11

ECN No. N/A CGI No. CGI-SNF-D-MHM-016C
Title: P2 & P63 Interlocks - Action Pak AP 1080-2000 Trip Point Relays & Sockets

Section 1: Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
Part Description: <u>N/A</u>		
End Use Description: <u>N/A</u>		

ORIGINAL

Section 2a Component Information

Equipment No.: <u>Trip Point Relays 5X, 6X, 7X, 8X</u>	Specification No.: <u>Ederer F-2566, Foster Wheeler MJX-SDX 452656</u>	Manufacturer: <u>Action Pak</u>	Past P.O. No.: <u>N/A</u>
Manufacturer's Part/Model No.: <u>Relay: AP1080-2000; Relay Sockets: M011 (Track/Surface Mount); MD11 (DIN Rail)</u>	Equipment Supplier (if different from manufacturer): <u>ALSTROM, Foster Wheeler</u>	Equip. Supplier's Part No.: <u>N/A</u>	

Component Description: 120 VAC Relay with Single Trip, with adjustable deadband, 0-20 mA Input, 5 Amp DPDT contacts, with 11-pin base. MD11 - Standard DIN Rail Mount and M011 - Track/Surface Mount plug-in Sockets for Action Pak Relays AP1080-2000

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate w/ project CGI Engineer or BTR)? YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate w/ project CGI Engineer or BTR)? YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)

2. List of Candidate qualified suppliers or ISO 9000 suppliers N/A

3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)

All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 2 of 11

ECN No. N/A CGI No. CGI-SNF-D-MHM-016C
Title: P2 & P63 Interlocks - Action Pak AP 1080-2000 Trip Point Relays & Sockets

Section 2d Reason for Dedication

The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):

<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input checked="" type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:
 1. **The P2 interlock serves to prevent the MHM from leaving a storage tube without replacing the tube plug by determining when the MCO Hoist weight is greater than the minimum grapple and tube plug weight and when the MCO Hoist weight is less than the maximum grapple only weight. The P63 interlock insures that the MCO Hoist cannot be raised if the MCO weight is exceeded. These relays inhibit the action as stated in the interlocks for the X channel only.**

B. Part/Component Functional Mode:

Safety Function #1:	<input checked="" type="checkbox"/> Active	<input type="checkbox"/> Passive	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function Passive - Change of state is not required for the component to perform its safety function
Safety Function #2:	<input type="checkbox"/> Active	<input type="checkbox"/> Passive	
Safety Function #3:	<input type="checkbox"/> Active	<input type="checkbox"/> Passive	

C. Host Component Safety Function (if applicable): N/A
1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):
 1. **Failure to actuate from the weight of the MCO Hoist weight and the weight it carries results in movement of the MHM or raising of the MCO hoist at improper times.**

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required: Yes [] No [X]	If yes: Environmental Qualification Requirements Limiting Environmental Conditions: Required Safety Functions: Qualification Period:
Natural Phenomena Hazard (NPH) Design Required: Yes [] No [X]	If yes: NPH Design Requirements Performance Category: NPH Design Req'ts.: Required Safety Functions:

Section 5 Component Functional Classification

<input checked="" type="checkbox"/> Safety Class (SC)	<input type="checkbox"/> General Service (GS)	<input type="checkbox"/> Safety Significant (SS)
---	---	--

If part/component classification is different from host component/system, document basis. N/A

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: N/A
 Safety Analysis Report (SAR): HNF-3672, Rev. 0
 Drawings: Ederer, Inc. EB-33056, Sht 11; H-2-827174 Sht 10, 21, 22, 23
 Vendor Manual/Manufacturer/Supplier Information: Action Pak, DC Input, Field Configurable Limit Alarms, Models AP1080, AP1090
 Other: ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A CGI No. CGI-SNF-D-MHM-016C

Page 3 of 11

Title: **P2 & P63 Interlocks – Action Pak AP 1080-2000 Trip Point Relays & Sockets**

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acc Meth	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Relay:				
Manufacturer - Relay	Action Pak	1, IN	X	
Model - Relay	AP1080-2000	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Insulation Resistance	Greater than 10 megohm across open contact terminals and terminals to ground at 500 VDC	1, T		X
Contact Rating	0.5 V max. voltage drop across closed contacts, 120 VAC at 5 Amps, resistive	1, T		X
Operation	Contacts open/close at trip and reset values in milliamps. See Table 1 on last page of this CGI.	1, T		X
Relay Socket:				
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer – Relay Socket	Action Pak	1, IN	X	
Model – Relay Socket	MD11 (11 pin for mounting on a DIN Rail)	1, IN	X	
Model – Relay Socket	M011 (11 pin for mounting on Track/Surface)	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Insulation Resistance	Greater than 10 megohm between terminal to terminal and terminal to ground at 500 VDC	1, T		X
4. Notes and Legend:				
Rev. 1: All Pages: Added Relay socket M011.		Acceptance Method (Acc Meth): 1. Special Test and Inspection: 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 4. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:

Designated Engineer: [Signature] 2/23/00

Design Authority: [Signature] 2/23/00

QA Engineer: [Signature] 2/24/00

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 4 of 11

ECN No. NA CGI No. CGI-SNF-D-MHM-016C
Title: P2 & P63 Interlocks - Action Pak AP 1080-2000 Trip Point Relays & Sockets

WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Failure to open the circuit by contact welding or hot short across the contact base.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Binding results in failure of contacts to open
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2: Additional Failure Modes Applicable to the Component Under Evaluation			
1.	Controller contacts fail to open. Cause could be binding or contacts welded.		
2.			
3.			
4.			
5.			

Commercial Grade Item Upgrade Dedication Form		Rev. No. 1
ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-MHM-016C</u>	Page 5 of 11
Title: P2 & P63 Interlocks - Action Pak AP 1080-2000 Trip Point Relays & Sockets		

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1	
Item Description: Trip Point Relays	Equip #: 5X, 6X, 7X, 8X
System #: MHM	Model #: AP1080-2000
Manufacturer (Address/Phone): 800-767-5726 Action Instruments, Inc. 8601 Aero Drive San Diego, CA 92123 Phone. # (619) 279-5726 Fax: (619) 270-6290 http://www.actionio.com/	Supplier (Address/Phone): Set-Point Control 603 4th Avenue, Suite 200 Kirkland, WA 98033 Kevin Gauce Tel : 800-255-5212 Fax : 425-822-5624 Email : kevin@set-point.com

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1

Insp	Test	Post-Test	Item
X			1. Manufacturer - Relay
X			2. Model - Relay
X			3. Manufacturer - Relay Socket
X			4. Model - Relay Socket
	X		5. Insulation resistance - Relay and Relay Socket
	X		6. Contact Rating
	X		7. Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic: Manufacturer - Relay	Sample Size*: 100%
Acceptance Criteria: Action Pak	
Receipt Inspection Plan / Report #: CGI-SNF-D-MHM-016C-TP-016C	
Characteristic: Model - Relay	Sample Size*: 100%
Acceptance Criteria: AP1080-2000	
Receipt Inspection Plan / Report #: TP-016C	
Characteristic: Manufacturer - Relay Socket	Sample Size*: 100%
Acceptance Criteria: Action Pak	
Receipt Inspection Plan / Report #: TP-016CS	
Characteristic: Model - Relay Socket	Sample Size*: 100%
Acceptance Criteria: MD11 (11 pin for mounting on a DIN Rail)	
Receipt Inspection Plan / Report #: TP-016CS	
Characteristic: Model - Relay Socket	Sample Size*: 100%
Acceptance Criteria: M011 (11 pin for mounting on a Track/Surface)	
Receipt Inspection Plan / Report #: TP-016CS	

THIS socket not used
YES JUN 4/10/00
JUN 4/10/00

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 6 of 11

ECN No. N/A CGI No. CGI-SNF-D-MHM-016C
Title: P2 & P63 Interlocks - Action Pak AP 1080-2000 Trip Point Relays & Sockets

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)	
Characteristic for Test: Insulation Resistance Acceptance Criteria: Greater than 10 megohm across open contact terminals and terminals to ground at 500 VDC Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-016C</u>
Characteristic for Test: Relay Contact Rating Acceptance Criteria: 0.5 V max. voltage drop across closed contacts, 120 VAC at 5 Amps, resistive Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-016C</u>
Characteristic for Test: Relay Operation Acceptance Criteria: Contacts open/close at trip and reset values in milliamps. See Table 1 on last page of this CGI. Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-016C</u>
Characteristic for Test: Relay Socket Insulation Resistance Acceptance Criteria: Greater than 10 megohm between terminal to terminal and terminal to ground at 500 VDC Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-016CS</u>

ECN No. N/A CGI No. CGI-SNF-D-MHM-016C

Page 8 of 11

Title: P2 & P63 Interlocks - Action Pak AP 1080-2000 Trip Point Relays & Sockets

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. Summary Of Verified Critical Characteristics , Their Verification Methods, And Results

ITEM DESCRIPTION: Relay Socket MD11

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Action Pak	X		1, IN	TP-016CS	NA	5	0	XWEST	LARRY W. PRICE	4/10/00
Model - Relay Socket	MD11 (11 pin for mounting on a DIN Rail)	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Insulation Resistance - Relay Socket	Greater than 10 megohm between terminal to terminal and terminal to ground at 500 VDC		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. Disposition Of Unverified Or Failed Critical Characteristics

Critical Characteristic	Disposition

3. Signature Indicates All Critical Characteristics Verified Satisfactory Or Acceptably Dispositioned And Commercial Grade Dedication Is Satisfactory And Complete.

See Test Plan TP-016CS cited above

Testing Agency Approval: <u>NR CBS 4/12/00</u> Date: _____	Design Authority: <u>CEB Wang</u> <u>Anderson</u> Date: <u>4/12/00</u>
Testing Agency QA Engineer: <u>NR CEB 4/12/00</u> Date: _____	QA Engineer: _____ Date: _____

SNF-6315, Rev. 0

Page 467

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A

CGI No. CGI-SNF-D-MHM-016C

Page 7 of 11

Title: P2 & P63 Interlocks - Action Pak AP 1080-2000 Trip Point Relays & Sockets

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. Summary Of Verified Critical Characteristics , Their Verification Methods, And Results

ITEM DESCRIPTION: Relay

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method TAN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Action Pak	X		1, IN	TP-016C	NA	2	0	XWEST	LARRY W. FORCE	4/11/00
Model - Relay	AP1080-2000	X		1, IN							
Insulation Resistance - Relay	Greater than 10 megohm across open contact terminals and terminals to ground at 500 VDC		X	1, T							
Contact Rating - Relay	0.5 V max. voltage drop across closed contacts, 120 VAC at 5 Amps, resistive		X	1, T							
Operation - Relay	Contacts open/close at trip and reset values in milliamps. See Table 1 on last page of this CGI.		X	1, T							

2. Disposition Of Unverified Or Failed Critical Characteristics

Critical Characteristic	Disposition

3. Signature Indicates All Critical Characteristics Verified Satisfactory Or Acceptably Dispositioned And Commercial Grade Dedication Is Satisfactory And Complete.

See Test Plan TP-016C cited above. CES

Testing Agency Approval: NR CES 4/12/00 Date: 4/12/00

Testing Agency QA Engineer: NR CES 4/12/00 Date: 4/12/00

Design Authority: CES Wang Anderson Date: 4/12/00

QA Engineer: _____ Date: _____

BUYER VERIFICATION

SNF-6315, Rev. 0

Page 468

SECTION 5: TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. Summary Of Verified Critical Characteristics , Their Verification Methods, And Results

ITEM DESCRIPTION: Relay Socket M011

Critical Characteristics		Verification Results									
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/M/N	Procedure or R/R#	Check-List ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Action Pak	X		1, IN							
Model - Relay Socket	M011 (11 pin for mounting on a Track/Surface)	X		1, IN							
Insulation Resistance - Relay Socket	Greater than 10 megohm between terminal to terminal and terminal to ground at 500 VDC		X	1, T							

Handwritten: THESE SOCKETS WERE NOT USED
Signature: [Signature]
Date: 4/19/00
CE 5
4/12/02

2. Disposition Of Unverified Or Failed Critical Characteristics

Critical Characteristic	Disposition

3. Signature Indicates All Critical Characteristics Verified Satisfactory Or Acceptably Dispositioned And Commercial Grade Dedication Is Satisfactory And Complete.

Testing Agency Approval: _____ Date _____	Design Authority: _____ Date _____
Testing Agency QA Engineer: _____ Date _____	QA Engineer: _____ Date _____

BUYER VERIFICATION

Commercial Grade Item Upgrade Dedication Form		Rev. No. 1
ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-MHM-016C</u>	Page 10 of 11
Title: <u>P2 & P63 Interlocks - Action Pak AP 1080-2000 Trip Point Relays & Sockets</u>		

SECTION 6 CONTACTS / PHONE NUMBERS

	Name	Phone
Design Authority	<u>CRAIG SWENSON</u>	<u>376-0288</u>
QA		
QC		
Cog - Engineer		
CGI Engineer		
Procurement Engineer		
Other		

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents		For Critical Characteristics
<input type="checkbox"/>	Drawings:	
<input type="checkbox"/>	Manuals (specify type & number):	
<input type="checkbox"/>	Design Calculations	
<input type="checkbox"/>	Installation Instructions	
<input type="checkbox"/>	Operation Instructions	
<input type="checkbox"/>	Calibration Instructions	
<input type="checkbox"/>	Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/>	Other: Action Pak, DC Input, Field Configurable Limit Alarms, Models AP1080, AP1090	All
Procurement Documents		For Critical Characteristics
<input type="checkbox"/>	Certificate of Conformance/Compliance	
<input type="checkbox"/>	Seismic Qualification Certificate	
<input type="checkbox"/>	Environmental Qualification Certificate	
<input type="checkbox"/>	Test Report (s):	
<input type="checkbox"/>	Inspection Report (s):	
<input type="checkbox"/>	CMTRs for ASME Pressure Retaining Materials	
<input type="checkbox"/>	Valve Seat Leakage Report	
<input type="checkbox"/>	Weld Record	
<input type="checkbox"/>	Material Traceability Record	
<input checked="" type="checkbox"/>	Other: CSB (W379)-015-11-059 & 060	Relay Setpoints

Commercial Grade Item Upgrade Dedication Form		Rev. No. 1
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-MHM-016C</u>	Page 11 of 11
Title: <u>P2 & P63 Interlocks - Action Pak AP 1080-2000 Trip Point Relays & Sockets</u>		

Table 1
Relay Actuation Points (Trip and Reset)

Relay ID	Trip	Reset	Tolerance
5X	6.34 mA Inc.	6.34 mA Dec.	±0.2% of full scale
6X	9.19 mA Inc.	9.19 mA Dec.	±0.2% of full scale
7X	6.76 mA Inc.	6.76 mA Dec.	±0.2% of full scale
8X	10.31 mA Inc.	10.31 mA Dec.	±0.2% of full scale

NR -
 Not on
 MHM
 SEL
 anymore
 CBS
 4/12/00

Note: To the "Testing authority" - the relay ID's above are those installed in the MHM system and when bench testing replacement relays, the new relays are tested, adjusted, and set per the trip and reset values listed above for a single relay, each must then be marked 5X, 6X, etc. for ID and placement purposes.

Dedication Test Plan – RLY-3 Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C Test Specimen: Acton Pak AP1080-2000 Relay	Rev. No. 0 Page 1 of 5
---	-------------------------------

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) *JMP Craig Swenson* Date: 1-31-00

RECOMMENDED EQUIPMENT:

Power Supply capable of 5 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

ORIGINAL

Record test instrument(s) serial numbers and calibration due

Test Instrument type: <u>PRIMA MFD</u>	I.D.: <u>SN:10012</u>	Calib. Due dates <u>3-25-00</u>
Test Instrument type: <u>HP3457A</u>	I.D.: <u>BAT-123</u>	Calib. Due dates <u>7-29-00</u>
Test Instrument type: <u>HP3457A</u>	I.D.: <u>BAT-124</u>	Calib. Due dates <u>7-30-00</u>
<u>AVO 2380/2 MEGGER, 6410-889/000100/5245</u>		<u>2-7-01</u>
<u>FLUKE 787 DMM</u>	<u>BAT-107</u>	<u>5-28-00</u>

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)


Test Specimen Description: Relay

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>ACTION PAK</u>	Action Pak	<u>ACCEPT</u>
Model:	<u>1080-2000</u>	AP1080-2000	<u>ACCEPT</u>
Contact Configuration:	<u>DPDT</u>	DPDT	<u>ACCEPT</u>
Serial No.:	<u>138507</u>	N/A	<u>N/A</u>

Setup the Relay(s) for testing configuration:


Input Range Selector, adjust selector for 10mA (5X) current ranges as follows:




ORIGINAL
ORIGINAL

Dedication Test Plan – RLY-3	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C	
Test Specimen: Acton Pak AP1080-2000 Relay	Page 2 of 5

Input Jumper W2, position the input jumper for all relays' current inputs as follows:



Mode Selector Switch, adjust for Unipolar for all relays' as follows:



Perform the following tests:

Record: Date /Time of Test Beginning: 2-16-00 8:00 AM

Record: Room Temperature: 68 °F.

Perform steps below:

1. Operation

Check , the relay being testing, regulate and record current to the coil of the relay and monitor the trip and reset milliamp values.

* applicable Relay	Relay No.	Description	Record Data	Acceptance Criteria	Comments/Deviations
	5X	Trip Current	6.34004 <i>JAC</i> mA	6.34 ± 0.02 mA Inc.	ACCEPT
		Reset Current	6.33007 <i>JAC</i> mA	6.34 ± 0.02 mA Dec.	ACCEPT

2. Contact Rating Test

Setup the Relay specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

Apply a nominal 5 amps, resistive, @ 120 VAC across the NC contacts of the test specimen. *JWP 2/17/00 CBS*

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
7-8	.2297 <i>JAC</i>	< 0.5 ± 10% Volts AC drop	ACCEPT
10-11	.2743 <i>JAC</i>	< 0.5 ± 10% Volts AC drop	ACCEPT

Dedication Test Plan - RLY-3
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C
Test Specimen: Acton Pak AP1080-2000 Relay

Rev. No. 0

Page 4 of 5

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

*Relay has been calibrated per the requirements
of this test plan. Relay is in compliance
and found to be acceptable*

J. Covert

2/16/00

Dedication Test Plan - RLY-3	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C	
Test Specimen: Acton Pak AP1080-2000 Relay	Page 5 of 5

Notes:

Relay was reverified to be in calibration after megger test was completed. This reverification was performed to verify no electronic components were damaged during megger testing with high voltage.

L. Cavitt
2/16/00

Test Engineer/Technician (Printed Name) LEFF CAVITT

Test Engineer/Technician (signature) *L. Cavitt* Date: 2/16/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *JMP Larry Swenson* Date: 3/1/00


QA/QC (signature) *T. J. Anderson* Date: 3/2/00
T. J. ANDERSON



Action Pak®

DC Input, Field Configurable Limit Alarms

Models AP1080, AP1090



Provides Relay Contact Closure(s) at a Preset DC Input Level

- Field Configurable Input Ranges for DC Voltage and Current
- Setpoint(s) Programmable HI or LO
- Exclusive "Dynamic Deadband" Prevents False Trips
- Selectable Failsafe/Latching Operation
- LED Trip Indicators
- Selectable 120/240VAC Operation (9 to 30 VDC Available)
- Lifetime Warranty



DESCRIPTION

Action Pak models AP1080 single setpoint and AP1090 dual setpoint limit alarms offer flexible, wide-ranging DC input capability. Voltage spans from 10mV to 200 volts and current spans from 1mA to 100mA can be field configured. Bipolar inputs are also accepted. Both models offer configurable latching, failsafe and HI/LO operation. The AP1080 and AP1090 also include 0.25%-50% adjustable deadbands and selectable 120/240VAC operation.

DIAGNOSTIC LED

Models AP1080-2000 and AP1090-2000 are equipped with a dual function diagnostic LED. The green center LED indicates line power and input signal status. Active line power is indicated by an illuminated LED. If the center LED is off, check line power and the wiring connection. If the input signal is above 100% full scale, the LED will flash at approximately 8Hz. Below 0%, the flash rate is approximately 4Hz.

OUTPUT SELECTION

The single setpoint AP1080 and the dual setpoint AP1090 provide the following relay outputs:

AP1080	Single Trip (DPDT, 5A)
AP1090	Single/Dual Trip (2 SPDT, 5A)

Setpoint(s) are top accessed 15-turn potentiometer(s) or option "P" provides ten-turn dial(s).

OPERATION

The field configurable AP1080 and AP1090 limit alarm setpoint(s) can be configured for HI, LO, latching and/or failsafe trip operation. Non-latching HI and LO setpoints have respective HI and LO deadbands. In a tripped condition, the setpoint is exceeded and the appropriate red LED will illuminate. The trip will reset only when the process falls below the HI deadband or rises above the LO deadband (see figure 1). To reset a latched setpoint the signal must be in the safe region and the line power turned off for at least 5 seconds. For proper deadband operation, a HI setpoint must always be set above a LO setpoint.

In failsafe operation, the relay is energized when the process is below the HI setpoint or above the LO setpoint (opposite for non-failsafe). In the failsafe mode, the relays go to the tripped condition when the power fails.




Figure 1: Limit alarm operation and effect of deadband(s).

DYNAMIC DEADBAND

LSI circuitry prevents false trips by repeatedly sampling the input. The input must remain beyond the setpoint for 100 milliseconds, uninterrupted, to qualify as a valid trip condition. Likewise, the input must fall outside the deadband and remain there for 100 milliseconds to return the alarm to an untripped condition. This effectively results in a "dynamic deadband"-based on time--in addition to the normal deadband.

OPTIONS

- U** Urethane coating of internal circuitry for protection from corrosive atmospheres.
- P** Top Mounted, Ten-Turn Dial(s) for setpoint adjustment.
- C620** Factory calibration to customer's specifications

CONFIGURATION

The factory presets models AP1080 and AP1090 as follows:

	AP1080	AP1090
Input	0-20mA	0-20mA
Output	Single, DPDT	Dual, SPDT
Trip	HI	A: HI, B: LO
Latching	No	No
Failsafe	Yes	No
Deadband	0.25%	A/B: 0.25%
Power	120VAC	120VAC


For other I/O ranges, remove the four base screws and case to access the configuration switches.

Replace the cover before applying power.


Refer to Figure 4 for configuration.

Input

- Position input jumper "W2" for Current or Voltage inputs.



- Set position 1 of the Mode Selector for Unipolar or Bipolar operation. Unipolar is the default.



Note: A bipolar span selection will double any span from Table 1 (e.g., 10V unipolar span = ±10V bipolar span)

- Using Table 1, configure positions 1 through 4 of the Input Range Selector for the desired maximum setpoint Input. Round desired maximum input values to the next highest range (e.g., 0-120V = 200V range).

Output

Configure the Mode Selector for the required function. See Figure 5.

Power

Configure the AC jumpers for either 120 or 240 VAC operation. See Figure 6.

CALIBRATION

Note: To maximize thermal stability, final calibration should be performed in the operating installation, allowing approximately 1-2 hours for warmup and thermal equilibrium of the system.

Setpoint. Set deadband at its minimum (20 turns Counter Clockwise) before adjusting the setpoint. With the specified trip voltage or current input applied, adjust setpoint until the relay trips. For HI trip calibration, start with the setpoint above the desired trip. For LO trip calibration, start below the desired trip.

Deadband. Set deadband to its minimum (fully Counter Clockwise). Set setpoint to desired trip. Adjust voltage/current input until relay trips. Readjust deadband to 50% (20 turns Clockwise). Set voltage/current input to desired deadband position. Slowly adjust deadband until relay untrips.

FACTORY ASSISTANCE

For additional information on calibration, operation and installation please contact Action's Technical Services Group. Call toll-free: **800-767-5726**

Table 1: AP1080-2000 and 1090-2000 Input Ranges

*Voltage	*Current	Input Range Selector
10mV	1mA	
20mV	2mA	
50mV	5mA	
100mV	10mA	
200mV	20mA	
500mV	50mA	
1V	100mA	
2V		
5V		
10V		
20V		
50V		
100V		
200V		

**Note: Use Jumper (W2) to configure either voltage or current input. All unipolar input ranges are zero based.*

RELAY PROTECTION AND EMI SUPPRESSION

When switching inductive loads, maximum relay life and transient EMI suppression is achieved using external protection (see Figures 2 & 3). Place all protection devices directly across the load and minimize all lead lengths. For AC inductive loads, place a properly-rated MOV across the load in parallel with a series RC snubber. Use a 0.01 to 0.1µF pulse film capacitor (foil polypropylene recommended) of sufficient voltage, and a 47Ω, 1/2W carbon resistor. For DC inductive loads, place a diode across the load (PRV > DC supply, 1N4006 recommended) with (+) to cathode and (-) to anode (the RC snubber is an optional enhancement)




Figure 2: DC Inductive Loads





Figure 3: AC Inductive Loads

PIN CONNECTIONS*

- AP1080, AP1090
- 1 AC Power (Hot)
- 2 Shield (Gnd)
- 3 AC Power (Neu)
- 4 Input (+)
- 5 Input (-)
- 6 N.O.
- 7 C
- 8 N.C.
- 9 N.O.
- 10 C
- 11 N.C



Key:

- N.O. = Normally Open
- C = Common
- N.C. = Normally Closed
- DC Power: Pin 1 = (+); Pin 3 = (-)

*Contacts are in the "normal" state when the relay is de-energized.




Figure 4: AP1090-2000 Factory Calibration 0-20mA, Dual HI/LO, Non-Latching, Non-Failsafe




Figure 6: 120/240 VAC Selection




Figure 5: Mode Selection Dual Trip/A: HI, B: LO, Non-Latching, Non-Failsafe
*Applicable for AP1090-2000, only

SPECIFICATIONS

Inputs

Voltage Input

Range: 10mV to 200V
 Impedance: >100K ohm
 Overvoltage: 400V, max.

Current Input

Range: 1mA to 100mA
 Impedance: 20 ohms, typical
 Overcurrent: 200mA, max.
 Overvoltage: 60VDC

Common Mode (Input to Ground):
 1000VDC, max.

LED Indications

Input Range (Green)
 >100% input: 8Hz flash
 <0% input: 4Hz flash

Setpoint (Red)

Tripped: Solid red
 Safe: Off

Limit Differentials (Deadbands)

>50mV/5mA: 0.25% to 50% of span
 <50mV/5mA: 1% to 50% of span

Response Time

Dynamic Deadband:
 Relay status will change when proper setpoint/process condition exists uninterrupted for 100msec.
 Normal Mode (analog filtering):
 <250msec, (10-90%)

Setpoint

Effectivity: Setpoint(s) are adjustable over 100% of the selected input span.
 Repeatability (constant temp):
 >50mV/5mA: 0.1% of full scale
 <50mV/5mA: 0.2% of full scale

Stability

Line Voltage: ±0.01%/%, max.
 Temperature: ±0.05% of full scale/°C, max.

Common Mode Rejection

DC to 60Hz: 120dB

Isolation

1000V DC between contacts, input and power

ESD Susceptibility

Meets IEC 801-2, Level 2 (4KV)

Humidity

Operating: 15 to 95% (@45°C)
 Soak: 90% for 24 hours (@65°C)

Temperature Range

Operating: 0 to 60°C (32 to 140°F)
 Storage: -15 to 70°C (5 to 158°F)

Power

Consumption: 2W typical, 5W max.
 Standard: Selectable 120/240VAC (±10%, 50-60Hz)
 Optional: 9 to 30VDC, Inverter-Isolated

Relay Contacts

AP1080: DPDT (2 Form C)
 AP1090: 1 SPDT (1 Form C) per setpoint
 Current Rating (resistive)
 120VAC: 5A
 240VAC: 2A
 28VDC: 5A

Material: Silver-Cadmium Oxide
 Electrical Life: 10⁶ operations at rated load

Note: External relay contact protection is required for use with inductive loads. See relay protection section (Figure 1 & 2).
 Mechanical Life: 10⁷ operations

Latch Reset Time

5 seconds

Weight

AP1080 0.46lbs
 AP1090 0.62lbs

Agency Approvals

CSA certified per standard C22.2, No. M1982 (File No. LR42272-8,9)
 UL recognized per standard UL508, (File No. E99775)

MOUNTING

All Action Paks feature plug-in installation. Models AP1080 and AP1090 use an 11-pin base, either molded socket (M011) or DIN rail socket (MD11).

ORDERING INFORMATION




Specify:

1. Model: AP1080-2000, AP1090-2000
2. Options: U, P (see text)
3. Line Power (see specs.)


(All power supplies are transformer-isolated from the internal circuitry.)

DIMENSIONS

Dimensions are in millimeters (inches)



M011(Track/Surface)




MD11 (DIN Rail)

All Prices and Specifications subject to change without notice

For order entry, applications or customer service assistance, call toll-free 800-767-5726

■ **United States**
 Action Instruments, Inc.
 8601 Aero Drive
 San Diego, CA 92123
 Phone: 619-279-5726
 FAX: 619-279-6290
 721-0479-00-J 12/98





STANDARD TEST SETUP FOR MEASURING
RESISTANCE ACROSS CONTACTS.

Dedication Test Plan - RLY-3
 Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C
 Test Specimen: Acton Pak AP1080-2000 Relay

Page 1 of 5

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) JUP Craig Swenson Date: 1-31-00

RECOMMENDED EQUIPMENT:

Power Supply capable of 5 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

ORIGINAL

Record test instrument(s) serial numbers and calibration due

Test Instrument type: PREMA MEM I.D.: S/N 10012 Calib. Due dates 2-25-00

Test Instrument type: HP3457A I.D.: BAT-123 Calib. Due dates 7-29-00

Test Instrument type: HP3457A I.D.: BAT-124 Calib. Due dates 7-30-00

AVO BM80/2 MEGGER, 6410-889/000/00/5345 2-9-01
FLUKE 787 Dmm, BAT-107 5-28-00

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)


Test Specimen Description: Relay

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>ACTION PAK</u>	Action Pak	<u>ACCEPT</u>
Model:	<u>1080-2000</u>	AP1080-2000	<u>ACCEPT</u>
Contact Configuration:	<u>DPDT</u>	DPDT	<u>ACCEPT</u>
Serial No.:	<u>38506</u>	N/A	

Setup the Relay(s) for testing configuration:

Input Range Selector, adjust selector for 10mA (5X) current ranges as follows:




ORIGINAL

Dedication Test Plan - RLY-3
 Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C
 Test Specimen: Acton Pak AP1080-2000 Relay


Rev. No. 0

Page 2 of 5

Input Jumper W2, position the input jumper for all relays' current inputs as follows:



Mode Selector Switch, adjust for Unipolar for all relays' as follows:



Perform the following tests:

Record: Date /Time of Test Beginning: 2-14-00 1:00 PM

Record: Room Temperature: 68 °F.

Perform steps below:

1. Operation

Check , the relay being testing, regulate and record current to the coil of the relay and monitor the trip and reset milliamp values.

Relay No.	Description	Record Data	Acceptance Criteria	Comments/Deviations
5X	Trip Current	6.34002 mA	8.34 ± 0.02 mA Inc.	CALIBRATED
	Reset Current	6.33004 mA	8.34 ± 0.02 mA Dec.	CALIBRATED

2. Contact Rating Test

Setup the Relay specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

Apply a nominal 5 amps, resistive, @ 120 VAC across the NC contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
7-8	.2319 VAC	< 0.5 ± 10% Volts AC drop	ACCEPT
10-11	.2354 VAC	< 0.5 ± 10% Volts AC drop	ACCEPT

Dedication Test Plan - RLY-3
 Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C
 Test Specimen: Acton Pak AP1080-2000 Relay

Rev. No. 0

Page 3 of 5

Reset the relay and allow the NO contacts to close. Apply a nominal 5 amps, resistive, @ 120 VAC across the closed normally open contacts of the test specimen. *VAC*

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
6-7	-1933 VAC	< 0.5 ± 10% Volts AC drop	ACCEPT
9-10	-2228 VAC	< 0.5 ± 10% Volts AC drop	ACCEPT

3. Insulation Resistance Test

Setup the Relay specimen for insulation resistance testing. Attach Relay in its normal mounting configuration to grounded fixture.

Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground				
Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
6	8	> 100 Gohm	> 10 Megohms	ACCEPT
9	11	> 100 G	> 10 Megohms	
COM	6	> 100 G	> 10 Megohms	
COM	9	> 100 G	> 10 Megohms	
1	2 (Ground)	> 100 G	> 10 Megohms	
3	2 (Ground)	> 100 G	> 10 Megohms	
6	2 (Ground)	> 100 G	> 10 Megohms	
7	2 (Ground)	> 100 G	> 10 Megohms	
8	2 (Ground)	> 100 G	> 10 Megohms	
9	2 (Ground)	> 100 G	> 10 Megohms	
10	2 (Ground)	> 100 G	> 10 Megohms	
11	2 (Ground)	> 100 G	> 10 Megohms	

- De-energize equipment.
- End test.
- Carefully disassemble test leads to Relay specimen. Label the test specimen as 5X, depending on the trip and reset values used during testing.
- Clean, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 2-16-00 9:43 AM

Dedication Test Plan - RLY-3
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C
Test Specimen: Acton Pak AP1080-2000 Relay

Rev. No. 0

Page 4 of 5

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

*Relay has been calibrated to this test plan
criteria. Relay is in compliance and found
to be acceptable.*

J. Coates

2-16-00

Dedication Test Plan - RLY-3 Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C Test Specimen: Acton Pak AP1080-2000 Relay	Rev. No. 0 Page 5 of 5
--	---

Notes:

Relay was reverified to be in calibration after megger test was performed. This reverification was performed to verify no electronic components were damaged during megger test with high voltage.

J. Cadwick

Test Engineer/Technician (Printed Name) JEFF CADWICK

Test Engineer/Technician (signature) J. Cadwick Date: 2/16/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Y.P. Craig Swenson Date: 3/1/00


QA/QC (signature) T. Z. Anderson Date: 3/2/00
T. Z. ANDERSON



Action Pak®

DC Input, Field Configurable Limit Alarms

Models AP1080, AP1090



Provides Relay Contact Closure(s) at a Preset DC Input Level

- Field Configurable Input Ranges for DC Voltage and Current
- Setpoint(s) Programmable HI or LO
- Exclusive "Dynamic Deadband" Prevents False Trips
- Selectable Failsafe/Latching Operation
- LED Trip Indicators
- Selectable 120/240VAC Operation (9 to 30 VDC Available)
- Lifetime Warranty



DESCRIPTION

Action Pak models AP1080 single setpoint and AP1090 dual setpoint limit alarms offer flexible, wide-ranging DC input capability. Voltage spans from 10mV to 200 volts and current spans from 1mA to 100mA can be field configured. Bipolar inputs are also accepted. Both models offer configurable latching, failsafe and HI/LO operation. The AP1080 and AP1090 also include 0.25%-50% adjustable deadbands and selectable 120/240VAC operation.

DIAGNOSTIC LED

Models AP1080-2000 and AP1090-2000 are equipped with a dual function diagnostic LED. The green center LED indicates line power and input signal status. Active line power is indicated by an illuminated LED. If the center LED is off, check line power and the wiring connection. If the input signal is above 100% full scale, the LED will flash at approximately 8Hz. Below 0%, the flash rate is approximately 4Hz.

OUTPUT SELECTION

The single setpoint AP1080 and the dual setpoint AP1090 provide the following relay outputs:

AP1080	Single Trip (DPDT, 5A)
AP1090	Single/Dual Trip (2 SPDT, 5A)

Setpoint(s) are top accessed 15-turn potentiometer(s) or option "P" provides ten-turn dial(s).

OPERATION

The field configurable AP1080 and AP1090 limit alarm setpoint(s) can be configured for HI, LO, latching and/or failsafe trip operation. Non-latching HI and LO setpoints have respective HI and LO deadbands. In a tripped condition, the setpoint is exceeded and the appropriate red LED will illuminate. The trip will reset only when the process falls below the HI deadband or rises above the LO deadband (see figure 1). To reset a latched setpoint the signal must be in the safe region and the line power turned off for at least 5 seconds. For proper deadband operation, a HI setpoint must always be set above a LO setpoint.

In failsafe operation, the relay is energized when the process is below the HI setpoint or above the LO setpoint (opposite for non-failsafe). In the failsafe mode, the relays go to the tripped condition when the power fails.




Figure 1: Limit alarm operation and effect of deadband(s).

DYNAMIC DEADBAND

LSI circuitry prevents false trips by repeatedly sampling the input. The input must remain beyond the setpoint for 100 milliseconds, uninterrupted, to qualify as a valid trip condition. Likewise, the input must fall outside the deadband and remain there for 100 milliseconds to return the alarm to an untripped condition. This effectively results in a "dynamic deadband"-based on time--in addition to the normal deadband.

OPTIONS

- U** Urethane coating of internal circuitry for protection from corrosive atmospheres.
- P** Top Mounted, Ten-Turn Dial(s) for setpoint adjustment.
- C620** Factory calibration to customer's specifications

CONFIGURATION

The factory presets models AP1080 and AP1090 as follows:

	AP1080	AP1090
Input	0-20mA	0-20mA
Output	Single, DPDT	Dual, SPDT
Trip	HI	A: HI, B: LO
Latching	No	No
Failsafe	Yes	No
Deadband	0.25%	A/B: 0.25%
Power	120VAC	120VAC


For other I/O ranges, remove the four base screws and case to access the configuration switches.

Replace the cover before applying power.


Refer to Figure 4 for configuration.

Input

1. Position input jumper "W2" for Current or Voltage inputs.



2. Set position 1 of the Mode Selector for Unipolar or Bipolar operation. Unipolar is the default.



Note: A bipolar span selection will double any span from Table 1 (e.g., 10V unipolar span = ±10V bipolar span)

3. Using Table 1, configure positions 1 through 4 of the Input Range Selector for the desired maximum setpoint input. Round desired maximum input values to the next highest range (e.g., 0-120V = 200V range).

Output

Configure the Mode Selector for the required function. See Figure 5.

Power

Configure the AC jumpers for either 120 or 240 VAC operation. See Figure 6.

CALIBRATION

Note: To maximize thermal stability, final calibration should be performed in the operating installation, allowing approximately 1-2 hours for warmup and thermal equilibrium of the system.

Setpoint. Set deadband at its minimum (20 turns Counter Clockwise) before adjusting the setpoint. With the specified trip voltage or current input applied, adjust setpoint until the relay trips. For HI trip calibration, start with the setpoint above the desired trip. For LO trip calibration, start below the desired trip.

Deadband. Set deadband to its minimum (fully Counter Clockwise). Set setpoint to desired trip. Adjust voltage/current input until relay trips. Readjust deadband to 50% (20 turns Clockwise). Set voltage/current input to desired deadband position. Slowly adjust deadband until relay untrips.

FACTORY ASSISTANCE

For additional information on calibration, operation and installation please contact Action's Technical Services Group. Call toll-free: **800-767-5726**

Table 1: AP1080-2000 and 1090-2000 Input Ranges

*Voltage	*Current	Input Range Selector
10mV	1mA	
20mV	2mA	
50mV	5mA	
100mV	10mA	
200mV	20mA	
500mV	50mA	
1V	100mA	
2V		
5V		
10V		
20V		
50V		
100V		
200V		

**Note: Use Jumper (W2) to configure either voltage or current input. All unipolar input ranges are zero based.*

RELAY PROTECTION AND EMI SUPPRESSION

When switching inductive loads, maximum relay life and transient EMI suppression is achieved using external protection (see Figures 2 & 3). Place all protection devices directly across the load and minimize all lead lengths. For AC inductive loads, place a properly-rated MOV across the load in parallel with a series RC snubber. Use a 0.01 to 0.1µF pulse film capacitor (foil polypropylene recommended) of sufficient voltage, and a 47Ω, 1/2W carbon resistor. For DC inductive loads, place a diode across the load (PRV > DC supply, 1N4006 recommended) with (+) to cathode and (-) to anode (the RC snubber is an optional enhancement)




Figure 2: DC Inductive Loads





Figure 3: AC Inductive Loads

PIN CONNECTIONS*

- AP1080, AP1090
- 1 AC Power (Hot)
- 2 Shield (Gnd)
- 3 AC Power (Neu)
- 4 Input (+)
- 5 Input (-)
- 6 N.O.
- 7 C
- 8 N.C.
- 9 N.O.
- 10 C
- 11 N.C.



Key:
 N.O. = Normally Open
 C = Common
 N.C. = Normally Closed
 DC Power: Pin 1 = (+); Pin 3 = (-)

*Contacts are in the "normal" state when the relay is de-energized.




Figure 4: AP1090-2000 Factory Calibration 0-20mA, Dual HI/LO, Non-Latching, Non-Failsafe




Figure 6: 120/240 VAC Selection




Figure 5: Mode Selection Dual Trip/A: HI, B: LO, Non-Latching, Non-Failsafe
 *Applicable for AP1090-2000, only

SPECIFICATIONS

Inputs

Voltage Input

Range: 10mV to 200V
 Impedance: >100K ohm
 Overvoltage: 400V, max.

Current Input

Range: 1mA to 100mA
 Impedance: 20 ohms, typical
 Overcurrent: 200mA, max.
 Overvoltage: 60VDC
 Common Mode (Input to Ground):
 1000VDC, max.

LED Indications

Input Range (Green)
 >100% input: 8Hz flash
 <0% input: 4Hz flash
 Setpoint (Red)
 Tripped: Solid red
 Safe: Off

Limit Differentials (Deadbands)

>50mV/5mA: 0.25% to 50% of span
 <50mV/5mA: 1% to 50% of span

Response Time

Dynamic Deadband:
 Relay status will change when proper
 setpoint/process condition exists
 uninterrupted for 100msec.
 Normal Mode (analog filtering):
 <250msec, (10-90%)

Setpoint

Effectivity: Setpoint(s) are adjustable
 over 100% of the selected input span.
 Repeatability (constant temp):
 >50mV/5mA: 0.1% of full scale
 <50mV/5mA: 0.2% of full scale

Stability

Line Voltage: ±0.01%/%, max.
 Temperature: ±0.05% of full
 scale/°C, max.

Common Mode Rejection

DC to 60Hz: 120dB

Isolation

1000V DC between contacts,
 input and power

ESD Susceptibility

Meets IEC 801-2, Level 2 (4KV)

Humidity

Operating: 15 to 95% (@45°C)
 Soak: 90% for 24 hours (@65°C)

Temperature Range

Operating: 0 to 60°C (32 to 140°F)
 Storage: -15 to 70°C (5 to 158°F)

Power

Consumption: 2W typical, 5W max.
 Standard: Selectable 120/
 240VAC (±10%, 50-60Hz)
 Optional: 9 to 30VDC,
 Inverter-Isolated

Relay Contacts

AP1080: DPDT (2 Form C)
 AP1090: 1 SPDT (1 Form C)
 per setpoint
 Current Rating (resistive)
 120VAC: 5A
 240VAC: 2A
 28VDC: 5A

Material: Silver-Cadmium Oxide
 Electrical Life: 10⁵ operations at
 rated load

Note: External relay contact
 protection is required for use with
 inductive loads. See relay
 protection section (Figure 1 & 2).
 Mechanical Life: 10⁷ operations

Latch Reset Time

5 seconds

Weight

AP1080 0.46lbs
 AP1090 0.62lbs

Agency Approvals

CSA certified per standard C22.2,
 No. M1982 (File No. LR42272-8,9)
 UL recognized per standard UL508,
 (File No. E99775)

MOUNTING

All Action Paks feature plug-in installa-
 tion. Models AP1080 and AP1090 use
 an 11-pin base, either molded socket
 (M011) or DIN rail socket (MD11).

ORDERING INFORMATION




Specify:

1. Model: AP1080-2000, AP1090-2000
2. Options: U, P (see text)
3. Line Power (see specs.)


(All power supplies are transformer-
 isolated from the internal circuitry.)

DIMENSIONS

Dimensions are in millimeters (inches)



M011 (Track/Surface)



MD11 (DIN Rail)


All Prices and Specifications subject to change without notice

For order entry, applications or customer service assistance, call toll-free 800-767-5726

United States

Action Instruments, Inc.
 8601 Aero Drive
 San Diego, CA 92123
 Phone: 619-279-5726
 FAX: 619-279-6290
 721-0479-00-J 12/98





STANDARD TEST SETUP FOR MEASURING
RESISTANCE ACROSS CONTACTS.

Dedication Test Plan – RLYSKT-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS	
Test Specimen: Acton Pak MD11 & M011 Relay Sockets	Page 1 of 4

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) [Signature] Date: 2/23/00

RECOMMENDED EQUIPMENT:

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

ORIGINAL

Record test instrument(s) serial numbers and calibration due

Test Instrument type: AVO BM 221 I.D.: BAT-137 Calib. Due dates 3-14-01

Test Instrument type: _____ I.D.: _____ Calib. Due dates _____

Test Instrument type: _____ I.D.: _____ Calib. Due dates _____

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Relay Socket

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>Action Pak</u>	Action Pak	<u>ACC</u>
Model:	<u>MD11</u>	MD11 or M011	<u>ACC</u>
Serial No.: <u>51214</u>	<u>4</u>	N/A	<u>ACC</u>

Setup the Relay Sockets for testing configuration:

Perform the following tests:

Record: Date /Time of Test Beginning: 9:00A 4-7-00

Record: Room Temperature: 68 °F.

ORIGINAL

Dedication Test Plan - RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 2 of 4

Perform steps below:

1. Insulation Resistance Test

Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
1	2	>999 mOhm	> 10 Megohms	ACC
1	3	>999 mOhm	> 10 Megohms	ACC
1	4	>999 mOhm	> 10 Megohms	ACC
1	5	>999 mOhm	> 10 Megohms	ACC
1	6	>999 mOhm	> 10 Megohms	ACC
1	7	>999 mOhm	> 10 Megohms	ACC
1	8	>999 mOhm	> 10 Megohms	ACC
1	9	>999 mOhm	> 10 Megohms	ACC
1	10	>999 mOhm	> 10 Megohms	ACC
1	11	>999 mOhm	> 10 Megohms	ACC
2	3	>999 mOhm	> 10 Megohms	ACC
2	4	>999 mOhm	> 10 Megohms	ACC
2	5	>999 mOhm	> 10 Megohms	ACC
2	6	>999 mOhm	> 10 Megohms	ACC
2	7	>999 mOhm	> 10 Megohms	ACC
2	8	>999 mOhm	> 10 Megohms	ACC
2	9	>999 mOhm	> 10 Megohms	ACC
2	10	>999 mOhm	> 10 Megohms	ACC
2	11	>999 mOhm	> 10 Megohms	ACC
3	4	>999 mOhm	> 10 Megohms	ACC
3	5	>999 mOhm	> 10 Megohms	ACC
3	6	>999 mOhm	> 10 Megohms	ACC
3	7	>999 mOhm	> 10 Megohms	ACC
3	8	>999 mOhm	> 10 Megohms	ACC
3	9	>999 mOhm	> 10 Megohms	ACC
3	10	>999 mOhm	> 10 Megohms	ACC
3	11	>999 mOhm	> 10 Megohms	ACC
4	5	>999 mOhm	> 10 Megohms	ACC
4	6	>999 mOhm	> 10 Megohms	ACC
4	7	>999 mOhm	> 10 Megohms	ACC
4	8	>999 mOhm	> 10 Megohms	ACC
4	9	>999 mOhm	> 10 Megohms	ACC
4	10	>999 mOhm	> 10 Megohms	ACC
4	11	>999 mOhm	> 10 Megohms	ACC
5	6	>999 mOhm	> 10 Megohms	ACC
5	7	>999 mOhm	> 10 Megohms	ACC
5	8	>999 mOhm	> 10 Megohms	ACC

Dedication Test Plan - RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 3 of 4

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/ Ground			
5	8	>999 mOhm	> 10 Megohms	ACC
5	10	>999 mOhm	> 10 Megohms	ACC
5	11	>999 mOhm	> 10 Megohms	ACC
6	7	>999 mOhm	> 10 Megohms	ACC
6	8	>999 mOhm	> 10 Megohms	ACC
6	9	>999 mOhm	> 10 Megohms	ACC
6	10	>999 mOhm	> 10 Megohms	ACC
6	11	>999 mOhm	> 10 Megohms	ACC
7	8	>999 mOhm	> 10 Megohms	ACC
7	9	>999 mOhm	> 10 Megohms	ACC
7	10	>999 mOhm	> 10 Megohms	ACC
7	11	>999 mOhm	> 10 Megohms	ACC
8	9	>999 mOhm	> 10 Megohms	ACC
8	10	>999 mOhm	> 10 Megohms	ACC
8	11	>999 mOhm	> 10 Megohms	ACC
9	10	>999 mOhm	> 10 Megohms	ACC
9	11	>999 mOhm	> 10 Megohms	ACC
10	11	>999 mOhm	> 10 Megohms	ACC
1	Ground	>999 mOhm	> 10 Megohms	ACC
2	Ground	>999 mOhm	> 10 Megohms	ACC
3	Ground	>999 mOhm	> 10 Megohms	ACC
4	Ground	>999 mOhm	> 10 Megohms	ACC
5	Ground	>999 mOhm	> 10 Megohms	ACC
6	Ground	>999 mOhm	> 10 Megohms	ACC
7	Ground	>999 mOhm	> 10 Megohms	ACC
8	Ground	>999 mOhm	> 10 Megohms	ACC
9	Ground	>999 mOhm	> 10 Megohms	ACC
10	Ground	>999 mOhm	> 10 Megohms	ACC
11	Ground	>999 mOhm	> 10 Megohms	ACC

2. De-energize equipment.
3. End test.
4. Carefully disassemble test leads to Relay Socket specimen.
5. Clean, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record:

Date /Time of Test End:

9:30A

4-7-00

Dedication Test Plan - RLYSKT-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS	
Test Specimen: Acton Pak MD11 & M011 Relay Sockets	Page 4 of 4

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Item meets requirements for this test plan.

Notes:

Test Engineer/Technician (Printed Name) JEFF CADRE

Test Engineer/Technician (signature) *J. Cadre* Date: 4-7-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *Jim Long Swenson* Date: 4-11-00

QA/QC (signature) *Stephen Scott Mose* Date: 4-12-2000

Dedication Test Plan – RLYSKT-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS	
Test Specimen: Acton Pak MD11 & M011 Relay Sockets	Page 1 of 4

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) [Signature] Date: 2/23/00

RECOMMENDED EQUIPMENT:

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

ORIGINAL

Record test instrument(s) serial numbers and calibration due

Test Instrument type: AVO BM221 I.D.: BAT-137 Calib. Due dates 3-14-01

Test Instrument type: _____ I.D.: _____ Calib. Due dates _____

Test Instrument type: _____ I.D.: _____ Calib. Due dates _____

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Relay Socket

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>Action Pak</u>	Action Pak	<u>ACC</u>
Model:	<u>MD11</u>	MD11 or M011	<u>ACC</u>
Serial No.:	<u>5</u>	N/A	<u>ACC</u>

Setup the Relay Sockets for testing configuration:

Perform the following tests:

Record: Date /Time of Test Beginning: 9:40 A 4-7-00

Record: Room Temperature: 68 °F.

ORIGINAL

Dedication Test Plan – RLYSKT-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS	
Test Specimen: Acton Pak MD11 & M011 Relay Sockets	Page 2 of 4

Perform steps below:

1. Insulation Resistance Test

Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
1	2	>999 mOhm	> 10 Megohms	ACC
1	3	>999 mOhm	> 10 Megohms	ACC
1	4	>999 mOhm	> 10 Megohms	ACC
1	5	>999 mOhm	> 10 Megohms	ACC
1	6	>999 mOhm	> 10 Megohms	ACC
1	7	>999 mOhm	> 10 Megohms	ACC
1	8	>999 mOhm	> 10 Megohms	ACC
1	9	>999 mOhm	> 10 Megohms	ACC
1	10	>999 mOhm	> 10 Megohms	ACC
1	11	>999 mOhm	> 10 Megohms	ACC
2	3	>999 mOhm	> 10 Megohms	ACC
2	4	>999 mOhm	> 10 Megohms	ACC
2	5	>999 mOhm	> 10 Megohms	ACC
2	6	>999 mOhm	> 10 Megohms	ACC
2	7	>999 mOhm	> 10 Megohms	ACC
2	8	>999 mOhm	> 10 Megohms	ACC
2	9	>999 mOhm	> 10 Megohms	ACC
2	10	>999 mOhm	> 10 Megohms	ACC
2	11	>999 mOhm	> 10 Megohms	ACC
3	4	>999 mOhm	> 10 Megohms	ACC
3	5	>999 mOhm	> 10 Megohms	ACC
3	6	>999 mOhm	> 10 Megohms	ACC
3	7	>999 mOhm	> 10 Megohms	ACC
3	8	>999 mOhm	> 10 Megohms	ACC
3	9	>999 mOhm	> 10 Megohms	ACC
3	10	>999 mOhm	> 10 Megohms	ACC
3	11	>999 mOhm	> 10 Megohms	ACC
4	5	>999 mOhm	> 10 Megohms	ACC
4	6	>999 mOhm	> 10 Megohms	ACC
4	7	>999 mOhm	> 10 Megohms	ACC
4	8	>999 mOhm	> 10 Megohms	ACC
4	9	>999 mOhm	> 10 Megohms	ACC
4	10	>999 mOhm	> 10 Megohms	ACC
4	11	>999 mOhm	> 10 Megohms	ACC
5	6	>999 mOhm	> 10 Megohms	ACC
5	7	>999 mOhm	> 10 Megohms	ACC
5	8	>999 mOhm	> 10 Megohms	ACC

Dedication Test Plan - RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 3 of 4

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
5	8	>999 mOhm	> 10 Megohms	ACC
5	10	>999 mOhm	> 10 Megohms	ACC
5	11	>999 mOhm	> 10 Megohms	ACC
6	7	>999 mOhm	> 10 Megohms	ACC
6	8	>999 mOhm	> 10 Megohms	ACC
6	9	>999 mOhm	> 10 Megohms	ACC
6	10	>999 mOhm	> 10 Megohms	ACC
6	11	>999 mOhm	> 10 Megohms	ACC
7	8	>999 mOhm	> 10 Megohms	ACC
7	9	>999 mOhm	> 10 Megohms	ACC
7	10	>999 mOhm	> 10 Megohms	ACC
7	11	>999 mOhm	> 10 Megohms	ACC
8	9	>999 mOhm	> 10 Megohms	ACC
8	10	>999 mOhm	> 10 Megohms	ACC
8	11	>999 mOhm	> 10 Megohms	ACC
9	10	>999 mOhm	> 10 Megohms	ACC
9	11	>999 mOhm	> 10 Megohms	ACC
10	11	>999 mOhm	> 10 Megohms	ACC
1	Ground	>999 mOhm	> 10 Megohms	ACC
2	Ground	>999 mOhm	> 10 Megohms	ACC
3	Ground	>999 mOhm	> 10 Megohms	ACC
4	Ground	>999 mOhm	> 10 Megohms	ACC
5	Ground	>999 mOhm	> 10 Megohms	ACC
6	Ground	>999 mOhm	> 10 Megohms	ACC
7	Ground	>999 mOhm	> 10 Megohms	ACC
8	Ground	>999 mOhm	> 10 Megohms	ACC
9	Ground	>999 mOhm	> 10 Megohms	ACC
10	Ground	>999 mOhm	> 10 Megohms	ACC
11	Ground	>999 mOhm	> 10 Megohms	ACC

2. De-energize equipment.
3. End test.
4. Carefully disassemble test leads to Relay Socket specimen.
5. Clean, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 10:25 A 4-7-00

Dedication Test Plan - RLYSKT-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS	
Test Specimen: Acton Pak MD11 & M011 Relay Sockets	Page 4 of 4

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Item meets requirements for this test plan.

Notes:

Test Engineer/Technician (Printed Name) Jeff Chadwick

Test Engineer/Technician (signature) J. Chadwick Date: 4-7-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) JMP Craig Swenson Date: 4-11-00

QA/QC (signature) Stephen Scott Mose Date: 4-12-2000

Dedication Test Plan - RLYSKT-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS	
Test Specimen: Acton Pak MD11 & M011 Relay Sockets	Page 1 of 4

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) [Signature] Date: 2/23/00

RECOMMENDED EQUIPMENT:

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

ORIGINAL

Record test instrument(s) serial numbers and calibration due

Test Instrument type: AVO BM221 I.D.: BAT-137 Calib. Due dates 3-14-01

Test Instrument type: _____ I.D.: _____ Calib. Due dates _____

Test Instrument type: _____ I.D.: _____ Calib. Due dates _____

SAFETY INSTRUCTIONS: PERSONNEL SAFETY - personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Relay Socket

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>Action Pak</u>	Action Pak	<u>ACC</u>
Model:	<u>MD11</u>	MD11 or M011	<u>ACC</u>
Serial No.:	<u>3</u>	N/A	<u>ACC</u>

Setup the Relay Sockets for testing configuration:

Perform the following tests:

Record: Date /Time of Test Beginning: 4:20P 4-6-00

Record: Room Temperature: 68 °F.

ORIGINAL

Dedication Test Plan - RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 2 of 4

Perform steps below:

1. Insulation Resistance Test

Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>999 mOhm	> 10 Megohms	ACC
1	3	>999 mOhm	> 10 Megohms	ACC
1	4	>999 mOhm	> 10 Megohms	ACC
1	5	>999 mOhm	> 10 Megohms	ACC
1	6	>999 mOhm	> 10 Megohms	ACC
1	7	>999 mOhm	> 10 Megohms	ACC
1	8	>999 mOhm	> 10 Megohms	ACC
1	9	>999 mOhm	> 10 Megohms	ACC
1	10	>999 mOhm	> 10 Megohms	ACC
1	11	>999 mOhm	> 10 Megohms	ACC
2	3	>999 mOhm	> 10 Megohms	ACC
2	4	>999 mOhm	> 10 Megohms	ACC
2	5	>999 mOhm	> 10 Megohms	ACC
2	6	>999 mOhm	> 10 Megohms	ACC
2	7	>999 mOhm	> 10 Megohms	ACC
2	8	>999 mOhm	> 10 Megohms	ACC
2	9	>999 mOhm	> 10 Megohms	ACC
2	10	>999 mOhm	> 10 Megohms	ACC
2	11	>999 mOhm	> 10 Megohms	ACC
3	4	>999 mOhm	> 10 Megohms	ACC
3	5	>999 mOhm	> 10 Megohms	ACC
3	6	>999 mOhm	> 10 Megohms	ACC
3	7	>999 mOhm	> 10 Megohms	ACC
3	8	>999 mOhm	> 10 Megohms	ACC
3	9	>999 mOhm	> 10 Megohms	ACC
3	10	>999 mOhm	> 10 Megohms	ACC
3	11	>999 mOhm	> 10 Megohms	ACC
4	5	>999 mOhm	> 10 Megohms	ACC
4	6	>999 mOhm	> 10 Megohms	ACC
4	7	>999 mOhm	> 10 Megohms	ACC
4	8	>999 mOhm	> 10 Megohms	ACC
4	9	>999 mOhm	> 10 Megohms	ACC
4	10	>999 mOhm	> 10 Megohms	ACC
4	11	>999 mOhm	> 10 Megohms	ACC
5	6	>999 mOhm	> 10 Megohms	ACC
5	7	>999 mOhm	> 10 Megohms	ACC
5	8	>999 mOhm	> 10 Megohms	ACC

Dedication Test Plan - RLYSKT-1 Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS Test Specimen: Acton Pak MD11 & M011 Relay Sockets	Rev. No. 0 Page 3 of 4
---	-------------------------------

Desc. of Terminal	Terminal to Terminal / Ground Desc. of Terminal / Ground	Record Data	Acceptance Criteria	Comments/Deviations
5	8 <i>JE 5 4/11/00</i>	> 999 mOhm	> 10 Megohms	ACC
5	10 <i>JE 5 4/11/00</i>	> 999 mOhm	> 10 Megohms	ACC
5	11	> 999 mOhm	> 10 Megohms	ACC
6	7	> 999 mOhm	> 10 Megohms	ACC
6	8	> 999 mOhm	> 10 Megohms	ACC
6	9	> 999 mOhm	> 10 Megohms	ACC
6	10	> 999 mOhm	> 10 Megohms	ACC
6	11	> 999 mOhm	> 10 Megohms	ACC
7	8	> 999 mOhm	> 10 Megohms	ACC
7	9	> 999 mOhm	> 10 Megohms	ACC
7	10	> 999 mOhm	> 10 Megohms	ACC
7	11	> 999 mOhm	> 10 Megohms	ACC
8	9	> 999 mOhm	> 10 Megohms	ACC
8	10	> 999 mOhm	> 10 Megohms	ACC
8	11	> 999 mOhm	> 10 Megohms	ACC
9	10	> 999 mOhm	> 10 Megohms	ACC
9	11	> 999 mOhm	> 10 Megohms	ACC
10	11	> 999 mOhm	> 10 Megohms	ACC
1	Ground	> 999 mOhm	> 10 Megohms	ACC
2	Ground	> 999 mOhm	> 10 Megohms	ACC
3	Ground	> 999 mOhm	> 10 Megohms	ACC
4	Ground	> 999 mOhm	> 10 Megohms	ACC
5	Ground	> 999 mOhm	> 10 Megohms	ACC
6	Ground	> 999 mOhm	> 10 Megohms	ACC
7	Ground	> 999 mOhm	> 10 Megohms	ACC
8	Ground	> 999 mOhm	> 10 Megohms	ACC
9	Ground	> 999 mOhm	> 10 Megohms	ACC
10	Ground	> 999 mOhm	> 10 Megohms	ACC
11	Ground	> 999 mOhm	> 10 Megohms	ACC

2. De-energize equipment.
3. End test.
4. Carefully disassemble test leads to Relay Socket specimen.
5. Clean, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date / Time of Test End: 8:50 A 4-7-00

Dedication Test Plan - RLYSKT-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS	
Test Specimen: Acton Pak MD11 & M011 Relay Sockets	Page 4 of 4

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Item meets requirements for this test plan.

Notes:

Test Engineer/Technician (Printed Name) JEFF CHWICK

Test Engineer/Technician (signature) J. Chwick Date: 4-6-00

Completed Test Evaluation Approval:
Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) J.P. Craig Swenson Date: 4-11-00

QA/QC (signature) Stephen Scott Mason Date: 4-12-2000

Dedication Test Plan – RLYSKT-1 Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS Test Specimen: Acton Pak MD11 & M011 Relay Sockets	Rev. No. 0 Page 1 of 4
---	-------------------------------

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) [Signature] Date: 2/23/00

RECOMMENDED EQUIPMENT:

Megger Instrument capable of 500 VDC Test Voltage
 MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
 Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

ORIGINAL

Record test instrument(s) serial numbers and calibration due

Test Instrument type: AVO BM2211 I.D.: BAT-137 Calib. Due dates 3-14-01
 Test Instrument type: _____ I.D.: _____ Calib. Due dates _____
 Test Instrument type: _____ I.D.: _____ Calib. Due dates _____

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Relay Socket

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>Action Pak</u>	Action Pak	<u>ACC</u>
Model:	<u>MD11</u>	MD11 or M011	<u>ACC</u>
Serial No.:	<u>2</u>	N/A	<u>ACC</u>

Setup the Relay Sockets for testing configuration:

Perform the following tests:

Record: Date /Time of Test Beginning: 3:40p 4-6-00

Record: Room Temperature: 68 °F.

ORIGINAL

Dedication Test Plan – RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 2 of 4

Perform steps below:

1. Insulation Resistance Test

Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>999 mOhm	> 10 Megohms	ACC
1	3	>999 mOhm	> 10 Megohms	ACC
1	4	>999 mOhm	> 10 Megohms	ACC
1	5	>999 mOhm	> 10 Megohms	ACC
1	6	>999 mOhm	> 10 Megohms	ACC
1	7	>999 mOhm	> 10 Megohms	ACC
1	8	>999 mOhm	> 10 Megohms	ACC
1	9	>999 mOhm	> 10 Megohms	ACC
1	10	>999 mOhm	> 10 Megohms	ACC
1	11	>999 mOhm	> 10 Megohms	ACC
2	3	>999 mOhm	> 10 Megohms	ACC
2	4	>999 mOhm	> 10 Megohms	ACC
2	5	>999 mOhm	> 10 Megohms	ACC
2	6	>999 mOhm	> 10 Megohms	ACC
2	7	>999 mOhm	> 10 Megohms	ACC
2	8	>999 mOhm	> 10 Megohms	ACC
2	9	>999 mOhm	> 10 Megohms	ACC
2	10	>999 mOhm	> 10 Megohms	ACC
2	11	>999 mOhm	> 10 Megohms	ACC
3	4	>999 mOhm	> 10 Megohms	ACC
3	5	>999 mOhm	> 10 Megohms	ACC
3	6	>999 mOhm	> 10 Megohms	ACC
3	7	>999 mOhm	> 10 Megohms	ACC
3	8	>999 mOhm	> 10 Megohms	ACC
3	9	>999 mOhm	> 10 Megohms	ACC
3	10	>999 mOhm	> 10 Megohms	ACC
3	11	>999 mOhm	> 10 Megohms	ACC
4	5	>999 mOhm	> 10 Megohms	ACC
4	6	>999 mOhm	> 10 Megohms	ACC
4	7	>999 mOhm	> 10 Megohms	ACC
4	8	>999 mOhm	> 10 Megohms	ACC
4	9	>999 mOhm	> 10 Megohms	ACC
4	10	>999 mOhm	> 10 Megohms	ACC
4	11	>999 mOhm	> 10 Megohms	ACC
5	6	>999 mOhm	> 10 Megohms	ACC
5	7	>999 mOhm	> 10 Megohms	ACC
5	8	>999 mOhm	> 10 Megohms	ACC

Dedication Test Plan - RLYSKT-1
 Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS
 Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Rev. No. 0

Page 3 of 4

Terminal to Terminal / Ground	Desc. of Terminal	Desc. of Terminal / Ground	Record Data	Acceptance Criteria	Comments/Deviations
	5	7-8	>999 mOhm	> 10 Megohms	ACC
	5	10	>999 mOhm	> 10 Megohms	ACC
	5	11	>999 mOhm	> 10 Megohms	ACC
	6	7	>999 mOhm	> 10 Megohms	ACC
	6	8	>999 mOhm	> 10 Megohms	ACC
	6	9	>999 mOhm	> 10 Megohms	ACC
	6	10	>999 mOhm	> 10 Megohms	ACC
	6	11	>999 mOhm	> 10 Megohms	ACC
	7	8	>999 mOhm	> 10 Megohms	ACC
	7	9	>999 mOhm	> 10 Megohms	ACC
	7	10	>999 mOhm	> 10 Megohms	ACC
	7	11	>999 mOhm	> 10 Megohms	ACC
	8	9	>999 mOhm	> 10 Megohms	ACC
	8	10	>999 mOhm	> 10 Megohms	ACC
	8	11	>999 mOhm	> 10 Megohms	ACC
	9	10	>999 mOhm	> 10 Megohms	ACC
	9	11	>999 mOhm	> 10 Megohms	ACC
	10	11	>999 mOhm	> 10 Megohms	ACC
	1	Ground	>999 mOhm	> 10 Megohms	ACC
	2	Ground	>999 mOhm	> 10 Megohms	ACC
	3	Ground	>999 mOhm	> 10 Megohms	ACC
	4	Ground	>999 mOhm	> 10 Megohms	ACC
	5	Ground	>999 mOhm	> 10 Megohms	ACC
	6	Ground	>999 mOhm	> 10 Megohms	ACC
	7	Ground	>999 mOhm	> 10 Megohms	ACC
	8	Ground	>999 mOhm	> 10 Megohms	ACC
	9	Ground	>999 mOhm	> 10 Megohms	ACC
	10	Ground	>999 mOhm	> 10 Megohms	ACC
	11	Ground	>999 mOhm	> 10 Megohms	ACC

2. De-energize equipment.
3. End test.
4. Carefully disassemble test leads to Relay Socket specimen.
5. Clean, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record:

Date /Time of Test End:

4:08P

4-6-00

Dedication Test Plan - RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 4 of 4

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Item meets requirements for this test plan.

Notes:

[Empty lined area for notes]

Test Engineer/Technician (Printed Name) JEFF CRICK

Test Engineer/Technician (signature) [Signature] Date: 4-6-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 4-11-00


QA/QC (signature) [Signature] Date: 4-12-2000



Action Pak[®]

DC Input, Field Configurable Limit Alarms

Models AP1080, AP1090



Provides Relay Contact Closure(s) at a Preset DC Input Level

- Field Configurable Input Ranges for DC Voltage and Current
- Setpoint(s) Programmable HI or LO
- Exclusive "Dynamic Deadband" Prevents False Trips
- Selectable Failsafe/Latching Operation
- LED Trip Indicators
- Selectable 120/240VAC Operation (9 to 30 VDC Available)
- Lifetime Warranty



DESCRIPTION

Action Pak models AP1080 single setpoint and AP1090 dual setpoint limit alarms offer flexible, wide-ranging DC input capability. Voltage spans from 10mV to 200 volts and current spans from 1mA to 100mA can be field configured. Bipolar inputs are also accepted. Both models offer configurable latching, failsafe and HI/LO operation. The AP1080 and AP1090 also include 0.25%-50% adjustable deadbands and selectable 120/240VAC operation.

DIAGNOSTIC LED

Models AP1080-2000 and AP1090-2000 are equipped with a dual function diagnostic LED. The green center LED indicates line power and input signal status. Active line power is indicated by an illuminated LED. If the center LED is off, check line power and the wiring connection. If the input signal is above 100% full scale, the LED will flash at approximately 8Hz. Below 0%, the flash rate is approximately 4Hz.

OUTPUT SELECTION

The single setpoint AP1080 and the dual setpoint AP1090 provide the following relay outputs:

AP1080	Single Trip (DPDT, 5A)
AP1090	Single/Dual Trip (2 SPDT, 5A)

Setpoint(s) are top accessed 15-turn potentiometer(s) or option "P" provides ten-turn dial(s).

OPERATION

The field configurable AP1080 and AP1090 limit alarm setpoint(s) can be configured for HI, LO, latching and/or failsafe trip operation. Non-latching HI and LO setpoints have respective HI and LO deadbands. In a tripped condition, the setpoint is exceeded and the appropriate red LED will illuminate. The trip will reset only when the process falls below the HI deadband or rises above the LO deadband (see figure 1). To reset a latched setpoint the signal must be in the safe region and the line power turned off for at least 5 seconds. For proper deadband operation, a HI setpoint must always be set above a LO setpoint.

In failsafe operation, the relay is energized when the process is below the HI setpoint or above the LO setpoint (opposite for non-failsafe). In the failsafe mode, the relays go to the tripped condition when the power fails.




Figure 1: Limit alarm operation and effect of deadband(s).

DYNAMIC DEADBAND

LSI circuitry prevents false trips by repeatedly sampling the input. The input must remain beyond the setpoint for 100 milliseconds, uninterrupted, to qualify as a valid trip condition. Likewise, the input must fall outside the deadband and remain there for 100 milliseconds to return the alarm to an untripped condition. This effectively results in a "dynamic deadband"-based on time--in addition to the normal deadband.

OPTIONS

- U** Urethane coating of internal circuitry for protection from corrosive atmospheres.
- P** Top Mounted, Ten-Turn Dial(s) for setpoint adjustment.
- C620** Factory calibration to customer's specifications

CONFIGURATION

The factory presets models AP1080 and AP1090 as follows:

	AP1080	AP1090
Input	0-20mA	0-20mA
Output	Single, DPDT	Dual, SPDT
Trip	HI	A: HI, B: LO
Latching	No	No
Failsafe	Yes	No
Deadband	0.25%	A/B: 0.25%
Power	120VAC	120VAC


For other I/O ranges, remove the four base screws and case to access the configuration switches.

Replace the cover before applying power.


Refer to Figure 4 for configuration.

Input

- Position input jumper "W2" for Current or Voltage inputs.



- Set position 1 of the Mode Selector for Unipolar or Bipolar operation. Unipolar is the default.



Note: A bipolar span selection will double any span from Table 1 (e.g., 10V unipolar span = ±10V bipolar span)

- Using Table 1, configure positions 1 through 4 of the Input Range Selector for the desired maximum setpoint input. Round desired maximum input values to the next highest range (e.g., 0-120V=200V range).

Output

Configure the Mode Selector for the required function. See Figure 5.

Power

Configure the AC jumpers for either 120 or 240 VAC operation. See Figure 6.

CALIBRATION

Note: To maximize thermal stability, final calibration should be performed in the operating installation, allowing approximately 1-2 hours for warmup and thermal equilibrium of the system.

Setpoint. Set deadband at its minimum (20 turns Counter Clockwise) before adjusting the setpoint. With the specified trip voltage or current input applied, adjust setpoint until the relay trips. For HI trip calibration, start with the setpoint above the desired trip. For LO trip calibration, start below the desired trip.

Deadband. Set deadband to its minimum (fully Counter Clockwise). Set setpoint to desired trip. Adjust voltage/current input until relay trips. Readjust deadband to 50% (20 turns Clockwise). Set voltage/current input to desired deadband position. Slowly adjust deadband until relay untrips.

FACTORY ASSISTANCE

For additional information on calibration, operation and installation please contact Action's Technical Services Group. Call toll-free: **800 -767-5726**

Table 1: AP1080-2000 and 1090-2000 Input Ranges

*Voltage	*Current	Input Range Selector
10mV	1mA	
20mV	2mA	
50mV	5mA	
100mV	10mA	
200mV	20mA	
500mV	50mA	
1V	100mA	
2V		
5V		
10V		
20V		
50V		
100V		
200V		

*Note: Use Jumper (W2) to configure either voltage or current input. All unipolar input ranges are zero based.

RELAY PROTECTION AND EMI SUPPRESSION

When switching inductive loads, maximum relay life and transient EMI suppression is achieved using external protection (see Figures 2 & 3). Place all protection devices directly across the load and minimize all lead lengths. For AC inductive loads, place a properly-rated MOV across the load in parallel with a series RC snubber. Use a 0.01 to 0.1µF pulse film capacitor (foil polypropylene recommended) of sufficient voltage, and a 47Ω, 1/2W carbon resistor. For DC inductive loads, place a diode across the load (PRV > DC supply, 1N4006 recommended) with (+) to cathode and (-) to anode (the RC snubber is an optional enhancement)




Figure 2: DC Inductive Loads





Figure 3: AC Inductive Loads

PIN CONNECTIONS*

- AP1080, AP1090
- 1 AC Power (Hot)
- 2 Shield (Gnd)
- 3 AC Power (Neu)
- 4 Input (+)
- 5 Input (-)
- 6 N.O.
- 7 C
- 8 N.C.
- 9 N.O.
- 10 C
- 11 N.C.



Key:
 N.O. = Normally Open
 C = Common
 N.C. = Normally Closed
 DC Power: Pin 1 = (+); Pin 3 = (-)

*Contacts are in the "normal" state when the relay is de-energized.




Figure 4: AP1090-2000 Factory Calibration 0-20mA, Dual HI/LO, Non-Latching, Non-Failsafe




Figure 6: 120/240 VAC Selection




Figure 5: Mode Selection Dual Trip/A: HI, B: LO, Non-Latching, Non-Failsafe
 *Applicable for AP1090-2000, only

SPECIFICATIONS

Inputs

Voltage Input

Range: 10mV to 200V
 Impedance: >100K ohm
 Overvoltage: 400V, max.

Current Input

Range: 1mA to 100mA
 Impedance: 20 ohms, typical
 Overcurrent: 200mA, max.
 Overvoltage: 60VDC

Common Mode (Input to Ground):
 1000VDC, max.

LED Indications

Input Range (Green)
 >100% input: 8Hz flash
 <0% input: 4Hz flash

Setpoint (Red)
 Tripped: Solid red
 Safe: Off

Limit Differentials (Deadbands)

>50mV/5mA: 0.25% to 50% of span
 <50mV/5mA: 1% to 50% of span

Response Time

Dynamic Deadband:
 Relay status will change when proper setpoint/process condition exists uninterrupted for 100msec.
 Normal Mode (analog filtering):
 <250msec, (10-90%)

Setpoint

Effectivity: Setpoint(s) are adjustable over 100% of the selected input span.
 Repeatability (constant temp):
 >50mV/5mA: 0.1% of full scale
 <50mV/5mA: 0.2% of full scale

Stability

Line Voltage: ±0.01%/%, max.
 Temperature: ±0.05% of full scale/°C, max.

Common Mode Rejection

DC to 60Hz: 120dB

Isolation

1000V DC between contacts, input and power

ESD Susceptibility

Meets IEC 801-2, Level 2 (4KV)

Humidity

Operating: 15 to 95% (@45°C)
 Soak: 90% for 24 hours (@65°C)

Temperature Range

Operating: 0 to 60°C (32 to 140°F)
 Storage: -15 to 70°C (5 to 158°F)

Power

Consumption: 2W typical, 5W max.
 Standard: Selectable 120/240VAC (±10%, 50-60Hz)
 Optional: 9 to 30VDC, Inverter-Isolated

Relay Contacts

AP1080: DPDT (2 Form C)
 AP1090: 1 SPDT (1 Form C) - per setpoint
 Current Rating (resistive)
 120VAC: 5A
 240VAC: 2A
 28VDC: 5A

Material: Silver-Cadmium Oxide
 Electrical Life: 10⁵ operations at rated load

Note: External relay contact protection is required for use with inductive loads. See relay protection section (Figure 1 & 2).
 Mechanical Life: 10⁷ operations

Latch Reset Time

5 seconds

Weight

AP1080 0.46lbs
 AP1090 0.62lbs

Agency Approvals

CSA certified per standard C22.2, No. M1982 (File No. LR42272-8,9)
 UL recognized per standard UL508, (File No. E99775)

MOUNTING

All Action Paks feature plug-in installation. Models AP1080 and AP1090 use an 11-pin base, either molded socket (M011) or DIN rail socket (MD11).

ORDERING INFORMATION




Specify:

1. Model: AP1080-2000, AP1090-2000
2. Options: U, P (see text)
3. Line Power (see specs.)


(All power supplies are transformer-isolated from the internal circuitry.)

DIMENSIONS

Dimensions are in millimeters (inches)



M011 (Track/Surface)



MD11 (DIN Rail)

All Prices and Specifications subject to change without notice

For order entry, applications or customer service assistance, call toll-free 800-767-5726

■ **United States**

Action Instruments, Inc.
 8601 Aero Drive
 San Diego, CA 92123
 Phone: 619-279-5726
 FAX: 619-279-6290
 721-0479-00-J 12/98



Dedication Test Plan – RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 1 of 4

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) [Signature] Date: 2/23/00

RECOMMENDED EQUIPMENT:

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

ORIGINAL

Record test instrument(s) serial numbers and calibration due

Test Instrument type: Avo BM221 I.D.: BAT 137 Calib. Due dates 3-14-01

Test Instrument type: _____ I.D.: _____ Calib. Due dates _____

Test Instrument type: _____ I.D.: _____ Calib. Due dates _____

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)Test Specimen Description: Relay Socket

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>Action Pak</u>	Action Pak	<u>Acc</u>
Model:	<u>MD 11</u>	MD11 or M011	<u>Acc</u>
Serial No.:	<u>1</u>	N/A	<u>Acc</u>

Setup the Relay Sockets for testing configuration:

Perform the following tests:

Record: Date /Time of Test Beginning: 3:00 p.m. 4-6-00Record: Room Temperature: 68 °F.**ORIGINAL
ORIGINAL**

Dedication Test Plan - RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 2 of 4

Perform steps below:

1. Insulation Resistance Test

Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	> 999 Mohm	> 10 Megohms	Acc
1	3	> 999 Mohm	> 10 Megohms	Acc
1	4	> 999 Mohm	> 10 Megohms	Acc
1	5	> 999 Mohm	> 10 Megohms	Acc
1	6	> 999 Mohm	> 10 Megohms	Acc
1	7	> 999 Mohm	> 10 Megohms	Acc
1	8	> 999 Mohm	> 10 Megohms	Acc
1	9	> 999 Mohm	> 10 Megohms	Acc
1	10	> 999 Mohm	> 10 Megohms	Acc
1	11	> 999 Mohm	> 10 Megohms	Acc
2	3	> 999 Mohm	> 10 Megohms	Acc
2	4	> 999 Mohm	> 10 Megohms	Acc
2	5	> 999 Mohm	> 10 Megohms	Acc
2	6	> 999 Mohm	> 10 Megohms	Acc
2	7	> 999 Mohm	> 10 Megohms	Acc
2	8	> 999 Mohm	> 10 Megohms	Acc
2	9	> 999 Mohm	> 10 Megohms	Acc
2	10	> 999 Mohm	> 10 Megohms	Acc
2	11	> 999 Mohm	> 10 Megohms	Acc
3	4	> 999 Mohm	> 10 Megohms	Acc
3	5	> 999 Mohm	> 10 Megohms	Acc
3	6	> 999 Mohm	> 10 Megohms	Acc
3	7	> 999 Mohm	> 10 Megohms	Acc
3	8	> 999 Mohm	> 10 Megohms	Acc
3	9	> 999 Mohm	> 10 Megohms	Acc
3	10	> 999 Mohm	> 10 Megohms	Acc
3	11	> 999 Mohm	> 10 Megohms	Acc
4	5	> 999 Mohm	> 10 Megohms	Acc
4	6	> 999 Mohm	> 10 Megohms	Acc
4	7	> 999 Mohm	> 10 Megohms	Acc
4	8	> 999 Mohm	> 10 Megohms	Acc
4	9	> 999 Mohm	> 10 Megohms	Acc
4	10	> 999 Mohm	> 10 Megohms	Acc
4	11	> 999 Mohm	> 10 Megohms	Acc
5	6	> 999 Mohm	> 10 Megohms	Acc
5	7	> 999 Mohm	> 10 Megohms	Acc
5	8	> 999 Mohm	> 10 Megohms	Acc

Dedication Test Plan - RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 3 of 4

Desc. of Terminal	Terminal to Terminal / Ground Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
5	8 <i>SWP</i>	> 999 Mohm	> 10 Megohms	Acc
5	10	> 999 Mohm	> 10 Megohms	Acc
5	11	> 999 Mohm	> 10 Megohms	Acc
6	7	> 999 Mohm	> 10 Megohms	Acc
6	8	> 999 Mohm	> 10 Megohms	Acc
6	9	> 999 Mohm	> 10 Megohms	Acc
6	10	> 999 Mohm	> 10 Megohms	Acc
6	11	> 999 Mohm	> 10 Megohms	Acc
7	8	> 999 Mohm	> 10 Megohms	Acc
7	9	> 999 Mohm	> 10 Megohms	Acc
7	10	> 999 Mohm	> 10 Megohms	Acc
7	11	> 999 Mohm	> 10 Megohms	Acc
8	9	> 999 Mohm	> 10 Megohms	Acc
8	10	> 999 Mohm	> 10 Megohms	Acc
8	11	> 999 Mohm	> 10 Megohms	Acc
9	10	> 999 Mohm	> 10 Megohms	Acc
9	11	> 999 Mohm	> 10 Megohms	Acc
10	11	> 999 Mohm	> 10 Megohms	Acc
1	Ground	> 999 Mohm	> 10 Megohms	Acc
2	Ground	> 999 Mohm	> 10 Megohms	Acc
3	Ground	> 999 Mohm	> 10 Megohms	Acc
4	Ground	> 999 Mohm	> 10 Megohms	Acc
5	Ground	> 999 Mohm	> 10 Megohms	Acc
6	Ground	> 999 Mohm	> 10 Megohms	Acc
7	Ground	> 999 Mohm	> 10 Megohms	Acc
8	Ground	> 999 Mohm	> 10 Megohms	Acc
9	Ground	> 999 Mohm	> 10 Megohms	Acc
10	Ground	> 999 Mohm	> 10 Megohms	Acc
11	Ground	> 999 Mohm	> 10 Megohms	Acc

2. De-energize equipment.
3. End test.
4. Carefully disassemble test leads to Relay Socket specimen.
5. Clean, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record:

Date /Time of Test End: 04-06-00 4:30 p.m.

Dedication Test Plan - RLYSKT-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016C-TP-016CS

Test Specimen: Acton Pak MD11 & M011 Relay Sockets

Page 4 of 4

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Test was acceptable

Michael Cram

04-06-00

Notes:

Test Engineer/Technician (Printed Name) Michael Cram

Test Engineer/Technician (signature) *Michael Cram* Date: 04-06-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *[Signature]* Date: 4-11-00

QA/QC (signature) *Stephen Scott Moss* Date: 4-12-2000

CGI REMOVAL/REPLACEMENT LOG

Equipment ID No.	Equipment Description	Removd By*	Date	Removal Verified By*	Date	Replaced By*	Date	Replacement Verified By*	Date
5X	MLO Hoist Weight System Trip/Relay (Action Pak AP1080-2000)	B. W.	4-13-00	SRL	4-13-00	B. W.	4-13-00	SRL	4-13-00

Personnel Identification Section

Title	Printed Name	Signature	Initials
GC Electrician	Stephen R Conley	<i>Stephen R Conley</i>	SRL
J.W.	BRIAN W. WHISTLER	<i>Brian Whistler</i>	B.W.W

Remarks:

* Complete Title, Printed Name, Signature and Initials in Personnel Identification Section

SNF-6315, Rev. 0

Dedication Test Plan - RLY-3	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016C-TP-016C	
Test Specimen: Acton Pak AP1080-2000 Relay	Page 1 of 5

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) *JUP Craig Swenson* Date: 1-31-00

RECOMMENDED EQUIPMENT:

Power Supply capable of 5 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

ORIGINAL

Record test instrument(s) serial numbers and calibration due

Test Instrument type: PREMA MEM I.D.: SIN 10012 Calib. Due dates 3-25-00

Test Instrument type: HP3457A I.D.: BAT-123 Calib. Due dates 7-29-00

Test Instrument type: HP3457A I.D.: BAT-124 Calib. Due dates 7-30-00

AVO BM80/2 MEGGER, 6410-889/000100/5345 2-9-01
FLUKE 787 DMM, BAT-107 5-28-00

SAFETY INSTRUCTIONS: PERSONNEL SAFETY - personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)


Test Specimen Description: Relay

Record the following identification information:


Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>ACTION PAK</u>	Action Pak	<u>ACCEPT</u>
Model:	<u>1080-2000</u>	AP1080-2000	<u>ACCEPT</u>
Contact Configuration:	<u>DPDT</u>	DPDT	<u>ACCEPT</u>
Serial No.:	<u>38506</u>	N/A	

Setup the Relay(s) for testing configuration:

Input Range Selector, adjust selector for 10mA (5X) current ranges as follows:



ORIGINAL



STANDARD TEST SETUP FOR MEASURING
RESISTANCE ACROSS COMPONENTS.

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A CGI No. CGI-SNF-D-MHM-016A

Page 1 of 7

Title: P2, P53, P62, & P63 Interlocks - Sensotec Load Cell

Handwritten initials/signature

Section 1 Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
Part Description: <u>N/A</u>		
ORIGINAL		
End Use Description: <u>N/A</u>		

Section 2a Component Information

Equipment No.: <u>LCMHR1X, LCMHR2X, LCMHR1Y, LCMHR2Y</u>	Specification No.: <u>Ederer F-2566, Foster Wheeler MJX-SDX 452656</u>	Manufacturer: <u>Sensotec</u>	Past P.O. No.: <u>N/A</u>
Manufacturer's Part/Model No.: <u>RM/C717-01</u>	Equipment Supplier (if different from manufacturer): <u>ALSTROM, Foster Wheeler</u>	Equip. Supplier's Part No.: <u>N/A</u>	

Component Description: **These load cells (LCMHR1X, LCMHR2X, LCMHR1Y, LCMHR2Y) measure the load (weight) on the ropes that support the MCO Hoist, they provide an output signal based upon that loading that is used for the P2, P53, P62 and P63 interlocks.**

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate w/ project CGI Engineer or BTR)? YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate w/ project CGI Engineer or BTR)? YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)
2. List of Candidate qualified suppliers or ISO 9000 suppliers N/A
3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

CGI Determination Questions:

- #1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)
 - #2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)
 - #3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)
- All three criteria have been satisfied. The Item meets the definition of commercial grade.**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 2 of 7

ECN No. N/A CGI No. CGI-SNF-D-MHM-016A

Title: P2, P53, P62, & P63 Interlocks - Sensotec Load Cell

Section 2d Reason for Dedication		
The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):		
<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.	
<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.	
<input checked="" type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.	
<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.	
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)	
Section 3 Failure Effects Evaluation		
A. Part/Component Safety Function: The P2 interlock serves to prevent the MHM from leaving a storage tube without replacing the tube plug by determining when the MCO Hoist weight is more than the min. grapple and tube plug weight and when the MCO Hoist weight is less than the max. grapple only weight. The P53 interlock ensures the MCO Hoist is not lowered unless the weight is above the min. grapple weight or above the min. grapple plus MCO weight w/grapple jaws closed unless the grapple is in the seating zone. The P62 interlock ensures that the MCO cannot be hoisted when MCO weight is detected and jaws are not closed. The P63 interlock ensures that the MCO Hoist cannot be raised if the MCO weight is exceeded. These load cells provide input to initiate the action as stated in the interlocks.		
B. Part/Component Functional Mode:		
Safety Function #1:	<input checked="" type="checkbox"/> Active <input type="checkbox"/> Passive	
Safety Function #2:	<input type="checkbox"/> Active <input type="checkbox"/> Passive	
Safety Function #3:	<input type="checkbox"/> Active <input type="checkbox"/> Passive	
<p>Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function</p> <p>Passive - Change of state is not required for the component to perform its safety function</p>		
C. Host Component Safety Function (if applicable): <u>N/A</u>		
D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1): Failure to properly function and ultimately actuate output devices based on input from the weight of the MCO Hoist weight and the weight it carries results in movement of the MHM or raising of the MCO hoist at improper times.		
Section 4 Environmental & Natural Phenomena Hazard Design		
Environmental Qualification Required:	If yes: Environmental Qualification Requirements	
Yes <input type="checkbox"/>	Limiting Environmental Conditions:	
No <input checked="" type="checkbox"/>	Required Safety Functions:	
	Qualification Period:	
Natural Phenomena Hazard (NPH) Design Required:	If yes: NPH Design Requirements	
Yes <input type="checkbox"/>	Performance Category	
No <input checked="" type="checkbox"/>	NPH Design Req'ts:	
	Required Safety Functions:	
Section 5 Component Functional Classification		
<input checked="" type="checkbox"/> Safety Class (SC)	<input type="checkbox"/> General Service (GS)	<input type="checkbox"/> Safety Significant (SS)
If part/component classification is different from host component/system, document basis. <u>N/A</u>		
Sections 6 and 7 (Reserved)		
Section 8 References (for Functional Classification)		
National Codes/Standards: <u>N/A</u>		
Safety Analysis Report (SAR): <u>HNF-3672, Rev. 0</u>		
Drawings: <u>Ederer, Inc. EB-33056, Sht 11, 12; H-2-827174 Sht 10, 21, 22, 23, 25</u>		
Vendor Manual/Manufacturer/Supplier Information: <u>Sensotec Manual</u>		
Other: <u>ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998</u>		

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 3 of 7

ECN No. N/A CGI No. CGI-SNF-D-MHM-016A
Title: P2, P53, P62, & P63 Interlocks - Sensotec Load Cell

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acc Meth	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Sensotec	1, IN	X	
Model	RM/C717-01	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
N/A				
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Load Cell Circuit Resistance (from lead to body of load cell)	>100 Megohms -0% +5% <<Do not Meggar or Hi-Pot>>	1, T		X
Load Cell Resistance (from - signal to + signal)	350-700 Ohms ± 5%	1, T		X
Load Cell Resistance (from - Excitation to + Excitation)	350-700 Ohms ± 5%	1, T		X
Operation	During operation of the hoist, determine the output of the load cell and reading compared to the load placed upon it. Deviation allowed @ meter ± 5%	1, T		X
4. Notes and Legend: Rev. 1: Pages 3, 5, 6 - Rev'd performance CC/Acc Crit. to ">100 Megohms -0% +5%"; added performance CC/Acc Crit. for "Load Cell Resistance" 2 lines.		Acceptance Method (Acc Meth): 1. Special Test and Inspection 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 1. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:
 Designated Engineer: [Signature]
 Design Authority: Wang Swengon 7/600
 QA Engineer: [Signature] 3/8/00 T2 ANDERSON

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 4 of 7

ECN No. N/A CGI No. CGI-SNF-D-MHM-016A
Title: P2, P53, P62, & P63 Interlocks – Sensotec Load Cell

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.	X	Failure to provide output due to opening of sensor leads
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.		
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Binding results in failure to transmit the correct signal
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
1.			
2.			
3.			
4.			
5.			

Commercial Grade Item Upgrade Dedication Form		Rev. No. 1
ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-MHM-016A</u>	Page 5 of 7
Title: P2, P53, P62, & P63 Interlocks - Sensotec Load Cell		

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1			
Item Description: Load Cells		Equip #: LCMHR1X, LCMHR2X, LCMHR1Y, LCMHR2Y	
System #: MHM		Model #: RM/C717-01	
Manufacturer (Address/Phone): (888) 736 - 7683 Sensotec 2080 Arlingate Lane, Columbus, Ohio 43228 Phone. # (614) 850-5000 Fax (614) 850-1111		Supplier (Address/Phone): email: sales@sensotec.com www.loadcell.com	
SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.			
Insp	Test	Post-Test	Item
X			1. Manufacturer
X			2. Model
	X		3. Circuit resistance
	X		4. Load Cell Resistance (signal)
	X		5. Load Cell Resistance (excitation)
	X		7. Operation
SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)			
Characteristic: Manufacturer		Sample Size*: 100%	
Acceptance Criteria: Sensotec			
Receipt Inspection Plan / Report #: CGI-SNF-D-MHM-016A-TP-016AX1, AX2, AY1, AY2			
Characteristic: Model		Sample Size*: 100%	
Acceptance Criteria: RM/C717-01			
Receipt Inspection Plan / Report #: TP-016AX1, AX2, AY1, AY2			
SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)			
Characteristic for Test: Circuit Resistance <<Do not Meggar or Hi-Pot>>		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened	
Acceptance Criteria: >100 Megohms -0% +5%			
Actual Test Value: See TP		Test Plan and Report #: TP-016 AX1, AX2, AY1, AY2	
Characteristic for Test: Load Cell Resistance (+signal to -signal)		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened	
Acceptance Criteria: 350-700 Ohms ± 5%			
Actual Test Value: See TP		Test Plan and Report #: TP016AX1, AX2, AY1, AY2	
Characteristic for Test: Load Cell Resistance (+excitation to -excitation)		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened	
Acceptance Criteria: 350-700 Ohms ± 5%			
Actual Test Value: See TP		Test Plan and Report #: TP-016AX1, AX2, AY1, AY2	
Characteristic for Test: Operation		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened	
Acceptance Criteria: During operation of the hoist, determine the output of the load cell and reading compared to the load placed upon it. Deviation allowed @ meter ± 5%			
Actual Test Value: See CTP		Test Plan and Report #: CSDC(w379)-015-059 & 060	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A CGI No. CGI-SNF-D-MHM-016A

Page 6 of 7

Title: P2, P53, P62, & P63 Interlocks - Sensotec Load Cell

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Load Cells

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Sensotec	X		1, IN	TP-016 AX1, AY1, AX2, AY2	NA	4	0	XWEST	LARRY W. PAICE <i>[Signature]</i>	4/10/00
Model	RM/C717-01	X		1, IN							
Circuit Resistance <<Do not Meggar or Hi-Pot>>	>100 Megohms -0% +5%		X	1, T							
Load Cell Resistance (+signal to -signal)	350-700 Ohms ± 5%		X	1, T							
Load Cell Resistance (+excitation to -excitation)	350-700 Ohms ± 5%		X	1, T							
Operation	During operation of the hoist, determine the output of the load cell and reading compared to the load placed upon it. Deviation allowed @ meter ± 5%		X	1, T	CTP * CSB(W379) -015- 11-059 -060						

2. Disposition Of Unverified or Failed Critical Characteristics

Critical Characteristic	Disposition

3. Signature Indicates All Critical Characteristics Verified Satisfactory or Acceptably Dispositioned and Commercial Grade Dedication Is Satisfactory And Complete.

See Test Plans TP-016 AX1, AY1, AX2, AY2 cited above. Testing Agency Approval: <u>NR CES 4/12/00</u> Date: <u>4/12/00</u>				BUYER VERIFICATION Design Authority: <u>CES [Signature]</u> Date: <u>4/12/00</u>			
Testing Agency QA Engineer: <u>NR CES 4/12/00</u> Date: <u>4/12/00</u>				QA Engineer: <u>Stephen Scott [Signature]</u> Date: <u>4-20-2000</u>			

* CTP CSB(W379)-015-11-059 & -060 available as Startup Test record. Excerpt attached. CES 4/12/00

SNF-6315, Rev. 0

Page 523

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A CGI No. CGI-SNF-D-MHM-016A

Page 7 of 7

Title: P2, P53, P62, & P63 Interlocks - Sensotec Load Cell

SNF-6315, Rev. 0

SECTION 6 CONTACTS / PHONE NUMBERS

	Name	Phone
Design Authority	<u>CRAIG SWENSON</u>	<u>376-0288</u>
QA		
QC		
Cog - Engineer		
CGI Engineer		
Procurement Engineer		
Other		

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents		For Critical Characteristics
	Drawings:	
<input checked="" type="checkbox"/>	Manuals (specify type & number): <u>Sensotec Manual</u>	<u>All</u>
	Design Calculations	
	Installation Instructions	
	Operation Instructions	
	Calibration Instructions	
	Manufacturer's Recommended Spare Parts List	
	Other:	
Procurement Documents		For Critical Characteristics
	Certificate of Conformance/Compliance	
	Seismic Qualification Certificate	
	Environmental Qualification Certificate	
	Test Report (s):	
	Inspection Report (s):	
	CMTRs for ASME Pressure Retaining Materials	
	Valve Seat Leakage Report	
	Weld Record	
	Material Traceability Record	
<input checked="" type="checkbox"/>	Other: <u>CSB (W379)-015-11-059 & 060</u>	<u>Operational CCs</u>

MHM WEIGHT SYSTEM LOAD TEST FOR X AND Y CHANNELS

Attachment A

		3964 .Grappel + test block Total load						
	Meter readings	Force applied	Total load	X ch	Y ch	X error	Y error	X-Y diff
Increasing weight	216	2160	6124	5911	5549	213	575	362
	421	4210	8174	7916	7514	258	660	402
	620	6200	10164	9896	9463	268	701	433
	821	8210	12174	11910	11480	264	694	430
	1020	10200	14164	13914	13449	250	715	465
	1215	12150	16114	15910	15450	204	664	460
	1410	14100	18064	17910	17425	154	639	485
	1605	16050	20014	19920	19420	94	594	500
	1800	18000	21964	21920	21400	44	564	520
	1992	19920	23884	23915	23350	-31	534	565
	2195	21950	25914	25920	25350	-6	564	570
	2385	23850	27814	27945	27320	-131	494	625
	2580	25800	29764	29930	29311	-166	453	619
	2765	27650	31614	31906	31250	-292	364	656
	Decreasing weight	2510	25100	29064	29890	29215	-826	-151
2312		23120	27084	27896	27244	-812	-160	652
2105		21050	25014	25699	25076	-685	-62	623
1915		19150	23114	23780	23170	-666	-56	610
1728		17280	21244	21915	21270	-671	-26	645
1524		15240	19204	19855	19242	-651	-38	613
1335		13350	17314	17875	17310	-561	4	565
1138		11380	15344	15791	15244	-447	100	547
950		9500	13464	13899	13362	-435	102	537
740		7400	11364	11800	11260	-436	104	540
550		5500	9464	9875	9340	-411	124	535
370		3700	7664	7850	7399	-186	265	451
170		1700	5664	5895	5460	-231	204	435

ALL readings are in pounds

DLW 6/24/99

Direction	Force	Total	X	X-Error	Y	Y-Error	Avg Error
Inc	2160	6124	5911	3.48%	5549	9.39%	6.43%
Inc	4210	8174	7916	3.16%	7514	8.07%	5.62%
Inc	6200	10164	9896	2.64%	9463	6.90%	4.77%
Inc	8210	12174	11910	2.17%	11480	5.70%	3.93%
Inc	10200	14164	13914	1.77%	13449	5.05%	3.41%
Inc	12150	16114	15910	1.27%	15450	4.12%	2.69%
Inc	14100	18064	17910	0.85%	17425	3.54%	2.19%
Inc	16050	20014	19920	0.47%	19420	2.97%	1.72%
Inc	18000	21964	21920	0.20%	21400	2.57%	1.38%
Inc	19920	23884	23915	-0.13%	23350	2.24%	1.05%
Inc	21950	25914	25920	-0.02%	25350	2.18%	1.08%
Inc	23850	27814	27945	-0.47%	27320	1.78%	0.65%
Inc	25800	29764	29930	-0.56%	29311	1.52%	0.48%
Inc	27650	31614	31906	-0.92%	31250	1.15%	0.11%
Average Error over Span (Inc):							2.54%
Dec	25100	29064	29890	-2.84%	29215	-0.52%	-1.68%
Dec	23120	27084	27896	-3.00%	27244	-0.59%	-1.79%
Dec	21050	25014	25699	-2.74%	25076	-0.25%	-1.49%
Dec	19150	23114	23780	-2.88%	23170	-0.24%	-1.56%
Dec	17280	21244	21915	-3.16%	21270	-0.12%	-1.64%
Dec	15240	19204	19855	-3.39%	19242	-0.20%	-1.79%
Dec	13350	17314	17875	-3.24%	17310	0.02%	-1.61%
Dec	11380	15344	15791	-2.91%	15244	0.65%	-1.13%
Dec	9500	13464	13899	-3.23%	13362	0.76%	-1.24%
Dec	7400	11364	11800	-3.84%	11260	0.92%	-1.46%
Dec	5500	9464	9875	-4.34%	9340	1.31%	-1.52%
Dec	3700	7664	7850	-2.43%	7399	3.46%	0.52%
Dec	1700	5664	5895	-4.08%	5460	3.60%	-0.24%
Average Error over Span (Dec):							-1.28%

Max. Deviation Allowed = 5% over span

X-Error = (Total-X)/Total

Y-Error = (Total-Y)/Total

Avg Error = (YError + XError)/2

Table is
BASED upon att A

John 4/12/00


Dedication Test Plan – IST-LC-1
 Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX1
 Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1X

ORIGINAL

Rev. No. 0

Page 1 of 6

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				Cog. Eng	DA	QA Post Review*
						 3/12/00 NO CHANGE

*QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX1

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1X

Page 2 of 6

In-Situ Test Procedure

ORIGINAL

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) JWP Living Swenson Date: 3/6/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Balthaven	Michael Cram	MRC
Electrician	JWEBERHART	PCE	JWE Eberhart	JWE
Electrician Quality Control	Stephen R. Couley	PCE	Stephen R Couley	SRC
Design Authority Representative	E.R. Kaller	XWest	ER Kaller	ERK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Insulation Resistance Instrument capable of measuring >100 megohms

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP3457A I.D.: BAT 123 Calib. Due date: 7-29-00

Test Instrument type: PROTO 6106 I.D.: 029E/009 Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX1

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1X

Page 3 of 6

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.

2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	LCMHR1X	Acc
Manufacturer:	YES	Sensotec	Acc
Model:	YES	FM/C717-01	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 03-09-00 9:00am

Record: Room Temperature: 70 °F.

3.2 Insulation Resistance Test

3.2.1 Setup the test equipment and Load Cell specimen for insulation resistance testing.

**Warning: Do not use a high-voltage Hypot tester or Megger type tester!
Test Equipment must apply no more than 20 VDC**

3.2.2 Disconnect wires from terminals on TB2 on the System 1 J-Box, record and verify on the Lifted Lead Log.

3.2.3 Apply a maximum of 20 VDC via Ohmmeter between wire No. LC11X from the load cell at the System 1 J-box and the metal casing of the load cell, LCMHR1X. Record the resistance.

3.2.4 Then connect Ohmmeter between wire No. LC12X from the load cell at the System 1 J-box and the metal casing of the load cell, LCMHR1X. Record the resistances.

3.2.5 Then connect Ohmmeter between wire No. LC15X from the load cell at the System 1 J-box and the metal casing of the load cell, LCMHR1X. Record the resistances.

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX1

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1X

Page 4 of 6

3.2.6 Then connect Ohmmeter between wire No. LC16X from the load cell at the System 1 J-box and the metal casing of the load cell, LCMHR1X. Record the resistances.

Terminal to Terminal / Ground				
Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
LC11X	Load Cell Housing	>100Gohm	>100 Megohms -0% +5%	Acc
LC12X	Load Cell Housing	>100Gohm	>100 Megohms -0% +5%	Acc
LC15X	Load Cell Housing	>100Gohm	>100 Megohms -0% +5%	Acc
LC16X	Load Cell Housing	>100Gohm	>100 Megohms -0% +5%	Acc

3.2.4 Connect Ohmmeter between wire nos. LC11X and LC12X. Record the resistance. Then connect Ohmmeter between wire nos. LC15X and LC16X. Record the resistance.

Terminal to Terminal / Ground				
Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
LC11X	LC12X	350.2 ohms	350-700 Ohms \pm 5%	Acc
LC15X	LC16X	350.2 ohms	350-700 Ohms \pm 5%	Acc

3.2.5 De-energize and remove the test equipment.

3.3 Terminate the test.

3.3.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.

3.3.2 Retorque the terminals to 12 in-pounds.

3.3.3 Remove lockout/tagout and restore system to normal.

3.3.3 Record: Date /Time of Test End: 03-09-00 10:30 a.m.

4.0 References

4.1 Elementary Wiring Drawings: EB-33056 Sheet 11

4.2 Wiring Diagram: 363A0033 Sheet 9

Dedication Test Plan – IST-LC-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX1	
Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1X	Page 5 of 6

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Devices under test has passed all parameters.

Michael Crane
03-09-00

Notes:

Certified Instrumentation Technician (signature) Michael D Crane Date: 03-09-00
Reviewed By: J. Coombs 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/9/00} [Signature] Date: 3-9-00

QA/QC (signature) [Signature] Date: 3/13/00
T ZANDERSON

LIFTED LEAD LOG

Junction Box: System 1 J-Box TB-2

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-33056	11	LC11X	LCMHR1X	TB2-1	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	LC12X	LCMHR1X	TB2-5	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	LC16X	LCMHR1X	TB2-3	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	LC15X	LCMHR1X	TB2-4	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	Jumper	LCMHR1X	TB2-1 to TB2-2	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	Jumper	LCMHR1X	TB2-5 to TB2-6	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00

Remarks:

SNF-6315, Rev. 0

Page 532

Dedication Test Plan - IST-LC-1

ORIGINAL


Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX2

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2X

Page 1 of 6

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				Cog. Eng	DA	QA Post Review*
						 3/13/00 NO CHANGES

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX2

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2X

Page 2 of 6

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

YMP Craig Swenson

Date:

*3/6/00***TEST PERSONNEL REQUIRED:**

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	<i>Michael Cram</i>	<i>MRC</i>
Electrician	<i>JW EISENHAUT</i>	<i>PCE</i>	<i>JW Eisenhaut</i>	<i>JWE</i>
Electrician Quality Control	Stephen R. Conley	<i>PCE</i>	<i>Stephen R. Conley</i>	<i>JRC</i>
Design Authority Representative	E.R. Kahler	<i>XWest</i>	<i>ER Kahler</i>	<i>ERK</i>
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Insulation Resistance Instrument capable of measuring >100 megohms

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 7-29-00Test Instrument type: PROTO 6106 I.D.: 029E/009 Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX2

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2X

Page 3 of 6

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

- 1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.
- 2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	LCMHR2X	Acc
Manufacturer:	YES	Sensotec	Acc
Model:	YES	FM/C717-01	Acc.
Serial No./Lot No./Date Code:	OK	N/A	Acc

- 3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 03-09-00 9:00 a.m.
 Record: Room Temperature: 70 °F.

3.2 Insulation Resistance Test

- 3.2.1 Setup the test equipment and Load Cell specimen for insulation resistance testing.

Warning: Do not use a high-voltage Hypot tester or Megger type tester!
Test Equipment must apply no more than 20 VDC

- 3.2.2 Disconnect wires from terminals on TB2 on the System 1 J-Box, record and verify on the Lifted Lead Log.
- 3.2.3 Apply a maximum of 20 VDC via Ohmmeter between wire No. LC21X from the load cell at the System 1 J-box and the metal casing of the load cell, LCMHR2X. Record the resistance.
- 3.2.4 Then connect Ohmmeter between wire No. LC22X from the load cell at the System 1 J-box and the metal casing of the load cell, LCMHR2X. Record the resistances.
- 3.2.5 Then connect Ohmmeter between wire No. LC25X from the load cell at the System 1 J-box and the metal casing of the load cell, LCMHR2X. Record the resistances.

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX2

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2X

Page 4 of 6

3.2.6 Then connect Ohmmeter between wire No. LC26X from the load cell at the System 1 J-box and the metal casing of the load cell, LCMHR2X. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
LC21X	Load Cell Housing	> 100 Gohm	>100 Megohms -0% +5%	Acc
LC22X	Load Cell Housing	> 100 Gohm	>100 Megohms -0% +5%	Acc
LC25X	Load Cell Housing	> 100 Gohm	>100 Megohms -0% +5%	Acc
LC26X	Load Cell Housing	> 100 Gohm	>100 Megohms -0% +5%	Acc

3.2.4 Connect Ohmmeter between wire nos. LC21X and LC22X. Record the resistance. Then connect Ohmmeter between wire nos. LC25X and LC26X. Record the resistance.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
LC21X	LC22X	350.2 ohms	350-700 Ohms \pm 5%	Acc
LC25X	LC26X	350.2 ohms	350-700 Ohms \pm 5%	Acc

3.2.5 De-energize and remove the test equipment.

3.3 Terminate the test.

3.3.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.

3.3.2 Retorque the terminals to 12 in-pounds.

3.3.3 Remove lockout/tagout and restore system to normal.

3.3.3 Record: Date /Time of Test End: 03-07-00 10:35 a.m.

4.0 References

4.1 Elementary Wiring Drawings: EB-33056 Sheet 11

4.2 Wiring Diagram: 363A0033 Sheet 9

Dedication Test Plan - IST-LC-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AX2	
Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2X	Page 5 of 6

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Devices under test have passed all parameters

Michael D. Cron
03-09-00

Notes:

Certified Instrumentation Technician (signature) *Michael D. Cron* Date: *03-09-00*
Reviewed By: J. Casals *3-10-00*

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{*3/9/00*} *[Signature]* Date: *3-9-00*

QA/QC (signature) *[Signature]* Date: *3/13/00*
TZ ANDERSON

LIFTED LEAD LOG

Junction Box: System 1 J-Box TB-2


Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-33056	11	LC21X	LCMHR2X	TB2-2	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	LC22X	LCMHR2X	TB2-6	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	LC26X	LCMHR2X	TB2-3	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	LC25X	LCMHR2X	TB2-4	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	Jumper	LCMHR2X	TB2-1 to TB2-2	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	11	Jumper	LCMHR2X	TB2-5 to TB2-6	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00

Remarks:

SNF-6315, Rev. 0

Dedication Test Plan – IST-LC-1 Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY1 Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1Y	ORIGINAL	Rev. No. 0 Page 1 of 6
--	----------	-------------------------------

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				Cog. Eng	DA	QA Post Review*
						<div style="text-align: right;">  3/17/00 NO CHANGES </div>

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY1

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1Y

Page 2 of 6

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

[Signature] Date: 3/6/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>[Signature]</i>	MRC
Electrician	J W EBERHART	PCE	<i>[Signature]</i>	JWE
Electrician Quality Control	Stephen R. Cowley	PCE	<i>[Signature]</i>	SRK
Design Authority Representative	E.R. Kahler	XWest	<i>[Signature]</i>	ERK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Insulation Resistance Instrument capable of measuring >100 megohms

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: PR906106 I.D.: 029E1009 Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY1

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1Y

Page 3 of 6

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

- 1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.
- 2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	LCMHR1Y	Acc
Manufacturer:	YES	Sensotec	Acc
Model:	YES	FM/C717-01	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

- 3.0 Perform the following testing steps:

- 3.1 Record: Date /Time of Test Beginning: 03-09-00 10:35 a.m.
Record: Room Temperature: 68 °F.

- 3.2 Insulation Resistance Test

- 3.2.1 Setup the test equipment and Load Cell specimen for insulation resistance testing.

**Warning: Do not use a high-voltage Hypot tester or Megger type tester!
Test Equipment must apply no more than 20 VDC**

- 3.2.2 Disconnect wires from terminals on TB2 on the System 2 J-Box, record and verify on the Lifted Lead Log.
- 3.2.3 Apply a maximum of 20 VDC via Ohmmeter between wire No. LC11Y from the load cell at the System 2 J-box and the metal casing of the load cell, LCMHR1Y. Record the resistance.
- 3.2.4 Then connect Ohmmeter between wire No. LC12Y from the load cell at the System 2 J-box and the metal casing of the load cell, LCMHR1Y. Record the resistances.
- 3.2.5 Then connect Ohmmeter between wire No. LC15Y from the load cell at the System 2 J-box and the metal casing of the load cell, LCMHR1Y. Record the resistances.

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY1

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1Y

Page 4 of 6

- 3.2.6 Then connect Ohmmeter between wire No. LC16Y from the load cell at the System 2 J-box and the metal casing of the load cell, LCMHR1Y. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
LC11Y	Load Cell Housing	> 100G ohm	>100 Megohms -0% +5%	Acc
LC12Y	Load Cell Housing	> 100G ohm	>100 Megohms -0% +5%	Acc
LC15Y	Load Cell Housing	> 100G ohm	>100 Megohms -0% +5%	Acc
LC16Y	Load Cell Housing	> 100 ohm	>100 Megohms -0% +5%	Acc

- 3.2.4 Connect Ohmmeter between wire nos. LC11Y and LC12Y. Record the resistance. Then connect Ohmmeter between wire nos. LC15Y and LC16Y. Record the resistance.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
LC11Y	LC12Y	350.1 ohm	350-700 Ohms \pm 5%	Acc
LC15Y	LC16Y	349.9 ohm	350-700 Ohms \pm 5%	Acc

- 3.2.5 De-energize and remove the test equipment.

3.3 Terminate the test.

- 3.3.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.

- 3.3.2 Retorque the terminals to 12 in-pounds.

- 3.3.3 Remove lockout/tagout and restore system to normal.

- 3.3.3 Record: Date /Time of Test End: 03-09-00 11:10 a.m.

4.0 References

- 4.1 Elementary Wiring Drawings: EB-33056 Sheet 12

- 4.2 Wiring Diagram: 363A0033 Sheet 13

Dedication Test Plan - IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY1

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR1Y

Page 5 of 6

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Devices under test have passed all parameters

Michael Cram
03-09-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-09-00
Reviewed By: J. Casilio 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/9/00} [Signature] Date: 3-9-00

QA/QC (signature) [Signature] Date: 3/19/00
TZ ANDERSON

LIFTED LEAD LOG


Junction Box: System 2 J-Box TB-2

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-33056	12	LC11Y	LCMHR1Y	TB2-1	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	12	LC12Y	LCMHR1Y	TB2-5	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	12	LC16Y	LCMHR1Y	TB2-3	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	12	LC15Y	LCMHR1Y	TB2-4	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	12	Jumper	LCMHR1Y	TB2-1 to TB2-2	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00
EB-33056	12	Jumper	LCMHR1Y	TB2-5 to TB2-6	JWE	3/9/00	SRL	3-9-00	JWE	3/9/00	SRL	3-9-00

Remarks:

Dedication Test Plan – IST-LC-1	ORIGINAL	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY2		
Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2Y		Page 1 of 6

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				Cog. Eng	DA	QA Post Review*
						 3/13/00 NO CHANGE

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST-LC-1 Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY2 Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2Y	Rev. No. 0 Page 2 of 6
--	-------------------------------

In-Situ Test Procedure

ORIGINAL

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *[Signature]* Waig Swenson Date: 3/6/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bellhaven	<i>[Signature]</i>	MCRC
Electrician	J WEBERHART	PCE	<i>[Signature]</i>	JWB
Electrician Quality Control	Stephen R. Conley	PCE	<i>[Signature]</i>	SRC
Design Authority Representative	E.R. Kahler	XWest	<i>[Signature]</i>	ERK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Insulation Resistance Instrument capable of measuring >100 megohms
 MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
 Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 34574 I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: PROTO 6106 I.D.: 029E/009 Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY2

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2Y

Page 3 of 6

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

- 1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.
- 2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	LCMHR2Y	Acc.
Manufacturer:	YES	Sensotec	Acc
Model:	YES	FM/C717-01	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

- 3.0 Perform the following testing steps:

- 3.1 Record: Date /Time of Test Beginning: 03-09-00 10:36 am
Record: Room Temperature: 68 °F.

3.2 Insulation Resistance Test

- 3.2.1 Setup the test equipment and Load Cell specimen for insulation resistance testing.

**Warning: Do not use a high-voltage Hypot tester or Megger type tester!
Test Equipment must apply no more than 20 VDC**

- 3.2.2 Disconnect wires from terminals on TB2 on the System 2 J-Box, record and verify on the Lifted Lead Log.
- 3.2.3 Apply a maximum of 20 VDC via Ohmmeter between wire No. LC21Y from the load cell at the System 1 J-box and the metal casing of the load cell, LCMHR2Y. Record the resistance.
- 3.2.4 Then connect Ohmmeter between wire No. LC22Y from the load cell at the System 2 J-box and the metal casing of the load cell, LCMHR2Y. Record the resistances.
- 3.2.5 Then connect Ohmmeter between wire No. LC25Y from the load cell at the System 2 J-box and the metal casing of the load cell, LCMHR2Y. Record the resistances.

Dedication Test Plan – IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY2

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2Y

Page 4 of 6

3.2.6 Then connect Ohmmeter between wire No. LC26Y from the load cell at the System 2 J-box and the metal casing of the load cell, LCMHR2Y. Record the resistances.

Terminal to Terminal / Ground				
Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
LC21Y	Load Cell Housing	> 100 Gohm	>100 Megohms -0% +5%	Acc.
LC22Y	Load Cell Housing	> 100 Gohm	>100 Megohms -0% +5%	Acc.
LC25Y	Load Cell Housing	> 100 Gohm	>100 Megohms -0% +5%	Acc.
LC26Y	Load Cell Housing	> 100 Gohm	>100 Megohms -0% +5%	Acc.

3.2.4 Connect Ohmmeter between wire nos. LC21Y and LC22Y. Record the resistance. Then connect Ohmmeter between wire nos. LC25Y and LC26Y. Record the resistance.

Terminal to Terminal / Ground				
Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
LC21Y	LC22Y	350.1 ohm	350-700 Ohms \pm 5%	Acc.
LC25Y	LC26Y	349.9 ohm	350-700 Ohms \pm 5%	Acc.

3.2.5 De-energize and remove the test equipment.

3.3 Terminate the test.

3.3.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

3.3.2 Retorque the terminals to 12 in-pounds.

3.3.3 Remove lockout/tagout and restore system to normal.

3.3.3 Record: Date /Time of Test End: 03-09-00 11.12 a.m.

4.0 References

4.1 Elementary Wiring Drawings: EB-33056 Sheet 12

4.2 Wiring Diagram: 363A0033 Sheet 13

Dedication Test Plan - IST-LC-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-016A-TP-016AY2

Test Specimen: Sensotec Load Cell FM/C717-01, Eqmt. No.: LCMHR2Y

Page 5 of 6

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Devices under test have passed all parameters.

Michael Cross
03-09-00

Notes:

Certified Instrumentation Technician (signature) Michael Cross Date: 03-09-00
Reviewed By: J. Caslick 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/9/00} [Signature] Date: 3-9-00

QA/QC (signature) [Signature] Date: 3/13/00
T. ZANDERSON

LIFTED LEAD LOG

Junction Box: System 2 J-Box TB-2

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-33056	12	LC21Y	LCMHR2Y	TB2-2	JWE	3/9/00	SRC	3-9-00	JWE	3/9/00	SRC	3-9-00
EB-33056	12	LC22Y	LCMHR2Y	TB2-6	JWE	3/9/00	SRC	3-9-00	JWE	3/9/00	SRC	3-9-00
EB-33056	12	LC26Y	LCMHR2Y	TB2-3	JWE	3/9/00	SRC	3-9-00	JWE	3/9/00	SRC	3-9-00
EB-33056	12	LC25Y	LCMHR2Y	TB2-4	JWE	3/9/00	SRC	3-9-00	JWE	3/9/00	SRC	3-9-00
EB-33056	12	Jumper	LCMHR2Y	TB2-1 to TB2-2	JWE	3/9/00	SRC	3-9-00	JWE	3/9/00	SRC	3-9-00
EB-33056	12	Jumper	LCMHR2Y	TB2-5 to TB2-6	JWE	3/9/00	SRC	3-9-00	JWE	3/9/00	SRC	3-9-00

Remarks:

SNF-6315, Rev. 0

Page 550

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	1 of 4

cal. #2
Signal Cards

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD

System No.: <u>015</u>	Project: <u>W379</u>	
Instrument No.: <u>MCOWD-1</u>		
Function: <u>MCO Hoist Weight Display 1</u>		
Manufacturer: <u>M/D Totco</u>	Model No.: <u>LM2000</u>	Location: <u>MHM Console</u>
Reference Documents (Vendor Information, Drawings): <u>EB-33056, Sht. 11</u>		
Instrument Input Range: <u>4</u>	to <u>20</u>	Units: <u>mA</u>
Instrument Indication Range: <u>0</u>	to <u>30,000</u>	Units: <u>lbs</u>
Allowable Instrument Error: <u>±0.15 %</u> <u>see 7/8/99</u>		
Startup Contact: <u>Jon Molnar</u>	Phone: <u>372-8794</u>	

Special Instructions: Reference TDR CSB(W379)-015-11-060-2, replaced signal conditioning card with 1mv/v card. New scaling is 4 ~ 20 mA = 0 - 30,000lbs. Recalibrate with new scaling.

NOTE: SET ALL RELAYS TO UNLATCHED.

Verify alarm setpoint values and relays are set in programming as follows:

High High = 24,597 Rlv 3

High = 20,000 (Alarm point to enable proper operation)

Low = 7,180 Rlv 1

Low Low = 1,840 Rlv 4

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	2 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

TEST EQUIPMENT	M&TE NUMBER	CALIBRATION DUE DATE
Fluke 867B Multimeter	1056024	5/12/00
Transmatioral	1056010	3/15/00

Proc. Step No.	ACTION	INITIAL/DATE
3.0	PREREQUISITES COMPLETED	<u>DLW 16/11/99</u>
5.0	INITIAL CONDITIONS COMPLETED	<u>DLW 16/11/99</u>
7.0	INSPECTION AND TEST RESULTS	
7.1	Installation inspection satisfactory	<u>DLW 16/11/99</u>
7.2	Electrical inspection satisfactory	<u>DLW 16/11/99</u>
7.3	Liquid/Gas service piping inspection satisfactory	<u>N/A 1</u>
7.4	Head correction completed	<u>N/A 1</u>
7.5	Instrument removed or isolated	<u>DLW 16/11/99</u>
7.6	Instrument range <u>0 to 30,000</u> Units <u>Lbs</u>	<u>DLW 16/11/99</u>
	Allowable instrument error <u>0.15</u> Units <u>% F.S.</u>	<u>DLW 16/11/99</u>

7.10, 7.11, 7.12, 7.13, 7.14:

INPUT UNITS: mA

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	3 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

% SPAN	DESIRED OUTPUT	AS FOUND OUTPUT	OUTPUT ERROR	FINAL OUTPUT	FINAL ERROR	INIT/ DATE
0% 4mA	0	0	0	0	0	DLW 16/11/99
25% 8mA	7500	7500	0	7500	0	DLW 16/11/99
50% 12mA	15,000	14995	-5	14995	-5	DLW 16/11/99
75% 16mA	22,500	22497	-3	22497	-3	DLW 16/11/99
100% 20mA	30,000	29998	-2	29998	-2	DLW 16/11/99
75% 16mA	22,500	22498	-2	22498	-2	DLW 16/11/99
50% 12mA	15,000	14997	-3	14997	-3	DLW 16/11/99
25% 8mA	7500	7498	-2	7498	-2	DLW 16/11/99
0% 4mA	0	-1	-1	-1	-1	DLW 16/11/99
Allowable error----->			$\pm 0.15\%$ DLW 7/1/99	----->	\pm	1

Proc. Step No.	ACTION	INITIAL/DATE
----------------	--------	--------------

7.13	Calculated error less than allowable error (10.1)	DLW 16/11/99
------	---	--------------

7.15	Calibration sticker attached	DLW 16/11/99
------	------------------------------	--------------

8.0	RESTORATION COMPLETE	DLW 16/11/99
-----	----------------------	--------------

Remarks: _____

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	4 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

Performed By: Darwayne Welch Date: 6/11/99
 Technician

Reviewed By: M.D. Post Date: 7-12-99
 A.I. Witness

Reviewed By: Roberto V. Cruz Date: 6/14/99
 Startup Test Engineer

Approved By: J. Miller Date: 6/14/99
 Test Director

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	1 of 4

Recal. #1

**DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD**

System No.: <u>015</u>		Project: <u>W379</u>	
Instrument No.: <u>MCOWD-1</u>			
Function: <u>MCO Hoist Weight Display 1</u>			
Manufacturer: <u>M/D Totco</u>	Model No.: <u>LM2000</u>	Location: <u>MHM Console</u>	
Reference Documents (Vendor Information, Drawings): <u>EB-33056, Sht. 11</u>			
Instrument Input Range: <u>4</u>	to <u>11.63</u>	Units: <u>mA</u>	
Instrument Indication Range: <u>0</u>	to <u>30,000</u>	Units: <u>lbs</u>	
Allowable Instrument Error: <u>±0.15 %</u> <i>plus 7/3/91</i>			
Startup Contact: <u>Jon Molnar</u>		Phone: <u>372-8794</u>	

Special Instructions: Reference TDR CSB(W379)-015-11-60-2. It was found that the load cell output does not match the Signal Conditioner full scale input. Load cell output is .83 m/v. The Signal Conditioner need 2 mv/v input for full span output of 4-20 mA. The output from the signal conditioner with full scale output from load cell applied will produce a max 11.63 mA. Set scaling at 4 - 11.63 mA equals 0 to 30,000 lbs.

NOTE: SET ALL RELAYS TO UNLATCHED.

Verify alarm setpoint values and relays are set in programming as follows:

High High = 24,597 Rly 3

High = 20,000 (Alarm point to enable proper operation)

Low = 7,180 Rly 1

Low Low = 1,840 Rly 4

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	2 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

TEST EQUIPMENT	M&TE NUMBER	CALIBRATION DUE DATE
Fluke 743B Calibrator	10S 6155	9/30/99
Transmatron	10S 6010	3/15/99

Proc. Step No.	ACTION	INITIAL/DATE
3.0	PREREQUISITES COMPLETED	DLW 15/19/99
5.0	INITIAL CONDITIONS COMPLETED	DLW 15/19/99
7.0	INSPECTION AND TEST RESULTS	
7.1	Installation inspection satisfactory	DLW 15/19/99
7.2	Electrical inspection satisfactory	DLW 15/19/99
7.3	Liquid/Gas service piping inspection satisfactory	N/A 1
7.4	Head correction completed	N/A 1
7.5	Instrument removed or isolated	DLW 15/19/99
7.6	Instrument range <u>0</u> to <u>30,000</u> Units <u>Lbs</u>	DLW 15/19/99
	Allowable instrument error <u>0.15</u> Units <u>% F.S.</u>	DLW 15/19/99

DLW
5/19/99

7.10, 7.11, 7.12, 7.13, 7.14:

INPUT UNITS: mA

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	3 of 4

**DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)**

% SPAN	DESIRED OUTPUT	AS FOUND OUTPUT	OUTPUT ERROR	FINAL OUTPUT	FINAL ERROR	INIT/ DATE
0% 4 mA	0	0	0	0	0	DLW 15/19/99
25% 5.91 mA	7500	7518	+18	7518	+18	DLW 15/19/99
50% 7.81 mA	15,000	14983	-17	14983	-17	DLW 15/19/99
75% 9.72 mA	22,500	22494	-6	22494	-6	DLW 15/19/99
100% 11.63 mA	30,000	30005	+5	30005	+5	DLW 15/19/99
75% 9.12 mA	22,500	22487	-13	22487	-13	DLW 15/19/99
50% 7.81 mA	15,000	14986	-14	14986	-14	DLW 15/19/99
25% 5.91 mA	7500	7504	+4	7504	+4	DLW 15/19/99
0% 4 mA	0	6	+6	6	+6	DLW 15/19/99
Allowable error----->			$\pm 0.15\%$ DLW 7/2/99	-----> ±		1

Proc. Step No.	ACTION	INITIAL/DATE
7.13	Calculated error less than allowable error (10.1)	DLW 15/19/99
7.15	Calibration sticker attached	DLW 15/19/99
8.0	RESTORATION COMPLETE	DLW 15/19/99

Remarks: _____

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	4 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

Performed By: Dawnayne Welch Date: 5/19/99
 Technician

Reviewed By: Mr. Peter DeLeonis Date: 7-12-99
 A.I. Witness

Reviewed By: Roberto V. Cruz Date: 6/14/99
 Startup Test Engineer

Approved By: J. Miller Date: 6/14/99
 Test Director

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	1 of 4

Original Cal.

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD

System No.: <u>015</u>	Project: <u>W379</u>	
Instrument No.: <u>MCOWD-1</u>		
Function: <u>MCO Hoist Weight Display 1</u>		
Manufacturer: <u>M/D Totco</u>	Model No.: <u>LM2000</u>	Location: <u>MHM Console</u>
Reference Documents (Vendor Information, Drawings): <u>EB-33056, Sht. 11</u>		
Instrument Input Range: <u>4</u>	to <u>20</u>	Units: <u>mA</u>
Instrument Indication Range: <u>0</u>	to <u>30,000</u>	Units: <u>Lbs</u>
Allowable Instrument Error:	$\pm 0.15\%$ <small>DLW 7/8/99</small>	
Startup Contact: <u>Jon Molnar</u>	Phone: <u>372-8794</u>	

Special Instructions: NOTE: SET ALL RELAYS TO UNLATCHED.

Verify alarm setpoint values are set in programming as follows:

Alarm 1 = 7180 R43 HH = 24597
H = 20000 FAKE ALARM POINT

Alarm 3 = 11,840 R41 L = 7180

Alarm 4 = 1840 R44 LL = 1840

TEST EQUIPMENT	M&TE NUMBER	CALIBRATION DUE DATE
Fluke 867B Multimeter	1050665	11/2/99
Fluke 743B Calibrator	1056155	9/30/99

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	2 of 4

**DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)**

Proc. Step No.	ACTION	INITIAL/DATE
3.0	PREREQUISITES COMPLETED	<u>DLW 14/26/99</u>
5.0	INITIAL CONDITIONS COMPLETED	<u>DLW 14/26/99</u>
7.0	INSPECTION AND TEST RESULTS	
7.1	Installation inspection satisfactory	<u>DLW 14/26/99</u>
7.2	Electrical inspection satisfactory	<u>DLW 14/26/99</u>
7.3	Liquid/Gas service piping inspection satisfactory	<u>N/A 1</u>
7.4	Head correction completed	<u>N/A 1</u>
7.5	Instrument removed or isolated	<u>DLW 14/26/99</u>
7.6	Instrument range <u>0 to 30,000</u> Units <u>Lbs</u>	<u>DLW 14/26/99</u>
	Allowable instrument error <u>0.15</u> Units % F.S.	<u>DLW 14/26/99</u>

Jan 14/26/99

7.10, 7.11, 7.12, 7.13, 7.14:

INPUT UNITS: mA

% SPAN	DESIRED OUTPUT	AS FOUND OUTPUT	OUTPUT ERROR	FINAL OUTPUT	FINAL ERROR	INIT/ DATE
⁴ 0%	0	0	∅	0	∅	<u>DLW 14/26/99</u>
⁸ 25%	7500	7500	∅	7500	∅	<u>DLW 14/26/99</u>
¹² 50%	15,000	14,999	-1	14,999	-1	<u>DLW 14/26/99</u>
¹⁶ 75%	22,500	22,500	∅	22,500	∅	<u>DLW 14/26/99</u>

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	3 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

100% 20	30,000	30,001	+1	30,001	+1	1
75% 10	22,500	22,500	∅	22,500	∅	1
50% 12	15,000	14,999	-1	14,999	-1	1
25% 8	7500	7499	-1	7499	-1	1
0% 42	0	1	+1	1	+1	1
Allowable error-----→			±0.15%	-----→	±	1
			Due 7/7/99			

Proc. Step No.	ACTION	INITIAL/DATE
7.13	Calculated error less than allowable error (10.1)	DW 14/26/99
7.15	Calibration sticker attached	DW 14/26/99
8.0	RESTORATION COMPLETE	DW 14/26/99

Remarks: High High set point set to 24,597. In order for the unit to function a High set point had to be entered, 20,000 was used for this value. Low set point set to 7,180, and a Low Low set point 1840. Relay 1 programmed to the L setpoint, Relay 3 programmed to High High and Relay 4 to the Low Low setpoint.
NOTE: Password is factory set to 01919

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	4 of 4

**DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)**

Performed By: Dawanna Welch Date: 4/26/99
Technician

Reviewed By: M. L. Dr. Penick Date: _____
A.I. Witness

Reviewed By: Roberto V. Cruz Date: 6/14/99
Startup Test Engineer

Approved By: J. P. Miller Date: 6/14/99
Test Director

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	1 of 4

*Recal #2
w Signal Cards*

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD

System No.: <u>015</u>	Project: <u>W379</u>	
Instrument No.: <u>MCOWD-2</u>		
Function: <u>MCO Hoist Weight Display 2</u>		
Manufacturer: <u>M/D Totco</u>	Model No.: <u>LM2000</u>	Location: <u>MHM Console</u>
Reference Documents (Vendor Information, Drawings): <u>EB-33056, Sht. 12</u>		
Instrument Input Range: <u>4</u>	to <u>20</u>	Units: <u>mA</u>
Instrument Indication Range: <u>0</u>	to <u>30,000</u>	Units: <u>Lbs</u>
Allowable Instrument Error: \pm <u>0.15 %</u>	<small>D/L 7/7/11</small>	
Startup Contact: <u>Jon Molnar</u>	Phone: <u>372-8794</u>	

Special Instructions: Reference TDR CSB(W379)-015-11-060-2, replaced signal conditioning card with 1mv/v card. New scaling is 4 ~ 20 mA = 0 - 30,000lbs. Recalibrate with new scaling.

NOTE: SET ALL RELAYS TO UNLATCHED

Verify alarm setpoint values and relays are set in programming as follows:

High High = 25.986 Rlv 3

High = 4.386 Rlv 2

Low = 1.840 Rlv 1

Low Low = (No Alarm point)

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	2 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

TEST EQUIPMENT	M&TE NUMBER	CALIBRATION DUE DATE
Fluke 867B Multimeter	1056024	5/12/00
Transmission	1056010	3/15/00

Proc. Step No.	ACTION	INITIAL/DATE
3.0	PREREQUISITES COMPLETED	DLW 16/11/99
5.0	INITIAL CONDITIONS COMPLETED	DLW 16/11/99
7.0	INSPECTION AND TEST RESULTS	
7.1	Installation inspection satisfactory	DLW 16/11/99
7.2	Electrical inspection satisfactory	DLW 16/11/99
7.3	Liquid/Gas service piping inspection satisfactory	N/A 1
7.4	Head correction completed	N/A 1
7.5	Instrument removed or isolated	DLW 16/11/99
7.6	Instrument range <u>0</u> to <u>30,000</u> Units <u>Lbs</u>	DLW 16/11/99
	Allowable instrument error <u>0.15</u> Units % F.S.	DLW 16/11/99 ^{DLW}

Pen
16/11/99

7.10, 7.11, 7.12, 7.13, 7.14:

INPUT UNITS: mA

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	3 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

% SPAN	DESIRED OUTPUT	AS FOUND OUTPUT	OUTPUT ERROR	FINAL OUTPUT	FINAL ERROR	INIT/ DATE
0%	0	1	+1	1	+1	DLW 16/11/99
25%	7500	7500	0	7500	0	DLW 16/11/99
50%	15,000	15001	+1	15001	+1	DLW 16/11/99
75%	22,500	22498	-2	22498	-2	DLW 16/11/99
100%	30,000	29999	-1	29999	-1	DLW 16/11/99
75%	22,500	22499	-1	22499	-1	DLW 16/11/99
50%	15,000	14997	-3	14997	-3	DLW 16/11/99
25%	7500	7502	+2	7502	+2	DLW 16/11/99
0%	0	1	+1	1	+1	DLW 16/11/99
Allowable error----->			$\pm 0.15\%$ /DIP 7/1/99	----->	\pm	1

Proc. Step No.	ACTION	INITIAL/DATE
7.13	Calculated error less than allowable error (10.1)	DLW 16/11/99
7.15	Calibration sticker attached	DLW 16/11/99
8.0	RESTORATION COMPLETE	DLW 16/11/99

Remarks: _____

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	.0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	4 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

Performed By: *Dwayne Welch* Date: 6/12/99
Technician

Reviewed By: *W. L. DeLoreau* Date: 7-12-99
A.I. Witness

Reviewed By: *Robert V. Gray* Date: 6/14/99
Startup Test Engineer

Approved By: *Jim Miller* Date: 6/14/99
Test Director

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	1 of 4

Recal #1

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD

System No.: <u>015</u>	Project: <u>W379</u>	
Instrument No.: <u>MCOWD-2</u>		
Function: <u>MCO Hoist Weight Display 2</u>		
Manufacturer: <u>M/D Totco</u>	Model No.: <u>LM2000</u>	Location: <u>MHM Console</u>
Reference Documents (Vendor Information, Drawings): <u>EB-33056, Sht. 12</u>		
Instrument Input Range: <u>4</u>	to <u>11.63</u>	Units: <u>mA</u>
Instrument Indication Range: <u>0</u>	to <u>30,000</u>	Units: <u>Lbs</u>
Allowable Instrument Error:	<u>± 0.15 %</u> <i>dup 7/8/11</i>	
Startup Contact: <u>Jon Molnar</u>	Phone: <u>372-8794</u>	

Special Instructions: Reference TDR CSB(W379)-015-11-60-2. It was found that the load cell output does not match the Signal Conditioner full scale input. Load cell output is .83 m/v. The Signal Conditioner need 2 mv/v input for full span output of 4-20 mA. The output from the Signal Conditioner with full scale output from load cell applied will produce a max 11.63 mA. Set scaling at 4 - 11.63 mA equals 0 to 30,000 lbs.

NOTE: SET ALL RELAYS TO UNLATCHED

Verify alarm setpoint values and relays are set in programming as follows:

High High = 25,986 Rly 3

High = 4,386 Rly 2

Low = 1,840 Rly 1

Low Low = (No Alarm point)

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	2 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

TEST EQUIPMENT	M&TE NUMBER	CALIBRATION DUE DATE
Transmatic	1056010	3/15/00
Fluke 743 B Calibrator	1056155	9/30/99

Proc. Step No.	ACTION	INITIAL/DATE
3.0	PREREQUISITES COMPLETED	DLW 15/19/99
5.0	INITIAL CONDITIONS COMPLETED	DLW 15/19/99
7.0	INSPECTION AND TEST RESULTS	
7.1	Installation inspection satisfactory	DLW 15/19/99
7.2	Electrical inspection satisfactory	DLW 15/19/99
7.3	Liquid/Gas service piping inspection satisfactory	N/A 1
7.4	Head correction completed	N/A 1
7.5	Instrument removed or isolated	N/A 1
7.6	Instrument range 0 to 30,000 Units Lbs	DLW 15/19/99
	Allowable instrument error 0.15 Units % F.S.	DLW 15/19/99

7.10, 7.11, 7.12, 7.13, 7.14:

INPUT UNITS: mA

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	3 of 4

**DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)**

% SPAN	DESIRED OUTPUT	AS FOUND OUTPUT	OUTPUT ERROR	FINAL OUTPUT	FINAL ERROR	INIT/ DATE
0% 4 mA	0	0	0	0	0	DLW 15/19/99
25% 5.91 mA	7500	7501	+1	7501	+1	DLW 15/19/99
50% 7.81 mA	15,000	14982	-18	14982	-18	DLW 15/19/99
75% 9.72 mA	22,500	22482	-18	22482	-18	DLW 15/19/99
100% 11.63 mA	30,000	29996	-4	29996	-4	DLW 15/19/99
75% 9.72 mA	22,500	22488	-12	22488	-12	DLW 15/19/99
50% 7.81 mA	15,000	14985	-15	14985	-15	DLW 15/19/99
25% 5.91 mA	7500	7507	+7	7507	+7	DLW 15/19/99
0% 4 mA	0	-4	-4	-4	-4	DLW 15/19/99
Allowable error----->			$\pm 0.15\%$ Date 7/8/97	----->	\pm	1

Proc. Step No.	ACTION	INITIAL/DATE
7.13	Calculated error less than allowable error (10.1)	DLW 15/19/99
7.15	Calibration sticker attached	DLW 15/19/99
8.0	RESTORATION COMPLETE	DLW 15/19/99
Remarks:	_____	

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	4 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

Performed By: Dawayne White Date: 5/19/99
Technician

Reviewed By: M.D. St. Denis Date: 7-12-99
A.I. Witness

Reviewed By: Robert V. Gray Date: 6/14/99
Startup Test Engineer

Approved By: J. Miller Date: 6/14/99
Test Director

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	1 of 4

Original

**DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD**

System No.: <u>015</u>	Project: <u>W379</u>	
Instrument No.: <u>MCOWD-2</u>		
Function: <u>MCO Hoist Weight Display 2</u>		
Manufacturer: <u>M/D Totco</u>	Model No.: <u>LM2000</u>	Location: <u>MHM Console</u>
Reference Documents (Vendor Information, Drawings): <u>EB-33056, Sht. 12</u>		
Instrument Input Range: <u>4</u>	to <u>20</u>	Units: <u>mA</u>
Instrument Indication Range: <u>0</u>	to <u>30,000</u>	Units: <u>Lbs</u>
Allowable Instrument Error: $\pm 0.15\%$ <small>Due 7/9/99</small>		
Startup Contact: <u>Jon Molnar</u>		Phone: <u>372-8794</u>

Special Instructions: **NOTE: SET ALL RELAYS TO UNLATCHED**

Verify alarm setpoint values are set in programming as follows:

Alarm 1 = 1840 L set point

Alarm 2 = 4386 H set point

Alarm 3 = 25,986 HH set point

TEST EQUIPMENT	M&TE NUMBER	CALIBRATION DUE DATE
Fluke 743B Calibrator	1056155	9/30/99
Transmatlon	1056010	3/15/00

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC
FACILITY/SYSTEM START-UP	Revision	
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	2 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

Proc. Step No.	ACTION	INITIAL/DATE
3.0	PREREQUISITES COMPLETED	<u>DLW 14/29/99</u>
5.0	INITIAL CONDITIONS COMPLETED	<u>DLW 14/29/99</u>
7.0	INSPECTION AND TEST RESULTS	
7.1	Installation inspection satisfactory	<u>DLW 14/29/99</u>
7.2	Electrical inspection satisfactory	<u>DLW 14/29/99</u>
7.3	Liquid/Gas service piping inspection satisfactory	<u>N/A /</u>
7.4	Head correction completed	<u>N/A /</u> <i>DLW 14/29/99</i>
7.5	Instrument removed or isolated	<u>N/A /</u>
7.6	Instrument range <u>0 to 30,000</u> Units <u>Lbs</u>	<u>DLW 14/29/99</u>
	Allowable instrument error <u>0.15</u> Units <u>% F.S.</u>	<u>DLW 14/29/99</u>

7.10, 7.11, 7.12, 7.13, 7.14:

INPUT UNITS: mA

% SPAN	DESIRED OUTPUT	AS FOUND OUTPUT	OUTPUT ERROR	FINAL OUTPUT	FINAL ERROR	INIT/ DATE
0%	0	1	+1	1	+1	<u>DLW 14/29/99</u>
25%	7500	7500	∅	7500	∅	<u>DLW 14/29/99</u>
50%	15,000	14,999	-1	14,999	-1	<u>DLW 14/29/99</u>
75%	22,500	22,500	∅	22,500	∅	<u>DLW 14/29/99</u>

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	3 of 4

DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)

100%	30,000	29,999	-1	29,999	-1	DLW 14/29/99
75%	22,500	22,498	-2	22,498	-2	DLW 14/29/99
50%	15,000	14,999	-1	14,999	-1	DLW 14/29/99
25%	7500	7500	∅	7500	∅	DLW 14/29/99
0%	0	0	∅	0	∅	DLW 14/29/99
Allowable error-----→			±0.15%	-----→	±	1
			DLW 9/2/99			

Proc. Step No.	ACTION	INITIAL/DATE
7.13	Calculated error less than allowable error (10.1)	DLW 14/29/99
7.15	Calibration sticker attached	DLW 14/29/99
8.0	RESTORATION COMPLETE	DLW 14/29/99

Remarks: Set points set as follows. ## High High set point 25,986. High set point 4386. Low setpoint 1840. There is no low low set points. Relay 1 set to low setpoint. Relay 2 set to High set Point and Relay 3 set to High High set point.

SPENT NUCLEAR FULL PROJECT	Procedure No.	SNF-CTP-IC-03
FACILITY/SYSTEM START-UP	Revision	0
COMPONENT TEST PROCEDURE	Effective Date	09/28/98
LOCAL INDICATION	Page	4 of 4

**DATA SHEET 11.1
LOCAL INDICATOR INSPECTION AND TEST RECORD (Continued)**

Performed By: Dwayne Welch Date: 4/29/99
Technician

Reviewed By: M.D. G. [Signature] Date: 7-12-99
A.I. Witness

Reviewed By: Robert V. [Signature] Date: 6/14/99
Startup Test Engineer

Approved By: [Signature] Date: 6/14/99
Test Director

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

Page 575

SNF-6315, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-016B

Page 1 of 7

Title: P2, P53, P62, & P63 Interlocks - Motherboard & Signal Conditioner

P2, P53, P62, P63

Section 1 Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
Part Description: <u>N/A</u>		
End Use Description: <u>N/A</u>		

ORIGINAL

Section 2a Component Information

Equipment No.: Motherboard, Signal Conditioner/Amplifier	Specification No.: Ederer F-2566, Foster Wheeler MJX-SDX 452656	Manufacturer: M/D TOTCO	Past P.O. No.: N/A
Manufacturer's Part/Model No.: 2077-034, 2078-101	Equipment Supplier (if different from manufacturer): ALSTROM, Foster Wheeler	Equip. Supplier's Part No.: N/A	

Component Description: **Signal Conditioner/Amplifier Mother Board with a current output mounted in a NEMA Type 4 enclosure. Four relays are integral to this printed circuit board and two (1) are used for shunt calibration, one (1) for zero check of the instrumentation and one (1) for gain check. The motherboard is P/N 2077-034 and the Signal Conditioner is P/N 2078-101.**

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate w/ project CGI Engineer or BTR)? YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate item)
If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate w/ project CGI Engineer or BTR)? YES (go to #2 below, procedure step 6.3.2, dedicate item) NO (procedure step 6.3.2, dedicate item)
2. List of Candidate qualified suppliers or ISO 9000 suppliers: N/A
3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

- CGI Determination Questions:
- #1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the item is not commercial grade) NO (continue)
- #2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)
- #3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)
- All three criteria have been satisfied. The Item meets the definition of commercial grade.**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 2 of 7

ECN No. N/A CGI No. CGI-SNF-D-MHM-016B
Title: P2, P53, P62, & P63 Interlocks - Motherboard & Signal Conditioner

Section 2: Reason for Dedication
The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):

<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input checked="" type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3: Failure Effects Evaluation

A. Part/Component Safety Function: **The P2 interlock serves to prevent the MHM from leaving a storage tube without replacing the tube plug by determining when the MCO Hoist weight is more than the min. grapple and tube plug weight and when the MCO Hoist weight is less than the max. grapple only weight. The P53 interlock ensures the MCO Hoist is not lowered unless the weight is above the min. grapple weight or above the min. grapple plus MCO weight w/grapple jaws closed unless the grapple is in the seating zone. The P62 interlock ensures that the MCO cannot be hoisted when MCO weight is detected and jaws are not closed. The P63 interlock ensures that the MCO Hoist cannot be raised if the MCO weight is exceeded. This signal conditioner/mother board initiate the action as stated in the interlocks.**

B. Part/Component Functional Mode:

Safety Function #1:	<input checked="" type="checkbox"/> Active	<input type="checkbox"/> Passive	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function Passive - Change of state is not required for the component to perform its safety function
Safety Function #2:	<input type="checkbox"/> Active	<input type="checkbox"/> Passive	
Safety Function #3:	<input type="checkbox"/> Active	<input type="checkbox"/> Passive	

C. Host Component Safety Function (if applicable): N/A

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1): **Failure to properly function and actuate output devices based on input from the weight of the MCO Hoist weight and the weight it carries results in movement of the MHM or raising of the MCO hoist at improper times.**

Section 4: Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required: Yes [] No [X]
If yes: Environmental Qualification Requirements
Limiting Environmental Conditions:
Required Safety Functions:
Qualification Period:

Natural Phenomena Hazard (NPH) Design Required: Yes [] No [X]
If yes: NPH Design Requirements
Performance Category:
NPH Design Req'ts.:
Required Safety Functions:

Section 5: Component Functional Classification

[X] Safety Class (SC) [] General Service (GS) [] Safety Significant (SS)
If part/component classification is different from host component/system, document basis. N/A

Sections 6 and 7: (Reserved)

Section 8: References (for Functional Classification)

National Codes/Standards:
Safety Analysis Report (SAR): HNF-3672, Rev. 0
Drawings: Ederer, Inc. EB-33056, Sht 11; H-2-827174 Sht 10, 21, 22, 23, 25
Vendor Manual/Manufacturer/Supplier Information: M/D TOTCO Instrumentation Installation, Calibration, and Operation Manual Series 2000 Instruments
Other: ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-0168

Page 3 of 7

Title: **P2, P53, P62, & P63 Interlocks - Motherboard & Signal Conditioner**

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acc Meth	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Motherboard:				
Manufacturer	M/D TOTCO	1, IN	X	
Model - Motherboard	2077-034	1, IN	X	
Model - Signal Conditioner	2078-101	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Circuit Loop Performance	With known force(s) applied, determine that the system responds and provides accurate meter readings within a deviation of 5%	1, T		X
4. Notes and Legend:			Acceptance Method (Acc Meth): 1. Special Test and Inspection: 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 4. Vendor/Item History	
Section 10 Initial Review and Approval				
Approvals: Designated Engineer: <u><i>J. J. [Signature]</i></u> Design Authority: <u><i>Wang [Signature]</i></u> 4-11-00 QA Engineer: <u><i>Stephen Scott Moss</i></u> 4-12-2000				

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-016B

Page 4 of 7

Title: P2, P53, P62, & P63 Interlocks – Motherboard & Signal Conditioner

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.	X	Inadvertant circuit break on printed circuit boards
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.		
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.		
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
1.			
2.			
3.			
4.			
5.			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-016B

Page 5 of 7

Title: P2, P53, P62, & P63 Interlocks – Motherboard & Signal Conditioner

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1			
Item Description: Motherboard and Signal Conditioner		Equip #: Motherboard, Signal Conditioner	
System #: MHM		Model #: 2077-034, 2078-101	
Manufacturer (Address/Phone): M/D TOTCO 1200 Cypress Creek Road Cedar Park, Texas 78613-3614 Phone. # (512) 331-0411		Supplier (Address/Phone):	
SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.			
Insp	Test	Post-Test	
X			1. Manufacturer - Motherboard & Signal Conditioner
X			2. Model - Motherboard
X			3. Model - Motherboard
	X		4. Circuit resistance - Internal mounted relays
	X		6. Contact Rating - Internal mounted relays
	X		7. Operation - Internal mounted relays
SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)			
Characteristic: Manufacturer - Motherboard		Sample Size*: 100%	
Acceptance Criteria: M/D TOTCO			
Receipt Inspection Plan / Report #: CSB(W379)-015-11-059 & 060			
Characteristic: Model - Motherboard		Sample Size*: 100%	
Acceptance Criteria: 2077-034			
Receipt Inspection Plan / Report #: CSB(W379)-015-11-059 & 060			
Characteristic: Manufacturer - Signal Conditioner		Sample Size*: 100%	
Acceptance Criteria: M/D TOTCO			
Receipt Inspection Plan / Report #: CSB(W379)-015-11-059 & 060			
Characteristic: Model - Signal Conditioner		Sample Size*: 100%	
Acceptance Criteria: 2078-101			
Receipt Inspection Plan / Report #: CSB(W379)-015-11-059 & 060			
SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)			
Characteristic for Test: Circuit Loop Performance		Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened	
Acceptance Criteria: With known force(s) applied, determine that the system responds and provides accurate meter readings within a deviation of 5%			
Actual Test Value: Summary Table (Att. A of Loop Calib.) of shows output readings are within the 5% deviation			
Test Plan and Report #: CSB(W379)-015-11-059 & 060			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-016B

Page 6 of 7

Title: P2, P53, P62, & P63 Interlocks - Motherboard & Signal Conditioner

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Signal Conditioner/Amplifier Mother Board

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	WD TOTCO	X		1, IN	CSB 11-059 CSB 11-060	N/A	2	0	XWEST	<i>Larry W. Peice</i> <i>John</i>	4/12/00
Model - Motherboard	2077-034	X		1, IN	*	↓	↓	↓	↓	↓	↓
Model - Signal Conditioner	2078-101	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Circuit Loop Performance	With known force(s) applied, determine that the system responds and provides meter readings within a deviation of 5%		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

Testing Agency Approval: <u>NA CES 4/12/00</u> Date _____	BUYER VERIFICATION Design Authority: <u>CES Larry Svensson</u> Date <u>4/12/00</u>
Testing Agency QA Engineer: <u>NA CES 4/12/00</u> Date _____	QA Engineer: _____ Date _____

* CTP CSB(4327)-015-11-059 | -060 available as Startup Test record & attached.

CES
4/12/00

SNF-6315, Rev. 0

Page 580

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-016B

Page 7 of 7

Title: P2, P53, P62, & P63 Interlocks - Motherboard & Signal Conditioner**SECTION 6 CONTACTS / PHONE NUMBERS**

Name	Phone
Design Authority <u>CRAIG SWENSON</u>	() <u>376-0288</u>
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents	For Critical Characteristics
<input type="checkbox"/> Drawings:	
<input type="checkbox"/> Manuals (specify type & number):	
<input type="checkbox"/> Design Calculations	
<input type="checkbox"/> Installation Instructions	
<input type="checkbox"/> Operation Instructions	
<input type="checkbox"/> Calibration Instructions	
<input type="checkbox"/> Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/> M/D TOTCO Instrumentation Installation, Calibration, and Operation Manual Series 2000 Instruments	All
Procurement Documents	
<input type="checkbox"/> Certificate of Conformance/Compliance	
<input type="checkbox"/> Seismic Qualification Certificate	
<input type="checkbox"/> Environmental Qualification Certificate	
<input type="checkbox"/> Test Report (s):	
<input type="checkbox"/> Inspection Report (s):	
<input type="checkbox"/> CMTRs for ASME Pressure Retaining Materials	
<input type="checkbox"/> Valve Seat Leakage Report	
<input type="checkbox"/> Weld Records	
<input type="checkbox"/> Material Traceability Record	
<input checked="" type="checkbox"/> Other: <u>CSB (W379)-015-11-059 & 060</u>	

Price, Larry W

From: Molnar, Jon C
Sent: Wednesday, April 12, 2000 8:17 AM
To: Kelmel, Gary J; Price, Larry W
Cc: Swenson, Craig E
Subject: RE: MD Totco Serial No.'s

Larry / Gary

I went back and looked at the old cards. They are being kept in the static-free bags that the new cards came in. On the outside of the static-free bags the new model numbers are hand written with a Sharpie which is 2078-101. So I would say this corroborates your note about the model number being changed.

To explain why one card in the field is marked 2078-102, I recall that we had a problem with one of the new cards. Of the two cards that I have in hand, one of the cards is marked with the 2078-102 model number on top of the heat sink while the other card has no marking. The card with no marking has a loose resistor, R13. This was the new card that had the problem. Dawayne did a part-by-part and circuit comparison between the two cards. We determined that the R13 resistor was the only difference between the new and old cards. We swapped resistors between the new and old cards in attempt to get the same performance as the other new card. It worked. Thus, one of the old cards was updated to the new card configuration.

Based on the hand-written marking on the outside of the static-free bags the model number for both cards should be 2078-101. Note, however, that this information is not identified on the new cards as it was on the old cards. I will pursue getting this memo into our test packages CSB(W379)-015-11-059 and -060. I guess we should also at least remove (or black out) the old model number on the Y Channel signal conditioner.

Gary - We should look at least removing or blacking out the model number on the Y Channel Signal Conditioner. If possible, it would even be better if we could at the new model number to both X and Y Channel Signal Conditioners.

Any questions, let me know

Thanks,

Jon

Larry, Jon.....

Steve Connley and myself looked for the Serial No.'s Larry gave me:

Motherboard 2077-034
 Signal Conditioner 2078-101

We could NOT find these no.'s.

What we could find was:

MD Totco MCO Weight Display No. 1 (X channel), Top of control Console
 SN 97EE0804972
 BC 2000
 PC# 7861, Series 2000

MD Totco MCO Weight Display No. 2 (Y channel), Inside of Control Console
 SN 97EE0884971
 BC 2000
 PC# 7861, Series 2000

Signal Conditioner Y Channel, on side of Hoist Compartment
CLI 610-2001
2078-102

Signal Conditioner X Channel, on side of Hoist Compartment
CLI 610-2001
No Label

That's all we could find without disassembling the machine.

GJK

Price, Larry W

From: Kelmel, Gary J
Sent: Tuesday, April 11, 2000 5:25 PM
To: Price, Larry W; Molnar, Jon C
Cc: Swenson, Craig E; Kelmel, Gary J
Subject: MD Totco Serial No.'s

Larry, Jon.....

Steve Connley and myself looked for the Serial No.'s Larry gave me:

Motherboard 2077-034
Signal Conditioner 2078-101

We could NOT find these no.'s.

What we could find was:

MD Totco MCO Weight Display No. 1 (X channel), Top of control Console
SN 97EE0804972
BC 2000
PC# 7861, Series 2000

MD Totco MCO Weight Display No. 2 (Y channel), Inside of Control Console
SN 97EE0884971
BC 2000
PC# 7861, Series 2000

Signal Conditioner Y Channel, on side of Hoist Compartment
CLI 610-2001
2078-102

Signal Conditioner X Channel, on side of Hoist Compartment
CLI 610-2001
No Label

That's all we could find without disassembling the machine.

GJK

CTP PACKAGE NO./ CSB(W379)-015-11-060

COMPONENT ID NO. MCOWD-2

SPENT NUCLEAR FUELS PROJECT COMPONENT TEST PROCEDURE (CTP) TEST DEFICIENCY REPORT (TDR)		
CTP TDR No.: CSB(W379)-015-11-060-2	CTP/Rev. No: CSB(W379)-015-11-060/0	Date: 5/12/99
Description of Discrepancy/Deficiency: Total weight seen on both the X and Y MCO WEIGHT displays is less than half of what is expected to be seen. Further investigation found that there is a mismatch between the output of the load cells and the input of the signal conditioner cards. Load cell output is calibrated at .83mv/v, signal card need 2mv/v to produce a full range output of 4-20 ma.		
NOTE: (This TDR impacts both -59 and -60 CTP packages)		
Signature <u>Dawayne Welch</u> <small>Initiator</small>		Date <u>5/12/99</u>
Disposition of TDR: (NOTE: If disposition involves a design change, an SFR is to be initiated,)		
Replace signal conditioning cards with a 1mv/v card. Calibrate cards to match load cells to produce a full scale output of 4-20 ma. <u>NEW P/N: 2078-101 / D. WELCH</u> <i>JW</i>		
Disposition By: <u>Roberto V. Cruz</u> <i>Plus see J. MOLNAR E-MAIL DTD. 4/12/00 JW 4/12/00</i>		
Signature <u>Roberto V. Cruz</u> <small>Startup Engineer</small>		Date <u>6/14/99</u>
1. Disposition Concurrence:		
Signature <u>J.C. Molnar</u> <small>Test Director</small>		Date <u>6/14/99</u>
2. Retest Required: YES <u>x</u> NO <u> </u> N/A <u> </u>		
Results: Satisfactory		
3. Retest Completed:		
Signature <u>Dawayne Welch</u> <small>Startup Technician/Startup Engineer</small>		Date <u>6/14/99</u>

M/D TOTOTM

INSTRUMENTATION

INDUSTRIAL SYSTEMS

1200 Cypress Creek Road
Cedar Park, Texas 78613-3614
Phone: (512) 331-0411



Ederer Corp.

System Certification

System 1, Consisting of:

BC2-1A-5555-ZZZZ	Crane Display	S.N. = 97EE0804972
XJA (2077-034 / 2078-102)	Boom Tip J-Box	S.N. = 11173

CALIBRATION:

0mV/V input to signal conditioner = 4mA Output = 0 TON Displayed
2mV/V input to signal conditioner = 20mA Output = 15.1 TONS Displayed

System 2, Consisting of:

BC2-1A-5555-ZZZZ	Crane Display	S.N. = 97EE0804971
XJA (2077-034 / 2078-102)	Boom Tip J-Box	S.N. = 9694

CALIBRATION:

0mV/V input to signal conditioner = 4mA Output = 0 TON Displayed
2mV/V input to signal conditioner = 20mA Output = 15.1 TONS Displayed

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-04
FACILITY SYSTEM START-UP	Revision No.	0
COMPONENT TEST PROCEDURE	Effective Date	12/4/98
INSTRUMENT LOOP CALIBRATION	Page	1 of 7

**DATA SHEET 11.1
INSTRUMENT LOOP CALIBRATION**

System No: <u>15</u>		Project: <u>W379</u>			
Reference Documents (Vendor Information, Drawings): <u>EB-33056, Sht.11, 363A0033, Sht.9</u>					
Loop: <u>1 (X)</u>					
Setpoint: <u>Multiple</u>	Sensing Element: <u>LCMHR1X,</u> <u>LCMHR2X</u>		Final Element #1: <u>MCO Hoist Wt.</u> <u>Meter</u>		
Final Element #2: <u>Trip Pt. Relay 5X-8X</u>			Final Element #3: <u> </u>		
Failure Mode (air and electric, as applicable):					
Test Loop Diagram: <u>EB-33056, Sht.11</u>					
Annunciator/MMI/HMI, Engraving/Designation: <u>See Reference Drawings</u>					
Required Annunciator Alarm point	<u>See SI 1</u>	\pm	<u> </u>	Inc./Dec.	<u> </u>
Required Annunciator Reset point	<u>See SI 1</u>	\pm	<u> </u>	Inc./Dec.	<u> </u>
Startup Contact: <u>Jon Molnar</u>			Phone: <u>372-8794</u>		

Special Instructions:

1. Alarm setpoints are validated in Procedure IC-03 for MCO Hoist Weight Meter #1.
2. Trip point relay setpoints are validated in Procedure IC-07 for Relays 5X, 6X, 7X, 8X.

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-04
FACILITY SYSTEM START-UP	Revision No.	0
COMPONENT TEST PROCEDURE	Effective Date	12/4/98
INSTRUMENT LOOP CALIBRATION	Page	2 of 7

**DATA SHEET 11.1
INSTRUMENT LOOP CALIBRATION (Continued)**

LOOP COMPONENTS	LOOP/COMPONENT NAME	INPUT UNITS	INSTRUMENT RANGE	OUTPUT UNITS	ACCURACY
LCMHR1X	LOAD CELL	LBS	0 TO 7500		
			0 TO 0.75	MV/V	0.15%
LCMHR2X	LOAD CELL	LBS	0 TO 7500		
			0 TO 0.75	MV/V	0.15%
MWS1	Signal Conditioner	MV/V	0 TO 2		
			4 TO 20	MA	0.1%
MCOWD-1	Display Meter	MA	4 TO 20		
			0 TO 30,000	LBS	0.01%
5X	Trip Point Relay	MA	1 TO 100		0.2%
6X	Trip Point Relay	MA	1 TO 100		0.2%
7X	Trip Point Relay	MA	1 TO 100		0.2%
8X	Trip Point Relay	MA	1 TO 100		0.2%

Proc Step No.	ACTION	INITIALS / DATE
3.0	PREREQUISITES COMPLETE.	DWJ 1/6/24/99

TEST EQUIPMENT	M&TE NUMBER	CALIBRATION DUE DATE
N/A		

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-04
FACILITY SYSTEM START-UP	Revision No.	0
COMPONENT TEST PROCEDURE	Effective Date	12/4/98
INSTRUMENT LOOP CALIBRATION	Page	3 of 7

DATA SHEET 11.1
INSTRUMENT LOOP CALIBRATION (Continued)

Proc. Step No.	ACTION	INITIALS / DATE
5.0	INITIAL CONDITIONS COMPLETE.	<u>DW 10/24/99</u>
7.1.1.1	Failure modes correct for sudden/bleed down air tests. Record failure mode _____ FO/FC	<u>N/A</u>
7.1.1.2	Failure modes correct for gradual bleed down air test. Record failure mode _____ FO/FC	<u>N/A</u>
7.1.2.1	Failure modes correct for gradual electrical test. Record failure mode _____ FO/FC	<u>N/A</u>

MHM WEIGHT SYSTEM LOAD TEST FOR X AND Y CHANNELS

Attachment A

3964 Grappel + test block Total load

	Meter readings	Force applied	Total load	X ch	Y ch	X error	Y error	X-Y diff
Increasing weight	216	2160	6124	5911	5549	213	575	362
	421	4210	8174	7916	7514	258	660	402
	620	6200	10164	9896	9463	268	701	433
	821	8210	12174	11910	11480	264	694	430
	1020	10200	14164	13914	13449	250	715	465
	1215	12150	16114	15910	15450	204	664	460
	1410	14100	18064	17910	17425	154	639	485
	1605	16050	20014	19920	19420	94	594	500
	1800	18000	21964	21920	21400	44	564	520
	1992	19920	23884	23915	23350	-31	534	565
	2195	21950	25914	25920	25350	-6	564	570
	2385	23850	27814	27945	27320	-131	494	625
	2580	25800	29764	29930	29311	-166	453	619
	2765	27650	31614	31906	31250	-292	364	656
Decreasing weight	2510	25100	29064	29890	29215	-826	-151	675
	2312	23120	27084	27896	27244	-812	-160	652
	2105	21050	25014	25699	25076	-685	-62	623
	1915	19150	23114	23780	23170	-666	-56	610
	1728	17280	21244	21915	21270	-671	-26	645
	1524	15240	19204	19855	19242	-651	-38	613
	1335	13350	17314	17875	17310	-561	4	565
	1138	11380	15344	15791	15244	-447	100	547
	950	9500	13464	13899	13362	-435	102	537
	740	7400	11364	11800	11260	-436	104	540
	550	5500	9464	9875	9340	-411	124	535
	370	3700	7664	7850	7399	-186	265	451
	170	1700	5664	5895	5460	-231	204	435

ALL readings are in pounds

Dw 6/24/99

DATA SHEET 11.1
 INSTRUMENT LOOP CALIBRATION (Continued)

7.2, 7.3, 7.4.1, 7.4.3 (10.0)

LOOP ACCURACY		DEVICE OUTPUTS											
± 5.0 % DWS 7/7/99		DESIRED			AS-FOUND			ERROR			ALLOWED ERROR		
INPUT COMPONENT NO.		COMPONENT ID NO.			COMPONENT ID NO.			COMPONENT ID NO.			COMPONENT ID NO.		
% SPAN	INPUT UNITS LBS	MCO D-1 LBS			MCO WD-1			MCO WD-1			MCO WD-1		
0%	0	0									5.0%		
25%	7,500	7,500									5.0%		
50%	15,000	15,000									5.0%		
75%	22,500	22,500									5.0%		
100%	30,000	30,000									5.0%		
75%	22,500	22,500									5.0%		
50%	15,000	15,000									5.0%		
25%	7,500	7,500									5.0%		
0%	0	0									5.0%		

SEE ATTACHED
 A

Proc. Step No. ACTION INITIALS / DATE

MWS1 CSB(W379)-015-11-059

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-04
FACILITY SYSTEM START-UP	Revision No.	0
COMPONENT TEST PROCEDURE	Effective Date	12/4/98
INSTRUMENT LOOP CALIBRATION	Page	5 of 7

DATA SHEET 11.1
INSTRUMENT LOOP CALIBRATION (Continued)

Proc. Step No.	ACTION	INITIALS/DATE
7.4.3	Verify the above data is acceptable and within the allowable error (10/2)	<u>DLW 1/6/24/99</u>
7.5.1	Verify annunciator window engraving or MMI/HMI alarm/status designations are correct, as listed below. Annunciator Engraving <u>See ref. drawings</u> MMI/HMI Designation <u>See ref. drawings</u>	<u>DLW 1/6/24/99</u>
7.5.4	Verify annunciator alarms and resets, at values specified below. (10.2) Required annunciator alarm point _____ Inc./Dec. _____ Required annunciator alarm reset point _____ Inc./Dec. _____ Actual annunciator alarm point _____ Inc./Dec. _____ Actual annunciator alarm reset point _____ Inc./Dec. _____	<u>DLW 1/6/24/99</u> } <u>SEE S.I.</u>
7.5.5	Verify that loop diagram has been highlighted for that portion of the loop that has been functionally tested.	<u>DLW 1/6/24/99</u>
7.6.1	Verify that the controller responds to changes in manual mode, as indicated below. Record results in space provided. Manually set controller output to 0% _____, 50% _____, 100% _____ Final control element position output to 0% _____, 50% _____, 100% _____	<u>N/A</u>
7.6.2	Verify limit switches and indicating lights operate properly	<u>DLW 1/6/24/99</u>
7.6.3	Record controller as-found PID settings. Re-adjust controller PID settings to a narrow proportional band (P) and minimum integral (I) and derivative (D). As-Found PID settings P _____, I _____, D _____	<u>N/A</u>

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-04
FACILITY SYSTEM START-UP	Revision No.	0
COMPONENT TEST PROCEDURE	Effective Date	12/4/98
INSTRUMENT LOOP CALIBRATION	Page	6 of 7

DATA SHEET 11.1
INSTRUMENT LOOP CALIBRATION (Continued)

Proc. Step No.	ACTION	INITIALS/DATE
7.6.4	Verify the final control elements response to varying controller inputs in automatic mode. The final control element will move to within 10 % of full closed or full open position, depending on controller action (i.e., – direct or reverse action). Record controller action _____ Dir./Rev.	<u>N/A</u>
7.6.5	Verify the final controllers PID settings have been returned to its as-found settings or to new settings, as directed by the Construction Field Engineer. Record as-left settings below. As-Left PID Settings P _____, I _____, D _____	<u>N/A</u>
7.7	Verify re-alignment of valves, switches and circuit breakers. Reinstallation of fuses and removal of jumpers, as configured for testing.	<u>DLW 16/24/99</u>
7.8	Verify acceptance criteria have been satisfied. Acceptance criteria satisfied <u>YES</u> Yes/No Additional calibration and testing required <u>NO</u> Yes/No	<u>DLW 16/24/99</u>
8.0	RESTORATION COMPLETE	<u>DLW 16/24/99</u>
10.0	ACCEPTANCE CRITERIA Loop accuracy is within allowable error limits.	<u>DLW 16/24/99</u>

SPENT NUCLEAR FUEL PROJECT	Procedure No.	SNF-CTP-IC-04
FACILITY SYSTEM START-UP	Revision No.	0
COMPONENT TEST PROCEDURE	Effective Date	12/4/98
INSTRUMENT LOOP CALIBRATION	Page	7 of 7

DATA SHEET 11.1
INSTRUMENT LOOP CALIBRATION (Continued)

Remarks: DATA WAS COLLECTED DURING PAT 1 STEPS 9.11.1529 -
9.11.1533 OF PROCEDURE SNF-W379-PAT-015-1
USING THE LOAD CELL VERIFICATION SYSTEM

Performed By: Dawayne Welch Date: 6/25/99
 Technician

Reviewed By: NO SENT IN PERSON ONE Date: 7-12-99
 AI Witness

Reviewed By: Roberto V. Cruz Date: 6/25/99
 Startup Test Engineer

Approved By: J. P. McLean Date: 6/25/99
 Test Director

Direction	Force	Total	X	X-Error	Y	Y-Error	Avg Error
Inc	2160	6124	5911	3.48%	5549	9.39%	6.43%
Inc	4210	8174	7916	3.16%	7514	8.07%	5.62%
Inc	6200	10164	9896	2.64%	9463	6.90%	4.77%
Inc	8210	12174	11910	2.17%	11480	5.70%	3.93%
Inc	10200	14164	13914	1.77%	13449	5.05%	3.41%
Inc	12150	16114	15910	1.27%	15450	4.12%	2.69%
Inc	14100	18064	17910	0.85%	17425	3.54%	2.19%
Inc	16050	20014	19920	0.47%	19420	2.97%	1.72%
Inc	18000	21964	21920	0.20%	21400	2.57%	1.38%
Inc	19920	23884	23915	-0.13%	23350	2.24%	1.05%
Inc	21950	25914	25920	-0.02%	25350	2.18%	1.08%
Inc	23850	27814	27945	-0.47%	27320	1.78%	0.65%
Inc	25800	29764	29930	-0.56%	29311	1.52%	0.48%
Inc	27650	31614	31906	-0.92%	31250	1.15%	0.11%
Average Error over Span (Inc):							2.54%
Dec	25100	29064	29890	-2.84%	29215	-0.52%	-1.68%
Dec	23120	27084	27896	-3.00%	27244	-0.59%	-1.79%
Dec	21050	25014	25699	-2.74%	25076	-0.25%	-1.49%
Dec	19150	23114	23780	-2.88%	23170	-0.24%	-1.56%
Dec	17280	21244	21915	-3.16%	21270	-0.12%	-1.64%
Dec	15240	19204	19855	-3.39%	19242	-0.20%	-1.79%
Dec	13350	17314	17875	-3.24%	17310	0.02%	-1.61%
Dec	11380	15344	15791	-2.91%	15244	0.65%	-1.13%
Dec	9500	13464	13899	-3.23%	13362	0.76%	-1.24%
Dec	7400	11364	11800	-3.84%	11260	0.92%	-1.46%
Dec	5500	9464	9875	-4.34%	9340	1.31%	-1.52%
Dec	3700	7664	7850	-2.43%	7399	3.46%	0.52%
Dec	1700	5664	5895	-4.08%	5460	3.60%	-0.24%
Average Error over Span (Dec):							-1.28%

Max. Deviation Allowed = 5% over span

X-Error = (Total-X)/Total

Y-Error = (Total-Y)/Total

Avg Error = (YError + XError)/2

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. **N/A**CGI No. **CGI-SNF-D-MHM-013**

Page 1 of 8

Title: **P2, P62, P65 and P80 - Honeywell Limit Switch LSYDC3K**

Section 1 Part Information

Item No.: **N/A**Manufacturer: **N/A**Supplier: **N/A**Mfg. Part/Model No.: **N/A**Supplier's P/N: **N/A**Part Description: **N/A****ORIGINAL**End Use Description: **N/A**

Section 2a Component Information

Equipment No.:

**LFMJCY, LFMCOCX,
LFMCOCY**

Specification No.:

**Ederer F-2566, Foster
Wheeler MJX-SDX
452656**

Manufacturer:

Honeywell

Past P.O. No.:

N/A

Manufacturer's Part/Model No.:

LSYDC3K

Equipment Supplier (if different from manufacturer):

ALSTOM, Foster Wheeler

Equip. Supplier's Part No.:

N/A

Component Description: Limit Switches for interlocks P02 and P80, LFMCOCX, LFM COCY and LFMJCY are located on the MCO grapple assembly, show when MCO grapple is in contact with a load (LFMCOCX & LFM COCY) and measure MCO grapple jaws fully closed (LFMJCY), to inhibit operating mode changes. LFMJCY is also used in interlocks P62 & P65.

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?

YES (go to #2 below)

NO (go to procedure step 6.3.2, proceed to dedicate Item)

If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate with project CGI Interface Engineer or BTR)

YES (go to #2 below, procedure step 6.3.2, dedicate Item)

NO (procedure step 6.3.2, dedicate Item)

2. List of Candidate qualified NQA1 suppliers or ISO 9000 suppliers, if used: **N/A**

3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): **N/A**

Section 2c CGI Determination

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?

YES (the Item is not commercial grade)

NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?

NO (the item is not commercial grade)

YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?

NO (the item is not commercial grade)

YES (continue)

All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. **N/A** CGI No. **CGI-SNF-D-MHM-013**

Page 2 of 8

Title: **P2, P62, P65 and P80 - Honeywell Limit Switch LSYDC3K**

Section 2d Reason for Dedication

The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):

- Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
- Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
- Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
- Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
- Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. **These interlocks inhibit operating mode changes, lowering of the shield skirt, and lowering of the MCO hoist if the grapple jaws are not closed, are in contact with a load, or the load is an MCO. Prevents MCO shear due to lateral movement of the MHM, MCO drop due to shear of the hoist cable, and MCO drop to the maintenance pit.**

B. Part/Component Functional Mode:

- Safety Function #1: Active Passive
- Safety Function #2: Active Passive
- Safety Function #3: Active Passive

Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function
 Passive - Change of state is not required for the component to perform its safety function

C. Host Component Safety Function (if applicable): **N/A**

1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

- 1. **Failure of switch contacts to open upon demand results in potential override of interlock channel.**
- 2. **Plunger/arm inoperative results in failure to provide interlock function at correct demand position.**

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required:

- Yes
- No

If yes: Environmental Qualification Requirements
 Limiting Environmental Conditions:
 Required Safety Functions:
 Qualification Period:

Natural Phenomena Hazard (NPH) Design Required:

- Yes
- No

If yes: NPH Design Requirements
 Performance Category:
 NPH Design Req'ts.:
 Required Safety Functions:

Section 5 Component Functional Classification

- Safety Class (SC)
- General Service (GS)
- Safety Significant (SS)

If part/component classification is different from host component/system, document basis. **N/A**

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: **N/A**

Safety Analysis Report (SAR): **HNF-3672 Rev. 0**

Drawings: **Ederer, Inc. EB-33056, Sht 13A & 13B, Hanford H-2-827174, Shts. 9, 23 & 27**

Vendor Manual/Manufacturer/Supplier Information: **Honeywell Series LS compact limit switches**

Other: **ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998.**


ENCLOSURE
 JWP CES
 4/11/00

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 3 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-013
Title: P2, P62, P65 and P80 - Honeywell Limit Switch LSYDC3K

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Honeywell	1, IN	X	
Model Number	LSYDC3K	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Actuator (Note 1)	RollerTop Plunger	1, IN	X	
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Contact rating	Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts	1, T		X
Insulation Resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v.	1, T		X
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring.	1, T		X
4. Notes and Legend:		Acceptance Method (Acc Meth):		
Rev. 2: All Pages: New Forms; Pages 3, 5, 7: added Note 1 Note 1: This actuator is installed with the limit switch - replacement limit switches will not include an actuator - the existing actuator will be placed on the replacement switch. Therefore, the physical CC specified for the actuator lever need not be performed on the replacement limit switch. Rev. 3: Pages 3, 6 & 7: Rev'd Contact Rating Criteria to "Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts" from 10 amps for prevention of equipment damage due to excessive current; Pages 1, 2 & 5: Rev'd equipment ID Nos., and the component description per SEL changes.		1. Special Test and Inspection 1, IN for Inspection 1,T for Test 2. Commercial Grade Survey 3. Source Verification 4. Vendor/Item History		

Section 10 Initial Review and Approval	
Approvals:	
Designated Engineer:	
Design Authority:	<u>Lang Andersen 2/29/00</u>
QA Engineer:	<u>Stephen Scott Mon 3-30-2000</u>

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. **N/A**CGI No. **CGI-SNF-D-MHM-013**

Page 4 of 8

Title: **P2, P62, P65 and P80 - Honeywell Limit Switch LSYDC3K**

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	X	Switch contacts corrode closed and fail to open upon demand.
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Switch contacts fuse closed and fail to open upon demand.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Switch mechanism jams and contacts fail to open upon demand.
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
1. Switch contacts are closed to permit equipment movement. Contacts open for the interlock function to prevent lateral movement of the MHM. Any failure which prevents contacts opening inhibits the particular switch interlock function.			
2. Actuator plunger/arm seizure or break renders the contact opening inoperable.			
3. Short circuit could give false signal to energize interlock function.			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 5 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-013
Title: P2, P62, P65 and P80 - Honeywell Limit Switch LSYDC3K

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1	
Item Description: P2, P62, P65 and P-80 Interlock limit switches	Equip #: LFMJCY, LFMCOCX, LFMCOCY
System #: MHM	Model #: LSYDC3K
Manufacturer (Address/Phone): Honeywell 1-800-537-6945	Supplier (Address/Phone):

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Model Number
X			3. Actuator (Note 1)
	X		4. Contact Rating
	X		5. Insulation Resistance
	X		6. Mechanical Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic: Manufacturer	Sample Size*: 100%
Acceptance Criteria: Honeywell	
Receipt Inspection Plan / Report #: CGI-SNF-D-MHM-013-TP-013B,C,D	
Characteristic: Model Number	Sample Size*: 100%
Acceptance Criteria: LSYDC3K	
Receipt Inspection Plan / Report #: TP-013 B, C, D	
Characteristic: Actuator (Note 1)	Sample Size*: 100%
Acceptance Criteria: RollerTop Plunger	
Receipt Inspection Plan / Report #: TP-013B,C,D	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/ACGI No. CGI-SNF-D-MHM-013

Page 6 of 8

Title: P2, P62, P65 and P80 - Honeywell Limit Switch LSYDC3K**SECTION 4 BY SPECIAL TEST** * See Attachment H, Table H-1 of Desk Instruction for Sampling Size References (See Section 7)Characteristic for Test: **Contact Rating**Samp Size*: Normal Reduced TightenedAcceptance Criteria: **Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts**Actual Test Value: See TPTest Plan and Report #: TP-013B,C,DCharacteristic for Test: **Insulation Resistance**Samp Size*: Normal Reduced TightenedAcceptance Criteria: **Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000 vdc.**Actual Test Value: See TPTest Plan and Report #: TP-013B,C,DCharacteristic for Test: **Mechanical Operation**Samp Size*: Normal Reduced TightenedAcceptance Criteria: **Cycle switch - confirm contacts open and close with smooth operation and free release of spring**Actual Test Value: See TPTest Plan and Report #: TP-013B,C,D

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. NA

CGI No. CGI-SNF-D-MHM-013

Page 7 of 8

Title: P2, P62, P65 and P80 - Honeywell Limit Switch LSYDC3K

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Honeywell Limit Switch

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Honeywell	X		1, IN	TP-013 B,C,D	NA	3	0	XWEST	LAPAGLIA PERE [Signature]	4/10/00
Model Number	LSYDC3K	X		1, IN							
Actuator (Note 1)	RollerTop Plunger	X		1, IN							
Contact Rating	Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts		X	1, T							
Insulation Resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v.		X	1, T							
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring		X	1, T							

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-013C,D,B cited above. CES Testing Agency Approval: <u>NR CES 4/11/00</u> Date: <u>4/11/00</u>		BUYER VERIFICATION Design Authority: <u>Wesley J. Jensen</u> Date: <u>4-11-00</u>	
Testing Agency QA Engineer: <u>NR CES 4/11/00</u> Date: _____		QA Engineer: <u>Stephan Scott Moore</u> Date: <u>4-20-2000</u>	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. **N/A** CGI No. **CGI-SNF-D-MHM-013**

Page 8 of 8

Title: **P2, P62, P65 and P80 - Honeywell Limit Switch LSYDC3K**

Section 6 Contacts/Phone Numbers

Name	Phone
Design Authority GRAIG SWENSON	() 376-0288
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents	For Critical Characteristics
Drawings:	
Manuals (specify type & number):	
Design Calculations	
Installation Instructions	
Operation Instructions	
Calibration Instructions	
Manufacturer's Recommended Spare Parts List	
X Other: Honeywell Series LS Compact Limit Switches	All
Procurement Documents	For Critical Characteristics
Certificate of Conformance/Compliance	
Seismic Qualification Certificate	
Environmental Qualification Certificate	
X Test Report (s): CSB(W379)-015-11-1042	
Inspection Report (s):	
CMTRs for ASME Pressure Retaining Materials	
Valve Seat Leakage Report	
Weld Records	
Material Traceability Record	
Other:	

ENCLOSURE 2/25/00

Dedication Test Plan – IST-LS-1 Test Plan No.: CGI-SNF-D-MHM-013-TP-013B Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMJCY	<b style="font-size: 2em;">ORIGINAL Rev. No. 1 Page 1 of 7
---	--

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
1	Avoid equipment damage	3.4.3 3.4.10	Lower current from 16 amps to 5 amps		CES 3/29/00	SSM 4-3-2000

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST-LS-1

ORIGINAL

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013B

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMJCY

Page 2 of 7

In-Situ Test Procedure**Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *JWP* *Craig Swenson* Date: 3/28/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MCC
Electrician	DAN K. YORK	P.C.E.	<i>Dan K. York</i>	DKY
Electrician Quality Control	Stephen R. Cowley	PEE	<i>Stephen R. Cowley</i>	SRC
Design Authority Representative	LARRY W. PERKE	XWBST	<i>Larry W. Perke</i>	JWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A
Design Authority	Craig Swenson	PHI	<i>Craig Swenson</i>	CS

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC

Megger Instrument capable of 1000 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: FLUKE 787 I.D.: BAT 167 Calib. Due date: 05-28-00

Test Instrument type: Avo BM80/2 I.D.: 6410-589 Calib. Due date: 02-09-01

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013B

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMJCY

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.

2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFMJCY	LFMJCY	Acc
Manufacturer:	HONEYWELL	Honeywell	Acc
Model:	LSYDC3K	LSYDC3K	Acc
Actuator:	OK	Roller Top Plunger	Acc
Serial No./Lot No./Date Code:	N/A	N/A	Acc

3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 03-29-00 9:30am

3.2 Mechanical Operation

3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	6	> 5 times	Acc
Describe Operation:	OK	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	OK	Free release of spring.	Acc

Dedication Test Plan – IST-LS-1	Rev. No. 1
Test Plan No.: CGI-SNF-D-MHM-013-TP-013B	
Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMJCY	Page 4 of 7

3.3 Insulation Resistance Test

- 3.3.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing. Remove the amphenol connector at the grapple housing.
- 3.3.2 Apply a nominal 1000 VDC via Megger device between non-continuity terminals on the limit switch side of the amphenol connector nos. 18 and 25 (Common - Across NO Contact) and then between terminal 25 and ground. Record the resistances.
- 3.3.3 Remove the Megger device.
- 3.3.4 Manually adjust the limit switch actuator to open the normally closed (NC) contacts.
- 3.4.5 Apply a nominal 1000 VDC via Megger device between non-continuity terminals on the the limit switch side of the amphenol connector nos. 18 and 24 (Common - Across open NC Contact) and then between terminal 24 and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
18 and 25	Common to NO	> 7.8 Gohm	> 10 Megohms	Acc
25 and Ground	NO to Ground	> 6.3 Gohm	> 10 Megohms	Acc
18 and 24	Common to open NC*	> 7.7 Gohm	> 10 Megohms	Acc
24 and ground	Open NC to Ground*	> 7.6 Gohm	> 10 Megohms	Acc

* Normally closed contacts are open.

- 3.3.6 De-energize and remove the test equipment.

3.4 Contact Rating Test

- 3.4.1 Setup the test equipment and Limit Switch specimen for contact rating testing.
- 3.4.2 At grapple mounted amphenol connector, disconnect the connector and imput test leads onto the limit switch side of the connector terminal no. 18 (Common) and terminal 24 (LFMJCY Normally Closed Contact).

5 Amps @ 100 VDC

- 3.4.3 Apply a nominal ~~10~~ 5 amps, resistive, across the normally closed contacts of the test specimen.

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013B

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMJCY

Page 5 of 7

Caution: Do not change state of contacts while energized.

3.4.4 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit 18 and 24 (Terminals COM-NC)	• 449 VAC	< 0.5 Volts AC drop	Acc

3.4.6 Reduce the current source to zero amps.

3.4.7 Disconnect the power supply from terminals 18 and 24.

3.4.8 Manually adjust the limit switch actuator to close the normally open contacts.

3.4.9 Connect the power supply to terminals 18 and 25.

3.4.10 Apply a nominal ^{5 amp 240VAC test} ~~10~~ amps, resistive, across the closed normally open contacts of the test specimen.

3.4.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit 18 and 25 (Terminals COM- Closed NO Contact):	• 488 VAC	< 0.5 Volts AC drop	Acc

3.4.12 Reduce the current source to zero amps and remove the power supply from terminals 18 and 25.

3.4.13 Manually adjust the limit switch actuator to close the normally closed contacts.

3.5 Terminate the test.

3.5.1 Reconnect the Amphenol connector and tighten hand tight.

3.5.2 Remove lockout/tagout and restore system to normal.

3.5.4 Record: Date /Time of Test End: 03-29-00 10:22 a.m.

Dedication Test Plan – IST-LS-1	Rev. No. 1
Test Plan No.: CGI-SNF-D-MHM-013-TP-013B	
Test Specimen: Honeywell.LSYDC3K Limit Switch, Eqmt. No.: LFMJCY	Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met

Michael Cram

03-29-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-29-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) JWP Wang Swenson Date: 3/29/00

QA/QC (signature) Stephen Scott Moss Date: 4-3-2000

LIFTED LEAD LOG

Junction Box: Grapple Amphenol Connector

Drawing #	Sheet #	Wire #	Device #	Amphenol Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	11	N/A	LFMJCY	Connector	OKY	3-29-00	SRL	3-29-00	OKY	3-29-00	SRL	3-29-00

Remarks:

SNF-6315, Rev. 0

Page 6 of 10

Limit and Enclosed Switches

Plunger Actuated Switches

ASSEMBLED CONDITIONS

Catalog listings in order guide below are factory assembled with:

- Side plungers facing front (label side) of switch. Rollers on side plungers are in horizontal position.


- Roller on top plungers are parallel to mounting surface.
- Lights on indicator versions are wired to N.O. circuit.

ORDER GUIDE

Momentary action, except for maintained contact LSG version. UL listed, CSA certified.

Refer to facing page to specify modifications to these assembled conditions.

For low temperature, high temperature or preleaded versions see page A42.



Circuits on any one pole must be the same polarity.

Catalog listings in this chart are complete switches.			Catalog Listings						
			Top Plungers			Side Plungers			
Circuitry	Elec. Rating Page A34	Body** Style	Plain	Roller	Adjustable	Plain	Roller	Adjustable	Maintained (Circuitry Shown Above)
Silver contacts	A	Plug-in 1/2" Conduit	LSC1A	LSD1A	LSV1A	LSE1A	LSF1A	LSW1A	LSG1A
Gold cross pt.	C	Plug-in 1/2" Conduit	LSC1J	LSD1J	LSV1J	LSE1J	LSF1J	LSW1J	---
Gold plated	C		---	LSD1E	---	---	LSF1E	LSW1E	---
 SPDT Double Break	A*	120 V. Ind. Lite Plug-in 1/2" Conduit*	LSC5A	LSD5A	LSV5A	LSE5A	LSF5A	LSW5A	LSG5A
	A*	240 V. Ind. Lite Plug-in 1/2" Conduit*	LSC8A	LSD8A	LSV8A	LSE8A	LSF8A	LSW8A	LSG8A
	A	Non plug-in 1/2" Conduit	LSC3K	LSD3K	LSV3K	LSE3K	LSF3K	LSW3K	LSG3K
 DPDT Double Break	B	Plug-in 3/4" Conduit	LSC2B	LSD2B	LSV2B	LSE2B	LSF2B	LSW2B	LSG2B
	B	120 V Ind. Lite Plug-in 3/4" Conduit	LSC2R	LSD2R	LSV2R	LSE2R	LSF2R	LSW2R	LSG2R
	B	Plug-in 1/2" Conduit	LSC6B	LSD6B	LSV6B	LSE6B	LSF6B	LSW6B	LSG6B
	B	Non plug-in 3/4" Conduit	LSC4L	LSD4L	LSV4L	LSE4L	LSF4L	LSW4L	LSG4L
	B	Non plug-in 1/2" Conduit	LSC7L	LSD7L	LSV7L	LSE7L	LSF7L	LSW7L	LSG7L
 SPNC Direct Acting	D	Non plug-in 1/2" Conduit	---	---	---	LSE3N	LSF3N	LSW3N	LSG3N

*Use at voltage indicated for light. Upper operating temperature limit for lighted units is 200°F. Wired to N.O. circuit.

** Plug-in listings include base receptacle.

OPERATING CHARACTERISTICS


mm Pretravel (in. max.)	1.78 .070	1.78 .070	1.78 .070	2.54 .100	2.54 .100	2.54 .100	4.32 .170
Differential mm Travel (in. max.)	SPDT	0.38 .015	0.38 .015	0.38 .015	0.64 .025	0.64 .025	2.29 .090
	DPDT	0.51 .020	0.51 .020	0.51 .020	0.89 .035	0.89 .035	2.29 .090
mm Overtravel (in. min.)	4.83 .190	4.83 .190	4.83 .190	4.83 .190	4.83 .190	4.83 .190	2.0 .080
Newton Operating Force (lb. max.)	17.8 4	17.8 4	17.8 4	26.7 6	26.7 6	26.7 6	44.5 10
Operating Point mm (in.)	45.8 ± 0.76 1.805 ± .030	55.9 ± 1.02 2.200 ± .040	53.0 to 59.3 2.085 to 2.335	33.0 ± 0.76 1.300 ± .030	44.1 ± 1.02 1.735 ± .040	41.0 to 47.4 1.615 to 1.865	37.6 ± 0.76 1.480 ± .030
Operating Temperature Range	10°F to 200°F -12 to 93°C		10°F to 200°F -12 to 93°C		10°F to 200°F -12 to 93°C		30°F to 200°F -1 to 93°C

LSYDC3K

FLUORO-CARBON SEALED VERSION of LSD3K

FOR NOTES SEE SET 1

363A0033



CONTROLLED COPY
MCC #15

M11M-PC2-087
572-91

M11M-PC2-093
521-99

M11M-PC2-086
12-11-198

U.S. DEPARTMENT OF ENERGY WASHINGTON FIELD OFFICE MW-504-432438 WCC-5-0488	
H-2-87169	
CRC ALSTOM SINGAPORE SYSTEMS LTD SINGAPORE, SINGAPORE	
NO. OF SHEETS	NO. OF SHEETS USED
363A0033	363A0033

BLACK INTERCONNECTION DIAGRAM - JANUARY 84, 6

ORIGINAL

Dedication Test Plan – IST-LS-1	Rev. No. 1
Test Plan No.: CGI-SNF-D-MHM-013-TP-013C	
Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCX	Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
1	Avoid equipment damage	3.9.3 3.9.16	Lower current from 10 amps to 5 amps		CES 2/29/00	SJM 4-3-200

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013C

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCX

Page 2 of 7

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *Craig Swenson* Date: 3/28/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Balhaven	<i>Michael Cram</i>	MCC
Electrician	DAN K. YORK	P.C.E	<i>Dan K. York</i>	D.K.Y
Electrician Quality Control	Stephen P. Cowley	PCE	<i>Stephen P. Cowley</i>	SEC
Design Authority Representative	LARRY W. PACE	WEST	<i>Larry W. Pace</i>	LWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A
Design Authority	Craig Swenson	PHI	<i>Craig Swenson</i>	CS

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC

Megger Instrument capable of 1000 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: AVO BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LS-1	Rev. No. 1
Test Plan No.: CGI-SNF-D-MHM-013-TP-013C	
Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCX	Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

- 1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.
- 2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFMCOCX	LFMCOCX	Acc
Manufacturer:	HONEYWELL	Honeywell	Acc
Model:	LSYDC3K	LSYDC3K	Acc
Actuator:	OK	Roller Top Plunger	Acc
Serial No./Lot No./Date Code:	N/A	N/A	Acc

- 3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 03-29-00 9:40 a.m.

- 3.2 Mechanical Operation

3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

- 3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	6	> 5 times	Acc
Describe Operation:	OK	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	OK	Free release of spring.	Acc

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013C

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCX

Page 4 of 7

3.3 Insulation Resistance Test

- 3.3.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing. Remove the amphenol connector at the grapple housing.
- 3.3.2 Apply a nominal 1000 VDC via Megger device between non-continuity terminals on the limit switch side of the amphenol connector nos. 1 and 4 (Common - Across NO Contact) and then between terminal 4 and ground. Record the resistances.
- 3.3.3 Remove the Megger device.
- 3.3.4 Manually adjust the limit switch actuator to open the normally closed (NC) contacts.
- 3.4.5 Apply a nominal 1000 VDC via Megger device between non-continuity terminals on the the limit switch side of the amphenol connector nos. 1 and 3 (Common - Across open NC Contact) and then between terminal 3 and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
1 and 4	Common to NO	> 6 Gohm	> 10 Megohms	Acc
4 and Ground	NO to Ground	> 5 Gohm	> 10 Megohms	Acc
1 and 3	Common to open NC*	> 5.6 Gohm	> 10 Megohms	Acc
3 and ground	Open NC to Ground*	> 9.7 Gohm	> 10 Megohms	Acc

* Normally closed contacts are open.

- 3.3.6 De-energize and remove the test equipment.

3.4 Contact Rating Test

- 3.4.1 Setup the test equipment and Limit Switch specimen for contact rating testing.
- 3.4.2 At grapple mounted amphenol connector, disconnect the connector and input test leads onto the limit switch side of the connector terminal no. 1 (Common) and terminal 3 (LFMCOCX Normally Closed Contact).
5 Amp 240V/00 OBS
- 3.4.3 Apply a nominal 10 amps, resistive, across the normally closed contacts of the test specimen.

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013C

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCX

Page 5 of 7

Caution: Do not change state of contacts while energized.

3.4.4 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit 1 and 3 (Terminals COM-NC)	.283 v _{ac}	< 0.5 Volts AC drop	Acc

3.4.6 Reduce the current source to zero amps.

3.4.7 Disconnect the power supply from terminals 1 and 3.

3.4.8 Manually adjust the limit switch actuator to close the normally open contacts.

3.4.9 Connect the power supply to terminals 1 and 4.

3.4.10 Apply a nominal ~~10~~ ⁵ amp ~~resistive~~ ^{5 amp resistive} load across the closed normally open contacts of the test specimen.

3.4.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit 1 and 4 (Terminals COM- Closed NO Contact):	.294 v _{ac}	< 0.5 Volts AC drop	Acc

3.4.12 Reduce the current source to zero amps and remove the power supply from terminals 1 and 4.

3.4.13 Manually adjust the limit switch actuator to close the normally closed contacts.

3.5 Terminate the test.

3.5.1 Reconnect the Amphenol connector and tighten hand tight.

3.5.2 Remove lockout/tagout and restore system to normal.

3.5.4 Record: Date /Time of Test End: 03-29-00 10:30 a.m.

Dedication Test Plan - IST-LS-1	Rev. No. 1
Test Plan No.: CGI-SNF-D-MHM-013-TP-013C	
Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCX	Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met.

Michael Cron
03-29-00

Notes:

Certified Instrumentation Technician (signature) *Michael Cron* Date: *03-29-00*

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *JMP Craig Anderson* Date: *3/29/00*

QA/QC (signature) *Stephen Scott Moss* Date: *4-3-2000*

Dedication Test Plan - IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013C

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCX

Page 7 of 7

LIFTED LEAD LOG

Junction Box: Grapple Amphenol Connector

Drawing #	Sheet #	Wire #	Device #	Amphenol Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	10	N/A	LFMCOCX	Connector	DKY	3-29-00	SRL	3-27-00	DKY	3-29-00	SRL	3-29-00

Remarks:

SNF-6315, Rev. 0

Page 619

Limit and Enclosed Switches Plunger Actuated Switches

ASSEMBLED CONDITIONS


Catalog listings in order guide below are factory assembled with:

- Side plungers facing front (label side) of switch. Rollers on side plungers are in horizontal position.

- Roller on top plungers are parallel to mounting surface.
- Lights on indicator versions are wired to N.O. circuit.

Refer to facing page to specify modifications to these assembled conditions.

For low temperature, high temperature or preflexed versions see page A42.



ORDER GUIDE

Momentary action, except for maintained contact LSG version. UL listed, CSA certified.

Catalog listings in this chart are complete switches.			Catalog Listings						
			Top Plungers			Side Plungers			
Circuitry	Elec. Rating Page A34	Body** Style	Plain	Roller	Adjustable	Plain	Roller	Adjustable	Maintained (Circuitry Shown Above)
Silver contacts	A	Plug-in 1/2" Conduit	LSC1A	LSD1A	LSV1A	LSE1A	LSF1A	LSW1A	LSG1A
Gold cross pt.	C	Plug-in 1/2" Conduit	LSC1J	LSD1J	LSV1J	LSE1J	LSF1J	LSW1J	---
Gold plated	C		---	LSD1E	---	---	LSF1E	LSW1E	---
 SPDT Double Break	A*	120 V. Ind. Lite Plug-in 1/2" Conduit*	LSC5A	LSD5A	LSV5A	LSE5A	LSF5A	LSW5A	LSG5A
	A*	240 V. Ind. Lite Plug-in 1/2" Conduit*	LSC8A	LSD8A	LSV8A	LSE8A	LSF8A	LSW8A	LSG8A
	A	Non plug-in 1/2" Conduit	LSC3K	LSD3K	LSV3K	LSE3K	LSF3K	LSW3K	LSG3K
 DPDT Double Break	B	Plug-in 3/4" Conduit	LSC2B	LSD2B	LSV2B	LSE2B	LSF2B	LSW2B	LSG2B
	B	120 V Ind. Lite Plug-in 3/4" Conduit	LSC2R	LSD2R	LSV2R	LSE2R	LSF2R	LSW2R	LSG2R
	B	Plug-in 1/2" Conduit	LSC6B	LSD6B	LSV6B	LSE6B	LSF6B	LSW6B	LSG6B
	B	Non plug-in 3/4" Conduit	LSC4L	LSD4L	LSV4L	LSE4L	LSF4L	LSW4L	LSG4L
	B	Non plug-in 1/2" Conduit	LSC7L	LSD7L	LSV7L	LSE7L	LSF7L	LSW7L	LSG7L
 SPNC Direct Acting	D	Non plug-in 1/2" Conduit	---	---	---	LSE3N	LSF3N	LSW3N	LSG3N


* Use at voltage indicated for light. Upper operating temperature limit for lighted units is 200°F. Wired to N.O. circuit.

** Plug-in listings include base receptacle.

OPERATING CHARACTERISTICS

mm	1.78	1.78	1.78	2.54	2.54	2.54	4.32	
Pretravel (in. max.)	.070	.070	.070	.100	.100	.100	.170	
Differential mm	SPDT		0.38	0.38	0.38	0.64	0.29	
	DPDT		.015	.015	.015	.025	.025	.090
Travel (in. max.)	DPDT		0.51	0.51	0.51	0.89	2.29	
mm	DPDT		.020	.020	.020	.035	.035	.090
mm	SPDT		4.83	4.83	4.83	4.83	4.83	2.0
	DPDT		.190	.190	.190	.190	.190	.080
Newton	SPDT		17.8	17.8	17.8	26.7	26.7	44.5
	DPDT		4	4	4	6	6	10
Operating Force (lb. max.)	SPDT		45.8 ± 0.76	55.9 ± 1.02	53.0 to 59.3	33.0 ± 0.76	44.1 ± 1.02	37.6 ± 0.76
	DPDT		1.805 ± 0.030	2.200 ± 0.040	2.085 to 2.335	1.300 ± 0.030	1.735 ± 0.040	1.480 ± 0.030
Operating Point mm (in.)	SPDT		10°F to 200°F	10°F to 200°F	10°F to 200°F	10°F to 200°F	10°F to 200°F	30°F to 200°F
	DPDT		-12 to 93°C	-12 to 93°C	-12 to 93°C	-12 to 93°C	-12 to 93°C	-1 to 93°C

LSYDC3K
FLUORO-CARBON SEALED VERSION OF LSD3K



ORIGINAL

Dedication Test Plan – IST-LS-1 Rev. No. 1
 Test Plan No.: CGI-SNF-D-MHM-013-TP-013D
 Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCY Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
1	Avoid equipment damage	3.4.7 3.4.10	lower current from 10 amps to 5 amps		UES 3/21/00	GSW 4-3-2000

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST-LS-1	Rev. No. 1
Test Plan No.: CGI-SNF-D-MHM-013-TP-013D	
Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCY	Page 2 of 7

In-Situ Test Procedure

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *JWP Craig Swanson* Date: 3/28/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MC
Electrician	DAN K. YORK	PCE	<i>Dan K. York</i>	DKY
Electrician Quality Control	Stephen R Cowley	PCE	<i>Stephen R Cowley</i>	SRC
Design Authority Representative	see below <u>SSM</u>	<u>4-3-200</u>		
Start-Up Representative (As Required) DA Rep.	LARRY W. PRICE	KUKST	<i>Larry W. Price</i>	JWP
Construction Management (As Required)	N/A	N/A	N/A	N/A
Design Authority	Craig Swanson	FHT	<i>Craig Swanson</i>	CBS

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC
 Megger Instrument capable of 1000 VDC Test Voltage
 MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
 Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM80/2 I.D.: GA10-889 Calib. Due date: 02-09-01
 Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00
 Test Instrument type: FULKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00
 Test Instrument type: _____ I.D.: _____ Calib. Due date: _____
 Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013D

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCY

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

- 1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.
- 2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFMCOCY	LFMCOCY	Acc
Manufacturer:	HONEYWELL	Honeywell	Acc
Model:	LSYDC3K	LSYDC3K	Acc
Actuator:	OK	Roller Top Plunger	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

- 3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 3-28-00 8:00 a.m.

- 3.2 Mechanical Operation

3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	6	> 5 times	Acc
Describe Operation:	OK	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	OK	Free release of spring.	Acc

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013D

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCY

Page 4 of 7

3.3 Insulation Resistance Test

- 3.3.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing. Remove the amphenol connector at the grapple housing.
- 3.3.2 Apply a nominal 1000 VDC via Megger device between non-continuity terminals on the limit switch side of the amphenol connector nos. 18 and 20 (Common - Across NO Contact) and then between terminal 20 and ground. Record the resistances.
- 3.3.3 Remove the Megger device.
- 3.3.4 Manually adjust the limit switch actuator to open the normally closed (NC) contacts.
- 3.3.5 Apply a nominal 1000 VDC via Megger device between non-continuity terminals on the the limit switch side of the amphenol connector nos. 18 and 21 (Common - Across open NC Contact) and then between terminal 21 and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
18 and 20	Common to NO	> 10.5 Gohm	> 10 Megohms	Acc
20 and Ground	NO to Ground	> 4.5 Gohm	> 10 Megohms	Acc
18 and 21	Common to open NC*	> 8.7 Gohm	> 10 Megohms	Acc
21 and ground	Open NC to Ground*	> 8.4 Gohm	> 10 Megohms	Acc

* Normally closed contacts are open.

- 3.3.6 De-energize and remove the test equipment.

3.4 Contact Rating Test

- 3.4.1 Setup the test equipment and Limit Switch specimen for contact rating testing.
- 3.4.2 At grapple mounted amphenol connector, disconnect the connector and input test leads onto the limit switch side of the connector terminal no. 18 (Common) and terminal 20 (LFMCOCY Normally Closed Contact).
- 3.4.3 Apply a nominal ^{5 amp @ 240V AC CES} ~~10~~ amps, resistive, across the normally closed contacts of the test specimen.

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013D

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCY

Page 5 of 7

Caution: Do not change state of contacts while energized.

3.4.4 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit 18 and 20 (Terminals COM-NC)	. 311 VAC	< 0.5 Volts AC drop	Acc

3.4.6 Reduce the current source to zero amps.

3.4.7 Disconnect the power supply from terminals 18 and 20.

3.4.8 Manually adjust the limit switch actuator to close the normally open contacts.

3.4.9 Connect the power supply to terminals 18 and 21.

3.4.10 Apply a nominal ^{5 Amp 3200 CES} ~~10~~ amps, resistive, across the closed normally open contacts of the test specimen.

3.4.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit 18 and 21 (Terminals COM- Closed NO Contact):	. 313 VAC	< 0.5 Volts AC drop	Acc

3.4.12 Reduce the current source to zero amps and remove the power supply from terminals 18 and 21.

3.4.13 Manually adjust the limit switch actuator to close the normally closed contacts.

3.5 Terminate the test.

3.5.1 Reconnect the Amphenol connector and tighten hand tight.

3.5.2 Remove lockout/tagout and restore system to normal.

3.5.4 Record: Date /Time of Test End: 03-28-00 9:30 a.m.

Dedication Test Plan - IST-LS-1	Rev. No. 1
Test Plan No.: CGI-SNF-D-MHM-013-TP-013D	
Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCY	Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met.

Michael Cram
03-29-00

Notes:

Certified Instrumentation Technician (signature) *Michael Cram* Date: 03-29-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *JMO Wang Swenson* Date: 3/29/00

QA/QC (signature) *Stephen Scott Moss* Date: 4-6-2000

Dedication Test Plan – IST-LS-1

Rev. No. 1

Test Plan No.: CGI-SNF-D-MHM-013-TP-013D

Test Specimen: Honeywell LSYDC3K Limit Switch, Eqmt. No.: LFMCOCY

Page 7 of 7

LIFTED LEAD LOG

Junction Box: Grapple Amphenol Connector

Drawing #	Sheet #	Wire #	Device #	Amphenol Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	11	N/A	LFMCOCY	Connector	DKY	3-29-00	JEL	3-29-00	DKY	3-29-00	SAL	3-29-00

Remarks:

SNF-6315, Rev. 0

Page 628

Limit and Enclosed Switches

HDL5 Series

Plunger Actuated Switches

ASSEMBLED CONDITIONS


Catalog listings in order guide below are factory assembled with:

- Side plungers facing front (label side) of switch. Rollers on side plungers are in horizontal position.

- Roller on top plungers are parallel to mounting surface.
- Lights on indicator versions are wired to N.O. circuit.

Refer to facing page to specify modifications to these assembled conditions.

For low temperature, high temperature or preleaded versions see page A42.



Circuits on any one pole must be the same polarity.

ORDER GUIDE

Momentary action, except for maintained contact LSG version. UL listed, CSA certified.

Catalog listings in this chart are complete switches.			Catalog Listings						
			Top Plungers			Side Plungers			
Circuitry	Elec. Rating Page A34	Body** Style	Plain	Roller	Adjustable	Plain	Roller	Adjustable	Maintained (Circuitry Shown Above)
Silver contacts	A	Plug-in 1/2" Conduit	LSC1A	LSD1A	LSV1A	LSE1A	LSF1A	LSW1A	LSG1A
Gold cross pt.	C	Plug-in 1/2" Conduit	LSC1J	LSD1J	LSV1J	LSE1J	LSF1J	LSW1J	---
Gold plated	C		---	LSD1E	---	---	LSF1E	LSW1E	---
Silver contacts MOMENTARY	A*	120 V. Ind. Lite Plug-in 1/2" Conduit*	LSC5A	LSD5A	LSV5A	LSE5A	LSF5A	LSW5A	LSG5A
SPDT Double Break	A*	240 V. Ind. Lite Plug-in 1/2" Conduit*	LSC8A	LSD8A	LSV8A	LSE8A	LSF8A	LSW8A	LSG8A
SPDT Double Break	A	Non plug-in 1/2" Conduit	LSC3K	LSD3K	LSV3K	LSE3K	LSF3K	LSW3K	LSG3K
Silver contacts	B	Plug-in 3/4" Conduit	LSC2B	LSD2B	LSV2B	LSE2B	LSF2B	LSW2B	LSG2B
MOMENTARY DPDT Double Break	B	120 V Ind. Lite Plug-in 3/4" Conduit	LSC2R	LSD2R	LSV2R	LSE2R	LSF2R	LSW2R	LSG2R
	B	Plug-in 1/2" Conduit	LSC6B	LSD6B	LSV6B	LSE6B	LSF6B	LSW6B	LSG6B
	B	Non plug-in 3/4" Conduit	LSC4L	LSD4L	LSV4L	LSE4L	LSF4L	LSW4L	LSG4L
SPNC Direct Acting	D	Non plug-in 1/2" Conduit	---	---	---	LSE3N	LSF3N	LSW3N	LSG3N


* Use at voltage indicated for light. Upper operating temperature limit for lighted units is 200°F. Wired to N.O. circuit.

** Plug-in listings include base receptacle.

OPERATING CHARACTERISTICS

	1.78	1.78	1.78	2.54	2.54	2.54	4.32
mm Pretravel (in. max.)	.070	.070	.070	.100	.100	.100	.170
Differential mm Travel (in. max.)	SPDT	0.38	0.38	0.38	0.64	0.64	2.29
	DPDT	.015	.015	.015	.025	.025	.090
mm Overtravel (in. min.)		0.51	0.51	0.51	0.89	0.89	2.29
		.020	.020	.020	.035	.035	.090
Newton Operating Force (lb. max.)		4.83	4.83	4.83	4.83	4.83	2.0
		.190	.190	.190	.190	.190	.080
Operating Point mm (in.)		17.8	17.8	17.8	26.7	26.7	44.5
		4	4	4	6	6	10
Operating Temperature Range		45.8 ± 0.76	55.9 ± 1.02	53.0 to 59.3	33.0 ± 0.76	44.1 ± 1.02	37.6 ± 0.76
		1.805 ± .030	2.200 ± .040	2.085 to 2.335	1.300 ± .030	1.735 ± .040	1.480 ± .030
		10°F to 200°F -12 to 93°C		10°F to 200°F -12 to 93°C		10°F to 200°F -12 to 93°C	30°F to 200°F -1 to 93°C

LSYDC3K
FLUORO-CARBON SEALED VERSION OF LSD3K



DO NOT CONNECT INTERLOCK CONTACT (1) TO MARKET RELAY CONTACT
 SEE ILLUSTRATION 130-13000 SHEET 1

Handwritten notes and signatures:
 300
 [Signature]
 [Signature]

CONTROLLED COPY
MCC #15

MHM - FCR-087
5-12-99

MHM - FCR-093
5-21-99

MHM - FCR-006
12.11.1988

U.S. DEPARTMENT OF ENERGY
 WESTINGHOUSE HAMFORD COMPANY
 MDK-50X-43268
 WPC-5-0468
 H-2-827169
 GEC ALSTOM ENGINEERING SYSTEMS LTD
 Multisite, Leicester, LE1 8JA, England

BLOCK INTERCONNECTION DIAGRAM - 363A0033 SHEET 6

THIS SHEET PRESENTS ON THE SCALE OF 1/8" = 1'-0" THE INTERCONNECTIONS BETWEEN THE EQUIPMENT OF THIS SHEET AND THE EQUIPMENT OF SHEETS REFERRED TO IN THE LISTING BELOW.	DRAWING NO. 363A0033
---	-------------------------

SNF-6315, Rev. 0

Page 630

**This document was too large to scan
as a single document. It has
been divided into smaller sections.**

Section 3 of 3

Document Information			
Document #	SNF-6315	Revision	0
Title	CSB MCH CGI DEDICATIONS		
Date	05/17/2000		
Originator	CE SWENSON	Originator Co.	FH
Recipient		Recipient Co.	
References	EDT-629027, USQ-LIKE-CSB-0-0030		
Keywords			
Projects	W-379, SNF		
Other Information			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 1 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-012
Title: **P02 and-80 – OMRON Photoelectric Switch E3V-R2C43S and sensor controller S3D2-CK-US**

Section 1 Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
Part Description: <u>N/A</u>		
End Use Description: <u>N/A</u>		

ORIGINAL

Section 2a Component Information

Equipment No.: PESSPX, PESSPY	Specification No.: Ederer F-2566, Foster Wheeler MJX-SDX 452656	Manufacturer: OMRON	Past P.O. No.: N/A
Manufacturer's Part/Model No.: E3V-R2C43S and S3D2-CK-US E3V	Equipment Supplier (if different from manufacturer): ALSTROM, Foster Wheeler	Equip. Supplier's Part No.: N/A	

Component Description: **Photoelectric switch and controller provide part of the P02 and-80 interlock. The controller provides power to the photoelectric switch and hard contacts that are wired into the control circuits. The photoelectric switches are located on the side wall of the tube plug cask. The controller is mounted in the panels on the operator platform.**

Section 2b Commercial Availability of the Item

- Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
 YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
 If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate with project CGI Interface Engineer or BTR)
 YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)
- List of Candidate qualified suppliers or ISO 9000 suppliers: **N/A**
- Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): **N/A**

Section 2c CGI Determination

- CGI Determination Questions:
- #1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)
 - #2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)
 - #3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)
- All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

Page 632

SNF-6315, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-012
 Title: **P02 and-80 – OMRON Photoelectric Switch E3V-R2C43S and sensor controller S3D2-CK-US**

Rev. No. 3
 Page 2 of 8

Section 2d Reason for Dedication

The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):

Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.

Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.

Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.

Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.

Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:
 1. **The photoelectric switch and controller provide part of the P-80 inhibit to the change of MHM operating mode unless the tube plug cask is empty.**

<p>B. Part/Component Functional Mode:</p> <p>Safety Function #1: <input checked="" type="checkbox"/> Active [] Passive</p> <p>Safety Function #2: [] Active [] Passive</p> <p>Safety Function #3: [] Active [] Passive</p>	<p>Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function</p> <p>Passive - Change of state is not required for the component to perform its safety function</p>
--	--

C. Host Component Safety Function (if applicable): *N/A*

1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):
 1. **Failure to detect the presence of a tube plug in the tube plug cavity.**

Section 4 Environmental & Natural Phenomena Hazard Design

<p>Environmental Qualification Required:</p> <p>Yes []</p> <p>No <input checked="" type="checkbox"/></p>	<p>If yes: Environmental Qualification Requirements</p> <p>Limiting Environmental Conditions:</p> <p>Required Safety Functions:</p> <p>Qualification Period:</p>
<p>Natural Phenomena Hazard (NPH) Design Required:</p> <p>Yes []</p> <p>No <input checked="" type="checkbox"/></p>	<p>If yes: NPH Design Requirements</p> <p>Performance Category:</p> <p>NPH Design Req'ts.:</p> <p>Required Safety Functions:</p>

Section 5 Component Functional Classification

<input checked="" type="checkbox"/> Safety Class (SC)	<input type="checkbox"/> General Service (GS)	<input type="checkbox"/> Safety Significant (SS)
---	---	--

If part/component classification is different from host component/system, document basis. *N/A*

Sections 6 and 7. (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: *N/A*

Safety Analysis Report (SAR): *HNF-3672, Rev. 0*

Drawings: *Ederer, Inc. EB-33056, Sht 17A*

Vendor Manual/Manufacturer/Supplier Information: *OMRON data sheets; Photoelectric Switch E3V and Controller S3D2*

Other: *ALSTOM ESL/R (96) 065 – Rev. D, 100% Design Submittal – June 1998*

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

Page 6 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-012
 Title: **P02 and-80 – OMRON Photoelectric Switch E3V-R2C43S and sensor controller S3D2-CK-US**

Page 3 of 8

SNF-6315, Rev. 0

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acc Meth	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	OMRON	1, IN	X	
Model - Photoelectric Switch	E3V-R2C43S with attached cable	1, IN	X	
Model - Controller	S3D2-CK-US	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
N/A				
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Current carrying capability	3 amps at 120 VAC resistive, nominal	1,T		X
Insulation Resistance	Minimum 10 Megohms at 500 VDC	1,T		X
Power supply voltage	12 VDC + or - 10%	1,T		X
4. Notes and Legend: This revision issued to add P02. This is the originally supplied equipment. It was determined to in-situ dedicate this equipment.		Acceptance Method (Acc Meth): 1. Special Test and Inspection: 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 4. Vendor/Item History		

Section 10 Initial Review and Approval	
Approvals:	
Designated Engineer:	<i>[Signature]</i>
Design Authority:	<i>Wang Swenson 4/12/00</i>
QA Engineer:	<i>Stephen Scott Mohr 4-20-2000</i>

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 4 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-012
Title: **P02 and-80 – OMRON Photoelectric Switch E3V-R2C43S and sensor controller S3D2-CK-US**

WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.		
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.		
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2. Additional Failure Modes Applicable to the Component Under Evaluation			
1. Controller contacts fail to open. Cause could be binding or contacts welded.			
2. Photoelectric switch fails in a way that provides false indication to the controller.			
3.			
4.			
5.			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 5 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-012
Title: P02 and-80 - OMRON Photoelectric Switch E3V-R2C43S and sensor controller S3D2-CK-US

SNF-6315, Rev. 0

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1	
Item Description: Photoelectric switch and Controller System #: MHM	Equip #: PESSPX, PESSPY Model #: 3EV-R2C43S and S3D2-CK-US
Manufacturer (Address/Phone): OMRON Electronics, Inc. 750 The City Drive South, Suite 120 Orange, CA 92868 Phone. # (714) 621-3455	Supplier (Address/Phone): ALSTROM

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.			
Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Photoelectric switch model number
X			3. Controller model number
	X		6. Current carrying capability
	X		7. Insulation resistance
	X		8. Power supply voltage

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)	
Characteristic: Manufacturer	Sample Size*: 100%
Acceptance Criteria: OMRON (photoelectric switch and controller)	
Receipt Inspection Plan / Report #: TP-012X, Y*	
Characteristic: Photoelectric switch model number	Sample Size*: 100%
Acceptance Criteria: 3EV-R2C43S with attached cable	
Receipt Inspection Plan / Report #: PAT-015-1 TP**	
Characteristic: Controller model number	Sample Size*: 100%
Acceptance Criteria: S3D2-CK-US	
Receipt Inspection Plan / Report #: TP-012X, Y*	

**** THIS PAT DOES NOT CONFIRM THE MODEL NO. OF THIS SWITCH. IT SHOWS ONLY THAT THE SWITCH, CABLE, CONTROLLER AND ASSOCIATED CIRCUITRY WORKS AND ACTUATES THE STATUS LIGHTS WHEN THE TUBE PLUG IS RAISED INTO THE CASK & WHEN IT IS REMOVED. THE MODEL NO. CANNOT BE SEEN AND VERIFIED.**

JWP 4/12/00

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A CGI No. CGI-SNF-D-MHM-012
Title: P02 and-80 - OMRON Photoelectric Switch E3V-R2C43S and sensor controller S3D2-CK-US

Page 6 of 8

SNF-6315, Rev. 0

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic for Test: **Controller output contacts, SPDT, current carrying capability** Samp Size*: Normal Reduced Tightened
Acceptance Criteria: **Nominal 3 amps at 120 VAC, resistive**
Actual Test Value: ^{See} TP-012X,Y Test Plan and Report #: TP-012X,Y*

Characteristic for Test: **Controller output contacts, SPDT, insulation resistance** Samp Size*: Normal Reduced Tightened
Acceptance Criteria: **10 megohms minimum, contact to contact and contact to ground**
Actual Test Value: See TP Test Plan and Report #: TP-012X,Y*

Characteristic for Test: **Controller supply voltage to photoelectric switch** Samp Size*: Normal Reduced Tightened
Acceptance Criteria: **12 VDC, + or - 10%**
Actual Test Value: See TP Test Plan and Report #: TP-012X,Y*

* Full No is: CGI-SNF-D-MHM-012-TP-012X
" " " " - 012Y
JWP 4/12/00

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A CGI No. CGI-SNF-D-MHM-012

Page 7 of 8

Title: **P02 and-80 – OMRON Photoelectric Switch E3V-R2C43S and sensor controller S3D2-CK-US**

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: **Photoelectric Switch and Controller**

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	OMRON	X		1, IN	TP-012XY*	N/A	2	0	XWEST	LARRY W. PRICE <i>[Signature]</i>	4/10/00
Model – Photoelectric Switch	E3V-R2C43S with attached cable	X		1, IN	PAT-015-TP**	NA	2	0	XWEST	↓ LARRY W. PRICE <i>[Signature]</i>	4/10/00
Model - Controller	S3D2-CK-US	X		1, IN	TP-012XY*	N/A	2	0	XWEST	LARRY W. PRICE <i>[Signature]</i>	4/10/00
Controller output contacts, SPDT, current carrying capability	3 amps at 120 VAC resistive, nominal		X	1, T	↓	↓	↓	↓	↓	↓	↓
Controller output contacts, SPDT, insulation Resistance	Minimum 10 Megohms at 500 VDC		X	1, T	↓	↓	↓	↓	↓	↓	↓
Controller power supply voltage to photoelectric switch	12 VDC + or – 10%		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP- Testing Agency Approval: <u>NR CES 4/12/00</u> Date: _____ Testing Agency QA Engineer: <u>NR CES 4/12/00</u> Date: _____		BUYER VERIFICATION Design Authority: <u>CES Larry Swenson</u> Date: <u>4-12-00</u> QA Engineer: <u>Stephen Scott Mack</u> Date: <u>4-20-2000</u>	
--	--	--	--

* SEE NOTE ON PAGE 6

** SEE NOTE ON PAGE 5

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 8 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-012
Title: **P02 and-80 – OMRON Photoelectric Switch E3V-R2C43S and sensor controller S3D2-CK-US**

SECTION 6 CONTACTS / PHONE NUMBERS

Name	Phone
Design Authority <i>CRAIG SWENSON</i>	() <i>376-0288</i>
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents		For Critical Characteristics
<input type="checkbox"/>	Drawings:	
<input type="checkbox"/>	Manuals (specify type & number):	
<input type="checkbox"/>	Design Calculations	
<input type="checkbox"/>	Installation Instructions	
<input type="checkbox"/>	Operation Instructions	
<input type="checkbox"/>	Calibration Instructions	
<input type="checkbox"/>	Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/>	Other: OMRON data sheets; Photoelectric Switch E3V and Controller S3D2	All
Procurement Documents:		For Critical Characteristics
<input type="checkbox"/>	Certificate of Conformance/Compliance	
<input type="checkbox"/>	Seismic Qualification Certificate	
<input type="checkbox"/>	Environmental Qualification Certificate	
<input type="checkbox"/>	Test Report (s):	
<input type="checkbox"/>	Inspection Report (s):	
<input type="checkbox"/>	CMTRs for ASME Pressure Retaining Materials	
<input type="checkbox"/>	Valve Seat Leakage Report	
<input type="checkbox"/>	Weld Records	
<input type="checkbox"/>	Material Traceability Record	
<input type="checkbox"/>	Other:	

Page - 639

Date: 3/20/00

TO: Ed Kahler
FAX: 415-453-8836

FROM: Larry Price - XWest
Ph: 509-372-8770 FAX: 509-373-9621

Re: Info received from Jon Molnar

Jon gave me the attached two pages of PAT-015-1 TP. He said you were expecting them.

Thanks,

Larry

Cover plus 2 pages

Ed, Jon highlighted Steps 9.10.11.5
and 9.10.11.6

Larry

SPENT NUCLEAR FUEL PROJECT	Procedure No. SNF-W379-PAT-015-1
FACILITY/SYSTEM START-UP	Revision 0
PREOPERATIONAL ACCEPTANCE TEST	Effective Date 4/29/99
MHM: Control Logic Test	Page 262 of 666

INITIAL/DATE

- 9.10.8 Place the TUBE PLUG GRAPPLE JAWS handswitch to the CLOSE position. PDZ, 4/11/99
- 9.10.9 Verify the TUBE PLUG GRAPPLE JAWS CLOSED status indicator illuminates. PDZ, 4/11/99
- 9.10.10 Verify the TUBE PLUG GRAPPLE JAWS OPEN status indicator is not illuminated. PDZ, 4/11/99
- 9.10.11 Momentarily depress the TUBE PLUG HOIST RAISE pushbutton and perform the following:
 - 9.10.11.1 Verify the Tube Plug Hoist drive starts in the raising direction. PDZ, 4/11/99
 - AC → 9.10.11.2 Verify the TUBE PLUG HOIST RAISING status indicator is illuminated. PDZ, 4/11/99
 - 9.10.11.3 Verify as the Tube Plug Hoist Grapple unseats, the TUBE PLUG GRAPPLE JAWS LOCKED status indicator illuminates. PDZ, 4/11/99
 - 9.10.11.4 Verify the TUBE PLUG GRAPPLE SEATED & JAWS UNLOCKED status indicator is not illuminated. PDZ, 4/11/99
 - AC → 9.10.11.5 As the Tube Plug Hoist raises, verify the TUBE PLUG CASK OCCUPIED status indicator illuminates. PDZ, 4/11/99
 - 9.10.11.6 Verify the TUBE PLUG CASK EMPTY status indicator is not illuminated. PDZ, 4/11/99
 - AC → 9.10.11.7 Verify the Tube Plug Hoist drive stops when it reaches the fully raised position. PDZ, 4/11/99



SPENT NUCLEAR FUEL PROJECT
FACILITY/SYSTEM START-UP
PREOPERATIONAL ACCEPTANCE TEST
MHM: Control Logic Test

Procedure No. SNF-W379-PAT-015-1
Revision 0
Effective Date 4/29/99
Page 263 of 666

INITIAL/DATE

AC

- 9.10.11.8 Verify the TUBE PLUG HOIST RAISING status indicator is not illuminated. PSJ 4/11/99
- 9.10.11.9 Verify the TUBE PLUG GRAPPLE FULLY RAISED status indicator is illuminated. PSJ 4/11/99
- 9.10.11.10 Verify that no binding or unusual noises were observed at the Tube Plug Hoist drive during the raising operation. PSJ 4/11/99

NOTE

Personnel performing local monitoring of the Tube Plug Hoist Drive may be released for other activities.

- 9.10.12 Momentarily depress the TUBE PLUG HOIST LOWER pushbutton and perform the following: PSJ 4/11/99
 - 9.10.12.1 Verify the TUBE PLUG HOIST LOWERING status indicator is illuminated. PSJ 4/11/99
 - 9.10.12.2 Verify the TUBE PLUG GRAPPLE FULLY RAISED status indicator is not illuminated. PSJ 4/11/99
 - ~~9.10.12.3 Verify as the Tube Plug Hoist lowers, the TUBE PLUG CASK EMPTY status indicator illuminates.~~ 1
 - 9.10.12.4 Verify the TUBE PLUG CASK OCCUPIED status indicator is not illuminated. PSJ 4/11/99
 - 9.10.12.5 As the Tube Plug Hoist approaches the fully lowered position, verify the TUBE PLUG GRAPPLE IN SEATING ZONE status indicator illuminates. PSJ 4/11/99

PCN 027 (1)



ORIGINAL

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-012-TP-012X	
Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPX	Page 1 of 9

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CEI Eng	DA	QA Post Review*
1	TESTING	24.4 / 4 25.8 / 5 25.13 / 5	ADD 120 VAC To Term. 1 & 2 MODIFIED PARAGRAPH ADD 120 VAC To Term 1 & 2	JMP	CEI 3/16/00	SSW 3-22-2000

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-012-TP-012X

Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPX

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

JWP Lang Anderson

Date:

*3/15/00***TEST PERSONNEL REQUIRED:**

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MRC
Electrician	<i>JWE BERHART</i>	PCE	<i>JWE</i>	JWE
Electrician Quality Control	Stephen R. Conley	PCE	<i>Stephen R Conley</i>	SRC
Design Authority Representative	<i>Lang Anderson</i>	XINGSD	<i>JWP</i>	JWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current source capable of 3 amps

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

DC voltage source capable of +12VDC

AC voltage source capable of 120 VAC

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 7-29-00

Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 7-30-00

Test Instrument type: AVO BM 80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: PROTO 6106 I.D.: 0295/009 Calib. Due date: 01-13-01

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-012-TP-012X

Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPX

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	YES	Omron	Acc
Model:	YES	S3D2-CK-US	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-15-00 12:30 p.m.

2.2 Open main disconnect switch MD, lock and tag out.

2.3 Mechanical Operation

2.3.1 At the Controller, record wire color for each terminal listed on the Lifted Lead Log.

2.3.2 At the Controller, disconnect all wiring as shown on the Lifted Lead Log.

2.3.3 Cycle the output relay 5 or more times by applying and removing 10 VDC to the controller terminals 8 and 9 to confirm contacts open and close, using a multi-meter, with smooth operation and free release when voltage is removed.

2.3.4 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	6	>5 times	Acc
Describe Operation:	YES	Contacts open and close with smooth operation.	Acc

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-012-TP-012X	
Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPX	Page 4 of 9

2.4 Insulation Resistance Test

- 2.4.1 Setup the test equipment and Controller for insulation resistance testing.
- 2.4.2 Apply a nominal 500 VDC via Megger device between non-continuity terminals 4 and 5 (Common - Across NO Contact) and then between terminal 5 and ground. Record the resistances.
- 2.4.3 Remove the Megger device.
- 2.4.4 Apply 10 VDC to terminals 8 and 9 to open the normally closed (NC) contacts.
- 2.4.5 Apply a nominal 500 VDC via Megger device between non-continuity terminals 4 and 6 (Common - Across open NC Contact) and then between terminal 6 and ground. Record the resistances.

and 120 VAC to terminals 1 and 2 YWP 3/15/00

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
4 and 5	Common to NO	> 100 Gohm	> 10 Megohms	Acc
5 and Ground	NO to Ground	> 100 Gohm	> 10 Megohms	Acc
4 and 6	Common to open NC*	> 100 Gohm	> 10 Megohms	Acc
6 and ground	Open NC to Ground*	> 100 Gohm	> 10 Megohms	Acc

* Normally closed contacts are open.

- 2.4.6 Remove the 10 VDC from terminals 8 and 9

2.5 Contact Rating Test

- 2.5.1 Setup the test equipment and Controller for contact rating testing.
- 2.5.3 Connect the current source to terminals 4 and 6.
- 2.5.4 Apply a nominal 3 amps, resistive, across the normally closed contacts of the test specimen.

Caution: Do not change state of contacts while energized.

- 2.5.5 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM-NC)	.0813 vac	< 0.5 Volts AC drop	Acc

- 2.5.6 Reduce the current source to zero amps.

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-012-TP-012X	
Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPX	Page 5 of 9

2.5.7 Disconnect the power supply from terminals 4 and 6.

2.5.8 Apply ~~10 VDC~~ ^{JMP 3/15/00} to terminals 8 and 9 to close the normally open contacts. ~~and 120VAC to terminals 1 and 2~~ ^{JMP 3/15/00 CE}
 CLOSE THE NO CONTACTS AND APPLY 120VAC TO TERMINALS 1 AND 2 ^{JMP a 3/16/00}

2.5.9 Connect the current source to terminals 4 and 5.

2.5.10 Apply a nominal 3 amps, resistive, across the closed normally open contacts of the test specimen.

2.5.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM-Closed NO Contact):	.0513 VAC	< 0.5 Volts AC drop	Acc

2.5.12 Reduce the current source to zero amps and remove from terminals 4 and 5.

2.5.13 Remove the ~~10 VDC~~ ^{JMP 3/15/00 CE} from terminals 8 and 9 to close the normally closed contacts. ~~and remove 120VAC from terminals 1 and 2~~ ^{JMP CE 3/15/00}

2.5.14 De-energize and remove the test equipment.

2.6 Controller supply voltage to photoelectric switch

2.6.1 Connect 120 VAC to Controller terminals 1 and 2. Measure photoelectric supply voltage at terminals 7 and 9

Description	Record Voltage	Acceptance Criteria	Comments/Deviations
At Controller terminals 7 and 9	12.48 VDC	12 VDC ±10% (10.8 – 13.2)	Acc

2.6.2 Disconnect 120 VAC supply

2.7 Terminate the test.

2.7.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.

2.7.2 Record: Date /Time of Test End: 03-16-00 11:15 a.m.

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-012-TP-012X	
Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPX	Page 6 of 9

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met.

Michael D Cram
03-16-00

Notes:

Certified Instrumentation Technician (signature) Michael D Cram Date: 03-16-00
~~L. Cadutz~~ 3/16/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) J.P. Lang Jensen Date: 3/16/00

QA/QC (signature) Stephen Scott Moss Date: 3-22-2000

LIFTED LEAD LOG

At Junction Box: JB05X

Drawing #	Sheet #	Record wire color#	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	1	101X	Controller	1	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
363A0033	1	102X	Controller	2	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
363A0033	1	101X	Controller	4	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
363A0033	1	17A06X	Controller	5	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
363A0033	1	17A02X	Controller	6	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
363A0033	1	#7	Controller	7	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
363A0033	1	#8	Controller	8	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
363A0033	1	#9	Controller	9	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00
"	"	GRD	"	3	JWE	3/16/00	SRL	3-16-00	JWE	3/16/00	SRL	3-16-00

Remarks:

SNF-6315, Rev. 0

Page 648

Dedication Test Plan - IST


Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-012-TP-012X

Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPX

Page 8 of 9

36340033 (1)



REV	NO	DATE
1	1	11/11/01
2	1	11/11/01
3	1	11/11/01
4	1	11/11/01
5	1	11/11/01
6	1	11/11/01
7	1	11/11/01
8	1	11/11/01
9	1	11/11/01
10	1	11/11/01
11	1	11/11/01
12	1	11/11/01
13	1	11/11/01
14	1	11/11/01
15	1	11/11/01
16	1	11/11/01
17	1	11/11/01
18	1	11/11/01
19	1	11/11/01
20	1	11/11/01
21	1	11/11/01
22	1	11/11/01
23	1	11/11/01
24	1	11/11/01
25	1	11/11/01
26	1	11/11/01
27	1	11/11/01
28	1	11/11/01
29	1	11/11/01
30	1	11/11/01
31	1	11/11/01
32	1	11/11/01
33	1	11/11/01
34	1	11/11/01
35	1	11/11/01
36	1	11/11/01
37	1	11/11/01
38	1	11/11/01
39	1	11/11/01
40	1	11/11/01
41	1	11/11/01
42	1	11/11/01
43	1	11/11/01
44	1	11/11/01
45	1	11/11/01
46	1	11/11/01
47	1	11/11/01
48	1	11/11/01
49	1	11/11/01
50	1	11/11/01

THIS DRAWING IS ONLY AN APPROVED COPY & SIGNED.

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-012-TP-012X

Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPX

Rev. No. 0


Page 9 of 9

S3D2


OMRON

S3D2

S3D2-AK-US




S3D2-CK-US/CC-US




No.	Name	Functions
1	Power supply indicator	This illuminates when the operating power is turned on and at the same time, the output is issued from the power supply for sensors. It does not illuminate when power supply output for sensors is short-circuited (between +12 V terminal and 0 V terminal).
2	IN1 indicator	This illuminates when it receives the output of the sensor which is connected with IN1 as an input.
3	IN2 indicator	This illuminates when it receives the output of the sensor which is connected with IN2 as an input.
4	OUT indicator	This illuminates when the output is turned on.
5	IN1 input signal selector switch	NORM: When the transistor (or output contact) is turned on, the switch receives it as a signal.
6	IN2 indicator	INV: When the transistor (or output contact) is turned off, the switch receives it as a signal.
7	AND/OR operation selector switch	AND: The output is turned on when input signals of both IN1 and IN2 are turned on. OR: The output is turned on when input signal of either IN1 or IN2 is turned ON.
8	Synchronous mode selector switch (This switch can operate only when AND is selected on the AND/OR operation selector switch.)	The output is turned on during input signals when both IN1 and IN2 are turned on. If the input signal of IN2 is turned on before (the timing time), when that of IN1 turns to the ON state, the output is turned on. IN1 is the "gate sensor."
9	Timer switch	When ON: the timer function operates. When OFF: the timer function does not operate.
10	Timer timing selector switch	With this switch, ranges of timer setting are changed. (Model S3D2-CK) 1s: Setting time lies in the range of 0.1 s to 1 s. 10s: Setting time lies in the range of 1 s to 10 s. (Model S3D2-CC) 0.1s: Setting time lies in the range of 0.01 s to 0.1 s. 1s: Setting time lies in the range of 0.1 s to 1 s.
11	Timer operation selector switch	O.S: One-shot delay timer ON.D: On-delay timer Off.D: Off-delay timer
12	Time setting trimmer	Setting time can be adjusted with the accessory screwdriver. It rotates 180°.


How to connect S3D2-AK-US



S3D2-CK-US



S3D2-CC-US




No.	Name/Function
1, 2	Power terminal supplies a voltage of 100 to 240 VAC.
3	FG terminal: In a location where much noise is expected, ground this terminal at a ground resistance of 100 Ω max.
4 to 6	Output terminals
7, 10	Power terminal for the sensor (+12 V)
8, 12	Power terminal for the sensor (0 V)
9, 11	Output terminals for the sensor (input of the sensor, synchronous input). Connect the output wiring of the sensor.

NOTES:-

- MANUFACTURING & ASSEMBLY TO BE IN ACCORDANCE WITH APPLICABLE TO THE FOLLOWING SPECIFICATIONS AND SPECIFICATIONS REFERRED TO THEREIN.
3437
- ITEMS OF CABLES USED
CABLE TYPES ARE DERIVED FROM ITEM NO'S (SHOWN IN CIRCLE) ON PARTS LIST - 363A0033.
- WIRE MARKERS
ALL MARKERS SHALL BE WHITE WITH PERMANENT INSCRIPTIONS. HEAT SHRINKABLE ONLY SHALL BE USED. THESE SHALL NOT SLIP ALONG THE WIRE. NEITHER SHALL THEY BE REMOVABLE WITHOUT RE-TERMINATING. ALL WIRE NO'S & LETTERS SHALL BE READ FROM THE TERMINAL OUTWARD ALONG THE WIRE.
- SPARE CORES
WHERE SPARE CORES ARE TURNED BACK IN CUBICLES/PANELS ETC. AND TIED BACK. SUFFICIENT LENGTH MUST BE LEFT FOR ANY SPARE CORE TO REACH THE FURTHERMOST TERMINAL IN THE CUBICLE/PANEL ETC.
- CABLE MARKERS
ALL MARKERS SHALL BE WHITE WITH BLACK INSCRIPTIONS. THE WIRE NO. MUST BE SHOWN AT EACH END OF THE CABLE. IN CASE OF SPACE RESTRICTIONS, ADDITIONAL CABLE NO.'S ARE REQUIRED, WHEN THEY SHOULD BE FITTED.
- SYSTEM ENDINGS
TO BE IN ACCORDANCE WITH DRG. 363A0043.
- SEGREGATION
ALL INFORMATION REGARDING CABLE SEGREGATION EXTERNAL TO CUBICLES IS SHOWN ON THE RELEVANT DRAWINGS.
- CABLE BUNDLING
TO BE IN ACCORDANCE WITH TEST CONFORMANCE DOCUMENT.
- ASSOCIATED DRAWINGS
BUILD LIST - 362A0549
PARTS LIST - 363A0032
B.I.D. - 363A0029
- SHEET ALLOCATIONS
1 & 2: TUBE PLUG HOST
3: BASE LOCKING PIN
4 & 5: TUBE PLUG GRAPPLE
6: TURRET - CCTV
7 & 8: MCO HOST
9: MCO CASK CONTAINMENT
10 & 11: MCO GRAPPLE
12: CASK EXTRACT FANS
13: MCO HOST CONTAINMENT
14 & 15: SHIELD SKIRT
16 & 17: TROLLEY
- ESTIMATING
EARLY CONNECTION OF CABLES ASSOCIATED WITH POWER CABLES TO BE CONNECTED TO EXHIBIT STUB ON CLAMP PLATE INDIVIDUALLY.
LINK ONE TERMINAL OF MCO CONTACT AND ONE TERMINAL OF MCO CONTACT TO FORM COMMON USING BLACK INSULATED WIRE (30/0.25) WHERE NECESSARY.
- NUMBERS SHOWN THUS:- (15) 117
INDICATE PLANT PARTS LIST ITEM NO. AND QUANTITY.

TO CHECK CONTROL CUBICLE (S) TURRET ROTATE FESTOON SET ELEMENTARY CB-33058 SWITCH 1, 16 & 17



MHM-FCR-006
12/10/98
MHM-FCR-034
2/19/99

CONTROLLED COPY
ACC#15

CONTINUED ON SHEET 3

U.S. DEPARTMENT OF ENERGY WESTINGHOUSE MANFORD COMPANY MOK-SOX-452656 WMC-S-0468	
H-2-827169	
GEC ALSTHOM ENGINEERING SYSTEMS LTD Whetstone, Leicester, LE8 6UH, England	
4433446009	4433446009
WIRING DIAGRAM TUBE PLUG HOST	363A0033
117A	117A

ISSUE NO.	1
ISSUE DATE	12/10/98
ISSUED BY	MHM
APPROVED BY	MHM
DATE APPROVED	12/10/98
REVISION NO.	1
REVISION DATE	12/10/98
REVISION BY	MHM
REVISION APPROVED BY	MHM
REVISION DATE	12/10/98

THIS DRAWING IS ONLY AN APPROVED COPY F. SIGNED

Dedication Test Plan - IST

ORIGINAL

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-012-TP-012Y

Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPY

Page 1 of 9

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGT Eng	DA	QA Post Review*
1	TESTABILITY	2.4.4/4 25.8/5 25.13/5	ADD 120VAC to Term. 1 & 2 MODIFIED PARAGRAPH ADD 120VAC to Term. 1 & 2	<i>[Signature]</i> 3/14/00	CE S 3/14/00	SSM 3-22-2000

*QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-012-TP-012Y	
Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPY	Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *[Signature]* Date: 3/15/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>[Signature]</i>	MRe
Electrician	JW EBERHART	PCE	<i>[Signature]</i>	JWE
Electrician Quality Control	Stephen R. Conley	PCE	<i>[Signature]</i>	SRL
Design Authority Representative	LARRY W. PRICE	XWST	<i>[Signature]</i>	Yup
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current source capable of 3 amps

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

DC voltage source capable of +12VDC

AC voltage source capable of 120 VAC

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 7-29-00

Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 7-30-00

Test Instrument type: AVO BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: PROTO 6106 I.D.: 029E/009 Calib. Due date: 01-13-01

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-012-TP-012Y

Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPY

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	YES	Omron	Acc
Model:	YES	S3D2-CK-US	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-15-00 12:45 p.m.

2.2 Open main disconnect switch MD, lock and tag out.

2.3 Mechanical Operation

2.3.1 At the Controller, record wire color for each terminal listed on the Lifted Lead Log.

2.3.2 At the Controller, disconnect all wiring as shown on the Lifted Lead Log.

2.3.3 Cycle the output relay 5 or more times by applying and removing 10 VDC to the controller terminals 8 and 9 to confirm contacts open and close, using a multi-meter, with smooth operation and free release when voltage is removed.

2.3.4 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	6	>5 times	Acc
Describe Operation:	OK	Contacts open and close with smooth operation.	Acc

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-012-TP-012Y	
Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPY	Page 4 of 9

2.4 Insulation Resistance Test

2.4.1 Setup the test equipment and Controller for insulation resistance testing.

2.4.2 Apply a nominal 500 VDC via Megger device between non-continuity terminals 4 and 5 (Common - Across NO Contact) and then between terminal 5 and ground. Record the resistances.

2.4.3 Remove the Megger device.

120VAC to terminals 1 and 2 Jul 3/15/00 cbb

2.4.4 Apply ~~10 VDC~~^{10 VDC} to terminals 8 and 9 to open the normally closed (NC) contacts.

2.4.5 Apply a nominal 500 VDC via Megger device between non-continuity terminals 4 and 6 (Common - Across open NC Contact) and then between terminal 6 and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
4 and 5	Common to NO	> 100 Gohm	> 10 Megohms	Acc
5 and Ground	NO to Ground	> 100 Gohm	> 10 Megohms	Acc
4 and 6	Common to open NC*	> 100 Gohm	> 10 Megohms	Acc
6 and ground	Open NC to Ground*	> 100 Gohm	> 10 Megohms	Acc

* Normally closed contacts are open.

2.4.6 Remove the 10 VDC from terminals 8 and 9

2.5 Contact Rating Test

2.5.1 Setup the test equipment and Controller for contact rating testing.

2.5.3 Connect the current source to terminals 4 and 6.

2.5.4 Apply a nominal 3 amps, resistive, across the normally closed contacts of the test specimen.

Caution: Do not change state of contacts while energized.

2.5.5 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM-NC)	.0798 VAC	< 0.5 Volts AC drop	REC VAC ACC

2.5.6 Reduce the current source to zero amps.

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-012-TP-012Y	
Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPY	Page 5 of 9

- 2.5.7 Disconnect the power supply from terminals 4 and 6.
YUP 3/15/00 CES
- 2.5.8 ~~Apply 10 VDC to terminals 8 and 9 to close the normally open contacts.~~
CLOSE THE NO CONTACTS AND APPLY 120VAC TO TERMINALS 1 and 2 YUP 3/15/00 CES
- 2.5.9 Connect the current source to terminals 4 and 5.
- 2.5.10 Apply a nominal 3 amps, resistive, across the closed normally open contacts of the test specimen.
- 2.5.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM-Closed NO Contact):	.0743 VAC	< 0.5 Volts AC drop	Acc

- 2.5.12 Reduce the current source to zero amps and remove from terminals 4 and 5.
YUP 3/15/00 CES
- 2.5.13 ~~Remove the 10 VDC from terminals 8 and 9 to close the normally closed contacts.~~
REMOVE 120VAC TO TERMINALS 1 and 2 YUP 3/15/00 CES
- 2.5.14 De-energize and remove the test equipment.

2.6 Controller supply voltage to photoelectric switch

- 2.6.1 Connect 120 VAC to Controller terminals 1 and 2. Measure photoelectric supply voltage at terminals 7 and 9

Description	Record Voltage	Acceptance Criteria	Comments/Deviations
At Controller terminals 7 and 9	12.62 VDC	12 VDC ±10% (10.8 – 13.2)	Acc

- 2.6.2 Disconnect 120 VAC supply
- 2.7 Terminate the test.
- 2.7.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.
- 2.7.2 Record: Date /Time of Test End: 03-16-00 11:15 a.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-012-TP-012Y

Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPY

Page 6 of 9

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met.

Michael Cram

03-15-00

Notes:

Certified Instrumentation Technician (signature)

Michael Cram
J. C. Cook 3-16-00

Date: *03-15-00*

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature)

J.P. Lang

Date: *3/16/00*

QA/QC (signature)

Stephen Scott Moss

Date: *3-22-2000*

LIFTED LEAD LOG

At Junction Box: JB05X

Drawing #	Sheet #	Record wire color#	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	2	101Y	Controller	1	JWE	3/15/00	SRL	3-15-00	JWE	3/16/00	SRL	3-16-00
363A0033	2	102Y	Controller	2	JWE	3/15/00	SRL	3-15-00	JWE	3/16/00	SRL	3-16-00
363A0033	2	101Y	Controller	4	JWE	3/15/00	SRL	3-15-00	JWE	3/16/00	SRL	3-16-00
363A0033	2	17A07Y	Controller	5	JWE	3/15/00	SRL	3-15-00	JWE	3/16/00	SRL	3-16-00
363A0033	2	17A03Y	Controller	6	JWE	3/15/00	SRL	3-15-00	JWE	3/16/00	SRL	3-16-00
363A0033	2	#7	Controller	7	JWE	3/15/00	SRL	3-15-00	JWE	3/16/00	SRL	3-16-00
363A0033	2	#8	Controller	8	JWE	3/15/00	SRL	3-15-00	JWE	3/16/00	SRL	3-16-00
363A0033	2	#9	Controller	9	JWE	3/15/00	SRL	3-15-00	JWE	3/16/00	SRL	3-16-00
"	"	GROUND	" "	3	JWE	3/15/00	SRL	3-15-00	JWE	3/16/00	SRL	3-16-00

Remarks:

SNF-6315, Rev. 0

Page 658

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-012-TP-012Y

Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPY


Page 8 of 9

S3D2


OMRON

S3D2

S3D2-AK-US




S3D2-CK-US-CC-US




No.	Name	Functions
1	Power supply indicator	This illuminates when the operating power is turned on and at the same time, the output is issued from the power supply for sensors. It does not illuminate when power supply output for sensors is short-circuited (between +12 V terminal and 0 V terminal).
2	IN1 indicator	This illuminates when it receives the output of the sensor which is connected with IN1 as an input.
3	IN2 indicator	This illuminates when it receives the output of the sensor which is connected with IN2 as an input.
4	OUT indicator	This illuminates when the output is turned on.
5	IN1 input signal selector switch	NORM: When the transistor (or output contact) is turned on, the switch receives it as a signal.
6	IN2 indicator	INV: When the transistor (or output contact) is turned off, the switch receives it as a signal.
7	AND/OR operation selector switch	AND: The output is turned on when input signals of both IN1 and IN2 are turned on. OR: The output is turned on when input signal of either IN1 or IN2 is turned on.
8	Synchronous mode selector switch (This switch can operate only when AND is selected on the AND/OR operation selector switch.)	The output is turned on during input signals when both IN1 and IN2 are turned on. If the input signal of IN2 is turned on before (the rising time), when that of IN1 turns to the ON state, the output is turned on. IN1 is the "gate sensor."
9	Timer switch	When ON: the timer function operates. When OFF: the timer function does not operate.
10	Timer timing selector switch	With this switch, ranges of timer setting are changed. (Model S3D2-CK) 1s: Setting time has in the range of 0.1 s to 1 s. 10 s: Setting time has in the range of 1 s to 10 s. (Model S3D2-CC) 0.1 s: Setting time has in the range of 0.01 s to 0.1 s. 1 s: Setting time has in the range of 0.1 s to 1 s.
11	Timer operation selector switch	ON.S: One-shot delay timer ON.D: On-delay timer OFF.D: Off-delay timer
12	Time setting trimmer	Setting time can be adjusted with the accessory screwdriver. It rotates 180°.

How to connect


S3D2-AK-US



S3D2-CK-US



S3D2-CC-US



No.	Name/Function
1, 2	Power terminal supply a voltage of 100 to 240 VAC.
3	FG terminal in a location where much noise is expected, ground this terminal at a ground resistance of 100 Ω max.
4 to 6	OUTPUT terminals
7, 10	Power terminal for the sensor (+12 V)
8, 12	Power terminal for the sensor (0 V)
9, 11	Output terminals for the sensor (input of the sensor, synchronous input). Connect the output wiring of the sensor.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-012-TP-012Y

Test Specimen: Omron Photoelectric Switch Controller Eqmt. No.: for PESSPY

Page 9 of 9



363A0033

2

TUBE PLUG CASE



PLUG CASE OCCUPIED/
EMPTY PHOTO-ELECTRIC
SENSOR (V)
OUTPUT E2V-RE+J35
24-DC 48VDC

OUTPUT ENERGIZED
WHEN BEAM OBSCURED
(SET MODE TO DARK-ON)






TUBE PLUG HOIST

TUBE PLUG GRAPPLE
WITH SEARING ZONE (V)
LIMIT SWITCH
362A057/62
HONEYWELL 1LS18-4C



TUBE PLUG HOIST
MOTOR & BRAKE

362A053
ELECTRODRIVES
480V 3ph 50Hz
3HP 3 BA PLC



CONTINUED ON SHEET 8

DATE	
BY	
REVISION	
NO.	
DATE	
BY	
REVISION	
NO.	
DATE	
BY	
REVISION	
NO.	



363A0033
 363A0033
 363A0033

U.S. DEPARTMENT OF ENERGY
 WESTINGHOUSE HANFORD COMPANY
 HOK-SOX-452656
 WMC-5-0468
 H-2-827169
 GEC ALSTHOM ELECTRIC SYSTEMS LTD
 Watlington, Leicestershire, LE18 5UH, England
 363A0033


MHM-FLZ-006
 12/10/98

CONTROLLED COPY
 MCE #15

TO CORRECT POWER CUBICLE (P) VIA TURNST ROARIE FEEDROOM
 SEE ELEVATOR ED-3056 SMT. 18
 253



TURBINE PUMP MOTOR
 MOTOR & BRAKE
 ELECTRODES
 24V DC R/W



TURBINE PUMP MOTOR
 MOTOR & BRAKE
 ELECTRODES
 24V DC R/W

TURBINE PUMP MOTOR
 MOTOR & BRAKE
 ELECTRODES
 24V DC R/W

363A0033

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A CGI No. CGI-SNF-D-MHM-011

Page 1 of 8

Title: P-80 - Honeywell Limit Switch 1LS19-4C

P-2 JWP
Section 1: Part Information

Item No.: N/A Manufacturer: N/A Supplier: N/A

Mfg. Part/Model No.: N/A Supplier's P/N: N/A

Part Description: N/A **ORIGINAL**

End Use Description: N/A

Section 2a: Component Information

Equipment No.: LFPFRX, LFPFRY Specification No.: Ederer F-2566, Foster Wheeler MJX-SDX 452656 Manufacturer: Honeywell Past P.O. No.: N/A

Manufacturer's Part/Model No.: 1LS19-4C Equipment Supplier (if different from manufacturer): ALSTOM, Foster Wheeler Equip. Supplier's Part No.: N/A

Component Description: Limit switches for interlock P-80, located inside the top of the tube plug hoist screw jack bellows assembly, measures tube plug hoist not fully raised, inhibits operating mode changes between MCO mode, impact absorber exchange mode, and tube plug exchange mode with the mode selector switch. P-2 JWP

Section 2b: Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
 YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate with project CGI Interface Engineer or BTR)
 YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)

2. List of Candidate qualified NQA1 suppliers or ISO 9000 suppliers, if used: N/A

3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c: CGI Determination

CGI Determination Questions:
#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the item is not commercial grade) NO (continue)
#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)
#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)
 All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form		Rev. No. 2
ECN No. N/A	CGI No. CGI-SNF-D-MHM-011	Page 2 of 8
Title: P- 80 - Honeywell Limit Switch 1LS19-4C		

Section 2d Reason for Dedication

The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):

<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input checked="" type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. **Interlock P-80 inhibits operating mode changes with the mode selector switch. Prevents MCO shear due to lateral movement of the MHM, MCO drop due to shear of hoist cable, and MCO drop to the maintenance pit.** *ADD P2 JWP CES 4/11/00*

B. Part/Component Functional Mode:

Safety Function #1: <input checked="" type="checkbox"/> Active [] Passive	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function
Safety Function #2: [] Active [] Passive	
Safety Function #3: [] Active [] Passive	

Passive - Change of state is not required for the component to perform its safety function

C. Host Component Safety Function (if applicable): **N/A**

1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

1. **Failure of switch contacts to open upon demand results in potential override of interlock channel.**

2. **Plunger/arm inoperative results in failure to provide interlock function at correct demand position.**

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required:	If yes: Environmental Qualification Requirements
Yes []	Limiting Environmental Conditions:
No [X]	Required Safety Functions:
	Qualification Period:
Natural Phenomena Hazard (NPH) Design Required:	If yes: NPH Design Requirements
Yes []	Performance Category:
No [X]	NPH Design Req'ts.:
	Required Safety Functions:

Section 5 Component Functional Classification

<input checked="" type="checkbox"/> Safety Class (SC)	<input type="checkbox"/> General Service (GS)	<input type="checkbox"/> Safety Significant (SS)
---	---	--

If part/component classification is different from host component/system, document basis. **N/A**

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards:

Safety Analysis Report (SAR): **HNF-3672 Rev. 0**

Drawings: **Ederer, Inc. EB-33056, Sht 15A, Hanford H-2-827174, Sht. 27**

Vendor Manual/Manufacturer/Supplier Information: **Honeywell Series LS compact limit switches**

Other: **ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998.**

Commercial Grade Item Upgrade Dedication Form

Page 663

Rev. No. 2

SNF-6315, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-011
Title: P- 80 - Honeywell Limit Switch 1LS19-4C


Page 3 of 8


Section 9 Critical Characteristics


Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Honeywell	1, IN	X	
Model Number	1LS19-4C	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Actuator (Note 1)	Side mounted, rotary with nominal 1.5 inch radius, metallic arm with roller.	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Contact Rating	Nominal 10 amps, resistive, @ 120vac, less than 0.5V drop across contacts.	1, T		X
Insulation Resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v.	1, T		X
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring.	1, T		X
4. Notes and Legend:		Acceptance Method (Acc Meth)		
Rev. 2: All Pages: New Forms; Pages 3, 5, 7: added Note 1		1. Special Test and Inspection		
Note 1: This actuator is installed with the limit switch - replacement limit switches will not include an actuator - the existing actuator will be placed on the replacement switch. Therefore, the physical CC specified for the actuator lever need not be performed on the replacement limit switch.		1, IN for Inspection 1,T for Test		
APPROVED PER PER SEL REVISION JWP		2. Commercial Grade Survey		
		3. Source Verification		
		4. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:

Designated Engineer: 

Design Authority:  2/1/00

QA Engineer:  T Z ANDERSON

Commercial Grade Item Upgrade Dedication Form		Rev. No. 2
ECN No. N/A	CGI No. CGI-SNF-D-MHM-011	Page 4 of 8
Title: P- 80 – Honeywell Limit Switch 1LS19-4C		

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	X	Switch contacts corrode closed and fail to open upon demand.
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Switch contacts fuse closed and fail to open upon demand.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Switch mechanism jams and contacts fail to open upon demand.
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2: Additional Failure Modes Applicable to the Component Under Evaluation			
1. Switch contacts are closed to permit equipment movement. Contacts open for the interlock function to prevent lateral movement of the MHM. Any failure which prevents contacts opening inhibits the particular switch interlock function.			
2. Actuator plunger/arm seizure or break renders the contact opening inoperable.			
3. Short circuit could give false signal to energize interlock function.			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

Page 665

ECN No. **N/A**

CGI No. **CGI-SNF-D-MHM-011**

Page 5 of 8

Title: **P-80 - Honeywell Limit Switch 1LS19-4C**

SNF-6315, Rev. 0

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1

Item Description: **P-80 interlock limit switches**
System #: **MHM**

Equip #: **LPHFRX, LPHFRY**
Model #: **1LS19-4C**

Manufacturer (Address/Phone):
Honeywell

1-800-537-6945
P.O. #

Supplier (Address/Phone):

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Model Number
X			3. Actuator (Note 1)
	X		4. Contact Rating
	X		5. Insulation Resistance
	X		6. Mechanical Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic: **Manufacturer** Sample Size*: **100%**

Acceptance Criteria: **Honeywell**

Receipt Inspection Plan / Report #: **TP011A, B***

Characteristic: **Model Number** Sample Size*: **100%**

Acceptance Criteria: **1LS19-4C**

Receipt Inspection Plan / Report #: **TP011A, B***

Characteristic: **Actuator (Note 1)** Sample Size*: **100%**

Acceptance Criteria: **Side mounted, rotary with nominal 1.5 inch radius, metallic arm with roller.**

Receipt Inspection Plan / Report #: **TP011A, B***

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 6 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-011
 Title: P-80 - Honeywell Limit Switch 1LS19-4C

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size, References (See Section 7)	
Characteristic for Test: Contact Rating Acceptance Criteria: Nominal 10 amps, resistive @ 120 vac, less than 0.5V drop across contacts Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP011A, B*</u>
Characteristic for Test: Insulation Resistance Acceptance Criteria: Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 500 vdc. Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP011A, B*</u>
Characteristic for Test: Mechanical Operation Acceptance Criteria: Cycle switch - confirm contacts open and close with smooth operation and free release of spring Actual Test Value: <u>See TP 011A, B*</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP011A, B*</u>

* Full nos is: CGI-SNF-D-MHM-011-TP-011A
 " " " -011B

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A

CGI No. CGI-SNF-D-MHM-011

Page 7 of 8

Title: P-80 - Honeywell Limit Switch 1LS19-4C

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Honeywell Limit Switch

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/A/N	Procedure or RR#	Check-ist ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Honeywell	X		1, IN	TP-011A,B	N/A	2	0	XWEST	LARRY W. PRICE <i>[Signature]</i>	4/10/00
Model	1LS19-4C	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Actuator (Note 1)	Side mounted, rotary with nominal 1.5 inch radius, metallic arm with roller.	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Contact Rating	Nominal 10 amps, resistive, @ 120 vac, less than 0.5V drop across contacts		X	1, T	↓	↓	↓	↓	↓	↓	↓
Insulation Resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v.		X	1, T	↓	↓	↓	↓	↓	↓	↓
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-011A,B cited above, CES 4/11/00 Testing Agency Approval: <u>NR CES 4/11/00</u> Date: _____ Testing Agency QA Engineer: <u>NR CES 4/11/00</u> Date: _____		BUYER VERIFICATION Design Authority: <u>Larry Swenson</u> Date: <u>4-11-00</u> QA Engineer: <u>Steph... Scott... Mark</u> Date: <u>4-20-2000</u>	
---	--	--	--

SNF-6315, Rev. 0

Page

667

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 8 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-011
Title: P-80 - Honeywell Limit Switch 1LS19-4C

SNF-6315, Rev. 0

Section 6 Contacts/Phone Numbers

Name	Phone
Design Authority	()
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents	For Critical Characteristics
Drawings:	
Manuals (specify type & number):	
Design Calculations	
Installation Instructions	
Operation Instructions	
Calibration Instructions	
Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/> Other: Honeywell Series LS Compact Limit Switches	All
Procurement Documents	For Critical Characteristics
Certificate of Conformance/Compliance	
Seismic Qualification Certificate	
Environmental Qualification Certificate	
<input checked="" type="checkbox"/> Test Report (s): CSB(W379)-015-1-074	
Inspection Report (s):	
CMTRs for ASME Pressure Retaining Materials	
Valve Seat Leakage Report	
Weld Records	
Material Traceability Record	
<input checked="" type="checkbox"/> Other: SU Test SNF-CTP-IC-07	

Dedication Test Plan – IST-LS-1

ORIGINAL


Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-011-TP-011A

Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRX

Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
						 3/13/00 NO CHANGES

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST-LS-1 Test Plan No.: CGI-SNF-D-MHM-011-TP-011A Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRX	Rev. No. 0 Page 2 of 7
---	-------------------------------

In-Situ Test Procedure

ORIGINAL

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *J.P. Craig Swenson* Date: 2/29/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	MICHAEL CRAM	BELLHAVEN	<i>Michael Cram</i>	<i>MC</i>
Electrician	JW EBERHART	PCE	<i>JW Eberhart</i>	<i>JWE</i>
Electrician Quality Control	Stephen R. Conley	PCE	<i>Stephen R. Conley</i>	<i>SR</i>
Design Authority Representative	LARRY W. PRICE	XWEST	<i>Larry W. Price</i>	<i>LWP</i>
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC
 Megger Instrument capable of 1000 VDC Test Voltage
 MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
 Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP3457A I.D.: BAT 123 Calib. Due date: 7-29-00

Test Instrument type: HP3457A I.D.: BAT 124 Calib. Due date: 7-30-00

Test Instrument type: AVO BMS42 I.D.: 6410-889 Calib. Due date: 2-9-01

Test Instrument type: PROTO 6106 I.D.: 0290/009 Calib. Due date: 1-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-011-TP-011A

Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRX

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

- 1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.
- 2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	LFPHFRX	Acc
Manufacturer:	YES	Honeywell	Acc.
Model:	YES	1LS19-4C	Acc.
Actuator:	YES	Side mounted, rotary w/ nominal 1.5 inch radius, metallic arm w/roller	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

- 3.0 Perform the following testing steps:

- 3.1 Record: Date /Time of Test Beginning: 3-07-00 8:45 a.m.
Record: Room Temperature: 68 °F. Room Barometric Pressure: N/A JIM/Hg.

3.2 Mechanical Operation

- 3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.
- 3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	6 times	> 5 times	Acc.
Describe Operation:	YES	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	YES	Free release of spring.	Acc

Dedication Test Plan – IST-LS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-011-TP-011A

Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRX

Page 4 of 7

Note: 3.4 may be performed before 3.3**3.3 Contact Rating Test**

3.3.1 De-energize equipment or panel and lockout/tagout prior to lifting leads.

3.3.2 Setup the test equipment and Limit Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

3.3.3 At limit switch LFPHFRX, lift leads on Common terminal, Normally Closed terminal and Normally Open terminal. Record on the lifted lead log.

3.3.4 Connect the power supply to terminals Common and Normally Closed.

3.3.5 Apply a nominal 10 amps, resistive, across the normally closed contacts of the test specimen.

Caution: Do not change state of contacts while energized.

3.3.6 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- NC)	.021vac	< 0.5 Volts AC drop	Acc

3.3.7 Reduce the current source to zero amps.

3.3.8 Disconnect the power supply from terminals Common and Normally Closed.

3.3.9 Manually adjust the limit switch actuator to close the normally open contacts.

3.3.10 Connect the power supply to terminals Common and Normally Open.

3.3.11 Apply a nominal 10 amps, resistive, across the closed normally open contacts of the test specimen.

3.3.12 Record the following data:

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- Closed NO Contact):	.035vac	< 0.5 Volts AC drop	Acc

Dedication Test Plan – IST-LS-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-011-TP-011A	
Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRX	Page 5 of 7

3.3.13 Reduce the current source to zero amps and remove the power supply from terminals Common and Normally Open.

3.3.14 Manually adjust the limit switch actuator to close the normally closed contacts.

3.4 Insulation Resistance Test

3.4.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing.

3.4.2 Apply a nominal 1000 VDC via Megger device between non-continuity terminals Common and Normally Open and then between terminal Normally Open and ground. Record the resistances.

3.4.3 Remove the Megger device.

3.4.4 Manually adjust the limit switch actuator to open the normally closed (NC) contacts.

3.4.5 Apply a nominal 1000 VDC via Megger device between non-continuity terminals Common and open Normally Closed and then between terminal Normally Closed and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
Common	NO	> 13.3 kohm	> 10 Megohms	Acc
NO	Ground	> 70 kohm	> 10 Megohms	Acc
Common	open NC*	> 124 kohm	> 10 Megohms	Acc
Open NC	Ground*	> 50 kohm	> 10 Megohms	Acc

* Normally closed contacts are open.

3.4.6 De-energize and remove the test equipment.

3.5 Terminate the test.

3.5.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.

3.5.2 Retorque the terminals to 7-9 in-pounds.

3.5.3 Remove lockout/tagout and restore system to normal.

3.5.3 Record: Date /Time of Test End: 03-07-00 9:15 a.m.

Dedication Test Plan - IST-LS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-011-TP-011A

Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRX

Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Device under test has passed all parameters

Michael Cram
03-07-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-07-00
Received By: J. Cadick 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 3/7/00

QA/QC (signature) [Signature] Date: 3/13/00
TZ ANDERSON

LIFTED LEAD LOG

Junction Box: N/A

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date	
363A0033	4	101X	LFPHFRX	C	JLS E	3/7/00	SRL	3-7-00	JLS E	3/7/00	SRL	3-7-00	
363A0033	4	1525X	LFPHFRX	NC	JLS E	3/7/00	SRL	3-7-00	JLS E	3/7/00	SRL	3-7-00	
363A0033	4	1520X	LFPHFRX	NO	JLS E	3/7/00	SRL	3-7-00	JLS E	3/7/00	SRL	3-7-00	
		15A25X		per FCR 006									
		18A20X		12/10/98									
				<i>[Signature]</i>									

Remarks:

Page 665

Page 666

Compact Limit Switches


- FEATURES**
- Mode of operation is field adjustable.
 - NEMA 1, 3, 4, 6 and 13.
 - Wide choice of heads and actuators.
 - Variety of operating characteristics.
 - Optional indicator light.
 - Captive screws.
 - UL Recognized, file #E12252
 - CSA Certified, file #LR57325

Compact LS and plug-in 200LS limit switches have a long record of successful performance in industrial applications.

The LS fits in many places too small for any other fully adjustable limit switch.

The 200LS switches are the original plug-in concept for reducing downtime by making changeover simple and fast.

CIRCUITRY



FIELD ADJUSTABLE

Rotary motion roller lever and rod actuators are adjustable through 360°. They may be set for operation clockwise, counter-clockwise, or in both directions.

Operating heads may be positioned in any of four 90° positions.

UL/CSA LS SWITCHES
Several UL recognized and CSA certified LS compact limit switches are in the order guides.

Other listings can be furnished in the UL version. Contact the 800 number for information.

For rapid response - off the shelf service, all bold face listings are normally stocked items.

ELECTRICAL RATINGS

A	10 amps, 120, 240 or 480 VAC; 1/4 hp, 120 VAC; 3/4 hp, 240 VAC; 0.8 amp, 115 VDC**; 0.4 amp, 230 VDC**; 0.1 amp, 550 VDC**; Pilot Duty, 600 VAC max.	APPLICATION NOTE: Silver Cadmium Oxide Contacts - Designed for use with Inductive loads such as relays, contactors, motors and solenoids. Honeywell MICRO SWITCH does not recommend the use of silver cadmium oxide switch contacts in non-arcing loads. Non-arcing loads are generally loads less than 12 volts and/or 0.5 amp.
B	10 amps, 120, 240 or 480 VAC; 1/4 hp, 120 VAC; 1/2 hp, 240 VAC. Pilot Duty, 600 VAC max.	
C	10 amps, 120 VAC; 1/2 hp, 120 VAC.	
D	10 amps, 120, 240, 480 VAC; 1/4 hp, 120 VAC; 1/2 hp, 240 VAC; 0.8 amp, 115 VDC**; 0.4 amp, 230 VDC**; 0.1 amp, 550 VDC**; Pilot Duty, 600 VAC max.	
E	10 amps, 120, 240 or 480 VAC; 1/4 hp, 120 VAC; 3/4 hp, 240 VAC. Pilot Duty, 600 VAC max.	Fine Silver Contacts
F	UL Rating: 10 amps, 125, 250, or 480 VAC; 1/2 hp, 125 VAC; 3/4 hp, 250 VAC; 0.8 amp, 125 VDC**; 0.4 amp, 250 VDC**	
G	UL Rating: 10 amps, 125, 250 or 480 VAC; 1/4 hp, 125 VAC; 1/2 hp, 250 VAC; 0.8 amp, 125 VDC**; 0.4 amp, 250 VDC**	


** Resistive Rating
NOTE: The terminals of two-circuit double-break switches must be wired to equal voltage sources and the same polarity. The loads should be on the same side of the line.

ROLLER LEVER ROTARY ACTUATED SWITCHES

(To order switches and levers separately, refer to pages A73 and A74 or A37 and A38.)

ORDER GUIDE

Momentary action. Steel rollers.



Compact



Plug-In*

Description	Rating	Catalog Listing		O.F. max.	P.T. max.	O.T. min.	D.T. max.
		Compact	Plug-In				
Standard	A	1LS1	201LS1*	13.3 N 3 lb.	20°	30°	12°
20° Pretravel UL/CSA	F	1LS1-L	—	13.3 N 3 lb.	20°	30°	12°
Low Pretravel 5°	B	1LS19	201LS19*	13.3 N 3 lb.	5°	30°	4°
Low Operating Force 5° Pretravel	B	1LS131	—	5.0 N 18 oz.	5°	30°	4°
Standard with indicator light 120 VAC only	C	1LS501	201LS501*	13.3 N 3 lb.	20°	30°	12°
Low Operating Force	A	1LS6	201LS6*	5.0 N 18 oz.	20°	30°	12°
Cavity Mount version of 1LS1	A	7LS1	—	13.3 N 3 lb.	20°	30°	12°

* Requires Terminal Block (18PA1 for 200LS switches) which must be ordered separately. Unless damaged, it is not necessary to replace terminal block when replacing switch.

Characteristics: O.F. — Operating Force; P.T. — Pretravel; O.T. — Overtravel; D.T. — Differential Travel.

Compact Limit Switches

ROTARY ACTUATED SWITCHES — WITHOUT LEVERS

The following compact LS and plug-in limit switches are sold without actuators. Levers are ordered separately from the order guide below and on the facing page.

ORDER GUIDE

Momentary action, except where noted.

Plug-in*



Compact



Description	Electrical Rating Page A70	Catalog Listing		O.Tq. max.	P.T. max.	O.T. min.	D.T. max.
		Compact	Plug-in				
Standard 20° pretravel	A	1LS2	201LS2*	0,51 Nm 4.5 in. lb.	20°	30°	12°
	F	1LS2-L	—	0,51 Nm 4.5 in. lb.	20°	30°	12°
Low pretravel 5°	B	1LS9	201LS9*	0,51 Nm 4.5 in. lb.	5°	30°	4°
Standard pretravel 20° Low operating force	A	1LS23	201LS23*	0,21 Nm 30 in. oz.	20°	30°	12°
	B	1LS56	201LS56*	0,11 Nm 15 in. oz.	5°	30°	4°
Maintained Contact	A	6LS2	206LS2*	0,34 Nm 3 in. lb.	55°	35°	20°
	F	6LS2-L	—	0,34 Nm 3 in. lb.	55°	35°	20°

Limit/Enclosed

* Require Terminal Block (18PA) for 200LS Switches.
Note 1 — Yoke lever actuators normally used

Characteristics
O.Tq. — Operating Torque; P.T. — Pretravel; O.T. — Overtravel; D.T. — Differential Travel

AUXILIARY ROTARY LEVERS


ORDER GUIDE

	Type	Catalog Listing	
	Roller arm, with nylon, steel, or ball bearing roller.	Nylon	6PA71
		Steel	6PA121
		Ball bearing	6PA144
	Yoke roller lever with nylon or steel rollers. Rollers on same side.	Steel	6PA30
		Steel	6PA32
		Nylon	6PA102


60mm radius levers Part # PA-J11

Mounting Dimensions (For reference only)


ROLLER LEVER



Compact




Plug-in




Cavity mount

SWITCH WITHOUT LEVER



Compact



Plug-in

Basic switches

LS-series listings have 2-circuit, double break precision basic switches as standard. These are fitted with keyed washers to facilitate wiring and obviate wrap-round. Step design and use of barriers provides ample over-surface dielectric spacing. Basic switches can be replaced easily without special tools.



4-circuit double break basic switch versions are available in LS switches with roller-lever, plunger and roller-plunger. This basic has solder terminals.



Basic switch listings for respective compact LS types are listed below.

Compact LS	Basic Switch	Operating Head	Actuator Only
1LS1-4 (C or PG)	2MN1-M	9PA15-4	6PA78-4
1LS2-4 (C or PG)	2MN1-M	9PA16-4	"
1LS-4 (C or PG)	2MN1-M	9PA16-4	6PA44-4
1LS10-4 (C or PG)	2MN1-M	9PA40-4	6PA43-4
1LS19-4 (C or PG)	2MN8-M	9PA15-4	6PA78-4
1LS23-4 (C or PG)	2MN1-M	"	"
1LS47-4 (C or PG)	2MN8-M	9PA40-4	6PA43-4
1LS56-4 (C or PG)	2MN8-M	9PA74-4	"
1LS243-4 (C or PG)	2MN24	914PA15	6PA78-4
1LS244-4 (C or PG)	2MN24	914PA15	6PA78-4
2LS1-4 (C or PG)	2MN1-M	9PA32-4	NA
3LS1-4 (C or PG)	2MN11-M	9PA45-4	NA
4LS1-4 (C or PG)	2MN11-M	9PA44-4	NA
5LS1-4 (C or PG)	2MN1-M	9PA33-4	NA
6LS1-4 (C or PG)	2MN1-M	9PA46-4	6PA80-4
6LS2-4 (C or PG)	2MN1-M	9PA47-4	"
6LS3-4 (C or PG)	2MN1-M	9PA47-4	6PA102-4
8LS1-4 (C or PG)	2MN1-M	9PA58-4	NA
8LS3-4 (C or PG)	2MN1-M	9PA49-4	NA
8LS125-4 (C or PG)	2MN11-M	9PA54-4	NA
8LS152-4 (C or PG)	2MN1-M	9PA42-4	NA
11LS1-4 (C or PG)	8AS42-2B	9PA15-4	6PA78-4
11LS2-4 (C or PG)	8AS42-2B	9PA16-4	"
12LS1-4 (C or PG)	8AS42-2B	9PA32-4	NA
15LS1-4 (C or PG)	8AS42-2B	9PA33-4	NA

Note: Operating head includes lever where appropriate and internal plunger.

* Actuators shown on page 45 may be used.

** Because of low operating force 6PA43-4; 6PA71-4 or 6PA78-4 auxiliary actuators only are recommended for these listings.

*** Yoke lever actuators only.

Conduit Thread

"PG" specifies PG 13.5 thread e.g. 1LS1-4PG

"C" specifies 20 mm thread e.g. 1LS1-4C

Replacement Parts

REPLACEMENT PARTS

Except where noted, all operating heads are furnished with actuators.

Catalog Listing	Contact Block		Operating Head	Actuator Only
	Compact	Plug-In		
1LS1-L 1LS1 201LS1	2MN1-L 2MN1	2MN6	9PA15	6PA121
1LS2-L 1LS2 201LS2	2MN1-L 2MN1	2MN6	9PA16†	Note 1
1LS3-L 1LS3 201LS3	2MN1-L 2MN1	2MN6	9PA16†	LSZ52C
1LS6 201LS6	2MN1	2MN6	9PA50	6PA121
1LS9 201LS9	2MN8	2MN13	9PA16†	Note 1
1LS10-L 1LS10 201LS10	2MN1-L 2MN1	2MN6	9PA40	6PA43
1LS19 201LS19	2MN8	2MN13	9PA15	6PA121
1LS23 201LS23	2MN1	2MN6	9PA68†	Note 2
1LS47 201LS47	2MN8	2MN13	9PA40	6PA43
1LS53 201LS53	2MN8	2MN13	9PA48	6PA43
1LS56 201LS56	2MN8	2MN13	9PA74†	Note 2
1LS58	2MN8	—	9PA16†	LSZ52C
1LS13†	2MN8	—	9PA50	6PA121
1LS501 201LS501	2MN1	2MN14	9PA15	6PA121

Catalog Listing	Contact Block		Operating Head	Actuator Only
	Compact	Plug-In		
2LS1-L 2LS1 202LS1	2MN1-L 2MN1	2MN6	9PA32	None
2LS111 202LS111	2MN3	2MN7	9PA71	None
3LS1 203LS1	2MN11	2MN9	9PA45	None
4LS1 204LS1	2MN11	2MN9	9PA44	None
5LS1-L 5LS1 205LS1	2MN1-L 2MN1	2MN6	9PA33	None
6LS1 206LS1	2MN1	2MN6	9PA46	6PA40
6LS2-L 6LS2 206LS2	2MN1-L 2MN1	2MN6	9PA47†	Note 3
6LS3	2MN1	—	9PA47†	6PA102
7LS1	2MN1	—	9PA15	6PA121
8LS1-L 8LS1 208LS1	2MN11-L 2MN11	2MN9	9PA58	None
8LS3 208LS3	2MN1	2MN6	9PA49	None
8LS125 208LS125	2MN11	2MN9	9PA54	None
8LS152 208LS152	2MN1	2MN6	9PA42	None

Limit/Enclosed

Furnished without actuator
 Note 1—Any auxiliary actuator shown can be used with these listings.
 Note 2—6PA43 6PA53 6PA71 or 6PA121 auxiliary actuators only are recommended for these listings.
 Note 3—Yoke lever actuators normally used

CONDUIT SEALING PACKETS

Packet	Cable O.D. Inches
2PA6	.400"-.435"
2PA16	.435"-.470"
2PA1	.530"-.570"

See page A49 for description)

MHM-FCL-006
12/10/98

MHM-FCL-034
2/19/99

MCC#10

U.S. DEPARTMENT OF ENERGY
WESTINGHOUSE HANFORD COMPANY
WHC-SOX-452656
WHC-S-0468

H-2-827169


CEC ALSTHOM ENGINEERING SYSTEMS LTD
Widmore, Leicester, LE8 6UH, England

4433 HANFORD

WIRING DIAGRAM
TUBE PLUG HOST

363A0033

4



CONTINUED FROM SHEET 3

CONTINUED ON SHEET 7

CONTINUED ON SHEET 6

TO ORDER INTERLOCK CIRCUIT (X) VIA TURRET ROTARY FEEDBACK
SEE ELEMENTARY EG-33058 SHEETS 15A, 17 & 17A

BLOCK INTERCONNECTION DIAGRAM - 363A0029 SHEET 4

THIRD ANGLE PROJECTION
DO NOT SCALE
COORDINATE CHANGE INDICATED BY FOLLOWING:
REVISION NUMBER
DATE
BY
CHECKED BY
VERIFIED BY
SUBMITTED BY

363A0033

THIS DRAWING IS ONLY AN APPROVED COPY IF SEALED.

Dedication Test Plan – IST-LS-1


Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-011-TP-011B

Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRY

Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
						 3/13/00 NO CHANGES

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST-LS-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-011-TP-011B	27
Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFY	Page 1 of 6

In-Situ Test Procedure

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *[Signature]* Date: 3/1/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bellhaven	<i>[Signature]</i>	MC
Electrician	J WEGERMAN	PCE	<i>[Signature]</i>	JWE
Electrician Quality Control	Stephen R. Conley	PCE	<i>[Signature]</i>	SR
Design Authority Representative	LARRY W. FRIE	KWEST	<i>[Signature]</i>	LWF
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC
 Megger Instrument capable of 1000 VDC Test Voltage
 MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
 Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type:	<u>HP3457</u>	I.D.:	<u>BAT 123</u>	Calib. Due date:	<u>7-29-00</u>
Test Instrument type:	<u>HP3457</u>	I.D.:	<u>BAT 124</u>	Calib. Due date:	<u>7-30-00</u>
Test Instrument type:	<u>AVO BM 89/2</u>	I.D.:	<u>6410-889 000100/5345</u>	Calib. Due date:	<u>2-9-01</u>
Test Instrument type:	<u>FLUKE 787</u>	I.D.:	<u>BAT 107</u>	Calib. Due date:	<u>5-28-00</u>
Test Instrument type:	<u>PROTO</u>	I.D.:	<u>029E1009/2</u>	Calib. Due date:	<u>1-14-2001</u>

TO REQ
SCREW DRIVER

ORIGINAL

Dedication Test Plan – IST-LS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-011-TP-011B

Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRY

Page 37 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFPHFRY	LFPHFRY	Acc.
Manufacturer:	HONEYWELL	Honeywell	Acc.
Model:	1LS19-4C	1LS19-4C	Acc.
Actuator:	YES	Side mounted, rotary w/ nominal 1.5 inch radius, metallic arm w/roller	Acc.
Serial No./Lot No./Date Code:	N/A	N/A	

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 2:10 p.m 3-2-00
 Record: Room Temperature: 68 °F. Room Barometric Pressure: N/A mmHg.

2.2 Mechanical Operation

2.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

2.2.2 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
No of Cycles:	6	> 5 times	Acc.
Describe Operation:	YES	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	YES	Free release of spring.	Acc

Dedication Test Plan – IST-LS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-011-TP-011B

47

Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRY

Page 3 of 6

2.3 Contact Rating Test

- 2.3.1 Setup the test equipment and Limit Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.
- 2.3.2 At limit switch LFPHFRY, lift leads on Common terminal, Normally Closed terminal and Normally Open terminal. Record on the lifted lead log.
- 2.3.3 Connect the power supply to terminals Common and Normally Closed.
- 2.3.4 Apply a nominal 10 amps, resistive, across the normally closed contacts of the test specimen.

Caution: Do not change state of contacts while energized.

- 2.3.5 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- NC)	.02 VAC	< 0.5 Volts AC drop	Acc
	.02 VAC		

- 2.3.6 Reduce the current source to zero amps.
- 2.3.7 Disconnect the power supply from terminals Common and Normally Closed.
- 2.3.8 Manually adjust the limit switch actuator to close the normally open contacts.
- 2.3.9 Connect the power supply to terminals Common and Normally Open.
- 2.3.10 Apply a nominal 10 amps, resistive, across the closed normally open contacts of the test specimen.
- 2.3.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- Closed NO Contact):	.02 VAC	< 0.5 Volts AC drop	Acc
	.		

Dedication Test Plan – IST-LS-1

Test Plan No.: CGI-SNF-D-MHM-011-TP-011B

Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFRY

Rev. No. 0

57

Page 4 of 6

2.3.12 Reduce the current source to zero amps and remove the power supply from terminals Common and Normally Open.

2.3.13 Manually adjust the limit switch actuator to close the normally closed contacts.

2.4 Insulation Resistance Test

2.4.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing.

2.4.2 Apply a nominal 1000 VDC via Megger device between non-continuity terminals Common and Normally Open and then between terminal Normally Open and ground. Record the resistances.

2.4.3 Remove the Megger device.

2.4.4 Manually adjust the limit switch actuator to open the normally closed (NC) contacts.

2.4.5 Apply a nominal 1000 VDC via Megger device between non-continuity terminals Common and open Normally Closed and then between terminal Normally Closed and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
Common	NO	5.6 Gohm	> 10 Megohms	ACC.
NO	Ground	6.5 Gohm	> 10 Megohms	ACC.
Common	open NC*	7.3 Gohm	> 10 Megohms	ACC.
Open NC	Ground*	8.5 Gohm	> 10 Megohms	ACC.

* Normally closed contacts are open.

2.4.6 De-energize and remove the test equipment.

2.5 Terminate the test.

2.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.5.2 Retorque the terminals to 7-9 in-pounds.

2.5.3 Record: Date /Time of Test End: 3:00 PM 3-2-00

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Dedication Test Plan - IST-LS-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-011-TP-011B	Page 67 of 68
Test Specimen: Honeywell 1LS19-4C Limit Switch, Eqmt. No.: LFPHFY	

Summary of Results (Continued):

Component meets all of this test plan requirements.

M. Cram 3-02-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 3-02-00
Reviewed by: gt 3/2/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 3/2/00

QA/QC (signature) [Signature] Date: 3/13/00
T Z ANDERSON

Compact Limit Switches

FEATURES


- Mode of operation is field adjustable.
- NEMA 1, 3, 4, 6 and 13.
- Wide choice of heads and actuators.
- Variety of operating characteristics.
- Optional indicator light.
- Captive screws.
- UL Recognized, file #E12252
- CSA Certified, file #LR57325

Compact LS and plug-in 200LS limit switches have a long record of successful performance in industrial applications.

The LS fits in many places too small for any other fully adjustable limit switch.

The 200LS switches are the original plug-in concept for reducing downtime by making changeover simple and fast.

CIRCUITRY



FIELD ADJUSTABLE

Rotary motion roller lever and rod actuators are adjustable through 360°. They may be set for operation clockwise, counter-clockwise, or in both directions.

Operating heads may be positioned in any of four 90° positions.

UL/CSA LS SWITCHES

Several UL recognized and CSA certified LS compact limit switches are in the order guides.

Other listings can be furnished in the UL version. Contact the 800 number for information.

For rapid response - off the shelf service, all bold face listings are normally stocked items.

ELECTRICAL RATINGS

A	10 amps, 120, 240 or 480 VAC; ½ hp, 120 VAC; ¾ hp, 240 VAC; 0.8 amp, 115 VDC**; 0.4 amp, 230 VDC** 0.1 amp, 550 VDC** Pilot Duty, 600 VAC max.	APPLICATION NOTE: Silver Cadmium Oxide Contacts - Designed for use with inductive loads such as relays, contactors, motors and solenoids. Honeywell MICRO SWITCH does <i>not</i> recommend the use of silver cadmium oxide switch contacts in non- arcing loads. Non-arcing loads are gen- erally loads less than 12 volts and/or 0.5 amp.
B	10 amps, 120, 240 or 480 VAC; ½ hp, 120 VAC; ¾ hp, 240 VAC. Pilot Duty, 600 VAC max.	
C	10 amps, 120 VAC; ½ hp, 120 VAC.	
D	10 amps, 120, 240, 480 VAC; ½ hp, 120 VAC; ¾ hp, 240 VAC; 0.8 amp, 115 VDC**; 0.4 amp, 230 VDC**; 0.1 amp, 550 VDC**; Pilot Duty, 600 VAC max.	
E	10 amps, 120, 240 or 480 VAC; ½ hp, 120 VAC; ¾ hp, 240 VAC. Pilot Duty, 600 VAC max.	Fine Silver Contacts
F	UL Rating: 10 amps, 125, 250, or 480 VAC; ½ hp, 125 VAC; ¾ hp, 250 VAC; 0.8 amp, 125 VDC**; 0.4 amp, 250 VDC**	
G	UL Rating: 10 amps, 125, 250 or 480 VAC; ½ hp, 125 VAC; ¾ hp, 250 VAC; 0.8 amp, 125 VDC**; 0.4 amp, 250 VDC**	

** Resistive Rating

NOTE: The terminals of two-circuit double-break switches must be wired to equal voltage sources and the same polarity. The loads should be on the same side of the line.

ROLLER LEVER ROTARY ACTUATED SWITCHES

(To order switches and levers separately, refer to pages A73 and A74 or A37 and A38.)

ORDER GUIDE

Momentary action. Steel rollers.



Compact



Plug-In*

Description	Rating	Catalog Listing		O.F. max.	P.T. max.	O.T. min.	D.T. max.
		Compact	Plug-in				
Standard	A	1LS1	201LS1*	13.3 N 3 lb.	20°	30°	12°
20° Pretravel UL/CSA	F	1LS1-L	—	13.3 N 3 lb.	20°	30°	12°
Low Pretravel 5°	B	1LS19	201LS19*	13.3 N 3 lb.	5°	30°	4°
Low Operating Force 5° Pretravel	B	1LS131	—	5.0 N 18 oz.	5°	30°	4°
Standard with indicator light 120 VAC only	C	1LS501	201LS501*	13.3 N 3 lb.	20°	30°	12°
Low Operating Force	A	1LS6	201LS6*	5.0 N 18 oz.	20°	30°	12°
Cavity Mount version of 1LS1	A	7LS1	—	13.3 N 3 lb.	20°	30°	12°

* Require Terminal Block (18PA1 for 200LS switches) which must be ordered separately. Unless damaged, it is not necessary to replace terminal block when replacing switch.

Characteristics: O.F. — Operating Force; P.T. — Pretravel; O.T. — Overtravel; D.T. — Differential Travel.

Compact Limit Switches


ROTARY ACTUATED SWITCHES — WITHOUT LEVERS

The following compact LS and plug-in 200LS limit switches are sold without actuators. Levers are ordered separately in the order guide below and on the facing page.

ORDER GUIDE

Momentary action, except where noted.

Plug-in*



Compact



Description	Electrical Rating Page A70	Catalog Listing		O.Tq. max.	P.T. max.	O.T. min.	D.T. max.
		Compact	Plug-in				
Standard 20° pretravel	A	1LS2	201LS2*	0,51 Nm 4.5 in. lb.	20°	30°	12°
	F	1LS2-L	—	0,51 Nm 4.5 in. lb.	20°	30°	12°
Low pretravel 5°	B	1LS9	201LS9*	0,51 Nm 4.5 in. lb.	5°	30°	4°
Standard pretravel 20° Low operating force	A	1LS23	201LS23*	0,21 Nm 30 in. oz.	20°	30°	12°
Low pretravel 5° Low operating force	B	1LS56	201LS56*	0,11 Nm 15 in. oz.	5°	30°	4°
Maintained Contact	A	6LS2	206LS2*	0,34 Nm 3 in. lb.	55°	35°	20°
	F	6LS2-L	—	0,34 Nm 3 in. lb.	55°	35°	20°

Limit/Enclosed

* Require Terminal Block (18PA1 for 200LS Switches).
 Note 1 — Yoke lever actuators normally used

Characteristics:
 O.Tq. — Operating Torque; P.T. — Pretravel; O.T. — Overtravel; D.T. — Differential Travel

AUXILIARY ROTARY LEVERS

ORDER GUIDE


Diagram	Type	Catalog Listing	
		Material	Part #
	Roller arm, with nylon, steel, or ball bearing roller.	Nylon	6PA71
		Steel	6PA121
		Ball bearing	6PA144
	Yoke roller lever with nylon or steel rollers. Rollers on same side.	Steel	6PA80
		Steel	6PA82
		Nylon	6PA102

60mm radius levers Part # PA-J11




Mounting Dimensions (For reference only)


ROLLER LEVER



Compact




Plug-in




Cavity mount

SWITCH WITHOUT LEVER



Compact



Plug-in

Basic switches

LS-series listings have 2-circuit, double break precision basic switches as standard. These are fitted with keyed washers to facilitate wiring and obviate wrap-round. Step design and use of barriers provides ample over-surface dielectric spacing. Basic switches can be replaced easily without special tools.



4-circuit double break basic switch versions are available in LS switches with roller-lever, plunger and roller-plunger. This basic has solder terminals.



Basic switch listings for respective compact LS types are listed below.

Compact LS	Basic Switch	Operating Head	Actuator Only
1LS1-4 (C or PG)	2MN1-M	9PA15-4	6PA78-4
1LS2-4 (C or PG)	2MN1-M	9PA16-4	"
1LS-4 (C or PG)	2MN1-M	9PA16-4	6PA44-4
1LS10-4 (C or PG)	2MN1-M	9PA40-4	6PA43-4
1LS19-4 (C or PG)	2MN8-M	9PA15-4	6PA78-4
1LS23-4 (C or PG)	2MN1-M	-	-
1LS47-4 (C or PG)	2MN8-M	9PA40-4	6PA43-4
1LS56-4 (C or PG)	2MN8-M	9PA74-4	"
1LS243-4 (C or PG)	2MN24	914PA15	6PA78-4
1LS244-4 (C or PG)	2MN24	914PA15	6PA78-4
2LS1-4 (C or PG)	2MN1-M	9PA32-4	NA
3LS1-4 (C or PG)	2MN11-M	9PA45-4	NA
4LS1-4 (C or PG)	2MN11-M	9PA44-4	NA
5LS1-4 (C or PG)	2MN1-M	9PA33-4	NA
6LS1-4 (C or PG)	2MN1-M	9PA46-4	6PA80-4
6LS2-4 (C or PG)	2MN1-M	9PA47-4	***
6LS3-4 (C or PG)	2MN1-M	9PA47-4	6PA102-4
8LS1-4 (C or PG)	2MN1-M	9PA58-4	NA
8LS3-4 (C or PG)	2MN1-M	9PA49-4	NA
8LS125-4 (C or PG)	2MN11-M	9PA54-4	NA
8LS152-4 (C or PG)	2MN1-M	9PA42-4	NA
11LS1-4 (C or PG)	8AS42-2B	9PA15-4	6PA78-4
11LS2-4 (C or PG)	8AS42-2B	9PA16-4	"
12LS1-4 (C or PG)	8AS42-2B	9PA32-4	NA
15LS1-4 (C or PG)	8AS42-2B	9PA33-4	NA

Note : Operating head includes lever where appropriate and internal plunger.

* Actuators shown on page 45 may be used.

** Because of low operating force 6PA43-4; 6PA71-4 or 6PA78-4 auxiliary actuators only are recommended for these listings.

*** Yoke lever actuators only.

Conduit Thread

"PG" specifies PG 13.5 thread e.g. 1LS1-4PG

"C" specifies 20 mm thread e.g. 1LS1-4C

Replacement Parts

REPLACEMENT PARTS

Except where noted, all operating heads are furnished with actuators.

Catalog Listing	Contact Block		Operating Head	Actuator Only
	Compact	Plug-In		
LS1-L	2MN1-L	2MN8	9PA15	6PA121
LS1 01LS1	2MN1			
LS2-L	2MN1-L	2MN6	9PA16†	Note 1
LS2 01LS2	2MN1			
LS3-L	2MN1-L	2MN6	9PA16†	LSZ52C
LS3 01LS3	2MN1			
LS6 01LS6	2MN1	2MN6	9PA50	6PA121
LS9 01LS9	2MN8	2MN13	9PA16†	Note 1
LS10-L	2MN1-L	2MN6	9PA40	6PA43
LS10 01LS10	2MN1			
LS19 01LS19	2MN8	2MN13	9PA15	6PA121
LS23 01LS23	2MN1	2MN6	9PA68†	Note 2
LS47 01LS47	2MN8	2MN13	9PA40	6PA43
LS53 01LS53	2MN8	2MN13	9PA48	6PA43
LS55 01LS55	2MN8	2MN13	9PA74†	Note 2
LS58	2MN8	—	9PA16†	LSZ52C
LS131	2MN8	—	9PA50	6PA121
LS501 01LS501	2MN1	2MN14	9PA15	6PA121

Furnished without actuator.

Note 1—Any auxiliary actuator shown can be used with these listings.

Note 2—6PA43, 6PA63, 6PA71 or 6PA121 auxiliary actuators only are recommended for these listings.

Note 3—Yoke lever actuators normally used.

CONDUIT SEALING PACKETS

Packet	Cable O.D. Inches
PA6	.400"-.435"
PA16	.435"-.470"
PA1	.530"-.570"


See page A49 for description)

Catalog Listing	Contact Block		Operating Head	Actuator Only
	Compact	Plug-In		
2LS1-L	2MN1-L	2MN6	9PA32	None
2LS1 202LS1	2MN1			
2LS111 202LS111	2MN3	2MN7	9PA71	None
3LS1 203LS1	2MN11	2MN9	9PA45	None
4LS1 204LS1	2MN11	2MN9	9PA44	None
5LS1-L	2MN1-L	2MN6	9PA33	None
5LS1 205LS1	2MN1			
6LS1 206LS1	2MN1	2MN6	9PA46	6PA80
6LS2-L	2MN1-L	2MN6	9PA47†	Note 3
6LS2 206LS2	2MN1			
6LS3	2MN1	—	9PA47†	6PA102
7LS1	2MN1	—	9PA15	6PA121
8LS1-L	2MN11-L	2MN9	9PA58	None
8LS1 208LS1	2MN11			
8LS3 208LS3	2MN1	2MN6	9PA49	None
8LS125 208LS125	2MN11	2MN9	9PA54	None
8LS152 208LS152	2MN1	2MN6	9PA42	None

Limit/Enclosed

FOR NOTES SEE SHT 1

TO ORDER INTERLOCK CURBLE (Y) VIA TURRET ROTATE RESTION
SEE ELEMENTARY EB-23058 SMTS. 15A, 17 & 17A



363A0033

- TUBE PLUG GRAPPLE
- TUBE PLUG GRAPPLE JAW FULLY OPEN (Y) LIGHT SWITCH
3A2P0557/171 HONEYWELL S.I.-E
- TUBE PLUG GRAPPLE JAW FULLY CLOSED (Y) LIGHT SWITCH
3A2P0557/171 HONEYWELL S.I.-E
- TUBE PLUG GRAPPLE JAW LOCKED (Y) LIGHT SWITCH
3A2P0557/171 HONEYWELL S.I.-H
- TUBE PLUG GRAPPLE SUPPORTED (Y) LIGHT SWITCH
3A2P0557/170 HONEYWELL S.I.-H
- TUBE PLUG HOIST FULLY RAISED (Y) LIGHT SWITCH
3A2P0557/62 HONEYWELL T1S19-4C

U.S. DEPARTMENT OF ENERGY
WESTINGHOUSE HANFORD COMPANY
MDK-SDX-432856
WMC-S-0468
H-2-827169

GEC ALSTHOM ENGINEERING SYSTEMS LTD
Walsley, Leicester, LE8 6JA, England

4683 HANFORD

363A0033

THIRD PARTY PRODUCTION
DO NOT SCALE IF IN DOUBT - ASK
FOR ORIGINAL
CHECK FOR
REVISIONS
REVISION NUMBER
SUBMITTAL

4683 HANFORD

363A0033

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. **N/A** CGI No. **CGI-SNF-D-MHM-009**

Page 1 of 8

Title: **P-21 - CCS Industrial Pressure Switch 604G3**

Section 1 Part Information

Item No.: N/A	Manufacturer: N/A	Supplier: N/A
----------------------	--------------------------	----------------------

Mfg. Part/Model No.: N/A	Supplier's P/N: N/A
---------------------------------	----------------------------

Part Description: N/A	ORIGINAL
------------------------------	-----------------

End Use Description: N/A

Section 2a Component Information

Equipment No.: PLSTSC1AX, PSLTSC2AY, PSLTSC2AX, PSLTSC2AY	Specification No.: Ederer F-2566, Foster Wheeler MJX-SDX 452656	Manufacturer: CCS Industrial	Past P.O. No.: N/A
--	--	-------------------------------------	---------------------------

all PSL
yup

Manufacturer's Part/Model No.: 604G3	Equipment Supplier (if different from manufacturer): ALSTOM, Foster Wheeler/Johnson Industries Ltd.	Equip. Supplier's Part No.: N/A
---	--	--

Component Description:
SPDT pressure switches for Interlock P-21, located inside the seismic clamps, to measure bridge seismic clamps not fully applied, inhibits turret rotation, base and turret locking pins disengaging, lowering of shield skirt, and MCO and tube plug hoist operation.

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)? YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
 If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate w/ project CGI Interface Engineer or BTR) YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)

2. List of Candidate qualified suppliers or ISO 9000 suppliers **N/A**

3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): **N/A**

Section 2c CGI Determination

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)

[X] All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. **N/A**

CGI No. **CGI-SNF-D-MHM-009**

Page 2 of 8

Title: **P-21 - CCS Industrial Pressure Switch 604G3**

Section 2d Reason for Dedication

The above described Item is being Dedicated for use in the application cited for the following reason(s):

- Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
- Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
- Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
- Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
- Other ('like-for-like', similar, substitution, replacement evaluation)

YIP
LES
4/19/00

Section 3 Failure Effects Evaluation

- A. Part/Component Safety Function:
1. **Interlock P-21 inhibits turret rotation, base and turret locking pins disengagement, shield skirt lowering, and hoists operation if the bridge seismic clamps are not fully applied. Prevent MCO shear from lateral movement of the MHM.**
 - 2.
- B. Part/Component Functional Mode:
- | | |
|--|---|
| Safety Function #1: <input checked="" type="checkbox"/> Active [] Passive | Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function
Passive - Change of state is not required for the component to perform its safety function |
| Safety Function #2: [] Active [] Passive | |
| Safety Function #3: [] Active [] Passive | |
- C. Host Component Safety Function (if applicable): **N/A**
- 1.
- D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):
1. **Failure of pressure switch contacts to open upon demand results in potential override of interlock channel.**

Section 4 Environmental & Natural Phenomena Hazard Design

- Environmental Qualification Required:
- Yes []
No
- If yes: Environmental Qualification Requirements
Limiting Environmental Conditions:
Required Safety Functions:
Qualification Period:
- Natural Phenomena Hazard (NPH) Design Required:
- Yes []
No
- If yes: NPH Design Requirements
Performance Category:
NPH Design Req'ts.:
Required Safety Functions:

Section 5 Component Functional Classification

Safety Class (SC)	General Service	<input checked="" type="checkbox"/>	Safety Significant (SS)
-------------------	-----------------	-------------------------------------	-------------------------

If part/component classification is different from host component/system, document basis. **N/A**

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

- National Codes/Standards: **N/A**
- Safety Analysis Report (SAR): **HNF-3672 Rev. 0**
- Drawings: **Ederer, Inc. EB-33056, Sheet 35, Hanford H-2-827174, Sheets 4, 9, 14, 15, 19, 23.**
- Vendor Manual/Manufacturer/Supplier Information: **CCS Industrial series 604G, 604P, 604V Vendor Sheet.**
- Other: **ALSTROM ESL/R (96) 065-Rev. D, 100% Design Submittal, June 1998.**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 3 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-009
Title: P-21 - CCS Industrial Pressure Switch 604G3

Section 9 Critical Characteristics

Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	CCS Industrial	1, IN	X	
Model	604G3	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Pressure Port	Nominal 1/4"	1, IN	X	
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Contact rating	Nominal 15 amps, resistive, @ 120 VAC less than 0.5 V drop across contacts.	1, T		X
Insulation Resistance	Greater than 10 megohms resistance, terminal to terminal and terminal to ground at 1000V.	1, T		X
Mechanical Operation	Cycle pressure - confirm switch contacts open and close at set points with a nominal deadband of 20 psi and with smooth operation and free release of spring.	1, T		X
Pressure Test	No leakage at 400 ¹⁸⁰⁰ psi (e.g. no bubbles if tested with a gas) 1800 CPS 4/12/00	1, T		X
4. Notes and Legend: The non-metallic polyimide Buna N, viton, and ethylene propylene parts are not susceptible to degradation or aging at the CSB environmental conditions. Rev. 1: Page 3, 5, 6 & 7: Revised to "Contact Rating" only; General: new forms		Acceptance Method (Acc Meth): 1. Special Test and Inspection: 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 3. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:
 Designated Engineer: [Signature]
 Design Authority: DW [Signature]
 QA Engineer: [Signature] 1/18/00
 T R ANDERSON

Commercial Grade Item Upgrade Dedication Form

Page 688

Rev. No. 1
Page 4 of 8

SNF-6315, Rev. 0

ECN No. **NA** CGI No. **CGI-SNF-D-MHM-009**
Title **P-21 - CCS Industrial Pressure Switch 604G3**

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	X	Switch contacts corrode closed and fail to open upon demand.
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Switch contacts fuse closed and fail to open upon demand.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Switch mechanism jams and contacts fail to open upon demand.
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2. Additional Failure Modes Applicable to the Component Under Evaluation			
1. Pressure switch contacts are closed to enable equipment movement. Contacts open for the interlock function to prevent lateral movement of the MHM. Any failure which prevents contacts to open inhibits the particular pressure switch interlock function.			
2. Short circuit could give false signal to energize interlock function.			
3.			

Commercial Grade Item Upgrade Dedication Form

Page 689

Rev. No. 1

ECN No. **N/A** CGI No. **CGI-SNF-D-MHM-009**

Page 5 of 8

Title: **P-21 - CCS Industrial Pressure Switch 604G3**

SNF-6315, Rev. 0

CHECKLIST 1 - ACCEPTANCE METHOD 1 - SPECIAL TEST/INSPECTION VERIFICATION

SECTION 1	
Item Description: CCS Industrial Pressure Switches System #: MHM	Equip #: PLSTSC1AX, PSLTSC2AY, PSLTSC2AX, PSLTSC2AY Model #: 604G3
Manufacturer (Address/Phone): CCS Industrial 477 S.O.M. Center Rd. Mayfield Village, OH 44143 (216)979-7378	Supplier (Address/Phone): Johnson Industries, Ltd. 8500 River Road Richmond BC, Canada (604) 273-3737 V6X1Y4

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Model
X			3. Pressure Port
	X		4. Contact Rating
	X		5. Insulation Resistance
	X		6. Mechanical Operation
	X		7. Pressure Retention

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic: Manufacturer Acceptance Criteria: CCS Industrial Receipt Inspection Plan / Report #: TP009*	Sample Size*: 100%
Characteristic: Model Acceptance Criteria: 604G3 Receipt Inspection Plan / Report #: TP009*	Sample Size*: 100%
Characteristic: Pressure Port Acceptance Criteria: 1/4" Nominal Receipt Inspection Plan / Report #: TP009*	Sample Size*: 100%

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A

CGI No. CGI-SNF-D-MHM-009

Page 6 of 8

Title P-21 - CCS Industrial Pressure Switch 604G3

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size, References (See Section 7)

Characteristic for Test: **Contact Rating** Samp Size*: Normal Reduced Tightened
 Acceptance Criteria: **Nominal 15 amps, resistive, @ 120 VAC less than 0.5 V drop across contacts.**
 Actual Test Value: SEE TP Test Plan and Report #: TP009*

Characteristic for Test: **Insulation Resistance** Samp Size*: Normal Reduced Tightened
 Acceptance Criteria: **Greater than 10 megohms resistance, terminal to terminal and terminal to ground at 1000V.**
 Actual Test Value: SEE TP Test Plan and Report #: TP009*

Characteristic for Test: **Mechanical Operation** Samp Size*: Normal Reduced Tightened
 Acceptance Criteria: **Cycle pressure - confirm switch contacts open and close at set points with a nominal deadband of 20 psi and with smooth operation and free release of spring.**
 Actual Test Value: SEE TP Test Plan and Report #: TP009*

Characteristic for Test: **Pressure Retention** Samp Size*: Normal Reduced Tightened
 Acceptance Criteria: **No leakage at ^{1200 psi} 400 psi (e.g. no bubbles if tested with a gas)**
 Actual Test Value: SEE TP Test Plan and Report #: TP009*

* Full no. is: CGI-SNF-D-MHM-009-TP-009

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A CGI No. CGI-SNF-D-MHM-009

Page 7 of 8

Title: P-21 - CCS Industrial Pressure Switch 604G3

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION:

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method TAN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	CCS Industrial	X		1, IN	TP-009	N/A	2	0	XWEST	LARRY W. PRICE	9/10/00
Model	604G3	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Pressure Port	Nominal 1/4"	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Contact Rating	Nominal 15 amps, resistive, @ 120 VAC less than 0.5 V drop across contacts.		X	1, T	↓	↓	↓	↓	↓	↓	↓
Insulation Resistance	Greater than 10 megohms resistance, terminal to terminal and terminal to ground at 1000V.		X	1, T	↓	↓	↓	↓	↓	↓	↓
Mechanical Operation	Cycle pressure - confirm switch contacts open and close at set points with a nominal deadband of 20 psi and with smooth operation and free release of spring.		X	1, T	↓	↓	↓	↓	↓	↓	↓
Pressure Retention	No leakage at ^{1000 psi} 400 psi (e.g. no bubbles if tested with a gas)		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-009 cited above. CES Testing Agency Approval: <u>NR-CES 9/12/00</u> Date <u>9/12/00</u>		BUYER VERIFICATION Design Authority: <u>Greg Jensen</u> Date <u>9/12/00</u>	
Testing Agency QA Engineer: <u>NR-CES 9/12/00</u> Date _____		QA Engineer: _____ Date _____	

01/17/00

SNF-6315, Rev. 0

Page 691

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. **N/A**

CGI No. **CGI-SNF-D-MHM-009**

Page 8 of 8

Title **P-21 - CCS Industrial Pressure Switch 604G3**

SNF-6315, Rev. 0

Section 6 Contacts/Phone Numbers

Name	Phone
Design Authority	
QA	
QC	
Cog - Engineer	
CGI Engineer	
Procurement Engineer	
Other	

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents	For Critical Characteristics
<input type="checkbox"/> Drawings:	
<input type="checkbox"/> Manuals (specify type & number):	
<input type="checkbox"/> Design Calculations	
<input type="checkbox"/> Installation Instructions	
<input type="checkbox"/> Operation Instructions	
<input type="checkbox"/> Calibration Instructions	
<input type="checkbox"/> Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/> Other: CCS Industrial Series 604G, 604P, 604V Vendor Sheet	All
Procurement Documents	For Critical Characteristics
<input type="checkbox"/> Certificate of Conformance/Compliance	
<input type="checkbox"/> Seismic Qualification Certificate	
<input type="checkbox"/> Environmental Qualification Certificate	
<input type="checkbox"/> Test Report (s):	
<input type="checkbox"/> Inspection Report (s):	
<input type="checkbox"/> CMTRs for ASME Pressure Retaining Materials	
<input type="checkbox"/> Valve Seat Leakage Report	
<input type="checkbox"/> Weld Records	
<input type="checkbox"/> Material Traceability Record	
<input checked="" type="checkbox"/> Other: SU Test SNF-CTP-IC-07	

Dedication Test Plan - PS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-009-TP-009

Test Specimen: CCS Industrial Pressure Switch

Page 1 of 4

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature)

Yump
*Liing Swenson*Date: 1/31/00**RECOMMENDED EQUIPMENT:**

Power Supply capable of 15 amps @ 125VAC

Megger Instrument capable of 1000 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Helium supply

Pressure regulator - helium supply to 1800+ psig

Peak Pressure indicator 0-2000+ psig

Set Point Pressure indicator 0-50 psig

Test jig to mount Pressure Switch vertically with port at bottom of switch

Personnel protection panel

Snoop or equivalent

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

ORIGINAL

Record test instrument(s) serial numbers and calibration dueTest Instrument type: HP 3457A I.D.: BAT-123 Calib. Due date 7-29-00Test Instrument type: HP 3457A I.D.: BAT-124 Calib. Due date 7-30-00Test Instrument type: AVO BM80/2 I.D.: 410-889/200102/5245 Calib. Due date 2-9-01Test Instrument type: AMETEK 93CP I.D.: BAT-042 Calib. Due date 1-13-02
TRANSCAT D6-B BAT-046 2-14-00

SAFETY INSTRUCTIONS: PERSONNEL SAFETY - personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)Test Specimen Description: Pressure Switch**Record the following identification information:**

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>CCS</u>	CCS Industrial	<u>ACCEPT</u>
Model:	<u>60463</u>	604G3	<u>ACCEPT</u>
Pressure Port:	<u>1/4 NPT</u>	1/4" Nominal	<u>ACCEPT</u>
Serial No.:	<u>MARKED "A"</u>	N/A	<u>✓</u>

ORIGINAL

Dedication Test Plan – PS-1 Test Plan No.: CGI-SNF-D-MHM-009-TP-009 Test Specimen: CCS Industrial Pressure Switch	Rev. No. 0 Page 2 of 4
---	-------------------------------

Perform the following tests:

Record: Date /Time of Test Beginning: 2-14-00, 3:25 P

Record: Room Temperature: 68 °F. Room Barometric Pressure: -6.1489 mmHg.

Perform steps below:

1. Contact Rating Test

Setup the Limit Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

Apply a nominal 15 amps, resistive, @ 125 VAC across the normally closed contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #1 (Terminals COM-NC):	<i>VAC</i> <i>2/14/00 CES</i> 2/14/00 VAC -107	<i>2/14/00 CES</i> 0.5 ± 10% Volts AC drop	<i>ACCEPT</i>

Apply a nominal 15 amps, resistive, @ 125 VAC across the closed normally open contacts of the test specimen. Move the actuator and close the NO contacts.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #1 (Terminals COM-NC these are closed NO Contacts):	<i>VAC</i> <i>2/14/00 CES</i> 2/14/00 VAC -112	<i>2/14/00 CES</i> 0.5 ± 10% Volts AC drop	<i>ACCEPT</i>

2. Insulation Resistance Test

Setup the Pressure Switch specimen for insulation resistance testing:

Apply a nominal 1000 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground				
Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
COM	NO	17.0 G Ohms	> 10 Megohms	<i>ACCEPT</i>
COM	NC (Open Contact)	11.5 G Ohms	> 10 Megohms	<i>ACCEPT</i>
COM or NC	Ground	> 200 G	> 10 Megohms	<i>ACCEPT</i>
NO	Ground	40.0 G	> 10 Megohms	<i>ACCEPT</i>

Dedication Test Plan - PS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-009-TP-009

Test Specimen: CCS Industrial Pressure Switch

Page 3 of 4

3. Mechanical Operation - Set Point Pressure Test

Mount Pressure Switch to test jig vertically with port at bottom of switch. Attach sketch of pressure switch mounting, test setup, show test instruments and source of pressure.

Cycle pressure - confirm switch contacts open and close at set points with a nominal deadband of 20 psi and with smooth operation and free release of spring. Note: use set point pressure range indicator (0-50 psig).

Description	Record Data	Acceptance Criteria	Comments/Deviations
Set Point Adjustment:	Increasing-Set @: <i>29.7 psig</i> Decreasing-Set @: <i>9.9 psig</i>	Increasing pressure, set switch to actuate @ 30 psig ± 3 psig. Decreasing pressure, set switch to actuate @ 10 psig ± 3 psig.	<i>(ACCEPTED)</i> <i>NOTE: MFG SCALE HAS MINIMUM SET POINT INDICATOR @ 50 PSIG.</i>
Take Set Point Readings:	1: <i>29.1 / 10.4 psig</i> 2: <i>29.0 / 10.3 psig</i> 3: <i>29.3 / 9.9 psig</i> 4: <i>29.5 / 10.8 psig</i>	Cycle ≥ 3 times at set points tolerance; 30 psig ± 3 psig 10 psig ± 3 psig	<i>ACCEPTED</i>
Describe Operation:	<i>OPERATES SMOOTH</i>	Contacts open and close with smooth operation.	<i>ACCEPTED</i>
Describe release of Spring:	<i>FREE RELEASE</i>	Free release of spring (No Binding)	<i>ACCEPTED</i>

4. Peak Pressure Test

PERSONNEL SAFETY - While performing the remainder of this test, personnel shall be behind protective panel when pressure exceeds 100 psig.

Mounting of the Pressure Switch to test jig vertically with port at bottom of switch is the same as in 3 above except that the peak pressure range indicator is used, not the set point indicator.

Increase pressure to 1800 + 5% - 0% - confirm no leakage (no bubbles) with Snoop or equivalent solution. Note: use peak pressure range indicator (0-2000+ psig).

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pressure Test:	<i>1810 psig</i> <i>NO VISIBLE LEAKS</i>	No leakage @ 1800 + 5% - 0% psig (No Bubbles)	<i>ACCEPTED</i>

5. De-energize equipment.
6. De-pressurize equipment.
7. End test.
8. Carefully disassemble test leads and pressure connection to pressure switch, replace gasket(s), re-torque any permanent connections and cover screws.

Dedication Test Plan - PS-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-009-TP-009	
Test Specimen: CCS Industrial Pressure Switch	Page 4 of 4

- 9. Clean, label w/calibration sticker, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 2/23/00 2:52 PM

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Switch has met all testing & acceptance criteria of this plan. Switch has been calibrated to requirements of para. 3 of this plan.

J. Casick
2/23/00

Notes:

Test Engineer/Technician (Printed Name) JEFF CASICK

Test Engineer/Technician (signature) J. Casick Date: 2/23/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) JMP Craig Jensen Date: 3/1/00

QA/QC (signature) T.Z. Anderson Date: 3/2/00
T.Z. ANDERSON

Belhaven

Applied Technologies

Customer Fluor Daniel Hanford PO# 2717

Certificate of Calibration

Tag BEL00-143 Model 604G3 Manufacturer CCS

Instrument Pressure Switch Serial No Marked "A"

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68F
 Accuracy of Instrument +/- 3psi
 Calibrated Range: 30 PSIG

Calibration Report No. 00-143

Date Due: 2-23-2001

Test Equipment

Ametek Pressure Indicator S/N: BAT-042
 Fluke 787 S/N: BAT-107

Calibrated by: *S. Caswell*

Certified by: *S. Caswell 2/23/00*
 Quality Assurance Manager

ORIGINAL

Tag No BEL00-143
Instrument Type Pressure Switch
Manufacturer CCS
Serial No Marked "A"
Model 604G3
Cal Due Date 2-23-2001
System
Special Instructions Calibrated to the requirements of CGI-SNF-D-MHM-009-TP-009

Units: PSIG
F.S. Accuracy +/- 3psi
F.S. Accuracy
Full Scale 30
Permitted Variation -0.9000 PSIG
Cal Temp 68F


Cal Point	As Found	As Left	% Full Scale Accuracy
30psi	29.7	29.7	-1.0000
10psi	9.9	9.9	-0.3333

Test Equipment Ametek Pressure Indicator S/N: BAT-042
Fluke 787 S/N: BAT-107

Calibration Performed By J. [Signature]


Date 2/23/00

ORIGINAL



STANDARD TEST SET-UP FOR MEASURING
RESISTANCE ACROSS CONTACTS.

STANDARD PRESSURE MANIFOLD SETUP



Page 701



Page 10

ISO 9002 Certified Company



[Home] [Up]

EXTERNAL ADJUSTMENT

WIDE RANGE
DIAPHRAGM
PISTON

PRESSURE
VACUUM

INSTALLATION DRAWING



604G & 604P
604G: 604G1, 604G2, 604G11, 604G12, 604G13, 604G15
604P: 604P12, 604P15, 604P21, 604P23, 604P31

Press. .3 to 4700 psi
Vac. 1.0 to 28.5" Hg

SERIES:
604G
604P
604V

Standard Features:

- U.L. Listed — See Note
- NEMA: 4, 13
- Weatherproof
- Internal Case Ground

AMBIENT TEMP. RANGE

-30° to 160° F
-34° to 71° C

OPERATING AND ORDERING DATA:


Table with multiple sections: PRESSURE SWITCHES MODEL 604G, PRESSURE SWITCHES MODEL 604P, and VACUUM SWITCHES MODEL 604V. Each section includes columns for Max. Sys. Press., Front Press., Adj. Set-Point Range, Approx. Dead-band, Model No., and Wt'd Parts.

ELECTRICAL CHARACTERISTICS:

Table showing Rating of Switch Element with columns for Volts and Amperes (SPDT, DPDT, etc.).

HOW TO ORDER:
1. Specify model number.
2. Specify optional feature by inserting the letter.

SCHEMATIC AND WIRING CODE



NOTE: All models shown are Underwriters' Laboratories, Inc. listed in the Recognized Component Index, Guide NKPZ "Water Controllers, Float and Pressure Operated", File No. E77028.

NOTE: Models 604CA11 & 604CX1 have an approximate dead band of .2 psi.

OPTIONAL FEATURES:
"A" = Viton O-ring

Page 102

DESIGNATION OF THE OPERATING TEMPERATURE RANGE OF THE SEAL
letter in the model number. Example: 604CF1

Material: Ethylene Propylene O-ring




-10-



Custom Control Sensors, Inc.

21111 Plummer Street, Chatsworth CA 91311 Ph: (818) 341-4610; Fax: (818) 709-0426
E-mail webmaster

604G
604P
604V



Dedication Test Plan – PS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-009-TP-009

Test Specimen: CCS Industrial Pressure Switch

Page 1 of 4

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) *Ying Swenson* Date: 1/31/00

RECOMMENDED EQUIPMENT:

Power Supply capable of 15 amps @ 125 VAC

Megger Instrument capable of 1000 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Helium supply

Pressure regulator – helium supply to 1800+ psig

Peak Pressure indicator 0-2000+ psig

Set Point Pressure indicator 0-50 psig

Test jig to mount Pressure Switch vertically with port at bottom of switch

Personnel protection panel

Snoop or equivalent

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) serial numbers and calibration due

Test Instrument type: HP3457A I.D.: BAT-123 Calib. Due date 7-29-2000Test Instrument type: HP3457A I.D.: BAT-124 Calib. Due date 7-30-00Test Instrument type: AVO BM 80/2 I.D.: 6410-881/00010 Calib. Due date 2-9-01Test Instrument type: OMETER 93CA I.D.: BAT-042 Calib. Due date 1-13-02

TRANSCAT 068 BAT-046 2-14-01

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)Test Specimen Description: Pressure Switch

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>CCS</u>	CCS Industrial	<u>ACCEPT</u>
Model:	<u>60463</u>	604G3	<u>ACCEPT</u>
Pressure Port:	<u>1/4 NAT</u>	1/4" Nominal	<u>ACCEPT</u>
Serial No.:	<u>"B" MARKED</u>	N/A	

ORIGINAL ORIGINAL

Dedication Test Plan - PS-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-009-TP-009	
Test Specimen: CCS Industrial Pressure Switch	Page 2 of 4

Perform the following tests:

Record: Date /Time of Test Beginning: 2-14-00, 4:00 P

Record: Room Temperature: 68 °F. Room Barometric Pressure: -6.1533 mmHg.

Perform steps below:

1. Contact Rating Test

Setup the Limit Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

Apply a nominal 15 amps, resistive, @ ^{VAC} 125 VAC across the normally closed contacts of the test specimen. *2/14/00 CES*

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #1 (Terminals COM-NC):	<i>.108 VAC</i>	<i>< 0.5 ± 10% Volts AC drop</i>	<i>ACCEPT</i>

Apply a nominal 15 amps, resistive, @ ^{VAC} 125 VAC across the closed normally open contacts of the test specimen. Move the actuator and close the NO contacts. *2/14/00 CES*

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #1 (Terminals COM-NC these are closed NO Contacts):	<i>.104 VAC</i>	<i>< 0.5 ± 10% Volts AC drop</i>	<i>ACCEPT</i>

2. Insulation Resistance Test

Setup the Pressure Switch specimen for insulation resistance testing:

Apply a nominal 1000 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
COM	NO	<i>45 G ohms</i>	<i>> 10 Megohms</i>	<i>ACCEPT</i>
COM	NC (Open Contact)	<i>35 G ohms</i>	<i>> 10 Megohms</i>	↓
COM or NC	Ground	<i>28 G ohms</i>	<i>> 10 Megohms</i>	
NO	Ground	<i>30 G ohms</i>	<i>> 10 Megohms</i>	

Dedication Test Plan – PS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-009-TP-009

Test Specimen: CCS Industrial Pressure Switch

Page 3 of 4

3. Mechanical Operation – Set Point Pressure Test

Mount Pressure Switch to test jig vertically with port at bottom of switch. Attach sketch of pressure switch mounting, test setup, show test instruments and source of pressure.

Cycle pressure – confirm switch contacts open and close at set points with a nominal deadband of 20 psi and with smooth operation and free release of spring. Note: use set point pressure range indicator (0-50 psig).

Description	Record Data	Acceptance Criteria	Comments/Deviations
Set Point Adjustment:	Increasing-Set @: <i>30.6 PSI</i> Decreasing-Set@: <i>10.5 PSI</i>	Increasing pressure, set switch to actuate @ 30 psig ± 3 psig. Decreasing pressure, set switch to actuate @ 10 psig ± 3 psig.	<i>NOTE: MFG SCALE HAS MINIMUM SET POINT INDICATOR @ 50 PSI.</i> <i>ACCEPTABLE</i>
Take Set Point Readings:	1: <i>28.3 & 9.7 PSI</i> 2: <i>30.2 & 12.1 PSI</i> 3: <i>30.2 & 11.6 PSI</i> 4: <i>29.9 & 11.7 PSI</i>	Cycle ≥ 3 times at set points tolerance; 30 psig ± 3 psig 10 psig ± 3 psig	<i>ACC.</i>
Describe Operation:	<i>ACCEPTABLE</i>	Contacts open and close with smooth operation.	<i>ACC.</i>
Describe release of Spring:	<i>ACCEPTABLE</i>	Free release of spring (No Binding)	<i>ACC.</i>

4. Peak Pressure Test

PERSONNEL SAFETY – While performing the remainder of this test, personnel shall be behind protective panel when pressure exceeds 100 psig.

Mounting of the Pressure Switch to test jig vertically with port at bottom of switch is the same as in 3 above except that the peak pressure range indicator is used, not the set point indicator.

Increase pressure to 1800 + 5% - 0% – confirm no leakage (no bubbles) with Snoop or equivalent solution. Note: use peak pressure range indicator (0-2000+ psig).

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pressure Test:	<i>1820 PSI NO VISIBLE LEAKS</i>	No leakage @ 1800 + 5% - 0%psig (No Bubbles)	<i>ACC.</i>

5. De-energize equipment.
6. De-pressurize equipment.
7. End test.
8. Carefully disassemble test leads and pressure connection to pressure switch, replace gasket(s), re-torque any permanent connections and cover screws.

Dedication Test Plan - PS-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-009-TP-009	
Test Specimen: CCS Industrial Pressure Switch	Page 4 of 4

- 9. Clean, label w/calibration sticker, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 2/23/00 1:37pm

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Switch is found to be acceptable to the requirements of this test plan.
Switch has been calibrated to the requirements of paragraph 3. See attached Cert of Cal.
J. Casick

Notes:

Test Engineer/Technician (Printed Name) JEFF CASICK

Test Engineer/Technician (signature) J. Casick Date: 2/23/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) JMP Wang Swenson Date: 3/1/00

QA/QC (signature) TJ Anderson Date: 3/2/00
 TJ ANDERSON

Belhaven

Applied Technologies

Customer Fluor Daniel Hanford PO# 2717

Certificate of Calibration

Tag BEL00-144 Model 604G3 Manufacturer CCS

Instrument Pressure Switch Serial No Marked "B"

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68F
 Accuracy of Instrument +/- 3psi
 Calibrated Range: 30 PSIG

Calibration Report No. 00-144

Date Due: 2-23-2001

Test Equipment

Ametek Pressure Indicator S/N: BAT-042
 Fluke 787 S/N: BAT-107

Calibrated by: *J. Cascard*

Certified by: *J. Cascard 2/23/00*
 Quality Assurance Manager

ORIGINAL

Tag No BEL00-144
Instrument Type Pressure Switch
Manufacturer CCS
Serial No Marked "B"
Model 604G3
Cal Due Date 2-23-2001
System
Special Instructions Calibrated to the requirements of CGI-SNF-D-MHM-009-TP-009


		Cal Point	As Found	As Left	% Full Scale Accuracy
Units:	PSIG	30psi	30.6	30.6	2.0000
F.S. Accuracy	+/- 3psi	10psi	10.5	10.5	1.6667
F.S. Accuracy					
Full Scale	30				
Permitted Variation	-0.9000 PSIG				
Cal Temp	68F				

Test Equipment Ametek Pressure Indicator S/N: BAT-042
Fluke 787 S/N: BAT-107


Calibration Performed By *[Signature]*

Date 2/23/00

ORIGINAL



STANDARD TEST SETUP FOR MEASURING
RESISTANCE ACROSS CONTACTS.



STANDARD PRESSURE MANIFOLD SETUP



ISO 9002 Certified Company



[Home] [Up]

EXTERNAL ADJUSTMENT

WIDE RANGE
DIAPHRAGM
PISTON

PRESSURE
VACUUM

INSTALLATION DRAWING



604G & 604P
SHIPPING WT.
4.19 (30.24 OZ)
1.00 (28.35 G)

604V
SHIPPING WT.
APPROX. 28 OZ
(792.24 G)

Press. .3 to 4700 psi
Vac. 1.0 to 28.5" Hg

SERIES:
604G
604P
604V

- Standard Features:
- U.L. Listed — See Note
 - NEMA: 4, 13
 - Weatherproof
 - Internal Case Ground

AMBIENT TEMP. RANGE
-30° to 160° F
-34° to 71° C

OPERATING AND ORDERING DATA:

PRESSURE SWITCHES MODEL 604G		1/4" ALUMINUM PRESSURE PORT AND POLYIMIDE DIAPHRAGM		Model No. and Witted Parts				
Max. Sys. Press. psi	Final (Test) Press. psi	Adj. Set-Point Range On Incr. Press. psi	On Decr. Press. psi	Approx. Dead-band psi	MODEL SPDT-Std.	MODEL DPDT "M"	MODEL Oht. Brk. "K"	Witted Parts
500	750	0-18	0-17.5	.6	604G1	604GM1	604GX1	Aluminum Polyimide Buna N
2000	4500	6-75	2-71	1	604G2	604GM2	604GX2	
3000	4900	12-150	4-142	6	604G11	604GM11	604GX11	
3000	4900	30-375	10-355	20	604G21	604GM21	604GX21	
3000	4900	300-1500	240-945	55	604G3	604GM3	604GX3	
PRESSURE SWITCHES MODEL 604P		PISTON PRESSURE SWITCH WITH 1/4" ALUMINUM PRESSURE PORT		FOR HIGH CYCLING—LONG LIFE— HYDRAULIC APPLICATIONS				
Hyd. psi	Hyd. psi	Piston switch dead bands shown are narrowest at bottom and widest at top of adjustable range.						
2000	3000	15-200	5-188	9.11	604P12	604PM12	604PX12	Aluminum 300 SS Buna N Nylon
3000	5000	150-1500	75-1350	75-150	604P15	604PM15	604PX15	
5000	7500	200-3000	100-2800	100-300	604P21	604PM21	604PX21	
7500	10,000	3000-4700	1750-4250	350-450	604P31	604PM31	604PX31	
VACUUM SWITCHES MODEL 604V		1/4" ALUMINUM PRESSURE PORT AND POLYIMIDE DIAPHRAGM		Model No. and Witted Parts				
Max. Sys. Press. psi	Final (Test) Press. psi	Adj. Set-Point Range On Incr. Vacuum In. Hg	On Decr. Vacuum In. Hg	Approx. Dead-band In. Hg	MODEL SPDT-Std.	MODEL DPDT "M"	Witted Parts	
150	280	3.5-28.5	1.0-26.0	3.5	604V1	604VM1	Aluminum Polyimide Buna N	

ELECTRICAL CHARACTERISTICS:


Rating of Switch Element

VOLTS	AMPERES			
	SPDT	DPDT "A"	DPDT "B"	DPDT "C"
120 AC-50/60 Hz	15	5	5	15
120 AC-50/60 Hz	15	5	5	15
240 AC-50/60 Hz	15	5	5	15
24 DC	5	5	5	5
125 DC	4	5	5	5

HOW TO ORDER:

1. Specify model number.
2. Specify optional feature by inserting the letter

SCHEMATIC AND WIRING CODE



NOTE:
All models shown are Underwriters' Laboratories, Inc. listed in the Recognized Component Index, Guide NRPZ "Motor Controllers, Pilot and Pressure Operated," File No. E77029.

NOTE:
Models 604GM1 & 604GM2 have an approximate dead band of .3 psi.

OPTIONAL FEATURES:

"A" = Viton O-ring

Page 713

...letter in the model number. Example: 604CF3

"F" = Ethylene Propylene O-ring




—10—



Custom Control Sensors, Inc.

21111 Plummer Street, Chatsworth CA 91311 Ph: (818) 341-4610; Fax: (818) 709-0426
E-mail webmaster

604C
604P
604V



Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) *Yump Wang Swenson* Date: 1/31/00

RECOMMENDED EQUIPMENT:

- Power Supply capable of 15 amps @ 125 VAC
- Megger Instrument capable of 1000 VDC Test Voltage
- MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
- Helium supply
- Pressure regulator – helium supply to 1800+ psig
- Peak Pressure indicator 0-2000+ psig
- Set Point Pressure indicator 0-50 psig
- Test jig to mount Pressure Switch vertically with port at bottom of switch
- Personnel protection panel
- Snoop or equivalent

ORIGINAL

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) serial numbers and calibration due

- Test Instrument type: 3457A I.D.: BAT-124 Calib. Due date 7-30-00
 - Test Instrument type: TEX-916 I.D.: BAT-052 Calib. Due date 12-18-00
 - Test Instrument type: MULTI-93CP I.D.: BAT-042 Calib. Due date 1-13-02
 - Test Instrument type: TRANSCAT I.D.: BAT-046 Calib. Due date 2-14-01
- PROCS. STA, PARO SCIENTIFIC, BAT-071, 11-12-00

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Pressure Switch

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	CCS	CCS Industrial	ACC.
Model:	604G3	604G3	ACC.
Pressure Port:	OK	1/4" Nominal	ACC.
Serial No.:	P60001111	N/A	ACC.

ORIGINAL

Perform the following tests:

Record: Date /Time of Test Beginning: 4-12-00 11:15A

Record: Room Temperature: 68 °F. Room Barometric Pressure: -8.45 mmHg.

Perform steps below:

1. Contact Rating Test

Setup the Limit Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

Apply a nominal 15 amps, resistive, ~~125~~ ^{YMP LES 5.3.00} VAC across the normally closed contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #1 (Terminals COM-NC):	0.1457VAC	< 0.5 Volts AC drop	ACC.

Apply a nominal 15 amps, resistive, ~~125~~ ^{YMP LES 5.3.00} VAC across the closed normally open contacts of the test specimen. Move the actuator and close the NO contacts.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #1 (Terminals COM-NC these are closed NO Contacts):	0.1763 VAC	< 0.5 Volts AC drop	ACC.

2. Insulation Resistance Test

Setup the Pressure Switch specimen for insulation resistance testing:

Apply a nominal 1000 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
COM	NO	70 GOhm	> 10 Megohms	ACC.
COM	NC (Open Contact)	70 GOhm	> 10 Megohms	ACC.
COM or NC	Ground	70 GOhm	> 10 Megohms	ACC.
NO	Ground	70 GOhm	> 10 Megohms	ACC.

ORIGINAL

3. Mechanical Operation - Set Point Pressure Test

Mount Pressure Switch to test jig vertically with port at bottom of switch. Attach sketch of pressure switch mounting, test setup, show test instruments and source of pressure.
 Cycle pressure - confirm switch contacts open and close at set points with a nominal deadband of 20 psi and with smooth operation and free release of spring. Note: use set point pressure range indicator (0-50 psig).

Description	Record Data	Acceptance Criteria	Comments/Deviations
Set Point Adjustment:	Increasing-Set @ 32.7652 PSI Decreasing-Set @ 31.2652 PSI New Set: 8.0440 PSI	Increasing pressure, set switch to actuate @ 30 psig ±3 psig. Decreasing pressure, set switch to actuate @ 10 psig ±3 psig.	NO FOUND SET: 33.265 BOOK @ 15.585
Take Set Point Readings:	1: 32.7652 / 10.9665 2: 32.8751 / 9.7655 3: 32.6987 / 8.6865 4: 32.7741 / 6.3858 SEE COMMENTS / NOTES	Cycle ≥ 3 times at set points tolerance: 30 psig ±3 psig 10 psig ±3 psig	2X TEST 34 OUT OF TOL. 1: 31.2652 / 8.0440 2: 31.0745 / 7.318 3: 31.1541 / 8.3160 4: 30.6771 / 7.9471
Describe Operation:	YES	Contacts open and close with smooth operation.	PCC.
Describe release of Spring:	YES	Free release of spring (No Binding)	PCC.

4. Peak Pressure Test

PERSONNEL SAFETY - While performing the remainder of this test, personnel shall be behind protective panel when pressure exceeds 100 psig.

Mounting of the Pressure Switch to test jig vertically with port at bottom of switch is the same as in 3 above except that the peak pressure range indicator is used, not the set point indicator.
 Increase pressure to 1800 + 5% - 0% - confirm no leakage (no bubbles) with Snoop or equivalent solution. Note: use peak pressure range indicator (0-2000+ psig).

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pressure Test:	1840 PSI	No leakage @ 1800 + 5% - 0%psig (No Bubbles)	NO. VISIBLG LEAKS

5. De-energize equipment.
6. De-pressurize equipment.
7. End test.
8. Carefully disassemble test leads and pressure connection to pressure switch, replace gasket(s), re-torque any permanent connections and cover screws.

ORIGINAL

- 9. Clean, label w/calibration sticker, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 4/17/00, 3:54 P

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

COMPONENT MEETS REQUIREMENTS OF THIS TEST PLAN
AND IS SET TO THE REQUIRED VALUES.

Notes:

SECT *3: DURING FINAL RUN AFTER FIRST SETTING, THE
FINAL TEST (*4) WAS FOUND OUT OF TOLERANCE. A NEW
SETPOINT WAS SET AND A SECOND RUN OF 4 TEST WAS
CONDUCTED AND FOUND TO BE ACCEPTABLE.

Test Engineer/Technician (Printed Name) JEFF CADICK

Test Engineer/Technician (signature) J. Cadick Date: 4-12-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 5-3-00

QA/QC (signature) [Signature] Date: 5-3-2000

ORIGINAL

Page 10

ISO 9002 Certified Company



[Home] [Up]

EXTERNAL ADJUSTMENT

WIDE RANGE
DIAPHRAGM
PISTON

PRESSURE
VACUUM

INSTALLATION DRAWING



Model 604G
Model 604P
Model 604V

Press. .3 to 4700 psi
Vac. 1.0 to 28.5" Hg

SERIES:
604G
604P
604V

Standard Features:

- U.L. Listed — See Note
- NEMA: 4, 13
- Weatherproof
- Internal Case Ground

AMBIENT TEMP. RANGE

-30° to 160° F
-34° to 71° C

OPERATING AND ORDERING DATA:

PRESSURE SWITCHES MODEL 604G					1/4" ALUMINUM PRESSURE PORT AND POLYIMIDE DIAPHRAGM			
Max. Sys. Press. psi	Proof (Test) Press. psi	Adj. Set-Point Range		Approx. Dead-band psi	Model No. and Wt'd Parts			
		On Incr. Press. psi	On Decr. Press. psi		MODEL SPDT-S1J	MODEL DPDT "M"	MODEL Dbl. Brk. "X"	Wt'd Parts
500	750	0-15	0-17.5	.5	604G1	604GM1	604X1	Aluminum Polyimide Buna N
3000	4500	6-15	2-71	.4	604G2	604GM2	604X2	
3000	4500	12-150	2-142	.5	604G11	604GM11	604X11	
1500	4500	30-375	10-335	.30	604G3	604GM3	604X3	
3000	4500	300-1500	245-945	.55	604G5	604GM5	604X5	
PRESSURE SWITCHES MODEL 604P					PISTON PRESSURE SWITCH WITH 1/4" ALUMINUM PRESSURE PORT			
Hyd. psi	Hyd. psi	Piston switch dead bands shown are narrowest at bottom and widest at top of adjustable range			FOR HIGH CYCLING—LONG LIFE—HYDRAULIC APPLICATIONS			
2000	3000	15-200	5-189	9-11	604P12	604PM12	604PX12	Aluminum 300 SS Buna N Nylon
3000	5000	150-1500	75-1350	75-150	604P15	604PM15	604PX15	
3000	7500	200-3000	100-2800	100-200	604P21	604PM21	604PX21	
7500	10,000	2000-4700	1750-4150	350-450	604P31	604PM31	604PX31	
VACUUM SWITCHES MODEL 604V					1/4" ALUMINUM PRESSURE PORT AND POLYIMIDE DIAPHRAGM			
Max. Sys. Press. psi	Proof (Test) Press. psi	Adj. Set-Point Range		Approx. Dead-band in. Hg	Model No. and Wt'd Parts			
		On Incr. Vacuum in. Hg	On Decr. Vacuum in. Hg		MODEL SPDT-S1J	MODEL DPDT "M"	Wt'd Parts	
150	250	1.5-28.5	1.0-26.0	.25	604V1	604VM1	Aluminum Polyimide Buna N	


ELECTRICAL CHARACTERISTICS:
Rating of Switch Element

VOLTS	AMPERES		
	SPDT	DPDT "M"	Dbl Brk "X"
125 AC-50-60 Hz	15	5	15
150 AC-50-60 Hz	15	5	15
480 AC-50/60 Hz	12	—	—
28 DC	6	3	6
175 DC	4	3	1

HOW TO ORDER:

1. Specify model number.
2. Specify optional features by inserting the letter

SCHEMATIC AND WIRING CODE



OPTIONAL FEATURES:

"A" = Viton O-ring

NOTE:

All models shown are Underwriters' Laboratories, Inc. listed in the Recognized Components Index, Guide NKPZ "Motor Controllers, Float and Pressure Operated" File No. E72038.

NOTE:

Models 604GM1 & 604X1 have an approximate dead band of .9 psi.

Designation of the O-ring material must be indicated by a letter in the model number. Example: 63NF3

"F" = Ethylene Propylene O-ring

—10—



Custom Control Sensors, Inc.


21111 Plummer Street, Chatsworth CA 91311 Ph: (818) 341-4610; Fax: (818) 709-0426

E-mail webmaster



Page 720

SNF-6315, Rev. 0

604G
604P
604V



CONDUIT CONNECTION
3/4-14 NPT WITH
TERMINAL STRIP



Belhaven

Applied Technologies

Customer Fluor Daniel PO# 2717-3

Certificate of Calibration

Tag PSLTSC1AX Model 6043G Manufacturer CCS

Instrument Pressure Switch Serial No PSLTSC1AX

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68F
Accuracy of Instrument +/- 3 psi
Calibrated Range: 31.2654 PSI

Calibration Report No. 00-209

Date Due: 4-12-2001

Test Equipment

Paroscientific Pressure Standard S/N 224

Calibrated by: *J. Cadwell* / 4-12-00Certified by: *[Signature]*
Quality Assurance Manager**ORIGINAL**

Tag No PSLTSC1AX

Instrument Type Pressure Switch

Manufacturer CCS

Serial No PSLTSC1AX

Model 6043G

Cal Due Date 4-12-2001

System

Special Instructions Set to the requirements of Test Plan CGI-SNF-D-MHM-009
As Found set point was set at 33.3957 psi and decrease psi @
15.585. Reset at below values.

	Cal Point	As Found	As Left	% Full Scale Accuracy
Units: PSI	30	31.2654	31.2654	4.0473
F.S. Accuracy +/- 3 psi	10	8.0440	8.0440	-6.2561
F.S. Accuracy				
Full Scale 31.2654				
Permitted Variation -0.9380 PSI				
Cal Temp 68F				

Test Equipment Paroscientific Pressure Standard S/N 224

Calibration Performed By L. Carver

Date 4-12-00

ORIGINAL

**THIS PAGE INTENTIONALLY
LEFT BLANK**

De-lication Test Plan – PS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-009-TP-009

Test Specimen: CCS Industrial Pressure Switch

Page 1 of 4

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) Wang Swenson Date: 4-11-00

RECOMMENDED EQUIPMENT:

Power Supply capable of 15 amps @ 125 VAC

Megger Instrument capable of 1000 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Helium supply

Pressure regulator – helium supply to 1800+ psig

Peak Pressure indicator 0-2000+ psig

Set Point Pressure indicator 0-50 psig

Test jig to mount Pressure Switch vertically with port at bottom of switch

Personnel protection panel

Snoop or equivalent

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) serial numbers and calibration due

Test Instrument type: 3457A HP I.D.: BAT-124 Calib. Due date 7-30-00Test Instrument type: TEK 916 I.D.: BAT-052 Calib. Due date 12-18-00Test Instrument type: BAT-TANDEM I.D.: BAT-046 Calib. Due date 2-14-01Test Instrument type: PAROSCOPE
PAGE 5TD I.D.: BAT-071 Calib. Due date 11-12-00

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Pressure Switch

Record the following Identification Information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	<u>CCS</u>	<u>CCS Industrial</u>	<u>ACC.</u>
Model:	<u>60463</u>	<u>604G3</u>	<u>ACC</u>
Pressure Port:	<u>1/4</u>	<u>1/4" Nominal</u>	<u>ACC</u>
Serial No.:	<u>PSLTSC2AX</u>	<u>N/A</u>	<u>ACC.</u>

ORIGINAL

Dedication Test Plan – PS-1
 Test Plan No.: CGI-SNF-D-MHM-009-TP-009
 Test Specimen: CCS Industrial Pressure Switch

Rev. No. 0

Page 2 of 4

Perform the following tests:

Record: Date /Time of Test Beginning: 4-13-00, 11:40 A

Record: Room Temperature: 68 °F. Room Barometric Pressure: -8.8739 mmHg.

Perform steps below:

1. Contact Rating Test

Setup the Limit Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

Apply a nominal 15 amps, resistive, 125 VAC across the normally closed contacts of the test specimen. *CCS 4/27/00*

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #1 (Terminals COM-NC):	<u>.1017 VAC</u>	< 0.5 Volts AC drop	<u>ACC</u>

Apply a nominal 15 amps, resistive, 125 VAC across the closed normally open contacts of the test specimen. Move the actuator and close the NO contacts. *CCS 4/27/00*

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Contact Circuit #1 (Terminals COM-NC these are closed NO Contacts):	<u>.1098 VAC</u>	< 0.5 Volts AC drop	<u>ACC.</u>

2. Insulation Resistance Test

Setup the Pressure Switch specimen for insulation resistance testing:

Apply a nominal 1000 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
COM	NO	<u>306ohm</u>	> 10 Megohms	<u>ACC.</u>
COM	NC (Open Contact)	<u>356ohm</u>	> 10 Megohms	<u>ACC.</u>
COM or NC	Ground	<u>406ohm</u>	> 10 Megohms	<u>ACC.</u>
NO	Ground	<u>506ohm</u>	> 10 Megohms	<u>ACC.</u>

Dedication Test Plan – PS-1
 Test Plan No.: CGI-SNF-D-MHM-009-TP-009
 Test Specimen: CCS Industrial Pressure Switch

Rev. No. 0

Page 3 of 4

3. Mechanical Operation – Set Point Pressure Test

Mount Pressure Switch to test jig vertically with port at bottom of switch. Attach sketch of pressure switch mounting, test setup, show test instruments and source of pressure.

Cycle pressure – confirm switch contacts open and close at set points with a nominal deadband of 20 psi and with smooth operation and free release of spring. Note: use set point pressure range indicator (0-50 psig).

Description	Record Data	Acceptance Criteria	Comments/Deviations
Set Point Adjustment:	Increasing-Set @: 29.7255 PSI Decreasing-Set@: 8.0425 PSI	Increasing pressure, set switch to actuate @ 30 psig ±3 psig. Decreasing pressure, set switch to actuate @ 10 psig ± 3 psig.	AS-Run: 32.8775 11.4672
Take Set Point Readings:	1: 29.6349 / 8.0425 2: 29.7223 / 7.8603 3: 29.6970 / 7.5763 4: 29.2977 / 8.3758 29.5415 / 7.8867	Cycle ≥ 3 times at set points tolerance; 30 psig ±3 psig 10 psig ± 3 psig	ACC. SEE NOTE:
Describe Operation:	YES	Contacts open and close with smooth operation.	ACC.
Describe release of Spring:	YES	Free release of spring (No Binding)	ACC

4. Peak Pressure Test

PERSONNEL SAFETY – While performing the remainder of this test, personnel shall be behind protective panel when pressure exceeds 100 psig.

Mounting of the Pressure Switch to test jig vertically with port at bottom of switch is the same as in 3 above except that the peak pressure range indicator is used, not the set point indicator.

Increase pressure to 1800 + 5% - 0% – confirm no leakage (no bubbles) with Snoop or equivalent solution. Note: use peak pressure range indicator (0-2000+ psig).

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pressure Test:	1865 PSI	No leakage @ 1800 + 5% - 0%psig (No Bubbles)	NO VISIBLE LEAKS

5. De-energize equipment.
6. De-pressurize equipment.
7. End test.
8. Carefully disassemble test leads and pressure connection to pressure switch, replace gasket(s), re-torque any permanent connections and cover screws.

Dedication Test Plan - PS-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-009-TP-009	
Test Specimen: CCS Industrial Pressure Switch	Page 4 of 4

- 9. Clean, label w/calibration sticker, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 4-13-01, 9:05 A

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

pressure switch meets requirement of this test plan after several readjustment.
J. Casick

Notes:

Linearity of Switch 10 PSI to 30 PSI is not consistent. Switch setting is below 20 PSI. Scale setting of 50 PSI.

Test Engineer/Technician (Printed Name) JEFF CASICK

Test Engineer/Technician (signature) J. Casick Date: 4-13-01

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Henry Swenson Date: 4-27-00

QA/QC (signature) Stephen Scott Moore Date: 4-27-2000

Belhaven

Applied Technologies

Customer Fluor Daniel PO# 2717-3

Certificate of Calibration

Tag PSLTSC2AX Model 6043G Manufacturer CCS

Instrument Pressure Switch Serial No PSLTSC2AX

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68F
 Accuracy of Instrument +/- 3 psi
 Calibrated Range: 30.00 PSI

Calibration Report No. 00-213

Date Due: 4-12-2001

Test Equipment

Paroscientific Pressure Standard S/N 224

Calibrated by: *J. Cadwell* 4-13-00

Certified by: *Paul J. Frazier* 4-13-00
 Quality Assurance Manager

ORIGINAL

Belhaven

Calibration Data Sheet

Report Number
00-213

SNF-6315, Rev. 0

Tag No PSLTSC2AX
Instrument Type Pressure Switch
Manufacturer CCS
Serial No PSLTSC2AX
Model 6043G
Cal Due Date 4-12-2001
System
Special Instructions Set to the requirements of Test Plan CGI-SNF-D-MHM-009
 As Found set point was set at 32.8775 psi and decrease psi @
 11.4672. Reset at below values.

		Cal Point	As Found	As Left	% Full Scale Accuracy
Units:	PSI	30	29.7255	29.7255	-0.9150
F.S. Accuracy	+/- 3 psi				0.0000
F.S. Accuracy		10	8.0245	8.0245	-6.5850
Full Scale	30.00				
Permitted Variation	-0.9000 PSI				
Cal Temp	68F				

Test Equipment Paroscientific Pressure Standard S/N 224

Calibration Performed By *L. [Signature]*

Date 4-13-00

ORIGINAL

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 1 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-007
Title: P2, P21, P80 - Microswitch / Honeywell Yamatake Limit Switch SL1

SNF-6315, Rev. 0

Section 1 Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
Part Description: <u>N/A</u>	<h1>ORIGINAL</h1>	
End Use Description: <u>N/A</u>		

Section 2a Component Information

Equipment No.: <u>LFPGCX, LFPGCY, LFPGOX, LFPGOY, LFPGLX, LFPGLY, LFTSLP1AX, LFTSLP1AY, LFTSLP2AX, LFTSLP2AY</u>	Specification No.: <u>Ederer F-2566, Foster Wheeler MJX-SDX 452656</u>	Manufacturer: <u>MicroSwitch Honeywell- Yamatake</u>	Past P.O. No.: <u>N/A</u>
---	---	---	------------------------------

Manufacturer's Part/Model No.: <u>SL 1 YIP LES M100</u>	Equipment Supplier (if different from manufacturer): <u>ALSTOM, Foster Wheeler</u>	Equip. Supplier's Part No.: <u>N/A</u>
---	---	---

Component Description: **Limit switches LFPGCX and LFPGCY for interlock P-2 measure grapple jaws not fully closed and Limit switches; LFPGOX & LFP GOY for Interlock P-2 & 80 measure grapple jaws fully open. LFPGLX and LFPGLY for Interlock P-2 measure grapple jaws not locked, inhibits shield skirt motor operation and bridge and trolley travel. LFTSLP1AX, LFTSLP1AY, LFTSLP2AX & LFTSLP2AY for interlock P21 measure trolley restraint pins North and South fully inserted.**

Section 2b Commercial Availability of the Item

- 1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
 YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
 If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate with project CGI Interface Engineer or BTR)
 YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)
- 2. List of Candidate qualified NQA1 suppliers or ISO 9000 suppliers, if used: N/A
- 3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)

All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

Page 7.31

SNF-6315, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-007
 Title: P2, P21, P80 - Microswitch / Honeywell Yamatake Limit Switch SL1

Rev. No. 3
 Page 2 of 8

Section 2d Reason for Dedication	
The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):	
<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input checked="" type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
Other ('like-for-like', similar, substitution, replacement evaluation)	

Section 3 Failure Effects Evaluation	
A. Part/Component Safety Function:	
1. Interlock P-2 prevents the MHM from leaving a storage tube without replacing the tube plug, to provide radiation protection and shielding for facility workers. P21 inhibits the Shield Jack lowering and Turret rotating and the Turret Locking Pin disengaging and the Base Locking Pin disengaging and Tube Plug Hoist operating and MCO Hoist operating unless the Crane Bridge Seismic clamps are fully applied AND the Trolley Restraint Pins are fully inserted.	
B. Part/Component Functional Mode:	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function
Safety Function #1: <input checked="" type="checkbox"/> Active <input type="checkbox"/> Passive	Passive - Change of state is not required for the component to perform its safety function
Safety Function #2: <input type="checkbox"/> Active <input type="checkbox"/> Passive	
Safety Function #3: <input type="checkbox"/> Active <input type="checkbox"/> Passive	
C. Host Component Safety Function (if applicable): <u>N/A</u>	
1.	
D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):	
1. Failure of switch contacts to open upon demand results in potential override of interlock channel.	
2. Actuator plunger/arm inoperative results in failure to provide interlock function at correct demand position.	

Section 4 Environmental & Natural Phenomena Hazard Design	
Environmental Qualification Required:	If yes: Environmental Qualification Requirements
Yes <input type="checkbox"/>	Limiting Environmental Conditions:
No <input checked="" type="checkbox"/>	Required Safety Functions:
	Qualification Period:
Natural Phenomena Hazard (NPH) Design Required:	If yes: NPH Design Requirements
Yes <input type="checkbox"/>	Performance Category:
No <input checked="" type="checkbox"/>	NPH Design Req'ts.:
	Required Safety Functions:

Section 5 Component Functional Classification		
<input checked="" type="checkbox"/> Safety Class (SC)	<input type="checkbox"/> General Service (GS)	<input type="checkbox"/> Safety Significant (SS)
If part/component classification is different from host component/system, document basis. <u>N/A</u>		

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)
National Codes/Standards: <u>N/A</u>
Safety Analysis Report (SAR): <u>HNF-3672, Rev. 0</u>
Drawings: <u>Ederer, Inc. EB-33056, Sht 17/17A, 37; Hanford H-2-827174, Sheets 2, 4, 9, 10, 14, 15, 19 & 23</u>
Vendor Manual/Manufacturer/Supplier Information: <u>Honeywell Series TS compact limit switches</u>
Other: <u>ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998</u>

ENCLOSURE
JUP LES 9/1/00

Page 732

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A

CGI No. CGI-SNF-D-MHM-007

Page 3 of 8

Title: **P2, P21, P80 – Microswitch / Honeywell Yamatake Limit Switch SL1**

SNF-6315, Rev. 0

Section 9 Critical Characteristics

Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	MicroSwitch / Honeywell-Yamatake	1, IN	X	
Model Number	SL1	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Actuator (Note 1)	Plunger	1, IN	X	
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Contact rating	Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts.	1, T		X
Insulation Resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 500vdc.	1, T		X
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring.	1, T		X

4. Notes and Legend:

Rev. 1: Page 2: Revised Sheet No.; Page 7: Added date to "Method R/IN" header; General: new forms.

Rev. 2: Pages 3, 5, 7: added Note 1

Note 1: This actuator is installed with the limit switch - replacement limit switches will not include an actuator - the existing actuator will be placed on the replacement switch. Therefore, the physical CC specified for the actuator lever need not be performed on the replacement limit switch.

Rev. 3: All Pages: Rev'd to include interlocks P2, P21 & P80 and include all SL1 Limit Switches into this CGI (CGI-008 now included in CGI-007). Rev'd Equipment ID Nos. to include CGI-008 ID's. Added Note 2. Pages 3, 5, 7, Rev'd Contact rating to "Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts." Test voltage varies with the load.

Note 2: The differences between the SL1-E & SL1-H are actuator only and vary the length of the plunger. All other physical and electrical characteristics are the same. Model(s) SL1-E was In-Situ Tested and SL1-E & -H were bench tested satisfactorily.

Acceptance Method (Acc Meth):

1. Special Test and Inspection:

1, IN for Inspection

1, T for Test

2. Commercial Grade Survey

3. Source Verification

4. Vendor/Item History

Approvals:

Designated Engineer: [Signature] 4/6/00

Design Authority: [Signature] 4/6/00

QA Engineer: [Signature] 4-6-2000

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 4 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-007
Title: P2, P21, P80 – Microswitch / Honeywell Yamatake Limit Switch SL1

SNF-6315, Rev. 0

WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	X	Switch contacts corrode closed and fail to open upon demand.
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Switch contacts fuse closed and fail to open upon demand.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Switch mechanism jams and contacts fail to open upon demand.
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		

Section 2: Additional Failure Modes Applicable to the Component Under Evaluation

- Switch contacts are closed to permit equipment movement. Contacts open for the interlock function. Any failure to open inhibits the particular switch interlock function.
- Actuator plunger/arm seizure or break renders the contact opening inoperable.
- Short circuit could give false signal to energize interlock function.

Commercial Grade Item Upgrade Dedication Form

ECN No. N/A	CGI No. CGI-SNF-D-MHM-007	Rev. No. 3 /
Title: P2, P21, P80 - Microswitch / Honeywell Yamatake Limit Switch SL1		Page 5 of 8

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1	
Item Description: P2, P21 & P80 interlock limit switches System #: MHM	Equip #: LFPGCX, LFPGCY, LFPGOX, LFPGOY, LFPGLX, LFPGLY, LFTSLP1AX, LFTSLP1AY, LFTSLP2AX, LFTSLP2AY Model #: SL1
Manufacturer (Address/Phone): MicroSwitch/Honeywell-Yamatake Honeywell Sensing and Control Freeport, Ill 1-800-537-6945	Supplier (Address/Phone): N/A

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Model Number
X			3. Actuator (Note 1)
	X		4. Contact Rating
	X		5. Insulation Resistance
	X		6. Mechanical Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size: References (See Section 7)

Characteristic: Manufacturer	Sample Size*: 100%
Acceptance Criteria: MicroSwitch / Honeywell-Yamatake	
Receipt Inspection Plan / Report #: CGI-SNF-D-MHM-007-TP-007C,D,E,F,J	
Characteristic: Model Number	Sample Size*: 100%
Acceptance Criteria: SL1	
Receipt Inspection Plan / Report #: TP-007C,D,E,F,J	
Characteristic: Actuator (Note 1)	Sample Size*: 100%
Acceptance Criteria: Plunger	
Receipt Inspection Plan / Report #: TP-007C,D,E,F,J	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 6 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-007
 Title: P2, P21, P80 - Microswitch / Honeywell Yamatake Limit Switch SL1

SNF-6315, Rev. 0

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)	
Characteristic for Test: Contact Rating Acceptance Criteria: Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts. Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-007C,D,E,F</u>
Characteristic for Test: Insulation Resistance Acceptance Criteria: Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 500 vdc. Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-007C,D,E,F</u>
Characteristic for Test: Mechanical Operation Acceptance Criteria: Cycle switch - confirm contacts open and close with smooth operation and free release of spring Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-007C,D,E,F</u>

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A

CGI No. CGI-SNF-D-MHM-007

Page 7 of 8

Title: P2, P21, P80 - Microswitch / Honeywell Yamatake Limit Switch SL1

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Limit Switch

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	MicroSwitch / Honeywell-Yamatake	X		1, IN	TP007 C,DEFJ	NA	7	0	XWEST	Larry W. Price <i>[Signature]</i>	4/10/00
Model Number	SL1	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Actuator (Note 1)	Plunger	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Contact Rating	Nominal 5 amps VAC, resistive, less than 0.5V drop across contacts.		X	1, T	TP007 C,DE,F	NA	4	0	↓	↓	↓
Insulation Resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 500 vdc.		X	1, T	↓	↓	↓	↓	↓	↓	↓
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-007C, D, E, F, J cited above. CES 9/11/00

Testing Agency Approval: <u>NR CES 4/11/00</u> Date <u>4/11/00</u>	Design Authority: <u>CES Gary Anderson</u> Date <u>4-11-00</u>
Testing Agency QA Engineer: <u>NR CES 4/11/00</u> Date _____	QA Engineer: <u>Stephen Scott Mohr</u> Date <u>4-20-2000</u>

SNF-6315, Rev. 0

Page 7310

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 8 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-007
Title: P2, P21, P80 - Microswitch / Honeywell Yamatake Limit Switch SL1

SNF-6315, Rev. 0

Section 6 Contacts/Phone Numbers

Name	Phone
Design Authority	()
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents		For Critical Characteristics
<input type="checkbox"/>	Drawings:	
<input type="checkbox"/>	Manuals (specify type & number):	
<input type="checkbox"/>	Design Calculations	
<input type="checkbox"/>	Installation Instructions	
<input type="checkbox"/>	Operation Instructions	
<input type="checkbox"/>	Calibration Instructions	
<input type="checkbox"/>	Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/>	Other: Honeywell Series LS Compact Limit Switches	All
Procurement Documents		For Critical Characteristics
<input type="checkbox"/>	Certificate of Conformance/Compliance	
<input type="checkbox"/>	Seismic Qualification Certificate	
<input type="checkbox"/>	Environmental Qualification Certificate	
<input checked="" type="checkbox"/>	Test Report (s): CSB(W379)-015-1-074	
<input type="checkbox"/>	Inspection Report (s):	
<input type="checkbox"/>	CMTRs for ASME Pressure Retaining Materials	
<input type="checkbox"/>	Valve Seat Leakage Report	
<input type="checkbox"/>	Weld Records	
<input type="checkbox"/>	Material Traceability Record	
<input checked="" type="checkbox"/>	Other: SU Test SNF-CTP-IC-07	

ENCLOSED ywf 4/10/00

Dedication Test Plan – IST-LS-2 Test Plan No.: CGI-SNF-D-MHM-007-TP-007C Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AX	<h1 style="margin: 0;">ORIGINAL</h1>	Rev. No. 0 Page 1 of 7
--	--------------------------------------	-------------------------------

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
						<div style="text-align: right;"> 3/12/00 NO CHANGES </div>

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007C

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AX

Page 2 of 7

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) Sup Wang Swenson Date: 3/8/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	Michael Cram	MC
Electrician	JW EBERHART	PCE	JW Eberhart	JWE
Electrician Quality Control	Stephen R Conley	PCE	Stephen R Conley	SR
Design Authority Representative	E. R. Keller	XWest	E R Keller	ERK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 5 amps @ 120 VAC

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-30-00

Test Instrument type: AVO BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007C

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AX

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.

2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	LFTSLP1AX	Acc
Manufacturer:	YES	Honeywell	Acc
Model:	YES	SL1	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 03-10-00 8:30 a.m.

Record: Room Temperature: 68 °F.

3.2 Mechanical Operation

Note: If switch cannot be stroked/cycled due to operational or physical restraints - make note in the note section of this procedure and proceed to the next step.

3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	6	> 5 times	Acc
Describe Operation:	YES	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	YES	Free release of spring.	Acc

Dedication Test Plan – IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007C

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AX

Page 4 of 7

3.3 Insulation Resistance Test

- 3.3.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing.
- 3.3.2 Apply a nominal 500 VDC via Megger device between non-continuity terminals Common and Normally Open and then between terminal Normally Open and ground. Record the resistances.
- 3.3.3 Remove the Megger device.
- 3.3.4 Manually adjust the limit switch actuator to open the normally closed (NC) contacts.
- 3.3.5 Apply a nominal 500 VDC via Megger device between non-continuity terminals Common and open-Normally Closed and then between terminal Normally Closed and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
Common	NO	> 6.1 Gohm	> 10 Megohms	Acc
NO	Ground	> 15 Gohm	> 10 Megohms	Acc
Common	open NC*	> 6.3 Gohm	> 10 Megohms	Acc
Open NC	Ground*	> 16 Gohm	> 10 Megohms	Acc

* Normally closed contacts are open.

- 3.3.6 De-energize and remove the test equipment.

3.4 Contact Rating Test

- 3.4.1 Setup the test equipment and Limit Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.
- 3.4.2 At limit switch, lift leads on Common terminal, Normally Closed terminal and Normally Open terminal. Record on the lifted lead log.
- 3.4.3 Connect the power supply to terminals Common and Normally Closed.
- 3.4.4 Apply a nominal 5 amps VAC, resistive, across the normally closed contacts of the test specimen.

Caution: Do not change state of contacts while energized.

- 3.4.5 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- NC)	• 366 VAC	< 0.5 Volts AC drop	Acc

Dedication Test Plan – IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007C

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AX

Page 5 of 7

3.4.6 Reduce the current source to zero amps.

3.4.7 Disconnect the power supply from terminals Common and Normally Closed.

3.4.8 Manually adjust the limit switch actuator to close the normally open contacts.

Note: If switch cannot be adjusted to close the NO contacts due to operational or physical restraints - make note in the note section of this procedure and proceed to step 3.5.

3.4.9 Connect the power supply to terminals Common and Normally Open.

3.4.10 Apply a nominal 5 amps, resistive, across the closed normally open contacts of the test specimen.

3.4.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- Closed NO Contact):	.351 VAC	< 0.5 Volts AC drop	Acc

3.4.12 Reduce the current source to zero amps and remove the power supply from terminals Common and Normally Open.

3.4.13 Manually adjust the limit switch actuator to close the normally closed contacts.

3.5 Terminate the test.

3.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

3.5.2 Retorque the terminals to 12 in-pounds.

3.5.3 Remove lockout/tagout and restore system to normal.

3.5.4 Record: Date /Time of Test End: 03-10-00 8:58 am

4.0 References

4.1 Elementary Wiring Drawings: EB-33056 Sheet 37

4.2 Wiring Diagram: 363A0033 Sheet 16

Dedication Test Plan - IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007C

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AX

Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

test was acceptable

Michael Cram

03-10-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-10-00
Reviewed By: J. Cadwell 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/10/00} [Signature] Date: 3/10/00

QA/QC (signature) [Signature] Date: 3/13/00
T. ANDERSON

LIFTED LEAD LOG

Junction Box: Local

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	16	101X	LFTSLP1AX	C	JWE	3/10/00	SRL	3-10-00	JWE	3/10/00	SRL	3-10-00
363A0033	16	3711X	LFTSLP1AX	NC	JWE	3/10/00	SRL	3-10-00	JWE	3/10/00	SRL	3-10-00
363A0033	16	3707X	LFTSLP1AX	NO	JWE	3/10/00	SRL	3-10-00	JWE	3/10/00	SRL	3-10-00

Remarks:

SNF-6315, Rev. 0

Page 744

Page 745

Micro Switch
Phone #1-800-537-6945
Fax #1-815-235-6545

SPECIFICATIONS

EXTERNAL VIEW SL1-E

11 DIA x 4 WIDE
SINTERED STAINLESS ROLLER

REFER TO NOTE 2

M14x1
2-M14x1
HEX NUT
2.5 THICKNESS
17 ACROSS FLATS
REFER TO NOTE 5

3-M3x5
TERMINAL SCREW
REFER TO NOTE 5


CONDUIT HOLE
φ9.7±0.15

NOTES

- 1 SWITCH ENCLOSURE IS OF ZINC ALLOY COATED WITH BLACK FLUOROPLASTICS
TERMINAL COVER IS PLASTIC.
2. SET FULL OVERTRAVEL POSITION SO THAT TOP OF BUSHING BE WITHIN RANGE OF
ROLLER PLUNGER GROOVES SHOWN WITH CROSS HATCHING.
3. SEAL IS ALREADY ASSEMBLED FOR A CABLE OF 5.8 TO 7.8 DIA.
SEAL IS ATTACHED FOR A CABLE OF 7.9 TO 9.6 DIA.
4. MOUNT COMPLETELY THE TERMINAL COVER AFTER WIRING. TO KEEP THE SEALING
OF TERMINAL HOUSING. TIGHTEN FULLY THE KNURLED CAPNUT BY HAND WITHOUT
USING A TOOL.
5. TERMINAL COVER, TERMINAL SCREWS AND HEX NUTS ARE FURNISHED
UNASSEMBLED.

CHARACTERISTICS			
OPERATING FORCE	11.8N	MAX	▲
RELEASE FORCE	4.9N	MIN	▲
MOVEMENT DIFFERENTIAL	0.1	MAX	
OVERTRAVEL	3	MIN	

尺規 TATSUURA 2.2.91	形番 MODEL SL1-*****	尺規 SCALE 1:1	記入の寸法の公差 TOL. UNLESS NOTED ±0.4
尺規 APPROV TAKAMOTO 2.2.91	名番 NAME MINIATURE LIMIT SWITCH		
尺規 REV 06	尺規 RECORD SI (MKS) - SI	尺規 DATE 8,30,99	尺規 BY TATSUURA TOMITA
尺規 NO. AD51236E	尺規 NO. 06	尺規 REV 8/17	




HANFORD DWG # H-2-828710 SHT 62 OF 97

NO.	DESCRIPTION	DATE	BY	CHK	ENG	APPO	APPO	CHK	J B SUPP	INSTR
A	GENERAL REVISIONS	7/29/97	JRR	JMH	TML	JRH	APPO	LLA	J W WOODS	11/91
B	DELETE UN-NEEDED L.S.	8/29/97	JRS	JMH	TML	JRH	LLA	J W WOODS	1/92	1/92
C	DESIGN MODIFICATION	9/15/97	JRS	JMH	TML	JRH	LLA	J W WOODS	1/92	1/92
D	ADD WIRE L'S	10/3/97	JRS	JMH	TML	JRH	LLA	J W WOODS	1/92	1/92
E	RE-INSERTING & SIMPLIFICATION	3/4/98	CSB	SKO	CSH					
F	ADD NORTH AND SOUTH REFERENCES	7/20/98	CSB	SKO	CSH					

COVER
 INCORPORATED
 ELECTRICAL ENGINEERING
 TROLLEY SEISMIC RESTRAINT PINS CONTROL ELEMENTARY
 SCALE: N/A
 1/2" = 1'-0"
 37
 EB-33056

FOR WIRE SIZE SEE 1



CONTROLLED COPY
MCC #15

14114 - F216 - 006
12.10.198

U.S. DEPARTMENT OF ENERGY
WESTINGHOUSE HAMFORD COMPANY
MOM-503-452858
WHC-5-0488

H-2-827169

GEC ALSTROM ENGINEERING SYSTEMS LTD
Industrial Estate, LES Bains

363A0033

16

MARKET LOCATING INFORMATION - JAMBOY SHEET 8

FOR DRAWING IS ONLY AN APPROXIMATE POSITION OF EQUIPMENT

Dedication Test Plan – IST-LS-2 Test Plan No.: CGI-SNF-D-MHM-007-TP-007D Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AY	<b style="font-size: 2em;">ORIGINAL Rev. No. 0 Page 1 of 6
--	--

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
						<i>AD</i> <i>2/1/00</i> NO CHANGES

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST-LS-2	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-007-TP-007D	
Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AY	Page 2 of 6

In-Situ Test Procedure

ORIGINAL

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *YUP Liang Jensen* Date: 3/8/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	MRE	<i>Michael Cram</i>	MRE
Electrician	<i>JW EBERHART</i>	PCE	<i>JW Eberhart</i>	<i>JWE</i>
Electrician Quality Control	Stephen R. Conley	PCE	<i>Stephen R. Conley</i>	SKC
Design Authority Representative	E.R. Kehler	Kabst	<i>E.R. Kehler</i>	ERR
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 5 amps @ 120 VAC

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00

Test Instrument type: AVO BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LS-2	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-007-TP-007D	
Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AY	Page 3 of 6

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.

2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	LFTSLP1AY	Acc
Manufacturer:	YES	Honeywell	Acc
Model:	YES	SL1	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 03-10-00 8:50 a.m.

Record: Room Temperature: 68 °F.

3.2 Mechanical Operation

Note: If switch cannot be stroked/cycled due to operational or physical restraints - make note in the note section of this procedure and proceed to the next step.

3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	YES	> 5 times	Acc
Describe Operation:	YES	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	YES	Free release of spring.	Acc

Dedication Test Plan – IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007D

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AY

Page 4 of 6

3.3 Insulation Resistance Test

3.3.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing.

3.3.2 Apply a nominal 500 VDC via Megger device between non-continuity terminals Common and Normally Open and then between terminal Normally Open and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
Common	NO	> 10 Gohm	> 10 Megohms	Acc
NO	Ground	> 14 Gohm	> 10 Megohms	Acc

* Normally closed contacts are open.

3.3.3 De-energize and remove the test equipment.

3.4 Contact Rating Test

3.4.1 Manually adjust the limit switch actuator to close the normally open contacts.

Note: If switch cannot be adjusted to close the NO contacts due to operational or physical restraints - make note in the note section of this procedure and proceed to step 3.5.

3.4.2 Connect the power supply to terminals Common and Normally Open.

3.4.3 Apply a nominal 5 amps, resistive, across the **closed normally open** contacts of the test specimen.

3.4.4 Record the following data:

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM-Closed NO Contact):	.492 VAC	< 0.5 Volts AC drop	Acc

3.4.5 Reduce the current source to zero amps and remove the power supply from terminals Common and Normally Open.

3.4.6 Manually adjust the limit switch actuator to close the normally closed contacts (if necessary).

3.5 Terminate the test.

3.5.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.

3.5.2 Retorque the terminals to 12 in-pounds.

Dedication Test Plan - IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007D

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP1AY

Page 5 of 6

3.5.3 Remove lockout/tagout and restore system to normal.

3.5.4 Record: Date /Time of Test End: 03-10-00 9:10a.m.

4.0 References

4.1 Elementary Wiring Drawings: EB-33056 Sheet 37

4.2 Wiring Diagram: 363A0033 Sheet 16

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Test was acceptable

Michael Cram

03-10-00

Notes:

Certified Instrumentation Technician (signature) *Michael Cram* Date: 03-10-00

Reviewed By: J. Cassin 3/10/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/10/00} *ERK Craig Anderson* Date: 3/10/00

QA/QC (signature) *T. J. [Signature]* Date: 3/13/00

T. J. Anderson

LIFTED LEAD LOG

Junction Box: Local


Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	16	101Y	LFTSLP1AY	C	JWG	3/10/00	SRL	3-10-00	JWG	3/10/00	SRL	3-10-00
363A0033	16	3709Y	LFTSLP1AY	NO	JWG	3/10/00	SRL	3-10-00	JWG	3/10/00	SRL	3-10-00


Remarks:

SNF-6315, Rev. 0

Page 753

Page 154





HANFORD DWG # H-2-828710 SHT 62 OF 97

REV	DATE	BY	CHK	ENG	APPO	APP'D	DESCR	J B SUPP	DATE
A	7/29/97	JBR	JUH	TUM	JRH		GENERAL REVISIONS	T W MEADOWS	11/17/97
B	9/29/97	JRS	JUH	TUM	JRH	LLA	DELETE UN-NEEDED L.S.	T W MEADOWS	4/22/98
C	9/15/97	JRS	ANSI	TUM	JRH	EM	DESIGN MODIFICATION	J M HANCOCK	1/17/98
D	10/2/97	JRS	ANSI	TUM	JRH	LLA	ADD WIRE #'S	L L ANDERSON	8/11/97
E	3/1/98	CSB	SEC	CSH			DE-NERGING & SIMPLIFICATION		
F	7/20/98	CSB	SEC	CSH			ADD NORTH AND SOUTH REFERENCES		

EDERER
INCORPORATED
WASHINGTON
EDERER COMPANY

TROLLEY SEISMIC RESTRAINT PINS CONTROL ELEMENTARY

SCALE: N/A
PAGE 62 OF 97
E3-33056

CONTROLLED COPY
MCC #15


11111 - F.B.K. ... 6.6
12.11.178

U.S. DEPARTMENT OF ENERGY
WESTINGHOUSE HAWFORD COMPANY
HAWFORD, PENNSYLVANIA 19348
MCC-3-0488
M-2-827169

GEC ALSTOM ENGINEERING SYSTEMS LTD
Moulton, Leicestershire, LE19 3BA England

363A0033

SEE INTERCOMPARISON SHEET - SHEET 16.1




THIS DRAWING IS ONLY AN APPROXIMATE COPY OF ORIGINAL

Dedication Test Plan – IST-LS-2
Test Plan No.: CGI-SNF-D-MHM-007-TP-007E
Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AX

Rev. No. 0
Page 1 of 7

ORIGINAL

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
						 3/12/00 NO CHANGE

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007E

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AX

Page 2 of 7

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

YJP Craig Swenson Date: 3/8/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	<i>Michael Cram</i>	<i>MC</i>
Electrician	<i>JW EBERHART</i>	<i>PCE</i>	<i>JW Eberhart</i>	<i>JWE</i>
Electrician Quality Control	<i>Stephen P. Cowley</i>	<i>PCE</i>	<i>Stephen P. Cowley</i>	<i>SEC</i>
Design Authority Representative	<i>E.R. Kahler</i>	<i>Xwest</i>	<i>ER Kahler</i>	<i>ERK</i>
Start-Up Representative (As Required)	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>
Construction Management (As Required)	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>

RECOMMENDED EQUIPMENT:

Power Supply capable of 5 amps @ 120 VAC

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO BM80/2 I.D.: 6A10-889 Calib. Due date: 02-09-01

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: HP-3457A I.D.: BAT 124 Calib. Due date: 07-30-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007E

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AX

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.

2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	LFTSLP2AX	Acc
Manufacturer:	YES	Honeywell	Acc
Model:	YES	SL1	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 03-09-00 70^{min} 1:07 p.m.

Record: Room Temperature: 70 °F.

3.2 Mechanical Operation

Note: If switch cannot be stroked/cycled due to operational or physical restraints - make note in the note section of this procedure and proceed to the next step.

3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	YES	> 5 times	Acc
Describe Operation:	YES	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	YES	Free release of spring.	Acc

Dedication Test Plan – IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007E

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AX

Page 4 of 7

3.3 Insulation Resistance Test

3.3.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing.

3.3.2 Apply a nominal 500 VDC via Megger device between non-continuity terminals Common and Normally Open and then between terminal Normally Open and ground. Record the resistances.

3.3.3 Remove the Megger device.

3.3.4 Manually adjust the limit switch actuator to open the normally closed (NC) contacts.

3.3.5 Apply a nominal 500 VDC via Megger device between non-continuity terminals Common and open Normally Closed and then between terminal Normally Closed and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
Common	NO	> 6.4 Gohms	> 10 Megohms	Acc
NO	Ground	> 12.5 Gohms	> 10 Megohms	Acc
Common	open NC*	> 40 Gohms	> 10 Megohms	Acc
Open NC	Ground*	> 12 Gohms	> 10 Megohms	Acc

*Normally closed contacts are open.

3.3.6 De-energize and remove the test equipment.

3.4 Contact Rating Test

3.4.1 Setup the test equipment and Limit Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

3.4.2 At limit switch, lift leads on Common terminal, Normally Closed terminal and Normally Open terminal. Record on the lifted lead log.

3.4.3 Connect the power supply to terminals Common and Normally Closed.

3.4.4 Apply a nominal 5 amps VAC, resistive, across the normally closed contacts of the test specimen.

Caution: Do not change state of contacts while energized.

3.4.5 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- NC)	493 vac	< 0.5 Volts AC drop	Acc

Dedication Test Plan – IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007E

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AX

Page 5 of 7

3.4.6 Reduce the current source to zero amps.

3.4.7 Disconnect the power supply from terminals Common and Normally Closed.

3.4.8 Manually adjust the limit switch actuator to close the normally open contacts.

Note: If switch cannot be adjusted to close the NO contacts due to operational or physical restraints - make note in the note section of this procedure and proceed to step 3.5.

3.4.9 Connect the power supply to terminals Common and Normally Open.

3.4.10 Apply a nominal 5 amps, resistive, across the closed normally open contacts of the test specimen.

3.4.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- Closed NO Contact):	• 361 VAC	< 0.5 Volts AC drop	Acc

3.4.12 Reduce the current source to zero amps and remove the power supply from terminals Common and Normally Open.

3.4.13 Manually adjust the limit switch actuator to close the normally closed contacts.

3.5 Terminate the test.

3.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

3.5.2 Retorque the terminals to 12 in-pounds.

3.5.3 Remove lockout/tagout and restore system to normal.

3.5.4 Record: Date /Time of Test End: 03-09-00 1:42

4.0 References

4.1 Elementary Wiring Drawings: EB-33056 Sheet 37

4.2 Wiring Diagram: 363A0033 Sheet 17

Dedication Test Plan - IST-LS-2 Test Plan No.: CGI-SNF-D-MHM-007-TP-007E Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AX	Rev. No. 0 Page 6 of 7
---	---

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Devices under test passed all parameters.

Michael Cram

03-09-00

Notes:

[Blank lined area for notes]

Certified Instrumentation Technician (signature) *Michael Cram* Date: *03-09-00*
 Reviewed By: *J. Cochran* *3-10-00*


Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{*3/9/00*} *[Signature]* Date: *3-9-00*

QA/QC (signature) *[Signature]* Date: *3/13/00*
T. ZANDERSON


Page 764



- NOTES**
- 1 SWITCH ENCLOSURE IS OF ZINC ALLOY COATED WITH BLACK FLUOROPLASTICS
TERMINAL COVER IS PLASTIC.
 2. SET FULL OVERTRAVEL POSITION SO THAT TOP OF BUSHING BE WITHIN RANGE OF ROLLER PLUNGER GROOVES SHOWN WITH CROSS HATCHING.
 3. SEAL IS ALREADY ASSEMBLED FOR A CABLE OF 5.8 TO 7.8 DIA.
SEAL IS ATTACHED FOR A CABLE OF 7.9 TO 9.6 DIA.
 4. MOUNT COMPLETELY THE TERMINAL COVER AFTER WIRING, TO KEEP THE SEALING OF TERMINAL HOUSING. TIGHTEN FULLY THE KNURLED CAPNUT BY HAND WITHOUT USING A TOOL.
 5. TERMINAL COVER, TERMINAL SCREWS AND HEX NUTS ARE FURNISHED UNASSEMBLED.

CHARACTERISTICS		
OPERATING FORCE	11.8N	MAX ▲
RELEASE FORCE	4.9N	MIN ▲
MOVEMENT DIFFERENTIAL	0.1	MAX
OVERTRAVEL	3	MIN

REV. 06	SI (MKS) - SI	8.30.99	TATSUHIRA	TOHTA	尺度 SCALE	記入の寸法 TOL. UNLESS NOTED	1:1	±0.4
REV. RECORD	DATE	BY	APPRO	図番 NO.	形番 MODEL	SL1-*****		
					名称 NAME	MINIATURE LIMIT SWITCH		
					図番 NO.	AD51236E		
					改番 REV.	8/17		



[38A01] A B C D E F [38F01] G HANFORD DWG // H-2-828710 SHT 62 OF 97

REV	DATE	BY	CHK	ENG	APPD	AMTD	DESCR	SCALE
A	3/29/97	JBR	JMH	TJM	JRM	AMTD	GENERAL REVISIONS	1/1/97
B	8/29/97	JRS	JMH	TJM	JRM	LLA	DELETE UN-NEEDED L.S.	5/25/97
C	9/15/97	JRS	JMH	TJM	JRM	EM	DESIGN MODIFICATION	1/1/97
D	10/13/97	JRS	JMH	TJM	JRM	LLA	ADD WIRE P'S	8/1/97
E	3/9/98	ESB	SEO	CSO	CSO		DE-MERGING & SIMPLIFICATION	
F	7/20/98	CSO	SEO	CSO	CSO		ADD NORTH AND SOUTH REFERENCES	

EDGER
 INCORPORATED
 10000 W. MEADOWS
 SUITE 100
 J. W. WARDEN
 L. E. ANDERSON
 TROLLEY SEISMIC RESTRAINT PINS CONTROL ELEMENTARY
 E3-33056
 37
 F

CONTROLLED COPY
MCC #15

MIRRA F. L. E. - C.C. -
11-18-98

U.S. DEPARTMENT OF ENERGY
WESTINGHOUSE INDIANAPOLIS COMPANY
IND-202-418148
IND-C-3-0148
H-2-827169

GENERAL ENGINEERING SYSTEMS LTD
Building, Lohrville, US MA (Japan)

363A0033

NOTE: INFORMATION SUBJECT - 31-0029 94. 1






NOTE: REFER TO CORNER DRAWINGS FOR DIMENSIONS OF THESE DETAILS

10 CORNER POINTS CHECKED (F)
SEE ELECTRICAL EN-2305 SHEET 37 & 38.

10 CORNER POINTS CHECKED (F)
SEE ELECTRICAL EN-2305 SHEET 37 & 38.

10 CORNER POINTS CHECKED (F)
SEE ELECTRICAL EN-2305 SHEET 37, 38, 39 & 40.

10 CORNER POINTS CHECKED (F)
SEE ELECTRICAL EN-2305 SHEET 37, 38, 39 & 40.



REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

REWORKED AND FULLY
ASSEMBLED TO ORDER
38289518/108
ALLEN BRADLEY 8710-8211-42

363A0033

ORIGINAL

Dedication Test Plan – IST-LS-2
 Test Plan No.: CGI-SNF-D-MHM-007-TP-007F
 Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AY

Rev. No. 0
 Page 1 of 6

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
						[Signature] 3/13/00 NO CHANGE

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST-LS-2	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-007-TP-007F	
Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AY	Page 2 of 6

ORIGINAL

In-Situ Test Procedure

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *YMP Craig Swenson* Date: 3/8/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	<i>Michael Cram</i>	MRC
Electrician	JW EBERTHART	PCE	<i>JW Eberhart</i>	JWG
Electrician Quality Control	Stephen R. Conley	PCE	<i>Stephen R. Conley</i>	SRC
Design Authority Representative	E.R. Kohler	West	<i>ERK</i>	ERK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 5 amps @ 120 VAC

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan -- IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007F

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AY

Page 3 of 6

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.

2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	LFTSLP2AY	Acc
Manufacturer:	YES	Honeywell	Acc
Model:	YES	SL1	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 03-09-00 1:17 p.m.

Record: Room Temperature: 70 °F.

3.2 Mechanical Operation

Note: If switch cannot be stroked/cycled due to operational or physical restraints - make note in the note section of this procedure and proceed to the next step.

3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	YES	> 5 times	Acc
Describe Operation:	YES	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	YES	Free release of spring.	Acc

Dedication Test Plan – IST-LS-2

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007F

Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AY

Page 4 of 6

3.3 Insulation Resistance Test

- 3.3.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing.
- 3.3.2 Apply a nominal 500 VDC via Megger device between non-continuity terminals Common and Normally Open and then between terminal Normally Open and ground. Record the resistances.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
Common	NO	> 8.46ohm	> 10 Megohms	Acc
NO	Ground	> 13.56ohm	> 10 Megohms	Acc

* Normally closed contacts are open.

- 3.3.3 De-energize and remove the test equipment.

3.4 Contact Rating Test

- 3.4.1 Manually adjust the limit switch actuator to close the normally open contacts.

Note: If switch cannot be adjusted to close the NO contacts due to operational or physical restraints - make note in the note section of this procedure and proceed to step 3.5.

- 3.4.2 Connect the power supply to terminals Common and Normally Open.
- 3.4.3 Apply a nominal 5 amps, resistive, across the closed normally open contacts of the test specimen.
- 3.4.4 Record the following data:

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM-Closed NO Contact):	.424 VAC	< 0.5 Volts AC drop	Acc

- 3.4.5 Reduce the current source to zero amps and remove the power supply from terminals Common and Normally Open.
- 3.4.6 Manually adjust the limit switch actuator to close the normally closed contacts (if necessary).
- 3.5 Terminate the test.**

- 3.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.
- 3.5.2 Retorque the terminals to 12 in-pounds.

Dedication Test Plan – IST-LS-2	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-007-TP-007F	
Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AY	Page 5 of 6

3.5.3 Remove lockout/tagout and restore system to normal.

3.5.4 Record: Date /Time of Test End: 03 - 09 - 00 1:46 p.m.

4.0 References

4.1 Elementary Wiring Drawings: EB-33056 Sheet 37

4.2 Wiring Diagram: 363A0033 Sheet 17

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Device under test passed all parameters.

Michael Cram

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-09-00
Reviewed By: J. Cadish 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/9/00} *[Signature]* Date: 3-9-00

QA/QC (signature) *[Signature]* Date: 3/13/00

Page 772

2/2/00


Remarks:												
Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	17	101V	LFTSLP2AY	C	SNF 3/9/00	3/9/00	SEC	3/9/00	SNF 3/9/00	3/9/00	SEC	3/9/00
363A0033	17	3710Y	LFTSLP2AY	NO	SNF 3/9/00	3/9/00	SEC	3/9/00	SNF 3/9/00	3/9/00	SEC	3/9/00

Junction Box: Local

LIFTED LEAD LOG

Dedication Test Plan - IST-LS-2
 Test Plan No.: CGI-SNF-D-MHM-007-TP-007F
 Test Specimen: Honeywell SL1 Limit Switch, Eqmt. No.: LFTSLP2AY
 Page 6 of 6
 Rev. No. 0

SP. No.	Micro Switch Phone #1-800-537-8945 Fax #1-815-235-8545	SPECIFICATIONS							
	EXTERNAL VIEW SL1-E								
	<p> 45.4 33 ±0.15 9.5 ±0.25 6.2 1.5 max PRETRAVEL 41.4 ±0.8 OPERATING POSITION 20 8 4.2 ±0.1 MOUNTING HOLE 28.4 4.5 ±0.1 4.2 ±0.1 4 20 44.8 (57.4) 12.6 ±1 KNURLED CAPNUT φ16 11 DIA x 4 WIDE SINTERED STAINLESS ROLLER REFER TO NOTE 2 M14x1 2-M14x1 HEX NUT 2.5 THICKNESS 17 ACROSS FLATS REFER TO NOTE 5 3-M3x5 TERMINAL SCREW REFER TO NOTE 5 CONDUIT HOLE φ97 ±0.15 18 TERMINAL COVER REFER TO NOTE 5 </p>								
	<p> NOTES 1 SWITCH ENCLOSURE IS OF ZINC ALLOY COATED WITH BLACK FLUOROPLASTICS TERMINAL COVER IS PLASTIC. 2. SET FULL OVERTRAVEL POSITION SO THAT TOP OF BUSHING BE WITHIN RANGE OF ROLLER PLUNGER GROOVES SHOWN WITH CROSS HATCHING. 3. SEAL IS ALREADY ASSEMBLED FOR A CABLE OF 5.8 TO 7.8 DIA. SEAL IS ATTACHED FOR A CABLE OF 7.9 TO 9.6 DIA. 4. MOUNT COMPLETELY THE TERMINAL COVER AFTER WIRING, TO KEEP THE SEALING OF TERMINAL HOUSING. TIGHTEN FULLY THE KNURLED CAPNUT BY HAND WITHOUT USING A TOOL. 5. TERMINAL COVER, TERMINAL SCREWS AND HEX NUTS ARE FURNISHED UNASSEMBLED. </p>								
	CHARACTERISTICS								
	OPERATING FORCE	11.8N	MAX	▲					
	RELEASE FORCE	4.9N	MIN	▲					
	MOVEMENT DIFFERENTIAL	0.1	MAX						
	OVERTRAVEL	3	MIN						
	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:15%;"> 作業者 TATSUHIRA 2.2.99 </td> <td style="width:15%;"> 検査 MSAD 2.2.99 </td> <td style="width:15%;"> 承認 TSUKAMOTO 2.2.99 </td> <td style="width:15%;"> 図番 AD51236E </td> <td style="width:15%;"> 改訂REV. 8 06 / 17 </td> </tr> </table>				作業者 TATSUHIRA 2.2.99	検査 MSAD 2.2.99	承認 TSUKAMOTO 2.2.99	図番 AD51236E	改訂REV. 8 06 / 17
作業者 TATSUHIRA 2.2.99	検査 MSAD 2.2.99	承認 TSUKAMOTO 2.2.99	図番 AD51236E	改訂REV. 8 06 / 17					
REV	RECORD	DATE	BY	APPD					
06	SI (MKS) - SI	8.30.99	TATSUHIRA	TOMITA					



REV	DESCRIPTION	DATE	BY	CHK	ENG	APPO	AP'D	DATE	BY	CHK	ENG	APPO	AP'D
A	GENERAL REVISIONS	3/29/97	JBR	JMH	LMH	JMH							
B	DELETE UN-NEEDED L.S.	8/20/97	JRS	JMH	LMH	JMH	LLA						
C	DESIGN MODIFICATION	9/15/97	JRS	AHN	LMH	JMH	LLA						
D	ADD WIRE #S	10/3/97	JRS	AHN	LMH	JMH	LLA						
E	RE-WIRING & SIMPLIFICATION	3/3/98	CSB	SED	CSH								
F	ADD NORTH AND SOUTH REFERENCES	3/26/98	CSB	SED	CSH								

SOEGER

INCORPORATED
WASHINGTON COUNTY

TROLLEY SEISMIC RESTRAINT PINS CONTROL ELEMENTARY

SCALE: N/A

FIG. NO. E8-33056



SHEET 37 OF 38

CONTROLLED COPY
MCC #15

Using F.E.S. C.C.C.
in 11-1980

U.S. DEPARTMENT OF ENERGY
WESTINGHOUSE HAWFORD COMPANY
MCC-5-8-048
H-2-827169
GEC ALSTHOM ENGINEERING SYSTEMS LTD
Moulton, Leighton Buzzard, LU8 5AP

3630033



BLACK INTERCONNECTION DIAGRAM - 31-0019 P4-1

NOTE: REFER TO DEVICE DIAGRAMS FOR DIMENSIONS
OF THESE DEVICES.

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-007-TP-007J

Test Specimen: Honeywell Limit Switch Eqmt. No.: LFPGOX,Y; LFPGCX, Y; LFPGLX,Y Page 1 of 4

ORIGINAL

Rev. No. 0

In-Situ Inspection Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI. Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007J

Test Specimen: Honeywell Limit Switch Eqmt. No.: LFPGOX,Y; LFPGCX, Y; LFPGLX,Y Page 2 of 4

In-Situ Inspection Procedure**ORIGINAL****Inspection Procedure Approval (Obtain prior to inspection):**

This procedure documents the visual verification of the identification critical characteristics of the remaining specimen which were in-situ tested on a sampling basis as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) JWP Larry Swenson Date: 4-6-00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Electrician	N/A	N/A	N/A	N/A
Electrician Quality Control	N/A	N/A	N/A	N/A
Design Authority Representative	LARRY W. PRICE	XWEST	JWP	JWP

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment.

INSPECTION PROCEDURE:**1.0 Record the following Test Specimen identification information:**

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFPGOX	LFPGOX	
Manufacturer:	Honeywell	Honeywell	
Model:	SL1-E	SL1-E	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFPGOY	LFPGOY	
Manufacturer:	Honeywell	Honeywell	
Model:	SL1-E	SL1-E	

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-007-TP-007J

Test Specimen: Honeywell Limit Switch Eqmt. No.: LFPGOX,Y; LFPGCX, Y; LFPGLX,Y Page 3 of 4

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFPGCX	LFPGCX	
Manufacturer:	Honeywell	Honeywell	
Model:	SL1-H	SL1-H	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFPGCX	LFPGCX	
Manufacturer:	Honeywell	Honeywell	
Model:	SL1-H	SL1-H	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFPGLX	LFPGLX	
Manufacturer:	Honeywell	Honeywell	
Model:	SL1-H	SL1-H	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFPGLY	LFPGLY	
Manufacturer:	Honeywell	Honeywell	
Model:	SL1-H	SL1-H	

2.0 Record: Date /Time of Test Beginning: 4/7/00

2.1 Record: Date /Time of Test End: 4/7/00

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 17, 17A

Dedication Test Plan - IST Test Plan No.: CGI-SNF-D-MHM-007-TP-007J Test Specimen: Honeywell Limit Switch Eqmt. No.: LFPGOX,Y; LFPGCX, Y; LFPGLX,Y	Rev. No. 0 Page 4 of 4
--	---------------------------

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

TEST (INSPECTION) WAS DONE 2/3/00 WHEN GRAPPLG WAS IN SAMPLE PIT, THIS FORM WAS COMPLETED 4/7/00

ALL ITEMS MEET ACCEPTANCE CRITERIA.

Notes:

N/A

Design Authority Representative (signature) *Jay* Date: 4-7-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *Greg Brennan* Date: 4/7/00

QA/QC (signature) *Stephen Scott Moss* Date: 4-7-2000

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

ECN No. N/A 4710000 CGI No. CGI-SNF-D-MHM-003C
Title: **MHM Interlock P6, P52, P53, P57 and P61 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)**

Rev. No. 1
Page 1 of 10

Section 1 Part Information

Item No.: N/A	Manufacturer:	Supplier:
Mfg. Part/Model No.:	Supplier's P/N:	
Part Description:		
End Use Description:		

ORIGINAL

Section 2a Component Information

Equipment No.: PLS1, PLS1-OM, PLS2, PLS2-OM	Specification No.: Ederer F-2566, Foster Wheeler MJX-SDX	Manufacturer: GEMCO	Past P.O. No.: N/A
Manufacturer's Part/Model No.: 1989-A-16-R-14-64-E-R, 1989-O-115-M-S	Equipment Supplier (if different from manufacturer): Foster Wheeler		Equip. Supplier's Part No.: N/A

Component Description: Programmable Limit Switch (PLS) for interlocks to measure height of MCO grapple, raise and lower commands, MCO seating zones and locking plns disengagement, located on MCO control station.

Section 2b Commercial Availability of the Item

- Is the item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier?
 YES (go to #2 below) NO (go to procedure step 6.3.2-dedicate item)
 If not available from a qualified NQA-1 supplier, is it available from an ISO 9000 supplier?
 YES (go to #2 below, procedure step 6.3.2, & dedicate item) NO (procedure step 6.3.2-dedicate item).
- List of Candidate qualified NQA1 suppliers or ISO 9000 suppliers, if used

company name & type	contact name	phone
N/A		
- Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

CGI Determination Questions:

#1: Is the item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the item is not commercial grade) NO (continue)

#2: Is the item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)

#3: Is the item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)

All three criteria have been satisfied. The item meets the definition of commercial grade.

Section 2d Reason for Dedication

The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):

Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.

Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.

Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.

Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.

Other ('like-for-like', similar, substitution, replacement evaluation)

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A CGI No. CGI-SNF-D-MHM-003C

Page 2 of 10

Title: MHM Interlock P6, P52, P53, P57 and P61 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. P6 reverts shear of MCO partially lowered with MHM. This MCO grapple limit switch prevents locking pins disengaging when the MCO hoist is not at the upper limit or at the tube plug exchange limit.

2. For interlocks P52, P53, P57 and P61, PLS provides safety significant functions to position the MHM and to prevent drop of the MCO from the MHM.

3. *OK 2/24/00*

1. Part/Component Functional Mode:

Safety Function #1: Active Passive

Safety Function #2: Active Passive

Safety Function #3: Active Passive

Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function

Passive - Change of state is not required for the component to perform its safety function

C. Host Component Safety Function (if applicable): N/A

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

1. Failure of the PLS or OM could cause the output relay contacts to open/close resulting in potential override of interlock channel.

2.

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required:

Yes

No

If yes: Environmental Qualification Requirements

Limiting Environmental Conditions:

Required Safety Functions:

Qualification Period:

Natural Phenomena Hazard (NPH) Design Required:

Yes

No

If yes: NPH Design Requirements

Performance Category:

NPH Design Req'ts.:

Required Safety Functions:

Section 5 Component Functional Classification

Safety Class (SC)

General Service (GS)

Safety Significant (SS)

If part/component classification is different from host component/system, document basis. N/A

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: N/A

Safety Analysis Report (SAR): HNF-3672, Rev. 0

Drawings: N/A

Vendor Manual/Manufacturer/Supplier Information: GEMCO Series 1989: Quik-Set III High Resolution Single Turn and Multi-turn PLS

Other: ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 3 of 10

ECN No. **N/A** CGI No. **CGI-SNF-D-MHM-003C**
 Title: **MHM Interlock P6, P52, P53, P57 and P61 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)**

Section 9 Critical Characteristics

Critical Characteristics	Acceptance Criteria/Tolerances	Acc Meth	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the item delivered is the item specified)				
PLS1 and 2				
Manufacturer	GEMCO	1, IN	X	
Model	1989-A-16-R-14-64-E-R	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the item delivered is the item specified)				
3 Performance Critical Characteristics (for reasonable assurance that the item will perform its intended safety function(s))				
Run/Prog selector lockout	Program cannot be changed in the Run mode	1, T		X
Transducer operating voltage	14.3 to 15.3 VDC between terminals 29 and 30 on terminal strip S2 in the CPU module	1, T		X
Microprocessor operating voltage	4.8 to 5.2 VDC between terminals 1 and 2 on terminal strip S2 in the CPU module	1, T		X

PLS1-OM, PLS2-OM

1. Item Identification Critical Characteristics (necessary for reasonable assurance that the item delivered is the item specified)				
Manufacturer	GEMCO	1, IN	X	
Model	1989-O-115-M-S	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the item delivered is the item specified)				
3 Performance Critical Characteristics (for reasonable assurance that the item will perform its intended safety function(s))				
Insulation Resistance	>10 Megohms across open contacts and contact terminals to ground at 500 VDC	1, T		X
Contact current carrying capability	<0.5 volt drop contacts at 115 VAC, 10 amps, resistive	1, T		X

PLS1 and PL1-OM, PLS2 and PL2-OM

3 Performance Critical Characteristics (for reasonable assurance that the item will perform its intended safety function(s))				
Output relay operation	Contacts close at programmed limit	1, T		X
PLS system operability	PLS system operates as programmed	1, T		X

<p>4. Notes and Legend: PLS1, PLS2 Model: 1989-A-16-R-64-E-R 1989 - Model number A - Complete system CPU and Keypad 16 - 16 Output circuits R - Resolver input 64 - 64 turn resolver E - Current sinking programmer output R - Remote serial display</p>	<p>PLS1-OM, PLS2-OM Model: 1989-O-115-M-S 1989 - Model Number O - Output Module 115 - 115 VAC M - Mechanical Relay, SPDT, 10 amp S - Standard Panel Mount</p>	<p>Acceptance Method (Acc Meth): 1. Special Test and Inspection: 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 5. Vendor/Item History</p>
--	---	---

Section 10 Initial Review and Approval

Approvals:
 Designated Engineer: EP KAWLER
 Design Authority: DWM David W. Jensen 10/12/99
 QA Engineer: T. Z. ANDERSON 10/13/99

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 4 of 10

ECN No. N/A CGI No. CGI-SNF-D-MHM-003C
Title: MHM Interlock P6, P52, P53, P57 and P61 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)

SNF-6315, Rev. 0

WORKSHEET 1 DETERMINATION OF FAILURE MECHANISMS/MODES		
Section 1		
Typical Failure Mechanisms	Definition	Applicable to Component under Evaluation
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.	Yes [] No [X]; If Yes, indicate failure Mode _____
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	Yes [] No [X]; If Yes, indicate failure Mode _____
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.	Yes [] No [X]; If Yes, indicate failure Mode _____
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.	Yes [] No [X]; If Yes, indicate failure Mode _____
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	Yes [X] No [] ; If Yes, indicate failure Mode PLS system provides incorrect position to CPU to energize permissive circuit.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.	Yes [] No [X]; If Yes, indicate failure Mode _____
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	Yes [] No [X]; If Yes, indicate failure Mode _____
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.	Yes [] No [X]; If Yes, indicate failure Mode _____
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.	Yes [] No [X]; If Yes, indicate failure Mode _____
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.	Yes [] No [X]; If Yes, indicate failure Mode _____
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.	Yes [] No [X]; If Yes, indicate failure Mode _____
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.	Yes [] No [X]; If Yes, indicate failure Mode _____
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation		
1. Programmable Limit Switch (PLS) switch contacts are closed to permit equipment movement. Contacts open for the interlock function. Any failure, which prevents contacts to open, inhibits the particular resolver interlock function.		
2.		
3.		
4.		
5.		

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 5 of 10

ECN No. N/A CGI No. CGI-SNF-D-MHM-003C
 Title: MHM Interlock P6, P52, P53, P57 and P61 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1	
Item Description: GEMCO Quik-Set III Programmable Limit Switch System #: MHM	Equip #: PLS1, PLS1-OM, PLS2, PLS2-OM Model #: 1989-A-16-R-14-64-E-R, 1989-O-115-M-S
Manufacturer (Address/Phone): GEMCO/PATRIOT 1080 N. Crooks Rd Clawson, MI 48017-1097 (810) 435-0700	Supplier (Address/Phone):

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Model
	X		3. Run/Prog selector lockout
	X		4. Transducer operating voltage
	X		5. Microprocessor operating voltage
	X		6. Insulation Resistance
	X		7. Contact current carrying capability
	X		8. Output relay operation
	X		9. PLS system operability

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

PLS1, PLS2

Characteristic: **Manufacturer** Sample Size*: **100%**
 Acceptance Criteria: **GEMCO**
 Receipt Inspection Plan / Report #: **CGI-SNF-D-MHM-003C-TP-003CX, 3CY**

Characteristic: **Model - PLS3** Sample Size*: **100%**
 Acceptance Criteria: **1989-A-16-R-14-64-E-R**
 Receipt Inspection Plan / Report #: **TP-003CX, 3CY**

PLS1-OM, PLS2-OM

Characteristic: **Manufacturer** Sample Size*: **100%**
 Acceptance Criteria: **GEMCO**
 Receipt Inspection Plan / Report #: **TP-003CX, 3CY**

Characteristic: **Model - PLS3 -OM** Sample Size*: **100%**
 Acceptance Criteria: **1989-O-115-M-S**
 Receipt Inspection Plan / Report #: **TP-003CX, 3CY**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1

ECN No. N/A CGI No. CGI-SNF-D-MHM-003C

Page 6 of 10

Title: MHM Interlock P6, P52, P53, P57 and P61 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size References (See Section 7)

PLS1, PLS2

Characteristic for Test: **Run/Prog selector lockout** Sampling Size*: Normal Reduced Tightened

Acceptance Criteria: **Program cannot be changed in the Run mode**

Actual Test Value: See TP Test Plan and Report #: TP-003CX, 3CY

Characteristic for Test: **Transducer operating voltage** Sampling Size*: Normal Reduced Tightened

Acceptance Criteria: **14.3 to 15.3 VDC between terminals 29 and 30 on terminal strip S2 in the CPU module**

Actual Test Value: See TP Test Plan and Report #: TP-003CX, 3CY

Characteristic for Test: **Microprocessor operating voltage** Sampling Size*: Normal Reduced Tightened

Acceptance Criteria: **4.8 to 5.2 VDC between terminals 1 and 2 on terminal strip S2 in the CPU module**

Actual Test Value: See TP Test Plan and Report #: TP-003CX, 3CY

PLS1-OM, PLS2-OM

Characteristic for Test: **Insulation Resistance** Sampling Size*: Normal Reduced Tightened

Acceptance Criteria: **>10 megohms across open contacts and contact terminals at 500 VDC** Relays were

Actual Test Value: See TP 003DX Test Plan and Report #: tested in TP003DX

Characteristic for Test: **Contact current carrying capability** Sampling Size*: Normal Reduced Tightened

Acceptance Criteria: **<0.5 volt across contacts at 115 VAC, 10 amps, resistive**

Actual Test Value: See TP 003DX Test Plan and Report #: Relays were tested in TP-003DX

PLS and PLS-OM tested as a unit with resolver

Characteristic for Test: **Output relay operation** Sampling Size*: Normal Reduced Tightened

Acceptance Criteria: **Contacts open and close at programmed limits**

Actual Test Value: CSB (W379) -015-11-058 → Test Plan and Report #: See TP

Characteristic for Test: **PLS system operability** Sampling Size*: Normal Reduced Tightened

Acceptance Criteria: **PLS system operates as programmed**

Actual Test Value CSB (W379) -015-11-058 → Test Plan and Report #: See TP

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A

CGI No. CGI-SNF-D-MHM-005C

Page 7 of 10

Title: **MHM Interlock P8 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)**

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: PLS1, PLS2

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method TAN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	GEMCO	X		1, IN	TR003 CX, CY	NA	2	0	XWEST	LARRY W. PRICE	9/12/00
Model	1989-A-16-R-14-64-E-R	X		1, IN							
Run/Prog selector lockout	Program cannot be changed in the Run mode		X	1, T							
Transducer operating voltage	14.3 to 15.3 VDC between terminals 29 and 30 on terminal strip S2 in the CPU module		X	1, T							
Microprocessor operating voltage	4.8 to 5.2 VDC between terminals 1 and 2 on terminal strip S2 in the CPU module		X	1, T							

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-007CX, -007CY cited

Testing Agency Approval: <u>NR CES 9/12/00</u>	Date: <u>above. CES 9/12/00</u>	Design Authority: <u>LES Larry Swenson</u>	Date: <u>9/12/00</u>
Testing Agency QA Engineer: <u>NR CES 9/12/00</u>	Date: <u>9/12/00</u>	QA Engineer: <u>Stephen Scott Moss</u>	Date: <u>4-20-2000</u>

BUYER VERIFICATION

SNF-6315, Rev. 0

Page 786

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 8 of 10

ECN No. N/A CGI No. CGI-SNF-D-MHM-005C
Title: MHM Interlock P8 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	GEMCO	X		1, IN	TP-003CKY	NA	3	0	XWEST	LARRY W. PRICE	4/10/00
Model	1989-O-115-M-S	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Insulation resistance	>10 megohms across open contacts and contact terminals at 500 VDC		X	1, T	TP-003CKY	NA	3	0	XWEST	LARRY W. PRICE	4/10/00
Contact current carrying capability	<0.5 volt across contacts at 115 VAC, 10 amps, resistive		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-003CKY, DX cited above.

Testing Agency Approval: <u>NR CES 4/12/00</u> Date <u>CES 4/12/00</u>	Design Authority: <u>Larry W. Price</u> Date <u>4-12-00</u>
Testing Agency QA Engineer: <u>NR CES 4/12/00</u> Date <u>CES 4/12/00</u>	QA Engineer: <u>Stephen Scott Motz</u> Date <u>4-20-2000</u>

SNF-6315, Rev. 0

Page 787

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 9 of 10

ECN No. N/A CGI No. CGI-SNF-D-MHM-005C
Title: MHM Interlock P8 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: PLS and PLS-OM tested as a unit with resolver

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Output relay operation	Contacts open and close at programmed limits		X	1, T	TR03 CX, CY	NA	2	0	XWEST	LARRY W. PEKS <i>[Signature]</i>	4/12/00
PLS system operability	PLS system operates as programmed		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-003CX, CY cited above.

Testing Agency Approval: <u>NR CES 4/12/00</u> Date: <u>CES 4/12/00</u>	Design Authority: <u>CES Craig Stevenson</u> Date: <u>4/12/00</u>
Testing Agency QA Engineer: <u>NR CES 4/12/00</u> Date: <u>4/12/00</u>	QA Engineer: <u>Stephan Scott Mack</u> Date: <u>4-20-2000</u>

SNF-6315, Rev. 0

Page 788

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. **NA**

CGI No. **CGI-SNF-D-MHM-005C**

Page 10 of 10

Title: **MHM Interlock P8 - Gemco Programmable Limit Switch (PLS) and Output Relay Module (OM)**

SNF-6315, Rev. 0

Section 6 Contacts/Phone Numbers

Name	Phone
Design Authority CRAIG SWENSON	() 376-0288
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents	For Critical Characteristics
<input type="checkbox"/> Drawings:	
<input type="checkbox"/> Manuals (specify type & number):	
<input type="checkbox"/> Design Calculations	
<input type="checkbox"/> Installation Instructions	
<input type="checkbox"/> Operation Instructions	
<input type="checkbox"/> Calibration Instructions	
<input type="checkbox"/> Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/> Other: GEMCO Series 1989: Quik-Set III High Resolution Single Turn and Multi-turn PLS	All
Procurement Documents	
<input type="checkbox"/> Certificate of Conformance/Compliance	
<input type="checkbox"/> Seismic Qualification Certificate	
<input type="checkbox"/> Environmental Qualification Certificate	
<input type="checkbox"/> Test Report (s):	
<input type="checkbox"/> Inspection Report (s):	
<input type="checkbox"/> CMTRs for ASME Pressure Retaining Materials	
<input type="checkbox"/> Valve Seat Leakage Report	
<input type="checkbox"/> Weld Records	
<input type="checkbox"/> Material Traceability Record	
<input type="checkbox"/> Other:	

ORIGINAL

Dedication Test Plan - IST.	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CY	
Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS2, PLS2 OM	Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
1	Perform as a Bench Test	Section 2.5 deleted	Contact Rating Test to be performed as a Bench Test No. CGI-SNF-D-MHM-003D-TP-003DX	ERK 3/7/00	LES 3/8/00	JR 3/13/00
2	Power not available use temporary 120 VAC Power	2.3 A, 2.4.2	Use temporary power	ERK 3/8/00	LES 3/8/00	JR 3/13/00
3	Terminal not wired to ground	2.4.1 Table:	Either Terminal 3 or 4 needs to be grounded. Terminal 3 was not grounded	ERK 3/8/00	LES 3/8/00	JR 3/13/00

*QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST.

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CY

Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS2, PLS2 OM

Page 2 of 7

In-Situ Test Procedure**Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

YWP Luigi Swenson Date: 3/6/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MPC
Electrician	<i>JW EBERHART</i>	PCE	<i>JW Eberhart</i>	JWE
Electrician Quality Control	<i>Stephen R. Conley</i>	PCE	<i>Stephen R. Conley</i>	SRC
Design Authority Representative	<i>ERK = E.R. Kahlor</i> <i>Luigi Swenson</i>	XWest		
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A
Design Authority	<i>C.E. Swenson</i>	KH1	<i>Luigi Swenson</i>	CES

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 115 VAC

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being verified unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO BM80/2 I.D.: 640-889 Calib. Due date: 02-09-01

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: PROTO 606 I.D.: 029E/009 Calib. Due date: 01/13/01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST.	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CY	
Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS2, PLS2 OM	Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing in Section 2.5 and 2.6 begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

1.0 Record the following Test Specimen identification information for PLS1:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	YES	Gemco	Acc
Model:	YES	1989-A-16-R-14-64-E-R	Acc
Serial No.:	OK	N/A	Acc

2.0 Record the following Test Specimen identification information for PLS1 OM:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	YES	Gemco	Acc
Model:	YES	1989-O-115-M-S	Acc
Serial No.:	OK	N/A	Acc

2.1 Perform the following testing steps:

2.2 Record: Date /Time of Test Beginning: 03-08-00 1:25 p.m.

Record: Room Temperature: 68 °F.

2.3 Program Lockout

2.3A At PLS OM2 terminals "Power" (101Y) and "ac" (102Y), lift leads per Lifted Lead Log and apply 120 VAC temporary power.

2.3.1 Attach, if not already attached, a Gemco Quik-Set III Programmer (keypad/display module) to PLS2.

2.3.2 With the Run/Prog selector lockout switch in the Run mode, verify that the program cannot be changed.

IPK
3/8/00
LES

Description	Record Data	Acceptance Criteria	Comments/Deviations
With Selector Switch in Run, try to change program:	OK	Program does not change	Acc

Dedication Test Plan – IST. Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CY
Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS2, PLS2 OM Page 4 of 7

2.4 Operating Voltage

2.4.1 At PLS2, terminal strip S2, record the following DC voltages:

Description	Terminal	Terminal	Record Data	Acceptance Criteria	Comments/Deviations
Transducer operating voltage	29	30 (ground)	14.96vdc	14.3 to 15.3 VDC	Acc
Microprocessor operating voltage	1	4 (ground)	5.17vdc	4.8 to 5.2 VDC	Acc
Microprocessor operating voltage	2	4 (ground)	5.17vdc	4.8 to 5.2 VDC	Acc

CEB
 CLK
 3/8/00

3/8/00
 CEB

2.4.2 Remove temporary power and reband lifted leads per lifted lead log and verify.

2.5 Contact Rating Test

2.5.1 Open main disconnect switch MD, lock and tag out.

2.5.2 With a Multi-meter, verify that 120 VAC is not present at LS2 COM terminal 101Y, disconnect wire from LS2 terminals COM and NO, circuits 101Y and 1004Y, disconnect wire from LS4 terminals COM and NO, circuits 101Y and 1008Y.

2.5.3 Setup the PLS2 OM for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

2.5.4 Apply a nominal 10 amps VAC, resistive, across the closed contacts (COM and NO) of LS2 and LS4.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
LS2 (Terminals COM and NO)		< 0.5 Volts AC drop	
LS4 (Terminals COM and NO)		< 0.5 Volts AC drop	

Delete
 RAK 3/2/00
 CEB

2.5.5 De-energize equipment and determinate test leads.

2.6 Insulation Resistance Test

2.6.1 Lift all leads on PLS2 OM relay outputs per Lifted Lead Log.

2.6.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

THIS TEST INCLUDED IN TP-003DX
 JWP
 4/14/00

Dedication Test Plan – IST.

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CY

Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS2, PLS2 OM

Page 5 of 7

Terminal to Terminal / Ground

PLS2 OM output relay	Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
LS2	COM	Ground	> 100Gohm	> 10 Megohms	Acc
LS2	NO	Ground	> 100Gohm	> 10 Megohms	Acc
LS2	COM	NO	> 1.19Gohm	> 10 Megohms	Acc
LS3	COM	Ground	> 100Gohm	> 10 Megohms	Acc
LS3	NO	Ground	> 100Gohm	> 10 Megohms	Acc
LS3	COM	NO	> 1.24Gohm	> 10 Megohms	Acc
LS4	COM	Ground	> 100Gohm	> 10 Megohms	Acc
LS4	NO	Ground	> 100Gohm	> 10 Megohms	Acc
LS4	COM	NO	> 1.21Gohm	> 10 Megohms	Acc
LS5	COM	Ground	> 100Gohm	> 10 Megohms	Acc
LS5	NO	Ground	> 100Gohm	> 10 Megohms	Acc
LS5	COM	NO	> 1.24Gohm	> 10 Megohms	Acc
LS7	COM	Ground	> 100Gohm	> 10 Megohms	Acc
LS7	NO	Ground	> 100Gohm	> 10 Megohms	Acc
LS7	COM	NO	> 1.27Gohm	> 10 Megohms	Acc
LS8	COM	Ground	> 100Gohm	> 10 Megohms	Acc
LS8	NO	Ground	> 100Gohm	> 10 Megohms	Acc
LS8	COM	NO	> 1.17Gohm	> 10 Megohms	Acc

2.6 De-energize test equipment.

2.7 Terminate the test.

2.7.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.7.2 Retorque the terminals to 12 in-pounds.

2.7.3 Remove lockout/tagout and restore system to normal.

2.7.4 Record: Date /Time of Test End: 03-08-00 2:00 p.m.

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 9

Dedication Test Plan – IST.	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CY	
Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS2, PLS2 OM	Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Device passed all test parameters.

Michael Ray Cram
03-08-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-08-00
Reviewed By: J. Coakley 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 3/8/00

QA/QC (signature) [Signature] Date: 3/13/00
T. ZANDERSON

LIFTED LEAD LOG

MHM Control Console

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-33056	9	101Y	LS2	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1004Y	LS2	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101Y	LS3	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1006Y	LS3	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101Y	LS4	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1008Y	LS4	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101Y	LS5	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1010Y	LS5	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101Y	LS7	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	10A29Y	LS7	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101Y	LS8	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	10A30Y	LS8	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
Remarks:							SRL	3-8-00	SRL	3-8-00	SRL	3-8-00
EB-33057 9 101Y PLSOM2 Power							SRL	3-8-00	SRL	3-8-00	SRL	3-8-00
EB-33056 9 102Y PLSOM2 AC							SRL	3-8-00	SRL	3-8-00	SRL	3-8-00

JWE
3/8/00

SNF-6315, Rev. 0

Page 7 of 6

Dedication Test Plan - IST
 Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CX
 Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS1, PLS1 OM

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
1	Perform as a Bench Test	Section 2.5 Deleted	Contact rating Test to be performed as a Bench test No. CGI-SNF-D-MHM-003D-TP-003DX	SRK 3/7/00	UES 3/8/00	[Signature] 3/12/00
2	Power not available, use Temporary 120VAC power	2.3A, 2.4.2	Use Temporary Power to run test	SRK 3/8/00	UES 3/8/00	[Signature] 3/12/00
3	Duplicate relay number deleted	Table 2.6.2	Deleted duplicate relay numbers from table	SRK 3/8/00	UES 3/8/00	[Signature] 3/13/00

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CX	
Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS1, PLS1 OM	Page 2 of 9

In-Situ Test Procedure

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) YMP Wing Swenson Date: 3/6/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	Michael Cram	MC
Electrician	J WEISBERHART	PCE	J Weisberhart	JWE
Electrician Quality Control	Stephen R. Coulogy	PCE	Stephen R. Coulogy	SR
Design Authority Representative	E. R. Kahler	XWest	ER Kahler	ERK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 115 VAC

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being verified unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: <u>AVO BM8012</u>	I.D.: <u>CA10-889</u>	Calib. Due date: <u>02-09-01</u>
Test Instrument type: <u>HP 3457A</u>	I.D.: <u>BAT 123</u>	Calib. Due date: <u>07-29-00</u>
Test Instrument type: <u>FLUKE 787</u>	I.D.: <u>BAT 107</u>	Calib. Due date: <u>05-28-00</u>
Test Instrument type: _____	I.D.: _____	Calib. Due date: _____
Test Instrument type: _____	I.D.: _____	Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CX

Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS1, PLS1 OM

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before certain testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads.

1.0 Record the following Test Specimen identification information for PLS1:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	YES	Gemco	Acc
Model:	YES	1989-A-16-R-14-64-E-R	Acc
Serial No.:	OK	N/A	Acc

2.0 Record the following Test Specimen identification information for PLS1 OM:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	YES	Gemco	Acc
Model:	YES	1989-O-115-M-S	Acc
Serial No.:	OK	N/A	Acc

2.1 Perform the following testing steps:

2.2 Record: Date /Time of Test Beginning: 03-08-00 8:40 a.m.

Record: Room Temperature: 68 °F.

2.3 Program Lockout

2.3A At PLS DM1 "Power" (101X) and AC (102X) lift leads per Listed Lead Log and apply 120VAC Temporary Power

2.3.1 Attach, if not already attached, a Gemco Quik-Set III Programmer (keypad/display module) to PLS1.

2.3.2 With the Run/Prog selector lockout switch in the Run mode, verify that the program cannot be changed.

Description	Record Data	Acceptance Criteria	Comments/Deviations
With Selector Switch in Run, try to change program:	OK	Program does not change	Acc

Dedication Test Plan - IST Rev. No. 0
 Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CX
 Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS1, PLS1 OM Page 4 of 9

2.4 Operating Voltage

2.4.1 At PLS1, terminal strip S2, record the following DC voltages:

Description	Terminal	Terminal	Record Data	Acceptance Criteria	Comments/Deviations
Transducer operating voltage	29	30 (ground)	15.03	14.3 to 15.3 VDC	Acc
Microprocessor operating voltage	1	3 (ground)	5.13	4.8 to 5.2 VDC	Acc
Microprocessor operating voltage	2	4 (ground)	5.12	4.8 to 5.2 VDC	Acc

3/8/00 2.4.2 ~~Disconnect temporary power and relay leads at "Power" (101X) and ACC102X per Lifted Lead Log and verify.~~

2.5 Contact Rating Test

2.5.1 Open main disconnect switch MD, lock and tag out.

2.5.2 With a Multi-meter, verify that 120 VAC is not present at LS2 COM terminal 101X, disconnect wire from LS2 terminals COM and NO, circuits 101X and 1003X

2.5.3 Setup the PLS1 OM for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

2.5.4 Apply a nominal 10 amps VAC, resistive, across the closed contacts (COM and NO) of LS2.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
LS2 (Terminals COM and NO)		< 0.5 Volts AC drop	

2.5.5 De-energize equipment and determinate test leads.

2.6 Insulation Resistance Test

2.6.1 Lift all leads on PLS1 OM relay outputs per Lifted Lead Log.

2.6.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

THIS TEST INCLUDED IN ywp TP-003DX 4/10/00

Terminal to Terminal / Ground

PLS1 OM output relay	Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
LS1	COM	Ground	> 100 Gohm	> 10 Megohms	Acc
LS1	NO	Ground	> 100 Gohm	> 10 Megohms	Acc
LS1	COM	NO	> 2.4 Gohm	> 10 Megohms	Acc

Relate Acc 4/7/00

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CX

Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS1, PLS1 OM

Page 5 of 9

PLS1 OM output relay	Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
LS2	COM	Ground	>100Gohm	> 10 Megohms	Acc
LS2	NO	Ground	>100Gohm	> 10 Megohms	Acc
LS2	COM	NO	>1.16 Gohm	> 10 Megohms	Acc
LS3	COM	Ground	>100Gohm	> 10 Megohms	Acc
LS3	NO	Ground	>100Gohm	> 10 Megohms	Acc
LS3	COM	NO	>1.17 Gohm	> 10 Megohms	Acc
LS4	COM	Ground	>100Gohm	> 10 Megohms	Acc
LS4	NO	Ground	>100Gohm	> 10 Megohms	Acc
LS4	COM	NO	>1.27Gohm	> 10 Megohms	Acc
LS4	COM	Ground		> 10 Megohms	
LS4	NO	Ground		> 10 Megohms	
LS4	COM	NO		> 10 Megohms	
LS1	COM	Ground		> 10 Megohms	
LS1	NO	Ground		> 10 Megohms	
LS1	COM	NO		> 10 Megohms	
LS2	COM	Ground		> 10 Megohms	
LS2	NO	Ground		> 10 Megohms	
LS2	COM	NO		> 10 Megohms	
LS3	COM	Ground		> 10 Megohms	
LS3	NO	Ground		> 10 Megohms	
LS3	COM	NO		> 10 Megohms	
LS4	COM	Ground		> 10 Megohms	
LS4	NO	Ground		> 10 Megohms	
LS4	COM	NO		> 10 Megohms	
LS5	COM	Ground	>100Gohm	> 10 Megohms	Acc
LS5	NO	Ground	>100Gohm	> 10 Megohms	Acc
LS5	COM	NO	>1.21Gohm	> 10 Megohms	Acc
LS6	COM	Ground	>100Gohm	> 10 Megohms	Acc
LS6	NO	Ground	>100Gohm	> 10 Megohms	Acc
LS6	COM	NO	>1.28Gohm	> 10 Megohms	Acc
LS7	COM	Ground	>100Gohm	> 10 Megohms	Acc
LS7	NO	Ground	>100Gohm	> 10 Megohms	Acc
LS7	COM	NO	>1.24Gohm	> 10 Megohms	Acc

3/8/00

Delet

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CX

Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS1, PLS1 OM

Page 6 of 9

PLS1 OM output relay	Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
LS8	COM	Ground	>1000ohm	> 10 Megohms	Acc
LS8	NO	Ground	>1000ohm	> 10 Megohms	Acc
LS8	COM	NO	>1.20Gohm	> 10 Megohms	Acc
LS9	COM	Ground	>1000ohm	> 10 Megohms	Acc
LS9	NO	Ground	>1000ohm	> 10 Megohms	Acc
LS9	COM	NO	>1.22Gohm	> 10 Megohms	Acc
LS10	COM	Ground	>1000ohm	> 10 Megohms	Acc
LS10	NO	Ground	>1000ohm	> 10 Megohms	Acc
LS10	COM	NO	>1.19Gohm	> 10 Megohms	Acc
LS11	COM	Ground	>1000ohm	> 10 Megohms	Acc
LS11	NO	Ground	>1000ohm	> 10 Megohms	Acc
LS11	COM	NO	>1.20Gohm	> 10 Megohms	Acc
LS12	COM	Ground	>1000ohm	> 10 Megohms	Acc
LS12	NO	Ground	>1000ohm	> 10 Megohms	Acc
LS12	COM	NO	>1.17Gohm	> 10 Megohms	Acc
LS13	COM	Ground	>1000ohm	> 10 Megohms	Acc
LS13	NO	Ground	>1000ohm	> 10 Megohms	Acc
LS13	COM	NO	>1.25Gohm	> 10 Megohms	Acc
LS14	COM	Ground	>1000ohm	> 10 Megohms	Acc
LS14	NO	Ground	>1000ohm	> 10 Megohms	Acc
LS14	COM	NO	>1.20Gohm	> 10 Megohms	Acc
LS15	COM	Ground	>1000ohm	> 10 Megohms	Acc
LS15	NO	Ground	>1000ohm	> 10 Megohms	Acc
LS15	COM	NO	>1.22Gohm	> 10 Megohms	Acc
LS16	COM	Ground	>1000ohm	> 10 Megohms	Acc
LS16	NO	Ground	>1000ohm	> 10 Megohms	Acc
LS16	COM	NO	>1.20Gohm	> 10 Megohms	Acc

2.6 De-energize test equipment.

2.7 Terminate the test.

2.7.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.

2.7.2 Retorque the terminals to 12 in-pounds.

Dedication Test Plan - IST	Rev. Nb. 0
Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CX	
Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS1, PLS1 OM	Page 7 of 9

2.7.3 Remove lockout/tagout and restore system to normal.

2.7.4 Record: Date /Time of Test End: 03-08-00

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 9

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Devices under test passed all parameters.

Michael Ray Cram
03-08-00

Notes:

Certified Instrumentation Technician (signature) *Michael Cram* Date: 03-08-00
Reviewed By: J. Coakley 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/8/00} *[Signature]* Date: 3/8/00

QA/QC (signature) *[Signature]* Date: 3/13/00
TZ ANDERSON

LIFTED LEAD LOG

MHM Control Console

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-33056	9	101X	LS1	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1001X	LS1	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101X	LS2	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1003X	LS2	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101X	LS3	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1005X	LS3	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101X	LS4	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1007X	LS4	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101X	LS5	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1009X	LS5	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101X	LS6	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1011X	LS6	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101X	LS7	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	1013X	LS7	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101X	LS8	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	10A20X	LS8	NO	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	101X	LS9	COM	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00

Remarks:

SNF-6315, Rev. 0

Page 804

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-003C-TP-003CX

Test Specimen: Gemco PLS and Output Relay Module; Eqmt. No.: PLS1, PLS1 OM

Rev. No. 0

Page 9 of 9

LIFTED LEAD LOG

MHM Control Console

					LIFTED BY	DATE	LIFT VERIFY	DATE	LAND BY	DATE	LAND VERIFY	DATE
EB-33056	9	10A21X	LS9	NO	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	101X	LS10	COM	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	10A22X	LS10	NO	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	101X	LS11	COM	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	10A23X	LS11	NO	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	101X	LS12	COM	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	10A24X	LS12	NO	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	101X	LS14	COM	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	10A26X	LS14	NO	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	101X	LS15	COM	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	10A27X	LS15	NO	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	101X	LS16	COM	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	10A28X	LS16	NO	JWE	3-8-00	SRC	3-8-00	JWE	3-8-00	SRC	3-8-00
EB-33056	9	101X	PLS OMI	Power	JWE	3/8/00	SRC	3-8-00	JWE	3/8/00	SRC	3-8-00
EB-33056	9	102X	PLS OMI	Ac	JWE	3/8/00	SRC	3-8-00	JWE	3/8/00	SRC	3-8-00

JWE
3/8/00

Remarks:

SNF-6315, Rev. 0

Page 805

Dedication Test	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003D-TP-003DX	
Test Specimen: Idec RH1B-U-DC24V Relay	Page 1 of 3

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) Harry Swenson Date: 4/4/00

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120VAC.

Power Supply capable of 1 watt @ 24 VDC.

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) serial numbers and calibration due

Test Instrument type: AYO BM221 I.D.: BAT 137 Calib. Due dates 3-14-01

Test Instrument type: HP3457A I.D.: BAT 124 Calib. Due dates 7-30-00

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due dates 5-28-00

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Relay

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	OK	Idec	Acc
Model:	OK	RH1B-U-DC24V	Acc
Terminal Configuration:	OK	Blade terminals	Acc
Serial No.:	OK LS13X	N/A	Acc

Perform the following tests:

Record: Date /Time of Test Beginning: 04-05-00 8:15 a.m.

Record: Room Temperature: 68 °F.

Perform steps below:

Page 807

Dedication Test	Rev. No 0
Test Plan No.: CGI-SNF-D-MHM-003D-TP-003DX	
Test Specimen: Idac RH1B-U-DC24V Relay	Page 2 of 3

1. Operation

Regulate voltage to the coil of the relay and monitor the max. pick-up voltage and min. drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	15.906 vdc	19.2 VDC Maximum	Acc
Drop-out Voltage	5.697 vdc	2.4 VDC minimum	Acc

2. Contact Rating Test

Setup the Relay specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	1.443 vdc	< 0.5 Volts AC drop	Acc

Apply a nominal 10 amps, resistive VAC, @ across the closed NO contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	1.521 vdc	< 0.5 Volts AC drop	Acc

3. Insulation Resistance Test

Setup the Relay specimen for insulation resistance testing. Attach Relay in its normal mounting configuration to grounded fixture.

Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground				
Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	5	> 999 Mohm	> 10 Megohms	Acc
5	9	> 999 Mohm	> 10 Megohms	Acc
1	Ground	> 999 Mohm	> 10 Megohms	Acc
5	Ground	> 999 Mohm	> 10 Megohms	Acc
9	Ground	> 999 Mohm	> 10 Megohms	Acc
13	Ground	> 999 Mohm	> 10 Megohms	Acc
14	Ground	> 999 Mohm	> 10 Megohms	Acc

Page 808

Dedication Test	Rev. No/0
Test Plan No.: CGI-SNF-D-MHM-003D-TP-003DX	
Test Specimen: Idec RH1B-U-DC24V Relay	Page 3 of 3

4. De-energize equipment.
5. End test.
6. Carefully disassemble test leads to Relay specimen.
7. Clean, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 04-05-00 9:12 a.m.

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable.
Michael Cram
04-05-00

Notes:

Test Engineer/Technician (Printed Name) Michael Cram

Test Engineer/Technician (signature) Michael Cram Date: 04-05-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.


Design Authority (signature) [Signature] Date: 4-6-00

QA/QC (signature) Stephen Scott Moss Date: 4-6-2000

RH Series — General Purpose Midget Relays

Key features of the RH series include:

- Compact midget size saves space
- High switching capacity (10A)
- Choice of blade or PCB style terminals
- Relay options include indicator light, check button, and top mounting bracket
- DIN rail, surface, panel, and PCB type sockets available for a wide range of mounting applications



UL Recognized
Files No. E67770
E59804
E64245



CSA Certified
File No. LR35144



File No. BL951113332319



D

Contact Material	Silver cadmium oxide.
Contact Resistance	50mΩ maximum (initial value)
Minimum Applicable Load	24V DC/30mA, 5V DC/100mA (reference value)
Operating Time	SPDT (RH1), DPDT (RH2): 20ms maximum 3PDT (RH3), 4PDT (RH4): 25ms maximum
Release Time	SPDT (RH1), DPDT (RH2): 20ms maximum 3PDT (RH3), 4PDT (RH4): 25ms maximum
Power Consumption	SPDT (RH1): DC: 0.8W AC: 1.1VA (50Hz), 1VA (60Hz) DPDT (RH2): DC: 0.9W AC: 1.4VA (50Hz), 1.2VA (60Hz) 3PDT (RH3): DC: 1.5W AC: 2VA (50Hz), 1.7VA (60Hz) 4PDT (RH4): DC: 1.5W AC: 2.5VA (50Hz), 2VA (60Hz)
Insulation Resistance	100MΩ min (measured with a 500V DC megger)
Dielectric Strength	SPDT (RH1) Between live and dead parts: 2,000V AC, 1 minute; Between contact circuit and operating coil: 2,000V AC, 1 minute; Between contacts of the same pole: 1,000V AC, 1 minute DPDT (RH2), 3PDT (RH3), 4PDT (RH4) Between live and dead parts: 2,000V AC, 1 minute; Between contact circuit and operating coil: 2,000V AC, 1 minute; Between contact circuits: 2,000V AC, 1 minute; Between contacts of the same pole: 1,000V AC, 1 minute
Frequency Response	1,800 operations/hour
Temperature Rise	Coil: 85°C maximum Contact: 65°C maximum
Vibration Resistance	0 to 6G (55Hz maximum)
Shock Resistance	SPDT/DPDT: 200N (approximately 20G) 3PDT/4PDT: 100N (approximately 10G)
Life Expectancy	Electrical: over 500,000 operations at 120V AC, 10A; (over 200,000 operations at 120V AC, 10A for SPDT (RH1), 3PDT (RH3), 4PDT (RH4)) Mechanical: 50,000,000 operations
Operating Temperature	-30 to +70°C
Weight	SPDT: 24g, DPDT: 37g (approximately) 3PDT: 50g, 4PDT: 74g (approximately)

Specifications

Operational Characteristics

Maximum Continuous Applied Voltage (AC/DC) at 20°C	110% of the rated voltage
Minimum Operating Voltage (AC/DC) at 20°C	80% of the rated voltage
Drop-Out Voltage (AC)	30% or more of the rated voltage
Drop-Out Voltage (DC)	10% or more of the rated voltage

Ordering Information

Order standard voltages for fastest delivery. Allow extra delivery time for non-standard voltages.

Basic Part No.	Coil Voltage:
RH2B-U	AC110-120V



See page D-29 for dimensions.

Relays

RH Series **idec**

Part Numbers

Part Numbers: RH Series with Options

Termination	Contact Configuration	Basic Part No.	Indicator Light	Check Button	Indicator Light and Check Button	Top Bracket
B (blade)	SPDT	RH1B-U	RH1B-L*	—	—	RH1B-UT
	DPDT	RH2B-U	RH2B-UL	RH2B-UC	RH2B-ULC	RH2B-UT
	3PDT	RH3B-U	RH3B-UL	RH3B-UC	RH3B-ULC	RH3B-UT
	4PDT	RH4B-U	RH4B-UL	RH4B-UC	RH4B-ULC	RH4B-UT
V2 (PCB 0.078" [2mm] wide)	SPDT	RH1V2-U	RH1V2-L*	—	—	—
	DPDT	RH2V2-U	RH2V2-UL	RH2V2-UC	RH2V2-ULC	—
	3PDT	RH3V2-U	RH3V2-UL	RH3V2-UC	RH3V2-ULC	—
	4PDT	RH4V2-U	RH4V2-UL	RH4V2-UC	RH4V2-ULC	—

1. * RH1B(V2)-L is not UL recognized.





2. For Coil and Contact Ratings, see the next page.

D Part Numbers: Sockets

Relay	Standard DIN Rail Mount	Finger-Safe DIN Rail Mount	Surface Mount	Panel Mount	PCB Mount	Spring (optional)
RH1B	SH1B-05	SH1B-05C	—	SH1B-51	SH1B-62	SY2S-02F1 SFA-101 SFA-202 SY4S-51F1 SFA-301 SFA-302
RH2B	SH2B-05	SH2B-05C	SH2B-02	SH2B-51	SH2B-62	SY4S-02F1 SFA-101 SFA-202 SY4S-51F1
RH3B	SH3B-05	SH3B-05C	—	SH3B-51	SH3B-62	SH3B-05F1 SFA-101, -202 SY4S-51F1
RH4B	SH4B-05	SH4B-05C	—	SH4B-51	SH4B-62	SH4B-02F1 SFA-101, -202 SY4S-51F1

3. See Section F for details on sockets. All DIN rail mount sockets shown above can be mounted using DIN rail BNDN1000.

Internal Circuit



Ratings

Coil Ratings

Rated Voltage	Rated Current ±15% at 20°C								Coil Resistance ±15% at 20°C			
	60Hz				50Hz				SPDT	DPDT	3PDT	4PDT
	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT				
6V	150mA	200mA	280mA	330mA	170mA	238mA	330mA	387mA	18.8Ω	9.4Ω	6.0Ω	5.4Ω
12V	75mA	100mA	140mA	165mA	86mA	118mA	165mA	196mA	76.8Ω	39.3Ω	25.3Ω	21.2Ω
24V	37mA	50mA	70mA	83mA	42mA	59.7mA	81mA	98mA	300Ω	153Ω	103Ω	84.5Ω
120V*	7.5mA	11mA	14.2mA	16.5mA	8.6mA	12.9mA	16.4mA	19.5mA	7,680Ω	4,170Ω	2,770Ω	2,220Ω
240V†	3.2mA	5.5mA	7.1mA	8.3mA	3.7mA	6.5mA	8.2mA	9.8mA	3,1200Ω	15,210Ω	12,100Ω	9,120Ω
6V	128mA	150mA	240mA	250mA	47Ω	40Ω	25Ω	24Ω				
12V	64mA	75mA	120mA	125mA	188Ω	160Ω	100Ω	96Ω				
24V	32mA	36.9mA	60mA	62mA	750Ω	650Ω	400Ω	388Ω				
48V	18mA	18.5mA	30mA	31mA	2,660Ω	2,600Ω	1,600Ω	1,550Ω				
110V†	8mA	9.1mA	12.8mA	15mA	13,800Ω	12,100Ω	8,600Ω	7,340Ω				



* For RH2 relays = 110-120V AC.
 † For RH2 relays = 220-240V AC.
 ‡ For RH2 relays = 100-110V DC.





Contact Ratings

Voltage	Rating	Resistive				Inductive				Motor Load	
		SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT
28V DC	UL	10A	10A	10A	10A	7.5A	—	—	7.5A	—	—
30V DC	UL	—	—	—	—	—	7A	—	—	—	—
	CSA Nominal	10A	10A	10A	10A	7A	7.5A	7.5A	7.5A	—	—
110V DC	Nominal	0.5A	0.5A	0.5A	0.5A	0.3A	0.3A	0.3A	0.3A	—	—
120V AC	UL	—	—	—	—	7.5A	—	—	—	1/6	1/6
	CSA Nominal	10A	10A	10A	10A	7A	7.5A	7.5A	7.5A	—	—
240V AC	UL	—	—	—	7.5A	7A	7A	—	—	1/3	1/3
	CSA Nominal	10A	10A	—	7.5A	7A	7A	7A	5A	—	—
		7A	7.5A	7.5A	4.5A	5A	5A	5A	—	—	



1. * 6.5:1 pole, 29A total.
 2. Inductive load cos φ = 0.3, L/R = 7ms

Electrical Life Curves



Dedication Test

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003D-TP-003DX

Test Specimen: Idec RH1B-U-DC24V Relay

Page 1 of 3

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) Wang Swenson Date: 4/4/00

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Power Supply capable of 1 watt @ 24 VDC.

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) serial numbers and calibration due

Test Instrument type: Avo BM221 I.D.: BAT 137 Calib. Due dates 3-14-01Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due dates 7-30-00Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due dates 5-28-00

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Relay

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	OK	Idec	Acc
Model:	OK	RH1B-U-DC24V	Acc
Terminal Configuration:	OK	Blade terminals	Acc
Serial No.:	LS9	N/A	Acc

Perform the following tests:

Record: Date /Time of Test Beginning: 04-05-00 10:00 a.m.Record: Room Temperature: 68 °F.

Perform steps below:

Dedication Test
Test Plan No.: CGI-SNF-D-MHM-003D-TP-003DX
Test Specimen: Idec RH1B-U-DC24V Relay

Rev. No. 0

Page 2 of 3

1. Operation

Regulate voltage to the coil of the relay and monitor the max. pick-up voltage and min. drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	16.71 VDC	19.2 VDC Maximum	Acc
Drop-out Voltage	6.05 VDC	2.4 VDC minimum	Acc

2. Contact Rating Test

Setup the Relay specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	12.31 VAC	< 0.5 Volts AC drop	Acc

Apply a nominal 10 amps, resistive VAC, @ across the closed NO contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	15.24 VAC	< 0.5 Volts AC drop	Acc

3. Insulation Resistance Test

Setup the Relay specimen for insulation resistance testing. Attach Relay in its normal mounting configuration to grounded fixture.

Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	5	> 999 Mohm	> 10 Megohms	Acc
5	9	> 999 Mohm	> 10 Megohms	Acc
1	Ground	> 999 Mohm	> 10 Megohms	Acc
5	Ground	> 999 Mohm	> 10 Megohms	Acc
9	Ground	> 999 Mohm	> 10 Megohms	Acc
13	Ground	> 999 Mohm	> 10 Megohms	Acc
14	Ground	> 999 Mohm	> 10 Megohms	Acc

Dedication Test	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003D-TP-003DX	
Test Specimen: Idec RH1B-U-DC24V Relay	Page 3 of 3

4. De-energize equipment.
5. End test.
6. Carefully disassemble test leads to Relay specimen.
7. Clean, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 04-05-00 10:20 a.m.

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was Acceptable.
Michael Cram
04-05-00

Notes:

Test Engineer/Technician (Printed Name) Michael Cram

Test Engineer/Technician (signature) *Michael Cram* Date: 04-05-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.


Design Authority (signature) *Jeff Wang Swenson* Date: 4-6-00

QA/QC (signature) *Stephen Scott Moss* Date: 4-6-2000

RH Series — General Purpose Midget Relays

Key features of the RH series include:

- Compact midget size saves space
- High switching capacity (10A)
- Choice of blade or PCB style terminals
- Relay options include indicator light, check button, and top mounting bracket
- DIN rail, surface, panel, and PCB type sockets available for a wide range of mounting applications



UL Recognized
Files No. E67770
E59804
E64245



CSA Certified
File No. LR35144



File No. BL951113332319



Specifications

Contact Material	Silver cadmium oxide.
Contact Resistance	50mΩ maximum (initial value)
Minimum Applicable Load	24V DC/30mA, 5V DC/100mA (reference value)
Operating Time	SPDT (RH1), DPDT (RH2): 20ms maximum 3PDT (RH3), 4PDT (RH4): 25ms maximum
Release Time	SPDT (RH1), DPDT (RH2): 20ms maximum 3PDT (RH3), 4PDT (RH4): 25ms maximum
Power Consumption	SPDT (RH1): DC: 0.8W AC: 1.1VA (50Hz), 1VA (60Hz) DPDT (RH2): DC: 0.9W AC: 1.4VA (50Hz), 1.2VA (60Hz) 3PDT (RH3): DC: 1.5W AC: 2VA (50Hz), 1.7VA (60Hz) 4PDT (RH4): DC: 1.5W AC: 2.5VA (50Hz), 2VA (60Hz)
Insulation Resistance	100MΩ min (measured with a 500V DC megger)
Dielectric Strength	SPDT (RH1) Between live and dead parts: 2,000V AC, 1 minute; Between contact circuit and operating coil: 2,000V AC, 1 minute; Between contacts of the same pole: 1,000V AC, 1 minute DPDT (RH2), 3PDT (RH3), 4PDT (RH4) Between live and dead parts: 2,000V AC, 1 minute; Between contact circuit and operating coil: 2,000V AC, 1 minute; Between contact circuits: 2,000V AC, 1 minute; Between contacts of the same pole: 1,000V AC, 1 minute
Frequency Response	1,800 operations/hour
Temperature Rise	Coil: 85°C maximum Contact: 65°C maximum
Vibration Resistance	0 to 6G (55Hz maximum)
Shock Resistance	SPDT/DPDT: 200N (approximately 20G) 3PDT/4PDT: 100N (approximately 10G)
Life Expectancy	Electrical: over 500,000 operations at 120V AC, 10A; (over 200,000 operations at 120V AC, 10A for SPDT (RH1), 3PDT (RH3), 4PDT (RH4)) Mechanical: 50,000,000 operations
Operating Temperature	-30 to +70°C
Weight	SPDT: 21g, DPDT: 37g (approximately) 3PDT: 50g, 4PDT: 74g (approximately)

Operational Characteristics

Maximum Continuous Applied Voltage (AC/DC) at 20°C	110% of the rated voltage
Minimum Operating Voltage (AC/DC) at 20°C	80% of the rated voltage
Drop-Out Voltage (AC)	30% or more of the rated voltage
Drop-Out Voltage (DC)	10% or more of the rated voltage

Ordering Information

Order standard voltages for fastest delivery. Allow extra delivery time for non-standard voltages.

Basic Part No.	Coil Voltage:
RH2B-U	AC110-120V



See page D-29 for dimensions.

Relays

RH Series **idec**

Part Numbers

Part Numbers: RH Series with Options

Termination	Contact Configuration	Basic Part No.	Indicator Light	Check Button	Indicator Light and Check Button	Top Bracket
B (blade)	SPDT	RH1B-U	RH1B-L*	—	—	RH1B-UT
	DPDT	RH2B-U	RH2B-UL	RH2B-UC	RH2B-ULC	RH2B-UT
	3PDT	RH3B-U	RH3B-UL	RH3B-UC	RH3B-ULC	RH3B-UT
	4PDT	RH4B-U	RH4B-UL	RH4B-UC	RH4B-ULC	RH4B-UT
V2 (PCB 0.078" [2mm] wide)	SPDT	RH1V2-U	RH1V2-L*	—	—	—
	DPDT	RH2V2-U	RH2V2-UL	RH2V2-UC	RH2V2-ULC	—
	3PDT	RH3V2-U	RH3V2-UL	RH3V2-UC	RH3V2-ULC	—
	4PDT	RH4V2-U	RH4V2-UL	RH4V2-UC	RH4V2-ULC	—


- * RH1B(V2)-L is not UL recognized.
- For Coil and Contact Ratings, see the next page.

D Part Numbers: Sockets

Relay	Standard DIN Rail Mount	Finger-Safe DIN Rail Mount	Surface Mount	Panel Mount	PCB Mount	Spring (optional)
RH1B	SH1B-05	SH1B-05C	—	SH1B-51	SH1B-62	SY2S-02F1 SFA-101 SFA-202 SY4S-51F1 SFA-301 SFA-302
RH2B	SH2B-05	SH2B-05C	SH2B-02	SH2B-51	SH2B-62	SY4S-02F1 SFA-101 SFA-202 SY4S-51F1
RH3B	SH3B-05	SH3B-05C	—	SH3B-51	SH3B-62	SH3B-05F1 SFA-101, -202 SY4S-51F1
RH4B	SH4B-05	SH4B-05C	—	SH4B-51	SH4B-62	SH4B-02F1 SFA-101, -202 SY4S-51F1

- See Section F for details on sockets. All DIN rail mount sockets shown above can be mounted using DIN rail BNDN1000.

Internal Circuit



Ratings

Coil Ratings

Rated Voltage	Rated Current ±15% at 20°C								Coil Resistance ±15% at 20°C			
	60Hz				50Hz				SPDT	DPDT	3PDT	4PDT
	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT				
6V	150mA	200mA	280mA	330mA	170mA	238mA	330mA	387mA	18.8Ω	9.4Ω	6.0Ω	5.4Ω
12V	75mA	100mA	140mA	165mA	86mA	118mA	165mA	196mA	76.8Ω	39.3Ω	25.3Ω	21.2Ω
24V	37mA	50mA	70mA	83mA	42mA	59.7mA	81mA	98mA	300Ω	153Ω	103Ω	84.5Ω
120V*	7.5mA	11mA	14.2mA	16.5mA	8.6mA	12.9mA	16.4mA	19.5mA	7,680Ω	4,170Ω	2,770Ω	2,220Ω
240V†	3.2mA	5.5mA	7.1mA	8.3mA	3.7mA	6.5mA	8.2mA	9.8mA	3,1200Ω	15,210Ω	12,100Ω	9,120Ω
	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT
6V	128mA	150mA	240mA	250mA	47Ω	40Ω	25Ω	24Ω				
12V	64mA	75mA	120mA	125mA	188Ω	160Ω	100Ω	96Ω				
24V	32mA	36.9mA	60mA	62mA	750Ω	650Ω	400Ω	388Ω				
48V	18mA	18.5mA	30mA	31mA	2,660Ω	2,600Ω	1,600Ω	1,550Ω				
110V‡	8mA	9.1mA	12.8mA	15mA	13,800Ω	12,100Ω	8,600Ω	7,340Ω				

* For RH2 relays = 110 120V AC.
† For RH2 relays = 220 240V AC.
‡ For RH2 relays = 100 110V DC.





Contact Ratings

Voltage	Rating	Resistive				Inductive				Motor Load	
		SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT
28V DC	UL	10A	10A	10A	10A	7.5A	—	—	7.5A	—	—
	UL	—	—	—	—	—	7A	—	—	—	—
30V DC	CSA	10A	10A	10A	10A	7A	7.5A	7.5A	7.5A	—	—
	Nominal	—	—	—	—	—	—	—	—	—	—
110V DC	Nominal	0.5A	0.5A	0.5A	0.5A	0.3A	0.3A	0.3A	0.3A	—	—
	UL	—	—	—	—	—	—	—	—	1/6	1/6
120V AC	CSA	10A	10A	10A	10A	7.5A	7.5A	7.5A	7.5A	—	—
	Nominal	—	—	—	—	—	—	—	—	—	—
240V AC	UL	10A	10A	—	7.5A	7A	7A	7A	5A	1/3	1/3
	CSA	—	—	—	—	—	—	—	—	—	—
	Nominal	7A	7.5A	7.5A	4.5A	5A	5A	5A	—	—	—

1. * 6.31 p.u.s. 20A total.
2. Inductive load cos φ = 0.3. L/R = 7ms.

Electrical Life Curves



Dedication Test

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003D-TP-003DX

Test Specimen: Idec RH1B-U-DC24V Relay

Page 1 of 3

Test Procedure Approval (Obtain prior to testing):

This test procedure adequately tests the critical characteristics of the test specimen upon acceptable completion of the testing.

Design Authority (signature) Lang Swenson Date: 4/4/00

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120VAC.

Power Supply capable of 1 watt @ 24 VDC.

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) serial numbers and calibration due

Test Instrument type: AVOBU221 I.D.: BAT 137 Calib. Due dates 3-14-01Test Instrument type: HP3457A I.D.: BAT 124 Calib. Due dates 7-30-00Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due dates 5-28-00

SAFETY INSTRUCTIONS: PERSONNEL SAFETY— personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE: (Note: use one set of sheets per test specimen)

Test Specimen Description: Relay

Record the following identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Manufacturer:	OK	Idec	Acc
Model:	OK	RH1B-U-DC24V	Acc
Terminal Configuration:	OK	Blade terminals	Acc
Serial No.:	LS1Y	N/A	Acc

Perform the following tests:

Record: Date /Time of Test Beginning: 04-05-00 10:20 a.m.

Record: Room Temperature: 68 °F.

Perform steps below:

Dedication Test	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003D-TP-003DX	
Test Specimen: Idec RH1B-U-DC24V Relay	Page 2 of 3

1. Operation

Regulate voltage to the coil of the relay and monitor the max. pick-up voltage and min. drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	15.67 VDC	19.2 VDC Maximum	Acc
Drop-out Voltage	6.11 VDC	2.4 VDC minimum	Acc

2. Contact Rating Test

Setup the Relay specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used.

Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	0.995 VAC	< 0.5 Volts AC drop	Acc

Apply a nominal 10 amps, resistive VAC, @ across the closed NO contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	14.68 VAC	< 0.5 Volts AC drop	Acc

3. Insulation Resistance Test

Setup the Relay specimen for insulation resistance testing. Attach Relay in its normal mounting configuration to grounded fixture.

Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Describe the terminals and their data below:

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
1	5	>999 Mohm	> 10 Megohms	Acc
5	9	>999 Mohm	> 10 Megohms	Acc
1	Ground	>999 Mohm	> 10 Megohms	Acc
5	Ground	>999 Mohm	> 10 Megohms	Acc
9	Ground	>999 Mohm	> 10 Megohms	Acc
13	Ground	>999 Mohm	> 10 Megohms	Acc
14	Ground	>999 Mohm	> 10 Megohms	Acc

Dedication Test	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003D-TP-003DX	
Test Specimen: Idec RH1B-U-DC24V Relay	Page 3 of 3

4. De-energize equipment.
5. End test.
6. Carefully disassemble test leads to Relay specimen.
7. Clean, box (in original packing & paperwork) and ready the test specimen for transfer to buyer.

Record: Date /Time of Test End: 04-05-00 10:30 a.m.

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable.
Michael Cram
04-05-00

Notes:

Test Engineer/Technician (Printed Name) Michael Cram

Test Engineer/Technician (signature) Michael Cram Date: 04-05-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.


Design Authority (signature) Jeff Craig Swenson Date: 4-6-00

QA/QC (signature) Stephen Scott Moss Date: 4-6-2000

RH Series — General Purpose Midget Relays

Key features of the RH series include:

- Compact midget size saves space
- High switching capacity (10A)
- Choice of blade or PCB style terminals
- Relay options include indicator light, check button, and top mounting bracket
- DIN rail, surface, panel, and PCB type sockets available for a wide range of mounting applications



UL Recognized
Files No. E67770
E59804
E64245



CSA Certified
File No. LR35144



File No. BL951113332319



D

Contact Material	Silver cadmium oxide -
Contact Resistance	50mΩ maximum (initial value)
Minimum Applicable Load	21V DC/30mA, 5V DC/100mA (reference value)
Operating Time	SPDT (RH1), DPDT (RH2): 20ms maximum 3PDT (RH3), 4PDT (RH4): 25ms maximum
Release Time	SPDT (RH1), DPDT (RH2): 20ms maximum 3PDT (RH3), 4PDT (RH4): 25ms maximum
Power Consumption	SPDT (RH1): DC: 0.8W AC: 1.1VA (50Hz), 1VA (60Hz) DPDT (RH2): DC: 0.9W AC: 1.4VA (50Hz), 1.2VA (60Hz) 3PDT (RH3): DC: 1.5W AC: 2VA (50Hz), 1.7VA (60Hz) 4PDT (RH4): DC: 1.5W AC: 2.5VA (50Hz), 2VA (60Hz)
Insulation Resistance	100MΩ min (measured with a 500V DC megger)
Dielectric Strength	SPDT (RH1) Between live and dead parts: 2,000V AC, 1 minute; Between contact circuit and operating coil: 2,000V AC, 1 minute; Between contacts of the same pole: 1,000V AC, 1 minute DPDT (RH2), 3PDT (RH3), 4PDT (RH4) Between live and dead parts: 2,000V AC, 1 minute; Between contact circuit and operating coil: 2,000V AC, 1 minute; Between contact circuits: 2,000V AC, 1 minute; Between contacts of the same pole: 1,000V AC, 1 minute
Frequency Response	1,800 operations/hour
Temperature Rise	Coil: 85°C maximum Contact: 65°C maximum
Vibration Resistance	0 to 6G (55Hz maximum)
Shock Resistance	SPDT/DPDT: 200N (approximately 20G) 3PDT/4PDT: 100N (approximately 10G)
Life Expectancy	Electrical: over 500,000 operations at 120V AC, 10A; (over 200,000 operations at 120V AC, 10A for SPDT (RH1), 3PDT (RH3), 4PDT (RH4)) Mechanical: 50,000,000 operations
Operating Temperature	-30 to +70°C
Weight	SPDT: 24g, DPDT: 37g (approximately) 3PDT: 50g, 4PDT: 74g (approximately)

Specifications

Operational Characteristics

Maximum Continuous Applied Voltage (AC/DC) at 20°C	110% of the rated voltage
Minimum Operating Voltage (AC/DC) at 20°C	80% of the rated voltage
Drop-Out Voltage (AC)	30% or more of the rated voltage
Drop-Out Voltage (DC)	10% or more of the rated voltage

Ordering Information

Order standard voltages for fastest delivery; Allow extra delivery time for non-standard voltages.

Basic Part No.	Coil Voltage:
RH2B-U	AC110-120V

See page D-29 for dimensions.

Relays

RH Series



Part Numbers

Part Numbers: RH Series with Options

Termination	Contact Configuration	Basic Part No.	Indicator Light	Check Button	Indicator Light and Check Button	Top Bracket
B (blade)	SPOT	RH1B-U	RH1B-L*	—	—	RH1B-UT
	DPOT	RH2B-U	RH2B-UL	RH2B-UC	RH2B-ULC	RH2B-UT
	3POT	RH3B-U	RH3B-UL	RH3B-UC	RH3B-ULC	RH3B-UT
	4POT	RH4B-U	RH4B-UL	RH4B-UC	RH4B-ULC	RH4B-UT
V2 (PCB 0.078" [2mm] wide)	SPOT	RH1V2-U	RH1V2-L*	—	—	—
	DPOT	RH2V2-U	RH2V2-UL	RH2V2-UC	RH2V2-ULC	—
	3POT	RH3V2-U	RH3V2-UL	RH3V2-UC	RH3V2-ULC	—
	4POT	RH4V2-U	RH4V2-UL	RH4V2-UC	RH4V2-ULC	—


- * RH1B(V2)-L is not UL recognized.
- For Coil and Contact Ratings, see the next page.

D Part Numbers: Sockets

Relay	Standard DIN Rail Mount	Finger-Safe DIN Rail Mount	Surface Mount	Panel Mount	PCB Mount	Spring (optional)
RH1B	SH1B-05	SH1B-05C	—	SH1B-51	SH1B-62	SY2S-02F1 SFA-101 SFA-202 SY4S-51F1 SFA-301 SFA-302
RH2B	SH2B-05	SH2B-05C	SH2B-02	SH2B-51	SH2B-62	SY4S-02F1 SFA-101 SFA-202 SY4S-51F1
RH3B	SH3B-05	SH3B-05C	—	SH3B-51	SH3B-62	SH3B-05F1 SFA-101, -202 SY4S-51F1
RH4B	SH4B-05	SH4B-05C	—	SH4B-51	SH4B-62	SH4B-02F1 SFA-101, -202 SY4S-51F1

- See Section F for details on sockets. All DIN rail mount sockets shown above can be mounted using DIN rail BNDN1000.

Internal Circuit



Ratings

Coil Ratings

Rated Voltage	Rated Current ±15% at 20°C								Coil Resistance ±15% at 20°C			
	60Hz				50Hz				SPDT	DPDT	3PDT	4PDT
	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT				
6V	150mA	200mA	280mA	330mA	170mA	238mA	330mA	387mA	18.8Ω	9.4Ω	6.0Ω	5.4Ω
12V	75mA	100mA	140mA	165mA	86mA	118mA	165mA	196mA	76.8Ω	39.3Ω	25.3Ω	21.2Ω
24V	37mA	50mA	70mA	83mA	42mA	59.7mA	81mA	98mA	300Ω	153Ω	103Ω	84.5Ω
120V*	7.5mA	11mA	14.2mA	16.5mA	8.6mA	12.9mA	16.4mA	19.5mA	7,680Ω	4,170Ω	2,770Ω	2,220Ω
240V†	3.2mA	5.5mA	7.1mA	8.3mA	3.7mA	6.5mA	8.2mA	9.8mA	3,1200Ω	15,210Ω	12,100Ω	9,120Ω
	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT
6V	128mA	150mA	240mA	250mA	47Ω	40Ω	25Ω	24Ω				
12V	64mA	75mA	120mA	125mA	188Ω	160Ω	100Ω	96Ω				
24V	32mA	36.9mA	60mA	62mA	750Ω	650Ω	400Ω	388Ω				
48V	18mA	18.5mA	30mA	31mA	2,660Ω	2,600Ω	1,600Ω	1,550Ω				
110V‡	8mA	9.1mA	12.8mA	15mA	13,800Ω	12,100Ω	8,600Ω	7,340Ω				

* For RH2 relays = 110 120V AC.
 † For RH2 relays = 220 240V AC.
 ‡ For RH2 relays = 100 110V DC.





Contact Ratings

Voltage	Rating	Resistive				Inductive				Motor Load	
		SPDT	DPDT	3PDT	4PDT	SPDT	DPDT	3PDT	4PDT	SPDT	DPDT
28V DC	UL	10A	10A	10A	10A	7.5A	—	—	7.5A	—	—
	UL	—	—	—	—	—	7A	—	—	—	—
30V DC	CSA	10A	10A	10A	10A	7A	7.5A	—	—	—	—
	Nominal	—	—	—	—	—	7.5A	7.5A	—	—	—
110V DC	Nominal	0.5A	0.5A	0.5A	0.5A	0.3A	0.3A	0.3A	0.3A	—	—
	UL	—	—	—	—	—	—	—	—	1/6	1/6
120V AC	CSA	10A	10A	10A	10A	7.5A	—	—	7.5A	—	—
	Nominal	—	—	—	—	7A	7.5A	7.5A	—	—	—
240V AC	UL	10A	10A	—	7.5A	7A	7A	—	—	1/3	1/3
	CSA	—	—	—	—	—	—	—	—	—	—
	Nominal	7A	7.5A	7.5A	4.5A	5A	5A	5A	—	—	—

1. * 6.5A p-pk, 20A total.
 2. Inductive load cos φ = 0.3, L/R = 7ms.



Electrical Life Curves



CGI REMOVAL/REPLACEMENT LOG

ORIGINAL

Equipment ID No.	Equipment Description	Removd By*	Date	Removal Verified By*	Date	Replaced By*	Date	Replacement Verified By*	Date
PLS1/LS13	RELAY	SRC	3-29-00	SRC	3-29-00	SRC	4-12-00	SRC/CEE	4-12-00
PLS2/LS1	RELAY	SRC	3-29-00	SRC	3-29-00	SRC	4-12-00	SRC/CEE	4-12-00
PLS2/LS9	RELAY	SRC	3-29-00	SRC	3-29-00	SRC	4-12-00	SRC/CEE	4-12-00

Personnel Identification Section

Title	Printed Name	Signature	Initials
Electrician	Steve Conneley		SRC
Design Authority	Craig Swenson	Craig Swenson	CEE

Remarks:

* Complete Title, Printed Name, Signature and Initials in Personnel Identification Section

SNF-6315, Rev. 0

Page 8214

Swenson, Craig E

From: Swenson, Craig E
Sent: Tuesday, April 11, 2000 3:19 PM
To: Keimel, Gary J
Cc: Swenson, Craig E; Price, Larry W; Molnar, Jon C
Subject: MHM PLS Idec Relay Replacement

Pls replace the 3 PLS 3 small Idec relays (RH1B-U DC24V, serial #27610) and complete the removal/replacement form. Return the completed replacement form to me.

Thx,
Craig E. Swenson, P.E.
MHM BTR & Design Authority
509-376-0288

PCE Mark

Please Have Steve

do this today.
charge to In Situ CO #53

AK

AK

Complete

4/12/00 AK

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A CGI No. CGI-SNF-D-MHM-003B
Title: MHM Interlocks P6, P52, P53, P57 and P61 - Gemco Cables

Page 1 of 8

Section 1 Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
Part Description: <u>N/A</u>		
End Use Description: <u>N/A</u>		

ORIGINAL

Section 2a Component Information

Equipment No.: <u>RSVMGHX, RSVMGHY</u>	Specification No.: <u>Ederer F-2566, Foster Wheeler MJX-SDX 452656</u>	Manufacturer: <u>GEMCO</u>	Past P.O. No.: <u>N/A</u>
Manufacturer's Part/Model No.: <u>SD0334900 and SD0336100</u>	Equipment Supplier (if different from manufacturer): <u>ALSTOM, Foster Wheeler</u>	Equip. Supplier's Part No.: <u>N/A</u>	
Component Description: <u>SD0334900 is the connector cable between the Resolver and the PLS. SD0336100 is the connector cable between the PLS and the Output Module.</u>			

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
 YES (go to #2 below) NO (go to procedure step 6.3.2-dedicate Item)
 If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier?
 YES (go to #2 below, procedure step 6.3.2, & dedicate Item) NO (procedure step 6.3.2-dedicate Item).

2. List of Candidate qualified NQA1 suppliers or of ISO 9000 suppliers, if used. N/A

1. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)

All three criteria have been satisfied. The Item meets the definition of commercial grade.

Section 2d Reason for Dedication

The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):

Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.

Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.

Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.

Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.

Other ('like-for-like', similar, substitution, replacement evaluation)

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 2 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-003B
Title: MHM Interlocks P6, P52, P53, P57 and P61 - Gemco Cables

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. SD0334900 transmits the rotational position of the turret from the resolver to the PLS. SD0336100 transmits the PLS logic to the Output Module to activate the output relays.

B. Part/Component Functional Mode:

Safety Function #1: Active Passive
 Safety Function #2: Active Passive
 Safety Function #3: Active Passive

Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function
 Passive - Change of state is not required for the component to perform its safety function

C. Host Component Safety Function (if applicable): N/A

1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

1. Failure of the cables to transmit signals by either short circuit or open circuit could provide incorrect information to the PLS or the Output Module and defeat the safety function of the P-6 interlock.

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required:

Yes
 No

If yes: Environmental Qualification Requirements
 Limiting Environmental Conditions:
 Required Safety Functions:
 Qualification Period:

Natural Phenomena Hazard (NPH) Design Required:

Yes
 No

If yes: NPH Design Requirements
 Performance Category:
 NPH Design Req'ts.:
 Required Safety Functions:

Section 5 Component Functional Classification

<input checked="" type="checkbox"/>	Safety Class (SC)	<input type="checkbox"/>	General Service (GS)	<input type="checkbox"/>	Safety Significant (SS)
-------------------------------------	-------------------	--------------------------	----------------------	--------------------------	-------------------------

If part/component classification is different from host component/system, document basis. N/A

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: N/A
 Safety Analysis Report (SAR): HNF-3672, Rev. 0
 Drawings: Ederer, Inc. EB-33056, Sht 9
 Vendor Manual/Manufacturer/Supplier Information: GEMCO Series 1989: Quik-Set III High Resolution Single Turn and Multi-turn PLS
 Other: ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998

Commercial Grade Item Upgrade Dedication Form

Rev. No. 21
Page 3 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-003B
Title: MHM Interlocks P6, P52, P53, P57 and P61 - Gemco Cables

SNF-6315, Rev. 0

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acc Meth	ID	Function
Gemco Cable SD0334900				
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
N/A				
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
N/A				
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Insulation resistance	> 10 megohm resistance each wire to shield ground and wire to wire at 500 VDC	1, T		X
Wire Continuity	No open circuits	1, T		X
Gemco Cable SD0336100				
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
None				
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
3 Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Insulation resistance	> 10 megohm resistance each wire to shield ground and wire to wire at 500 VDC	1, T		X
Wire Continuity	No open circuits	1, T		X
4. Notes and Legend				Acceptance Method (Acc Meth):
Rev 2 was issued due to supplier, Gemco, using a variety of cable manufacturers. Therefore, only performance characteristics will be verified.				1. Special Test and Inspection: 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 2. Vendor/Item History

Section 10 Initial Review and Approval	
Approvals:	
Designated Engineer: <u>[Signature]</u>	
Design Authority: <u>[Signature]</u> 3/6/00	
QA Engineer: <u>[Signature]</u> 3/8/00 TZANDERSON	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 4 of 8

ECN No. NA CGI No. CGI-SNF-D-MHM-003B
Title: MHM Interlocks P6, P52, P53, P57 and P61 - Gemco Cables

SNF-6315, Rev. 0

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.	X	Open circuit would not allow transmission of information to perform safety function.
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Cables provides incorrect position to CPU to energize permissive circuit.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.		
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2: Additional Failure Modes Applicable to the Component Under Evaluation			
1.			
2.			
3.			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A

CGI No. CGI-SNF-D-MHM-003B

Page 5 of 8

Title: MHM Interlocks P6, P52, P53, P57 and P61 - Gemco Cables

SNF-6315, Rev. 0

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1

Item Description: Resolver Cable and PLS to relay module cable System #: MHM	Equip #: None Model #: SD0334900, SD0336100
---	--

Manufacturer (Address/Phone): GEMCO/PATRIOT 1080 N. Crooks Rd Clawson, MI 48017-1097 (810) 435-0700	Supplier (Address/Phone): N/A
---	----------------------------------

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	
	X		1. Insulation resistance
	X		2. Wire continuity
			3.

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

N/A

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

GEMCO Cable SD0334900

Characteristic for Test: Insulation resistance Sampling Size*: (X)Normal [Reduced] [Tightened]
 Acceptance Criteria: > 10 megohm resistance each wire to shield ground and wire to wire at 500 VDC
 Actual Test Value: See TP Test Plan and Report #: CGI-SNF-D-MHM-003B - TP-003BIX, B1Y

Characteristic for Test: Wire continuity Sampling Size*: (X)Normal [Reduced] [Tightened]
 Acceptance Criteria: No open circuits
 Actual Test Value: See TP Test Plan and Report #: TP-003BIX, B1Y

GEMCO Cable SD0336100 *

Characteristic for Test: Insulation resistance * Sampling Size*: (X)Normal [Reduced] [Tightened]
 Acceptance Criteria: > 10 megohm resistance each wire to shield ground and wire to wire at 500 VDC
 Actual Test Value: Test Plan and Report #:

Characteristic for Test: Wire continuity * Sampling Size*: (X)Normal [Reduced] [Tightened]
 Acceptance Criteria: No open circuits
 Actual Test Value: Test Plan and Report #:

* THIS CABLE AND THESE TESTS WERE DELETED BECAUSE THE TELEPHONE TYPE WIRE AND TERMINALS WERE SO SMALL THAT REMOVAL TO TEST AND DETERMINATION COULD DO MORE DAMAGE THAN GOOD. SYSTEM WORKS SATISFACTORILY. JWP 4/10/00

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A

CGI No. CGI-SNF-D-MHM-003B

Page 6 of 8

Title: MHM Interlocks P6, P52, P53, P57 and P61 - Gemco Cables

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Gemco Cable SD0334900

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Insulation resistance	> 10 megohm resistance each wire to shield ground and wire to wire at 500 VDC		X	1, T	TP-003 BIX, B1Y	NA	2	0	XWEST	LARRY W. PRICE <i>[Signature]</i>	4/10/00
Circuit Continuity	No open circuits		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-003BIX, -003B1Y

Testing Agency Approval: <u>NR</u> <u>CES</u> <u>4/12/00</u> Date _____	BUYER VERIFICATION
Testing Agency QA Engineer: <u>NR</u> <u>CES</u> <u>4/12/00</u> Date _____	Design Authority: <u>Wang Swenson</u> Date <u>4-12-00</u>
	QA Engineer: <u>Stephen Scott Moore</u> Date <u>4-20-2000</u>

SNF-6315, Rev. 0

Page 831

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A

CGI No. CGI-SNF-D-MHM-003B

Page 7 of 8

Title: MHM Interlocks P6, P52, P53, P57 and P61 – Gemco Cables

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Gemco Cable SD0336100

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Insulation resistance	> 10 megohm resistance each wire to shield ground and wire to wire at 500 VDC		X	1, T	} SEE ASTERISK NOTE ON PAGE 5					YUP 4/10/00	
Circuit Continuity	No open circuits		X	1, T							

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

Testing Agency Approval: _____ Date _____ Testing Agency QA Engineer: _____ Date _____				BUYER VERIFICATION			
Design Authority: _____ Date _____ QA Engineer: _____ Date _____				_____ _____			

SNF-6315, Rev. 0

Page 832

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A CGI No. CGI-SNF-D-MHM-003B

Page 8 of 8

Title: MHM Interlocks P6, P52, P53, P57 and P61 - Gemco Cables

SNF-6315, Rev. 0

SECTION 6 CONTACTS / PHONE NUMBERS

Name	Phone
Design Authority	
QA	
QC	
Cog - Engineer	
CGI Engineer	
Procurement Engineer	
Other	

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents	For Critical Characteristics
Drawings:	
Manuals (specify type & number):	
Design Calculations	
Installation Instructions	
Operation Instructions	
Calibration Instructions	
Manufacturer's Recommended Spare Parts List	
<input checked="" type="checkbox"/> Other: GEMCO Series 1989: Qulk-Set III High Resolution Single Turn and Multi-turn PLS	All
Procurement Documents	For Critical Characteristics
Certificate of Conformance/Compliance	
Seismic Qualification Certificate	
Environmental Qualification Certificate	
Test Report (s):	
Inspection Report (s):	
CMTRs for ASME Pressure Retaining Materials	
Valve Seat Leakage Report	
Weld Record	
Material Traceability Record	
Other:	

Dedication Test Plan - IST
 Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1X
 Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

ORIGINAL

Rev. No. 0

Page 1 of 6

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				Cog. Eng	DA	QA Post Review*
1	As found condition	2.3.1 Table	Residual cable pin J is wire 51H, pin G is 41H. See FCR-1006	ERK 3/10/00	JES 3/10/00	 3/13/00

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST
 Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1X
 Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

ORIGINAL

Rev. No. 0

Page 2 of 6

In-Situ Test Procedure

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *E.R. Kahler* Date: 3-7-00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MC
Electrician	<i>J.W. Eberhart</i>	PCE	<i>J.W. Eberhart</i>	JWE
Electrician Quality Control	Stephen R. Couley	RE	<i>Stephen R. Couley</i>	SRC
Design Authority Representative	E.R. Kahler	Kwest	<i>E.R. Kahler</i>	ERK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being verified unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO BM80/2 I.D.: 0410-889 Calib. Due date: 2/9/01

Test Instrument type: FLUKE 787 I.D.: 6910042 Calib. Due date: 5/28/00

Test Instrument type: PROTO6106 I.D.: 029E/009 Calib. Due date: 01/13/01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1X

Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

Page 3 of 6

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	OK	None	Acc
Manufacturer:	OK	N/A	Acc
Configuration	OK	N/A	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-07-00 1:10 p.m.
Record: Room Temperature: 68 °F.

2.2 Insulation Resistance Test

- 2.2.1 Open main disconnect switch MD and tag out.
- 2.2.2 Disconnect cable from resolver, RSVMGHX and tag cable as energized.
- 2.2.3 At PLS 1, terminal strip S1, lift incoming wire per the Lifted Lead Log.
- 2.2.4 Setup the test equipment for insulation resistance testing.
- 2.2.5 Apply a nominal 500 VDC via Megger device wire to shield ground. Record the resistances.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1X

Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

Page 4 of 6

Resolver Pin / Ground

Desc. of Wire No.	Desc. of Wire No./Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
11H	Ground	> 6.1 Gohm	> 10 Megohms	
21H	Ground	> 6.1 Gohm	> 10 Megohms	
31H	Ground	> 6.1 Gohm	> 10 Megohms	
41H	Ground	> 6.1 Gohm	> 10 Megohms	
51H	Ground	> 5.8 Gohm	> 10 Megohms	
61H	Ground	> 5.8 Gohm	> 10 Megohms	
71H	Ground	> 5.9 Gohm	> 10 Megohms	

2.2.6 Short all wires together except the one being tested. Check with Ohm-meter

2.2.7 Apply a nominal 500 VDC via Megger device wire to wire. Record the resistances

Desc. of Wire No.	Desc. of Wire No	Record Resistance	Acceptance Criteria	Comments/Deviations
11H	Other wires	0 Ohms	None	Verify shorted
Megger 11H	Other wires	> 7.5 Gohms	> 10 Megohms	Acc
21H	Other wires	0 Ohms	None	Verify shorted
Megger 21H	Other wires	> 7.3 Gohms	> 10 Megohms	Acc
31H	Other wires	0 Ohms	None	Verify shorted
Megger 31H	Other wires	> 7.3 Gohms	> 10 Megohms	Acc
41H	Other wires	0 Ohms	None	Verify shorted
Megger 41H	Other wires	> 7.1 Gohms	> 10 Megohms	Acc
51H	Other wires	0 Ohms	None	Verify shorted
Megger 51H	Other wires	> 7.2 Gohms	> 10 Megohms	Acc
61H	Other wires	0 Ohms	None	Verify shorted
Megger 61H	Other wires	> 7.1 Gohms	> 10 Megohms	Acc
71H	Other wires	Shorted 0 Ohms	None	Verify shorted
Megger 71H	Other wires	> 7.5 Gohms	> 10 Megohms	Acc

2.2.6 Remove the Megger device.

2.3 Wire Continuity test

2.3.1 Attach Ohmmeter between resolver cable connector pins and lifted wire at PLS1 to verify wire continuity. Record below:

Desc. of Pin No.	Desc. of Wire No	Record Resistance	Acceptance Criteria	Comments/Deviations
A	11H	0 Ohms	No open circuit	Acc
B	21H	0 Ohms	No open circuit	Acc
H	31H	0 Ohms	No open circuit	Acc
J	51H 41H	0 Ohms	No open circuit	Acc
G	41H 51H	0 Ohms	No open circuit	Acc
K	61H	0 Ohms	No open circuit	Acc
N	71H	0 Ohms	No open circuit	Acc


 3/4/00

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1X

Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

Page 5 of 6

2.3.2 Remove Ohmmeter.

2.4 Terminate the test.

2.4.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.4.2 Retorque the terminals to 12 in-pounds

2.4.3 Re-attach cable to resolver, hand tight.

2.5.2 Record: Date /Time of Test End: 03-08-00 10:12 a.m

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Devices under test passed all parameters

Michael Ray Cram
03-08-00

Notes:

Certified Instrumentation Technician (signature) *Michael Cram* Date: 03-08-00
Received: J. Cadish 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/10/00} *TRK* *Wig Swenson* Date: 3/10/00

QA/QC (signature) *T.J. Anderson* Date: 3/13/00
T J ANDERSON

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	7	P 8X S C50X	RSVMGHX	Cable connector	JWS	3/7/00			JWS			
EB-33056	9	11H	PLS 1	9	JWS	3/7/00	SRL	3-7-00	JWS	3/7/00	SRL	3-7-00
EB-33056	9	21H	PLS 1	10	JWS	3/7/00	SRL	3-7-00	JWS	3/7/00	SRL	3-7-00
EB-33056	9	31H	PLS 1	12	JWS	3/7/00	SRL	3-7-00	JWS	3/7/00	SRL	3-7-00
EB-33056	9	41H	PLS 1	14	JWS	3/7/00	SRL	3-7-00	JWS	3/7/00	SRL	3-7-00
EB-33056	9	51H	PLS 1	13	JWS	3/7/00	SRL	3-7-00	JWS	3/7/00	SRL	3-7-00
EB-33056	9	61H	PLS 1	15	JWS	3/7/00	SRL	3-7-00	JWS	3/7/00	SRL	3-7-00
EB-33056	9	71H	PLS 1	21	JWS	3/7/00	SRL	3-7-00	JWS	3/7/00	SRL	3-7-00
Remarks:												

SNF-6315, Rev. 0

Page 839

Dedication Test Plan - IST
 Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1Y
 Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

ORIGINAL

Rev. No. 0

Page 1 of 6

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				Cog. Eng	DA	QA Post Review*
1	As found condition	2.3.1 Table	Resdoor cable pin J is wire number 52H, G is 42H. See FCR-1006.	ERK 3/14/00	LES 3/10/00	 3/13/00

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1Y

Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

ORIGINAL

Rev. No. 0

Page 2 of 6

In-Situ Test Procedure**Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *Eric Waig Swenson* Date: 3-7-00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MRE
Electrician	<i>J WEBERHART</i>	PCE	<i>J Weberhart</i>	JWB
Electrician Quality Control	Stephen R. Conley	PCE	<i>Stephen R Conley</i>	SRC
Design Authority Representative	E.R. Kehlner	XWest	<i>ERK</i>	ERK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being verified unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM842 I.D.: 6410-889 Calib. Due date: 02/09/01

Test Instrument type: FLUKE 787 I.D.: BAT107 Calib. Due date: 05/28/00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1Y

Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

Page 3 of 6

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	OK	None	Acc
Manufacturer:	OK	N/A	Acc
Configuration	OK	N/A	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-08-00 11:00AM

Record: Room Temperature: 68 °F.

2.2 Insulation Resistance Test

2.2.1 Open main disconnect switch MD and tag out.

2.2.2 Disconnect cable from resolver, RSVMGHY and tag cable as energized.

2.2.3 At PLS2, terminal strip S1, lift incoming wire per the Lifted Lead Log.

2.2.4 Setup the test equipment for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device wire to shield ground. Record the resistances.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1Y

Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

Page 4 of 6

Resolver Pin / Ground

Desc. of Wire No.	Desc. of Wire No./Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
12H	Ground	>1.236ohm	> 10 Megohms	Acc
22H	Ground	>1.366ohm	> 10 Megohms	Acc
32H	Ground	>2.406ohm	> 10 Megohms	Acc
42H	Ground	>1.353ohm	>10 Megohms	Acc
52H	Ground	>1.356ohm	>10 Megohms	Acc
62H	Ground	>2.356ohm	>10 Megohms	Acc
72H	Ground	>2.386ohm	>10 Megohms	Acc

2.2.6 Short all wires together except the one being tested. Check with Ohm-meter

2.2.7 Apply a nominal 500 VDC via Megger device wire to wire. Record the resistances

Desc. of Wire No.	Desc. of Wire No	Record Resistance	Acceptance Criteria	Comments/Deviations
12H	Other wires	0 Ohm	None	Verify shorted
Megger 12H	Other wires	>1.576ohm	>10 Megohms	Acc
22H	Other wires	0 Ohm	None	Verify shorted
Megger 22H	Other wires	>1.596ohm	>10 Megohms	Acc
32H	Other wires	0 Ohm	None	Verify shorted
Megger 32H	Other wires	>1.576ohm	>10 Megohms	Acc
42H	Other wires	0 Ohm	None	Verify shorted
Megger 42H	Other wires	>1.556ohm	>10 Megohms	Acc
52H	Other wires	0 Ohm	None	Verify shorted
Megger 52H	Other wires	>1.626ohm	>10 Megohms	Acc
62H	Other wires	0 Ohm	None	Verify shorted
Megger 62H	Other wires	>1.526ohm	>10 Megohms	Acc
72H	Other wires	0 Ohm	None	Verify shorted
Megger 72H	Other wires	>1.626ohm	>10 Megohms	Acc

2.2.6 Remove the Megger device.

2.3 Wire Continuity test

2.3.1 Attach Ohmmeter between resolver cable connector pins and lifted wire at PLS2 to verify wire continuity. Record below:

Desc. of Pin No.	Desc. of Wire No	Record Resistance	Acceptance Criteria	Comments/Deviations
A	12H	0 Ohm	No open circuit	Acc
B	22H	1.1 Ohm	No open circuit	Acc
H	32H	2.1 Ohm	No open circuit	Acc
J	52H 42H	3.1 Ohm	No open circuit	Acc
G	42H 52H	2.4 Ohm	No open circuit	Acc
K	62h	2.2 Ohm	No open circuit	Acc
N	72H	2.9 Ohm	No open circuit	Acc

ERK
7/8/00

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003B-TP-003B1Y

Test Specimen: Gemco Cable SD0334900, Eqmt. No: None

Page 5 of 6

2.3.2 Remove Ohmmeter.

2.4 Terminate the test.

2.4.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.4.2 Retorque the terminals to 12 in-pounds

2.4.3 Re-attach cable to resolver, hand tight.

2.5.2 Record: Date /Time of Test End: 03-08-00 11:42 a.m.

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Devices under test have passed all parameters.

Michael Ray Cram
03-08-00

Notes:

Certified Instrumentation Technician (signature) *Michael Cram* Date: 03-08-00
Received By: J. Ladick 3-10-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/10/00} *Ray Swenson* Date: 3/10/00

QA/QC (signature) *T. Anderson* Date: 3/13/00
T. ANDERSON

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	8	P 9Y S C51Y	RSVMGHX	Cable connector								
EB-33056	9	12H	PLS 2	9	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	22H	PLS 2	10	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	32H	PLS 2	12	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	42H	PLS 2	14	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	52H	PLS 2	13	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	62H	PLS 2	15	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
EB-33056	9	72H	PLS 2	21	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00

Remarks:

SNF-6315, Rev. 0

Page 845

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 1 of 7

ECN No. N/A CGI No. CGI-SNF-D-MHM-003A
Title: MHM Interlock P6 - Gemco Resolver

Section 1 Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
Part Description: <u>N/A</u>	ORIGINAL	
End Use Description: <u>N/A</u>		

Section 2a Component Information

Equipment No.: <u>RSVMGHX, RSVMGHY</u>	Specification No.: <u>Ederer F-2566, Foster Wheeler MJX-SDX 452656</u>	Manufacturer: <u>GEMCO</u>	Past P.O. No.: <u>N/A</u>
Manufacturer's Part/Model No.: <u>SD0410901</u>	Equipment Supplier (if different from manufacturer): <u>ALSTOM, Foster Wheeler</u>	Equip. Supplier's Part No.: <u>N/A</u>	
Component Description: <u>Resolver for interlocks to measure height of MCO grapple for raise and lower commands, inhibits turret rotation, MCO seating zones and locking pins disengagement, located on MCO holst drive unit</u>			

Section 2b Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
 YES (go to #2 below) NO (go to procedure step 6.3.2-dedicate Item)
 If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier?
 YES (go to #2 below, procedure step 6.3.2, & dedicate Item) NO (procedure step 6.3.2-dedicate Item).

2. List of Candidate qualified NQA1 suppliers or of ISO 9000 suppliers, if used. N/A

3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c CGI Determination

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)

All three criteria have been satisfied. The Item meets the definition of commercial grade.

Section 2d Reason for Dedication

The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):

	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
X	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
	Other ('like-for-like', similar, substitution, replacement evaluation)

Commercial Grade Item Upgrade Dedication Form

ECN No. NA	CGI No. CGI-SNF-D-MHM-003A	Rev. No. 2
Title: MHM Interlock P6 - Gemco Resolver		Page 2 of 7

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:
1. P6 prevents shear of MCO partially lowered with MHM. This MCO grapple limit switch prevents turret rotation and turret and base locking pins disengaging when the MCO hoist is not at the upper limit or at the tube plug exchange limit.

B. Part/Component Functional Mode:	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function
Safety Function #1: <input checked="" type="checkbox"/> Active <input type="checkbox"/> Passive	
Safety Function #2: <input type="checkbox"/> Active <input type="checkbox"/> Passive	
Safety Function #3: <input type="checkbox"/> Active <input type="checkbox"/> Passive	

C. Host Component Safety Function (if applicable): **N/A**
 1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):
1. Failure of resolver position indication to PLS switch contacts to open upon demand results in potential override of interlock channel.

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	If yes: Environmental Qualification Requirements Limiting Environmental Conditions: Required Safety Functions: Qualification Period:
Natural Phenomena Hazard (NPH) Design Required: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	If yes: NPH Design Requirements Performance Category: NPH Design Req'ts.: Required Safety Functions:

Section 5 Component Functional Classification

<input checked="" type="checkbox"/> Safety Class (SC)	<input type="checkbox"/> General Service (GS)	<input type="checkbox"/> Safety Significant (SS)
---	---	--

If part/component classification is different from host component/system, document basis. **N/A**

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: **N/A**

Safety Analysis Report (SAR): **HNF-3672, Rev. 0**

Drawings: **Ederer, Inc. EB-33056, Sht 9**

Vendor Manual/Manufacturer/Supplier Information: **GEMCO Series 1989: Quik-Set III High Resolution Single Turn and Multi-turn PLS**

Other: **ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 3 of 7

ECN No. N/A CGI No. CGI-SNF-D-MHM-003A
Title: MHM Interlock P6 - Gemco Resolver

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acc Meth	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	GEMCO	1, IIN	X	
Model	SD0410901	1, IIN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Insulation resistance	> 10 megohm resistance to ground, rotor and stator windings at 500 VDC	1, T		X
Resolver rotor excitation voltage	With resolver connected to CPU, verify 7.0 to 7.9V RMS at CPU terminal strip S1, terminals 9 and 10 and at 9 and 21	1, T		X
4. Notes and Legend:				Acceptance Method (Acc Meth):
Rev 2 was issued due to wiring changes per MHM-FCR-079, 081, 086, and 102. Deleted references to Interlocks P52, P53, P57 and P61. Deleted Performance CC for Mechanical/Electrical Operation.				1. Special Test and Inspection: 1, IIN for Inspection 1, T for Test
				2. Commercial Grade Survey
				3. Source Verification
				4. Vendor/Item History

Section 10 Initial Review and Approval

Approvals:

Designated Engineer: [Signature]

Design Authority: Wesley Swenson 3/6/00

QA Engineer: [Signature] 3/8/00
TZ ANDERSON

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 4 of 7

ECN No. N/A CGI No. CGI-SNF-D-MHM-003A
Title: MHM Interlock P6 - Gemco Resolver

SNF-6315, Rev. 0

WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Resolver provides incorrect position to CPU to energize passive circuit.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Resolver mechanism jams and CPU contacts fail to open upon demand.
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2: Additional Failure Modes Applicable to the Component Under Evaluation			
<p>1. Resolver position indication to Programmable Limit Switch (PLS) switch contacts are closed to permit equipment movement. Contacts open for the interlock function. Any failure which prevents contacts to open inhibits the particular resolver interlock function.</p>			

Commercial Grade Item Upgrade Dedication Form		Rev. No. 2
ECN No. <u>N/A</u>	CGI No. <u>CGI-SNF-D-MHM-003A</u>	Page 5 of 7
Title: <u>MHM Interlock P6 - Gemco Resolver</u>		

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1	
Item Description: <u>Dual Resolver Transducer, 128 turn</u> System #: <u>MHM</u>	Equip #: <u>RSVMGHX, RSVMGHY</u> Model #: <u>SD0410901</u>
Manufacturer (Address/Phone): <u>GEMCO/PATRIOT</u> <u>1080 N. Crooks Rd</u> <u>Clawson, MI 48017-1097</u> <u>(810) 435-0700</u>	Supplier (Address/Phone): <u>N/A</u>

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.			
Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Model
	X		3. Insulation resistance
	X		4. Resolver rotor excitation voltage

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)	
Characteristic: <u>Manufacturer</u>	Sample Size*: <u>100%</u>
Acceptance Criteria: <u>GEMCO</u>	
Receipt Inspection Plan / Report #: <u>CGI-SNF-D-MHM-003A-TP-003AX</u>	<u>AY</u> <u>Yup 4/10/00</u>
Characteristic: <u>Model</u>	Sample Size*: <u>100%</u>
Acceptance Criteria: <u>SD0410901</u>	
Receipt Inspection Plan / Report #: <u>TP-003AX; BX</u>	

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)	
Characteristic for Test: <u>Insulation resistance</u>	Sampling Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: <u>> 10 megohm resistance to ground, rotor and stator windings at 500 VDC</u>	
Actual Test Value: <u>See TP</u>	Test Plan and Report #: <u>TP 003AX; BX</u>
Characteristic for Test: <u>Resolver rotor excitation voltage</u>	Sampling Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened
Acceptance Criteria: <u>With resolver connected to CPU, verify 7.0 to 7.9V RMS at CPU terminal strip S1, terminals 9 and 10, and at 9 and 21</u>	
Actual Test Value: <u>See TP</u>	Test Plan and Report #: <u>TP 003AX; BX</u>

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2

ECN No. N/A

CGI No. CGI-SNF-D-MHM-003A

Page 6 of 7

Title: MHM Interlock P6 - Gemco Resolver

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: GEMCO Resolver

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	GEMCO	X		1, IN	TP003A	NA	2	0	XWEST	Larry W. Price	4/10/00
Model	SD0410901	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Insulation resistance	> 10 megohm resistance to ground, rotor and stator windings at 500 VDC		X	1, T	↓	↓	↓	↓	↓	↓	↓
Resolver rotor excitation voltage	With resolver connected to CPU, verify 7.0 to 7.9V RMS at CPU terminal strip S1, terminals 9 and 10 and at 9 and 21				↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

<p>see Test Plan TP-003A, TP</p>		BUYER VERIFICATION	
Testing Agency Approval: <u>NR</u> <u>LES</u> <u>4/12/00</u> Date	Design Authority: <u>Larry Swenson</u> Date <u>4-12-00</u>	Testing Agency QA Engineer: <u>NR</u> <u>LES</u> <u>4/12/00</u> Date	QA Engineer: <u>Stephen Scottman</u> Date <u>4-20-2000</u>

SNF-6315, Rev. 0

Page 851

Commercial Grade Item Upgrade Dedication Form

Rev. No. 2
Page 7 of 7

ECN No. NA CGI No. CGI-SNF-D-MHM-003A
Title: MHM Interlock P6 - Gemco Resolver

SNF-6315, Rev. 0

SECTION 6 CONTACTS / PHONE NUMBERS

	Name	Phone
Design Authority	<u>CRAIG SWENSON</u>	<u>376-0288</u>
QA		
QC		
Cog - Engineer		
CGI Engineer		
Procurement Engineer		
Other		

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents		For Critical Characteristics
	Drawings:	
X	Manuals (specify type & number): <u>Gemco Technical Documentation</u>	All
	Design Calculations	
	Installation Instructions	
	Operation Instructions	
	Calibration Instructions	
	Manufacturer's Recommended Spare Parts List	
	Other:	
Procurement Documents		For Critical Characteristics
	Certificate of Conformance/Compliance	
	Seismic Qualification Certificate	
	Environmental Qualification Certificate	
	Test Report (s):	
	Inspection Report (s):	
	CMTRs for ASME Pressure Retaining Materials	
	Valve Seat Leakage Report	
	Weld Record	
	Material Traceability Record	
	Other:	

ORIGINAL

Dedication Test Plan - IST Test Plan No.: CGI-SNF-D-MHM-003A-TP-003AX Test Specimen: Gemco Resolver SD0410901, Eqmt. No: RSVMGHX	Rev. No. 0 Page 1 of 6
--	-------------------------------

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
1	Physical inaccessibility of resolver	Revise 2.2.3, 2.2.5, 2.2.8, 2.2.9 and LITCO lead log	(change) Megger Resolver rotor and stator through cable at PLS1	ERK 3/7/00	GGS 3/7/00	[Signature] 3/13/00
2	Main power to MD not available	2.3A	Use temporary 120VAC power to energize PLS1	ERK 3/7/00	GGS 3/7/00	[Signature] 3/13/00
3	Vendor manual incorrect	2.3.2 2.3.3	Vendor manual "Series 1989" Technical Documentation para A2a page 30 is incorrect. Schematic page 20 is correct.	ERK 3/7/00	GGS 3/7/00	[Signature] 3/13/00

*QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST

Rev/No. 0

Test Plan No.: CGI-SNF-D-MHM-003A-TP-003AX

Test Specimen: Gemco Resolver SD0410901, Eqmt. No: RSVMGHX

Page 2 of 6

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

JWP Waig Swenson Date: 3/6/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bellhaven	<i>Michael Cram</i>	MC
Electrician	JW EBERHART	PCE	<i>JW Eberhart</i>	JWE
Electrician Quality Control	Stephen R Conley	PCE	<i>Stephen R Conley</i>	SR
Design Authority Representative	E.R. Kahler	X West	<i>E.R. Kahler</i>	EAK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being verified unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP3457A I.D.: BAT123 Calib. Due date: 7-29-00

Test Instrument type: AVO BM 80/2 I.D.: 6410-889 Calib. Due date: 2-9-01

Test Instrument type: PROTO 6106 I.D.: 029E/009 Calib. Due date: 1-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003A-TP-003AX	
Test Specimen: Gemco Resolver SD0410901, Eqmt. No: RSVMGHX	Page 3 of 6

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	RSVMGHX	Acc
Manufacturer:	YES	Gemco	Acc
Model:	YES	SD0410901	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 3-07-00 10:33 a.m.
 Record: Room Temperature: 68 °F.

2.2 Resolver Insulation Resistance Test

2.2.1 Open main disconnect switch MD, lock and tag out.
 2.2.2 At the Control Console, PLS1 OM "Power"(101X) to "AC"(102X) terminals ^{determine and attach} verify no, 120 VAC power. _{start}

~~2.2.3 At the resolver, disconnect cable from resolver, RSVMGHX. at PLS-1 Lift leads per lifted Lead log~~

2.2.4 Setup the test equipment for insulation resistance testing.

~~2.2.5 Apply a nominal 500 VDC via Megger device between resolver cable connection pin ^{11H 21H} K or B and ground, ^{31H 51H} G or H and ground, and ^{41H 61H} J or K and ground. Record the resistances.~~

Resolver Pin / Ground		Record Resistance	Acceptance Criteria	Comments/Deviations
Desc. of Pins	Desc. of Terminal/Ground			
A or B (rotor) ^{11H} or ^{21H}	Ground	> 1.56 Gohm	> 10 Megohms	Acc
G or H (stator 1) ^{31H} or ^{51H}	Ground	> 2.32 Gohm	> 10 Megohms	Acc
J or K (stator 2) ^{41H} or ^{61H}	Ground	> 3.21 Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003A-TP-003AX	
Test Specimen: Gemco Resolver SD0410901, Eqmt. No: RSVMGHX	Page 4 of 6

- 2.2.6 Remove the Megger device.
- 2.2.7 De-energize and remove the test equipment.

RRR 2.2.8 Reattach cable to Resolver, hand tight. leads for Lifted Lead Log
 3/2/00
~~2.2.9 Remove tags from main disconnect switch MD and close.~~ *delete*
 3/2/00

2.3 Resolver Rotor Excitation Voltage

- 2.3.1 Attach Multi-meter to PLS1 CPU terminal strip S1, terminals 9 and 10.
at PLS1 OM "Power" (101X) to AC (102X) terminals, determine wire and attach temporary 120VAC power
- 2.3.2 Attach Multi-meter to PLS1 CPU terminal strip S1, terminals 9 and 21.
10
- 2.3.3 Record the following data;

Description	Record Voltage	Acceptance Criteria	Comments/Deviations
Terminals 9 and 10	7.762 VAC	7.0 to 7.9 V RMS	Acc
Terminals 9 and 21 <i>10</i>	7.678 VAC	7.0 to 7.9 V RMS	Acc

RRR
 3/2/00

- 2.4 Terminate the test.
- 2.4.1 Reland the lifted leads and verify reband in accordance with the Lifted Lead Log.
- 2.4.2 Record: Date /Time of Test End: 03-07-00 12:56 p.m.

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Device under test was found to be within parameters

Michael Ray Cran
 03-07-00

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-003A-TP-003AX Test Specimen: Gemco Resolver SD0410901, Eqmt. No: RSVMGHX	Rev. No. 0 Page 5 of 6
--	-------------------------------

Notes:

Certified Instrumentation Technician (signature) Michael D Cram Date: 03-07-00
 Reviewed By: J. Cadwell 3-10-00

Completed Test Evaluation Approval:
 Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/7/00} [Signature] Date: 3/7/00

QA/QC (signature) [Signature] Date: 3/13/00
 TZ ANDERSON

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0035	7	P8XS C50X	RSVMGHX	Cable connector	Ddebc							
EB 33002	9	11H	PLS1	9	JWE	3/7/00	SRL	3-7-00	JWE	3/7/00	SRL	3-7-00
		21H		10	JWE	3/7/00	SRL	3-7-00	JWE	3/7/00	SRL	3-7-00
		31H		12	JWE	3/7/00	SRL	3-7-00	JWE	3/7/00	SRL	3-7-00
		41H		14	JWE	3/7/00	SRL	3-7-00	JWE	3/7/00	SRL	3-7-00
		51H		13	JWE	3/7/00	SRL	3-7-00	JWE	3/7/00	SRL	3-7-00
		61H		15	JWE	3/7/00	SRL	3-7-00	JWE	3/7/00	SRL	3-7-00
		71H		21	JWE	3/7/00	SRL	3-7-00	JWE	3/7/00	SRL	3-7-00
		101X		Power	JWE	3/7/00	SRL	3-7-00	JWE	3/7/00	SRL	3-7-00
		102X		AC	JWE	3/7/00	SRL	3-7-00	JWE	3/7/00	SRL	3-7-00

SRL
3/7/00

Remarks:

SNF-6315, Rev. 0

Page 858



3/8/00
ZLV

~~3/8/00~~

~~FROM [unclear] TO [unclear]~~

007AX

SERIES 1989: QUIK-SET III HIGH RESOLUTION SINGLE TURN & MULTI-TURN PLS



This document provides a detailed system description for the Gemco 1989 QUIK-SET III Programmable Limit Switch (PLS). The manual includes a complete description of the components, applications and optional features of the 1989, as well as complete installation, maintenance, programming and troubleshooting instructions.

The 1989 QUIK-SET III is a versatile and reliable motion control system which can be used in many types of motion and process control applications. Virtually any kind of transducer can be used for input with a Gemco PLS, making it usable with a wide range of applications. The PLS system's position information, programs and set point memory are non-volatile, making it as reliable as fixed limit or proximity switches, but far more flexible.


The remainder of this manual will describe in detail all the advanced features of the 1989, which include: up to 48 output channels; 8 separate programs which are keypad selectable; compatibility with single- or multi-turn resolvers and two-axis systems; and virtually limitless combinations of options and features.



INSTALLATION


Page 860

Transducer to Controller - Single Resolver Diagram E-0117100-C



11-6
01-5

Transducer to Controller - Dual Resolver Diagram E-0184600-C



TROUBLESHOOTING

INTRODUCTION

The following procedures are intended to aid in isolating system malfunctions to field replaceable modules. These modules include the display/keypad module, CPU module, output/power supply module, auxiliary output boards, transducer and all interconnecting cables. Once isolated, the defective module should be replaced and returned for factory repair.

Field repair beyond this level is not recommended.

Note: The screw terminals of the CPU module terminal strip do not make electrical contact when not tightened down. Insure that these screw terminals are fully tightened when taking voltage readings.

PRELIMINARY CHECKS

Check all system wiring connections at the transducer, CPU module and output module. Amphenol-type connectors on the transducer and its cabling should be checked for tightness. A slight tug on all wire terminations will verify a good connection. Push-on cable connectors at the keypad, CPU and output modules should be checked for proper connections.

Verify that all wiring at the CPU module is in agreement with its legend plate. The terminal designations of your CPU module may not be identical to the enclosed general wiring diagrams due to the wide range of available options.

Note: Verify that the keypad cable is connected to a multipin connector located through a cutout in the lower left corner of the CPU module's sheetmetal base. Other similar looking connectors may have been used by mistake.

A. Input Operation

A1. Check the operating voltage of the 5 VDC and 15 VDC inputs at the CPU module. Voltage between the terminals labeled 5 VDC (terminals 1 and 2 of terminal strip S2) and ground (terminals 3 and 4 of terminal strip S2) should be 4.8 to 5.2 VDC. This voltage range is critical for proper operation of the microprocessor. Voltage between the terminal labeled 15 VDC (terminal 29 of terminal strip S2) and ground (terminal 30 of terminal strip S2) should be 14.3 to 15.3 VDC. This input powers the transducer excitation circuitry.

If either of these voltages are not present at the CPU module terminals, the input wires should be disconnected and the voltage level checked across the wires. If the correct voltage is seen across the input wires, a short condition probably exists within the CPU module and it should be replaced.

If the correct voltage levels are not seen across these wires, the power supply has failed. This power supply can be an integral part of a Gemco output/power supply module, a Gemco power supply without outputs or a standard power supply not provided by Gemco. All Gemco power supply modules have a circuit board-mounted line fuse that should be checked. AC input voltages to these modules should be 105 to 125 VAC or 210 to 250 VAC depending on the version specified.

After verifying the AC input voltages and line fuse, the 5 VDC and 15 VDC output should be verified at the power supply with all wiring disconnected at its output terminals. See diagram E-0190100-C, (pages 11-12), for the location of these output pins on a Gemco output/power supply module. On a Gemco power supply without outputs, these are screw

terminals that are clearly labeled on its circuit board.

If the 5 VDC and 15 VDC voltages are now correct at the power supply terminals, an open or short condition of the power supply to CPU module wiring should be suspected. Incorrect voltages at the power supply indicate a defective power supply and the complete power supply module should be replaced.

A2. Transducer excitation voltage should be checked at the CPU module terminal strip S1. Use the following procedures based on the type of transducer that your system was designed for:

A2a. Single-turn resolver: AC voltage across terminals 9 and 10 of terminal strip S1 (labeled Red and Bk/R) should be 7.0 to 7.9V RMS. This is the output voltage being supplied to the resolver rotor. If this voltage is not present, disconnect the resolver wires at the CPU module and recheck the voltage. If this voltage is still not present, the resolver excitation circuitry in the CPU module has failed and it should be replaced. If this voltage reappears, a short condition in the resolver or its cable should be looked for.

The return signals from the resolver stator windings wire to the CPU module on terminal strip S1 terminals 12 and 14 (labeled White and Bk/W) and terminals 13 and 15 (labeled Green and Bk/G). To verify the presence of these AC return signals, put a voltmeter across terminals 12 and 14 and rotate the resolver. A voltage reading that rises and falls between these terminals as the resolver is rotated indicates a good resolver return signal. Repeat this same procedure with your meter across terminals 13 and 15. No voltage or a voltage that does not vary as the resolver rotates indicates an open or short condition in the resolver windings or the resolver cable.

The blue resolver wire that connects to the CPU module at terminal strip S1 terminal 21 (labeled BL) is a feedback wire used to verify that the resolver excitation voltage has reached the resolver rotor. A loss of this feedback voltage is intended to indicate a disconnected or severed resolver cable or other resolver excitation fault. If this feedback voltage is not present, the display on the keypad will show all E's. A voltmeter across terminal strip S1 terminal 9 (labeled Red) and terminal 21 (labeled BL) should read 7.0 to 7.9V RMS. If this voltage is not present, but was present across terminals 9 and 10 when checked earlier, an open or short condition exists in the resolver or its cable. If it is present, and all E's still appear on the display, a fault in the CPU module has been detected and it should be replaced.

Note: The reason for an all "E" fault display can be quickly isolated without the use of a voltmeter. Remove the resolver cable wires from terminals 9, 10 and 21

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003A-TP-003AY

Test Specimen: Gemco Resolver SD0410901, Eqmt. No: RSVMGHY

Page 1 of 6

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
1	Inaccessibility of resolver	2.2.3, 2.2.5 2.2.8, 2.2.9 Table 2.2.5 and lifted head log	Megger resolver rotors and stator through cable from PLS 2	ERK 3/7/00	CES 3/8/00	 3/13/00
2.	Power not available at MD	2.3A	Use temporary power to test PLS2 excitation voltage	ERK 3/7/00	CES 3/8/00	 3/13/00
3	Vendor manual incorrect	2.3.2 2.3.3	Vendor manual "Series 1989" Technical Documentation page 30, para A2a is incorrect. Schematic page 20 is correct. Vendor sheets attached	ERK 3/2/00	CES 3/8/00	 3/13/00

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-003A-TP-003AY

Test Specimen: Gemco Resolver SD0410901, Eqmt. No: RSVMGHY

Page 2 of 6

In-Situ Test Procedure**ORIGINAL**

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) JWP Lang Swenson Date: 3/6/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	Michael Cram	MC
Electrician	J WEERHART	PCE	JW Weerhart	JWE
Electrician Quality Control	Stephen R. Conley	PCE	Stephen R. Conley	SRC
Design Authority Representative	E.R. Kehler	XWest	ER Kehler	ERK
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Megger Instrument capable of 500 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being verified unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM8012 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-003A-TP-003AY Test Specimen: Gemco Resolver SD0410901, Eqmt. No: RSVMGHY	Rev. No. 0 Page 3 of 6
---	-------------------------------

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	YES	RSVMGHY	Acc
Manufacturer:	YES	Gemco	Acc
Model:	YES	SD0410901	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-08-00 10:45 a.m.
 Record: Room Temperature: 68 °F.

2.2 Insulation Resistance Test

- 2.2.1 Open main disconnect switch MD, lock and tag out.
- 2.2.2 At the Control Console, PLS2 OM "Power"(101Y) to "AC"(102Y) terminals verify no 120 VAC power.

ERK 3/7/00 2.2.3 At the resolver, disconnect cable from resolver, RSVMGHY at PLS2, determine per Lifted Lead log

2.2.4 Setup the test equipment for insulation resistance testing.

ERK 3/7/00 2.2.5 Apply a nominal 500 VDC via Megger device between resolver pin ~~K~~ or ~~B~~ and ground, ~~B~~ or ~~H~~ and ground, and ~~J~~ or ~~K~~ and ground. Record the resistances.
12H 22H 32H 52H 42H 62H

Resolver Pin / Ground

Desc. of Pins	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
A or B (rotor)	12H or 22H Ground	> 1.43 Gohm	> 10 Megohms	Acc
G or H (stator 1)	32H or 52H Ground	> 1.10 Gohm	> 10 Megohms	Acc
J or K (stator 2)	42H or 62H Ground	> 1.10 Gohm	> 10 Megohms	Acc

ERK 3/7/00

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-003A-TP-003AY	
Test Specimen: Gemco Resolver SD0410901, Eqmt. No: RSVMGHY	Page 4 of 6

- 2.2.6 Remove the Megger device.
- 2.2.7 De-energize and remove the test equipment.

- ERK* 2.2.8 ~~Reattach cable to Resolver, hand tight~~
3/7/00 ~~and leads per Lifted Lead Log and verify~~
- ERK* 2.2.9 ~~Remove tags from main disconnect switch MD and close.~~ *delete*
3/7/00

2.3 Resolver Rotor Excitation Voltage
at PLS 0mV "power" (101V) and AC (102V), Lift Leads per Lifted Lead Log and apply temporary 120VAC power.

- ERK* 2.3.1 Attach Multi-meter to PLS2 CPU terminal strip S1, terminals 9 and 10.
3/7/00
- ERK* 2.3.2 Attach Multi-meter to PLS2 CPU terminal strip S1, terminals ~~9~~ and 21.
3/7/00
- 2.3.3 Record the following data;

Description	Record Voltage	Acceptance Criteria	Comments/Deviations
Terminals 9 and 10	7.66 VAC	7.0 to 7.9 V RMS	Acc
Terminals 9 and 21 <i>10</i>	7.55 VAC	7.0 to 7.9 V RMS	Acc

- 2.4 Terminate the test.
- 2.4.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.
- 2.4.2 Record: Date /Time of Test End: 03-08-00 1:25 pm

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Devices under test were found to be acceptable.

Michael Cran 03-08-00

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
363A0033	8	P9YS 051Y	RSVMGHY	Cable connector	Deleted							
EB-3308	9	12H	PLS2	9	JWS	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
		22H		10	JWS	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
		32H		12	JWS	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
		42H		14	JWS	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
		52H		13	JWS	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
		62H		15	JWS	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
		72H		21	JWE	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
		101Y		POWER	JWS	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00
		102Y		AC	JWS	3/8/00	SRL	3-8-00	JWE	3/8/00	SRL	3-8-00

all
3/7/00

Remarks:

SNF-6315, Rev. 0

Page 867



3/8/00
RLK

~~XXXXXXXXXX~~

~~XXXXXXXXXXXXXXXXXXXXXXXXXXXX~~

003AY

SERIES 1989: QUIK-SET III HIGH RESOLUTION SINGLE TURN & MULTI-TURN PLS



This document provides a detailed system description for the Gemco 1989 QUIK-SET III Program-mable Limit Switch (PLS). The manual includes a complete description of the components, applications and optional features of the 1989, as well as complete installation, maintenance, programming and troubleshooting instructions.

The 1989 QUIK-SET III is a versatile and reliable motion control system which can be used in many types of motion and process control applications. Virtually any kind of transducer can be used for input with a Gemco PLS, making it usable with a wide range of applications. The PLS system's position information, programs and set point memory are non-volatile, making it as reliable as fixed limit or proximity switches, but far more flexible.


The remainder of this manual will describe in detail all the advanced features of the 1989, which include: up to 48 output channels; 8 separate programs which are keypad selectable; compatibility with single- or multi-turn resolvers and two-axis systems; and virtually limitless combinations of options and features.



INSTALLATION


Page 869

Transducer to Controller - Single Resolver Diagram E-0117100-C



f1-a
01-j

Transducer to Controller - Dual Resolver Diagram E-0184600-C



I. TROUBLESHOOTING

CAUTION

The following procedures are intended to aid in isolating system malfunctions to field replaceable modules. These modules include the display/keypad module, CPU module, output/power supply module, auxiliary output boards, transducer and all interconnecting cables. Once isolated, the defective module should be replaced and returned for factory repair.

Field repair beyond this level is not recommended.

Note: The screw terminals of the CPU module terminal strip do not make electrical contact when not tightened down. Insure that these screw terminals are fully tightened when taking voltage readings.

PRELIMINARY CHECKS

Check all system wiring connections at the transducer, CPU module and output module. Amphenol-type connectors on the transducer and its cabling should be checked for tightness. A slight tug on all wire terminations will verify a good connection. Push-on cable connectors at the keypad, CPU and output modules should be checked for proper connections.

Verify that all wiring at the CPU module is in agreement with its legend plate. The terminal designations of your CPU module may not be identical to the enclosed general wiring diagrams due to the wide range of available options.

Note: Verify that the keypad cable is connected to a multipin connector located through a cutout in the lower left corner of the CPU module's sheetmetal base. Other similar looking connectors may have been used by mistake.

A. Input Operation

A1. Check the operating voltage of the 5 VDC and 15 VDC inputs at the CPU module. Voltage between the terminals labeled 5 VDC (terminals 1 and 2 of terminal strip S2) and ground (terminals 3 and 4 of terminal strip S2) should be 4.8 to 5.2 VDC. This voltage range is critical for proper operation of the microprocessor. Voltage between the terminal labeled 15 VDC (terminal 29 of terminal strip S2) and ground (terminal 30 of terminal strip S2) should be 14.3 to 15.3 VDC. This input powers the transducer excitation circuitry.

If either of these voltages are not present at the CPU module terminals, the input wires should be disconnected and the voltage level checked across the wires. If the correct voltage is seen across the input wires, a short condition probably exists within the CPU module and it should be replaced.

If the correct voltage levels are not seen across these wires, the power supply has failed. This power supply can be an integral part of a Gemco output/power supply module, a Gemco power supply without outputs or a standard power supply not provided by Gemco. All Gemco power supply modules have a circuit board-mounted line fuse that should be checked. AC input voltages to these modules should be 105 to 125 VAC or 210 to 250 VAC depending on the version specified.

After verifying the AC input voltages and line fuse, the 5 VDC and 15 VDC output should be verified at the power supply with all wiring disconnected at its output terminals. See diagram E-0190100-C, (pages 11-12), for the location of these output pins on a Gemco output/power supply module. On a Gemco power supply without outputs, these are screw

terminals that are clearly labeled on its circuit board.

If the 5 VDC and 15 VDC voltages are now correct at the power supply terminals, an open or short condition of the power supply to CPU module wiring should be suspected. Incorrect voltages at the power supply indicate a defective power supply and the complete power supply module should be replaced.

A2. Transducer excitation voltage should be checked at the CPU module terminal strip S1. Use the following procedures based on the type of transducer that your system was designed for:

A2a. Single-turn resolver: AC voltage across terminals 9 and 10 of terminal strip S1 (labeled Red and Bk/R) should be 7.0 to 7.9V RMS. This is the output voltage being supplied to the resolver rotor. If this voltage is not present, disconnect the resolver wires at the CPU module and recheck the voltage. If this voltage is still not present, the resolver excitation circuitry in the CPU module has failed and it should be replaced. If this voltage reappears, a short condition in the resolver or its cable should be looked for.

The return signals from the resolver stator windings wire to the CPU module on terminal strip S1 terminals 12 and 14 (labeled White and Bk/W) and terminals 13 and 15 (labeled Green and Bk/G). To verify the presence of these AC return signals, put a voltmeter across terminals 12 and 14 and rotate the resolver. A voltage reading that rises and falls between these terminals as the resolver is rotated indicates a good resolver return signal. Repeat this same procedure with your meter across terminals 13 and 15. No voltage or a voltage that does not vary as the resolver rotates indicates an open or short condition in the resolver windings or the resolver cable.

The blue resolver wire that connects to the CPU module at terminal strip S1 terminal 21 (labeled BL) is a feedback wire used to verify that the resolver excitation voltage has reached the resolver rotor. A loss of this feedback voltage is intended to indicate a disconnected or severed resolver cable or other resolver excitation fault. If this feedback voltage is not present, the display on the keypad will show all E's. A voltmeter across terminal strip S1 terminal 9 (labeled Red) and terminal 21 (labeled BL) should read 7.0 to 7.9V RMS. If this voltage is not present, but was present across terminals 9 and 10 when checked earlier, an open or short condition exists in the resolver or its cable. If it is present, and all E's still appear on the display, a fault in the CPU module has been detected and it should be replaced.

Note: The reason for an all "E" fault display can be quickly isolated without the use of a voltmeter. Remove the resolver cable wires from terminals 9, 10 and 21

10
Corrected
EEL
3/8/00

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Price, Larry W

From: Swenson, Craig E
Sent: Wednesday, May 03, 2000 12:28 PM
To: Price, Larry W
Cc: Swenson, Craig E; Bazinet, Gerald D (Jerry); Salazar, Pamela K (Pam)
Subject: MHM CGI Records Submittal

The CGI items that will be included under an EDT will be packaged as a "SNF-XXXX" document.

SNF-6315: "Canister Storage Building - MCO Handling Machine - Commercial Grade Item Dedication Program"

Table of Contents:

Introduction and Purpose

Tab 1. Memorandum 00-SNF/CES-003, dated 3/22/00.

Tab 2. CGI Personnel Qualifications

Tab 3. QA Surveillances of Test Laboratory (Belhaven)

Tab 4. Test Laboratory Equipment Qualification

Tab 5. Safety Equipment & CGI Dedication Working List

Tab 6. CGI Dedication Forms and Test Reports

(Summary List: CGI & Test Plan No. and Mfr/Model for each test plan)

I will have the TOC, Intro/Purpose, and section dividers made up.

Craig Swenson

SNF/CSB/MHM 376-0288

Page 873

Manufacturer or Vendor	Model No.	CGI	Test Procedure No.
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020C
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020C
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020C
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020C
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020C
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020C
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020C
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-20A	ITP020D
Honeywell	LSYAC3K	CGI-SNF-D-MHM-22	ITP022B
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-23	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-23	ITP020D
Idec	RH4B-UL-AC120V	CGI-SNF-D-MHM-23	ITP020C
Siemens	3TH4310-0AK6	CGI-SNF-D-MHM-23	ITP023A
Siemens	3TH4310-0AK6	CGI-SNF-D-MHM-23	ITP023C
Siemens	3TH4310-0AK6	CGI-SNF-D-MHM-23	ITP023B
Fortress Solenoid Interlock Assy w/Craig Derricott switch & contacts	H31SS w/120 VAC Solenoid, 3PDT Selector Switch	CGI-SNF-D-MHM-32	ITP032
Ashcroft	45 1009 S 02L 2000	CGI-SNF-D-MHM-37	BTP037
Ashcroft	45 1009 S 02L 2000	CGI-SNF-D-MHM-37	BTP037
Siemens	3TF4422-0AK6	CGI-SNF-D-MHM-47	ITP047
Siemens	3TF4222-0AK6	CGI-SNF-D-MHM-48	ITP048D
Siemens	3TF4222-0AK6	CGI-SNF-D-MHM-48	ITP048A
Siemens	3TF4222-0AK6	CGI-SNF-D-MHM-48	ITP048B
Siemens	3TF4222-0AK6	CGI-SNF-D-MHM-48	ITP048C
Siemens	3TF4222-0AK6	CGI-SNF-D-MHM-48	ITP048D
Siemens	3TF4222-0AK6	CGI-SNF-D-MHM-48	ITP048D
Honeywell	SL1-H	CGI-SNF-D-MHM-7	ITP007G
Honeywell	SL1-H	CGI-SNF-D-MHM-7	ITP007H
Honeywell	SL1-H	CGI-SNF-D-MHM-7	ITP007
Honeywell	SL1-H	CGI-SNF-D-MHM-7	ITP007
Honeywell	SL1-E	CGI-SNF-D-MHM-8	ITP007A
Honeywell	SL1-E	CGI-SNF-D-MHM-8	ITP007B

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 1 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-002
Title: P-6 - Honeywell Limit Switch 5LS1-4PG

Section 1: Part Information

Item No.: <u>N/A</u>	Manufacturer: <u>N/A</u>	Supplier: <u>N/A</u>
Mfg. Part/Model No.: <u>N/A</u>	Supplier's P/N: <u>N/A</u>	
Part Description: <u>N/A</u>		
End Use Description: <u>N/A</u>		

ORIGINAL

Section 2a: Component Information

Equipment No.: <u>LFMGUDX</u>	Specification No.: <u>Ederer F-2566, Foster Wheeler MJX-SDX 452656</u>	Manufacturer: <u>Honeywell</u>	Past P.O. No.: <u>N/A</u>
Manufacturer's Part/ Model No.: <u>5LS1-4PG</u>	Equipment Supplier (if different from manufacturer): <u>ALSTOM, Foster Wheeler</u>	Equip. Supplier's Part No.: <u>N/A</u>	

Component Description: MCO grapple not at upper datum limit switch for Interlock P-6, located in the MCO hoist compartment, inhibits turret rotation and turret and base locking pins disengagement, when in MCO mode or impact absorber mode.

Section 2b: Commercial Availability of the Item

- Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
 YES (go to #2 below) NO (go to procedure step 6.3.2, proceed to dedicate Item)
 If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate with project CGI interface Engineer or BTR)
 YES (go to #2 below, procedure step 6.3.2, dedicate Item) NO (procedure step 6.3.2, dedicate Item)
- List of Candidate qualified NQA1 suppliers or ISO 9000 suppliers, if used: N/A
- Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A

Section 2c: CGI Determination

- CGI Determination Questions:
- Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
 YES (the Item is not commercial grade) NO (continue)
 - Is the Item used in applications other than nuclear facilities or activities?
 NO (the item is not commercial grade) YES (continue)
 - Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?
 NO (the item is not commercial grade) YES (continue)
- All three criteria have been satisfied. The Item meets the definition of commercial grade.

Commercial Grade Item Upgrade Dedication Form

ECN No. <u>N/A</u> CGI No. <u>CGI-SNF-D-MHM-002</u>	Rev. No. 1
Title: <u>P-6 - Honeywell Limit Switch 5LS1-4PG</u>	Page 2 of 8

Section 2d Reason for Dedication
The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s)

	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
X	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. **MCO grapple limit switch (P-6) prevents turret rotation and turret and base locking pins disengaging when the MCO hoist is not at the upper limit. Prevents shear of hoist cable and MCO drop. P-6 prevents partially lowered MCO shear due to lateral movement of the MHM.**

B. Part/Component Functional Mode:	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function
Safety Function #1: <input checked="" type="checkbox"/> Active <input type="checkbox"/> Passive	Passive - Change of state is not required for the component to perform its safety function
Safety Function #2: <input type="checkbox"/> Active <input type="checkbox"/> Passive	
Safety Function #3: <input type="checkbox"/> Active <input type="checkbox"/> Passive	

C. Host Component Safety Function (if applicable): N/A

1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

1. **Failure of switch contacts to open upon demand results in potential override of interlock channel.**

2. **Actuator plunger/arm inoperative results in failure to provide interlock function at correct demand position.**

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	If yes: Environmental Qualification Requirements Limiting Environmental Conditions: Required Safety Functions: Qualification Period:
Natural Phenomena Hazard (NPH) Design Required: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	If yes: NPH Design Requirements Performance Category: NPH Design Req'ts.: Required Safety Functions:

Section 5 Component Functional Classification

X Safety Class (SC)	General Service (GS)	Safety Significant (SS)
----------------------------	----------------------	-------------------------

If part/component classification is different from host component/system, document basis. N/A

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: N/A
 Safety Analysis Report (SAR): HNF-3672, Rev. 0
 Drawings: Ederer, Inc. EB-33056, Sheets 10A
 Vendor Manual/Manufacturer/Supplier Information: Honeywell Series LS compact limit switches
 Other: ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 3 of 8


ECN No. NA CGI No. CGI-SNF-D-MHM-002
Title: P-6 - Honeywell Limit Switch 5LS1-4PG


SNF-6315, Rev. 0


Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Honeywell	1,IN	X	
Model Number	5LS1-4PG	1,IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Actuator arm	5LS1-4PG 4 position adjustable head; plunger with top roller	1,IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Contact rating	Nominal 10 amps, resistive, @ 120 vac, less than 0.5V drop across contacts	1,T		X
Insulation resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v.	1,T		X
Mechanical operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring	1,T		X
4. Notes and Legend:		Acceptance Method (Acc Meth):		
Rev. 1: Page 5: Revised Section 3 header; Page 6: Revised Section 4 header; General: new forms.		1. Special Test and Inspection: 1, IN for Inspection 1,T for Test 2. Commercial Grade Survey 3. Source Verification 4. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:

Designated Engineer: 

Design Authority: 

QA Engineer:  1/18/00
TZ RNOGELSON

Commercial Grade Item Upgrade Dedication Form

Rev. No. 1
Page 4 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-002
Title: P-6 - Honeywell Limit Switch 5LS1-4PG

SNF-6315, Rev. 0

WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	X	Switch contacts corrode closed and fall to open upon demand.
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Switch contacts fuse closed and fail to open upon demand.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Switch mechanism jams and contacts fail to open upon demand
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2: Additional Failure Modes Applicable to the Component Under Evaluation			
1. Switch contacts are closed to permit equipment movement. Contacts open for the interlock function. Any failure which prevents contacts to open inhibits the particular switch interlock function.			
2. Actuator plunger/arm seizure or break renders the contact opening inoperable.			
3. Short circuit could give false signal to energize interlock function.			

Commercial Grade Item Upgrade Dedication Form

ECN No. N/A CGI No. CGI-SNF-D-MHM-002
 Title: P-6 - Honeywell Limit Switch 5LS1-4PG

Rev. No. 1
 Page 5 of 8

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1

Item Description: P-6 interlock limit switch	Equip #: LFMGUDX
System #: MHM	Model #: 5LS1-4PG
Manufacturer (Address/Phone): Honeywell 1-800-537-6945 P.O. #	Supplier (Address/Phone):

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1

Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Model Number
X			3. Actuator
	X		4. Contact Rating
	X		5. Insulation Resistance
	X		6. Mechanical Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic: Manufacturer	Sample Size*: 100%
Acceptance Criteria: Honeywell	
Receipt Inspection Plan / Report #: CGI-SNF-D-MHM-002-TP-002A	
Characteristic: Model Number	Sample Size*: 100%
Acceptance Criteria: 5LS1-4PG	
Receipt Inspection Plan / Report #: TP-002A	
Characteristic: Actuator	Sample Size*: 100%
Acceptance Criteria: Plunger with top roller	
Receipt Inspection Plan / Report #: TP-002A	

Commercial Grade Item Upgrade Dedication Form

ECN No. NA CGI No. CGI-SNF-D-MHM-002
 Title: P-6 - Honeywell Limit Switch 5LS1-4PG

Rev. No. 1
 Page 6 of 8

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size References (See Section 7)

Characteristic for Test: Contact Rating Acceptance Criteria: Nominal 10 amps, resistive, @ 120 vac, less than 0.5V drop across contacts Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-002A</u>
Characteristic for Test: Insulation Resistance Acceptance Criteria: Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v. Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-002A</u>
Characteristic for Test: Mechanical Operation Acceptance Criteria: Cycle switch - confirm contacts open and close with smooth operation and free release of spring Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-002A</u>

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A

CGI No. CGI-SNF-D-MHM-002

Page 7 of 8

Title: MHM INTERLOCK P-6 - HONEYWELL LIMIT SWITCH

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Limit Switch

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or RR#	Check-List ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Honeywell	X		1, IN	TP-002A	NA	1	0	XWEST	<i>LABBY W. PERE</i>	4/11/00
Model Number	5LS1-4PG	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Actuator	Plunger with top roller	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Contact Rating	Nominal 10 amps, resistive, @ 120 vac, less than 0.5V drop across contacts		X	1, T	↓	↓	↓	↓	↓	↓	↓
Insulation Resistance	Greater than 10 megohm resistance, terminal to terminal and terminal to ground at 1000v.		X	1, T	↓	↓	↓	↓	↓	↓	↓
Mechanical Operation	Cycle switch - confirm contacts open and close with smooth operation and free release of spring		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plan TP-002A cited above. CES 4/11/00
 Testing Agency Approval: NR CES 4/11/00 Date _____
 Testing Agency QA Engineer: NR CES 4/11/00 Date _____

BUYER VERIFICATION
 Design Authority: Wesley Sherman Date 4-11-00
 QA Engineer: Stephen Scott Moss Date 4-24-2000

SNF-6315, Rev. 0

Page 280

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-002

Page 8 of 8

Title: **MHM INTERLOCK P-6 – HONEYWELL LIMIT SWITCH**

SNF-6315, Rev. 0

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents		For Critical Characteristics
	Drawings:	
	Manuals (specify type & number):	
	Design Calculations	
	Installation Instructions	
	Operation Instructions	
	Calibration Instructions	
	Manufacturer's Recommended Spare Parts List	
X	Other: Honeywell Series LS Compact Limit Switches	All
Procurement Documents		For Critical Characteristics
	Certificate of Conformance/Compliance	
	Seismic Qualification Certificate	
	Environmental Qualification Certificate	
X	Test Report (s): CSB (W379)-015-1-062	
	Inspection Report (s):	
	CMTRs for ASME Pressure Retaining Materials	
	Valve Seat Leakage Report	
	Weld Records	
	Material Traceability Record	
X	Other: SU Test SNF-CTP-IC-07	

Dedication Test Plan – IST-LS-1 Test Plan No.: CGI-SNF-D-MHM-002-TP-002A Test Specimen: Honeywell 5LS1-4PG Limit Switch, Eqmt. No.: LFMGUDX	Rev. No. 0 Page 1 of 8
---	-------------------------------

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*
1	Test device directly	3.4.2	Input signal at limit switch not J522X	JUP	CES 3/29/00	SSM 4-3-2000
2	Clarification	3.3.2 3.4.7 3.3.5 3.4.9 3.4.2 3.4.12	Terminals are "terminals for wires..."	JUP	CES 3/29/00	SSM 4-3-2000

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST-LS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-002-TP-002A

Test Specimen: Honeywell 5LS1-4PG Limit Switch, Eqmt. No.: LFMGUDX

Page 2 of 8

ORIGINAL

In-Situ Test Procedure

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *Craig Swenson* Date: 3/17/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MEC
Electrician	DAN K. YORK	PCE	<i>Dan K. York</i>	DKY
Electrician Quality Control	Stephen R. Conley	PCE	<i>Stephen R. Conley</i>	SRC
Design Authority Representative	LARRY W. PECK	XQUEST	<i>Larry W. Peck</i>	LWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A
Design Authority	Craig Swenson	F41	<i>Craig Swenson</i>	CS

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC

Megger Instrument capable of 1000 VDC Test Voltage

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: ~~05-28-00~~ 3-29-00

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: Avo BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST-LS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-002-TP-002A

Test Specimen: Honeywell 5LS1-4PG Limit Switch, Eqmt. No.: LFMGUDX

Page 3 of 8

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Lock and tagout Main Disconnect CRN-004, or Main Disconnect MD.

2.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LFMGUDX	LFMGUDX	Acc
Manufacturer:	HONEYWELL	Honeywell	Acc
Model:	5LS1-4PG	5LS1-4PG	Acc
Actuator:	OK	Standard Top roller Plunger	Acc
Serial No./Lot No./Date Code:	N/A	N/A	Acc

3.0 Perform the following testing steps:

3.1 Record: Date /Time of Test Beginning: 03-29-00 11:20 a.m.

Record: Room Temperature: 68 °F.

3.2 Mechanical Operation

3.2.1 Cycle the switch actuator full stroke 5 or more times to confirm contacts open and close with smooth operation and free release of spring.

3.2.2 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
No of Cycles:	6	> 5 times	Acc
Describe Operation:	OK	Contacts open and close with smooth operation.	Acc
Describe release of Spring:	OK	Free release of spring.	Acc

Dedication Test Plan – IST-LS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-002-TP-002A

Test Specimen: Honeywell 5LS1-4PG Limit Switch, Eqmt. No.: LFMGUDX

Page 4 of 7

3.3 Insulation Resistance Test

- 3.3.1 Setup the test equipment and Limit Switch specimen for insulation resistance testing.
- 3.3.2 Apply a nominal 1000 VDC via Megger device between non-continuity terminals 101X and 10A31X (Common - Across NO Contact) and then between terminal 10A31X and ground. Record the resistances. *for wires CES 3/29/00*
- 3.3.3 Remove the Megger device. *for wires CES 3/29/00*
- 3.3.4 Manually adjust the limit switch actuator to open the normally closed (NC) contacts. *for wires CES 3/29/00*
- 3.3.5 Apply a nominal 1000 VDC via Megger device between non-continuity terminals 101X and 10A32X (Common - Across open NC Contact) and then between terminal 10A32X and ground. Record the resistances. *for wires CES 3/29/00*

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Resistance	Acceptance Criteria	Comments/Deviations
101X and 10A31X	Common to NO	> 13.5 Gohm	> 10 Megohms	Acc
10A31X and Ground	NO to Ground	> 29 Gohm	> 10 Megohms	Acc
101X and 10A32X	Common to open NC*	> 8.5 Gohm	> 10 Megohms	Acc
10A32X and ground	Open NC to Ground*	> 22 Gohm	> 10 Megohms	Acc

* Normally closed contacts are open.

- 3.3.6 De-energize and remove the test equipment.

3.4 Contact Rating Test

- 3.4.1 Setup the test equipment and Limit Switch specimen for contact rating testing. Attach a sketch of test circuit with all test instrumentation used. *for wires CES 3/29/00*
- 3.4.2 ~~At junction box JB22X~~, lift leads on terminal 101X (Common), terminal 10A32X (LFMGUDX Normally Closed Contact) and terminal 10A31X (LFMGUDX Normally Open Contact). Record on the lifted lead log. *for wires CES 3/29/00*
- 3.4.3 Connect the power supply to terminals 101X and 10A32X.
- 3.4.4 Apply a nominal 10 amps VAC, resistive, across the normally closed contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Dedication Test Plan – IST-LS-1

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-002-TP-002A

Test Specimen: Honeywell 5LS1-4PG Limit Switch, Eqmt. No.: LFMGUDX

Page 5 of 7

3.4.5 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- NC)	.056 ✓	< 0.5 Volts AC drop	Acc

3.4.6 Reduce the current source to zero amps.

3.4.7 Disconnect the power supply from terminals 101X and 10A32X.

3.4.8 Manually adjust the limit switch actuator to close the normally open contacts.

3.4.9 Connect the power supply to terminals 101X and 10A31X.

3.4.10 Apply a nominal 10 amps VAC, resistive, across the closed normally open contacts of the test specimen.

3.4.11 Record the following data.

Description	Record Voltage Drop	Acceptance Criteria	Comments/Deviations
Contact Circuit (Terminals COM- Closed NO Contact):	.120V	< 0.5 Volts AC drop	Acc

3.4.12 Reduce the current source to zero amps and remove the power supply from terminals 101X and 10A31X.

3.4.13 Manually adjust the limit switch actuator to close the normally closed contacts.

3.5 Terminate the test.

3.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

3.5.2 Retorque the terminals to 12 in-pounds.

3.5.3 Remove lockout/tagout and restore system to normal.

3.5.4 Record: Date /Time of Test End: 03 - 29 - 00 2:30 p.m.for wires
LE 3/29/00

Dedication Test Plan - IST-LS-1	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-002-TP-002A	
Test Specimen: Honeywell 5LS1-4PG Limit Switch, Eqmt. No.: LFMGUDX	Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met

Michael Cram
03-29-00

Notes:

Step 3.4.10 - 10 amp signal applied at limit switch terminals directly in lieu of junction box due to electrical voltage drop.
Larry Swenson 3/29/00

Certified Instrumentation Technician (signature) Michael Cram Date: 03-29-00


Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) JMP Larry Swenson Date: 3/29/00

QA/QC (signature) Stephen Scott Moss Date: 4-3-2000

Compact Limit Switches
TOP PLUNGER ACTUATED SWITCHES




Compact

ORDER GUIDE
Momentary action.

Description	Electrical Rating Page A70	Catalog Listing		O.F. max. N lb.	P.T. max. mm in.	O.T. min. mm in.	D.T. max. mm in.
		Compact	Plug-in				
Standard top plunger	A	2LS1	202LS1*	31,1 7	1,65 .065	6,35 .250	0,51 .020
UL/CSA	F	2LS1-L	—	31,1 7	1,65 .065	6,35 .250	0,51 .020
Low operating force top plunger	E	2LS111	202LS111*	10 36 oz.	1,65 .065	5,56 .219	0,23 .009

TOP ROLLER PLUNGER ACTUATED SWITCHES




Plug-in*

ORDER GUIDE
Momentary action.

Description	Electrical Rating Page A70	Catalog Listing		O.F. max. N lb.	P.T. max. mm in.	O.T. min. mm in.	D.T. max. mm in.
		Compact	Plug-in				
Standard top roller Plunger	A	5LS1	205LS1*	31,1 7	1,65 .065	5,56 .219	0,51 .020
Steel roller UL/CSA	F	5LS1-L	—	31,1 7	1,65 .065	5,56 .219	0,51 .020

SIDE PLUNGER ACTUATED SWITCHES




Compact

ORDER GUIDE
Momentary action. Assembled with plunger facing front (label side).

Description	Electrical Rating Page A70	Catalog Listing		O.F. max. N lb.	P.T. max. mm in.	O.T. min. mm in.	D.T. max. mm in.
		Compact	Plug-in				
Standard side roller	A	4LS1	204LS1*	40 9	2,77 .109	6,35 .250	1,02 .040

SIDE ROLLER PLUNGER ACTUATED SWITCHES



Plug-in*

ORDER GUIDE
Momentary action. Assembled with plunger facing front (label side).

Description	Electrical Rating Page A70	Catalog Listing		O.F. max. N lb.	P.T. max. mm in.	O.T. min. mm in.	D.T. max. mm in.
		Compact	Plug-in				
Standard side roller plunger Steel Roller	A	3LS1	203LS1*	40 9	2,77 .109	5,56 .219	1,02 .040

* Require Terminal Block (18PA1 for 203LS Switches) which must be ordered separately. Unless damaged it is not necessary to replace terminal block when replacing switch.
N = Newton

Characteristics: O.F. — Operating Force; P.T. — Pretravel; O.T. — Overtravel; D.T. — Differential Travel.

Roller may be turned in any position through 360°.

Compact Limit Switches


- FEATURES**
 Mode of operation is field adjustable.
 NEMA 1, 3, 4, 6 and 13.
 Wide choice of heads and actuators.
 Variety of operating characteristics.
 Optional indicator light.
 Captive screws.
 UL Recognized, file #E12252
 CSA Certified, file #LR57325

Compact LS and plug-in 200LS limit switches have a long record of successful performance in industrial applications.

The LS fits in many places too small for any other fully adjustable limit switch.

The 200LS switches are the original plug-in concept for reducing downtime by making changeover simple and fast.

CIRCUITRY



FIELD ADJUSTABLE

Rotary motion roller lever and rod actuators are adjustable through 360°. They may be set for operation clockwise, counter-clockwise, or in both directions.

Operating heads may be positioned in any of four 90° positions.

UL/CSA LS SWITCHES
 Several UL recognized and CSA certified LS compact limit switches are in the order guides.

Other listings can be furnished in the UL version. Contact the 800 number for information.

For rapid response - off the shelf service, all bold face listings are normally stocked items.

ELECTRICAL RATINGS

A	10 amps, 120, 240 or 480 VAC; 1/2 hp, 120 VAC; 3/4 hp, 240 VAC; 0.8 amp, 115 VDC**; 0.4 amp, 230 VDC**; 0.1 amp, 550 VDC**; Pilot Duty, 600 VAC max.	APPLICATION NOTE: Silver Cadmium Oxide Contacts - Designed for use with inductive loads such as relays, contactors, motors and solenoids. Honeywell MICRO SWITCH does not recommend the use of silver cadmium oxide switch contacts in non-arcing loads. Non-arcing loads are generally loads less than 12 volts and/or 0.5 amp.
B	10 amps, 120, 240 or 480 VAC; 1/4 hp, 120 VAC; 1/2 hp, 240 VAC. Pilot Duty, 600 VAC max.	
C	10 amps, 120 VAC; 1/2 hp, 120 VAC.	
D	10 amps, 120, 240, 480 VAC; 1/4 hp, 120 VAC; 1/2 hp, 240 VAC; 0.8 amp, 115 VDC**; 0.4 amp, 230 VDC**; 0.1 amp, 550 VDC**; Pilot Duty, 600 VAC max.	
E	10 amps, 120, 240 or 480 VAC; 1/2 hp, 120 VAC; 3/4 hp, 240 VAC. Pilot Duty, 600 VAC max.	
F	UL Rating: 10 amps, 125, 250, or 480 VAC; 1/2 hp, 125 VAC; 3/4 hp, 250 VAC; 0.8 amp, 125 VDC**; 0.4 amp, 250 VDC**	Fine Silver Contacts
G	UL Rating: 10 amps, 125, 250 or 480 VAC; 1/4 hp, 125 VAC; 1/2 hp, 250 VAC; 0.8 amp, 125 VDC**; 0.4 amp, 250 VDC**	

** Resistive Rating

NOTE: The terminals of two-circuit double-break switches must be wired to equal voltage sources and the same polarity. The loads should be on the same side of the line.

ROLLER LEVER ROTARY ACTUATED SWITCHES


(To order switches and levers separately, refer to pages A73 and A74 or A37 and A38.)

ORDER GUIDE

Momentary action. Steel rollers.



Compact



Plug-In*

Description	Rating	Compact	Plug-in	O.F. max.	P.T. max.	O.T. min.	D.T. max.
Standard	A	1LS1	201LS1*	13.3 N 3 lb.	20°	30°	12°
20° Pretravel UL/CSA	F	1LS1-L	—	13.3 N 3 lb.	20°	30°	12°
Low Pretravel 5°	B	1LS19	201LS19*	13.3 N 3 lb.	5°	30°	4°
Low Operating Force 5° Pretravel	B	1LS131	—	5.0 N 18 oz.	5°	30°	4°
Standard with indicator light 120 VAC only	C	1LS501	201LS501*	13.3 N 3 lb.	20°	30°	12°
Low Operating Force	A	1LS6	201LS6*	5.0 N 18 oz.	20°	30°	12°
Cavity Mount version of 1LS1	A	7LS1	—	13.3 N 3 lb.	20°	30°	12°

* Require Terminal Block (18PA1 for 200LS switches) which must be ordered separately. Unless damaged, it is not necessary to replace terminal block when replacing switch.

Characteristics: O.F. — Operating Force; P.T. — Pretravel; O.T. — Overtravel; D.T. — Differential Travel.

**This document was too large to scan
as a single document. It has
been divided into smaller sections.**

Section 1 of 3

Document Information

Document #	SNF-6315	Revision	0
Title	CSB MCH CGI DEDICATIONS		
Date	05/17/2000		
Originator	CE SWENSON	Originator Co.	FH
Recipient		Recipient Co.	
References	EDT-629027, USQ-LIKE-CSB-0-0030		
Keywords			
Projects	W-379, SNF		
Other Information			

14
16
MAY 17 2000

ENGINEERING DATA TRANSMITTAL

Page 1 of 1
 1. EDT **629027**

2. To: (Receiving Organization) SNF -Canister Storage Building		3. From: (Originating Organization) CSB Project/MCO Handling Machine		4. Related EDT No.: NA	
5. Proj./Prog./Dept./Div.: SNF/CSB (W379)/Engineering		6. Design Authority/Design Agent/Cog. Engr.: CE Swenson 376-0288		7. Purchase Order No.:	
8. Originator Remarks: The program and test results for the MHM commercial grade dedication is included in document SNF-6315 attached. (*) For distribution - SNF-6315, sections 1 thru 5 only. <i>USG LIKE SCREENING CSB-00-030 RWM 5-16-00</i>				9. Equip./Component No.: MHM-001	
				10. System/Bldg./Facility: 212H	
11. Receiver Remarks: 11A. Design Baseline Document? <input type="radio"/> Yes <input checked="" type="radio"/> No				12. Major Assem. Dwg. No.: H-2-827086	
				13. Permit/Permit Application No.:	
14. Required Response Date:					

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	SNF-6315		0	CSB-MHM-CGI Dedications	SnQ	1	1	

16. KEY				
Approval Designator (F)	Reason for Transmittal (G)			Disposition (H) & (I)
E, S, Q, D OR N/A (See WHC-CM-3-5, Sec. 12.7)	1. Approval	4. Review	1. Approved	4. Reviewed no/comment
	2. Release	5. Post-Review	2. Approved w/comment	5. Reviewed w/comment
	3. Information	6. Dist. (Receipt Acknow. Required)	3. Disapproved w/comment	6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
1	1	Design Authority	CE Swenson	<i>hars swenson</i> 5/5/00	S8-07 (*)	1	1	LW Price	<i>LW Price</i> 5-5-00	R3-26 (*)	
		Design Agent	NA			3		GD Bazinet, S*-06 (*)			
		Cog. Eng.	NA			3		TW Libs, R3-86 (*)			
1	1	Cog. Mgr.	AS Daughtridge	<i>AS Daughtridge</i> 5/5/00	R3-86 (*)	3		CSB Project Files, S8-06 (Originals)			
1	1	QA	SS Moss	<i>Stephen South Mohr</i> 5-8-2000	R3-11 (*)			Central Files (2)			
1	1	Safety	YJ Liu	<i>YJ Liu</i> 5/9/00	R3-26 (*)						
		Env.									

18. Signature of EDT Originator <i>hars swenson</i> 5/5/00 Date		19. Authorized Representative for Receiving Organization Date		20. Design Authority/Cognizant Manager <i>Dean W. Medford</i> 5/16/00 Date		21. DOE APPROVAL (if required) Ctrl No. _____ <input type="radio"/> Approved <input type="radio"/> Approved w/comments <input type="radio"/> Disapproved w/comments	
---	--	--	--	--	--	---	--

S

SNF-6315
Revision 0
EDT 627029 5/17/00
9027 ps


Canister Storage Building - MCO Handling Machine – Commercial Grade Item Dedications


C.E. Swenson
Fluor Hanford Inc

Date Published
May 2000

Prepared for the U.S. Department of Energy
Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC06-98RL132009RL14047

Fluor Hanford
P.O. Box 1000
Richland, Washington 99352


Release Approval
Date 5/16/00



Release Stamp

SNF-6315
Revision 0

CANISTER STORAGE BUILDING - MCO HANDLING MACHINE - COMMERCIAL GRADE ITEM DEDICATIONS

Prepared for the U.S. Department of Energy

Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC05-96RL132000RL14047

Fluor Hanford
P.O. Box 1000
Richland, Washington 99352

DISCLAIMER

This report has been reproduced from the best available copy.
Available in paper copy and microfiche.

Printed in the United States of America

Total Pages:

914

Table of Contents

Introduction and Purpose

Section 1 – Internal Memorandum

Section 2 – CGI Personnel Qualifications

Section 3 – Quality Assurance Surveillances

Section 4 – Test Equipment Calibration Records

Section 5 – Safety Equipment and CGI Dedication Working List

Section 6 – CGI Dedication and Test Plan Records

Introduction

The Multi-Canister Overpack (MCO) Handling Machine (MHM) will transport MCOs inside the Canister Storage Building (CSB) and provide radiation shielding for personnel protection. The MHM has dual-girders with a trolley that supports a three-part rotating cask which is fixed to the trolley frame. The cask rotates on large turret bearings and the MCO hoisting system is the largest part of the cask assembly. The girders are supported on end tie beams which are supported by two bridge trucks with two wheels each that bear on the north-south CSB rails that are 126'6" apart. The 480 volt power is supplied via festoon cable system along the east side of the CSB. The power supply continues thru the trolley festoon system along the south side of the south girder. Power is then distributed to five control panel enclosures (6'x 7') and an operator console mounted on the trolley deck. The control panels contain relays, contactors, disconnects, fuses, and motor controllers that provide the controls and protection for the MHM functions. The 480 VAC power is stepped down to 120 VAC for the control system. Additionally, there are sensors that provide signals to relays and circuit logic devices. Although there are redundant circuits and control devices in the control system for prevention of nuclear safety accidents defined in the MHM specification, HNF-S-0468 revision 5, the procurement of the devices by the MHM supplier/manufacturer did not include evidence of the traceability according to the contract quality assurance requirements nor did the supplier/manufacturer perform dedications of commercial grade items (CGI). The reason for the latter is that the supplier did not have responsibility for the accident basis in the nuclear safety analysis to assign accident prevention credit to specific devices within a control circuit. Therefore, the devices that had to be dedicated to perform a safety function was performed by the CSB Project organization at the Hanford site.

Purpose

This document serves to explain and to document the test results and qualifications for personnel and test equipment for the MHM CGI program. Which components are CGI dedicated are based on the Safety Equipment List (SEL), SNF-5591, and the procedures for the Spent Nuclear Fuel Project.

UNREVIEWED SAFETY QUESTION-LIKE SCREENING FORM		
Document Number: EDT 629027	USQ-Like Tracking # (Facility & Unique Identifying #) CSB-00-030	Page 1 of 3
Title: Canister Storage Building – MCO Handling Machine – Commercial Grade Item Dedications		

Description: The program and test results for the MHM commercial grade dedication is included in document SNF-6315. This document serves to explain and to document the test results and qualifications for personnel and test equipment for the MHM CGI program. Selection of component for CGI dedication was based on the Safety Equipment List (SEL), SNF-5591, and the procedures for the Spent Nuclear Fuel Project. The USQ-Like was performed per the pending CSB SAR Rev.0.

USQ-Like Screening Questions

Note: Respond to each question and provide basis/justification for each response. An adequate justification provides sufficient explanation such that an independent reviewer could reach the same conclusion.

1. Does the Proposed Activity Result in a Permanent or Temporary Change in the Facility as Described in the Pending Authorization Basis (ABs not fully implemented – not included in Appendix B to NS-4-001)?

N/A NO YES/MAYBE

Basis: This document serves to explain and to document the test results and qualifications for personnel and test equipment for the MHM CGI program. The test results demonstrate that the components tested meet their functional requirements, which is consistent with the facility design as described in the pending AB. Selection of component for CGI dedication was based on the Safety Equipment List (SEL), SNF-5591, and the procedures for the Spent Nuclear Fuel Project. The SEL and procedures are the same as those in the pending AB. Therefore, the proposed activity does not result in a permanent or temporary change in the facility as described in the pending AB.

- 1a. Does the proposed activity result in a change or need for a change to any other SNF Project facility, including those not yet included in Appendix B to NS-4-001?

N/A NO YES/MAYBE

If Yes or Yes/Maybe indicate

CVDF CSB MCO Topical K Basins

UNREVIEWED SAFETY QUESTION-LIKE SCREENING FORM		
Document Number: EDT 629027	USQ-Like Tracking # (Facility & Unique Identifying #) CSB-00-030	Page 2 of 3
Title: Canister Storage Building – MCO Handling Machine – Commercial Grade Item Dedications		

2. Does the Proposed Activity Result in a Temporary or Permanent Change in the Procedure(s) as Described, Outline or Summarized in the Pending Authorization Basis (ABs not fully implemented – not included in Appendix B to NS-4-001)?

N/A NO YES/MAYBE

Basis: This document serves to explain and to document the test results and qualifications for personnel and test equipment for the MHM CGI program. The test results demonstrate that the components tested meet their functional requirements, which is consistent with the facility design as described in the pending AB. Selection of component for CGI dedication was based on the Safety Equipment List (SEL), SNF-5591, and the procedures for the Spent Nuclear Fuel Project. The SEL and procedures are the same as those in the pending AB. Therefore, the proposed activity does not result in a permanent or temporary change in the procedures as described, outlined, or summarized in the pending AB.

- 2a. Does the proposed activity result in a change or need for a change to any other SNF Project facility, including those not yet included in Appendix B to NS-4-001?

N/A NO YES/MAYBE

If Yes or Yes/Maybe indicate

CVDF CSB MCO Topical K Basins

3. Does the Proposed Activity Result in a Test or Experiment Not Described in the Pending Authorization Basis (ABs not fully implemented – not included in Appendix B to NS-4-001)?

N/A NO YES/MAYBE

Basis: This document serves to explain and to document the test results and qualifications for personnel and test equipment for the MHM CGI program. The test results demonstrate that the components tested meet their functional requirements, which is consistent with the facility design as described in the pending AB. Selection of component for CGI dedication was based on the Safety Equipment List (SEL), SNF-5591, and the procedures for the Spent Nuclear Fuel Project. The SEL and procedures are the same as those in the pending AB. Therefore, the proposed activity does not result in a test or experiment not described in the pending AB.

4. Does the Proposed Activity, Reportable Occurrence, or Issue Require Changes to Pending Technical Safety Requirements (TSRs not fully implemented – not included in Appendix B to NS-4-001)?

N/A NO YES/MAYBE

Basis: This document serves to explain and to document the test results and qualifications for personnel and test equipment for the MHM CGI program. The test results demonstrate that the components tested meet their functional requirements, which is consistent with the facility design as described in the pending AB. Selection of component for CGI dedication was based on the Safety Equipment List (SEL), SNF-5591, and the procedures for the Spent Nuclear Fuel Project. The SEL and procedures are the same as those in the pending AB. Therefore, the proposed activity does not result require changes to TSRs.

UNREVIEWED SAFETY QUESTION-LIKE SCREENING FORM		
Document Number: EDT 629027	USQ-Like Tracking # (Facility & Unique Identifying #) CSB-00-030	Page 3 of 3
Title: Canister Storage Building – MCO Handling Machine – Commercial Grade Item Dedications		

5. Does the Reportable Occurrence or Issue Have Any Potential for Impacting the pending Authorization Basis (ABs not fully implemented – not included in Appendix B to NS-4-001)?

N/A NO YES/MAYBE

Basis: This is an EDT, not a reportable occurrence or issue.

Agree
 Disagree (Requires explanation; attach additional pages as necessary)

USQ-Like Evaluator No. 1

Justin Liu 5/10/00
Signature Date

Yih Justin Liu
(Print Name)

USQ-Like Evaluator No. 2

L. J. Garver 5/10/00
Signature Date

L. J. GARVER
(Print Name)

IF ANY RESPONSE IS "YES/MAYBE" OR THERE IS A DISAGREEMENT WITH ALL "NOs" COMPLETE THE USQ-LIKE EVALUATION FORM USING THE SAME USQ NUMBER AND ATTACH THIS FORM TO THE USQ-LIKE EVALUATION FORM.

SNF Project Nuclear Safety Manager Decision _____

Basis for Decision _____

Signature Date

SNF-6315
Revision 0
PAGE 4

Section 1
Internal Memorandum
00-SNF/CES-003,
dated 3/22/00

INTEROFFICE



CORRESPONDENCE

00-SNF/CES-003

To: G. D. Bazinet S8-06 Date: March 22, 2000
 V. D. Zarasua S2-44
 S. S. Moss R3-11

From: C. E. Swenson *C. E. Swenson* Telephone: 376-0288

cc: A. S. Daughtridge R3-86 L. W. Price R3-26
 T. Z. Anderson B4-68 J. C. Molnar S1-53
 T. W. Libs R3-86 CES File/LB R3-86
 R. C. Garrison S8-07 CSB Project Files S8-06
 D. W. Medford R3-86

Subject: PROJECT NUMBER W-379 – MULTI-CANISTER OVERPACK HANDLING MACHINE – COMMERCIAL GRADE ITEM DEDICATION

The purpose for this memorandum is to document and explain the commercial grade item (CGI) dedication process for the Multi-Canister Overpack Handling Machine (MHM). Components selected for CGI dedication in a safety related application were those that had been specified, procured, and installed on subassemblies by the MHM manufacturers, Alstom Automation (Leicester, U.K.) and Ederer Cranes (Seattle, WA.). Other engineered subassemblies that perform a safety function, such as trolley and bridge seismic restraints, and the Multi-Canister Overpack (MCO) hoisting system, were fabricated, inspected, and tested at the manufacturer's facilities according to the quality assurance program requirements of the contract which is American Society of Mechanical Engineers (ASME) Nuclear Quality Assurance (NQA-1). This is an acceptable method to meet the requirements of 10 CFR 830.120. There is documentation of these results with the supplier's submittals. However, the detailed acceptance testing of the electrical devices for its critical attributes is not available in the MHM supplier's documentation or the site component test packages. So, the special CGI testing of devices selected for safety-related dedication are control panel relays, control contactors, and sensors. These devices are consistent with the Safety Equipment List (SEL), SNF-5591, Part B, for the MHM. The MHM CGI process is based on AP EN-035-00, "Dedication of Commercial Grade Items," section 6.2.3.1, Acceptance Method 1 – special tests and inspections. The original strategy for the MHM CGI program in 1999 was that several items would need to be dedication tested and that this could occur during Pre-Operational Acceptance Testing and completion activities. Therefore, separate items would be ordered for bench testing at a laboratory with a Quality Assurance program that met the requirements for qualified equipment and certified personnel. Initially, the orders were placed by material requisition and purchase order process. The material requisition orders in August 1999 thru October 1999 became an obstacle, so we ordered the devices by contract requisition which invoked a contract for the procurement resulting in more control and responsiveness.

In November 1999, it became obvious due to engineering evaluations of the application of requirements for "Class 1E" items as defined by Institute of Electrical and Electronics Engineers, Inc. (IEEE) 603 and required for Safety Class items, that the MHM SEL was incomplete. So, the

et. all
Page 2
March 23, 2000

basis for which discrete devices were performing a safety function in the control system was incomplete. The MHM SEL was upgraded in December 1999 and has served as the basis for CGI dedication. As devices were delivered in January thru March of 2000 in a piecemeal manner, there was considerable special interaction required with Spent Nuclear Fuel (SNF) Procurement to support the schedule. When enough components were received at Hanford, a contract for laboratory testing services was awarded to Belhaven Applied Technologies (Belhavel) of Kennewick. Also, in January 2000, a review of the Canister Storage Building (CSB) Final Safety Analysis Report had resulted in a reassessment of the nuclear consequences for various accidents. This resulted in fewer devices that served a safety-related function. In fact, The SEL designates the MHM seismic restraints as the ONLY components preventing a Safety Class accident. All other devices are classified Safety Significant.

Since the nuclear safety review of the detailed design for mitigating features of the MHM in Fall 1999, there were a number of modifications required to upgrade the MHM engineering features to ensure prevention of accidents in consequence analysis. Since then, some modification were reassessed and deleted because of the change of the nuclear safety accident consequences in January 2000. Also, since the MHM pre-operational testing phase was essentially complete, CGI testing of devices on the MHM would not interfere with physical testing. In addition, there would be less disruption to the MHM configuration if the installed devices were "in-situ" CGI tested instead of replaced with bench tested devices. Also, it was noted in some cases that bench tested Idec AC relays that plug into a relay socket base does not disrupt the configuration because wires do not need to be de-terminated and re-terminated with strict control to ensure the configuration of the pre-operational test is restored. Since the relay base socket needs to be CGI tested anyway, de-termination of the wires is necessary to perform its CGI test also. CGI testing of Siemens Power Corporation contactors and relays requires de-termination of wires whether tested in-situ or replaced. So, in-situ CGI testing seemed to be the easiest to avoid material transfers through SNF Procurement to Belhaven. Several Honeywell SL1 microswitches were CGI tested in-situ to avoid resetting the microswitch and affecting both the Component Test Procedure (CTP) and the Pre-Operational Test for that device.

The quantity of devices that require CGI testing as a sample of a "Lot" is specified in the sampling basis in the Desk Instruction, DI-003, "*Commercial Grade Item Upgrade Dedication Process Requirements and Implementation Instructions*," Table H-1. These quantities are based upon accepted practice in the commercial nuclear industry in which Electric Power Research Institute (EPRI), EPRI 7218 (NCIG-19) serves as a guideline. A summary is attached. The devices procured and installed on the MHM components by the supplier and its manufacturers are considered from the same "Lot" because they are nearly identical devices (i.e. - same manufacturer and model) and ordered specially for their MHM contract in the same time period in 1997 and 1998. The turret assembly and control panels were built in 1997 and the MCO hoist assembly was completed in 1998.

The CGI testing of operational spare parts needs to be addressed. There are several devices that were procured as explained above, but there will be no CGI dedication qualification for it. Most, if not all of the parts can be CGI dedication bench tested at Belhaven if necessary to have

et. all
Page 3
March 23, 2000

00-SNF/CES-003

“qualified” spare parts available for a safety-related application. Otherwise, the spare parts can be left “Conditionally Accepted” and an emergency CGI dedication bench test can be performed by Belhaven, if still under contract, or by a yet-to-be-identified Hanford instrument test laboratory.

I am available to discuss recommendations for spare parts at your convenience.

rit

00-SNF/CES-003

Attachment
Lot Sampling Quantities

2 pages, including cover

Info from ENG-DI-003 Att H, Table H-1

Sampling Plans

3/8/00 10:54 AM

Reduced Sampling Plan		Normal Sampling Plan		Tightened Sampling Plan	
Lot Size	Sample Size	Lot Size	Sample Size	Lot Size	Sample Size
1-5	1	1	1	1	1
6-13	2	2-4	2	2	2
14-24	3	5-6	3	3-4	3
25-41	4	7-11	4	5-6	4
42-50	5	12-20	5	7-8	5
51-63	6	21-24	6	9-10	6
64-76	7	25-28	7	11	7
77-90	8	29-32	8	12-13	8
91-102	9	33-41	9	14-15	9
103-114	10	42-50	10	16-20	10
115-126	11	51-56	11	21-25	11
127-138	12	57-62	12	26-31	12
139-150	13	63-69	13	32-38	13
151-175	14	70-76	14	39-46	14
176-200	15	77-83	15	47-50	15
201-225	16	84-90	16	51-54	16
>225	16	91-96	17	55-58	17
		97-102	18	59-62	18
		103-108	19	63-66	19
		109-114	20	67-70	20
		115-120	21	71-74	21
		121-126	22	75-78	22
		127-132	23	79-82	23
		133-138	24	83-86	24
		139-144	25	87-90	25
		145-150	26	91-94	26
		151-162	27	95-98	27
		163-174	28	99-102	28
		175-186	29	103-106	29
		187-198	30	107-110	30
		199-210	31	111-114	31
		211-225	32	115-118	32
		225	32	119-122	33
				123-126	34
				127-130	35
				131-135	36
				136-140	37
				141-145	38
				146-150	39
				151-158	40
				159-166	41
				167-174	42
				175-182	43
				183-190	44
				191-198	45
				199-207	46
				208-216	47
				217-225	48
				>225	48

Section 2
CGI Personnel Qualifications

SNF CGI Dedication Qualification Form

In accordance with SNF Project requirements as specified in AP-EN-035-00, SNF Project Dedication of Commercial Grade Items (CGIs), and SNF-DI-003, Commercial Grade Item Upgrade Dedication Process Requirements & Implementation Instructions, the completion of this form designates an individual to be qualified to perform CGI dedication activities.

Individual:

Name: Larry W. Price
 SSN: [REDACTED]
 Location: 2750/D146
 Phone: 372-8770

ORIGINAL

Qualification Summary: (Attach Resume)

Experience: 2 yrs @ Rocky Flats - Dedication Engineering
2 yrs @ Test Laboratory - Dedication Engineering & Testing
1 yr @ Gasser Assoc. - Instructor & developer of Dedication Engineering Training

Education: B.S. Chemical Engineering/Nuclear Engineering
EPRI Seminar - Commercial Grade

AP-EN-035 Training (required): Yes No Completion Date: 7/28/99

Other: 3-4 months at Hanford - performing CGI dedications
Over 25 years of Commercial Nuclear Power Experience plus 6 years of Navy Nuclear Submarine Duty

Evaluation:

Based upon the qualification summary above, review of the individual's resume and the comments below, this individual has the appropriate background and expertise to perform dedication activities.

Comments:

Responsible Manager(s):

By: Dean W. Malford Title: Manager technical Integration Signature: Dean W. Malford Date: 8-12-99
Printed Name Printed Title Printed Title

By: _____ Title: _____ Signature: _____ Date: _____
Printed Name Printed Title Printed Title

By: _____ Title: _____ Signature: _____ Date: _____
Printed Name Printed Title Printed Title

Required Attachment: Resume Optional Attachment: Training Sign-In Form for AP-EN-6-035

Résumé - Larry W. Price**Personal Data:**

Health: excellent
Married-two children
Interests: Scuba diving, private plane piloting,
working out and reading

Address:

P.O. Box 26
Humboldt, AZ 86329
Ph: (520)632-5700
Fax: (520) 632-5701

Education:

Arizona State University-Tempe, Arizona-B.S. Chemical Engineering/Nuclear Engineering (1968-71)
Glendale Community College - Glendale, Arizona (1967-1968)
Academic Honor Society

Special Training:

Basic Nuclear Power School and Nuclear Power Prototype (U.S. Navy)
Management Academy (Arizona Public Service)
Seminars: Nuclear Engineering/Procurement/Receipt/QA/Commercial Grade/Maintenance (by EPRI),
Computer Inter-relational Data Bases, Maintenance Programs, Dale Carnegie Sales Course, etc.

Skills:

Familiar with IBM & MacIntosh word processing, spreadsheet, graphics, presentation and database programs. These include Microsoft Word, Excel, PowerPoint, Project, and File. Others include: WordPerfect, MacWrite, WriteNow, MacFlow, MacDraw, SuperPaint, Filemaker-Pro, and HyperCard.

Experience:

Mr. Price presently provides consulting services to nuclear industry.

Mr. Price provided Senior Project Management services for Johnson Controls Sunbelt Area Office located in Tempe, Arizona. He and his team of engineers, technicians, installers and sub-contractors designed, constructed, and started-up HVAC controls, fire, lighting and security installations for both new construction and renovations. Installations include small, medium and large projects around the metropolitan Phoenix area and the state.

Mr. Price provided engineering services at the DOE facilities at Rocky Flats, Colorado. He was responsible for the development, installation, and training of personnel for the Oracle-based relational database for site-wide use. This program reduces time spent to prepare bills of material for design & work packages to support the Operations Department. Mr. Price also wrote procurement specifications for material, equipment and parts ensuring they met appropriate codes and standards.

Larry W. Price Résumé - Experience (Continued)

- Page 2

Mr. Price provided training services at the DOE facilities at Hanford, Wash. He developed lesson plans for personnel training on applications of DOE Order 5480.19 Conduct of Operations. Note: this activity was in conjunction with that in Rocky Flats described above.

Mr. Price provided engineering, operations and quality assurance services to the nuclear industry. He organized and developed the environmental qualification (EQ) program for safety-related equipment at the Nine Mile Point Unit 1 BWR. Mr. Price was responsible for the EQ program meeting NRC code requirements. He aided in NRC presentations and audit activities. Later, he functioned in a leading role on the NMP-2 program.

Mr. Price developed and presented a training program for Commercial Grade Procurement of parts and equipment for Commonwealth Edison nuclear power plants.

Mr. Price served as the Director of the GA Engineering Test Laboratory in Prescott Valley, Arizona. He was responsible for start-up of the facility, marketing, testing and inspection activities for the EQ and Dedication of parts for the Nuclear Industry. All operational and testing procedures and start-up of equipment and systems were his responsibilities.

Mr. Price developed an inter-relational data base computer code. It is used for EQ, nameplate data, equipment lists and locations, spare parts, zone info, etc. The code calculates the qualified life of operating nuclear plant equipment based on actual ambient conditions measurement. It is practical for tracking plant life extension (PLEX) data.

Mr. Price prepared performance goals for the Rancho Seco Nuclear Plant. These goals met NRC, ANI and INPO requirements in the areas of engineering, operations, training, maintenance, and surveillances. Mr. Price prepared design changes, licensing and compliance submittals; also, field walkdowns and overview of the EQ program for Wisconsin Public Service's Kewaunee PWR.

He was Management Analysis Company's (MAC) project leader for work control process improvement for Southern California Edison at San Onofre Nuclear Generating Station, working in the control room for both units. He co-authored the Methods Manual for Work and Equipment Control, essentially a handbook to provide detailed direction and guidance to increase the efficiency of the work process for the start-up and operation of SONGS.

At APS, Mr. Price was the Site Construction Manager for the Palo Verde Nuclear Power Plant project representing five utilities for the construction of three units. Earlier, he was the field engineering manager of Civil, Electrical, Mechanical and Instrumentation & Control engineering disciplines.

Larry W. Price Résumé - Experience (Continued)

Page 3

At Exxon Nuclear, he was a planner/scheduler, system coordinator, and contracts administrator. As a construction supervisor and later as a start-up engineer, he completed the turnover of the St. Lucie Unit 1 plant to the Florida Power and Light's Operations Department. He also performed nuclear fuel max power flux profile calculations prior to movement of control rods at Oyster Creek plant. He also was a member of the Exxon nuclear fuel inspection team. Before this, he developed maintenance training programs and taught nuclear plant training courses for Westinghouse to prepare reactor operators for their NRC exams as well as plant nuclear engineer's training, and many others. At Powers Regulator, he provided sales and engineering of environmental control systems, many were computer-based.

Employment:

<u>Dates</u>	<u>Company/Location</u>	<u>Position/Responsibility</u>
11/97 - Present	Centurion Engineering Humboldt, Arizona	President - Engineering Contractor in Nuclear Power
6/95 - 11/97	Johnson Controls Tempe, AZ	Senior Project Manager
6/93 - 6/95	VIP/Barri/EG & G Rocky Flats, Colo.	Engineer - Procurement Engineering & Software Development Project Leader
4/94 - 7/94	Gasser Associates/ Kaiser Engineering Hanford, Washington	Trainer for DOE Conduct of Operations
4/88 - 6/93	Centurion Engineering Prescott, Arizona	President - Engineering Contractor in Nuclear Power
8/83 - 1/93	Gasser Associates	Principal Engineer and Lab Director U.S. Nuclear Power Plants and Test Lab in Prescott, AZ
4/80 - 8/83	Centurion Engineering Prescott, Arizona	President and Project Leader for Management Analysis Company
4/76 - 4/80	Arizona Public Service Phoenix, Arizona	Site Construction Manager
4/74 - 4/76	Exxon Nuclear Co. Bellevue, Wash.	Field Engineer
4/73 - 4/74	Westinghouse Corp. Pittsburgh, PA	Lead Training Engineer
5/71 - 4/73	Powers Regulator Co. Denver, Colorado	Sales Engineer

Page 16

In accordance with SNF Project requirements as specified in AP-EN-035-00, SNF Project Dedication of Commercial Grade Items (CGIs), and SNF-DI-003, Commercial Grade Item Upgrade Dedication Process Requirements & Implementation Instructions, the completion of this form designates an individual to be qualified to perform CGI dedication activities.

Individual:

Name: Edwin R. Kahler
 SSN: [REDACTED]
 Location: 8 Elm Court San Anselmo, CA 94960
 Phone: (415) 453-8836

ORIGINAL

Qualification Summary: (Attach Resume)

Experience: Supervisor – Spare Parts Dedication Group, PG&E., max staff 35 1988-1994
EPRI Joint Utility Task Group – developed generic dedication packages for utilities
Pacific Gas & Electric Co. 1973-1999, 20+ years commercial nuclear power
experience

Education: Registered Professional Engineer, Electrical, California #E10110
Washington State University

AP-EN-035 Training (required): Yes No Completion Date: 7/28/99
Co-author and trainer for AP-EN-035 and ENG-DI-002

Other: Member of various EPRI Task Groups developing utility CGI standards, e.g. NP-
5652, TR-102260, etc.
Former member ASME NQA-1 QA Committee, Design and Procurement Work
Group 1985-1995, also Task Group member on Supplement for CGI.

Evaluation:

Based upon the qualification summary above, review of the individual's resume and the comments below, this individual has the appropriate background and expertise to perform dedication activities.

Comments:

Responsible Manager(s):

By: Dean W. Medford Title: Manager Tech Integration Signature: Dean W. Medford Date: 8-12-99
 Printed Name Printed Title Printed Title
 By: _____ Title: _____ Signature: _____ / _____
 Printed Name Printed Title Printed Title
 By: _____ Title: _____ Signature: _____ / _____
 Printed Name Printed Title Printed Title

RESUME

Edwin R. Kahler, P.E.

1994 - Present

Management oversight of the Diablo Canyon Nuclear Power Plant Commercial Grade Dedication Program including reviews of program and procedure revisions for conformance to NRC requirements and expectations, technical reviews of dedication packages, maintaining cognizance of industry activities and interfacing with the NRC on CGI issues.

1988 - 1994

Supervisor, Spare and Replacement Parts Program - Supervised 22 engineers in developing technical evaluations, dedication requirements and acceptance criteria for commercial grade items, providing technical evaluations of commercial and Appendix B supplier programs. Major projects included:

- CGI dedication of an emergency diesel generator
- CGI dedication of replacement SF6 4kV circuit breakers
- Fastener consolidation program.

Also supervised the Environmental Qualification Program from 1988 to 1991.

1981 - 1988

Supervisor, Engineering Quality Control Program - Supervised 12 engineers and auditors in developing, maintaining and implementing programs and procedures for engineering activities.

1975 - 1980

Electrical Engineer - Major design projects included; system and seismic upgrades for Humboldt Bay Power Plant Nuclear Unit 3, generator replacement Antioch Power Plant, Los Medanos Natural Gas Storage Field, H2S abatement systems for Geysers Power Plants.

1973 - 1975

Start-up Engineer - Geysers Power Plants Units 9, 10 and 11; Morro Bay Power Plant Tank Farm, Diablo Canyon Nuclear Power Plant.

Industry Associations

ASME NQA-1 Quality Assurance Committee - Member of the Design and Procurement Work Group 1984 to 1996. This work group was responsible for Sections 3 and 7 and supplements for design and procurement. Member of subcommittee that developed the supplement on commercial grade dedication.

EPRI Joint Utility Task Group (JUTG) 19988 to 1994 responsible for developing the EPRI standards for commercial grade dedication. Committee chairman for several of the industry generic dedication packages

Qualifications

Registered Professional Electrical Engineer - California
Washington State University - Electrical Engineering

SNF CGI Dedication Qualification Form

In accordance with SNF Project requirements as specified in AP-EN-035-00, SNF Project Dedication of Commercial Grade Items (CGIs), and SNF-DI-003, Commercial Grade Item Upgrade Dedication Process Requirements & Implementation Instructions, the completion of this form designates an individual to be qualified to perform CGI dedication activities.

Individual:

Name: THOMAS W. LIBS
 SSN: [REDACTED]
 Location: 2750E/D279
 Phone: 376-1850

ORIGINAL

Qualification Summary: (Attach Resume)

Experience: 35 YEARS IN NUCLEAR FIELD - TEST & OPS EXPERIENCE
INCLUDES EQUIP DUAL WITH GE & QUADREC, CGI
DEDICATION WITH DUKE AT HANFORD

Education: MS PHYSICAL SCIENCE
MBA
NUMEROUS TRAINING COURSES / OTHER COLLEGE COURSES

AP-EN-035 Training (required): Yes No Completion Date: MAY 99

Other: _____

Evaluation:

Based upon the qualification summary above, review of the individual's resume and the comments below, this individual has the appropriate background and expertise to perform dedication activities.

Comments: _____

Responsible Manager(s):

By: Dean W. Medford Title: Manager Technical Integration Signature: Dean W. Medford Date: 8-12-99
Printed Name Printed Title

By: _____ Title: _____ Signature: _____ Date: _____
Printed Name Printed Title

By: _____ Title: _____ Signature: _____ Date: _____
Printed Name Printed Title

THOMAS W. LIBS**Operations Engineering and Testing, Regulatory Analysis and Licensing,
and Safety Evaluation**

Mr Libs has over 30 years of experience in the nuclear industry (government facilities, commercial power plants and commercial industry institutes), providing assistance to approximately twenty (20) nuclear BWR, PWR and government production and test facilities. These include Diablo Canyon, Trojan, Humboldt Bay BWR, Grand Gulf, Fermi, Nine Mile Point 1 & 2, Hope Creek, Kauwanee, Prairie Island 1 & 2, Duane Arnold, Beaver Valley 1 & 2 and DC Cook 1 & 2, Westinghouse, GE, EPRI, INPO, Hanford N-Reactor, LOFT and at naval reactors. He has broad and diversified 'hands-on' experience in operations, testing, maintenance and engineering of nuclear power plant systems. He has defined and developed engineering, operations and maintenance programs and procedures for essentially categories of plant operation, testing and maintenance, consistent with utility, USNRC and other governmental requirements. Further, Mr Libs has extensive experience in the preparation of nuclear facility SARs, Technical Specifications and regulatory analysis and licensing.

In particular, Mr Libs' experience includes the following:

- Developed procedures for surveillance and testing at seven (7) commercial PWRs and four (4) BWRs
- Prepared Plant Technical Specifications for four (4) PWRs and three (3) BWRs
- Prepared plant operating, test and maintenance procedures for four (4) PWRs and two (2) BWRs
- Prepared procedures for rad-waste management at Beaver Valley Nuclear Power Station
- Participated in the preparation of initial Technical Specifications and surveillance test procedures for the Loss of Flow Test Facility (LOFT) in Idaho
- Performed engineering and operational design review of selected safety related systems at two (2) commercial PWRs
- Startup Test Engineer for the safety related I&C systems at three (3) commercial PWRs
- Developed I&C systems test equipment in use at commercial nuclear facilities, including transducer time response test equipment, planning and test procedures for equipment qualification and monitoring requirements for equipment operability and performance

Recently Mr Libs completed ten years as senior engineer and supervising engineer in PG&E's Nuclear Regulatory Affairs Department for licensing of Diablo Canyon Power Plant. His prior experience includes three years as project manager with the Electric Power Research Institute (EPRI) responsible for formulation and technical management of component reliability and plant availability improvement projects and seven years as an engineering, licensing, and operations consultant. Other experience includes two years as test engineer on overhaul, construction, and startup of naval nuclear plants, three years as a licensed naval reactor operator and plant operations engineer, and four years as project engineer for testing with the Lawrence Livermore Laboratory at the Nevada Test Site.

PG&E: Mr Libs was a Supervising Engineer in the Nuclear Regulatory Affairs Department responsible for operational licensing activities to ensure compliance with USNRC requirements and practices. He prepared and organized the operations and engineering information in response to NRC requirements. As such, he was responsible for assuring the accuracy and completeness of the owner's responses to the regulatory agency. Prior to the receipt of the commercial operating license at Diablo Canyon, he was directly involved with operations, maintenance and engineering activities on behalf of the Nuclear Regulatory Affairs Department for preparation of regulatory correspondence for NRC Letters, I&E Bulletins, Regional NRC Inspection Reports and License Amendment requests. Specific duties and accomplishments included preparation of responses to construction, engineering and operations licensing issues, responses to allegations and preparation of the rate adjustment application to the CPUC. Mr Libs recommended and implemented direction and strategy necessary to maintain and comply with the DCPD operating licenses, including development of technical positions for response to NRC information requests; license amendment requests including changes to the Technical Specifications; and

coordination of activities between the Nuclear Regulatory Affairs Department and Operating Plant Staff.

ENG and PTA: Prior to working on Diablo Canyon and Humboldt Bay, he was a Senior Nuclear Engineering Consultant for plant licensing, plant availability and component reliability improvements, procedures preparation and review, plant site engineering, operations and design review. He also prepared FSAR sections and responses to NRC questions for GE for WPPSS 2, Grand Gulf and Hope Creek.

He contributed to Fermi Project for identification of Class IE equipment (NSSS & BOP) for qualification per IEEE 323 and NUREG-0588. The effort included instrument and electrical systems review, plant records search, identification of harsh environment zones, and preparation of equipment qualification summaries and test plans. Also prepared input for a computerized equipment qualification data base system for GE. Completed assignment as project engineer on a General Electric contract to develop Qualification Sample Material Evaluation (QSME) aging analysis reports for Grand Gulf Nuclear Plant IE devices. Mr Libs completed six (6) month assignment at Susquehanna plant, where he prepared operations and I&C test and surveillance procedures prior to issuance of the operating license. As a consultant to the General Electric Company, he evaluated the Nine Mile Point 2 and Hope Creek FSARs against the NRC Standard Review Plan criteria for engineering and operational requirements.

EPRI: At the EPRI's Nuclear Safety Analysis Center, Mr Libs helped establish the Significant Event and Licensee Evaluation Report assessment project prior to turning it over to INPO. He assisted EPRI in the analysis of residual heat removal system operating and design experience for both BWR and PWR plants and analysis for generic qualification of Class IE equipment.

As a Project manager in EPRI's Engineering and Operations Department, Systems and Component Performance Program, he was responsible for formulation and management of projects for research and development to improve power plant components and systems. His project responsibilities included system controls; primary coolant pumps and seals; piping support reliability improvements; improved cable tray and conduit supports; refueling water clarity and refueling equipment improvements; containment leak rate testing; feedwater heater tube erosion and flow effects; evaluation of on-line leak sealing methods; valve stem leakage improvements; MSR and feedwater heater performance monitoring; and other plant availability and component reliability improvement projects.

NSC (Quadrex): Mr Libs was responsible for test group assistance and preparation of pre-op, surveillance, maintenance, and operations procedures for five (5) commercial nuclear plants (Kewaunee, Prairie Island, Duane Arnold, Beaver Valley, Trojan and DC Cook). He also performed design review of selected plant safety systems PWR facilities and assisted with SAR revisions and preparation, training, review of programs for operations, piping and system analysis for pipe whip and jet impingement effects at other nuclear plants.

As Manager of the Plant Operational Support Group, he managed over 40 engineers on such tasks as planning programs and preparing manuals and procedures for initial construction test, plant startup, operations, maintenance, and surveillance for eight (8) PWR and five (5) BWR plants. He also prepared QA Plans, Plant Procedures Plan, manpower requirements, and definition of system boundaries for the preoperational testing phase for six (6) nuclear plants in the PWR Standard Nuclear Unit Power Plant Systems ('SNUPPs'). He also implemented Standardized Technical Specifications at DC Cook and the Beaver Valley Nuclear Stations. As a consultant to GE, he prepared answers to NRC questions on two BWRs facilities. Other group responsibilities included I&C and electrical construction testing at Trojan Nuclear Plant; transducer time response equipment design and testing at Beaver Valley and Trojan; chemistry, health physics, and instrumentation procedures and systems operation and maintenance training at FitzPatrick; plant productivity studies for the FEA; radwaste management program for Beaver Valley; redwaste management risk analysis for ERDA; plant safety systems studies for EPRI; and engineering and test support for plant systems and piping design review, and A/E and NSSS bid evaluations.

Mr Libs also has diversified government facilities experience working with Westinghouse. At Hanford's N-Reactor, Mr Libs assisted in the preparation of a computerized preventive maintenance program ('PM') and at LOFT, he prepared the initial Technical Specifications for LOFT to be consistent with commercial nuclear power 22 requirements and comply with consistency with AEC-NRC requirements. At LOFT, he also worked in the operational engineering group to prepare LOFT's operations and surveillance testing procedures. Later, as a consultant to Kaiser, he performed safety assessment and feasibility studies for processing, containerization and transportation to DOT requirements for low-level waste from Hanford's storage tanks to Nevada. This included assessment of other alternatives, such glass bead vitrification, clay calcification and other options considered by ERDA.

EDUCATION: BS, Engineering Physics, Humboldt State University, 1961
 MS, Physical Science, Oregon State University, 1967
 MBA, San Jose State University, 1975
 Course work in MS Taxation at San Jose State University

PROFESSIONAL:

Graduate Westinghouse - Idaho Nuclear Power School, 1968
 Qualified Plant Operator, Dual Reactor AIW Naval Prototype, 1970
 Registered Professional Nuclear Engineer, California, 1975

Employment History

1995 - Present Self Employed Consultant and businessman
 1986 - 1995: PG&E, San Francisco and Diablo Canyon
 1980 - 1986: ENG Services Corporation and Power Technical Associates Inc.
 Campbell, CA
 1977 - 1980: Electric Power Research Institute, Palo Alto, CA
 1972 - 1977: Nuclear Services Corporation (Quadrex), Campbell, CA
 1967 - 1972: Westinghouse Idaho and Mare Island, CA
 1964 - 1967: University of California, Lawrence Radiation Laboratory

Publications:

Residual Heat Removal Experience Review and Safety Analysis (PWRs), NSAC-52 (1983), Co-author with G. Vine, W. Layman, S. Farrington

Feedwater Heater Workshop Proceedings, EPRI 78-123 (1979)

Design, Stress Analysis and Operating Experience in Feedwater Heaters, Proceeding of the Conference on Industrial Energy Conservation Technology (1980)

Training Record of Attendance

Administrative Procedure No.: EN-6-035-00

Title: SNF Project Dedication of Commercial Grade Items (CGIs)

Date of Training: 7/28/99

Location: 2150 / 200E

Attendees:

Print Name	SSN	Signature
LARRY W. PRICE	XXXXXXXXXX	<i>[Signature]</i>
DAVID C MARBURGER	XXXXXXXXXX	<i>[Signature]</i>
THOMAS LIBS	XXXXXXXXXX	<i>[Signature]</i>

SNF CGI Dedication Qualification Form

In accordance with SNF Project requirements as specified in AP-EN-035-00, SNF Project Dedication of Commercial Grade Items (CGIs), and SNF-DI-003, Commercial Grade Item Upgrade Dedication Process Requirements & Implementation Instructions, the completion of this form designates an individual to be qualified to perform CGI dedication activities.

Individual:

Name: DAVID MARBURGER
SSN: [REDACTED]
Location: 2750 - D146 200 E
Phone: 509 372 8669

ORIGINAL

Qualification Summary: (Attach Resume)

Experience: NUCLEAR COMMERCIAL PLANTS - SAFETY - REGULATORY

Education: BSME

AP-EN-035 Training (required): Yes No Completion Date: 7/28/99

Other: _____

Evaluation:

Based upon the qualification summary above, review of the individual's resume and the comments below, this individual has the appropriate background and expertise to perform dedication activities.

Comments:

Responsible Manager(s):

By: Dean V. Melford Title: Manager Technical Interst^{ation} Signature: Dean V. Melford Date: 8/2-99

By: _____ Title: _____ Signature: _____ / _____
Printed Name Printed Title Date

By: _____ Title: _____ Signature: _____ / _____
Printed Name Printed Title Date

Required Attachment: Resume Optional Attachment: Training Sign-In Form for AP-EN-6-035

DAVID C. MARBURGER
PO Box 3062
Richland, WA 99352

Residence - None

SUMMARY

This overview describes my experience gained through positions with Westinghouse Electric Corporation since 1966. This experience has been mainly in commercial nuclear power, although it includes three recent assignments at Hanford, DOE site. I am knowledgeable with the Nuclear Steam Supply System and the Balance of Plant system designs. Positions held include Regulatory, Project, Systems Design Engineering, interfacing with Architect Engineers and with Regulatory Agencies and utility customer technical/regulatory support. Much of my experience has been in the regulatory/licensing field, specializing in resolution of non-conformances, definition of root cause, determination of corrective action and the associated documentation to the NRC such as Licensing Event Reports, Justification for Continued Operation and Operability Evaluations. I am experienced with performance of 10 CFR 50.59 evaluations and safety evaluations. I have also prepared numerous Licensing Amendment Requests.

Since 1985, I have successfully completed field assignments with six different customers. In these assignments, I worked as a member of the customer's organization on tasks defined by them. I typically operated in a mode where the task/problem was outlined and then I worked as an independent contributor with minimum direction from the customer or from Westinghouse headquarters. My field assignments were with:

- o Westinghouse Hanford Corporation, Richland, WA
- o Pacific Gas and Electric, Diablo Canyon Power Station
- o Tennessee Valley Authority, Sequoyah Nuclear Plant
- o Florida Power and Light, Turkey Point Nuclear Generation Plant
- o Omaha Public Power District, Fort Calhoun
- o Iowa Electric Light and Power Company, Duane Arnold Nuclear Plant

My last assignment, at Hanford, ended in October, 94. The Pittsburgh Westinghouse Corporate reduction in force effective at that time eliminated this position, I would like to continue my career with work on assignments of interest where my skills and experience would be effectively utilized.

My most recent positions are:
(No longer with Westinghouse)

Oct./98 to present Hanford, Washington SNF/VDF

Update VDF commercial dedication packages to capture later revisions of the Procurement Packages and of the Safety Equipment List and other changes.

June/98 to Sept/98 Hanford, Washington SNF/VDF

Prepare SNF VDF commercial dedication packages for Safety Category hardware components.

Oct/96 to April/ 98 Diablo Canyon Power Plant

Prepare second submittal of the Improved Standard Technical Specification.

Oct/95 to June/96 Diablo Canyon Power Plant

Prepare assigned chapters of the Improved Diablo Canyon Technical Specification to the NUREG-1441 Merits Specification.

March/95 to Aug/95 New Jersey Power and Light

Administer the NRC Resident Open Item List for Unit 1.

1) Experience Summary at Hanford WHC.

July 1994 to
November 1994

Westinghouse Electric Corporation
Nuclear Technology Division
Nuclear Safety and Regulatory Initiatives

On-site support to Westinghouse Hanford Corporation at Richland, Wa. Prepare K-Basins Seismic Leak USQ Summary Report. Conduct reviews leading to signature and issuance as a WHC controlled document. Conduct independent design review and resolve comments. Assist Task Team Leader, J. C. Wiborg, in other tasks as requested.

September 1993 to July 1994

Westinghouse Electric Corporation
Nuclear Technology Division
Nuclear Safety and Regulatory Initiatives

On-site support to Westinghouse Hanford Corporation at Richland, Wa. Prepare management level procedures for Regulatory Standards under the direction of K. D. Daschke. These include a policy procedure for 10 CFR 820 compliance, a procedure for guidelines for preparation of Technical Safety Requirements, and a revised procedure on processing Unreviewed Safety Questions.

June 1993 to
September 1993

Westinghouse Electric Corporation
Advanced Nuclear Technology Division
Nuclear Safety

Provide on-site assistance in the preparation of portions of the Deactivation Plan for the Westinghouse Hanford Company PUREX facility in Richland WA under the direction of D. J. Washenfelter. This plutonium processing facility is being deactivated. The Plan documents the actions to be taken and the acceptance guidelines for the deactivation completion. The Plan is submitted to the Regulatory agencies for their review and approval.

2) Experience Summary at PG&E Diablo Canyon Power Plant

September 1988 to June 1993.

Westinghouse Electric Corporation
Nuclear Technology Systems Division
Nuclear Safety

This assignment was with Pacific Gas and Electric Diablo Canyon Power Plant in Avila Beach, CA. I worked directly with the Regulatory Compliance section under the direction of T. L. Grebel. I provided a background of knowledge of Westinghouse design and a communication channel to Westinghouse technical groups in Pittsburgh to obtain their assistance to resolve plant problems, as appropriate. My work involves participation

in Technical Review Groups which are a procedural approach utilized by DCPD to investigate problems determine root cause, and define corrective actions. One major activity is the preparation of Operability Evaluations. These OEs are used to document/justify continued operation of the plant in the presence of some non-conforming condition. The OE documents that the plant can operate safely and within the License and Design basis until the condition is corrected. I also have prepared License Amendment Requests. License Event Reports, and Non-conformance Reports. I provided preparation guidance, technical review and comment on similar documents prepared by others in the group. I served as Westinghouse senior site representative for the performance of the Diablo Canyon Power Plant Surveillance Test Procedure Basis program in 1992.

AFFILIATIONS

Professional Engineer registration in the states of Ohio and Pennsylvania.

EDUCATION

Bachelor of Mechanical Engineering. 1959 Ohio State University Columbus. Ohio (5 year curriculum)

Specialized Training

- Management Techniques
- Management by Objectives
- Management by Problem Solving
- Performance Review
- Stress Management
- Games People Play
- Managerial Grid
- Negotiation Training
- Communication Workshop
- Quality is Free

- Psychology of Human Behavior University of Pittsburgh
- Nuclear Power Reactor Safety. Massachusetts Institute of Technology
- Personnel Management. University of Pittsburgh
- Personnel Administration. University of Pittsburgh

Training Record of Attendance

Administrative Procedure No.: EN-6-035-00

Title: SNF Project Dedication of Commercial Grade Items (CGIs)

Date of Training: 7/28/99

Location: 2150 / 200E

Attendees:

Print Name	SSN	Signature
LARRY W. PRICE	[REDACTED]	<i>[Signature]</i>
DAVID C MARBURGER	[REDACTED]	<i>[Signature]</i>
THOMAS LIBS	[REDACTED]	<i>[Signature]</i>

Section 3
Quality Assurance Surveillances

SPENT NUCLEAR FUEL PROJECT QUALITY ASSURANCE SURVEILLANCE REPORT

DATE: February 10, 2000

SR# 1K-FY00-059

Page 1 of 1

Copies To:

D. L. Anderson	S7-41	K. Napora	S2-48	SNF Project Files	R3-11
T. Z. Anderson	B4-68	R. P. Ruth	R3-11	Surveillance File	S2-48
A. S. Daughtridge	R3-86	C.E. Swenson	S8-07	W-379 (CSB) Project File	S8-06
M. F. Nicol	S2-48	FHA VS	G1-50		

Subject: MHM Commercial Grade Item Dedication Testing - Bellhaven Labs**System:** CSB MCO Handling Machine (MHM)**Equipment No.:** CR-2**Location:** Bellhaven Labs, Kennewick WA**Survey Item:** N/A**Reference:** Contract 2717 Release 3**Person Contacted:** Jeff Cadick, Bellhaven QA**Report:**

On February 10, 2000, a supplier performance monitoring surveillance was performed at Bellhaven Laboratories, Kennewick, Washington. This surveillance was performed at the request of the MHM Design Authority (DA) to assess the supplier's conformance to the requirements of Statement of Work (SOW) for Contract 2717 Release 3, "CGI Bench Testing of Electrical Components." Sixteen (16) attributes were developed from the SOW and reviewed at the vendor's facility; eight (8) of the items were found to be satisfactory. Testing of items has just begun (in progress, none completed) so the remaining eight (8) were considered to be not applicable (N/A) at the time of the review. These attributes will be reviewed when testing of some items is completed. (No deficiencies identified)

The attributes reviewed during this surveillance included use of current approved revision of test procedures, maintenance of test procedures, control of changes to the test procedures (approved redlines), documentation of test information and results on the test procedure, verification of test instrument calibration, and verification of appropriate training records.

The vendor's test facility was neat and well organized. No other work was being performed in the same testing location, thus segregation and special control of the Buyer's material was not required. The Buyer's status indicators (Conditional Accept envelops) were with the parts and contained copies of the receiving inspection plans used for each item. (The vendor will provide a separate status indicator to document their activity for each completed item after testing.)

The vendor's representatives were helpful and provided all required information upon request. Results of the surveillance were discussed with the vendor's Quality Assurance Manager upon completion of the surveillance (exit briefing).

Performed By: T.Z. Anderson**Concurred By:** K. Napora

Signature

Date

Signature

Date

ORIGINAL

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-059 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELLHAVEN

Page 1 of 4 DATE 02/09/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

TZA 2/9/00

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
This surveillance is intended to review Bellhaven's performance of testing in accordance with Contract 2717 Release 3 SOW (Rev 1, 1/20/00) and various Buyer provided CGI testing procedures.	Bellhaven contact: Jeff Cadick, QA				
WORK SCOPE (Section 3)					
1. Items failing inspection/testing shall be documented on the testing facility's deficiency form and forwarded to the Buyer's representative for disposition. (3.c)		No items have failed inspection or testing			X
2. Test anomalies shall be documented. (3.d)		No test anomalies have occurred			X
3. Inspections or tests beyond the capability of the testing facility may be subcontracted to qualified sub-vendors that are approved for the work activity. (3.e)		No testing has been performed by a subcontractor			X
4. Test procedures will be provided by the Buyer. (3.f) Note: Changes to procedures must be approved by the Buyer's representative.	Procedure RLY-1 for items MHM-023 & -026	Copy of original being used for testing. Original copy at test location. Changes to procedure are signed by Buyer's representative. Copy being used has contains these changes.	X		
DELIVERABLES (Section 4)					
5. The Contractor will provide a complete, certified test report for each component or family of components.		No items completed, three items in progress. Awaiting megger tester to complete testing of in process items.			X

SNF-6315, Rev. 0

Page 32

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-059 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELLHAVEN

Page 2 of 4 DATE 02/09/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
6. Packaging of returned items shall prevent dirt, moisture, or other foreign matter from contaminating or damaging the components, thus maintaining the validity of the calibration/testing.		No items completed, three items in progress.			X
CONFIGURATION MANAGEMENT (Section 11)					
7. Parts may not be substituted without Buyer's approval. All components and accompanying documentation delivered to the Contractor shall be maintained together and returned to the Buyer.		No substitutions have been made. All items have been supplied by Buyer.	X		
TRAINING (Section 12)					
8. Contractor's personnel are required to have documented qualifications, experience, and training to perform bench testing of electrical components of this type.	Jim Johnson, Jeff Cadick training folders reviewed.	Cadick folder has certification for calibration expiration date of 9/21/99. Noted to Contractor. No calibrations have been performed to date.	X		
STANDARDS (Section 15)					
9. Instruments used for testing shall be calibrated in accordance with calibration standards and have traceability of primary/secondary standards to NIST. (Also 3.j)	BAT-123 (HP3457A), 7/29/00 BAT-124 (HP3457A), 7/30/00 BAT-052 (TEK DMM916), 2/18/00	All items being used are under current calibration	X		

SNF-6315, Rev. 0

Page 33

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-059 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELLHAVEN

Page 3 of 4 DATE 02/09/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
TEST PROCEDURES					
10. Test procedure approved by DA.	See attached table		X		
11. Test instrument information recorded.	See attached table		X		
12. CGI item identification information recorded.	See attached table		X		
13. Test performance recorded.	See attached table	Items in process, no items completed at the time of this review. Testing to date has been properly recorded on test procedure sheet copies.	X		
14. Summary of Results recorded.		Items in process, no items completed at the time of this review			X
15. Notes completed (when applicable).		Items in process, no items completed at the time of this review			X
16. Test Engineer/Technician signature.		Items in process, no items completed at the time of this review			X

SNF-6315, Rev. 0

Page 34

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-059 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELLHAVEN

Page 4 of 7 DATE 02/09/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

TEST PROCEDURE NO.	RLY-1	RLY-1							
CGI Dedication Package #	MHM-023	MHM-026							
TEST PROCEDURE ATTRIBUTES									
Test procedure approved by DA	X	X							
Test instrument information recorded	X	X							
CGI item identification information recorded	X	X							
Test performance recorded	X *	X *							
Summary of results recorded									
Notes (when applicable)									
Test Engineer/ Technician signature									

* - Testing in progress, tests not completed at time of review. Awaiting megger.

SNF-6315, Rev. 0

Page 35

SPENT NUCLEAR FUEL PROJECT QUALITY ASSURANCE SURVEILLANCE REPORT

DATE: February 15, 2000

SR# 1K-FY00-067

Page 1 of 1

Copies To:

D. L. Anderson	S7-41	K. Napora	S2-48	SNF Project Files	R3-11
T. Z. Anderson	B4-68	R. P. Ruth	R3-11	Surveillance File	S2-48
A. S. Daughtridge	R3-86	C.E. Swenson	S8-07	W-379 (CSB) Project File	S8-06
M. F. Nicol	S2-48	FHAVS	G1-50		

Subject: MHM Commercial Grade Item Dedication Testing - Belhaven Labs**System:** CSB MCO Handling Machine (MHM)**Equipment No.:** CR-2**Location:** Belhaven Labs, Kennewick WA**Survey Item:** N/A**Reference:** Contract 2717 Release 3**Person Contacted:** Jeff Cadick, Belhaven Quality Assurance**Report:**

On February 15, 2000, a supplier performance monitoring surveillance was performed at Belhaven Laboratories, Kennewick, Washington. This surveillance was performed to review testing documentation for first five (5) items completed under Contract 2717 Release 3, "CGI Bench Testing of Electrical Components." Eighteen (18) attributes were reviewed at the vendor's facility; thirteen (13) of the items were found to be satisfactory while the remaining five (5) were considered to be not applicable (N/A). (No deficiencies identified)

The attributes reviewed during this surveillance included use of current approved revision of test procedures, control of changes to the test procedures (approved redlines), documentation of test information and results on the test procedure, verification of test instrument calibration and use of status indicators.

All testing documentation for the five (5) test specimens had been completed with all information recorded and sign-offs completed. Tested items were wrapped and sealed in plastic along with the vendor's status indicators. The Buyer's status indicators (Conditional Accept envelopes) were with the parts and contained copies of the receiving inspection plans used for each item. The vendor included a Certificate of Conformance for the tested items.

The vendor's test facility was neat and well organized. No other work was being performed in the same testing location, thus segregation and special control of the Buyer's material was not required.

The vendor's representative was helpful and provided all required information upon request. Results of the surveillance were discussed with the vendor's QA Manager upon completion of the surveillance (exit briefing).

[Note: This is the second surveillance performed on Contract 2717 Release 3. Previous surveillance: 1K-FY00-059.]

Performed By: T.Z. Anderson

Concurred By: K. Napora

Signature

Date

Signature

Date

ORIGINAL

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-067 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 1 of 4 DATE 02/15/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson *[Signature]* 2/16/00

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
This surveillance is intended to review Belhaven's performance of testing in accordance with Contract 2717 Release 3 SOW (Rev 1, 1/20/00) and various Buyer provided CGI testing procedures.	Belhaven contact: Jeff Cadick, QA				
WORK SCOPE (Section 3)					
1. Items failing inspection/testing shall be documented on the testing facility's deficiency form and forwarded to the Buyer's representative for disposition. (3.c)		None			X
2. Test anomalies shall be documented. (3.d)		None			X
3. Inspections or tests beyond the capability of the testing facility may be subcontracted to qualified sub-vendors that are approved for the work activity. (3.e)		None			X
4. Test procedures will be provided by the Buyer. (3.f) Note: Changes to procedures must be approved by the Buyer's representative.	CON-1 (MHM-019), RLY-1 (MHM-023, -026), LS-2 (MHM-007)	Redline changes initialed and dated by Buyer's representative	X		
DELIVERABLES (Section 4)					
5. The Contractor will provide a complete, certified test report for each component or family of components.	Certificate of Conformance signed 2/15/00	Testing is not complete. CofC for first 5 items tested.	X		
6. Packaging of returned items shall prevent dirt, moisture, or other foreign matter from contaminating or damaging the components, thus maintaining the validity of the calibration/testing.	Items for test procedures noted in #4 above	Each item protected by sealed plastic wrap. Tags inside package. Awaiting completion of packaging.	X		
CONFIGURATION MANAGEMENT (Section 11)					

SNF-6315, Rev. 0

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER IK-FY00-067 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 2 of 4 DATE 02/15/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
7. Parts may not be substituted without Buyer's approval. All components and accompanying documentation delivered to the Contractor shall be maintained together and returned to the Buyer.		None			X
TRAINING (Section 12)					
8. Contractor's personnel are required to have documented qualifications, experience, and training to perform bench testing of electrical components of this type.		Reviewed previously, see Surveillance Report IK-FY00-59			X
STANDARDS (Section 15)					
9. Instruments used for testing shall be calibrated in accordance with calibration standards and have traceability of primary/secondary standards to NIST. (Also 3.j)	AVO Megger BM80/2, #6410-889/0000100/5345, expiration 2/9/00	Other items reviewed previously, see Surveillance Report IK-FY00-059	X		

SNF-6315, Rev. 0

Page 58

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-067 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 3 of 7 DATE 02/15/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
TEST PROCEDURES					
10. Test procedure approved by DA.	See attached table		X		
11. Test instrument information recorded.	See attached table		X		
12. CGI item identification information recorded.	See attached table		X		
13. Test performance recorded.	See attached table		X		
14. Summary of Results recorded.	See attached table		X		
15. Notes completed (when applicable).	See attached table		X		
16. Test Engineer/Technician signature.	See attached table		X		
STATUS INDICATORS					
17. Buyer's Conditional Acceptance Envelop	See attached table		X		
18. Belhaven Green Acceptance Tag	See attached table		X		

SNF-6315, Rev. 0

Page 39

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-067 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 4 of 4 DATE 02/15/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

TEST PROCEDURE NO.	CON-1	RLY-1	RLY-1	LS-2	LS-2				
CGI Dedication Package #	MHM-019	MHM-023	MHM-026	MHM-007 Bag #1	MHM-007 Bag #2				
TEST PROCEDURE ATTRIBUTES									
Test procedure approved by DA	X	X	X	X	X				
Test instrument information recorded	X	X	X	X	X				
CGI item identification information recorded	X	X	X	X	X				
Test performance recorded	X	X	X	X	X				
Summary of results recorded	X	X	X	X	X				
Notes (when applicable)	X	X	X	X	X				
Test Engineer/ Technician signature	X	X	X	X	X				
STATUS INDICATORS									
Conditional Acceptance Envelop	X	X	X	X	X				
Belhaven Green Acceptance Tag	X	X	X	X	X				

SNF-6315, Rev. 0

Page 40

SPENT NUCLEAR FUEL PROJECT QUALITY ASSURANCE SURVEILLANCE REPORT

DATE: March 2, 2000

SR# 1K-FY00-085

Page 1 of 1

Copies To:

D. L. Anderson	S7-41	K. Napora	S2-48	SNF Project Files	R3-11
T. Z. Anderson	B4-68	R. P. Ruth	R3-11	Surveillance File	S2-48
A. S. Daughtridge	R3-86	C.E. Swenson	S8-07	W-379 (CSB) Project File	S8-06
M. F. Nicol	S2-48	FHAVS	G1-50		

Subject: MHM Commercial Grade Item Dedication Testing – Belhaven Labs**System:** CSB MCO Handling Machine (MHM)**Equipment No.:** CR-2**Location:** Belhaven Labs, Kennewick WA**Survey Item:** N/A**Reference:** Contract 2717 Release 3**Person Contacted:** Jeff Cadick, Belhaven Quality Assurance**Report:**

On March 2, 2000, a supplier performance monitoring surveillance was performed at Belhaven Laboratories, Kennewick, Washington. This surveillance was performed to review testing documentation for items completed under Contract 2717 Release 3, "CGI Bench Testing of Electrical Components." Nineteen (19) attributes were reviewed at the vendor's facility; fourteen (14) of the items were found to be satisfactory while the remaining five (5) were considered to be not applicable (N/A). (No deficiencies identified)

The attributes reviewed during this surveillance included use of current approved revision of test procedures, control of changes to the test procedures (approved redlines), documentation of test information and results on the test procedure, verification of test instrument calibration, use of status indicators, sign-off by the test performer, the Buyer's test engineer and Design Authority, and preliminary packaging prior to shipment

All testing documentation for the twenty-six (26) test specimens had been completed with all information recorded and sign-offs completed. Some of the tested items were wrapped and sealed in plastic along with the vendor's status indicator, while the remainder were staged for wrapping. The Buyer's status indicators (Conditional Accept envelopes) were with the parts and contained copies of the receiving inspection plans used for each item. The vendor is including a Certificate of Conformance signed by the Company President for the tested items.

The vendor's test facility was neat and well organized. The Buyer's material was identified and segregation from other material in the laboratory facility. There are a number of items which remain to be tested. Field testing (in-situ) has been initiated so that some test equipment has been moved to the field to support this testing. Some of the bench testing will not be able to proceed until the test equipment is returned to the lab.

The vendor's representative was helpful and provided all required information upon request. Results of the surveillance were discussed with the vendor's QA Manager upon completion of the surveillance (exit briefing).

[Note: This is the third surveillance performed on Contract 2717 Release 3. Previous surveillances: 1K-FY00-059, -067.]


Performed By: T.Z. Anderson

Concurred By: K. Napora

Signature


 3/6/00
 Date

Signature


 3/7/00
 Date

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-085 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 1 of 4 DATE 03/02/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

TZA 3/2/00

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
This surveillance is intended to review Belhaven's performance of testing in accordance with Contract 2717 Release 3 SOW (Rev 1, 1/20/00) and various Buyer provided CGI testing procedures.	Belhaven contact: Jeff Cadick, QA	3/2/00			
WORK SCOPE (Section 3)					
1. Items failing inspection/testing shall be documented on the testing facility's deficiency form and forwarded to the Buyer's representative for disposition. (3.c)		None			X
2. Test anomalies shall be documented. (3.d)		None			X
3. Inspections or tests beyond the capability of the testing facility may be subcontracted to qualified sub-vendors that are approved for the work activity. (3.e)		None			X
4. Test procedures will be provided by the Buyer. (3.f) Note: Changes to procedures must be approved by the Buyer's representative.	All completed bench test plans. See table listing.	Acceptance signature by Buyer's test engineer and DA. Copy of original used to start multiple testing using same test plan.	X		
DELIVERABLES (Section 4)					
5. The Contractor will provide a complete, certified test report for each component or family of components.	Certificate of Compliance. Completed test plans.	CoC signed by Company President Test plans signed by tester.	X		
6. Packaging of returned items shall prevent dirt, moisture, or other foreign matter from contaminating or damaging the components, thus maintaining the validity of the calibration/testing.	All completed bench test items. See table listing.	Being prepared for shipment to Buyer.	X		
CONFIGURATION MANAGEMENT (Section 11)					

SNF-6315, Rev. 0

Page 42

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-085 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 2 of 4 DATE 03/02/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
7. Parts may not be substituted without Buyer's approval. All components and accompanying documentation delivered to the Contractor shall be maintained together and returned to the Buyer.		No part substituted.			X
TRAINING (Section 12)					
8. Contractor's personnel are required to have documented qualifications, experience, and training to perform bench testing of electrical components of this type.	Michael Cram qualification and training file - new employee.	Certified for electrical & instrumentation only as of 2/29/00. Required reading in progress; 6 of 11 completed with due date of 3/15/00. Work to be reviewed by supervision and checked by QA.	X		
STANDARDS (Section 15)					
9. Instruments used for testing shall be calibrated in accordance with calibration standards and have traceability of primary/secondary standards to NIST. (Also 3.j)		Instruments reviewed during previous surveillances (1K-FY00-0059 & 0067)			X

SNF-6315, Rev. 0

Page 43

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-085 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 3 of 4 DATE 03/02/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
TEST PROCEDURES					
10. Test procedure approved by DA.	See attached table		X		
11. Test instrument information recorded.	See attached table		X		
12. CGI item identification information recorded.	See attached table		X		
13. Test performance recorded.	See attached table		X		
14. Summary of Results recorded.	See attached table		X		
15. Notes completed (when applicable).	See attached table		X		
16. Test Engineer/Technician signature.	See attached table		X		
17. Buyer's representatives.	See attached table	LS-1 (9951) just completed, awaiting signature	X		
STATUS INDICATORS					
18. Buyer's Conditional Acceptance Envelope	See attached table		X		
19. Belhaven Green Acceptance Tag	See attached table		X		

SNF-6315, Rev. 0

Rope 444

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-085 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 4 of 4 DATE 03/02/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

TEST PROCEDURE NO.	CON-1	RLY-1	LS-2	SELSW-1	RLY-3	LS-1	PS-1	LS-1	
CGI Dedication Package #	019	026 023		027	016C	013	009	022	
Item Identification	1 - 10		#1, #2		B8506 B8507	A - F	A, B	9951 9951	
TEST PROCEDURE ATTRIBUTES									
Test procedure approved by DA	X	X	X	X	X	X	X	X	
Test instrument information recorded	X	X	X	X	X	X	X	X	
CGI item identification information recorded	X	X	X	X	X	X	X	X	
Test performance recorded	X	X	X	X	X	X	X	X	
Summary of results recorded	X	X	X	X	X	X	X	X	
Notes (when applicable)	N/A	N/A	N/A	N/A	X	N/A	N/A	N/A	
Test Engineer/ Technician signature	X	X	X	X	X	X	X	X	
Buyer's representatives	X	X	X	X	X	X	X	*	
STATUS INDICATORS									
Conditional Acceptance Envelop	X	X	X	X	X	X	X	X	
Belhaven Green Acceptance Tag	X	X	X	X	X	X	X	X	

* - Testing just completed, awaiting Buyer's representative review and signature (scheduled 3/3/00).

SPENT NUCLEAR FUEL PROJECT QUALITY ASSURANCE SURVEILLANCE REPORT

DATE: March 14, 2000

SR# 1K-FY00-091

Page 1 of 1

Copies To:

D. L. Anderson	S7-41	K. Napora	S2-48	SNF Project Files	R3-11
T. Z. Anderson	B4-68	R. P. Ruth	R3-11	Surveillance File	S2-48
A. S. Daughtridge	R3-86	C.E. Swenson	S8-07	W-379 (CSB) Project File	SS-06
M. F. Nicol	S2-48	FHAVS	G1-50		

Subject: MHM Commercial Grade Item Dedication Testing – Belhaven Labs**System:** CSB MCO Handling Machine (MHM)**Equipment No.:** CR-2**Location:** Belhaven Labs, Kennewick WA**Survey Item:** N/A**Reference:** Contract 2717 Release 3 and 4**Person Contacted:** Jeff Cadick, Belhaven Quality Assurance**Report:**

On March 13, 2000, a supplier performance monitoring surveillance was performed at Belhaven Laboratories, Kennewick, Washington. This surveillance was performed to review bench and in-situ testing documentation for items completed under Contract 2717 Release 3, "CGI Bench Testing of Electrical Components," and Release 4, "In-Situ Testing." Nineteen (19) attributes were reviewed at the vendor's facility; fifteen (15) of the items were found to be satisfactory while the remaining four (4) were considered to be not applicable (N/A). (No deficiencies identified)

The attributes reviewed during this surveillance included use of current approved revision of test procedures, control of changes to the test procedures (approved redlines and revision log), documentation of test information and results on the test procedure, use of status indicators, sign-off by the test performer, the Buyer's test engineer and Design Authority.

Testing documentation for the six (6) bench test specimens had been completed with all information recorded and sign-offs completed. The Buyer's status indicators (Conditional Accept envelopes) were with the parts and contained copies of the receiving inspection plans used for each item. The vendor had provided a green acceptance tag to cover all six items. After a review of the test paperwork and a check of the items, a Buyer's green acceptance tag was written for each item. The Buyer's tag will be included with the item when packaged and shipped to the CSB.


Seventeen completed in-situ test plans were reviewed. All vendor attributes were properly completed. Buyer representative initials were missing from several plans (does not invalidate the test results). These missing items were marked using Post-It Notes. The Design Authority will be notified to provide the missing initials prior to final acceptance of the respective in-situ dedication packages.

The vendor's test facility was neat and well organized. The Buyer's material was identified and segregation from other material in the laboratory facility. The vendor's representative was helpful and provided all required information upon request. Results of the surveillance were discussed with the vendor's QA Manager upon completion of the surveillance (exit briefing).


[Note: This is the fourth surveillance performed on Contract 2717 Release 3 and 4. Previous surveillances: 1K-FY00-059, -067, -085.]

Performed By: T.Z. Anderson**Concurred By:** K. Napora

Signature


 3/14/00
 Date

Signature


 3/15/00
 Date

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-091 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 1 of 5 DATE 03/13/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

[Signature] 3/14/00

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
This surveillance is intended to review Belhaven's performance of testing in accordance with Contract 2717 Release 3 SOW (Rev 1, 1/20/00) and various Buyer provided CGI testing procedures.	Belhaven contact: Jeff Cadick, QA	3/13/00			
WORK SCOPE (Section 3)					
1. Items failing inspection/testing shall be documented on the testing facility's deficiency form and forwarded to the Buyer's representative for disposition. (3.c)	NCR BEL 00-01 Contactor 044-4, Model # 3TF4411-OAK6	NCR issued 3/6/00 and transmitted to Buyer representative	X		
2. Test anomalies shall be documented. (3.d)	NCR BEL 00-01	NCR issued 3/6/00	X		
3. Inspections or tests beyond the capability of the testing facility may be subcontracted to qualified sub-vendors that are approved for the work activity. (3.e)		None			X
4. Test procedures will be provided by the Buyer. (3.f) Note: Changes to procedures must be approved by the Buyer's representative.	See table for test plans reviewed	All changes to bench and in-situ tests have been properly approved	X		
DELIVERABLES (Section 4)					
5. The Contractor will provide a complete, certified test report for each component or family of components.	See table for test plans reviewed		X		
6. Packaging of returned items shall prevent dirt, moisture, or other foreign matter from contaminating or damaging the components, thus maintaining the validity of the calibration/testing.		Items reviewed not ready for shipment			X

SNF-6315, Rev. 0

Page 47

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-091 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 2 of 5 DATE 03/13/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
CONFIGURATION MANAGEMENT (Section 11)					
7. Parts may not be substituted without Buyer's approval. All components and accompanying documentation delivered to the Contractor shall be maintained together and returned to the Buyer.		None			X
TRAINING (Section 12)					
8. Contractor's personnel are required to have documented qualifications, experience, and training to perform bench testing of electrical components of this type.	Michael Cram	Required reading in progress. Required to be completed by 3/15/00.	X		
STANDARDS (Section 15)					
9. Instruments used for testing shall be calibrated in accordance with calibration standards and have traceability of primary/secondary standards to NIST. (Also 3.j)	See test plans	Test instruments identified on test plans. Test instruments reviewed previously.	X		

SNF-6315, Rev. 0

Page 48

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-091 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 3 of 5 DATE 03/13/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
TEST PROCEDURES					
10. Test procedure approved by DA.	See attached table		X		
11. Test instrument information recorded.	See attached table		X		
12. CGI item identification information recorded.	See attached table		X		
13. Test performance recorded.	See attached table		X		
14. Summary of Results recorded.	See attached table		X		
15. Notes completed (when applicable).	See attached table		X		
16. Test Engineer/Technician signature.	See attached table		X		
17. Buyer's representatives.	See attached table	A few initials random missing. Marked. Does not invalidate testing.	X		
STATUS INDICATORS					
18. Buyer's Conditional Acceptance Envelope	See attached table	Bench tested items only	X		
19. Belhaven Green Acceptance Tag	See attached table	Bench tested items only	X		

SNF-6315, Rev. 0

Page 49

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-091 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 4 of 5 DATE 03/13/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

TEST PROCEDURE NO.	CON-1	IST-LS-2	IST	IST-LC-1	IST	IST	IST-LS-1	IST-Se1Sw-2
CGI Dedication Package #	044	007	003B	016A	003C	003A	011	032
Item Identification	1,2,3,5 ,6,7 [4**]	LFTSLPIAY LFTSLPIAX LFTSLP2AY LFTSLP2AX	1X 1Y	LCMHR1X LCMHR1Y LCMHR2X LCMHR2Y	PLS2, OM PLS1, OM	RSVMGHX RSVMGHY	LFPHFRX FLPHFRY	Mode Selector Switch
TEST PROCEDURE ATTRIBUTES								
In-situ test revision log	N/A	X	*	X	*	*	X	X
Test procedure approved by DA	X	X	X	X	X	X	X	X
Test instrument information recorded	X	X	X	X	X	X	X	X
CGI item identification information recorded	X	X	X	X	X	X	X	X
Test performance recorded	X	X	X	X	X	X	X	X
Summary of results recorded	X	X	X	X	X	X	X	X
Notes (when applicable)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Test Engineer/ Technician signature	X	X	X	X	X	X	X	X
Buyer's representatives	X	X	X	X	X	X	X	X

SNF-6315, Rev. 0

Page 50

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-091 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 5 of 5 DATE 03/13/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

STATUS INDICATORS								
Conditional Acceptance Envelope	X	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Belhaven Green Acceptance Tag	X	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Buyer's Green Acceptance Tag	X	N/A	N/A	N/A	N/A	N/A	N/A	N/A

* - Buyer's representative initials missing.

** - 044-4 failed one test attribute. NCR BEL 00-01 issued to Buyer.

SNF-6315, Rev. 0

Page 51

SPENT NUCLEAR FUEL PROJECT QUALITY ASSURANCE SURVEILLANCE REPORT

DATE: March 22, 2000

SR# 1K-FY00-101

Page 1 of 1

Copies To:

D. L. Anderson	S7-41	K. Napora	S2-48	SNF Project Files	R3-11
T.Z. Anderson	B4-68	R. P. Ruth	R3-11	Surveillance File	S2-48
A. S. Daughtridge	R3-86	C.E. Swenson	S8-07	W-379 (CSB) Project File	S8-06
M. F. Nicol	S2-48	FHAVS	G1-50		

Subject: MHM Commercial Grade Item Dedication Testing – Belhaven Labs**System:** CSB MCO Handling Machine (MHM)**Equipment No.:** CR-2**Location:** Belhaven Labs, Kennewick WA**Survey Item:** N/A**Reference:** Contract 2717 Release 3 and 4**Person Contacted:** Jeff Cadick, Belhaven Quality Assurance**Report:**

On March 22, 2000, a supplier performance monitoring surveillance was performed at Belhaven Laboratories, Kennewick, Washington. This surveillance was performed to review bench and in-situ testing documentation for items completed under Contract 2717 Release 3, "CGI Bench Testing of Electrical Components," and Release 4, "In-Situ Testing." Nineteen (19) attributes were reviewed at the vendor's facility; sixteen (16) of the items were found to be satisfactory while the remaining three (3) were considered to be not applicable (N/A). (No deficiencies identified)

The attributes reviewed during this surveillance included: use of current approved revision of test procedures, control of changes to the test procedures (approved redlines and revision log), documentation of test information and results on the test procedure, use of status indicators, sign-off by the test performer, the Buyer's test engineer and Design Authority.

Testing documentation for the twenty-four (24) bench test specimens had been completed with all information recorded and sign-offs completed. The Buyer's status indicators (Conditional Accept envelopes) were with the parts and contained copies of the receiving inspection plans used for each item. The vendor had provided green acceptance stickers for each of the items. After a review of the test paperwork and a check of the items, a Buyer's green acceptance tag was written for each item or group of items. The Buyer's tag will be included with the items when packaged and shipped to the CSB.


Seventeen (17) completed in-situ test plans were reviewed. All vendor attributes were properly completed. Several plans were awaiting the Buyer representative's signature. These signatures will be required prior to test plan acceptance.

The vendor's test facility was neat and well organized. The Buyer's material was segregated from other material in the laboratory facility. The vendor's representative was helpful and provided all required information upon request. Results of the surveillance were discussed with the vendor's QA Manager upon completion of the surveillance (exit briefing).

[Note: This is the fifth surveillance performed on Contract 2717 Release 3 and 4. Previous surveillances: 1K-FY00-059, -067, -085, -091.]

Performed By: T.Z. Anderson

Concurred By: K. Napora


 Signature _____ Date 3/22/00


 Signature _____ Date 3/27/00

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-101 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 1 of 5 DATE 03/22/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

T.Z. Anderson
3/22/00

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
This surveillance is intended to review Belhaven's performance of testing in accordance with Contract 2717 Release 3 SOW (Rev 1, 1/20/00), Release 4, and various Buyer provided CGI testing procedures.	Belhaven contact: Jeff Cadick, QA	3/22/00			
WORK SCOPE (Section 3)					
1. Items failing inspection/testing shall be documented on the testing facility's deficiency form and forwarded to the Buyer's representative for disposition. (3.c)	NCR BEL-00-01	Reviewed previously. Awaiting Buyer disposition and return to Belhaven.	X		
2. Test anomalies shall be documented. (3.d)	NCR BEL-00-01	Reviewed previously	X		
3. Inspections or tests beyond the capability of the testing facility may be subcontracted to qualified sub-vendors that are approved for the work activity. (3.e)		None			X
4. Test procedures will be provided by the Buyer. (3.f) Note: Changes to procedures must be approved by the Buyer's representative.	Bench and in-situ test plans	See table	X		
DELIVERABLES (Section 4)					
5. The Contractor will provide a complete, certified test report for each component or family of components.	Bench and in-situ test plans	See table	X		
6. Packaging of returned items shall prevent dirt, moisture, or other foreign matter from contaminating or damaging the components, thus maintaining the validity of the calibration/testing.		Not ready for shipment			X

SNF-6315, Rev. 0

Page 53

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-101 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 2 of 5 DATE 03/22/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
CONFIGURATION MANAGEMENT (Section 11)					
7. Parts may not be substituted without Buyer's approval. All components and accompanying documentation delivered to the Contractor shall be maintained together and returned to the Buyer.		None			X
TRAINING (Section 12)					
8. Contractor's personnel are required to have documented qualifications, experience, and training to perform bench testing of electrical components of this type.	Michael Cram	Required reading completed and checked off by J Cadick	X		
STANDARDS (Section 15)					
9. Instruments used for testing shall be calibrated in accordance with calibration standards and have traceability of primary/secondary standards to NIST. (Also 3.j)	Instruments noted on test plans with tag ID and calibration due date	Instruments reviewed previously	X		

SNF-6315, Rev. 0

Page 54

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-101 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 3 of 5 DATE 03/22/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

SUBJECT/ACTIVITY REQUIREMENT REFERENCE	EVIDENCE EXAMINED/ PERSONNEL CONTACTED	OBSERVATIONS/COMMENTS	COMPLY		
			YES	NO	N/A
TEST PROCEDURES					
10. Test procedure approved by DA.	See attached table		X		
11. Test instrument information recorded.	See attached table		X		
12. CGI item identification information recorded.	See attached table		X		
13. Test performance recorded.	See attached table		X		
14. Summary of Results recorded.	See attached table		X		
15. Notes completed (when applicable).	See attached table		X		
16. Test Engineer/Technician signature.	See attached table		X		
17. Buyer's representatives.	See attached table		X		
STATUS INDICATORS					
18. Buyer's Conditional Acceptance Envelope	See attached table		X		
19. Belhaven Green Acceptance Tag	See attached table		X		

SNF-6315, Rev. 0

Page 55

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-101 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 4 of 5 DATE 03/22/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

TEST PROCEDURE NO.	020A	LS-1	LS-1	IST	IST	IST	IST	LST-1; LS-1
CGI Dedication Package #	020A	014	004	012; 019A	019B; 048A	048B; 048C	023B; 047	002; 004
Item Identification	1-19, 1-3, 1-6	1,2	1	PESSPX, PESSPY; BLC	TLC; PHHY	PHLY; SSLY	TPXM; TRLC	1; 1
TEST PROCEDURE ATTRIBUTES								
In-situ test revision log	N/A	N/A	N/A	X	X	X	X	X
Test procedure approved by DA	X	X	X	X	X	X	X	X
Test instrument information recorded	X	X	X	X	X	X	X	X
CGI item identification information recorded	X	X	X	X	X	X	X	X
Test performance recorded	X	X	X	X	X	X	X	X
Summary of results recorded	X	X	X	X	X	X	X	X
Notes (when applicable)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Test Engineer/ Technician signature	X	X	X	X	X	X	X	X
Buyer's representatives	X	Missing *	X	X	Missing ;X	X; Missing	X	X

SNF-6315, Rev. 0

Page 54

SURVEILLANCE CHECKLIST

SURVEILLANCE NUMBER 1K-FY00-101 TITLE MHM COMMERCIAL GRADE ITEM (CGI) TESTING - BELHAVEN

Page 5 of 5 DATE 03/22/00 PREPARED BY T.Z. Anderson Rev. 0 PERFORMED BY T.Z. Anderson

STATUS INDICATORS								
Conditional Acceptance Envelope	X 3453	X 3449	X 3454	N/A	N/A	N/A	N/A	X 3467; X 70634
Belhaven Green Acceptance Tag	X	X	X	N/A	N/A	N/A	N/A	X
Buyer's Green Acceptance Tag	X	X	X	N/A	N/A	N/A	N/A	X

* - Buyer's representative signature missing, DA notified

SPENT NUCLEAR FUEL PROJECT QUALITY ASSURANCE SURVEILLANCE REPORT

DATE: March 22, 2000

SR# 1K-FY00-101

Page 1 of 1

Copies To:

D. L. Anderson	S7-41	K. Napora	S2-48	SNF Project Files	R3-11
T. Z. Anderson	B4-68	R. P. Ruth	R3-11	Surveillance File	S2-48
A. S. Daughtridge	R3-86	████████████████████	████████████████████	W-379 (CSB) Project File	S8-06
M. F. Nicol	S2-48	FHAVS	G1-50		

Subject: MHM Commercial Grade Item Dedication Testing – Belhaven Labs**System:** CSB MCO Handling Machine (MHM)**Equipment No.:** CR-2**Location:** Belhaven Labs, Kennewick WA**Survey Item:** N/A**Reference:** Contract 2717 Release 3 and 4**Person Contacted:** Jeff Cadick, Belhaven Quality Assurance**Report:**

On March 22, 2000, a supplier performance monitoring surveillance was performed at Belhaven Laboratories, Kennewick, Washington. This surveillance was performed to review bench and in-situ testing documentation for items completed under Contract 2717 Release 3, "CGI Bench Testing of Electrical Components," and Release 4, "In-Situ Testing." Nineteen (19) attributes were reviewed at the vendor's facility; sixteen (16) of the items were found to be satisfactory while the remaining three (3) were considered to be not applicable (N/A). (No deficiencies identified)

The attributes reviewed during this surveillance included: use of current approved revision of test procedures, control of changes to the test procedures (approved redlines and revision log), documentation of test information and results on the test procedure, use of status indicators, sign-off by the test performer, the Buyer's test engineer and Design Authority.

Testing documentation for the twenty-four (24) bench test specimens had been completed with all information recorded and sign-offs completed. The Buyer's status indicators (Conditional Accept envelopes) were with the parts and contained copies of the receiving inspection plans used for each item. The vendor had provided green acceptance stickers for each of the items. After a review of the test paperwork and a check of the items, a Buyer's green acceptance tag was written for each item or group of items. The Buyer's tag will be included with the items when packaged and shipped to the CSB.


Seventeen (17) completed in-situ test plans were reviewed. All vendor attributes were properly completed. Several plans were awaiting the Buyer representative's signature. These signatures will be required prior to test plan acceptance.

The vendor's test facility was neat and well organized. The Buyer's material was segregated from other material in the laboratory facility. The vendor's representative was helpful and provided all required information upon request. Results of the surveillance were discussed with the vendor's QA Manager upon completion of the surveillance (exit briefing).

[Note: This is the fifth surveillance performed on Contract 2717 Release 3 and 4. Previous surveillances: 1K-FY00-059, -067, -085, -091.]

Performed By: T.Z. Anderson**Concurred By:** K. Napora


 Signature _____ Date 3/22/00


 Signature _____ Date 3/27/00

ORIGINAL

SNF PROJECT QUALITY ASSURANCE SURVEILLANCE REPORT

DATE: 3-28-2000

SR# 1K-FY00-104

Page 1 of 1

Copies To:

D. L. Anderson	S7-41	A. S. Daughtridge	R3-86	C. E. Swenson	S8-07
K. Napora	S2-48	M. F. Nicol	S2-48	Surveillance File	S2-48
S. S. Moss	R3-11	R. P. Ruth	R3-11	SNF-CAM(deficient only)	S2-48
SNF Project File	R3-11	CSB Project File	S8-06		

Subject: MHM CGI SUVEILLANCE BELHAVEN LABS (W-379)

System: N/A

Location: Canister Storage Building

Reference: N/A

Person Contacted: Jeff Cadick (Belhaven)

Equipment No.: N/A

Survey Item: N/A

Report:

This unscheduled surveillance report documents SNF Project QA review and approval of reports of Commercial Grade Item (CGI) testing of Safety Class components for the MCO Handling Machine (MHM). These reports were reviewed at Belhaven Labs on 3-27-2000. Reports of both bench and in-situ testing were reviewed. In general, the reports were complete and acceptable with the following exceptions.

- 1) On a few reports, textual changes and corrections were initialed, but not dated. Some these were corrected by the individual who made the change or correction. The others were flagged and left for correction.
- 2) On one test report the instrument ID number and calibration due date was not filled in for one item of M&TE. This was on the second test report of a set of two identical components test one after the other. The missing information was recorded on the first test report. The second test report was completed by the individual who performed the test, and was approved.

Note, some of the textual changes and corrections, and signatures on the test reports were made in colored inks. However, the colors used produce legible photocopies.

Performed By: S. Scott Moss

Concurred By: K. Napora

Stephen Scott Moss 4-3-2000
 Signature Date

Karen Napora 4-6-00
 Signature Date

10/1/01

Page 60

Page 60

SNF-6315
Revision 0

Section 4

Test Equipment Calibration Records

Belhaven

Applied Technologies

Customer SESCO Electric

Certificate of Calibration

Tag 029E/009 Model 6106 Manufacturer PROTO

Instrument Torque Wrench Serial No 5239875

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 70F
Accuracy of Instrument 4% CW FS
Calibrated Range: 0-36 in lbs

Calibration Report No. 00-068

Date Due: 1/13/2001

Test Equipment

BAT-072

Calibrated by: *[Signature]* 1/13/01

Certified by: *[Signature]*
Quality Assurance Manager

QA RECO

Belhaven

Applied Technologies

Customer BAT

Certificate of Calibration

Tag BAT-092 Model L1010 Manufacturer Staco Energy Products

Instrument Power Source Serial No 8232

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68 F
 Accuracy of Instrument See report
 Calibrated Range: 140 V

Calibration Report No. BEL99-100

Date Due: 4/6/2000

Test Equipment

Prema Multi-Function Meter S/N10012

Calibrated by:  4-6-99

Certified by:  4-9-99
 Quality Assurance Manager

ORIGINAL COPY

Bethaven Calibration Data Sheet

Tag No BAT-092
 Instrument Type Power Source
 Manufacturer Staco Energy Products
 Serial No 8232
 Model L1010
 Cal Due Date 4/6/2000
 System
 Special Instructions

	Cal Point	As Found	As Left	% Full Scale Accuracy
Units: V	0	0.01557	0.01557	0.0111
F.S. Accuracy See report	10	9.963	9.963	-0.0264
F.S. Accuracy	20	19.923	19.923	-0.0550
Full Scale 140	30	31.115	31.115	0.7964
Permitted Variation 0.0000	40	41.722	41.722	1.2300
Cal Temp 68 F	50	51.04	51.04	0.7429
	60	61.82	61.82	1.3000
	70	71.50	71.50	1.0714
	80	81.59	81.59	1.1357
	90	91.69	91.69	1.2071
	100	100.92	100.92	0.6571
	110	110.49	110.49	0.3500
	120	120.18	120.18	0.1286
	130	129.81	129.81	-0.1357
	140	140.42	140.42	0.3000

Test Equipment Prema Multi-Function Meter S/N10012

Calibration Performed By *[Signature]* Date 4-6-89

ORIGINAL

Belhaven

Applied Technologies

Customer Belhaven

Certificate of Calibration

Tag BAT-105 Model 4363 Manufacturer Leeds & Northrup

Instrument Resistor / Shunt Serial No 1656470

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68 F
 Accuracy of Instrument 0.0350%
 Calibrated Range: 0.001 ohms

Calibration Report No. BEL99-378

Date Due: 5/25/2000

Test Equipment

Prema Multi-Function Meter S/N10012
 Isotek CS-10 Current Shunt, S/N: H121776 (BAT-104)

Calibrated by: Sean S for GPS 5-25-99

Certified by: J. Caswell 5-25-99
 Quality Assurance Manager

ORIGINAL**COPY**

Belhaven Calibration Data Sheet

Report Number
BEL99-378

Tag No BAT-105

Instrument Type Resistor / Shunt

Manufacturer Leeds & Northrup

Serial No 1656470

Model 4363

Cal Due Date 5/25/2000

System

Special Instructions

Cal Point	As Found	As Left	% Full Scale Accuracy
0.001	0.00099965	0.00099965	-0.0350

Units: ohms

F.S. Accuracy 0.0350%

F.S. Accuracy

Full Scale 0.001

Permitted Variation 0.0000 ohms

Cal Temp 68 F

Test Equipment Prema Multi-Function Meter S/N10012
Isotek CS-10 Current Shunt, S/N: H121776 (BAT-104)

Calibration Performed By

J. S. for GPS

Date

May 25, 1999

ORIGINAL

Belhaven

Applied Technologies

Customer Belhaven Applied Tech.

Certificate of Calibration

Tag BAT-124 Model 3457A Manufacturer Hewlett Packard
Instrument Multimeter Serial No 3114A14701

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.


Temperature at Calibration: 69F
Accuracy of Instrument See data sht.
Calibrated Range: Full
Calibration Report No. BEL99-647

Date Due: 7/30/2000


Test Equipment

Prema Multi-Function Meter S/N10012

Calibrated by:

 7-30-99

Certified by:

 7-30-99

Quality Assurance Manager

ORIGINAL**COPY**

PERFORMANCE TEST CARD 90 DAY LIMITS

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14701

Test Performed by GPS
Date 7-27-99
Reference Temperature 69

DC VOLTAGE TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
OFFSET TEST							
1	Short	300 V Range	+ 000.0007 V	<u>000.0002</u>	- 000.0007 V	<u>✓</u>	_____
2	Short	30 V Range	+ 00.00020 V	<u>00.00002</u>	- 00.00020 V	<u>✓</u>	_____
3	Short	3 V Range	+ 0.000007 V	<u>0.000001</u>	- 0.000007 V	<u>✓</u>	_____
4	Short	300 mV Range	+ 000.0040 mV	<u>000.0015</u>	- 000.0040 mV	<u>✓</u>	_____
5	Short	30 mV Range	+ 00.00385 mV	<u>00.00049</u>	- 00.00385 mV	<u>✓</u>	_____
GAIN TEST							
6	30 mV	30 mV Range	+ 30.00505 mV	<u>30.0024</u>	+ 29.99495 mV	<u>✓</u>	_____
7	300 mV	300 mV Range	+ 300.0115 mV	<u>299.9992</u>	+ 299.9885 mV	<u>✓</u>	_____
8	3 V	3 V Range	+ 3.000058 V	<u>3.000020</u>	+ 2.999942 V	<u>✓</u>	_____
9	30 V	30 V Range	+ 30.00125 V	<u>30.0009</u>	+ 29.99875 V	<u>✓</u>	_____
10	300 V	300 V Range	+ 300.0157 V	<u>300.0020</u>	+ 299.9843 V	<u>✓</u>	_____
LINEARITY TEST							
11	3 V	3 V Range	+ 3.000058 V	<u>2.999972</u>	+ 2.999942 V	<u>✓</u>	_____
12	2 V	3 V Range	+ 2.000041 V	<u>1.999992</u>	+ 1.999959 V	<u>✓</u>	_____
13	1 V	3 V Range	+ 1.000024 V	<u>1.000002</u>	+ 0.999976 V	<u>✓</u>	_____
14	- 1 V	3 V Range	- 0.999976 V	<u>-1.000000</u>	- 1.000024 V	<u>✓</u>	_____
15	- 2 V	3 V Range	- 1.999959 V	<u>-1.999978</u>	- 2.000041 V	<u>✓</u>	_____
16	- 3 V	3 V Range	- 2.999942 V	<u>-2.999973</u>	- 3.000058 V	<u>✓</u>	_____

PERFORMANCE TEST CARD
90 DAY LIMITS

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A(470)

Test Performed by GPS
Date 7-27-89
Reference Temperature 69

AC VOLTAGE TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
-------	----------------	--------------------------	------------	---------	-----------	-----------	-----------

1 Set the 3457A to the AC Voltage function and run the AUTO-CAL 2 routine.

GAIN TEST

2	30mV, 1KHz	30 mVAC Range	30.05020 mV	<u>30.00047</u>	29.94980 mV	<u>✓</u>	
3	300mV, 1KHz	300 mVAC Range	300.5020 mV	<u>299.9950</u>	299.4980 mV	<u>✓</u>	
4	1V, 1KHz	3 VAC Range	1.002420 V	<u>1.00033</u>	0.997580 V	<u>✓</u>	
5	2V, 1KHz	3 VAC Range	2.003720 V	<u>2.000666</u>	1.996280 V	<u>✓</u>	
6	3V, 1KHz	3 VAC Range	3.005100 V	<u>3.000583</u>	2.994900 V	<u>✓</u>	
7	30V, 1KHz	30 VAC Range	30.05020 V	<u>30.00155</u>	29.94980 V	<u>✓</u>	
8	300V, 1KHz	300 VAC Range	300.6820 V	<u>299.9850</u>	299.3180 V	<u>✓</u>	
9	30V, 1KHz	300 VAC Range	030.1690 V	<u>030.0011</u>	029.8310 V	<u>✓</u>	
10	3V, 1KHz	30 VAC Range	03.01510 V	<u>03.00008</u>	02.98490 V	<u>✓</u>	
11	300mV, 1KHz	3 VAC Range	0.301510 V	<u>0.300159</u>	0.298490 V	<u>✓</u>	
12	30mV, 1KHz	300 mVAC Range	030.1510 mV	<u>030.0237</u>	029.8490 mV	<u>✓</u>	

13 Set the 3457A to AC Fast Response (ACBAND > 400)

FREQUENCY RESPONSE TEST

14	30mV, 1MHz	300 mVAC Range	039.6880 mV	<u>*029.9272</u>	020.3120 mV	<u>✓</u>	
15	30mV, 300KHz	300 mVAC Range	031.9180 mV	<u>029.5891</u>	028.0820 mV	<u>✓</u>	
16	30mV, 100KHz	300 mVAC Range	030.4080 mV	<u>*029.9054</u>	029.5920 mV	<u>✓</u>	
17	30mV, 20KHz	300 mVAC Range	030.1510 mV	<u>029.9898</u>	029.8490 mV	<u>✓</u>	
18	30mV, 6.5KHz	300 mVAC Range	030.1510 mV	<u>029.9816</u>	029.8490 mV	<u>✓</u>	
19	30mV, 400Hz	300 mVAC Range	030.1510 mV	<u>029.9822</u>	029.8490 mV	<u>✓</u>	

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14701

Test Performed by GPS
Date 7-27-99
Reference Temperature 69

AC VOLTAGE TEST (Cont'd)

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
FREQUENCY RESPONSE TEST (Cont'd)							
20	300mV, 1MHz	300 mVAC Range	337.1200 mV	<u>306.3303</u>	262.8800 mV	<input checked="" type="checkbox"/>	
21	300mV, 300KHz	300 mVAC Range	310.4500 mV	<u>297.9299</u>	289.5500 mV	<input checked="" type="checkbox"/>	
22	300mV, 100KHz	300 mVAC Range	302.1900 mV	<u>299.4786</u>	297.8100 mV	<input checked="" type="checkbox"/>	
23	300mV, 20KHz	300 mVAC Range	300.5320 mV	<u>299.9363</u>	299.4680 mV	<input checked="" type="checkbox"/>	
24	300mV, 6.5KHz	300 mVAC Range	300.5320 mV	<u>299.7964</u>	299.4680 mV	<input checked="" type="checkbox"/>	
25	300mV, 400Hz	300 mVAC Range	300.5320 mV	<u>299.8031</u>	299.4680 mV	<input checked="" type="checkbox"/>	
26	300mV, 1MHz	3 VAC Range	0.396880 V	<u>0.278654</u>	0.203120 V	<input checked="" type="checkbox"/>	
27	300mV, 300KHz	3 VAC Range	0.319180 V	<u>0.294486</u>	0.280820 V	<input checked="" type="checkbox"/>	
28	300mV, 100KHz	3 VAC Range	0.304080 V	<u>0.298728</u>	0.295920 V	<input checked="" type="checkbox"/>	
29	300mV, 20KHz	3 VAC Range	0.301510 V	<u>0.299894</u>	0.298490 V	<input checked="" type="checkbox"/>	
30	300mV, 6.5KHz	3 VAC Range	0.301510 V	<u>0.299956</u>	0.298490 V	<input checked="" type="checkbox"/>	
31	300mV, 400Hz	3 VAC Range	0.301510 V	<u>0.299943</u>	0.298490 V	<input checked="" type="checkbox"/>	
32	3V, 1MHz	3 VAC Range	3.371200 V	<u>2.977694</u>	2.628800 V	<input checked="" type="checkbox"/>	
33	3V, 300KHz	3 VAC Range	3.104500 V	<u>2.986486</u>	2.895500 V	<input checked="" type="checkbox"/>	
34	3V, 100KHz	3 VAC Range	3.021900 V	<u>3.002223</u>	2.978100 V	<input checked="" type="checkbox"/>	
35	3V, 20KHz	3 VAC Range	3.005320 V	<u>3.003210</u>	2.994680 V	<input checked="" type="checkbox"/>	
36	3V, 6.5KHz	3 VAC Range	3.005320 V	<u>3.001577</u>	2.994680 V	<input checked="" type="checkbox"/>	
37	3V, 400Hz	3 VAC Range	3.005320 V	<u>3.000979</u>	2.994680 V	<input checked="" type="checkbox"/>	

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A

Digital Multimeter

Serial Number 3114A14701Test Performed by BPSDate 2-27-89Reference Temperature 69

2-WIRE OHMS TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
OFFSET TEST							
1	Short	30 Ohm Range	+ 00.20335 ohm	<u>00.01407</u>	00.20335 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2	Short	300 Ohm Range	+ 000.2035 ohm	<u>000.0137</u>	000.2035 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3	Short	3 KOhm Range	+ 0.000207 Kohm	<u>0.00001</u>	0.000207 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4	Short	30 KOhm Range	+ 00.00027 Kohm	<u>00.00003</u>	00.00027 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5	Short	300 KOhm Range	+ 000.0010 Kohm	<u>00.00001</u> <u>0.000001</u>	000.0010 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6	Short	3 MOhm Range	+ 0.000014 Mohm	<u>000.0001</u>	0.000014 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7	Short	30 MOhm Range	+ 00.00083 Mohm	<u>00.00001</u>	00.00083 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
GAIN TEST							
8	30 Ohm	30 Ohm Range	30.20530 ohm	<u>30.00174</u>	29.79470 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9	300 Ohm	300 Ohm Range	300.2170 ohm	<u>300.0125</u>	299.7830 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
10	3 KOhm	3 KOhm Range	3.000312 Kohm	<u>29.999982</u>	2.999688 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
11	30 KOhm	30 KOhm Range	30.00132 Kohm	<u>29.99998</u>	29.99868 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
12	300 KOhm	300 KOhm Range	300.0130 Kohm	<u>300.0080</u>	299.9870 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
13	3 MOhm	3 MOhm Range	3.000179 Mohm	<u>2.00085</u>	2.999821 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
14	30 MOhm	30 MOhm Range	30.00833 Mohm	<u>30.00028</u>	29.99167 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>

PERFORMANCE TEST CARD 90 DAY LIMITS

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14701

Test Performed by BRB
Date 7-27-94
Reference Temperature 29

4-WIRE OHMS TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
-------	-------------------	-----------------------------	---------------	---------	--------------	--------------	--------------

OFFSET TEST

1	Short	30 Ohm Range	+ 00.00335 ohm	<u>00.00022</u>	00.00335 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2	Short	300 Ohm Range	+ 000.0035 ohm	<u>000.0003</u>	000.0035 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3	Short	3 KOhm Range	+ 0.000007 Kohm	<u>0.000001</u>	0.000007 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4	Short	30 KOhm Range	+ 00.00007 Kohm	<u>00.00001</u>	00.00007 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5	Short	300 KOhm Range	+ 000.0008 Kohm	<u>000.0001</u>	000.0008 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6	Short	3 MOhm Range	+ 0.000014 Mohm	<u>0.000001</u>	0.000014 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7	Short	30 MOhm Range	+ 00.00083 Mohm	<u>00.00001</u>	00.00083 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>

GAIN TEST

8	30 Ohm	30 Ohm Range	30.00530 ohm	<u>29.99967</u>	29.99470 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9	300 ohm	300 Ohm Range	300.0170 ohm	<u>299.9999</u>	299.9830 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
10	3 KOhm	3 KOhm Range	3.000112 Kohm	<u>3.000081</u>	2.999888 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
11	30 KOhm	30 KOhm Range	30.00112 Kohm	<u>30.00091</u>	29.99888 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
12	300 KOhm	300 KOhm Range	300.0128 Kohm	<u>300.0067</u>	299.9872 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
13	3 MOhm	3 MOhm Range	3.000179 Mohm	<u>3.000136</u>	2.999821 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
14	30 MOhm	30 MOhm Range	30.00833 Mohm	<u>30.00409</u>	29.99167 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>

PERFORMANCE TEST CARD 90 DAY LIMITS

Hewlett-Packard Model 3457A

Digital Multimeter

Serial Number 3114A14701Test Performed by LRSDate 7-27-81Reference Temperature 64

REAR INPUT TESTS (STANDARD INSTRUMENT)

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
DC VOLTAGE OFFSET TEST (Rear Terminals)							
1	Short	300 V Range	+ 000.0007 V	<u>000.0001</u>	000.0007 V	<u>✓</u>	_____
2	Short	30 V Range	+ 00.00020 V	<u>00.00007</u>	00.00020 V	<u>✓</u>	_____
3	Short	3 V Range	+ 0.000007 V	<u>0.000001</u>	0.000007 V	<u>✓</u>	_____
4	Short	300 mV Range	+ 000.0040 mV	<u>000.0006</u>	000.0040 mV	<u>✓</u>	_____
5	Short	30 mV Range	+ 00.00385 mV	<u>00.00110</u>	00.00385 mV	<u>✓</u>	_____
DC CURRENT OFFSET TEST (Rear Terminals)							
6	Open	300 uADCI Range	+ 000.0104 uA	<u>000.0003</u>	000.0104 uA	<u>✓</u>	_____
7	Open	3 mADCI Range	+ 0.000104 mA	<u>0.000005</u>	0.000104 mA	<u>✓</u>	_____
8	Open	30 mADCI Range	+ 00.00104 mA	<u>00.00003</u>	00.00104 mA	<u>✓</u>	_____
9	Open	300 mADCI Range	+ 000.0204 mA	<u>000.0007</u>	000.0204 mA	<u>✓</u>	_____
10	Open	3 ADCI Range	+ 0.000604 A	<u>0.000006</u>	0.000604 A	<u>✓</u>	_____
2-WIRE OHMS OFFSET TEST (Rear Terminals)							
11	Short	30 Ohm Range	+ 00.20335 ohm	<u>00.02341</u>	00.20335 ohm	<u>✓</u>	_____
12	Short	300 Ohm Range	+ 000.2035 ohm	<u>000.0227</u>	000.2035 ohm	<u>✓</u>	_____
13	Short	3 KOhm Range	+ 0.000207 Kohm	<u>0.000027</u>	0.000207 Kohm	<u>✓</u>	_____
14	Short	30 KOhm Range	+ 00.00027 Kohm	<u>00.00003</u>	00.00027 Kohm	<u>✓</u>	_____
15	Short	300 KOhm Range	+ 000.0010 Kohm	<u>000.0001</u>	000.0010 Kohm	<u>✓</u>	_____
16	Short	3 MOhm Range	+ 0.000014 Mohm	<u>0.000001</u>	0.000014 Mohm	<u>✓</u>	_____
17	Short	30 MOhm Range	+ 00.00083 Mohm	<u>00.00002</u>	00.00083 Mohm	<u>✓</u>	_____

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14701

Test Performed by GPS
Date 7-27-88
Reference Temperature 69

REAR INPUT TESTS (STANDARD INSTRUMENT)

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
4-WIRE OHMS OFFSET TEST (Rear Terminals)							
18	Short	30 Ohm Range	+ 00.00335 ohm	<u>00.00029</u>	00.00335 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
19	Short	300 Ohm Range	+ 000.0035 ohm	<u>000.0004</u>	000.0035 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
20	Short	3 KOhm Range	+ 0.000007 Kohm	<u>0.000001</u>	0.000007 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
21	Short	30 KOhm Range	+ 00.00007 Kohm	<u>00.00001</u>	00.00007 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
22	Short	300 KOhm Range	+ 000.0008 Kohm	<u>000.0001</u>	000.0008 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
23	Short	3 MOhm Range	+ 0.000014 Mohm	<u>0.000001</u>	0.000014 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
24	Short	30 MOhm Range	+ 00.00083 Mohm	<u>00.00001</u>	00.00083 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Belhaven

Applied Technologies

Customer Belhaven Applied Tech

Certificate of Calibration

Tag BAT-123 Model 3457A Manufacturer Hewlett Packard

Instrument Voltmeter Serial No 3114A14460

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 69F
Accuracy of Instrument See Data Sheet
Calibrated Range: Full

Calibration Report No. BEL99-646

Date Due: 7/29/2000

Test Equipment

Prema Multi-Function Meter S/N10012

Calibrated by:



Certified by:



Quality Assurance Manager

ORIGINAL**COPY**

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14466

Test Performed by GPS
Date 7-27-89
Reference Temperature 69

DC VOLTAGE TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
OFFSET TEST							
1	Short	300 V Range	• 000.0007 V	<u>000.0000</u>	- 000.0007 V	<u>✓</u>	_____
2	Short	30 V Range	+ 00.00020 V	<u>000.00002</u>	00.00020 V	<u>✓</u>	_____
3	Short	3 V Range	+ 0.000007 V	<u>0.000001</u>	- 0.000007 V	<u>✓</u>	_____
4	Short	300 mV Range	+ 000.0040 mV	<u>000.0004</u>	- 000.0040 mV	<u>✓</u>	_____
5	Short	30 mV Range	+ 00.00385 mV	<u>00.00055</u>	- 00.00385 mV	<u>✓</u>	_____
GAIN TEST							
6	30 mV	30 mV Range	+ 30.00505 mV	<u>29.99547</u>	+ 29.99495 mV	<u>✓</u>	_____
7	300 mV	300 mV Range	+ 300.0115 mV	<u>299.9886</u>	+ 299.9885 mV	<u>✓</u>	_____
8	3 V	3 V Range	+ 3.000058 V	<u>3.000004</u>	+ 2.999942 V	<u>✓</u>	_____
9	30 V	30 V Range	+ 30.00125 V	<u>29.99925</u>	+ 29.99875 V	<u>✓</u>	_____
10	300 V	300 V Range	+ 300.0157 V	<u>299.9987</u>	+ 299.9843 V	<u>✓</u>	_____
LINEARITY TEST							
11	3 V	3 V Range	+ 3.000058 V	<u>2.999999</u>	+ 2.999942 V	<u>✓</u>	_____
12	2 V	3 V Range	+ 2.000041 V	<u>1.999994</u>	+ 1.999959 V	<u>✓</u>	_____
13	1 V	3 V Range	+ 1.000024 V	<u>1.000000</u>	+ 0.999976 V	<u>✓</u>	_____
14	• 1 V	3 V Range	- 0.999976 V	<u>-.999997</u>	- 1.000024 V	<u>✓</u>	_____
15	• 2 V	3 V Range	- 1.999959 V	<u>-1.999998</u>	- 2.000041 V	<u>✓</u>	_____
16	• 3 V	3 V Range	- 2.999942 V	<u>-2.999992</u>	- 3.000058 V	<u>✓</u>	_____

PERFORMANCE TEST CARD
90 DAY LIMITS

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number: 3114A14460

Test Performed by BPS
Date 7-27-89
Reference Temperature 69

AC VOLTAGE TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
-------	----------------	--------------------------	------------	---------	-----------	-----------	-----------

1 Set the 3457A to the AC Voltage Function and run the AUTO-CAL 2 routine.

GAIN TEST

2	30mV, 1KHz	30 mVAC Range	30.05020 mV	<u>29.9846</u>	29.94980 mV	<u>✓</u>	
3	300mV, 1KHz	300 mVAC Range	300.5020 mV	<u>300.0657</u>	299.4980 mV	<u>✓</u>	
4	1V, 1KHz	3 VAC Range	1.002420 V	<u>.999035</u>	0.997580 V	<u>✓</u>	
5	2V, 1KHz	3 VAC Range	2.003720 V	<u>1.999245</u>	1.996280 V	<u>✓</u>	
6	3V, 1KHz	3 VAC Range	3.005100 V	<u>2.999816</u>	2.994900 V	<u>✓</u>	
7	30V, 1KHz	30 VAC Range	30.05020 V	<u>30.00954</u>	29.94980 V	<u>✓</u>	
8	300V, 1KHz	300 VAC Range	300.6820 V	<u>300.1317</u>	299.3180 V	<u>✓</u>	
9	30V, 1KHz	300 VAC Range	030.1690 V	<u>30.0054</u> <u>30.00903</u> BPS	029.8310 V	<u>✓</u>	
10	3V, 1KHz	30 VAC Range	03.01510 V	<u>2.99983</u> <u>32.99857</u> BPS	02.98490 V	<u>✓</u>	
11	300mV, 1KHz	3 VAC Range	0.301510 V	<u>.299876</u> <u>300.0517</u> BPS	0.298490 V	<u>✓</u>	
12	30mV, 1KHz	300 mVAC Range	030.1510 mV	<u>.029876</u> <u>030.002</u> BPS	029.8490 mV	<u>✓</u>	

13 Set the 3457A to AC Fast Response (ACBAND > 400)

FREQUENCY RESPONSE TEST

14	30mV, 1MHz	300 mVAC Range	039.6880 mV	<u>028.9365</u> <u>30.05517</u>	020.3120 mV	<u>✓</u>	
15	30mV, 300KHz	300 mVAC Range	031.9180 mV	<u>029.5448</u> <u>29.6057</u>	028.0820 mV	<u>✓</u>	
16	30mV, 100KHz	300 mVAC Range	030.4080 mV	<u>029.8923</u> <u>29.8146</u>	029.5920 mV	<u>✓</u>	
17	30mV, 20KHz	300 mVAC Range	030.1510 mV	<u>029.9905</u> <u>29.9920</u>	029.8490 mV	<u>✓</u>	
18	30mV, 6.5KHz	300 mVAC Range	030.1510 mV	<u>029.9857</u> <u>29.9867</u>	029.8490 mV	<u>✓</u>	
19	30mV, 400Hz	300 mVAC Range	030.1510 mV	<u>029.9844</u> <u>29.9843</u>	029.8490 mV	<u>✓</u>	

maintain higher next range BPS

BPS

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14460

Test Performed by GPS
Date 2-27-99
Reference Temperature 69

AC VOLTAGE TEST (Cont'd)

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
-------	-------------------	-----------------------------	---------------	---------	--------------	--------------	--------------

FREQUENCY RESPONSE TEST (Cont'd)

20	300mV, 1MHz	300 mVAC Range	337.1200 mV	<u>305.6887</u>	262.8800 mV	✓	
21	300mV, 300KHz	300 mVAC Range	310.4500 mV	<u>297.7653</u>	289.5500 mV	✓	
22	300mV, 100KHz	300 mVAC Range	302.1900 mV	<u>299.4375</u>	297.8100 mV	✓	
23	300mV, 20KHz	300 mVAC Range	300.5320 mV	<u>299.9620</u>	299.4680 mV	✓	
24	300mV, 6.5KHz	300 mVAC Range	300.5320 mV	<u>299.8723</u>	299.4680 mV	✓	
25	300mV, 400Hz	300 mVAC Range	300.5320 mV	<u>300.0926</u>	299.4680 mV	✓	
26	300mV, 1MHz	3 VAC Range	0.396880 V	<u>.780261</u>	0.203120 V	✓	
27	300mV, 300KHz	3 VAC Range	0.319180 V	<u>.294341</u>	0.280820 V	✓	
28	300mV, 100KHz	3 VAC Range	0.304080 V	<u>.298527</u>	0.295920 V	✓	
29	300mV, 20KHz	3 VAC Range	0.301510 V	<u>.299921</u>	0.298490 V	✓	
30	300mV, 6.5KHz	3 VAC Range	0.301510 V	<u>.299991</u>	0.298490 V	✓	
31	300mV, 400Hz	3 VAC Range	0.301510 V	<u>.299991</u>	0.298490 V	✓	
32	3V, 1MHz	3 VAC Range	3.371200 V	<u>2.984521</u>	2.628800 V	✓	
33	3V, 300KHz	3 VAC Range	3.104500 V	<u>2.987990</u>	2.895500 V	✓	
34	3V, 100KHz	3 VAC Range	3.021900 V	<u>GPS 3.011627</u> <u>2.9</u>	2.978100 V	✓	
35	3V, 20KHz	3 VAC Range	3.005320 V	<u>3.001220</u>	2.994680 V	✓	
36	3V, 6.5KHz	3 VAC Range	3.005320 V	<u>3.000207</u>	2.994680 V	✓	
37	3V, 400Hz	3 VAC Range	3.005320 V	<u>3.000093</u>	2.994680 V	✓	

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14460

Test Performed by CS
Date 7-27-89
Reference Temperature 69

AC VOLTAGE TEST (Cont'd)

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
FREQUENCY RESPONSE TEST (Cont'd)							
37	Set the 3457A to AC Slow Response (ACBAND < 400)						
38	3V, 100Hz	3 VAC Range	3.008800 V	<u>2.989524</u>	2.991200 V	<u>✓</u>	_____
39	3V, 45Hz	3 VAC Range	3.026800 V	<u>2.989664</u>	2.973200 V	<u>✓</u>	_____
40	3V, 20Hz	3 VAC Range	3.026800 V	<u>2.998490</u>	2.973200 V	<u>✓</u>	_____
41	300mV, 100Hz	300 mVAC Range	300.8800 mV	<u>300.0774</u>	299.1200 mV	<u>✓</u>	_____
42	300mV, 45Hz	300 mVAC Range	302.6800 mV	<u>300.0869</u>	297.3200 mV	<u>✓</u>	_____
43	300mV, 20Hz	300 mVAC Range	302.6800 mV	<u>299.9959</u>	297.3200 mV	<u>✓</u>	_____

FREQUENCY TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
1	1V, 20Hz	3 VAC Range	20.01000 Hz	<u>20.0082</u>	19.99000 Hz	<u>✓</u>	_____
2	1V, 1MHz	3 VAC Range	1.000100 MHz	<u>0.999985</u>	0.999900 MHz	<u>✓</u>	_____

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14460

Test Performed by BP
Date 7-27-89
Reference Temperature 69

DC CURRENT TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
OFFSET TEST							
1	Open	300 uADCI Range	+ 000.0104 uA	<u>000.0007</u>	- 000.0104 uA	<u>V</u>	_____
2	Open	3 mADCI Range	+ 0.000104 mA	<u>0.00012</u>	- 0.000104 mA	<u>V</u>	_____
3	Open	30 mADCI Range	+ 00.00104 mA	<u>00.00012</u>	- 00.00104 mA	<u>V</u>	_____
4	Open	300 mADCI Range	+ 000.0204 mA	<u>000.0012</u>	- 000.0204 mA	<u>V</u>	_____
5	Open	1 ADCI Range	+ 0.000604 A	<u>0.00014</u>	- 0.000604 A	<u>V</u>	_____
GAIN TEST							
6	300 uA	300 uADCI Range	300.0704 uA	<u>300.0226</u>	299.9296 uA	<u>V</u>	_____
7	3 mA	3 mADCI Range	3.000704 mA	<u>3.000131</u>	2.999296 mA	<u>V</u>	_____
8	30 mA	30 mADCI Range	30.00704 mA	<u>30.00245</u>	29.99296 mA	<u>V</u>	_____
9	300 mA	300 mADCI Range	300.2304 mA	<u>299.8364</u>	299.7696 mA	<u>V</u>	_____
10	1 A	1 ADCI Range	1.001304 A	<u>.999472</u>	0.998696 A	<u>F</u>	_____

AC CURRENT TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
<u>1 kHz</u>							
GAIN TEST							
1	30 mA	30 mAACI Range	30.10300 mA	<u>30.00959</u>	29.89700 mA	<u>V</u>	_____
2	300 mA	300 mAACI Range	301.0300 mA	<u>299.9429</u>	298.9700 mA	<u>V</u>	_____
3	1 A	1 AACI Range	1.005300 A	<u>.999239</u>	0.994700 A	<u>V</u>	_____

PERFORMANCE TEST CARD
90 DAY LIMITS

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14460

Test Performed by GD
Date 7-27-88
Reference Temperature 69

2-WIRE OHMS TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
OFFSET TEST							
1	Short	30 Ohm Range	+ 00.20335 ohm	<u>00.00214</u>	00.20335 ohm	<u>V</u>	_____
2	Short	300 Ohm Range	+ 000.2035 ohm	<u>000.0029</u>	000.2035 ohm	<u>V</u>	_____
3	Short	3 KOhm Range	+ 0.000207 Kohm	<u>0.000009</u>	0.000207 Kohm	<u>V</u>	_____
4	Short	30 KOhm Range	+ 00.00027 Kohm	<u>00.00001</u>	00.00027 Kohm	<u>V</u>	_____
5	Short	300 KOhm Range	+ 000.0010 Kohm	<u>000.0000</u>	000.0010 Kohm	<u>V</u>	_____
6	Short	3 MOhm Range	+ 0.000014 Mohm	<u>0.000000</u>	0.000014 Mohm	<u>V</u>	_____
7	Short	30 MOhm Range	+ 00.00083 Mohm	<u>00.00000</u>	00.00083 Mohm	<u>V</u>	_____
GAIN TEST							
8	30 Ohm	30 Ohm Range	30.20530 ohm	<u>30.04960</u>	29.79470 ohm	<u>V</u>	_____
9	300 Ohm	300 Ohm Range	300.2170 ohm	<u>300.0456</u>	299.7830 ohm	<u>V</u>	_____
10	3 KOhm	3 KOhm Range	3.000312 Kohm	<u>3000.007</u> <u>300.0134</u> <u>29.99978</u>	2.999688 Kohm	<u>V</u>	_____
11	30 KOhm	30 KOhm Range	30.00132 Kohm	<u>30.607</u>	29.99868 Kohm	<u>V</u>	_____
12	300 KOhm	300 KOhm Range	300.0130 Kohm	<u>299.9876</u>	299.9870 Kohm	<u>V</u>	_____
13	3 MOhm	3 MOhm Range	3.000179 Mohm	<u>2.999921</u>	2.999821 Mohm	<u>V</u>	_____
14	30 MOhm	30 MOhm Range	30.00833 Mohm	<u>2999862</u>	29.99167 Mohm	<u>V</u>	_____

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14460

Test Performed by EOS
Date 7-27-99
Reference Temperature 69

4-WIRE OHMS TEST

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
OFFSET TEST							
1	Short	30 Ohm Range	+ 00.00335 ohm	<u>00.00035</u>	00.00335 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2	Short	300 Ohm Range	+ 000.0035 ohm	<u>000.0006</u>	000.0035 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3	Short	3 KOhm Range	+ 0.000007 Kohm	<u>0.000003</u>	0.000007 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4	Short	30 KOhm Range	+ 00.00007 Kohm	<u>00.00001</u>	00.00007 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5	Short	300 KOhm Range	+ 000.0008 Kohm	<u>000.0000</u>	000.0008 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6	Short	3 MOhm Range	+ 0.000014 Mohm	<u>0.000001</u>	0.000014 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7	Short	30 MOhm Range	+ 00.00083 Mohm	<u>00.00001</u>	00.00083 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
GAIN TEST							
8	30 Ohm	30 Ohm Range	30.00530 ohm	<u>29.99903</u>	29.99470 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9	300 Ohm	300 Ohm Range	300.0170 ohm	<u>300.0081</u>	299.9830 ohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
10	3 KOhm	3 KOhm Range	3.000112 Kohm	<u>2.999949</u>	2.999888 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
11	30 KOhm	30 KOhm Range	30.00112 Kohm	<u>29.99923</u>	29.99888 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
12	300 KOhm	300 KOhm Range	300.0128 Kohm	<u>299.9999</u> 300.009	299.9872 Kohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
13	3 MOhm	3 MOhm Range	3.000179 Mohm	<u>2.999967</u>	2.999821 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>
14	30 MOhm	30 MOhm Range	30.00833 Mohm	<u>29.99839</u>	29.99167 Mohm	<input checked="" type="checkbox"/>	<input type="checkbox"/>

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114A14460

Test Performed by GS
Date 7-27-99
Reference Temperature 69

REAR INPUT TESTS (STANDARD INSTRUMENT)

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
DC VOLTAGE OFFSET TEST (Rear Terminals)							
1	Short	300 V Range	+ 000.0007 V	<u>000.0001</u>	- 000.0007 V	<u>✓</u>	_____
2	Short	30 V Range	+ 00.00020 V	<u>00.00002</u>	00.00020 V	<u>✓</u>	_____
3	Short	3 V Range	+ 0.000007 V	<u>0.000000</u>	0.000007 V	<u>✓</u>	_____
4	Short	300 mV Range	+ 000.0040 mV	<u>000.0002</u>	- 000.0040 mV	<u>✓</u>	_____
5	Short	30 mV Range	+ 00.00385 mV	<u>00.00017</u>	- 00.00385 mV	<u>✓</u>	_____
DC CURRENT OFFSET TEST (Rear Terminals)							
6	Open	300 uADCI Range	+ 000.0104 uA	<u>-000.0022</u>	- 000.0104 uA	<u>✓</u>	_____
7	Open	3 mADCI Range	+ 0.000104 mA	<u>-0.000023</u>	0.000104 mA	<u>✓</u>	_____
8	Open	30 mADCI Range	+ 00.00104 mA	<u>-00.00023</u>	00.00104 mA	<u>✓</u>	_____
9	Open	300 mADCI Range	+ 000.0204 mA	<u>-000.0024</u>	- 000.0204 mA	<u>✓</u>	_____
10	Open	3 ADCI Range	+ 0.000604 A	<u>-0.000022</u>	0.000604 A	<u>✓</u>	_____
2-WIRE OHMS OFFSET TEST (Rear Terminals)							
11	Short	30 Ohm Range	+ 00.20335 ohm	<u>-00.00054</u>	00.20335 ohm	<u>✓</u>	_____
12	Short	300 Ohm Range	+ 000.2035 ohm	<u>-000.0005</u>	000.2035 ohm	<u>✓</u>	_____
13	Short	3 KOhm Range	+ 0.000207 Kohm	<u>-0.000001</u>	0.000207 Kohm	<u>✓</u>	_____
14	Short	30 KOhm Range	+ 00.00027 Kohm	<u>-00.00001</u>	00.00027 Kohm	<u>✓</u>	_____
15	Short	300 KOhm Range	+ 000.0010 Kohm	<u>000.0001</u>	- 000.0010 Kohm	<u>✓</u>	_____
16	Short	3 MOhm Range	+ 0.000014 Mohm	<u>0.000004</u>	- 0.000014 Mohm	<u>✓</u>	_____
17	Short	30 MOhm Range	+ 00.00083 Mohm	<u>00.00000</u>	- 00.00083 Mohm	<u>✓</u>	_____

**PERFORMANCE TEST CARD
90 DAY LIMITS**

Hewlett-Packard Model 3457A
Digital Multimeter
Serial Number 3114914460

Test Performed by POD
Date 7-22-89
Reference Temperature 69

REAR INPUT TESTS (STANDARD INSTRUMENT)

Step#	Input to 3457A	Set-Up and Configuration	High Limit	Reading	Low Limit	Test Pass	Test Fail
4-WIRE OHMS OFFSET TEST (Rear Terminals)							
18	Short	30 Ohm Range	+ 00.00335 ohm	<u>00.00015</u>	00.00335 ohm	<u>✓</u>	_____
19	Short	300 Ohm Range	+ 000.0035 ohm	<u>000.0002</u>	000.0035 ohm	<u>✓</u>	_____
20	Short	3 KOhm Range	+ 0.000007 Kohm	<u>0.000001</u>	0.000007 Kohm	<u>✓</u>	_____
21	Short	30 KOhm Range	+ 00.00007 Kohm	<u>00.00000</u>	00.00007 Kohm	<u>✓</u>	_____
22	Short	300 KOhm Range	+ 000.0008 Kohm	<u>000.0001</u>	000.0008 Kohm	<u>✓</u>	_____
23	Short	3 MOhm Range	+ 0.000014 Mohm	<u>0.000001</u>	0.000014 Mohm	<u>✓</u>	_____
24	Short	30 MOhm Range	+ 00.00083 Mohm	<u>00.00002</u>	00.00083 Mohm	<u>✓</u>	_____

Belhaven

Applied Technologies

Customer Belhaven

Certificate of Calibration

Tag BAT-107 Model 787 Manufacturer Fluke

Instrument Process Meter Serial No 6910042

Calibration traceable to the National Institute of Standards and Technology in accordance with ANSI- Z540.1 has been accomplished on the above-named instrument by comparison with standards maintained by Belhaven. The accuracy and stability of all standards maintained by Belhaven are traceable to national standards maintained by the National Institute of Standards and Technology in Washington, D.C. and Boulder, Colorado.

Temperature at Calibration: 68 F

Accuracy of Instrument See report

Calibrated Range: See report

Calibration Report No. **BEL99-420**

Date Due: 5/28/2000

Test Equipment

Prema Multi-Function Meter S/N10012

Calibrated by: Sean S. for GPS May 28, 1999

Certified by: J. L. [Signature] 6-1-99
Quality Assurance Manager

ORIGINAL**COPY**

Belhaven**Calibration Data Sheet**Report Number
BEL99-420

Tag No BAT-107

Instrument Type Process Meter

Manufacturer Fluke

Serial No 6910042

Model 787

Cal Due Date 5/28/2000

System

Special Instructions DC VOLTAGE

		Cal Point	As Found	As Left	% Full Scale Accuracy
Units:	V	999.247	999	999	-0.0247
F.S. Accuracy	0.05%	799.409	799	799	-0.0409
F.S. Accuracy		599.709	600	600	0.0291
Full Scale	1000.0	399.999	400	400	0.0001
Permitted Variation	0.5000 V	200.513	200.5	200.5	-0.0013
Cal Temp	68 F	100.664	100.7	100.7	0.0036
		49.784	49.8	49.8	0.0016
		25.034	25.03	25.03	-0.0004
		3.000068	3.000	3.000	-0.0000
		1.500024	1.500	1.500	-0.0000
		0.750002	0.750	0.750	-0.0000
		0.324984	0.325	0.325	0.0000
		0.1000016	0.100	0.100	-0.0000
		0.0500074	0.0500	0.0500	-0.0000
		0.0250031	0.0250	0.0250	-0.0000

Test Equipment Prema Multi-Function Meter S/N10012

Calibration Performed By

Sean J. GPS

Date

May 28, 1999

ORIGINAL

Belhaven**Calibration Data Sheet**

Report Number

BEL99-420

Tag No BAT-107

Instrument Type Process Meter

Manufacturer Fluke

Serial No 6910042

Model 787

Cal Due Date 5/28/2000

System

Special Instructions Resistance

		Cal Point	As Found	As Left	% Full Scale Accuracy
Units:	ohms	100000.13	100000	100000	-0.0001
F.S. Accuracy	0.003%	50002.41	50000	50000	-0.0024
F.S. Accuracy		25001.30	25000	25000	-0.0013
Full Scale	100000	10000.228	10000	10000	-0.0002
Permitted Variation	3.0000 ohms	5000.193	5000	5000	-0.0002
Cal Temp	68 F	2500.0942	2500	2500	-0.0001
		1000.0520	1000	1000	-0.0001
		500.0470	500	500	-0.0000
		250.02579	250.0	250.0	-0.0000
		100.01811	100.0	100.0	-0.0000
		50.01369	50.0	50.0	-0.0000
		25.01324	25.0	25.0	-0.0000
		10.01381	10.0	10.0	-0.0000
		5.01173	5.0	5.0	-0.0000
		1.01160	1.0	1.0	-0.0000

Test Equipment Prema Multi-Function Meter S/N10012

Calibration Performed By

Sean S. [Signature] for GPS

Date

May 28, 1999**ORIGINAL**

Belhaven**Calibration Data Sheet**

Tag No BAT-107

Instrument Type Process Meter

Manufacturer Fluke

Serial No 6910042

Model 787

Cal Due Date 5/28/2000

System

Special Instructions DC mA Source

		Cal Point	As Found	As Left	% Full Scale Accuracy
Units:	mA	4.000	4.00061	4.00061	0.0025
F.S. Accuracy		8.000	8.00017	8.00017	0.0007
F.S. Accuracy		12.000	11.99988	11.99988	-0.0005
Full Scale	24.00	16.000	15.99963	15.99963	-0.0015
Permitted Variation	0.0000 mA	20.000	19.99983	19.99983	-0.0007
Cal Temp	68 F	24.000	24.0002	24.0002	0.0008

Test Equipment Prema Multi-Function Meter S/N10012

Calibration Performed By

SEAN S. for GPS

Date

May 28, 1999

ORIGINAL

Belhaven**Calibration Data Sheet**Report Number
BEL99-420

Page 88

Tag No BAT-107

Instrument Type Process Meter

Manufacturer Fluke

Serial No 6910042

Model 787

Cal Due Date 5/28/2000


System

Special Instructions DC Current (mA)

		Cal Point	As Found	As Left	% Full Scale Accuracy
Units:	mA	4.000	4.000	4.000	0.0000
F.S. Accuracy		8.000	8.000	8.000	0.0000
F.S. Accuracy		12.000	12.000	12.000	0.0000
Full Scale	400	16.000	16.000	16.000	0.0000
Permitted Variation	0.0000 mA	20.000	20.001	20.001	0.0003
Cal Temp	68 F	50.000	50	50	0.0000
		200.000	200	200	0.0000
		400.00	400	400	0.0000

Test Equipment Prema Multi-Function Meter S/N10012

Calibration Performed By

 for GPS

Date

May 28, 1999

ORIGINAL

Tag No BAT-107
Instrument Type Process Meter
Manufacturer Fluke
Serial No 6910042
Model 787
Cal Due Date 5/28/2000
System
Special Instructions AC Voltage @ 60 Hz

Cal Point	As Found	As Left	% Full Scale Accuracy
0.01000	0.01003	0.01003	0.0000
1.000	1.002	1.002	0.0003
10.000	10.02	10.02	0.0033
599.822	601	601	0.1963

Units: V
F.S. Accuracy 0.20%
F.S. Accuracy
Full Scale 600
Permitted Variation 1.2000 V
Cal Temp 68 F

Test Equipment Prema Multi-Function Meter S/N10012

Calibration Performed By *Sen J for GIS*

Date *May 26, 1999*

ORIGINAL



TRANSCAT

CERTIFICATE OF CALIBRATION

Customer: BELHAVEN
415 N QUAY ST
KENNEWICK, WA 99336

Cert/RA Nbr: 1-OS264-2-1	Date Received: 02/08/00
ID Nbr: NONE	Date Calibrated: 2/9/00
Manufacturer: AVO INTERNATIONAL	Next Calibration: 2/9/01
Description: MEGOHMMETER	Calibration Proc: 33K1-4-2462-1
Model Nbr: BM80/2	Data Sheet Nbr: 24-00684-2
Serial Nbr: 6410-889/000100/5345	Item Received: In Tolerance
PO Nbr: 22844	Item Returned: In Tolerance

Temperature: 70°F

Relative Humidity: 44%

TRANSCAT will maintain and document the traceability of all its standards to the National Institute of Standards and Technology, NIST (formerly NBS), or the National Research Council, NRC, of Canada, or to other recognized national or international standard bodies, or to measurable conditions created in our laboratory, or accepted fundamental and/or natural physical constants, ratio type of calibration, or by comparison to consensus standards. The TRANSCAT calibration system, when applicable, conforms to the requirements of MIL-STD-45662A, ANSINC SL Z540-1-1994, ISO10012-1-1992, and ISO/IEC Guide 25. 10CFR21 and/or IEEE-A98-1985 applies if specified contractually.

Complete records of work performed are maintained by TRANSCAT and are available for inspection. Laboratory assets used in the performance of this calibration are shown below.

The results in this report relate only to the item calibrated or tested.

All calibrations have been performed using the standards having a test accuracy ratio of four or more times greater than the unit calibrated, unless otherwise noted. Uncertainties have been estimated at a 95 percent confidence level (k=2). Limitations on the uses of this instrument are detailed in the manufacturer's operating instructions.


Customer Notes:

Assets	Manufacturer	Model Nbr	Description	Date Cal'd	Date Due	Traceability Numbers
000233	WAVETEK	9100	Calibration System	12/2/99	12/2/00	14-NH928-1-1
2503	BIDDLE INSTRUMENTS	72-6340	Megadek	2/6/99	2/29/00	1-&2503-2-9
2559	GENERAL RESISTANCE	RDS-63A	Decade Box	5/3/99	5/3/00	1-&2559-5-9

COPY

Calibrated at:
10 Vantage Point Dr
Rochester, NY 14624
By Tom Honig

Facility Responsible:
10 Vantage Point Dr
Rochester, NY 14624
716-352-9720

for 
Tom Honig
Lab Manager
Date 2-9-2000

F0013R11 10/22/99

Page 1 of 1



TRANSCAT

SUPPLEMENTAL REPORT FOR CALIBRATION LAB DATA

RA Nbr: 1-OS264-2-1	Mfg: AVO INTERNATIONAL
Description: MEGOHMMETER	Model: BM80/2
Customer: BELHAVEN	Serial: 6410-889/000100/5345
Calibrated: 2/9/00	PO Nbr: 22844
Date due: 2/9/01	ID Nbr: NONE
Service Type: S6	Verification Procedure: 24-00684-2

Input	I/O	Accuracy	Low	High	Limits	As Rec'd	As Shipped
1 KV MOHMS							
Range: 1 KV MOHMS							
1.000	MOHMS	I ±2% of Rdg ±2Dgt	0.98	1.02	MOHMS	0.99	0.99
Range: 1 KV MOHMS							
10.00	MOHMS	I ±2% of Rdg ±2Dgt	9.8	10.2	MOHMS	10.0	10.0
Range: 1 KV MOHMS							
100.0	MOHMS	I ±2% of Rdg ±2Dgt	98.0	102	MOHMS	100	100
1 KV GOHMS							
Range: 1 KV GOHMS							
10	GOHMS	I ±.4% per G±2%±2Dgt	9.2	10.8	GOHMS	9.6	9.6
500V MOHMS							
Range: 500V MOHMS							
1.000	MOHMS	I ±2% of Rdg ±2Dgt	0.98	1.02	MOHMS	0.99	0.99
Range: 500V MOHMS							
10.00	MOHMS	I ±2% of Rdg ±2Dgt	9.80	10.2	MOHMS	10.0	10.0
Range: 500V MOHMS							
100.0	MOHMS	I ±2% of Rdg ±2Dgt	98.0	102	MOHMS	99.0	99.0
500V GOHMS							
Range: 500V GOHMS							
10.00	GOHMS	I ±.4% per G±2%±2Dgt	9.2	10.8	GOHMS	9.4	9.4
250V MOHMS							
Range: 250V MOHMS							
1.000	MOHMS	I ±2% of Rdg ±2Dgt	0.98	1.02	MOHMS	0.99	0.99
Range: 250V MOHMS							
10.00	MOHMS	I ±2% of Rdg ±2Dgt	9.8	10.2	MOHMS	10.0	10.0
Range: 250V MOHMS							
100.0	MOHMS	I ±2% of Rdg ±2Dgt	98.0	102	MOHMS	99.0	99.0
250V GOHMS							
Range: 250V GOHMS							
10.00	GOHMS	I ±.8% per G±2%±2Dgt	7.0	13.0	GOHMS	8.9	8.9
100V MOHMS							
Range: 100V MOHMS							
1.000	MOHMS	I ±2% of Rdg ±2Dgt	0.98	1.02	MOHMS	0.99	0.99



TRANSCAT

SUPPLEMENTAL REPORT FOR CALIBRATION LAB DATA

RA Nbr: 1-OS264-2-1	Mfg: AVO INTERNATIONAL
Description: MEGOHMMETER	Model: BM80/2
Customer: BELHAVEN	Serial: 6410-889/000100/5345
Calibrated: 2/9/00	PO Nbr: 22844
Date due: 2/9/01	ID Nbr: NONE
Service Type: S6	Verification Procedure: 24-00684-2

-----Input-----|---I/O---|-----Accuracy-----|-----Low /High Limits----- As Rec'd As Shipped

Range: 100V MOHMS						
10.00	MOHMS	I ±2% of Rdg ±2Dgt	9.8	10.2	MOHMS	9.9 9.9

Range: 100V MOHMS						
100.0	MOHMS	I ±2% of Rdg ±2Dgt	98.0	102	MOHMS	99 99

100V GOHMS

Range: 100V GOHMS						
10.00	GOHMS	I ±2% per G ±2% ±2Dgt	7.6	12.4	GOHMS	9.0 9.0

50V MOHMS

Range: 50V MOHMS						
1.000	MOHMS	I ±2% of Rdg ±2Dgt	0.98	1.02	MOHMS	0.99 0.99

Range: 50V MOHMS						
10.00	MOHMS	I ±2% of Rdg ±2Dgt	9.8	10.2	MOHMS	9.9 9.9

Range: 50V MOHMS						
100.0	MOHMS	I ±2% of Rdg ±2Dgt	98.0	102	MOHMS	99.0 99.0

50V GOHMS

Range: 50V GOHMS						
10.00	GOHMS	I ±4% per G ±2% ±2	6.0	14.0	GOHMS	9.3 9.3

KOHMS

Range: KOHMS KOHMS						
1.00	KOHMS	I ±3% of Rdg ±2Dgt	0.7	1.3	KOHMS	1.0 1.0

Range: KOHMS KOHMS						
10.00	KOHMS	I ±3% of Rdg ±2Dgt	9.7	10.3	KOHMS	10.1 10.1

Range: KOHMS KOHMS						
100.0	KOHMS	I ±3% of Rdg ±2Dgt	97.0	103	KOHMS	100 100

OHMS

Range: OHMS OHMS						
25.00	OHMS	I ±2% of Rdg ±2Dgt	24.3	25.7	OHMS	25.4 25.4

Range: OHMS OHMS						
50.00	OHMS	I ±2% of Rdg ±2Dgt	47.0	53.0	OHMS	50.4 50.4

Range: OHMS OHMS						
100.0	OHMS	I ±2% of Rdg ±2Dgt	96.0	104	OHMS	99.9 99.9

DC VOLTS

Range: DC VOLTS VOLTS						
25.0	VOLTS	I ±1% of Rdg ±2Dgt	23	27	VOLTS	25 25



**SUPPLEMENTAL REPORT FOR
CALIBRATION LAB DATA**



RA Nbr: 1-OS264-2-1	Mfg: AVO INTERNATIONAL
Description: MEGOHMMETER	Model: BM80/2
Customer: BELHAVEN	Serial: 6410-889/000100/5345
Calibrated: 2/9/00	PO Nbr: 22844
Date due: 2/9/01	ID Nbr: NONE
Service Type: S6	Verification Procedure: 24-00684-2

Input	I/O	Accuracy	Low /High Limits		As Rec'd	As Shipped
Range: DC VOLTS VOLTS						
100.0	VOLTS	I ±1% of Rdg ±2Dgt	97	103	VOLTS 100	100
Range: DC VOLTS VOLTS						
250.0	VOLTS	I ±1% of Rdg ±2Dgt	246	254	VOLTS 249	249
Range: DC VOLTS VOLTS						
500.0	VOLTS	I ±1% of Rdg ±2Dgt	493	507	VOLTS 498	498

ACV@60Hz

Range: ACV@60Hz VOLTS						
25.0	VOLTS	I ±1% of Rdg ±2Dgt	23	27	VOLTS 26	26
Range: ACV@60Hz VOLTS						
100.0	VOLTS	I ±1% of Rdg ±2Dgt	97	103	VOLTS 101	101
Range: ACV@60Hz VOLTS						
250.0	VOLTS	I ±1% of Rdg ±2Dgt	246	254	VOLTS 251	251
Range: ACV@60Hz VOLTS						
500.0	VOLTS	I ±2% of Rdg ±2Dgt	488	512	VOLTS 501	501

ACV@400Hz

Range: ACV@400Hz VOLTS						
100	VOLTS	I ±5% of Rdg ±2Dgt	93	107	VOLTS 97	97
Range: ACV@400Hz VOLTS						
250	VOLTS	I ±5% of Rdg ±2Dgt	235	265	VOLTS 244	244
Range: ACV@400Hz VOLTS						
400	VOLTS	I ±5% of Rdg ±2Dgt	378	422	VOLTS 388	388

Remarks:

Section 5
Safety Equipment and
CGI Dedication Working List

Qty.	Component No.	Description	Safety Class.	Safety Function	Design and Operational Attributes	Reference Drawing(s) (No. Sheet, Rev.)	Manufacturer or Vendor	Model No. or Engineered Equipment	Test Procedure No.	Test Status	Part No.	CGI	Interlock	Notes
	15	LFPGX	SS	Tube Plug Grapple Jaws Fully Closed Limit Switch (X)	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17 Rev L	Honeywell	SL1-H	ITP007G	4/10 SS Qual	N/A	CGI-SNF-D-MHM-7	P62	
	15	LFPGY	SS	Tube Plug Grapple Jaws Fully Closed Limit Switch (Y)	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17 Rev L	Honeywell	SL1-H	ITP007H	4/10 SS Qual	N/A	CGI-SNF-D-MHM-7	P62	
	15	LFPGLX	SS	Plug Hoist Grapple Jaws Locked (X)	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17A Rev H	Honeywell	SL1-H	ITP007	4/10 SS Qual	N/A	CGI-SNF-D-MHM-7	P62	
	15	LFPGLY	SS	Plug Hoist Grapple Jaws Locked (Y)	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17A Rev H	Honeywell	SL1-H	ITP007	4/10 SS Qual	N/A	CGI-SNF-D-MHM-7	P62	
	15	BF	SS	Bridge Travel Interlocks Satisfied Relay	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 24 Rev J	Idec	RH4B-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MHM-20A	P62, 03, 05, 08, 10	
	15	BSC1AX	SS	Bridge Solenoid Clamp East Fully Applied	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 35 Rev K	Idec	RH4B-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MHM-20A	P21	
	15	BSC1AY	SS	Bridge Solenoid Clamp East Fully Applied	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 35 Rev K	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P21	
	15	BSC2AX	SS	Bridge Solenoid Clamp West Fully Applied	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 35 Rev K	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P21	
	15	BSC2AY	SS	Bridge Solenoid Clamp West Fully Applied	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 35 Rev K	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P21	
	15	IAGMY	SS	Impact Absorber Exchange Mode	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 4 Rev K	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-23	P62, 06, 01	
	15	LSZX	SS	MCO Hoist at tube plug raise limit	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 10 Rev K	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P66	
	15	LSZY	SS	MCO Hoist at tube plug raise limit	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 10 Rev K	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P66	
	15	LSZY	SS	MCO Hoist at tube plug raise limit	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 10 Rev K	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P66	
	15	MCOY	SS	MCO Mode	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 4 Rev K	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62, 06, 01, 05	Labeled MCOY(1) w/MCOY(2) in parallel
	15	MGCY	SS	MCO Hoist Grapple Jaws Closed	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 13A Rev G	Idec	RH4B-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MHM-20A	P62, 02	MCO Hoist Grapple Jaws Closed
	15	MGCX	SS	MCO Grapple in contact with a load	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 13A Rev G	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	
	15	MGCY	SS	MCO Grapple in contact with a load	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 13A Rev G	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	
	15	MGNCLX	SS	MCO Hoist Grapple Jaws not closed	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 13A Rev G	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62, 05, 06, 00	Labeled MGNCLX(1)
	15	MGNCLY	SS	MCO Hoist Grapple Jaws not closed	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 13A Rev G	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62, 05, 00	
	15	MGNCY	SS	MCO Grapple not in contact with a load	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 13A Rev G	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62, 00	
	15	MGUD	SS	MCO Grapple upper datum	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 10A Rev E	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P66	
	15	MNDX	SS	MCO Hoist Hoisting permit	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 8 Rev L	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P08, 21, 26, 57, 61, 62, 63	
	15	MNF	SS	MCO Hoist Permissive Relay	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 8 Rev L	Idec	RH4B-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MHM-20A	P08, 21, 26	Turret Rotate Permit
	15	MW11	SS	MCO Hoist Weigh System 1 Cutout	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 11 Rev L:	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	Actuates MW11 relay for MCO Hoist Weigh System 1 Cutout
	15	MW15	SS	MCO Hoist Weigh System 1 Cutout	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 11 Rev L:	Idec	RH4B-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MHM-20A	P62, 02	MCO Hoist Weigh System 1 Cutout
	15	P21X	SS	Solenoid Restraints Applied	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 52 Rev G	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P21	Labeled P21X(1) w/ P21X(2) in parallel
	15	P21Y	SS	Solenoid Restraints Applied	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 52 Rev G	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P21	Labeled P21Y(1) w/ P21Y(2) in parallel
	15	P26X	SS	Shield Start Lowered & Seated	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 52 Rev G	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P21, 00	Labeled P26X(1) w/ P26X(2) in parallel
	15	P2X	SS	Travel Permit Interlock	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 51 Rev F	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	Labeled P2X(1) w/ P2X(2) in parallel
	15	P2Y	SS	Travel Permit Interlock	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 51 Rev F	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	Labeled P2Y(1) w/ P2Y(2) in parallel
	15	P6X	SS	Travel Permit Interlock	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 51 Rev F	Idec	RH4B-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MHM-20A	P66	Labeled P6X(1) w/ P6X(2) in parallel
	15	P6Y	SS	Travel Permit Interlock	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 51 Rev F	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P66	Labeled P6Y(1) w/ P6Y(2) in parallel
	15	PGCLX	SS	Tube Plug Grapple Jaws Fully Closed	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17 Rev L	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	Labeled PGCLX(1) w/ PGCLX(2) in parallel
	15	PGCLY	SS	Tube Plug Grapple Jaws Fully Closed	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17 Rev L	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	Labeled PGCLY(1) w/ PGCLY(2) in parallel
	15	PGEX	SS	Plug Cask Empty	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17A Rev H	Idec	RH4B-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MHM-20A	P62, 00	
	15	PGEY	SS	Plug Cask Empty	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17A Rev H	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62, 00	
	15	PGLX	SS	Plug Hoist Grapple Jaws Locked	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17A Rev H	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	
	15	PGLY	SS	Plug Hoist Grapple Jaws Locked	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17A Rev H	Idec	RH4B-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MHM-20A	P62	
	15	PGNEX	SS	Plug Cask Occupied	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17A Rev H	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	
	15	PGNEY	SS	Plug Cask Occupied	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17A Rev H	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62	
	15	PGOPX	SS	Tube Plug Grapple Jaws Fully Open Limit (X)	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17 Rev L	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62, 00	Labeled PGOPX(1) w/ PGOPX(2) in parallel
	15	PGOPY	SS	Tube Plug Grapple Jaws Fully Open Limit (Y)	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 17 Rev L	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62, 00	Labeled PGOPY(1) w/ PGOPY(2) in parallel
	15	PHR	SS	Plug hoist common interlocks satisfied	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 15 Rev J	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P08, 21, 26	
	15	PHLX	SS	Tube Plug Hoist Fully Raised	FR(s): Inhibit(s) before operation. PC(s): Operability of device and interlock circuit.	EB-33056 Sht 15A Rev H	Idec	RH4B-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MHM-20A	P62, 00	Labeled PHLX(1) w/PHLX(2), (3) & (4) in parallel

Syn.	Component No.	Description	Safety Class.	Safety Function	Design and Operational Attributes	Reference Drawing(s) (No. Sheet, Rev.)	Manufacturer or Vendor	Model No. or Engineered Equipment	Test Procedure No.	Test Method	Part No.	CGI	Interface	Notes
15	PHLY	Relay	SS	Tube Plug Hold Fully Raised	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 15A Rev H	Mec	RH48-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MFM-20A	P02, 00	Labelled PHLY(1) in PHLY(2) & (3) in parallel
15	SSRD	Relay	SS	Shield Start Raise Permit	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 32 Rev K	Mec	RH48-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MFM-20A	P02, 00, 09	Turret Rotate Permit
15	TF	Relay	SS	Trolley Travel Interlocks Satisfied Relay	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 21 Rev L	Mec	RH48-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MFM-20A	P02, 03, 00, 10	
15	TP01Y	Relay	SS	Tube Plug Exchange Mode	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 4 Rev K	Mec	RH48-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MFM-23	P02, 00, 01	
15	TRD	Relay	SS	Turret Rotate Permits	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 25A Rev K	Mec	RH48-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MFM-23	P06	
15	TSP1FX	Relay	SS	Trolley North Restraint Pin (1) Fully Inserted	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 37 Rev F	Mec	RH48-UL-AC120V	ITP020C	Complete	N/A	CGI-SNF-D-MFM-20A	P21	
15	TSP1FY	Relay	SS	Trolley North Restraint Pin (1) Fully Inserted	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 37 Rev F	Mec	RH48-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MFM-20A	P21	
15	TSP2FX	Relay	SS	Trolley South Restraint Pin (2) Fully Inserted	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 37 Rev F	Mec	RH48-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MFM-20A	P21	
15	TSP2FY	Relay	SS	Trolley South Restraint Pin (2) Fully Inserted	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 37 Rev F	Mec	RH48-UL-AC120V	ITP020D	>1049 SS Qual	N/A	CGI-SNF-D-MFM-20A	P21	
15	C-36640	Bridge Y Restraint, Rail Clamp	SC	Provide restraint during vehicle event	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	C-36640 SH 1 Rev B	Johnson Industries	Engineered Equipment	N/A	N/A	N/A	N/A	N/A	
15	LCMR1X	Motherboard	SS	MCO Hold Rope 1 Load Call	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 11 Rev L	MWD TOTCO	2077-004	CTP50,60	Complete	N/A	CGI-SNF-D-MFM-108	P02, 02, 03	
15	LCMR2X	Motherboard	SS	MCO Hold Rope 2 Load Call	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 11 Rev L	MWD TOTCO	2077-004	CTP50,60	Complete	N/A	CGI-SNF-D-MFM-108	P02, 02, 03	
15	LCMR1Y	Signal Conditioner	SS	MCO Hold Rope 1 Load Call	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 11 Rev L	MWD TOTCO	2076-101	CTP50,60	Complete	N/A	CGI-SNF-D-MFM-108	P02, 02, 03	
15	LCMR2Y	Signal Conditioner	SS	MCO Hold Rope 2 Load Call	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 11 Rev L	MWD TOTCO	2076-101	CTP50,60	Complete	N/A	CGI-SNF-D-MFM-108	P02, 02, 03	
15	H-3-00605	MCO centering guide	SS	Provides restraint during vehicle event	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	H-3-00605 SH 1 Rev 0	N/A	Engineered Equipment	N/A	N/A	N/A	N/A	N/A	Replacement in E3V3-001
15	PESSPX	Switch, Photoelectric	SS	Plug Cask Empty	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 17A Rev H	Omnron	ESV-R2C-43S	ITP012X	Complete	N/A	CGI-SNF-D-MFM-12	P02, P00	Replacement in E3V3-001
15	PESSPY	Switch, Photoelectric	SS	Plug Cask Empty	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 17A Rev H	Omnron	ESV-R2C-43S	ITP012Y	Complete	N/A	CGI-SNF-D-MFM-12	P02, P00	Replacement in E3V3-001
15	PESSPX	Controller, Sensor	SS	Plug Cask Empty	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 17A Rev H	Omnron	S302-CK-US	ITP012X	Complete	N/A	CGI-SNF-D-MFM-12	P02, P00	
15	PESSPY	Controller, Sensor	SS	Plug Cask Empty	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 17A Rev H	Omnron	S302-CK-US	ITP012Y	Complete	N/A	CGI-SNF-D-MFM-12	P02, P00	
15	LCMR1X	Load Call	SS	MCO Hold Rope 1 Load Call	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 11 Rev L	Sensotec	RMCT17-01	ITP018AXZ	Complete	N/A	CGI-SNF-D-MFM-16A	P02, 02, 03	
15	LCMR2X	Load Call	SS	MCO Hold Rope 2 Load Call	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 11 Rev L	Sensotec	RMCT17-01	ITP018AYZ	Complete	N/A	CGI-SNF-D-MFM-16A	P02, 02, 03	
15	BLPDY	Contactor	SS	Base Locking Pin Disengage Redundant Contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 30 Rev J	Siemens	3TF4222-0A4G	ITP048D	3/8 SS Qual	N/A	CGI-SNF-D-MFM-48	P00, 07, 21, 26	
15	PHY	Contactor	SS	Plug hold raise redundant contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 15 Rev J	Siemens	3TF4222-0A4G	ITP048A	Complete	N/A	CGI-SNF-D-MFM-48	P00, 21, 26, 44, 45	
15	PHLY	Contactor	SS	Plug hold lower redundant contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 15 Rev J	Siemens	3TF4222-0A4G	ITP048B	Complete	N/A	CGI-SNF-D-MFM-48	P00, 21, 26	
15	SSLY	Contactor	SS	Shield Start Lowering Redundant Contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 32 Rev K	Siemens	3TF4222-0A4G	ITP048C	Complete	N/A	CGI-SNF-D-MFM-48	P21, 05	
15	SSRY	Contactor	SS	Shield Start Raise Redundant Contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 32 Rev K	Siemens	3TF4222-0A4G	ITP048D	3/8 SS Qual	N/A	CGI-SNF-D-MFM-48	P02, 00, 09	
15	TLPDY	Contactor	SS	Turret Locking Pin Disengage Redundant Contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 28 Rev J	Siemens	3TF4222-0A4G	ITP048D	3/8 SS Qual	N/A	CGI-SNF-D-MFM-48	P00, 07, 21, 26	
15	TRLC	Contactor	SS	Turret Rotate Contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 25A Rev K	Siemens	3TF4222-0A4G	ITP047	Complete	N/A	CGI-SNF-D-MFM-47	P00, 21, 26	
15	BLC	Contactor	SS	Bridge Line Contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 34A Rev G	Siemens	3TF4611-0A4G	BTPO19A	Complete	N/A	CGI-SNF-D-MFM-19	P02, 03, 05, 09, 10	
15	W4LC	Contactor	SS	MCO Hold Line Contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 21 Rev L	Siemens	3TF4611-0A4G	BTPO19C	Complete	N/A	CGI-SNF-D-MFM-19	P00, 21, 26, 57, 61, 62, 63, 65, 66	
15	TLC	Contactor	SS	Trolley Line Contactor	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 4 Rev K	Siemens	3TF4611-0A4G	BTPO19B	Complete	N/A	CGI-SNF-D-MFM-19	P02, 03, 09, 10	
15	IAXM	Relay	SS	Impact Absorber Exchange Mode	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 4 Rev K	Siemens	3TH4310-0A4G	ITP023A	Complete	N/A	CGI-SNF-D-MFM-23	P02, 00, 01, 03	IAXM(1) - Idoc relay in parallel
15	MCO	Relay	SS	MCO Mode	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 4 Rev K	Siemens	3TH4310-0A4G	ITP023C	Complete	N/A	CGI-SNF-D-MFM-23	P02, 00, 01, 03, 05	MCO(1) - Idoc relay in parallel
15	TPXM	Relay	SS	Tube Plug Exchange Mode	FR(0): Inhibit(0) before operation. PC(0): Operability of device and interlock circuit.	EB-33056 SH 4 Rev K	Siemens	3TH4310-0A4G	ITP023B	Complete	N/A	CGI-SNF-D-MFM-23	P02, 00, 01, 03	

Legend:
ALARA = as low as reasonably achievable
CGI = CGI Dedication Package No.
CSB = Center Storage Building
FSAR, Table 2-1, "Multi-Casker Overpack Process Steps and Possible Drop, Shear, or Impact Scenarios." dated 11/4/98
FSAR, Table 4-1, "Summary of Safety-Class Systems, Structures, and Components." Dtd 11/2/99
FSAR, Table 4-11, "Summary of Safety-Significant Systems, Structures, and Components." Dtd 11/2/99
E-Mail from Nabli, Michael K., "Inspect of current safety problems on MFM CSB Program," dated 11/4/98, annotated by Ralph Creve
Updated SNF CSB Equipment List, dated 3/11/99
Electrical Elementary Drawings; EB-33056, Multiple sheets
CSB System Nos. Memo from Douglas M. Black dated 11/1/99

Section 6
CGI Dedication and Test Plan Records

CGI-SNF-D-MHM-020A

Commercial Grade Item Upgrade Dedication Form

Page 102

Rev. No. 3

ECN No. N/A CGI No. CGI-SNF-D-MHM-020A

Page 2 of 9

Title: **Various MHM P Interlocks – Idec Relay #RH4B-UL-AC120V**

SNF-6315, Rev. 0

Handwritten:
4/24/00

Section 2d Reason for Dedication		
The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):		
<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.	
<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.	
<input checked="" type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.	
<input checked="" type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.	
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)	
Section 3: Failure Effects Evaluation		
A. Part/Component Safety Function:		
1. Relay contacts must open the circuit to disable the MCO hoist lowering permit, the MCO hoist hoisting permit or the MCO hoist line contactor.		
B. Part/Component Functional Mode:	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function	
Safety Function #1: <input checked="" type="checkbox"/> Active <input type="checkbox"/> Passive		
Safety Function #2: <input type="checkbox"/> Active <input type="checkbox"/> Passive		
Safety Function #3: <input type="checkbox"/> Active <input type="checkbox"/> Passive		
C. Host Component Safety Function (if applicable):		
1. Relays are used in control circuits providing interlocks that ensure proper MCO grapple and hoist operation for protection against events that could result in an MCO drop, including P57, P61, P62, P63, P65, and P66		
D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):		
1. Contact resistance out of spec results in overheating and welding of contacts		
2. Hot short across contacts results in failure to open the circuit		
3. Binding of contacts results in failure to open circuit		
Section 4 Environmental & Natural Phenomena Hazard Design		
Environmental Qualification Required:	If yes: Environmental Qualification Requirements	
Yes <input type="checkbox"/>	Limiting Environmental Conditions:	
No <input checked="" type="checkbox"/>	Required Safety Functions:	
	Qualification Period:	
Natural Phenomena Hazard (NPH) Design Required:	If yes: NPH Design Requirements	
Yes <input type="checkbox"/>	Performance Category:	
No <input checked="" type="checkbox"/>	NPH Design Req'ts.:	
	Required Safety Functions:	
Section 5 Component Functional Classification		
<input type="checkbox"/> Safety Class (SC)	<input type="checkbox"/> General Service (GS)	<input checked="" type="checkbox"/> Safety Significant (SS)
If part/component classification is different from host component/system, document basis. N/A		
Sections 6 and 7 (Reserved)		
Section 8 References (for Functional Classification)		
National Codes/Standards: N/A		
Safety Analysis Report (SAR): HNF-3672, Rev. 0		
Drawings: Ederer, Inc. EB-33056, Sht 8 (primary with various others)		
Vendor Manual/Manufacturer/Supplier Information: Idec General Purpose Relays, section D2		
Other: ALSTOM ESL/R (96) 065 – Rev. D, 100% Design Submittal – June 1998		

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A CGI No. CGI-SNF-D-MHM-020A

Page 3 of 9

Title: Various MHM P Interlocks - Idec Relay #RH4B-UL-AC120V

Section 9 Critical Characteristics

Critical Characteristics:	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Idec	1, IN	X	
Model Number	RH4B-UL-AC120V	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Terminal Configuration	Blade Terminals ^{40PT} 40PT ^{CB} 4-11-00	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Current carrying capability	0.5V max. voltage drop across closed contacts at 10 amps VAC, resistive	1, T		X
Insulation resistance	10 Megohm min across open contact terminals and terminals to ground at 500 VDC	1, T		X
Mechanical Operation	Contacts change state at max pickup voltage of 96VAC and at min drop-out voltage of 36VAC	1, T		X
4. Notes and Legend:		Acceptance Method (Acc Meth):		
<p>Rev. 1: Page 3: corrected function column; Page 7: added data to "Method T/IN" Column; Page 9: Revised Attachment; General: new forms</p> <p>Rev. 2: Pages 3, 6, 7: revised Current carrying capability acceptance criteria to "0.5V max. voltage drop across closed contacts at 10 amps VAC, resistive"; Pages 3, 6, 7: revised Mechanical Operation acceptance criteria to " Contacts change state at max pickup voltage of 96VAC and at min drop-out voltage of 36VAC "</p> <p>Rev 3 issued to conform equipment number list attachment to the SEL and add slave relays.</p>		<p>1. Special Test and Inspection:</p> <p>1, IN for Inspection</p> <p>1,T for Test</p> <p>2. Commercial Grade Survey</p> <p>3. Source Verification</p> <p>1. Vendor/Item History</p>		

Section 10 Initial Review and Approval

Approvals:

Designated Engineer: [Signature] 4/6/00

Design Authority: [Signature] 4/6/00

QA Engineer: [Signature] 4-6-2000

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A CGI No. CGI-SNF-D-MHM-020A

Page 4 of 9

Title: Various MHM P Interlocks - Idec Relay #RH4B-UL-AC120V

SNF-6315, Rev. 0

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Failure to open the circuit by contact welding or hot short across the contact base.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Results in failure of contacts to open.
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
1.			
2.			
3.			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 5 of 9

ECN No. NA CGI No. CGI-SNF-D-MHM-020A
Title: Various MHM P Interlocks - Idec Relay #RH4B-UL-AC120V

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1

Item Description: Idec Relay	Equip #: See Attachment 1
System #: MHM	Model #: RH4B-UL-AC120V
Manufacturer (Address/Phone): Idec (800) 262-4332 P.O. #	Supplier (Address/Phone): ALSTROM, FASTER WHEELER Alstom CES 4-11-00

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	PIT	
X			1. Manufacturer
X			2. Model Number
X			3. Terminal Configuration
	X		4. Current Carrying Capability
	X		5. Insulation Resistance
	X		6. Mechanical Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size, References (See Section 7)

Characteristic: Manufacturer	Sample Size*: 100%
Acceptance Criteria: Idec	
Receipt Inspection Plan / Report #: TP-020C, D*	
Characteristic: Model Number	Sample Size*: 100%
Acceptance Criteria: RH4B-UL-AC120V	
Receipt Inspection Plan / Report #: TP-020C, D*	
Characteristic: Terminal Configuration	Sample Size*: 100%
Acceptance Criteria: Blade Terminals	
Receipt Inspection Plan / Report #: TP-020C, D*	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3
Page 6 of 9

ECN No. NA CGI No. CGI-SNF-D-MHM-020A
Title: Various MHM P Interlocks - Idec Relay #RH4B-UL-AC120V

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size. References (See Section 7)	
Characteristic for Test: Current carrying Capability Acceptance Criteria: 0.5V max. voltage drop across closed contacts at 10 amps VAC, resistive Actual Test Value: <u>See TP020C*</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP020C</u>
Characteristic for Test: Insulation Resistance Acceptance Criteria: 10 Megohms min across open contact terminals and terminals to ground (500VDC megger) Actual Test Value: <u>See TP020C*</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP020C</u>
Characteristic for Test: Mechanical Operation Acceptance Criteria: Contacts change state at max pickup voltage of 96VAC and at min drop-out voltage of 36VAC Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP020C</u>

* Full hrs is: CGI-SNF-D-MHM-020C
" " " " -020D

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A CGI No. CGI-SNF-D-MHM-020A

Page 7 of 9

Title: Various MHM P Interlocks - Idec Relay #RH4B-UL-AC120V

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Relay

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Idec	X		1, IN	TP020C, D	NA	15	0	XWEST	Larry W. Price <i>[Signature]</i>	4/10/00
Model Number	RH4B-UL-AC120V	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Terminal Configuration	Blade Terminals	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Current Carrying Capability	0.5V max. voltage drop across closed contacts at 10 amps VAC, resistive		X	1, T	TP020C	NA	15	0	XWEST	Larry W. Price <i>[Signature]</i>	4/10/00
Insulation Resistance	10 Megohms min across open contact terminals and terminals to ground (500VDC megger)		X	1, T	↓	↓	↓	↓	↓	↓	↓
Mechanical Operation	Contacts change state at max pickup voltage of 96VAC and at min drop-out voltage of 36VAC		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

See Test Plans TP-020C, D cited above. CES
 Testing Agency Approval: NR CES 4-11-00 Date 4-11-00
 Testing Agency QA Engineer: NR CES 4-11-00 Date _____

BUYER VERIFICATION
 Design Authority: Craig Jensen Date 4/24/00
 QA Engineer: Stephen Scott Mox Date 4-24-2000

04/06/00

SNF-6315, Rev. 0

Page 107

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A CGI No. CGI-SNF-D-MHM-020A

Page 8 of 9

Title: Various MHM P Interlocks - Idec Relay #RH4B-UL-AC120V

SECTION 6 CONTACTS / PHONE NUMBERS

Name	Phone
Design Authority <u>LIZALG SWENSON</u>	<u>376-0288</u>
QA	
QC	
Cog - Engineer	
CGI Engineer	
Procurement Engineer	
Other	

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents		For Critical Characteristics
	Drawings:	
X	Manuals (specify type & number): <u>Idec General Purpose Relays, RH Series, Section D2</u>	All
	Design Calculations	
	Installation Instructions	
	Operation Instructions	
	Calibration Instructions	
	Manufacturer's Recommended Spare Parts List	
	Other:	
Procurement Documents		For Critical Characteristics
	Certificate of Conformance/Compliance	
	Seismic Qualification Certificate	
	Environmental Qualification Certificate	
	Test Report (s):	
	Inspection Report (s):	
	CMTRs for ASME Pressure Retaining Materials	
	Valve Seat Leakage Report	
	Weld Record	
	Material Traceability Record	
	Other:	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 3

ECN No. N/A CGI No. CGI-SNF-D-MHM-020A

Page 9 of 9

Title: Various MHM P Interlocks - Idec Relay #RH4B-UL-AC120V

Attachment 1
Section 2a Equipment Numbers

BF	P6X(1)
BSC1AX	P6X(2)
BSC1AY	P6Y(1)
BSC2AX	P6Y(2)
BSC2AY	PGCLX(1)
IAXM(1)	PGCLX(2)
IAXMY	PGCLY(1)
LS2X	PGCLY(2)
LS2Y	PGEX
LS4Y	PGEY
MCO(1)	PGLX
MCOY(1)	PGLY
MCOY(2)	PGNEX
MGCLX(1)	PGNEY
MGCLX(2)	PGOPX(1)
MGCLY	PGOPX(2)
MGCX	PGOPY(1)
MGCY	PGOPY(2)
MGNCLX(1)	PHIR
MGNCLY	PHULX(1)
MGNCY	PHULX(2)
MGUD	PHULX(3)
MHDX	PHULX(4)
MHF	PHULY(1)
MW11	PHULY(2)
MW15	PHULY(3)
P21X(1)	SSRD
P21X(2)	TF
P21Y(1)	TPXMY
P21Y(2)	TRD
P26X(1)	TSP1FIX
P26X(2)	TSP1FIY
P2X(1)	TSP2FIX
P2X(2)	TSP2FIY
P2Y	

Total = 69

Note: Equipment ID Nos. with 1, 2, 3, 4 in parenthesis after the ID nos. are relays in parallel with others of the same ID. e.g. PHULX(1), PHULX(2), PHULX(3) & PHULX(4) are 4 relays whose coils are wired in parallel with each other, the SEL listing for this component is PHULX.

ORIGINAL

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020D Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various	Rev. No. 0 Page 1 of 14
--	--------------------------------

In-Situ Inspection Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI. Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 2 of 14

In-Situ Inspection Procedure**ORIGINAL****Inspection Procedure Approval (Obtain prior to inspection):**

This procedure documents the visual verification of the identification critical characteristics of the remaining specimen which were in-situ tested on a sampling basis as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *[Signature]* Date: 4-6-00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Electrician	N/A	N/A	N/A	N/A
Electrician Quality Control	N/A	N/A	N/A	N/A
Design Authority Representative	LARRY W. PRICE	XUEST	<i>[Signature]</i>	JWP

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment.

INSPECTION PROCEDURE:**1.0 Record the following Test Specimen identification information:**

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	BSC1AY	BSC1AY	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	BSC2AX	BSC2AX	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 3 of 14

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	BSC2AY	BSC2AY	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	IAXMY	IAXMY	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LS2X	LS2X	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LS2Y	LS2Y	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	LS4Y	LS4Y	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
-------------	-------------	---------------------	---------------------

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 4 of 14

Equipment ID No.:	MCOY (1)	MCOY(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MGCLX(1)	MGCLX(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MGCLX(2)	MGCLX(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MGCX	MGCX	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MGCY	MGCY	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MGNCLX(1)	MGNCLX(1)	

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 5 of 14

Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MGNCLY	MGNCLY	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MGNCY	MGNCY	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MGUD	MGUD	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MHDX	MHDX	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MW11	MW11	
Manufacturer:	IDEC	Idec	

Dedication Test Plan - IST		Rev. No. 0	
Test Plan No.: CGI-SNF-D-MHM-020-TP-020D			
Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various		Page 6 of 14	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P21X1	P21X(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P21X2	P21X(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P21Y1	P21Y(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P21Y2	P21Y(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P26X1	P26X(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 7 of 14

Contact Configuration:	4PDT	4PDT Contacts	
------------------------	------	---------------	--

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P26X2	P26X(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P2X(2)	P2X(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P2Y	P2Y	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P6X(2)	P6X(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P6Y1	P6Y(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 8 of 14

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P6Y2	P6Y(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGCLX(1)	PGCLX(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGCLX(2)	PGCLX(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGCLY1	PGCLY(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGCLY2	PGCLY(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGEY	PGEY	

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 9 of 14

Manufacturer:	Idec	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGLX	PGLX	
Manufacturer:	Idec	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGNEX	PGNEX	
Manufacturer:	Idec	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGNEY	PGNEY	
Manufacturer:	Idec	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGOPX(1)	PGOPX(1)	
Manufacturer:	Idec	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGOPX(2)	PGOPX(2)	
Manufacturer:	Idec	Idec	

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 10 of 14

Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGOPY1	PGOPY(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGOPY 2	PGOPY(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHIR PHIR	PHIR	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHULX(1)	PHULX(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHULX(2)	PHULX(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 11 of 14

Contact Configuration:	4PDT	4PDT Contacts	
------------------------	------	---------------	--

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHULX(3)	PHULX(3)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHULX(4)	PHULX(4)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHULY1	PHULY(1)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHULY2	PHULY(2)	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	SSRD	SSRD	
Manufacturer:	IDEC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020D

Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various

Page 12 of 14

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TF	TF	
Manufacturer:	IDGC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TPXMY	TPXMY	
Manufacturer:	IDGC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TSP1FIY	TSP1FIY	
Manufacturer:	IDGC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TSP2FIX	TSP2FIX	
Manufacturer:	IDGC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TSP2FIY	TSP2FIY	
Manufacturer:	IDGC	Idec	
Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	
Contact Configuration:	4PDT	4PDT Contacts	

Dedication Test Plan - IST		Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-020-TP-020D		
Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various		Page 13 of 14

2.0 Record: Date /Time of Test Beginning: 8:30 AM 4/7/00

2.1 Record: Date /Time of Test End: 4/7/00 9:22 AM

3.0 References

3.1 Elementary Wiring Drawings: EB-33056

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

ACCEPTANCE CRITERIA MET.

Notes:

N/A

Design Authority Representative (signature)

[Handwritten Signature]

Date: 4/7/00

[Handwritten Name] 4/7/00 CES 4/7/00

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-020-TP-020D	
Test Specimen: Idec RH4B-UL-AC120V, Eqmt. No.: Various	Page 14 of 14

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Lang Swenson Date: 4/7/00

QA/QC (signature) Stephen Scott Moss Date: 4-7-2000

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

ORIGINAL

Rev. No. 0

Page 1 of 9

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**



This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	Michael Cram	MRC
Electrician	DANIEL K. YORK	P.C.E	Daniel K. York	D.K.Y
Electrician Quality Control	Stephen R. Conley	P.C.E	Stephen R. Conley	SRC
Design Authority Representative	LARRY W. PRICE	WEST		
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO BM802 I.D.: 6410-859 Calib. Due date: 02-09-01Test Instrument type: FLOKE 787 I.D.: BAT107 Calib. Due date: 05-28-00Test Instrument type: HP3457A I.D.: BAT123 Calib. Due date: 07-29-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
→ 1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

- 1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P2X(1)	Select from List provided above	Acc
Manufacturer:	Idec	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

- 2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-28-00 1:50 pm

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
1	2	> 100Gohm	> 10 Megohms	Acc
1	3	> 100Gohm	> 10 Megohms	Acc
1	4	> 100Gohm	> 10 Megohms	Acc
1	5	> 100Gohm	> 10 Megohms	Acc
1	6	> 100Gohm	> 10 Megohms	Acc
1	7	> 100Gohm	> 10 Megohms	Acc
1	8	> 100Gohm	> 10 Megohms	Acc
1	9	> 100Gohm	> 10 Megohms	Acc
1	10	> 100Gohm	> 10 Megohms	Acc
1	11	> 100Gohm	> 10 Megohms	Acc
1	12	> 100Gohm	> 10 Megohms	Acc
1	13	> 100Gohm	> 10 Megohms	Acc
1	14	> 100Gohm	> 10 Megohms	Acc
2	3	> 100Gohm	> 10 Megohms	Acc
2	4	> 100Gohm	> 10 Megohms	Acc
2	5	> 100Gohm	> 10 Megohms	Acc
2	6	> 100Gohm	> 10 Megohms	Acc
2	7	> 100Gohm	> 10 Megohms	Acc
2	8	> 100Gohm	> 10 Megohms	Acc
2	9	> 100Gohm	> 10 Megohms	Acc
2	10	> 100Gohm	> 10 Megohms	Acc
2	11	> 100Gohm	> 10 Megohms	Acc
2	12	> 100Gohm	> 10 Megohms	Acc
2	13	> 100Gohm	> 10 Megohms	Acc
2	14	> 100Gohm	> 10 Megohms	Acc
3	4	> 100Gohm	> 10 Megohms	Acc
3	5	> 100Gohm	> 10 Megohms	Acc
3	6	> 100Gohm	> 10 Megohms	Acc
3	7	> 100Gohm	> 10 Megohms	Acc
3	8	> 100Gohm	> 10 Megohms	Acc
3	9	> 100Gohm	> 10 Megohms	Acc
3	10	> 100Gohm	> 10 Megohms	Acc
3	11	> 100Gohm	> 10 Megohms	Acc
3	12	> 100Gohm	> 10 Megohms	Acc
3	13	> 100Gohm	> 10 Megohms	Acc
3	14	> 100Gohm	> 10 Megohms	Acc
4	5	> 100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	> 100Gohm	> 10 Megohms	Acc
4	7	> 100Gohm	> 10 Megohms	Acc
4	8	> 100Gohm	> 10 Megohms	Acc
4	9	> 100Gohm	> 10 Megohms	Acc
4	10	> 100Gohm	> 10 Megohms	Acc
4	11	> 100Gohm	> 10 Megohms	Acc
4	12	> 100Gohm	> 10 Megohms	Acc
4	13	> 100Gohm	> 10 Megohms	Acc
4	14	> 100Gohm	> 10 Megohms	Acc
5	6	> 100Gohm	> 10 Megohms	Acc
5	7	> 100Gohm	> 10 Megohms	Acc
5	8	> 100Gohm	> 10 Megohms	Acc
5	8	> 100Gohm	> 10 Megohms	Acc
5	10	> 100Gohm	> 10 Megohms	Acc
5	11	> 100Gohm	> 10 Megohms	Acc
5	12	> 100Gohm	> 10 Megohms	Acc
5	13	> 100Gohm	> 10 Megohms	Acc
5	14	> 100Gohm	> 10 Megohms	Acc
6	7	> 100Gohm	> 10 Megohms	Acc
6	8	> 100Gohm	> 10 Megohms	Acc
6	9	> 100Gohm	> 10 Megohms	Acc
6	10	> 100Gohm	> 10 Megohms	Acc
6	11	> 100Gohm	> 10 Megohms	Acc
6	12	> 100Gohm	> 10 Megohms	Hcc
6	12	> 100Gohm	> 10 Megohms	Acc
6	14	> 100Gohm	> 10 Megohms	Acc
7	8	> 100Gohm	> 10 Megohms	Acc
7	9	> 100Gohm	> 10 Megohms	Acc
7	10	> 100Gohm	> 10 Megohms	Acc
7	11	> 100Gohm	> 10 Megohms	Acc
7	12	> 100Gohm	> 10 Megohms	Acc
7	13	> 100Gohm	> 10 Megohms	Acc
7	14	> 100Gohm	> 10 Megohms	Acc
8	9	> 100Gohm	> 10 Megohms	Acc
8	10	> 100Gohm	> 10 Megohms	Acc
8	11	> 100Gohm	> 10 Megohms	Acc
8	12	> 100Gohm	> 10 Megohms	Acc
8	13	> 100Gohm	> 10 Megohms	Hcc
8	14	> 100Gohm	> 10 Megohms	Acc
9	10	> 100Gohm	> 10 Megohms	Acc
9	11	> 100Gohm	> 10 Megohms	Acc
9	12	> 100Gohm	> 10 Megohms	Acc
9	13	> 100Gohm	> 10 Megohms	Acc
9	14	> 100Gohm	> 10 Megohms	Acc
10	11	> 100Gohm	> 10 Megohms	Acc
10	12	> 100Gohm	> 10 Megohms	Acc
10	13	> 100Gohm	> 10 Megohms	Acc
10	14	> 100Gohm	> 10 Megohms	Acc
11	12	> 100Gohm	> 10 Megohms	Acc
11	13	> 100Gohm	> 10 Megohms	Acc
11	14	> 100Gohm	> 10 Megohms	Acc

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	> 100Gohm	> 10 Megohms	Acc
10	Ground	> 100Gohm	> 10 Megohms	Acc
11	Ground	> 100Gohm	> 10 Megohms	Acc
12	Ground	> 100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	> 100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground				
Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	> 100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	> 100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	> 100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

- 2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	68.70 VAC	96 VAC maximum	Acc
Drop-out Voltage	65.86 VAC	36 AC minimum	Acc

- 2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

- 2.4.1 Setup the Relay specimen for contact rating testing.

- 2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1168 VAC	< 0.5 Volts AC drop	Acc
2-10	.1022 VAC	< 0.5 Volts AC drop	Acc
3-11	.0989 VAC	< 0.5 Volts AC drop	Acc
4-12	.0963 VAC	< 0.5 Volts AC drop	Acc

- 2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

- 2.4.4 Apply a nominal 10 amps VAC, resistive, across the **closed** NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1150 VAC	< 0.5 Volts AC drop	Acc
6-10	.0929 VAC	< 0.5 Volts AC drop	Acc
7-11	.0946 VAC	< 0.5 Volts AC drop	Acc
8-12	.1319 VAC	< 0.5 Volts AC drop	Acc

- 2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

- 2.5.1 Reland the relay and verify reband in accordance with the Lifted Lead Log.

- 2.5.2 Record: Date /Time of Test End: 03/28/00 2:20 p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met

Michael Cron 03-28-00

Notes:

Certified Instrumentation Technician (signature) Michael Cron Date: 03-28-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) [Signature] Date: 3/28/00

QA/QC (signature) [Signature] Date: 4-6-2000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
		2405X	P2X1	6	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		2104X		5	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		2) 102X		14	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		2) 5103X		13	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		Black	RCS2A-6	13	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		Grey	" "	14	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		2105X		9	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
		2406X		10	DKY	3-22-00	SRL	3-22-00	DKY	3-22-00	SRL	3-22-00
Remarks:												

SNF-6315, Rev. 0

Page 132

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**


This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	Michael Cram	MCC
Electrician	DANIEL K. YORK	P.C.E	Daniel K. York	D.K.Y
Electrician Quality Control	Stephen R. Conley	RE	Stephen R. Conley	SEC
Design Authority Representative	LEO W. PERCE	XINST		JWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO MEGGER²⁴⁸⁹² I.D.: CA10-889 Calib. Due date: 02-09-01

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 7-29-00

Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 7-30-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
→ 2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

- 1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	P6X(1)	Select from List provided above	Acc
Manufacturer:	Idec	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	YES	4PDT Contacts	Acc
Socket Model:	YES	SH4B-05	Acc

- 2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-28-00 1:00p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the **Relay Socket** specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
1	2	>100Gohm	> 10 Megohms	Acc
1	3	>100Gohm	> 10 Megohms	Acc
1	4	>100Gohm	> 10 Megohms	Acc
1	5	>100Gohm	> 10 Megohms	Acc
1	6	>100Gohm	> 10 Megohms	Acc
1	7	>100Gohm	> 10 Megohms	Acc
1	8	>100Gohm	> 10 Megohms	Acc
1	9	>100Gohm	> 10 Megohms	Acc
1	10	>100Gohm	> 10 Megohms	Acc
1	11	>100Gohm	> 10 Megohms	Acc
1	12	>100Gohm	> 10 Megohms	Acc
1	13	>100Gohm	> 10 Megohms	Acc
1	14	>100Gohm	> 10 Megohms	Acc
2	3	>100Gohm	> 10 Megohms	Acc
2	4	>100Gohm	> 10 Megohms	Acc
2	5	>100Gohm	> 10 Megohms	Acc
2	6	>100Gohm	> 10 Megohms	Acc
2	7	>100Gohm	> 10 Megohms	Acc
2	8	>100Gohm	> 10 Megohms	Acc
2	9	>100Gohm	> 10 Megohms	Acc
2	10	>100Gohm	> 10 Megohms	Acc
2	11	>100Gohm	> 10 Megohms	Acc
2	12	>100Gohm	> 10 Megohms	Acc
2	13	>100Gohm	> 10 Megohms	Acc
2	14	>100Gohm	> 10 Megohms	Acc
3	4	>100Gohm	> 10 Megohms	Acc
3	5	>100Gohm	> 10 Megohms	Acc
3	6	>100Gohm	> 10 Megohms	Acc
3	7	>100Gohm	> 10 Megohms	Acc
3	8	>100Gohm	> 10 Megohms	Acc
3	9	>100Gohm	> 10 Megohms	Acc
3	10	>100Gohm	> 10 Megohms	Acc
3	11	>100Gohm	> 10 Megohms	Acc
3	12	>100Gohm	> 10 Megohms	Acc
3	13	>100Gohm	> 10 Megohms	Acc
3	14	>100Gohm	> 10 Megohms	Acc
4	5	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST
 Test Plan No.: CGI-SNF-D-MHM-020-TP-020C
 Test Specimen: Idcc RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic
 Rev. No. 0
 Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	> 100 Gohm	> 10 Megohms	Acc
12	14	> 100 Gohm	> 10 Megohms	Acc
13	14	> 100 Gohm	> 10 Megohms	Acc
1	1	> 100 Gohm	> 10 Megohms	Acc
2	2	> 100 Gohm	> 10 Megohms	Acc
3	3	> 100 Gohm	> 10 Megohms	Acc
4	4	> 100 Gohm	> 10 Megohms	Acc
5	5	> 100 Gohm	> 10 Megohms	Acc
6	6	> 100 Gohm	> 10 Megohms	Acc
7	7	> 100 Gohm	> 10 Megohms	Acc
8	8	> 100 Gohm	> 10 Megohms	Acc
9	9	> 100 Gohm	> 10 Megohms	Acc
10	10	> 100 Gohm	> 10 Megohms	Acc
11	11	> 100 Gohm	> 10 Megohms	Acc
12	12	> 100 Gohm	> 10 Megohms	Acc
13	13	> 100 Gohm	> 10 Megohms	Acc
14	14	> 100 Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	> 100 Gohm	> 10 Megohms	Acc
1-9	3-11	> 100 Gohm	> 10 Megohms	Acc
1-9	4-12	> 100 Gohm	> 10 Megohms	Acc
5	6	> 100 Gohm	> 10 Megohms	Acc
6	7	> 100 Gohm	> 10 Megohms	Acc
7	8	> 100 Gohm	> 10 Megohms	Acc
7	8	> 100 Gohm	> 10 Megohms	Acc
5	6	> 100 Gohm	> 10 Megohms	Acc
3-11	4-12	> 100 Gohm	> 10 Megohms	Acc
2-10	3-11	> 100 Gohm	> 10 Megohms	Acc
2-10	4-12	> 100 Gohm	> 10 Megohms	Acc
1-9	2-10	> 100 Gohm	> 10 Megohms	Acc
1-9	3-11	> 100 Gohm	> 10 Megohms	Acc
1-9	4-12	> 100 Gohm	> 10 Megohms	Acc
14	Ground	> 100 Gohm	> 10 Megohms	Acc
13	Ground	> 100 Gohm	> 10 Megohms	Acc
8	Ground	> 100 Gohm	> 10 Megohms	Acc
7	Ground	> 100 Gohm	> 10 Megohms	Acc
6	Ground	> 100 Gohm	> 10 Megohms	Acc
5	Ground	> 100 Gohm	> 10 Megohms	Acc
4-12	Ground	> 100 Gohm	> 10 Megohms	Acc
3-11	Ground	> 100 Gohm	> 10 Megohms	Acc
2-10	Ground	> 100 Gohm	> 10 Megohms	Acc
1-9	Ground	> 100 Gohm	> 10 Megohms	Acc
1-9	Ground	> 100 Gohm	> 10 Megohms	Acc
1-9	Ground	> 100 Gohm	> 10 Megohms	Acc
1-9	Terminal/Ground	> 100 Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

- 2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	81.1 VAC	96 VAC maximum	Acc
Drop-out Voltage	64.5 VAC	36 AC minimum	Acc

- 2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

- 2.4.1 Setup the Relay specimen for contact rating testing.
- 2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1086 VAC	< 0.5 Volts AC drop	Acc
2-10	.0803 VAC	< 0.5 Volts AC drop	Acc
3-11	.0855 VAC	< 0.5 Volts AC drop	Acc
4-12	.1059 VAC	< 0.5 Volts AC drop	Acc

- 2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

- 2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1137 VAC	< 0.5 Volts AC drop	
6-10	.1318 VAC	< 0.5 Volts AC drop	
7-11	.1562 VAC	< 0.5 Volts AC drop	
8-12	.1140 VAC	< 0.5 Volts AC drop	

- 2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

- 2.5.1 Reland the relay and verify reband in accordance with the Lifted Lead Log.

- 2.5.2 Record: Date /Time of Test End: 03-28-00 2:55 p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met.

Michael Cram

03-28-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-28-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) ^{3/28/00} [Signature] Date: 3/28/00

QA/QC (signature) [Signature] Date: 4-3-2000

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

ORIGINAL

Rev. No. 0

Page 1 of 9

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *JWP Craig Swenson* Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MRC
Electrician	DAN K. YORK	PCE	<i>Dan K. York</i>	DKY
Electrician Quality Control	Stephen P. Cowley	PE	<i>Stephen P. Cowley</i>	SPC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Ayo BM80/2 I.D.: 6410-559 Calib. Due date: 02-09-01

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
→ 3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	IAXM(1)	Select from List provided above	Acc
Manufacturer:	Idec	Idec	Acc
Relay Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-28-00 2:30 p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>100Gohm	> 10 Megohms	Acc
1	3	>100Gohm	> 10 Megohms	Acc
1	4	>100Gohm	> 10 Megohms	Acc
1	5	>100Gohm	> 10 Megohms	Acc
1	6	>100Gohm	> 10 Megohms	Acc
1	7	>100Gohm	> 10 Megohms	Acc
1	8	>100Gohm	> 10 Megohms	Acc
1	9	>100Gohm	> 10 Megohms	Acc
1	10	>100Gohm	> 10 Megohms	Acc
1	11	>100Gohm	> 10 Megohms	Acc
1	12	>100Gohm	> 10 Megohms	Acc
1	13	>100Gohm	> 10 Megohms	Acc
1	14	>100Gohm	> 10 Megohms	Acc
2	3	>100Gohm	> 10 Megohms	Acc
2	4	>100Gohm	> 10 Megohms	Acc
2	5	>100Gohm	> 10 Megohms	Acc
2	6	>100Gohm	> 10 Megohms	Acc
2	7	>100Gohm	> 10 Megohms	Acc
2	8	>100Gohm	> 10 Megohms	Acc
2	9	>100Gohm	> 10 Megohms	Acc
2	10	>100Gohm	> 10 Megohms	Acc
2	11	>100Gohm	> 10 Megohms	Acc
2	12	>100Gohm	> 10 Megohms	Acc
2	13	>100Gohm	> 10 Megohms	Acc
2	14	>100Gohm	> 10 Megohms	Acc
3	4	>100Gohm	> 10 Megohms	Acc
3	5	>100Gohm	> 10 Megohms	Acc
3	6	>100Gohm	> 10 Megohms	Acc
3	7	>100Gohm	> 10 Megohms	Acc
3	8	>100Gohm	> 10 Megohms	Acc
3	9	>100Gohm	> 10 Megohms	Acc
3	10	>100Gohm	> 10 Megohms	Acc
3	11	>100Gohm	> 10 Megohms	Acc
3	12	>100Gohm	> 10 Megohms	Acc
3	13	>100Gohm	> 10 Megohms	Acc
3	14	>100Gohm	> 10 Megohms	Acc
4	5	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground				
Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	71.047 VAC	96 VAC maximum	Acc
Drop-out Voltage	57.562 VAC	36 AC minimum	Acc

2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

2.4.1 Setup the Relay specimen for contact rating testing.

2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.08156 VAC	< 0.5 Volts AC drop	Acc
2-10	.08778 VAC	< 0.5 Volts AC drop	Acc
3-11	.08246 VAC	< 0.5 Volts AC drop	Acc
4-12	.07505 VAC	< 0.5 Volts AC drop	Acc

2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.08112 VAC	< 0.5 Volts AC drop	Acc
6-10	.12499 VAC	< 0.5 Volts AC drop	Acc
7-11	.10300 VAC	< 0.5 Volts AC drop	Acc
8-12	.10025 VAC	< 0.5 Volts AC drop	Acc

2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the relay and verify reland in accordance with the Lifted Lead Log.

2.5.2 Record: Date /Time of Test End: 03-30-00 11:20 a.m.

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-020-TP-020C	
Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Test was acceptable
Michael Cram
03-30-00

Notes:

Notes section with multiple horizontal lines for text entry.

Certified Instrumentation Technician (signature) Michael Cram Date: 03-30-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Larry Swenson Date: 3/30/00

QA/QC (signature) Stephen Scott Moss Date: 4-6-2000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
		2 102X	FAXM(1)	14	DKY	3-28-00	SEC	3-28-00	DKY	3-30-00	SEC	3-30-00
		Grey	RCS2A-6	14	DKY	3-28-00	SEC	3-28-00	DKY	3-30-00	SEC	3-30-00
		Black	RCS2A-6	13	DKY	3-28-00	SEC	3-28-00	DKY	3-30-00	SEC	3-30-00
		405X	JAXM(1)	13	DKY	3-28-00	SEC	3-28-00	DKY	3-30-00	SEC	3-30-00
		5201K	..	9	DKY	3-28-00	SEC	3-28-00	DKY	3-30-00	SEC	3-30-00
		5712X	..	5	DKY	3-28-00	SEC	3-28-00	DKY	3-30-00	SEC	3-30-00

Remarks:

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

ORIGINAL

Rev. No. 0

Page 1 of 9

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-020-TP-020C	
Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	Page 2 of 9

In-Situ Test Procedure

ORIGINAL

Test Procedure Approval (Obtain prior to testing):

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *JWP Craig Swenson* Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	<i>Michael Cram</i>	MRC
Electrician	DAN K. YORK	PCE	<i>Dan K. York</i>	DKY
Electrician Quality Control	Stephen R. Cowley	PE	<i>Stephen R. Cowley</i>	SRC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

- Power Supply capable of 10 amps @ 120 VAC.
- Megger Instrument capable of 500 VDC Test Voltage
- Adjustable Voltage Power supply capable of 0 to 120 VAC minimum
- MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
- Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM30/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

- 1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MCO(1)	Select from List provided above	Acc
Manufacturer:	Idec	Idec	Acc
Relay Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

- 2.0 Perform the following testing steps:

- 2.1 Record: Date /Time of Test Beginning: 03-30-00 11:30 a.m.

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Rev. No. 0

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the **Relay Socket** specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	> 100Gohm	> 10 Megohms	Acc
1	3	> 100Gohm	> 10 Megohms	Acc
1	4	> 100Gohm	> 10 Megohms	Acc
1	5	> 100Gohm	> 10 Megohms	Acc
1	6	> 100Gohm	> 10 Megohms	Acc
1	7	> 100Gohm	> 10 Megohms	Acc
1	8	> 100Gohm	> 10 Megohms	Acc
1	9	> 100Gohm	> 10 Megohms	Acc
1	10	> 100Gohm	> 10 Megohms	Acc
1	11	> 100Gohm	> 10 Megohms	Acc
1	12	> 100Gohm	> 10 Megohms	Acc
1	13	> 100Gohm	> 10 Megohms	Acc
1	14	> 100Gohm	> 10 Megohms	Acc
2	3	> 100Gohm	> 10 Megohms	Acc
2	4	> 100Gohm	> 10 Megohms	Acc
2	5	> 100Gohm	> 10 Megohms	Acc
2	6	> 100Gohm	> 10 Megohms	Acc
2	7	> 100Gohm	> 10 Megohms	Acc
2	8	> 100Gohm	> 10 Megohms	Acc
2	9	> 100Gohm	> 10 Megohms	Acc
2	10	> 100Gohm	> 10 Megohms	Acc
2	11	> 100Gohm	> 10 Megohms	Acc
2	12	> 100Gohm	> 10 Megohms	Acc
2	13	> 100Gohm	> 10 Megohms	Acc
2	14	> 100Gohm	> 10 Megohms	Acc
3	4	> 100Gohm	> 10 Megohms	Acc
3	5	> 100Gohm	> 10 Megohms	Acc
3	6	> 100Gohm	> 10 Megohms	Acc
3	7	> 100Gohm	> 10 Megohms	Acc
3	8	> 100Gohm	> 10 Megohms	Acc
3	9	> 100Gohm	> 10 Megohms	Acc
3	10	> 100Gohm	> 10 Megohms	Acc
3	11	> 100Gohm	> 10 Megohms	Acc
3	12	> 100Gohm	> 10 Megohms	Acc
3	13	> 100Gohm	> 10 Megohms	Acc
3	14	> 100Gohm	> 10 Megohms	Acc
4	5	> 100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground				
Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

- 2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	74.695 VAC	96 VAC maximum	Acc
Drop-out Voltage	55.945 VAC	36 AC minimum	Acc

- 2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

- 2.4.1 Setup the Relay specimen for contact rating testing.

- 2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1143 VAC	< 0.5 Volts AC drop	Acc
2-10	.1112 VAC	< 0.5 Volts AC drop	Acc
3-11	.1134 VAC	< 0.5 Volts AC drop	Acc
4-12	.1232 VAC	< 0.5 Volts AC drop	Acc

- 2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

- 2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1218 VAC	< 0.5 Volts AC drop	Acc
6-10	.1224 VAC	< 0.5 Volts AC drop	Acc
7-11	.1587 VAC	< 0.5 Volts AC drop	Acc
8-12	.1177 VAC	< 0.5 Volts AC drop	Acc

- 2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

- 2.5.1 Reland the relay and verify reband in accordance with the Lifted Lead Log.

- 2.5.2 Record: Date /Time of Test End: 03-30-00 12:45 p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Test was acceptable
Michael Chan
03-30-00

Notes:

[Blank lined area for notes]

Certified Instrumentation Technician (signature) *Michael Chan* Date: 03-30-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *Wang Swenson* Date: 3/30/00

QA/QC (signature) *Stephen Scott Moore* Date: 4-6-2000

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020C Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	<div style="font-size: 2em; font-weight: bold; margin-bottom: 5px;">ORIGINAL</div> Rev. No. 0 Page 1 of 9
--	--

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Circim	Belhaven	Michael Circim	MRC
Electrician	DAN K. YORK	PCE	Dan K. York	DKY
Electrician Quality Control	Stephen R. Cowley	PE	Stephen R. Cowley	SRC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM 3012 I.D.: 6410-559 Calib. Due date: 02-09-01

Test Instrument type: HP 3457A I.D.: BAT124 Calib. Due date: 07-30-00

Test Instrument type: FLUKE 937 I.D.: BAT107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
→ 5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MHF	Select from List provided above	Acc
Manufacturer:	Idec	Idec	Acc
Relay Model:	RH4B-UL-AC120V	RH4B-UL-AC120V	Acc
Contact Configuration:	4PDT Contacts	4PDT Contacts	Acc
Socket Model:	SH4B-05	SH4B-05	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-30-00

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>100Gohm	> 10 Megohms	Acc
1	3	>100Gohm	> 10 Megohms	Acc
1	4	>100Gohm	> 10 Megohms	Acc
1	5	>100Gohm	> 10 Megohms	Acc
1	6	>100Gohm	> 10 Megohms	Acc
1	7	>100Gohm	> 10 Megohms	Acc
1	8	>100Gohm	> 10 Megohms	Acc
1	9	>100Gohm	> 10 Megohms	Acc
1	10	>100Gohm	> 10 Megohms	Acc
1	11	>100Gohm	> 10 Megohms	Acc
1	12	>100Gohm	> 10 Megohms	Acc
1	13	>100Gohm	> 10 Megohms	Acc
1	14	>100Gohm	> 10 Megohms	Acc
2	3	>100Gohm	> 10 Megohms	Acc
2	4	>100Gohm	> 10 Megohms	Acc
2	5	>100Gohm	> 10 Megohms	Acc
2	6	>100Gohm	> 10 Megohms	Acc
2	7	>100Gohm	> 10 Megohms	Acc
2	8	>100Gohm	> 10 Megohms	Acc
2	9	>100Gohm	> 10 Megohms	Acc
2	10	>100Gohm	> 10 Megohms	Acc
2	11	>100Gohm	> 10 Megohms	Acc
2	12	>100Gohm	> 10 Megohms	Acc
2	13	>100Gohm	> 10 Megohms	Acc
2	14	>100Gohm	> 10 Megohms	Acc
3	4	>100Gohm	> 10 Megohms	Acc
3	5	>100Gohm	> 10 Megohms	Acc
3	6	>100Gohm	> 10 Megohms	Acc
3	7	>100Gohm	> 10 Megohms	Acc
3	8	>100Gohm	> 10 Megohms	Acc
3	9	>100Gohm	> 10 Megohms	Acc
3	10	>100Gohm	> 10 Megohms	Acc
3	11	>100Gohm	> 10 Megohms	Acc
3	12	>100Gohm	> 10 Megohms	Acc
3	13	>100Gohm	> 10 Megohms	Acc
3	14	>100Gohm	> 10 Megohms	Acc
4	5	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc.
12	14	>100Gohm	> 10 Megohms	Acc.
13	14	>100Gohm	> 10 Megohms	Acc.
1	Ground	>100Gohm	> 10 Megohms	Acc.
2	Ground	>100Gohm	> 10 Megohms	Acc.
3	Ground	>100Gohm	> 10 Megohms	Acc.
4	Ground	>100Gohm	> 10 Megohms	Acc.
5	Ground	>100Gohm	> 10 Megohms	Acc.
6	Ground	>100Gohm	> 10 Megohms	Acc.
7	Ground	>100Gohm	> 10 Megohms	Acc.
8	Ground	>100Gohm	> 10 Megohms	Acc.
9	Ground	>100Gohm	> 10 Megohms	Acc.
10	Ground	>100Gohm	> 10 Megohms	Acc.
11	Ground	>100Gohm	> 10 Megohms	Acc.
12	Ground	>100Gohm	> 10 Megohms	Acc.
13	Ground	>100Gohm	> 10 Megohms	Acc.
14	Ground	>100Gohm	> 10 Megohms	Acc.

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground				
Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc.
1-9	3-11	>100Gohm	> 10 Megohms	Acc.
1-9	4-12	>100Gohm	> 10 Megohms	Acc.
2-10	3-11	>100Gohm	> 10 Megohms	Acc.
2-10	4-12	>100Gohm	> 10 Megohms	Acc.
3-11	4-12	>100Gohm	> 10 Megohms	Acc.
5	6	>100Gohm	> 10 Megohms	Acc.
6	7	>100Gohm	> 10 Megohms	Acc.
7	8	>100Gohm	> 10 Megohms	Acc.
1-9	Ground	>100Gohm	> 10 Megohms	Acc.
2-10	Ground	>100Gohm	> 10 Megohms	Acc.
3-11	Ground	>100Gohm	> 10 Megohms	Acc.
4-12	Ground	>100Gohm	> 10 Megohms	Acc.
5	Ground	>100Gohm	> 10 Megohms	Acc.
6	Ground	>100Gohm	> 10 Megohms	Acc.
7	Ground	>100Gohm	> 10 Megohms	Acc.
8	Ground	>100Gohm	> 10 Megohms	Acc.
13	Ground	>100Gohm	> 10 Megohms	Acc.
14	Ground	>100Gohm	> 10 Megohms	Acc.

2.2.6 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	74.018 VAC	96 VAC maximum	Acc
Drop-out Voltage	57.953 VAC	36 AC minimum	Acc

2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

2.4.1 Setup the Relay specimen for contact rating testing.

2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1198 VAC	< 0.5 Volts AC drop	Acc
2-10	.1420 VAC	< 0.5 Volts AC drop	Acc
3-11	.1323 VAC	< 0.5 Volts AC drop	Acc
4-12	.1224 VAC	< 0.5 Volts AC drop	Acc

2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1239 VAC	< 0.5 Volts AC drop	Acc
6-10	.1395 VAC	< 0.5 Volts AC drop	Acc
7-11	.1354 VAC	< 0.5 Volts AC drop	Acc
8-12	.1176 VAC	< 0.5 Volts AC drop	Acc

2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the relay and verify reband in accordance with the Lifted Lead Log.

2.5.2 Record: Date /Time of Test End: 03-30-00 1:40 p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Test was acceptable

Michael D. Cram
03-30-00

Notes:

Certified Instrumentation Technician (signature) *Michael D. Cram* Date: *03-30-00*

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *Wang Swenson* Date: *3/30/00*

QA/QC (signature) *Stephen Scott Mason* Date: *4-6-2000*

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
FB-33066	1	2) 101X	MHF	5	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00
		812X		6	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00
		2) 101X		7	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00
		616X		9	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00
		814X		10	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00
		815X		11	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00
		806X		13	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00
		Grey	R862A-6	13	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00
		Black		14	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00
		2) 102X		14	DKY	3-30-00	SRG	3-30-00	DKY	3-30-00	SRG	3-30-00

Remarks:

SNF-6315, Rev. 0

Page 168

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020C Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	<b style="font-size: 2em;">ORIGINAL Rev. No. 0 Page 1 of 9
--	--

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date:

3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	Michael Cram	MC
Electrician	DAN K. YORK	PCE	Dan K. York	DKY
Electrician Quality Control	Stephen R. Couley	PEE	Stephen R. Couley	SR
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO BUS012 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: HP3457A I.D.: BAT124 Calib. Due date: 07-30-00Test Instrument type: FLOKE 787 I.D.: BAT107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
→ 6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGEX	Select from List provided above	Acc
Manufacturer:	Idec.	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-30-00 1:20 p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the **Relay Socket** specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
1	2	>100Gohm	> 10 Megohms	Acc
1	3	>100Gohm	> 10 Megohms	Acc
1	4	>100Gohm	> 10 Megohms	Acc
1	5	>100Gohm	> 10 Megohms	Acc
1	6	>100Gohm	> 10 Megohms	Acc
1	7	>100Gohm	> 10 Megohms	Acc
1	8	>100Gohm	> 10 Megohms	Acc
1	9	>100Gohm	> 10 Megohms	Acc
1	10	>100Gohm	> 10 Megohms	Acc
1	11	>100Gohm	> 10 Megohms	Acc
1	12	>100Gohm	> 10 Megohms	Acc
1	13	>100Gohm	> 10 Megohms	Acc
1	14	>100Gohm	> 10 Megohms	Acc
2	3	>100Gohm	> 10 Megohms	Acc
2	4	>100Gohm	> 10 Megohms	Acc
2	5	>100Gohm	> 10 Megohms	Acc
2	6	>100Gohm	> 10 Megohms	Acc
2	7	>100Gohm	> 10 Megohms	Acc
2	8	>100Gohm	> 10 Megohms	Acc
2	9	>100Gohm	> 10 Megohms	Acc
2	10	>100Gohm	> 10 Megohms	Acc
2	11	>100Gohm	> 10 Megohms	Acc
2	12	>100Gohm	> 10 Megohms	Acc
2	13	>100Gohm	> 10 Megohms	Acc
2	14	>100Gohm	> 10 Megohms	Acc
3	4	>100Gohm	> 10 Megohms	Acc
3	5	>100Gohm	> 10 Megohms	Acc
3	6	>100Gohm	> 10 Megohms	Acc
3	7	>100Gohm	> 10 Megohms	Acc
3	8	>100Gohm	> 10 Megohms	Acc
3	9	>100Gohm	> 10 Megohms	Acc
3	10	>100Gohm	> 10 Megohms	Acc
3	11	>100Gohm	> 10 Megohms	Acc
3	12	>100Gohm	> 10 Megohms	Acc
3	13	>100Gohm	> 10 Megohms	Acc
3	14	>100Gohm	> 10 Megohms	Acc
4	5	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100 Gohm	> 10 Megohms	Acc
12	14	>100 Gohm	> 10 Megohms	Acc
13	14	>100 Gohm	> 10 Megohms	Acc
1	Ground	>100 Gohm	> 10 Megohms	Acc
2	Ground	>100 Gohm	> 10 Megohms	Acc
3	Ground	>100 Gohm	> 10 Megohms	Acc
4	Ground	>100 Gohm	> 10 Megohms	Acc
5	Ground	>100 Gohm	> 10 Megohms	Acc
6	Ground	>100 Gohm	> 10 Megohms	Acc
7	Ground	>100 Gohm	> 10 Megohms	Acc
8	Ground	>100 Gohm	> 10 Megohms	Acc
9	Ground	>100 Gohm	> 10 Megohms	Acc
10	Ground	>100 Gohm	> 10 Megohms	Acc
11	Ground	>100 Gohm	> 10 Megohms	Acc
12	Ground	>100 Gohm	> 10 Megohms	Acc
13	Ground	>100 Gohm	> 10 Megohms	Acc
14	Ground	>100 Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground				
Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100 Gohm	> 10 Megohms	Acc
1-9	3-11	>100 Gohm	> 10 Megohms	Acc
1-9	4-12	>100 Gohm	> 10 Megohms	Acc
2-10	3-11	>100 Gohm	> 10 Megohms	Acc
2-10	4-12	>100 Gohm	> 10 Megohms	Acc
3-11	4-12	>100 Gohm	> 10 Megohms	Acc
5	6	>100 Gohm	> 10 Megohms	Acc
6	7	>100 Gohm	> 10 Megohms	Acc
7	8	>100 Gohm	> 10 Megohms	Acc
1-9	Ground	>100 Gohm	> 10 Megohms	Acc
2-10	Ground	>100 Gohm	> 10 Megohms	Acc
3-11	Ground	>100 Gohm	> 10 Megohms	Acc
4-12	Ground	>100 Gohm	> 10 Megohms	Acc
5	Ground	>100 Gohm	> 10 Megohms	Acc
6	Ground	>100 Gohm	> 10 Megohms	Acc
7	Ground	>100 Gohm	> 10 Megohms	Acc
8	Ground	>100 Gohm	> 10 Megohms	Acc
13	Ground	>100 Gohm	> 10 Megohms	Acc
14	Ground	>100 Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	71.319 VAC	96 VAC maximum	Acc
Drop-out Voltage	57.334 VAC	36 AC minimum	Acc

2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

2.4.1 Setup the Relay specimen for contact rating testing.

2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1163 VAC	< 0.5 Volts AC drop	Acc
2-10	.1325 VAC	< 0.5 Volts AC drop	Acc
3-11	.1205 VAC	< 0.5 Volts AC drop	Acc
4-12	.1278 VAC	< 0.5 Volts AC drop	Acc

2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1154 VAC	< 0.5 Volts AC drop	Acc
6-10	.1538 VAC	< 0.5 Volts AC drop	Acc
7-11	.1273 VAC	< 0.5 Volts AC drop	Acc
8-12	.1478 VAC	< 0.5 Volts AC drop	Acc

2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the relay and verify re-land in accordance with the Lifted Lead Log.

2.5.2 Record: Date /Time of Test End: 03-30-00 2:42 p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable

Michael Cram
03-30-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-30-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Lang Swenson Date: 3/30/00

QA/QC (signature) Stephen Scott Moss Date: 4-6-2000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
13-33066	1	2) 5103x	PGEX	5	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00
		5106x		6	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00
		6208x		7	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00
		5102x		9	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00
		5105x		10	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00
		6207x		11	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00
		17A02x		13	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00
		Grey	RCS2A-6	13	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00
		Black	" "	14	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00
		2) 102x		14	DKY	3-30-00	SLC	3-30-00	DKY	3-30-00	SLC	3-30-00

Remarks:

SNF-6315, Rev. 0

Page 177

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020C Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	<b style="font-size: 2em;">ORIGINAL Rev. No. 0 Page 1 of 9
--	--

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

JWP Craig Swenson Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MCE
Electrician	DAN K YORK	PCE	<i>Dan K York</i>	DKY
Electrician Quality Control	Stephen R. Cowley	PE	<i>Stephen R. Cowley</i>	SRC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
→ 7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

- 1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MW15	Select from List provided above	Acc
Manufacturer:	Idec	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

- 2.0 Perform the following testing steps:

- 2.1 Record: Date /Time of Test Beginning: 03-31-00 8:15am

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>100Gohm	> 10 Megohms	Acc
1	3	>100Gohm	> 10 Megohms	Acc
1	4	>100Gohm	> 10 Megohms	Acc
1	5	>100Gohm	> 10 Megohms	Acc
1	6	>100Gohm	> 10 Megohms	Acc
1	7	>100Gohm	> 10 Megohms	Acc
1	8	>100Gohm	> 10 Megohms	Acc
1	9	>100Gohm	> 10 Megohms	Acc
1	10	>100Gohm	> 10 Megohms	Acc
1	11	>100Gohm	> 10 Megohms	Acc
1	12	>100Gohm	> 10 Megohms	Acc
1	13	>100Gohm	> 10 Megohms	Acc
1	14	>100Gohm	> 10 Megohms	Acc
2	3	>100Gohm	> 10 Megohms	Acc
2	4	>100Gohm	> 10 Megohms	Acc
2	5	>100Gohm	> 10 Megohms	Acc
2	6	>100Gohm	> 10 Megohms	Acc
2	7	>100Gohm	> 10 Megohms	Acc
2	8	>100Gohm	> 10 Megohms	Acc
2	9	>100Gohm	> 10 Megohms	Acc
2	10	>100Gohm	> 10 Megohms	Acc
2	11	>100Gohm	> 10 Megohms	Acc
2	12	>100Gohm	> 10 Megohms	Acc
2	13	>100Gohm	> 10 Megohms	Acc
2	14	>100Gohm	> 10 Megohms	Acc
3	4	>100Gohm	> 10 Megohms	Acc
3	5	>100Gohm	> 10 Megohms	Acc
3	6	>100Gohm	> 10 Megohms	Acc
3	7	>100Gohm	> 10 Megohms	Acc
3	8	>100Gohm	> 10 Megohms	Acc
3	9	>100Gohm	> 10 Megohms	Acc
3	10	>100Gohm	> 10 Megohms	Acc
3	11	>100Gohm	> 10 Megohms	Acc
3	12	>100Gohm	> 10 Megohms	Acc
3	13	>100Gohm	> 10 Megohms	Acc
3	14	>100Gohm	> 10 Megohms	Acc
4	5	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	76.036 VAC	96 VAC maximum	Acc
Drop-out Voltage	58.585 VAC	36 AC minimum	Acc

2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

2.4.1 Setup the Relay specimen for contact rating testing.

2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1302 VAC	< 0.5 Volts AC drop	Acc
2-10	.1177 VAC	< 0.5 Volts AC drop	Acc
3-11	.1307 VAC	< 0.5 Volts AC drop	Acc
4-12	.1224 VAC	< 0.5 Volts AC drop	Acc

2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1456 VAC	< 0.5 Volts AC drop	Acc
6-10	.1422 VAC	< 0.5 Volts AC drop	Acc
7-11	.1402 VAC	< 0.5 Volts AC drop	Acc
8-12	.1279 VAC	< 0.5 Volts AC drop	Acc

2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the relay and verify reband in accordance with the Lifted Lead Log.

2.5.2 Record: Date /Time of Test End: 03-31-00 8:50 a.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable
Michael Cram
03-31-00

Notes:

[Blank lined area for notes]

Certified Instrumentation Technician (signature) Michael Cram Date: 03-31-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Wraig Swensen Date: 4/3/00

QA/QC (signature) Stephen Scott Mon Date: 4-6-2000

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020C Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	ORIGINAL Rev. No. 0 Page 1 of 9
--	---

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date:

3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	Michael Cram	MCE
Electrician	DAN K YORK	PCE	Dan K. York	DKY
Electrician Quality Control	Stephen R. Cowley	PE	Stephen R. Cowley	SRC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM 80/2 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

- 1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	BF	Select from List provided above	Acc
Manufacturer:	Idec	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

- 2.0 Perform the following testing steps:

- 2.1 Record: Date /Time of Test Beginning: 03-31-00 9:00 a.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>100Gohm	> 10 Megohms	Acc
1	3	>100Gohm	> 10 Megohms	Acc
1	4	>100Gohm	> 10 Megohms	Acc
1	5	>100Gohm	> 10 Megohms	Acc
1	6	>100Gohm	> 10 Megohms	Acc
1	7	>100Gohm	> 10 Megohms	Acc
1	8	>100Gohm	> 10 Megohms	Acc
1	9	>100Gohm	> 10 Megohms	Acc
1	10	>100Gohm	> 10 Megohms	Acc
1	11	>100Gohm	> 10 Megohms	Acc
1	12	>100Gohm	> 10 Megohms	Acc
1	13	>100Gohm	> 10 Megohms	Acc
1	14	>100Gohm	> 10 Megohms	Acc
2	3	>100Gohm	> 10 Megohms	Acc
2	4	>100Gohm	> 10 Megohms	Acc
2	5	>100Gohm	> 10 Megohms	Acc
2	6	>100Gohm	> 10 Megohms	Acc
2	7	>100Gohm	> 10 Megohms	Acc
2	8	>100Gohm	> 10 Megohms	Acc
2	9	>100Gohm	> 10 Megohms	Acc
2	10	>100Gohm	> 10 Megohms	Acc
2	11	>100Gohm	> 10 Megohms	Acc
2	12	>100Gohm	> 10 Megohms	Acc
2	13	>100Gohm	> 10 Megohms	Acc
2	14	>100Gohm	> 10 Megohms	Acc
3	4	>100Gohm	> 10 Megohms	Acc
3	5	>100Gohm	> 10 Megohms	Acc
3	6	>100Gohm	> 10 Megohms	Acc
3	7	>100Gohm	> 10 Megohms	Acc
3	8	>100Gohm	> 10 Megohms	Acc
3	9	>100Gohm	> 10 Megohms	Acc
3	10	>100Gohm	> 10 Megohms	Acc
3	11	>100Gohm	> 10 Megohms	Acc
3	12	>100Gohm	> 10 Megohms	Acc
3	13	>100Gohm	> 10 Megohms	Acc
3	14	>100Gohm	> 10 Megohms	Acc
4	5	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Acc ~~Acc~~ NR 03-31-00

Dedication Test Plan -- IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

- 2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	77.757 VAC	96 VAC maximum	Acc
Drop-out Voltage	62.502 VAC	36 AC minimum	Acc

- 2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

- 2.4.1 Setup the Relay specimen for contact rating testing.

- 2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1236 VAC	< 0.5 Volts AC drop	Acc
2-10	.1152 VAC	< 0.5 Volts AC drop	Acc
3-11	.1260 VAC	< 0.5 Volts AC drop	Acc
4-12	.1121 VAC	< 0.5 Volts AC drop	Acc

- 2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

- 2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1301 VAC	< 0.5 Volts AC drop	Acc
6-10	.1170 VAC	< 0.5 Volts AC drop	Acc
7-11	.1362 VAC	< 0.5 Volts AC drop	Acc
8-12	.1774 VAC	< 0.5 Volts AC drop	Acc

- 2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

- 2.5.1 Reland the relay and verify reband in accordance with the Lifted Lead Log.

- 2.5.2 Record: Date /Time of Test End: 03-31-00 9:35 a.m.

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-020-TP-020C	
Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable.

Michael Cram

03-31-00

Notes:

Certified Instrumentation Technician (signature) *Michael Cram* Date: *03-31-00*

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *Wang Swenson* Date: *4/3/00*

QA/QC (signature) *Stephen Scott Mason* Date: *4-6-2000*

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020C Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	ORIGINAL
Rev. No. 0	Page 1 of 9

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

• QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date:

3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	Michael Cram	MCC
Electrician	DAN K YORK	PCR	Dan K. York	DKY
Electrician Quality Control	Stephen R. Conley	PCE	Stephen R. Conley	SRC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: HP 3457A I.D.: BAT 12A Calib. Due date: 07-30-00Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	BSC1AX	Select from List provided above	Acc
Manufacturer:	OK	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-31-00 9:52 a.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>100Gohm	> 10 Megohms	Acc
1	3	>100Gohm	> 10 Megohms	Acc
1	4	>100Gohm	> 10 Megohms	Acc
1	5	>100Gohm	> 10 Megohms	Acc
1	6	>100Gohm	> 10 Megohms	Acc
1	7	>100Gohm	> 10 Megohms	Acc
1	8	>100Gohm	> 10 Megohms	Acc
1	9	>100Gohm	> 10 Megohms	Acc
1	10	>100Gohm	> 10 Megohms	Acc
1	11	>100Gohm	> 10 Megohms	Acc
1	12	>100Gohm	> 10 Megohms	Acc
1	13	>100Gohm	> 10 Megohms	Acc
1	14	>100Gohm	> 10 Megohms	Acc
2	3	>100Gohm	> 10 Megohms	Acc
2	4	>100Gohm	> 10 Megohms	Acc
2	5	>100Gohm	> 10 Megohms	Acc
2	6	>100Gohm	> 10 Megohms	Acc
2	7	>100Gohm	> 10 Megohms	Acc
2	8	>100Gohm	> 10 Megohms	Acc
2	9	>100Gohm	> 10 Megohms	Acc
2	10	>100Gohm	> 10 Megohms	Acc
2	11	>100Gohm	> 10 Megohms	Acc
2	12	>100Gohm	> 10 Megohms	Acc
2	13	>100Gohm	> 10 Megohms	Acc
2	14	>100Gohm	> 10 Megohms	Acc
3	4	>100Gohm	> 10 Megohms	Acc
3	5	>100Gohm	> 10 Megohms	Acc
3	6	>100Gohm	> 10 Megohms	Acc
3	7	>100Gohm	> 10 Megohms	Acc
3	8	>100Gohm	> 10 Megohms	Acc
3	9	>100Gohm	> 10 Megohms	Acc
3	10	>100Gohm	> 10 Megohms	Acc
3	11	>100Gohm	> 10 Megohms	Acc
3	12	>100Gohm	> 10 Megohms	Acc
3	13	>100Gohm	> 10 Megohms	Acc
3	14	>100Gohm	> 10 Megohms	Acc
4	5	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	> 100 Gohms	> 10 Megohms	Acc
4	7	> 100 Gohms	> 10 Megohms	Acc
4	8	> 100 Gohms	> 10 Megohms	Acc
4	9	> 100 Gohms	> 10 Megohms	Acc
4	10	> 100 Gohms	> 10 Megohms	Acc
4	11	> 100 Gohm	> 10 Megohms	Acc
4	12	> 100 Gohm	> 10 Megohms	Acc
4	13	> 100 Gohm	> 10 Megohms	Acc
4	14	> 100 Gohm	> 10 Megohms	Acc
5	6	> 100 Gohm	> 10 Megohms	Acc
5	7	> 100 Gohm	> 10 Megohms	Acc
5	8	> 100 Gohm	> 10 Megohms	Acc
5	8	> 100 Gohm	> 10 Megohms	Acc
5	10	> 100 Gohm	> 10 Megohms	Acc
5	11	> 100 Gohm	> 10 Megohms	Acc
5	12	> 100 Gohm	> 10 Megohms	Acc
5	13	> 100 Gohm	> 10 Megohms	Acc
5	14	> 100 Gohm	> 10 Megohms	Acc
6	7	> 100 Gohm	> 10 Megohms	Acc
6	8	> 100 Gohm	> 10 Megohms	Acc
6	9	> 100 Gohm	> 10 Megohms	Acc
6	10	> 100 Gohm	> 10 Megohms	Acc
6	11	> 100 Gohm	> 10 Megohms	Acc
6	12	> 100 Gohm	> 10 Megohms	Acc
6	12	> 100 Gohm	> 10 Megohms	Acc
6	14	> 100 Gohm	> 10 Megohms	Acc
7	8	> 100 Gohm	> 10 Megohms	Acc
7	9	> 100 Gohm	> 10 Megohms	Acc
7	10	> 100 Gohm	> 10 Megohms	Acc
7	11	> 100 Gohm	> 10 Megohms	Acc
7	12	> 100 Gohm	> 10 Megohms	Acc
7	13	> 100 Gohm	> 10 Megohms	Acc
7	14	> 100 Gohm	> 10 Megohms	Acc
8	9	> 100 Gohm	> 10 Megohms	Acc
8	10	> 100 Gohm	> 10 Megohms	Acc
8	11	> 100 Gohm	> 10 Megohms	Acc
8	12	> 100 Gohm	> 10 Megohms	Acc
8	13	> 100 Gohm	> 10 Megohms	Acc
8	14	> 100 Gohm	> 10 Megohms	Acc
9	10	> 100 Gohm	> 10 Megohms	Acc
9	11	> 100 Gohm	> 10 Megohms	Acc
9	12	> 100 Gohm	> 10 Megohms	Acc
9	13	> 100 Gohm	> 10 Megohms	Acc
9	14	> 100 Gohm	> 10 Megohms	Acc
10	11	> 100 Gohm	> 10 Megohms	Acc
10	12	> 100 Gohm	> 10 Megohms	Acc
10	13	> 100 Gohm	> 10 Megohms	Acc
10	14	> 100 Gohm	> 10 Megohms	Acc
11	12	> 100 Gohm	> 10 Megohms	Acc
11	13	> 100 Gohm	> 10 Megohms	Acc
11	14	> 100 Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground				
Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	67.152 VAC	96 VAC maximum	Acc
Drop-out Voltage	43.416 VAC	36 AC minimum	Acc

2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

2.4.1 Setup the Relay specimen for contact rating testing.

2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1163 VAC	< 0.5 Volts AC drop	Acc
2-10	.1189 VAC	< 0.5 Volts AC drop	Acc
3-11	.1298 VAC	< 0.5 Volts AC drop	Acc
4-12	.1025 VAC	< 0.5 Volts AC drop	Acc

2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1153 VAC	< 0.5 Volts AC drop	Acc
6-10	.1185 VAC	< 0.5 Volts AC drop	Acc
7-11	.1270 VAC	< 0.5 Volts AC drop	Acc
8-12	.1804 VAC	< 0.5 Volts AC drop	Acc

2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the relay and verify reland in accordance with the Lifted Lead Log.

2.5.2 Record: Date /Time of Test End: 03-31-00 11:00 a.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable
Michael Cram
03-31-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-31-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Ray Swenson Date: 4/3/00

QA/QC (signature) Stephen Scott Mose Date: 4-6-2000

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

ORIGINAL

Rev. No. 0

Page 1 of 9

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	Michael Cram	MCC
Electrician	DAN K YORK	PCE	Dan K York	DKY
Electrician Quality Control	Stephen R. Cowley	PCE	Stephen R. Cowley	SRC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BMS0/2 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: FLOKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

- 1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TSP1FIX	Select from List provided above	Acc
Manufacturer:	OK	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	SL	SH4B-05	Acc

- 2.0 Perform the following testing steps:

- 2.1 Record: Date /Time of Test Beginning: 04-03-00 11:45 a.m.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>100Gohm	> 10 Megohms	Acc
1	3	>100Gohm	> 10 Megohms	Acc
1	4	>100Gohm	> 10 Megohms	Acc
1	5	>100Gohm	> 10 Megohms	Acc
1	6	>100Gohm	> 10 Megohms	Acc
1	7	>100Gohm	> 10 Megohms	Acc
1	8	>100Gohm	> 10 Megohms	Acc
1	9	>100Gohm	> 10 Megohms	Acc
1	10	>100Gohm	> 10 Megohms	Acc
1	11	>100Gohm	> 10 Megohms	Acc
1	12	>100Gohm	> 10 Megohms	Acc
1	13	>100Gohm	> 10 Megohms	Acc
1	14	>100Gohm	> 10 Megohms	Acc
2	3	>100Gohm	> 10 Megohms	Acc
2	4	>100Gohm	> 10 Megohms	Acc
2	5	>100Gohm	> 10 Megohms	Acc
2	6	>100Gohm	> 10 Megohms	Acc
2	7	>100Gohm	> 10 Megohms	Acc
2	8	>100Gohm	> 10 Megohms	Acc
2	9	>100Gohm	> 10 Megohms	Acc
2	10	>100Gohm	> 10 Megohms	Acc
2	11	>100Gohm	> 10 Megohms	Acc
2	12	>100Gohm	> 10 Megohms	Acc
2	13	>100Gohm	> 10 Megohms	Acc
2	14	>100Gohm	> 10 Megohms	Acc
3	4	>100Gohm	> 10 Megohms	Acc
3	5	>100Gohm	> 10 Megohms	Acc
3	6	>100Gohm	> 10 Megohms	Acc
3	7	>100Gohm	> 10 Megohms	Acc
3	8	>100Gohm	> 10 Megohms	Acc
3	9	>100Gohm	> 10 Megohms	Acc
3	10	>100Gohm	> 10 Megohms	Acc
3	11	>100Gohm	> 10 Megohms	Acc
3	12	>100Gohm	> 10 Megohms	Acc
3	13	>100Gohm	> 10 Megohms	Acc
3	14	>100Gohm	> 10 Megohms	Acc
4	5	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground				
Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	73.283 VAC	96 VAC maximum	Acc
Drop-out Voltage	50.783	36 AC minimum	Acc

2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

2.4.1 Setup the Relay specimen for contact rating testing.

2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1237 VAC	< 0.5 Volts AC drop	Acc
2-10	.1362 VAC	< 0.5 Volts AC drop	Acc
3-11	.1187 VAC	< 0.5 Volts AC drop	Acc
4-12	.1045 VAC	< 0.5 Volts AC drop	Acc

2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1214 VAC	< 0.5 Volts AC drop	Acc
6-10	.1136 VAC	< 0.5 Volts AC drop	Acc
7-11	.1253 VAC	< 0.5 Volts AC drop	Acc
8-12	.1455 VAC	< 0.5 Volts AC drop	Acc

2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the relay and verify reband in accordance with the Lifted Lead Log.

2.5.2 Record: Date /Time of Test End: 04-03-00 1 p.m.

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-020-TP-020C	
Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Test was acceptable
Michael Cram
04-03-00

Notes:

Certified Instrumentation Technician (signature) *Michael Cram* Date: 04-03-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *Craig Swenson* Date: 4/3/00

QA/QC (signature) *Stephen Scott Moss* Date: 4-6-2000

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date:

3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	Michael Cram	MRC
Electrician	DAN K YORK	PCB	Dan K York	DKY
Electrician Quality Control	Stephen R. Cowley	RE	Stephen R. Cowley	SR
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO BM802 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: HP3457A I.D.: BAT 124 Calib. Due date: 07-30-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY - personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1



TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TRD	Select from List provided above	Acc
Manufacturer:	OK	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 04-03-00 1:10 p.m.

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>100Gohm	> 10 Megohms	Acc
1	3	>100Gohm	> 10 Megohms	Acc
1	4	>100Gohm	> 10 Megohms	Acc
1	5	>100Gohm	> 10 Megohms	Acc
1	6	>100Gohm	> 10 Megohms	Acc
1	7	>100Gohm	> 10 Megohms	Acc
1	8	>100Gohm	> 10 Megohms	Acc
1	9	>100Gohm	> 10 Megohms	Acc
1	10	>100Gohm	> 10 Megohms	Acc
1	11	>100Gohm	> 10 Megohms	Acc
1	12	>100Gohm	> 10 Megohms	Acc
1	13	>100Gohm	> 10 Megohms	Acc
1	14	>100Gohm	> 10 Megohms	Acc
2	3	>100Gohm	> 10 Megohms	Acc
2	4	>100Gohm	> 10 Megohms	Acc
2	5	>100Gohm	> 10 Megohms	Acc
2	6	>100Gohm	> 10 Megohms	Acc
2	7	>100Gohm	> 10 Megohms	Acc
2	8	>100Gohm	> 10 Megohms	Acc
2	9	>100Gohm	> 10 Megohms	Acc
2	10	>100Gohm	> 10 Megohms	Acc
2	11	>100Gohm	> 10 Megohms	Acc
2	12	>100Gohm	> 10 Megohms	Acc
2	13	>100Gohm	> 10 Megohms	Acc
2	14	>100Gohm	> 10 Megohms	Acc
3	4	>100Gohm	> 10 Megohms	Acc
3	5	>100Gohm	> 10 Megohms	Acc
3	6	>100Gohm	> 10 Megohms	Acc
3	7	>100Gohm	> 10 Megohms	Acc
3	8	>100Gohm	> 10 Megohms	Acc
3	9	>100Gohm	> 10 Megohms	Acc
3	10	>100Gohm	> 10 Megohms	Acc
3	11	>100Gohm	> 10 Megohms	Acc
3	12	>100Gohm	> 10 Megohms	Acc
3	13	>100Gohm	> 10 Megohms	Acc
3	14	>100Gohm	> 10 Megohms	Acc
4	5	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohms	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohms	> 10 Megohms	Acc
4	12	>100Gohms	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohms	> 10 Megohms	Acc
5	6	>100Gohms	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohms	> 10 Megohms	Acc
5	8	>100Gohms	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohms	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohms	> 10 Megohms	Acc
6	12	>100Gohms	> 10 Megohms	Acc
6	12	>100Gohms	> 10 Megohms	Acc
6	14	>100Gohms	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohms	> 10 Megohms	Acc
8	10	>100Gohms	> 10 Megohms	Acc
8	11	>100Gohms	> 10 Megohms	Acc
8	12	>100Gohms	> 10 Megohms	Acc
8	13	>100Gohms	> 10 Megohms	Acc
8	14	>100Gohms	> 10 Megohms	Acc
9	10	>100Gohms	> 10 Megohms	Acc
9	11	>100Gohms	> 10 Megohms	Acc
9	12	>100Gohms	> 10 Megohms	Acc
9	13	>100Gohms	> 10 Megohms	Acc
9	14	>100Gohms	> 10 Megohms	Acc
10	11	>100Gohms	> 10 Megohms	Acc
10	12	>100Gohms	> 10 Megohms	Acc
10	13	>100Gohms	> 10 Megohms	Acc
10	14	>100Gohms	> 10 Megohms	Acc
11	12	>100Gohms	> 10 Megohms	Acc
11	13	>100Gohms	> 10 Megohms	Acc
11	14	>100Gohms	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

- 2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	75.521 VAC	96 VAC maximum	Acc
Drop-out Voltage	55.823	36 AC minimum	Acc

- 2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

- 2.4.1 Setup the Relay specimen for contact rating testing.

- 2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1056 VAC	< 0.5 Volts AC drop	Acc
2-10	.1088 VAC	< 0.5 Volts AC drop	Acc
3-11	.1089 VAC	< 0.5 Volts AC drop	Acc
4-12	.1237 VAC	< 0.5 Volts AC drop	Acc

- 2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

- 2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1262 VAC	< 0.5 Volts AC drop	Acc
6-10	.1188 VAC	< 0.5 Volts AC drop	Acc
7-11	.1301 VAC	< 0.5 Volts AC drop	Acc
8-12	.1281 VAC	< 0.5 Volts AC drop	Acc

- 2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

- 2.5.1 Reland the relay and verify reland in accordance with the Lifted Lead Log.

- 2.5.2 Record: Date /Time of Test End: 04-03-00 1:30 p.m.

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020C Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	Rev. No. 0 Page 8 of 9
---	---

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable
Michael Cran
04-03-00

Notes:

Certified Instrumentation Technician (signature) Michael Cran Date: 04-03-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Leung Swenson Date: 4/3/00

QA/QC (signature) Stephen Scott Moss Date: 4-6-2000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
68-33068	1	25A02X	TRD	5	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00
		25A42X		7	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00
		2703X		8	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00
		25A03X		9	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00
		25A3X		11	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00
		2) 101X		12	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00
		25A20X		13	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00
		Black	RC52A-6	13	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00
		Grey	RC52A-6	14	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00
		2) 102X	TRD	14	DKY	4-3-00	SRC	4-3-00	DKY	4-3-00	SRC	4-3-00

Remarks:

SNF-6315, Rev. 0

Page 202

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020C Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	<div style="font-size: 2em; font-weight: bold; margin-bottom: 5px;">ORIGINAL</div> Rev. No. 0 Page 1 of 9
--	--

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

JWP Craig Swenson Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MRC
Electrician	DAN K YORK	PCE	<i>Dan K. York</i>	DKY
Electrician Quality Control	Stephen R. Conley	PE	<i>Stephen R. Conley</i>	SRC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01

Test Instrument type: HP 3457A I.D.: BAT 12A Calib. Due date: 07-30-00

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
→ 12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MCOY(2)	Select from List provided above	Acc
Manufacturer:	OK	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-31-00 11:05 a.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
1	2	>100 Gohm	> 10 Megohms	Acc
1	3	>100 Gohm	> 10 Megohms	Acc
1	4	>100 Gohm	> 10 Megohms	Acc
1	5	>100 Gohm	> 10 Megohms	Acc
1	6	>100 Gohm	> 10 Megohms	Acc
1	7	>100 Gohm	> 10 Megohms	Acc
1	8	>100 Gohm	> 10 Megohms	Acc
1	9	>100 Gohm	> 10 Megohms	Acc
1	10	>100 Gohm	> 10 Megohms	Acc
1	11	>100 Gohm	> 10 Megohms	Acc
1	12	>100 Gohm	> 10 Megohms	Acc
1	13	>100 Gohm	> 10 Megohms	Acc
1	14	>100 Gohm	> 10 Megohms	Acc
2	3	>100 Gohm	> 10 Megohms	Acc
2	4	>100 Gohm	> 10 Megohms	Acc
2	5	>100 Gohm	> 10 Megohms	Acc
2	6	>100 Gohm	> 10 Megohms	Acc
2	7	>100 Gohm	> 10 Megohms	Acc
2	8	>100 Gohm	> 10 Megohms	Acc
2	9	>100 Gohm	> 10 Megohms	Acc
2	10	>100 Gohm	> 10 Megohms	Acc
2	11	>100 Gohm	> 10 Megohms	Acc
2	12	>100 Gohm	> 10 Megohms	Acc
2	13	>100 Gohm	> 10 Megohms	Acc
2	14	>100 Gohm	> 10 Megohms	Acc
3	4	>100 Gohm	> 10 Megohms	Acc
3	5	>100 Gohm	> 10 Megohms	Acc
3	6	>100 Gohm	> 10 Megohms	Acc
3	7	>100 Gohm	> 10 Megohms	Acc
3	8	>100 Gohm	> 10 Megohms	Acc
3	9	>100 Gohm	> 10 Megohms	Acc
3	10	>100 Gohm	> 10 Megohms	Acc
3	11	>100 Gohm	> 10 Megohms	Acc
3	12	>100 Gohm	> 10 Megohms	Acc
3	13	>100 Gohm	> 10 Megohms	Acc
3	14	>100 Gohm	> 10 Megohms	Acc
4	5	>100 Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground				
Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

- 2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	72.951 VAC	96 VAC maximum	Acc
Drop-out Voltage	55.802 VAC	36 AC minimum	Acc

- 2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

- 2.4.1 Setup the Relay specimen for contact rating testing.

- 2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1099 VAC	< 0.5 Volts AC drop	Acc
2-10	.1227 VAC	< 0.5 Volts AC drop	Acc
3-11	.1132 VAC	< 0.5 Volts AC drop	Acc
4-12	.1284 VAC	< 0.5 Volts AC drop	Acc

- 2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

- 2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1335 VAC	< 0.5 Volts AC drop	Acc
6-10	.1195 VAC	< 0.5 Volts AC drop	Acc
7-11	.1293 VAC	< 0.5 Volts AC drop	Acc
8-12	.1078 VAC	< 0.5 Volts AC drop	Acc

- 2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

- 2.5.1 Reland the relay and verify reband in accordance with the Lifted Lead Log.

- 2.5.2 Record: Date /Time of Test End: 03-31-00 11:30 a.m.

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-020-TP-020C	
Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable

Michael Cram
03-31-00

Notes:

Certified Instrumentation Technician (signature) *Michael Cram* Date: 03-31-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *Gary Swenson* Date: 4/3/00

QA/QC (signature) *Stephen Scott Moss* Date: 4-6-2000

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020C Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	<b style="font-size: 2em;">ORIGINAL	Rev. No. 0 Page 1 of 9
--	---	-------------------------------

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	MICHAEL CRAM	Belhaven	Michael Cram	MRE
Electrician	DAN K YORK	PCE	Dan K. York	DKY
Electrician Quality Control	Stephen R. Couley	RE	Stephen R. Couley	SEC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: Avo BM8012 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

- 1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	MGCLY	Select from List provided above	Acc
Manufacturer:	OK	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

- 2.0 Perform the following testing steps:

- 2.1 Record: Date /Time of Test Beginning: 03-31-00 11:50 a.m.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the **Relay Socket** specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground		Record Data	Acceptance Criteria	Comments/Deviations
Desc. of Terminal	Desc. of Terminal/Ground			
1	2	> 100 Gohm	> 10 Megohms	Acc
1	3	> 100 Gohm	> 10 Megohms	Acc
1	4	> 100 Gohm	> 10 Megohms	Acc
1	5	> 100 Gohm	> 10 Megohms	Acc
1	6	> 100 Gohm	> 10 Megohms	Acc
1	7	> 100 Gohm	> 10 Megohms	Acc
1	8	> 100 Gohm	> 10 Megohms	Acc
1	9	> 100 Gohm	> 10 Megohms	Acc
1	10	> 100 Gohm	> 10 Megohms	Acc
1	11	> 100 Gohm	> 10 Megohms	Acc
1	12	> 100 Gohm	> 10 Megohms	Acc
1	13	> 100 Gohm	> 10 Megohms	Acc
1	14	> 100 Gohm	> 10 Megohms	Acc
2	3	> 100 Gohm	> 10 Megohms	Acc
2	4	> 100 Gohm	> 10 Megohms	Acc
2	5	> 100 Gohm	> 10 Megohms	Acc
2	6	> 100 Gohm	> 10 Megohms	Acc
2	7	> 100 Gohm	> 10 Megohms	Acc
2	8	> 100 Gohm	> 10 Megohms	Acc
2	9	> 100 Gohm	> 10 Megohms	Acc
2	10	> 100 Gohm	> 10 Megohms	Acc
2	11	> 100 Gohm	> 10 Megohms	Acc
2	12	> 100 Gohm	> 10 Megohms	Acc
2	13	> 100 Gohm	> 10 Megohms	Acc
2	14	> 100 Gohm	> 10 Megohms	Acc
3	4	> 100 Gohm	> 10 Megohms	Acc
3	5	> 100 Gohm	> 10 Megohms	Acc
3	6	> 100 Gohm	> 10 Megohms	Acc
3	7	> 100 Gohm	> 10 Megohms	Acc
3	8	> 100 Gohm	> 10 Megohms	Acc
3	9	> 100 Gohm	> 10 Megohms	Acc
3	10	> 100 Gohm	> 10 Megohms	Acc
3	11	> 100 Gohm	> 10 Megohms	Acc
3	12	> 100 Gohm	> 10 Megohms	Acc
3	13	> 100 Gohm	> 10 Megohms	Acc
3	14	> 100 Gohm	> 10 Megohms	Acc
4	5	> 100 Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	> 100Gohm	> 10 Megohms	Acc
4	7	> 100Gohm	> 10 Megohms	Acc
4	8	> 100Gohm	> 10 Megohms	Acc
4	9	> 100Gohm	> 10 Megohms	Acc
4	10	> 100Gohm	> 10 Megohms	Acc
4	11	> 100Gohm	> 10 Megohms	Acc
4	12	> 100Gohm	> 10 Megohms	Acc
4	13	> 100Gohm	> 10 Megohms	Acc
4	14	> 100Gohm	> 10 Megohms	Acc
5	6	> 100Gohm	> 10 Megohms	Acc
5	7	> 100Gohm	> 10 Megohms	Acc
5	8	> 100Gohm	> 10 Megohms	Acc
5	8	> 100Gohm	> 10 Megohms	Acc
5	10	> 100Gohm	> 10 Megohms	Acc
5	11	> 100Gohm	> 10 Megohms	Acc
5	12	> 100Gohm	> 10 Megohms	Acc
5	13	> 100Gohm	> 10 Megohms	Acc
5	14	> 100Gohm	> 10 Megohms	Acc
6	7	> 100Gohm	> 10 Megohms	Acc
6	8	> 100Gohm	> 10 Megohms	Acc
6	9	> 100Gohm	> 10 Megohms	Acc
6	10	> 100Gohm	> 10 Megohms	Acc
6	11	> 100Gohm	> 10 Megohms	Acc
6	12	> 100Gohm	> 10 Megohms	Acc
6	12	> 100Gohm	> 10 Megohms	Acc
6	14	> 100Gohm	> 10 Megohms	Acc
7	8	> 100Gohm	> 10 Megohms	Acc
7	9	> 100Gohm	> 10 Megohms	Acc
7	10	> 100Gohm	> 10 Megohms	Acc
7	11	> 100Gohm	> 10 Megohms	Acc
7	12	> 100Gohm	> 10 Megohms	Acc
7	13	> 100Gohm	> 10 Megohms	Acc
7	14	> 100Gohm	> 10 Megohms	Acc
8	9	> 100Gohm	> 10 Megohms	Acc
8	10	> 100Gohm	> 10 Megohms	Acc
8	11	> 100Gohm	> 10 Megohms	Acc
8	12	> 100Gohm	> 10 Megohms	Acc
8	13	> 100Gohm	> 10 Megohms	Acc
8	14	> 100Gohm	> 10 Megohms	Acc
9	10	> 100Gohm	> 10 Megohms	Acc
9	11	> 100Gohm	> 10 Megohms	Acc
9	12	> 100Gohm	> 10 Megohms	Acc
9	13	> 100Gohm	> 10 Megohms	Acc
9	14	> 100Gohm	> 10 Megohms	Acc
10	11	> 100Gohm	> 10 Megohms	Acc
10	12	> 100Gohm	> 10 Megohms	Acc
10	13	> 100Gohm	> 10 Megohms	Acc
10	14	> 100Gohm	> 10 Megohms	Acc
11	12	> 100Gohm	> 10 Megohms	Acc
11	13	> 100Gohm	> 10 Megohms	Acc
11	14	> 100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	72.702 VAC	96 VAC maximum	Acc
Drop-out Voltage	51.160 VAC	36 AC minimum	Acc

2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

2.4.1 Setup the Relay specimen for contact rating testing.

2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1387 VAC	< 0.5 Volts AC drop	Acc
2-10	.1081 VAC	< 0.5 Volts AC drop	Acc
3-11	.1181 VAC	< 0.5 Volts AC drop	Acc
4-12	.1046 VAC	< 0.5 Volts AC drop	Acc

2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1393 VAC	< 0.5 Volts AC drop	Acc
6-10	.1251 VAC	< 0.5 Volts AC drop	Acc
7-11	.1258 VAC	< 0.5 Volts AC drop	Acc
8-12	.1074 VAC	< 0.5 Volts AC drop	Acc

2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the relay and verify reland in accordance with the Lifted Lead Log.

2.5.2 Record: Date /Time of Test End: 03-31-00 1:30 p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable.

Michael Cram

03-31-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-31-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Gary Swenson Date: 4/3/00

QA/QC (signature) Stephen Scott Mon Date: 4-6-2000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
E8-33249	1	5126Y	MGCLY	5	DKY	3-31-00	SRC	3-31-00	DKY	3-31-00	SRC	3-31-00
		2)101Y	MGCLY	6	DKY	3-31-00	SRC	3-31-00	DKY	3-31-00	SRC	3-31-00
		5127Y	MGCLY	9	DKY	3-31-00	SRC	3-31-00	DKY	3-31-00	SRC	3-31-00
		2)5908Y	MGCLY	10	DKY	3-31-00	SRC	3-31-00	DKY	3-31-00	SRC	3-31-00
		13A04Y	MGCLY	13	DKY	3-31-00	SRC	3-31-00	DKY	3-31-00	SRC	3-31-00
		Grey	RS2A-6	13	DKY	3-31-00	SRC	3-31-00	DKY	3-31-00	SRC	3-31-00
		Black	"	14	DKY	3-31-00	SRC	3-31-00	DKY	3-31-00	SRC	3-31-00
		2)102Y	MGCLY	14	DKY	3-31-00	SRC	3-31-00	DKY	3-31-00	SRC	3-31-00
Remarks:												

SNF-6315, Rev. 0

Page 240

Dedication Test Plan – IST

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

ORIGINAL

Rev. No. 0

Page 1 of 9

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C


Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 2 of 9

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)



Date: 3/22/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	Michael Cram	MRC
Electrician	DAN K YORK	PCE	Dan K York	DKY
Electrician Quality Control	Stephen R. Conley	RE	Stephen R. Conley	SRC
Design Authority Representative	N/A	N/A	N/A	N/A
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: FLUKE 787 I.D.: BAT 107 Calib. Due date: 05-28-00Test Instrument type: AVO BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: HP 3457A I.D.: BAT 12A Calib. Due date: 07-30-00

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

- 1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHULY (3)	Select from List provided above	Acc
Manufacturer:	OK	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

- 2.0 Perform the following testing steps:

- 2.1 Record:

Date /Time of Test Beginning: 03-31-00 1:40 p.m.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the Relay Socket specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	>100 Gohm	> 10 Megohms	Acc
1	3	>100 Gohm	> 10 Megohms	Acc
1	4	>100 Gohm	> 10 Megohms	Acc
1	5	>100 Gohm	> 10 Megohms	Acc
1	6	>100 Gohm	> 10 Megohms	Acc
1	7	>100 Gohm	> 10 Megohms	Acc
1	8	>100 Gohm	> 10 Megohms	Acc
1	9	>100 Gohm	> 10 Megohms	Acc
1	10	>100 Gohm	> 10 Megohms	Acc
1	11	>100 Gohm	> 10 Megohms	Acc
1	12	>100 Gohm	> 10 Megohms	Acc
1	13	>100 Gohm	> 10 Megohms	Acc
1	14	>100 Gohm	> 10 Megohms	Acc
2	3	>100 Gohm	> 10 Megohms	Acc
2	4	>100 Gohm	> 10 Megohms	Acc
2	5	>100 Gohm	> 10 Megohms	Acc
2	6	>100 Gohm	> 10 Megohms	Acc
2	7	>100 Gohm	> 10 Megohms	Acc
2	8	>100 Gohm	> 10 Megohms	Acc
2	9	>100 Gohm	> 10 Megohms	Acc
2	10	>100 Gohm	> 10 Megohms	Acc
2	11	>100 Gohm	> 10 Megohms	Acc
2	12	>100 Gohm	> 10 Megohms	Acc
2	13	>100 Gohm	> 10 Megohms	Acc
2	14	>100 Gohm	> 10 Megohms	Acc
3	4	>100 Gohm	> 10 Megohms	Acc
3	5	>100 Gohm	> 10 Megohms	Acc
3	6	>100 Gohm	> 10 Megohms	Acc
3	7	>100 Gohm	> 10 Megohms	Acc
3	8	>100 Gohm	> 10 Megohms	Acc
3	9	>100 Gohm	> 10 Megohms	Acc
3	10	>100 Gohm	> 10 Megohms	Acc
3	11	>100 Gohm	> 10 Megohms	Acc
3	12	>100 Gohm	> 10 Megohms	Acc
3	13	>100 Gohm	> 10 Megohms	Acc
3	14	>100 Gohm	> 10 Megohms	Acc
4	5	>100 Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan -- IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	72.588 VAC	96 VAC maximum	Acc
Drop-out Voltage	55.346 VAC	36 AC minimum	Acc

2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

2.4.1 Setup the Relay specimen for contact rating testing.

2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	. 1212 VAC	< 0.5 Volts AC drop	Acc
2-10	. 1245 VAC	< 0.5 Volts AC drop	Acc
3-11	. 1468 VAC	< 0.5 Volts AC drop	Acc
4-12	. 1061 VAC	< 0.5 Volts AC drop	Acc

2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	. 1170 vac	< 0.5 Volts AC drop	Acc
6-10	. 1239 vac	< 0.5 Volts AC drop	Acc
7-11	. 1421 vac	< 0.5 Volts AC drop	Acc
8-12	. 1085	< 0.5 Volts AC drop	Acc

2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the relay and verify reland in accordance with the Lifted Lead Log.

2.5.2 Record: Date /Time of Test End: 03-31-00 2:30 p.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Testing was acceptable

Michael Cram
03-31-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 03-31-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Craig Swenson Date: 4/3/00

QA/QC (signature) Stephen Scott Moss Date: 4-6-2000

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-020-TP-020C Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic	<div style="font-size: 2em; font-weight: bold; margin-bottom: 5px;">ORIGINAL</div> Rev. No. 0 Page 1 of 9
--	--

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

Dedication Test Plan - IST
 Test Plan No.: CGI-SNF-D-MHM-020-TP-020C
 Test Specimen: Idcc RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

In-Situ Test Procedure

ORIGINAL

Test Procedure Approval (Obtain prior to testing):
 This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) *[Signature]*
 Date: 3/22/02

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Gram	Behaven	<i>[Signature]</i>	MEG
Electrician	DAN K YORK	ECF	<i>[Signature]</i>	DKY
Electrician Quality Control	Stephen R. Cowley	FE	<i>[Signature]</i>	SC
Design Authority Representative	Laurey W. Peice	XIKST	<i>[Signature]</i>	LWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Power Supply capable of 10 amps @ 120 VAC.
 Megger Instrument capable of 500 VDC Test Voltage
 Adjustable Voltage Power supply capable of 0 to 120 VAC minimum
 MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance
 Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: AVO BM80/2	I.D.: 6410-889	Calib. Due date: 02-09-01
Test Instrument type: FLUKE 787	I.D.: BAT107	Calib. Due date: 05-28-00
Test Instrument type: HP 3457A	I.D.: BAT124	Calib. Due date: 07-30-00
Test Instrument type:	I.D.:	Calib. Due date:
Test Instrument type:	I.D.:	Calib. Due date:

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 3 of 9

SAFETY INSTRUCTIONS: PERSONNEL SAFETY -- personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

Relay Selection List

No.	Eqmt ID No.	Panel No.	Dwg. Reference
1	P2X(1)	201	ED-33065 Sht. 1
2	P6X(1)	201	ED-33065 Sht. 1
3	IAXM(1)	201	ED-33065 Sht. 1
4	MCO(1)	201	ED-33065 Sht. 1
5	MHF	202	ED-33066 Sht. 1
6	PGEX	202	ED-33066 Sht. 1
7	MW15	202	ED-33066 Sht. 1
8	BF	203	ED-33067 Sht. 1
9	BSC1AX	203	ED-33067 Sht. 1
10	TSP1FIX	204	ED-33068 Sht. 1
11	TRD	204	ED-33068 Sht. 1
12	MCOY(2)	205	ED-33069 Sht. 1
13	MGCLY	205	ED-33069 Sht. 1
14	PHULY(3)	205	ED-33069 Sht. 1
15	PGLY	205	ED-33069 Sht. 1

TEST PROCEDURE:

For this In-Situ Test, the relay and its socket must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of the relay and its socket.

- 1.0 Select a relay from the list above. Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PGLY	Select from List provided above	Acc
Manufacturer:	OK	Idec	Acc
Relay Model:	OK	RH4B-UL-AC120V	Acc
Contact Configuration:	OK	4PDT Contacts	Acc
Socket Model:	OK	SH4B-05	Acc

- 2.0 Perform the following testing steps:

- 2.1 Record:

Date /Time of Test Beginning: 4-3-00 10:40 a.m

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 4 of 9

2.1.1 Complete the Lifted Lead Log prior to removing the plug-in relay and its associated socket.

2.2 Insulation Resistance Test

2.2.1 Setup the **Relay Socket** specimen for insulation resistance testing. Attach Relay Socket in its normal mounting configuration to grounded fixture.

2.2.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay socket test specimen. Record the socket data.

Terminal to Terminal / Ground

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1	2	> 100Gohm	> 10 Megohms	Acc
1	3	> 100Gohm	> 10 Megohms	Acc
1	4	> 100Gohm	> 10 Megohms	Acc
1	5	> 100Gohm	> 10 Megohms	Acc
1	6	> 100Gohm	> 10 Megohms	Acc
1	7	> 100Gohm	> 10 Megohms	Acc
1	8	> 100Gohm	> 10 Megohms	Acc
1	9	> 100Gohm	> 10 Megohms	Acc
1	10	> 100Gohm	> 10 Megohms	Acc
1	11	> 100Gohm	> 10 Megohms	Acc
1	12	> 100Gohm	> 10 Megohms	Acc
1	13	> 100Gohm	> 10 Megohms	Acc
1	14	> 100Gohm	> 10 Megohms	Acc
2	3	> 100Gohm	> 10 Megohms	Acc
2	4	> 100Gohm	> 10 Megohms	Acc
2	5	> 100Gohm	> 10 Megohms	Acc
2	6	> 100Gohm	> 10 Megohms	Acc
2	7	> 100Gohm	> 10 Megohms	Acc
2	8	> 100Gohm	> 10 Megohms	Acc
2	9	> 100Gohm	> 10 Megohms	Acc
2	10	> 100Gohm	> 10 Megohms	Acc
2	11	> 100Gohm	> 10 Megohms	Acc
2	12	> 100Gohm	> 10 Megohms	Acc
2	13	> 100Gohm	> 10 Megohms	Acc
2	14	> 100Gohm	> 10 Megohms	Acc
3	4	> 100Gohm	> 10 Megohms	Acc
3	5	> 100Gohm	> 10 Megohms	Acc
3	6	> 100Gohm	> 10 Megohms	Acc
3	7	> 100Gohm	> 10 Megohms	Acc
3	8	> 100Gohm	> 10 Megohms	Acc
3	9	> 100Gohm	> 10 Megohms	Acc
3	10	> 100Gohm	> 10 Megohms	Acc
3	11	> 100Gohm	> 10 Megohms	Acc
3	12	> 100Gohm	> 10 Megohms	Acc
3	13	> 100Gohm	> 10 Megohms	Acc
3	14	> 100Gohm	> 10 Megohms	Acc
4	5	> 100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 5 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
4	6	>100Gohm	> 10 Megohms	Acc
4	7	>100Gohm	> 10 Megohms	Acc
4	8	>100Gohm	> 10 Megohms	Acc
4	9	>100Gohm	> 10 Megohms	Acc
4	10	>100Gohm	> 10 Megohms	Acc
4	11	>100Gohm	> 10 Megohms	Acc
4	12	>100Gohm	> 10 Megohms	Acc
4	13	>100Gohm	> 10 Megohms	Acc
4	14	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
5	7	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	8	>100Gohm	> 10 Megohms	Acc
5	10	>100Gohm	> 10 Megohms	Acc
5	11	>100Gohm	> 10 Megohms	Acc
5	12	>100Gohm	> 10 Megohms	Acc
5	13	>100Gohm	> 10 Megohms	Acc
5	14	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
6	8	>100Gohm	> 10 Megohms	Acc
6	9	>100Gohm	> 10 Megohms	Acc
6	10	>100Gohm	> 10 Megohms	Acc
6	11	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	12	>100Gohm	> 10 Megohms	Acc
6	14	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
7	9	>100Gohm	> 10 Megohms	Acc
7	10	>100Gohm	> 10 Megohms	Acc
7	11	>100Gohm	> 10 Megohms	Acc
7	12	>100Gohm	> 10 Megohms	Acc
7	13	>100Gohm	> 10 Megohms	Acc
7	14	>100Gohm	> 10 Megohms	Acc
8	9	>100Gohm	> 10 Megohms	Acc
8	10	>100Gohm	> 10 Megohms	Acc
8	11	>100Gohm	> 10 Megohms	Acc
8	12	>100Gohm	> 10 Megohms	Acc
8	13	>100Gohm	> 10 Megohms	Acc
8	14	>100Gohm	> 10 Megohms	Acc
9	10	>100Gohm	> 10 Megohms	Acc
9	11	>100Gohm	> 10 Megohms	Acc
9	12	>100Gohm	> 10 Megohms	Acc
9	13	>100Gohm	> 10 Megohms	Acc
9	14	>100Gohm	> 10 Megohms	Acc
10	11	>100Gohm	> 10 Megohms	Acc
10	12	>100Gohm	> 10 Megohms	Acc
10	13	>100Gohm	> 10 Megohms	Acc
10	14	>100Gohm	> 10 Megohms	Acc
11	12	>100Gohm	> 10 Megohms	Acc
11	13	>100Gohm	> 10 Megohms	Acc
11	14	>100Gohm	> 10 Megohms	Acc

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 6 of 9

Desc. of Terminal	Desc. of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
12	13	>100Gohm	> 10 Megohms	Acc
12	14	>100Gohm	> 10 Megohms	Acc
13	14	>100Gohm	> 10 Megohms	Acc
1	Ground	>100Gohm	> 10 Megohms	Acc
2	Ground	>100Gohm	> 10 Megohms	Acc
3	Ground	>100Gohm	> 10 Megohms	Acc
4	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
9	Ground	>100Gohm	> 10 Megohms	Acc
10	Ground	>100Gohm	> 10 Megohms	Acc
11	Ground	>100Gohm	> 10 Megohms	Acc
12	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.3 De-energize and remove test equipment.

2.2.4 Setup the test equipment and relay specimen for insulation resistance testing.

2.2.5 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the relay test specimen. Record the relay data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
1-9	2-10	>100Gohm	> 10 Megohms	Acc
1-9	3-11	>100Gohm	> 10 Megohms	Acc
1-9	4-12	>100Gohm	> 10 Megohms	Acc
2-10	3-11	>100Gohm	> 10 Megohms	Acc
2-10	4-12	>100Gohm	> 10 Megohms	Acc
3-11	4-12	>100Gohm	> 10 Megohms	Acc
5	6	>100Gohm	> 10 Megohms	Acc
6	7	>100Gohm	> 10 Megohms	Acc
7	8	>100Gohm	> 10 Megohms	Acc
1-9	Ground	>100Gohm	> 10 Megohms	Acc
2-10	Ground	>100Gohm	> 10 Megohms	Acc
3-11	Ground	>100Gohm	> 10 Megohms	Acc
4-12	Ground	>100Gohm	> 10 Megohms	Acc
5	Ground	>100Gohm	> 10 Megohms	Acc
6	Ground	>100Gohm	> 10 Megohms	Acc
7	Ground	>100Gohm	> 10 Megohms	Acc
8	Ground	>100Gohm	> 10 Megohms	Acc
13	Ground	>100Gohm	> 10 Megohms	Acc
14	Ground	>100Gohm	> 10 Megohms	Acc

2.2.6 De-energize and remove test equipment.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 7 of 9

2.3 Operation

2.3.1 Assemble the relay onto its socket. Regulate voltage to the coil of the relay and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	75.136 VAC	96 VAC maximum	Acc
Drop-out Voltage	52.819 VAC	36 AC minimum	Acc

2.3.2 De-energize and remove test equipment.

2.4 Contact Rating Test

2.4.1 Setup the Relay specimen for contact rating testing.

2.4.2 Apply a nominal 10 amps VAC, resistive, across the NC contacts of the test specimen. Record the data in the table below.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
1-9	.1089 VAC	< 0.5 Volts AC drop	Acc
2-10	.1152 VAC	< 0.5 Volts AC drop	Acc
3-11	.1106 VAC	< 0.5 Volts AC drop	Acc
4-12	.1018 VAC	< 0.5 Volts AC drop	Acc

2.4.3 Energize the relay coil with 120VAC to change the contacts' position of the test specimen.

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO contacts of the test specimen. Record the data in the table below.

Description	Record Data	Acceptance Criteria	Comments/Deviations
5-9	.1447 VAC	< 0.5 Volts AC drop	Acc
6-10	.1269 VAC	< 0.5 Volts AC drop	Acc
7-11	.1633 VAC	< 0.5 Volts AC drop	Acc
8-12	.1108 VAC	< 0.5 Volts AC drop	Acc

2.4.5 De-energize and remove test equipment.

2.5 Terminate the test.

2.5.1 Reland the relay and verify reband in accordance with the Lifted Lead Log.

2.5.2 Record: Date /Time of Test End: 04-03-00 11:40 a.m.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-020-TP-020C

Test Specimen: Idec RH4B-UL-AC120V & SH4B-05, Eqmt. No.: Generic

Page 8 of 9

3.0 References

3.1 Panel Wiring Drawings: See list provided with relay selection list (page 3).

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Test was acceptable
Michael Cram
04-03-00

Notes:

Certified Instrumentation Technician (signature) Michael Cram Date: 04-03-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Wally Swenson Date: 4/3/00

QA/QC (signature) Stephen Scott Moss Date: 4-6-2000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-33064	1	5130Y	PLLY	5	DKY	4-3-00	SKC	4-3-00	DKY	4-3-00	SKC	4-3-00
		5505Y		6	DKY	4-3-00	SKC	4-3-00	DKY	4-3-00	SKC	4-3-00
		5129Y		9	DKY	4-3-00	SKC	4-3-00	DKY	4-3-00	SKC	4-3-00
		5506Y		10	DKY	4-3-00	SKC	4-3-00	DKY	4-3-00	SKC	4-3-00
		17A05Y		13	DKY	4-3-00	SKC	4-3-00	DKY	4-3-00	SKC	4-3-00
		Green	R-52A-6	13	DKY	4-3-00	SKC	4-3-00	DKY	4-3-00	SKC	4-3-00
		Black	"	14	DKY	4-3-00	SKC	4-3-00	DKY	4-3-00	SKC	4-3-00
		2102Y	PLLY	14	DKY	4-3-00	SKC	4-3-00	DKY	4-3-00	SKC	4-5-00
Remarks:												

**THIS PAGE INTENTIONALLY
LEFT BLANK**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 2 of 8

ECN No. **N/A** CGI No. **CGI-SNF-D-MHM-048**
Title: **Various P02, 06, 07, 08, 09, 21, 26, 44, 45, and 85 Interlocks-Siemens Contactor #3TF4422-0AK6**

Section 2d Reason for Dedication	
The above Commercial Grade (CG) described Item is being Dedicated for use in the application cited for the following reason(s):	
<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item is being purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input checked="" type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Class application.
<input type="checkbox"/>	Item was purchased from a non ESL manufacturer supplier as CG to be used in a Safety Significant application.
<input type="checkbox"/>	Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation	
A. Part/Component Safety Function:	
1. Isolates line power from the Turret Rotate Drive motor when permissives are not met.	
1. Part/Component Functional Mode: Safety Function #1: <input checked="" type="checkbox"/> Active [] Passive Safety Function #2: [] Active [] Passive Safety Function #3: [] Active [] Passive	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function Passive - Change of state is not required for the component to perform its safety function
C. Host Component Safety Function (if applicable):	
1. N/A	
D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):	
1. Contact resistance out of spec results in overheating and welding of contacts	
2. Hot short across contacts results in failure to open the circuit	
3. Binding of contacts results in failure to open/close circuit	

Section 4 Environmental & Natural Phenomena Hazard Design	
Environmental Qualification Required: Yes [] No [<input checked="" type="checkbox"/>]	If yes: Environmental Qualification Requirements Limiting Environmental Conditions: Required Safety Functions: Qualification Period:
Natural Phenomena Hazard (NPH) Design Required: Yes [] No [<input checked="" type="checkbox"/>]	If yes: NPH Design Requirements Performance Category: NPH Design Req'ts.: Required Safety Functions:

Section 5 Component Functional Classification			
<input checked="" type="checkbox"/>	Safety Class (SC)	<input type="checkbox"/>	General Service (GS)
<input type="checkbox"/>		<input type="checkbox"/>	Safety Significant (SS)

If part/component classification is different from host component/system, document basis. **N/A**

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: **N/A**
 Safety Analysis Report (SAR): **HNF-3672, Rev. 0**
 Drawings: **Ederer, Inc. EB-33056, Sheets 15, 28, 30, 32, and 32A**
 Vendor Manual/Manufacturer/Supplier Information: **Siemens Industrial Control Products, World Series Contactors, 3TF4 3-Pole with AC coil**
 Other: **ALSTOM ESL/R (96) 065 - Rev. D, 100% Design Submittal - June 1998**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 3 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-048
Title Various P02, 06, 07, 08, 09, 21, 26, 44, 45, and 85 Interlocks-Siemens Contactor #3TF4422-0AK6

Section 9 Critical Characteristics

Critical Characteristics	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Siemens	1, IN	X	
Model Number	3TF42	1, IN	X	
Coil	K6	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Contact configuration	3 pole NO main contacts, 2 NO and 2 NC Aux. Contacts	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Current carrying capability	0.5V max. voltage drop across closed contacts at 10 amps resistive on main contacts and at 10 amps, resistive on auxiliary contacts	1, T		X
Insulation resistance	10 Megohm min across open contact terminals and terminals to ground (500 VDC meggar)	1, T		X
Operation	Contacts open/close at maximum pick-up (96 VAC) and minimum drop-out (36 VAC) voltages	1, T		X
4. Notes and Legend: Siemens Number 3TF4222-0AK6 is a catalogue ordering number. 3TF42 is the model number of the contactor, the next two numbers are the style and number of auxiliary contacts, and the last two digits is the type of coil (e.g. K6 is a 120VAC, 60 hz coil). Typically the aux contacts do not have a designator on them so visual verification is used.			Acceptance Method (Acc Meth): 1. Special Test and Inspection: 1, IN for Inspection 1, T for Test 2. Commercial Grade Survey 3. Source Verification 1. Vendor/Item History	

Section 10 Initial Review and Approval

Approvals:
 Designated Engineer: [Signature] 4/6/00
 Design Authority: [Signature] 4/6/00
 Quality Assurance: [Signature] 4/6-2000

Commercial Grade Item Upgrade Dedication Form	Rev. No. 0
ECN No. N/A CGI No. CGI-SNF-D-MHM-048	Page 4 of 8
Title Various P02, 06, 07, 08, 09, 21, 26, 44, 45, and 85 Interlocks-Siemens Contactor #3TF4422-0AK6	

**WORKSHEET 1
DETERMINATION OF FAILURE MECHANISMS/MODES**

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	Failure to open the circuit by contact welding or hot short across the contact base.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	X	Results in failure of contacts to open
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 5 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-048
 Title: Various P02, 06, 07, 08, 09, 21, 26, 44, 45, and 85 Interlocks-Siemens Contactor #3TF4422-0AK6

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1	
Item Description: Siemens Contactor System #: Various	Equip #: <u>IRLC SSBY, BLPDY, PWAY, PNY, SSBY,</u> Model #: <u>3TF4422-0AK6</u> <u>2</u> <u>NO</u> <u>TRDY</u>
Manufacturer (Address/Phone): Siemens Industrial Control Products 1-800-964-4114	Supplier (Address/Phone): <u>LES</u> <u>4/10/00</u> Ederer, Inc.

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	PIT	
X			1. Manufacturer
X			2. Contactor Model Number
X			3. Coil Model Number
X			4. Contact Configuration
	X		5. Contact Rating
	X		6. Insulation Resistance
	X		7. Operation

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size, References (See Section 7)

Characteristic: Manufacturer Acceptance Criteria: Siemens Receipt Inspection Plan / Report #: <u>CGI-SNF-D-MHM-048-TP-048 A, B, C & D</u>	Sample Size*: 100%
Characteristic: Contactor Model Number Acceptance Criteria: 3TF42 Receipt Inspection Plan / Report #: <u>TP-048 A, B, C & D</u>	Sample Size*: 100%
Characteristic: Coil Model Number Acceptance Criteria: K6 Receipt Inspection Plan / Report #: <u>TP-048 A, B, C & D</u>	Sample Size*: 100%
Characteristic: Contact Configuration Acceptance Criteria: 3 Pole NO Main Contacts and 2 NO and 2 NC auxiliary contacts Receipt Inspection Plan / Report #: <u>TP-048 A, B, C & D</u>	Sample Size*: 100%

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0
Page 6 of 8

ECN No. N/A CGI No. CGI-SNF-D-MHM-048
 Title: Various P02, 06, 07, 08, 09, 21, 26, 44, 45, and 85 Interlocks-Siemens Contactor #3TF4422-0AK6

SECTION 4 BY SPECIAL TEST * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic for Test: Current carrying capability Acceptance Criteria: 0.5V max. voltage drop across closed contacts at 10 amps resistive on main contacts and at 10 amps, resistive on auxiliary contacts Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-048 A,B,C</u>
Characteristic for Test: Insulation Resistance Acceptance Criteria: 10 Megohms min across open contact terminals and terminals to ground, with 500 vdc megger. Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-048 A,B,C</u>
Characteristic for Test: Operation Acceptance Criteria: Contacts change state at max. pickup voltage of 96VAC and at min. drop-out voltage of 36VAC Actual Test Value: <u>See TP</u>	Samp Size*: <input checked="" type="checkbox"/> Normal <input type="checkbox"/> Reduced <input type="checkbox"/> Tightened Test Plan and Report #: <u>TP-048 A,B,C</u>

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A

CGI No. CGI-SNF-D-MHM-048

Page 7 of 8

Title: Various P02, 06, 07, 08, 09, 21, 26, 44, 45, and 85 Interlocks-Siemens Contactor #3TF4422-0AK6

SECTION 5 TEST / INSPECTION SUMMARY (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION: Contactor

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Siemens	X		1, IN	TP018ABCD	N/A	6	0	XWEST	LARRY PRISK <i>[Signature]</i>	4/6/00
Contact Model Number	3TF44 2 CES 4/12/00	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Coil Model Number	K6	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Contact Configuration	3 Pole NO Main Contacts and 2 NO and 2 NC auxiliary contacts	X		1, IN	↓	↓	↓	↓	↓	↓	↓
Current Carrying Capability	0.5V max voltage drop across closed terminals, 10 amps on main contacts and at 10 amps on aux. contacts, resistive		X	1, T	TP018ABCD	N/A	3	0	XWEST	LARRY PRISK <i>[Signature]</i>	4/6/00
Insulation Resistance	10 Megohms min across open contact terminals and terminals to ground (500VDC megger)		X	1, T	↓	↓	↓	↓	↓	↓	↓
Operation	Contacts change state at max pick-up voltage of 96VAC and at min drop-out voltage of 36VAC		X	1, T	↓	↓	↓	↓	↓	↓	↓

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS

Critical Characteristic	Disposition

3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.

Testing Agency Approval: NR CES 4/12/00 Date: 4/12/00
 Testing Agency QA Engineer: NR CES 4/12/00 Date: 4/12/00

BUYER VERIFICATION
 Design Authority: CES Gary Swenson Date: 4/12/00
 QA Engineer: Stephen Scott Mohr Date: 4-20-2000

04/05/00

SNF-6315, Rev. 0

Page 265

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. N/A CGI No. CGI-SNF-D-MHM-048
 Title Various P02, 06, 07, 08, 09, 21, 26, 44, 45, and 85 Interlocks--Siemens Contactor #3TF4422-0AK6

Page 8 of 8

SECTION 6 CONTACTS / PHONE NUMBERS

Name	Phone
Design Authority <u>CRAIG SWENSON</u>	() <u>376-0288</u>
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

SECTION 7 SUPPORTING DOCUMENTATION FOR THIS CHECKLIST

Initial Procurement Documents		For Critical Characteristics
	Drawings:	
<input checked="" type="checkbox"/>	Manuals (specify type & number): <u>Siemens Industrial Control Products, Contractor, 3TF4 3-Pole</u>	<u>All</u>
	Design Calculations	
	Installation Instructions	
	Operation Instructions	
	Calibration Instructions	
	Manufacturer's Recommended Spare Parts List	
	Other:	
Procurement Documents:		For Critical Characteristics
	Certificate of Conformance/Compliance	
	Seismic Qualification Certificate	
	Environmental Qualification Certificate	
	Test Report (s):	
	Inspection Report (s):	
	CMTRs for ASME Pressure Retaining Materials	
	Valve Seat Leakage Report	
	Weld Records	
	Material Traceability Record	
	Other:	


Dedication Test Plan - IST
Test Plan No.: CGI-SNF-D-MHM-048-TP-048A
Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PH11

ORIGINAL

Rev. No. 0

Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI. Eng	DA	QA Post Review*
						 3/22/00 NO CHANGE

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048A


Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHHY

Page 2 of 7

ORIGINAL**In-Situ Test Procedure****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.





Design Authority (signature)



Date:

3/16/00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven		MC
Electrician	JW EBERHART	PCE		JWE
Electrician Quality Control	Stephen R Conley	PE		SR
Design Authority Representative	Larry W. Price	KUKST		LWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current Source capable of 10 amps

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00Test Instrument type: AVO BM 80/2 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: PROTO 6106 I.D.: 029E 1009 Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048A

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHHY

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHHY	PHHY	Acc
Manufacturer:	SIEMENS	Siemens	Acc
Model:	3TF4222	3TF4222	Acc
Contact Configuration:	YES	3 pole Main Contacts and 2 NO & 2 NC auxiliary contacts	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc
Coil:	K6	K6	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-17-00 8:25 am,

2.1.1 Complete the Lifted Lead Log prior to lifting leads.

2.1.2 Lift all leads

2.2 Operation

2.2.1 Regulate voltage to the coil of the contactor and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	85.080 VAC	102 VAC maximum	Acc
Drop-out Voltage	57.725 VAC	36 AC minimum	Acc

2.2.2 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048A

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHHY

Page 4 of 7

2.3 Insulation Resistance Test

2.3.1 Setup the test equipment and contactor specimen for insulation resistance testing.

2.3.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal a terminal to ground of the test specimen. Record data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
L1	T1	>100 Gohm	> 10 Megohms	Acc
L2	T2	>100 Gohm	> 10 Megohms	Acc
L3	T3	>100 Gohm	> 10 Megohms	Acc
NO AUX 13	NO AUX 14	>100 Gohm	> 10 Megohms	Acc
NO AUX 43	NO AUX 44	>100 Gohm	> 10 Megohms	Acc
L1	Ground	>100 Gohm	> 10 Megohms	Acc
L2	Ground	>100 Gohm	> 10 Megohms	Acc
L3	Ground	>100 Gohm	> 10 Megohms	Acc
T1	Ground	> 100 Gohm	> 10 Megohms	Acc
T2	Ground	> 100 Gohm	> 10 Megohms	Acc
T3	Ground	> 100 Gohm	> 10 Megohms	Acc
NO AUX 13	Ground	>100 Gohm	> 10 Megohms	Acc
NO AUX 14	Ground	>100 Gohm	> 10 Megohms	Acc
NO AUX 43	Ground	>100 Gohm	> 10 Megohms	Acc
NO AUX 44	Ground	>100 Gohm	> 10 Megohms	Acc
NC AUX 21 or 22	Ground	>100 Gohm	> 10 Megohms	Acc
NC AUX 31 or 32	Ground	>100 Gohm	> 10 Megohms	Acc
A1 or A2 (coil)	Ground	> 100 Gohm	> 10 Megohms	Acc

LES
LES
LES

LES
LES
LES
LES
LES
LES
LES

LES
LES

LES

2.4 Contact Rating Test

2.4.1 Setup the test equipment and contactor specimen for contact rating testing.

2.4.2 Manually adjust the contactor or apply 120 VAC to the coil to close the normally open contacts

2.4.3 Apply a nominal 10 amps VAC, resistive, across closed main contacts of the test specimen

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO auxiliary contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048A

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHHY

Page 5 of 7

2.4.5 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Main Contacts L1-T1 Closed	.0825 VAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L2-T2 Closed	.0426 VAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L3-T3 Closed	.1381 VAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 13-14 (closed)	.1407 VAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 43-44 (closed)	.1360 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.6 De-energize and remove test equipment.

2.4.7 Apply a nominal 10 amps VAC, resistive, across the normally closed auxiliary contacts of the test specimen.

2.4.8 Record the following data.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Auxiliary NC 21-22 Contacts	.1391 VAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NC 31-32 Contacts	.1390 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.9 De-energize and remove the test equipment.

2.5 Terminate the test.

2.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.5.2 Retorque the terminals to 12 in-pounds.

2.5.3 Record: Date /Time of Test End: 03-17-00 10:00 a.m.

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 15

3.2 Y-Channel Main Power Panel Wiring Diagram: ED-33069 Sheet 1

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-048-TP-048A	
Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHHY	Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met

Michael Cram

03-17-00

Notes:

Notes section with multiple horizontal lines for text entry.

Certified Instrumentation Technician (signature) *Michael Cram* Date: *03-17-00*


Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) *JWP Craig Swenson* Date: *3/20/00*

QA/QC (signature) *Stephen Scott Moss* Date: *3-22-2000*

SNF-6315, Rev. 0



MCC#15
 HANFORD DWG # H-2-828710 SHIT 24 OF 97


REVISIONS									
LTR	DESCRIPTION	DATE	BY	CHK	ENG	APPO	APPO	CHK	DATE
C	ADDED PHHY, PHLY & PHLY	8/18/97	JBR	TMM	TMM	JMH		CHK	8/18/97
D	GENERAL REVISIONS	7/23/97	JCR	JMH	TMM	JMH		CHK	7/23/97
E	CHANGE SWITCH TO PUSHBUTTONS	8/18/97	JRS	AH	TMM	JMH	LLA	APP	8/18/97
F	ADDED WIRE I'S	9/1/97	JCR	AH	TMM	JMH	CU	APP	9/1/97
G	MOVE STOP PUSH BUTTON	10/25/97	JRS	TMM	TMM	JMH	CU		
H	DE-WIRING & SIMPLIFICATION	3/9/98	CSO	SEO	CSO				
J	ADD PIX & CORRECT SPELLING	7/20/98	CSO	SEO	CSO				

EB-33056	SCALE N/A	REV 15	REV J
EB-33056	SCALE F-2560	REV 15	REV J

World Series Contactors

Selection

3TF4 3-Pole with AC Coil

 <p>3TF43 3TF48</p>	Ordering Information ▶ Select Contactor from table below. ▶ Complete Catalog Number from coil code table. Example: 3TF4010-0AK6	Additional References ▶ Overload Relays see pages 361-363. ▶ Accessories see pages 357-360. ▶ Replacement Parts see pages 912-913. ▶ Technical Data see pages 376-379. ▶ Electrical Life Curves see page 381. ● Dimensions see page 394. ▶ Wiring Diagrams see page 302.	Coil Voltage Codes <table border="1"> <thead> <tr> <th>AC Voltage</th> <th>80Hz</th> <th>50Hz</th> <th>Code</th> </tr> </thead> <tbody> <tr><td>24</td><td>24</td><td></td><td>C2</td></tr> <tr><td>120</td><td>110</td><td></td><td>K6</td></tr> <tr><td>208</td><td>208</td><td></td><td>M2</td></tr> <tr><td>277</td><td>220</td><td></td><td>U1</td></tr> <tr><td>240</td><td>220</td><td></td><td>P6</td></tr> <tr><td>480</td><td>380-415</td><td></td><td>V0</td></tr> <tr><td>600</td><td>500</td><td></td><td>S0</td></tr> </tbody> </table>	AC Voltage	80Hz	50Hz	Code	24	24		C2	120	110		K6	208	208		M2	277	220		U1	240	220		P6	480	380-415		V0	600	500		S0
	AC Voltage	80Hz	50Hz	Code																															
24	24		C2																																
120	110		K6																																
208	208		M2																																
277	220		U1																																
240	220		P6																																
480	380-415		V0																																
600	500		S0																																

Ampere Rating Enclosed		1 Phase HP Ratings						3 Phase HP Ratings				Auxiliary Contacts Type		Catalog No	Price \$
IEC AC-3	UL	115V	230V	200V	230V	460V	575V	NO	NC						
9	20	1/2	1 1/2	2	3	5	7 1/2	1	0	3TF4010-0A1T	105.				
12	20	1	2	3	3	7 1/2	10	1	0	3TF4110-0A1T	135.				
16	30	1	3	5	5	10	15	1	0	3TF4210-0A1T	150.				
22	30	2	3	7 1/2	7 1/2	15	20	1	0	3TF4310-0A1T	159.				
32	55	3	5	10	10	25	30	1	1	3TF4411-0A1T	180.				
38	55	3	7 1/2	10	15	25	30	1	1	3TF4511-0A1T	206.				
Auxiliary Contacts may be added to 3TF41-3TF56 for maximum 4 NO and 4 NC															
41	80	5	10	15	20	40	50	1	1	3TF4611-0A1T	276.				
63	80	5	15	20	25	50	60	1	1	3TF4711-0A1T	348.				
75	100	7 1/2	15	25	30	60	75	1	1	3TF4811-0A1T	420.				
85	105	—	—	30	40	75	100	1	1	3TF4911-0A1T	520.				

3TF Contactors—Auxiliary Contact
 Replace 6th (NO Aux. Contact) and 7th (NC Aux. Contact) digit in Catalog Number per chart. Example: 3TF4411-0AK6.

Contactors	Auxiliary Contacts		
	NO 6th Digit	NC 7th Digit	Price Adder \$
3TF40-3TF43	1	0	STD
	0	1	No Adder
	1	1	12.
3TF44-3TF45	2	2	24.
	1	1	STD
	2	2	24.
3TF46-3TF49	1	1	STD
	2	2	24.
	4	4	48.

Ⓞ See Auxiliary Contact table for standard and optional Auxiliary Contact Configurations. Ⓞ Field assembled kit.

IEC Control

World Series Contactors

Technical

3TF3, 3TF4, CRLOF3 and CRLOF4

Technical Data

NEMA Size			00		0		1	
Contactor	Type	Units of Measure	3TF30/40 CRLOF30/40	3TF31/41 CRLOF31/41	3TF32/42 CRLOF32/42	3TF33/43 CRLOF33/43	3TF34/44 CRLOF34/44	3TF35/45 CRLOF35/45
Mechanical life	make/break operations	Mil	15		15		10	
Insulation rating		V	690					
Ambient temperature range		°C	-25 to +55 in operation, -55 to +80 when stored					
Coil ratings (cold coil 1.0 x U _c)		Hz	50		60		50	
AC operation	Inrush	VA	60	75			87	115
	p.f.		0.82	0.76			0.82	0.75
	Sealed	VA	10	9.4			13	13
	p.f.		0.29	0.29			0.27	0.27
DC operation	Inrush = Sealed	W	65				11.7	
Coil voltage range:	AC at DC 24V		0.85 to 1.1 x U _c 0.8 to 1.2 x U _c				0.85 to 1.1 U _c 0.8 to 1.1 U _c	
Operating times ⁽¹⁾ (Valid for 20% undervoltage to 10% overvoltage cold or warm coil)			(Values are applicable up to and including 20% undervoltage, 10% overvoltage as well as with the coil in cold state and operating temperature)					
AC operation	closing delay	ms	8-35		10-35		13-57	
	opening delay	ms	4-18		5-20		5-10	
DC operation	closing delay	ms	20-170		35-180		54-182	
	opening delay	ms	10-25		10-25		13-17	
Operating times at 1.0 x U _c ⁽²⁾								
AC operation	closing delay	ms	10-15		10-25		13-32	
	opening delay	ms	4-18		5-20		5-10	
DC operation	closing delay	ms	30-70		40-80		58-107	
	opening delay	ms	12-20		10-25		13-17	
Resistance to shock (rectangular pulse)	AC	g/ms	7.7/5, 4.4/10		5.8/5, 3.4/10		6.2/5, 3.6/10	
Conductor sizes								
For contactors without overload relay								
main conductor, solid or stranded	main	AWG	(2) 18-12		(2) 18-12		(1) 14-3 or (2) 16-6	
auxiliary conductor, solid or stranded	aux	AWG	(2) 18-12		(2) 18-12		(2) 18-12	
Switching frequency in make/break operations per hour								
Contactors without overload relay								
	to AC-1	ops./h	1500		1500		1200	
	to AC-2	ops./h	1000		750		750	
	to AC-3	ops./h	1000		750		750	
	to AC-4	ops./h	250		250		250	
Contactor with overload relay (avg. value)		1/h	15		15		15	
Auxiliary contacts								
①, ② and ratings ③ for auxiliary contacts								
Auxiliary Contacts within 3TF30 and 3TF31 and 3TF40 through 3TF45	Rated voltage switching capacity continuous current: 10 Amp (AC/DC)	AC 600V max NEMA A600		24V	120V	240V	480V	600V
		Make	A	60	60	30	15	12
		Break	A	6	6	3	1.5	1.2
		DC 600V max NEMA P600		24V	125V	250V	300V	600V
		Make	A	1.1	1.1	0.55	0.20	0.20
		Break	A	1.1	1.1	0.55	0.20	0.20
Auxiliary contact blocks for 3TF30 to 3TF35, Cat. 3TX40		AC 600V max NEMA A600		24V	125V	200V	300V	600V
		DC 600V max NEMA Q600		24V	125V	200V	300V	600V
		Make	A	0.55	0.55	0.27	0.10	0.10
		Break	A	0.55	0.55	0.27	0.10	0.10

Load/Life Curves shown with 3TF contactor technical data page XXX

⁽¹⁾The opening time delay is increased when the contactor coil is protected against voltage peaks (diodes 6 to 9 times; diode combination 2 to 5 times; varistor ~ 2 to 6 ms).

123 CONTACT

378

World Series Contactors

Technical

3TF4 and CRLOF4

NEMA Size			2		3	
Contactors	Type	Unit of Measure	3TF46 CRLOF46	3TF47 CRLOF47	3TF48 CRLOF48	3TF49 CRLOF49
Mechanical life	make/break operations	Mil	10	10	10	10
Insulation rating		V	1000	1000	1000	1000
Ambient temperature range		°C	-25 to +55 in operation, -50 to +80 when stored			
Coil ratings (coil coil, 1.0 × U _c)		Hz	50	60	50	60
AC operation	Inrush	VA	183	185	345	360
	p.f.		0.5	0.54	0.5	0.4
	Sealed p.f.	VA	17	15	35	31
DC economy circuit	Inrush	W	400	—	420	—
	Sealed	W	2.1	—	2.7	—
DC solenoid system	Closing = Closed	W	15	—	—	—
Coil voltage range	AC		0.85 to 1.1 × U _c			
Operating times (valid for 20% undervoltage to 10% overvoltage, cold or warm coil)						
Total break time = opening delay + arcing time						
AC operation	closing delay	ms	15-40		20-50	
	opening delay ¹⁾	ms	5-25		5-30	
	arcing time	ms	10-15		10-15	
Operating times at 1.0 × U _c AC operation	closing delay	ms	17-30		22-35	
	opening delay ¹⁾	ms	5-25		5-30	
Resistance to shock (rectangular pulse)		g/ms	11.2/5	6.6/10	6.6/5	4.8/10
Conductor sizes						
For contactors without overload relay						
main conductor: solid or stranded	AWG		max 1/0		max 1/0	
auxiliary conductor: solid or stranded	AWG		2 × (18 to 12)		2 × (18 to 12)	
Switching frequency in make/break operations per hour (1/h)						
Contactors without overload relay	duty AC-1	1/h	1000	1000	500	900
	duty AC-2	1/h	600	400	400	350
	duty AC-3	1/h	1200	1000	1000	850
	duty AC-4	1/h	400	300	300	350
	Contactors with overload relay (average value)	1/h	15	15	15	15

Auxiliary contacts								
④, ⑤ and ⑥ ratings for auxiliary contacts								
3TF40 thru 3TF57	Rated voltage switching capacity	AC 600V maximum NEMA A600		24V	120V	240V	480V	600V
		Make	A	60	60	30	15	12
Break	A	6	6	3	1.5	1.2		
Continuous current 10A (AC/DC)	DC 600V maximum NEMA P600			24V	150V	250V	300V	600V
		Make	A	11	11	0.55	0.20	0.20
		Break	A	11	11	0.55	0.20	0.20

¹⁾The opening delay can increase if the coils have voltage spike protection. Diodes may only be attached to contactors up to 3TF44.




AC Control




Non-Reversing Starters ----- Type 3TF


Without Control Power Transformer



With Control Power Transformer



Standard Pilot Control
Wire "C" omitted on starters with coils rated 120V or less.



Note: Starters with Contactor Sizes 3TF40 through 3TF44 are provided with the overload relays which mount directly to the contactor. These overload relays are provided with a contactor coil A2 repeat terminal. Wire "D" is integral with the overload relay. Jumper wire "E" is provided on the overload relay.

Dedication Test Plan - IST

Test Plan No.: CGI-SNF-D-MHM-048-TP-048B


Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHL

Rev. No. 0

ORIGINAL

Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI. Eng	DA	QA Post Review*
						 3/22/00 No CHANGE

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048B

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHLV

Page 2 of 7

In-Situ Test Procedure**ORIGINAL****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

JWP

Date:

*3/16/00***TEST PERSONNEL REQUIRED:**

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Belhaven	<i>Michael Cram</i>	MRC
Electrician	JW EBERHART	PCE	<i>JW Eberhart</i>	JWS
Electrician Quality Control	Stephen R. Cowley	PE	<i>Stephen R. Cowley</i>	SCC
Design Authority Representative	LARRY W. PRICE	KWEST	<i>JWP</i>	JWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current Source capable of 10 amps

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00Test Instrument type: AVO BM 8012 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: PROTO 6106 I.D.: 029E/009 Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048B

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHL Y

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	PHLY	PHLY	Acc
Manufacturer:	SIEMENS	Siemens	Acc
Model:	3TF4222	3TF4222	Acc
Contact Configuration:	YES	3 pole Main Contacts and 2 NO & 2 NC auxiliary contacts	Acc
Serial No./Lot No./Date Code:	CK	N/A	Acc
Coil:	K6	K6	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-17-00 8:50am

2.1.1 Complete the Lifted Lead Log prior to lifting leads.

2.1.2 Lift all leads

2.2 Operation

2.2.1 Regulate voltage to the coil of the contactor and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	86.462 VAC	102 VAC maximum	Acc
Drop-out Voltage	61.220 VAC	36 AC minimum	Acc

2.2.2 De-energize and remove test equipment.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048B

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHL Y

Page 5 of 7

2.4.5 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Main Contacts L1-T1 Closed	.0464 VAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L2-T2 Closed	.0525 VAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L3-T3 Closed	.0393 VAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 13- 14 (closed)	.1356 VAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 43- 44 (closed)	.1307 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.6 De-energize and remove test equipment.

2.4.7 Apply a nominal 10 amps VAC, resistive, across the normally closed auxiliary contacts of the test specimen.

2.4.8 Record the following data.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Auxiliary NC 21-22 Contacts	.0843 VAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NC 31-32 Contacts	.1221 VAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.9 De-energize and remove the test equipment.

2.5 Terminate the test.

2.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.5.2 Retorque the terminals to 12 in-pounds.

2.5.3 Record: Date /Time of Test End: 03-17-00 9:30 a.m.

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 15

3.2 Y-Channel Main Power Panel Wiring Diagram: ED-33069 Sheet 1

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048B

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: PHL Y

Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met
Michael Crum
03-17-00

Notes:

Certified Instrumentation Technician (signature) Michael Crum Date: 03-17-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) JW Craig Swenson Date: 3/20/00

QA/QC (signature) Stephen Scott Moss Date: 3-22-2000

LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
EB-3305L		1516Y	PHLY	A-1	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00
		Black	R4S2A-6	A-1	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00
		Gray	" "	A-2	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00
		2) 102Y	PHLY	A-2	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00
		PHX-11		L-1	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00
		PHX-12		L-2	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00
		PHX-13		L-3	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00
		PHI-11		T-1	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00
		PHI-12		T-2	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00
		PHI-13		T-3	JWE	3/17/00	SRL	3-17-00	JWE	3/17/00	SRL	3-17-00


Remarks:

SNF-6315, Rev. 0

World Series Contactors

Selection

3TF4 3-Pole with AC Coil

 <p>3TF43 3TF48</p>	Ordering Information ▶ Select Contactor from table below. ▶ Complete Catalog Number from coil code table. Example: 3TF4010-0AK6	Additional References ▶ Overload Relays see pages 361-363 ▶ Accessories see pages 357-360. ▶ Replacement Parts see pages 912-913. ▶ Technical Data see pages 376-379 ▶ Electrical Life Curves see page 381. ▶ Dimensions see page 394. ▶ Wiring Diagrams see page 302.	Coil Voltage Codes		
			AC Voltage 60Hz 50Hz Code	24 24 C2 120 110 K6 208 208 M2 277 220 U1 240 220 P6 480 330-415 V0 600 500 S0	

Ampere Rating Enclosed		1 Phase HP Ratings		3 Phase HP Ratings				Auxiliary Contacts Type		Catalog No	Price \$
IEC AC-3	UL	115V	230V	200V	230V	480V	575V	NO	NC		
9	20	1/2	1 1/2	2	3	5	7 1/2	1	0	3TF4010-0A1T	105.
12	20	1	2	3	3	7 1/2	10	1	0	3TF4110-0A1T	135.
16	30	1	3	5	5	10	15	1	0	3TF4210-0A1T	150.
22	30	2	3	7 1/2	7 1/2	15	20	1	0	3TF4310-0A1T	155.
32	55	3	5	10	10	25	30	1	1	3TF4411-0A1T	180.
38	55	3	7 1/2	10	15	25	30	1	1	3TF4511-0A1T	200.
Auxiliary Contacts may be added to 3TF46-3TF56 for maximum 4 NO and 4 NC.											
45	80	5	10	15	20	40	50	1	1	3TF4611-0A1T	270.
63	80	5	15	20	25	50	60	1	1	3TF4711-0A1T	340.
75	100	7 1/2	15	25	30	60	75	1	1	3TF4811-0A1T	420.
85	105	—	—	30	40	75	100	1	1	3TF4911-0A1T	520.

3TF Contactors—Auxiliary Contact

Replace 6th (NO Aux. Contact) and 7th (NC Aux. Contact) digit in Catalog Number per chart. Example: 3TF4411-0AK6.

Contactors	Auxiliary Contacts		
	NO 6th Digit	NC 7th Digit	Price Adder \$
3TF40-3TF43	1	0	STD
	0	1	No Aux.
	1	1	12.
3TF44-3TF45	2	2	24.
	1	1	STD
	2	2	24.
3TF46-3TF49	1	1	STD
	2	2	24.
	4 ¹⁾	4 ²⁾	48.

¹⁾See Auxiliary Contact table for standard and optional Auxiliary Contact Configurations.

²⁾Field assembled kit.

IEC Control

World Series Contactors

3TF3, 3TF4, CRLOF3 and CRLOF4

Technical Data

NEMA Size			00		0		1		
Contactor	Type	Units of Measure	3TF30/40 CRLOF30/40	3TF31/41 CRLOF31/41	3TF32/42 CRLOF32/42	3TF33/43 CRLOF33/43	3TF34/44 CRLOF34/44	3TF35/45 CRLOF35/45	
Mechanical life	make/break operations	Mil	15			15		10	
Insulation rating		V	690						
Ambient temperature range		°C	-25 to +55 in operation, -55 to +80 when stored						
Coil ratings (coil 1.0 × U ₂)		Hz	50		60		50		
AC operation	Inrush	VA	68	75			87	115	
	p.f.		0.82	0.76			0.82	0.75	
	Sealed	VA	10	9.4			13	13	
	p.f.		0.29	0.29			0.27	0.27	
DC operation	Inrush = Sealed	W	6.5						
Coil voltage range:	AC at DC 24V		0.85 to 1.1 × U ₂ 0.8 to 1.2 × U ₂				0.85 to 1.1 U ₂ 0.8 to 1.1 U ₂		
Operating times ¹ (Valid for 20% undervoltage to 10% overvoltage cold or warm coil)			(Values are applicable up to and including 20% undervoltage, 10% overvoltage as well as with the coil in cold state and operating temperature)						
AC operation	closing delay	ms	8-35		10-35		13-57		
	opening delay	ms	4-18		5-20		5-10		
DC operation	closing delay	ms	20-170		35-180		54-182		
	opening delay	ms	10-25		10-25		13-17		
Operating times at 1.0 × U ₂ ²									
AC operation	closing delay	ms	10-15		10-25		13-32		
	opening delay	ms	4-18		5-20		5-10		
DC operation	closing delay	ms	30-70		40-80		58-107		
	opening delay	ms	12-20		10-25		13-17		
Resistance to shock (rectangular pulse)	AC	g/ms	7.7/5, 4.4/10			5.8/5, 3.4/10		6.2/5, 3.6/10	
Conductor sizes									
For contactors without overload relay									
main conductor, solid or stranded	main	AWG	(2) 18-12	(2) 18-12	(2) 14-10	(2) 14-10	(1) 14-3 cr (2) 16-6		
auxiliary conductor, solid or stranded	aux	AWG	(2) 18-12	(2) 18-12	(2) 18-12	(2) 18-12	(2) 18-12		
Switching frequency in make/break operations per hour									
Contactors without overload relay									
	to AC-1	cps./h	1500		1500		1200		
	to AC-2	cps./h	1000		750		750		
	to AC-3	cps./h	1000		750		750		
	to AC-4	cps./h	250		250		250		
Contactor with overload relay (avg. value)		1/h	15		15		15		
Auxiliary contacts									
④ and ratings ⑤ for auxiliary contacts									
Auxiliary Contacts within 3TF30 and 3TF31 and 3TF40 through 3TF45	Rated voltage switching capacity continuous current: 10 Amp (AC/DC)	AC 600V max NEMA A600		24V	120V	240V	480V	600V	
		Make	A	60	60	30	15	12	
		Break	A	6	6	3	1.5	1.2	
		DC 600V max NEMA P600		24V	125V	250V	300V	600V	
		Make	A	1.1	1.1	0.55	0.20	0.20	
		Break	A	1.1	1.1	0.55	0.20	0.20	
Auxiliary contact blocks for 3TF30 to 3TF35, Cat 3TX40		AC 600V max NEMA A600		24V	125V	200V	300V	600V	
		DC 600V max NEMA Q600		24V	125V	200V	300V	600V	
		Make	A	0.55	0.55	0.27	0.10	0.10	
		Break	A	0.55	0.55	0.27	0.10	0.10	

Load/Life Curves shown with 3TF contactor technical data page XXX

¹The opening time delay is increased when the contactor coil is protected against voltage peaks (diode 6 to 9 times; diode combination 2 to 6 times; varistor + 2 to 6 ms).

1E3 001203

World Series Contactors

3TF4 and CRLOF4

NEMA Size			2		3	
Contactor	Type	Unit of Measure	3TF46 CRLOF46	3TF47 CRLOF47	3TF48 CRLOF48	3TF49 CRLOF49
Mechanical life	make/break operations	Mil	10	10	10	10
Insulation rating		V	1000	1000	1000	1000
Ambient temperature range		°C	-25 to +55 in operation, -50 to +80 when stored			
Coil ratings (cold coil, $1.0 \times U_c$)		Hz	50	60	50	60
AC operation	Inrush	VA	183	185	345	360
	p.f.		0.5	0.54	0.5	0.4
	Sealed p.f.	VA	17	15	35	31
DC economy circuit	Inrush	W	400	—	420	—
	Sealed	W	2.1	—	2.7	—
DC solenoid system	Closing = Closed	W	15	—	—	—
Coil voltage range	AC		0.85 to $1.1 \times U_c$			
Operating times (valid for 20% undervoltage to 10% overvoltage, cold or warm coil)						
Total break time = opening delay + arcing time						
AC operation	closing delay	ms	15-40		20-50	
	opening delay ^①	ms	5-25		5-30	
	arcing time	ms	10-15		10-15	
Operating times at $1.0 \times U_c$						
AC operation	closing delay	ms	17-30		22-35	
	opening delay ^①	ms	5-25		5-30	
Resistance to shock (rectangular pulse)		g/ms	11 2/5	6.6/10	8.6/5	4.8/10
Conductor sizes						
For contactors without overload relay						
main conductor: solid or stranded	AWG		max 1/0		max 1/0	
auxiliary conductor: solid or stranded	AWG		2 x (18 to 12)		2 x (18 to 12)	
Switching frequency in make/break operations per hour (1/h)						
Contactors without overload relay	duty AC-1	1/h	1000	1000	900	900
	duty AC-2	1/h	600	400	400	350
	duty AC-3	1/h	1200	1000	1000	850
	duty AC-4	1/h	400	300	300	250
Contactors with overload relay (average value)		1/h	15	15	15	15

Auxiliary contacts								
①, ② and ③ ratings for auxiliary contacts								
3TF40 thru 3TF57	Rated voltage switching capacity	AC 600V maximum NEMA A600	A	24V	120V	240V	480V	600V
				Make	60	60	30	15
Break	6	6	3	1.5	1.2			
Continuous current 10A (AC/DC)	DC 600V maximum NEMA P600	A	24V	150V	250V	300V	600V	
			Make	1.1	1.1	0.55	0.20	0.20
Break	1.1	1.1	0.55	0.20	0.20			

① The opening delay can increase if the coils have voltage spike protection. Diodes may only be attached to contactors up to 3TF44




TEL: 64810331




Non-Reversing Starters — Type 3TF


Without Control Power Transformer



With Control Power Transformer



Standard Pilot Control
Wire "C" omitted on starters with coils rated 120V or less.



Note: Starters with Contactor Sizes 3TF40 through 3TF44 are provided with the overload relays which mount directly to the contactor. These overload relays are provided with a contactor coil A2 repeat terminal. Wire "D" is integral with the overload relay. Jumper wire "E" is provided on the overload relay.

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048C

ORIGINAL

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: SSLY

Page 1 of 7

In-Situ Test Procedure Revision Log

Item	Basis for Change	Para/Page Affected	Desc. Of Change (Add/Change/Delete)	Approvals/Date		
				CGI. Eng	DA	QA Post Review*

* QA Post Review of Individual Revisions is allowed

ORIGINAL

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048C

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: SSLY

Page 2 of 7

ORIGINAL**In-Situ Test Procedure****Test Procedure Approval (Obtain prior to testing):**

This procedure tests the critical characteristics of the test specimen as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature)

J.P. Lang

Date:

3/16/00**TEST PERSONNEL REQUIRED:**

Title	Print Name	Company	Signature	Initials
Certified Instrumentation Technician	Michael Cram	Bethaven	<i>Michael D Cram</i>	MRC
Electrician	J W EBERHART	PCE	<i>J W Eberhart</i>	JWE
Electrician Quality Control	Stephen R. Cowley	RE	<i>Stephen R Cowley</i>	SR
Design Authority Representative	LARRY W. PRICE	RUBEN	<i>Larry W Price</i>	LWP
Start-Up Representative (As Required)	N/A	N/A	N/A	N/A
Construction Management (As Required)	N/A	N/A	N/A	N/A

RECOMMENDED EQUIPMENT:

Current Source capable of 10 amps

Megger Instrument capable of 500 VDC Test Voltage

Adjustable Voltage Power supply capable of 0 to 120 VAC minimum

MT&E: Multi-Meter, or individual meters for voltage, amperage, and resistance

Note: The collective uncertainty of the calibration standards used for M&TE shall not exceed 25% of the acceptable tolerance for each characteristic being calibrated unless otherwise specified.

Record test instrument(s) type, serial number, and calibration due date:

Test Instrument type: HP 3457A I.D.: BAT 123 Calib. Due date: 07-29-00Test Instrument type: HP 3457A I.D.: BAT 124 Calib. Due date: 07-30-00Test Instrument type: AVO BM80/2 I.D.: 6410-889 Calib. Due date: 02-09-01Test Instrument type: PROTO 6106 I.D.: 029E/009 Calib. Due date: 01-13-01

Test Instrument type: _____ I.D.: _____ Calib. Due date: _____

Dedication Test Plan - IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048C

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: SSLY

Page 3 of 7

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment. They shall be trained in precautions to prevent electrical shock. The equipment shall be appropriately grounded.

TEST PROCEDURE:

For this In-Situ Test, certain leads must be removed before testing begins, the Lifted Lead Log on the last page(s) of this procedure will be used for verification of lifting and landing of leads..

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	SSLY	SSLY	Acc
Manufacturer:	SIEMENS	Siemens	Acc
Model:	3TF4222	3TF4222	Acc
Contact Configuration:	YES	3 pole Main Contacts and 2 NO & 2 NC auxiliary contacts	Acc
Serial No./Lot No./Date Code:	OK	N/A	Acc
Coil:	K6	K6	Acc

2.0 Perform the following testing steps:

2.1 Record: Date /Time of Test Beginning: 03-17-00 10:40 a.m.

2.1.1 Complete the Lifted Lead Log prior to lifting leads.

2.1.2 Lift all leads

2.2 Operation

2.2.1 Regulate voltage to the coil of the contactor and monitor the maximum pick-up voltage and minimum drop-out voltages.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Pick-up Voltage	94.51	102 VAC maximum	Acc
Drop-out Voltage	43.20	36 AC minimum	Acc

2.2.2 De-energize and remove test equipment.

Dedication Test Plan – IST Test Plan No.: CGI-SNF-D-MHM-048-TP-048C Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: SSLY	Rev. No. 0 Page 4 of 7
--	---

2.3 Insulation Resistance Test

1 Setup the test equipment and contactor specimen for insulation resistance testing.

2.3.2 Apply a nominal 500 VDC via Megger device between each non-continuity terminals; terminal to terminal and terminal to ground of the test specimen. Record data below.

Terminal to Terminal / Ground

Desc. Of Terminal	Desc. Of Terminal/Ground	Record Data	Acceptance Criteria	Comments/Deviations
L1	T1	>100Gohm	> 10 Megohms	
L2	T2	>100Gohm	> 10 Megohms	
L3	T3	>100Gohm	> 10 Megohms	
13	14	>100Gohm	> 10 Megohms	
43	44	>100Gohm	> 10 Megohms	
L1	Ground	>100Gohm	> 10 Megohms	
L2	Ground	>100Gohm	> 10 Megohms	
L3	Ground	>100Gohm	> 10 Megohms	
T1	Ground	>100Gohm	> 10 Megohms	
T2	Ground	>100Gohm	> 10 Megohms	
T3	Ground	>100Gohm	> 10 Megohms	
13	Ground	>100Gohm	> 10 Megohms	
14	Ground	>100Gohm	> 10 Megohms	
43	Ground	>100Gohm	> 10 Megohms	
44	Ground	>100Gohm	> 10 Megohms	
21 or 22	Ground	>100Gohm	> 10 Megohms	
31 or 32	Ground	>100Gohm	> 10 Megohms	
A1 or A2 (coil)	Ground	>100Gohm	> 10 Megohms	

JMP 6/5

JMP 6/5

2.4 Contact Rating Test

2.4.1 Setup the test equipment and contactor specimen for contact rating testing.

2.4.2 Manually adjust the contactor or apply 120 VAC to the coil to close the normally open contacts

2.4.3 Apply a nominal 10 amps VAC, resistive, across closed main contacts of the test specimen

2.4.4 Apply a nominal 10 amps VAC, resistive, across the closed NO auxiliary contacts of the test specimen.

Caution: Do not change state of contacts while energized.

Dedication Test Plan – IST

Rev. No. 0

Test Plan No.: CGI-SNF-D-MHM-048-TP-048C

Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: SSLY

Page 5 of 7

2.4.5 Record the following data.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Main Contacts L1 T1 Closed	.0441 vAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L2-T2 Closed	.0499 vAC	< 0.5 ± 10% Volts AC drop	Acc
Main Contacts L3-T3 Closed	.1265 vAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 13-14 (closed)	.0854 vAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NO Contact 43-44 (closed)	.0849 vAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.6 De-energize and remove test equipment.

2.4.7 Apply a nominal 10 amps VAC, resistive, across the normally closed auxiliary contacts of the test specimen.

2.4.8 Record the following data.

Caution: Do not change state of contacts while energized.

Description	Record Data	Acceptance Criteria	Comments/Deviations
Auxiliary NC 21-22 Contacts	.0995 vAC	< 0.5 ± 10% Volts AC drop	Acc
Auxiliary NC 31-32 Contacts	.0964 vAC	< 0.5 ± 10% Volts AC drop	Acc

2.4.9 De-energize and remove the test equipment.

2.5 Terminate the test.

2.5.1 Reland the lifted leads and verify reland in accordance with the Lifted Lead Log.

2.5.2 Retorque the terminals to 12 in-pounds.

2.5.3 Record: Date /Time of Test End: 03-17-00 11:02 a.m.**3.0 References**

3.1 Elementary Wiring Drawings: EB-33056 Sheet 32

3.2 Y-Channel Main Power Panel Wiring Diagram: ED-33069 Sheet 1

Dedication Test Plan - IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-048-TP-048C	
Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.: SSLY	Page 6 of 7

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

Acceptance Criteria has been met.
 Michael O'Crain
 03-17-00

Notes:

Certified Instrumentation Technician (signature) Michael O'Crain Date: 03-17-00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.

Design Authority (signature) Jeffrey Craig Anderson Date: 3/29/00

QA/QC (signature) Stephen Scott Mohr Date: 3-27-2000


LIFTED LEAD LOG

Drawing #	Sheet #	Wire #	Device #	Terminal #	Lifted By	Date	Lift Verified By	Date	Relanded By	Date	Reland Verified By	Date
FB-33056		3221Y	SSLY	A-1	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00
		Black	RCS2A-6	A-1	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00
		Grey	" "	A-2	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00
		2 102Y	SSLY	A-2	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00
		SSX-11	"	L-1	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00
		SSX-12	"	L-2	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00
		SSX-13	"	L-3	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00
		SSL-11	"	T-1	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00
		SSL-12	"	T-2	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00
		SSL-13	"	T-3	JWG	3/17/00	SQL	3-17-00	JWG	3/17/00	SQL	3-17-00

Remarks:

SNF-6315, Rev. 0

Page 295



HANFORD DWG # H-2-828710 SHT 53 OF 97

REV	DESCRIPTION	DATE	BY	CHK	ENG	APP'D	APP'D	Drawn	Checked	DATE
D	GENERAL REVISION	7/29/97	JDR	JMI	TMM	JMI		JMI	JMI	1/18/98
E	CHANGE JOB #	8/20/97	JDR	JMI	TMM	JMI	ELA	JMI	JMI	1/22/98
F	MODIFIED NOMENCLATURE	3/15/98	JDR	JMI	TMM	JMI	EN	JMI	JMI	1/23/98
C	ADD LAMP LABELS	10/3/97	JIS	JIS	TMM	JMI	LA	JMI	JMI	1/23/98
H	MODIFY STOP PUSHBUTTON	10/25/97	JIS	TMM	TMM	JMI	EN	JMI	JMI	1/23/98
J	DE-INTEGRATE & SIMPLIFICATION	1/9/98	CSB	SEC	CSB					
K	GENERAL REVISION	7/20/98	CSB	SEC	CSB					


SCALE	N/A
DATE	1/18/98
BY	F-25GG

REV	32
DATE	1/22/98
BY	JMI

World Series Contactors

Selection

3TF4 3-Pole with AC Coil

 <p>3TF43 3TF48</p>	Ordering Information ▶ Select Contactor from table below. ▶ Complete Catalog Number from coil code table. Example: 3TF4010-0AK6	Additional References ▶ Overload Relays see pages 361-363. ▶ Accessories see pages 357-360. ▶ Replacement Parts see pages 912-913. ▶ Technical Data see pages 376-379. ▶ Electrical Life Curves see page 381. ▶ Dimensions see page 394. ▶ Wiring Diagrams see page 302.	Coil Voltage Codes		
			AC Voltage 60Hz 50Hz Code	24 24 C2 120 110 K6 209 208 M2 277 220 U1 240 220 P6 480 390-415 V0 600 500 S0	

Ampere Rating Enclosed		1 Phase HP Ratings		3 Phase HP Ratings				Auxiliary Contacts Type		Catalog No	Price \$
IEC AC-3	UL	115V	230V	200V	230V	460V	575V	NO	NC		
9	20	1/2	1 1/2	2	3	5	7 1/2	1	0	3TF4010-0ATT	105.
12	20	1	2	3	3	7 1/2	10	1	0	3TF4110-0ATT	135.
16	30	1	3	5	5	10	15	1	0	3TF4210-0ATT	150.
22	30	2	3	7 1/2	7 1/2	15	20	1	0	3TF4310-0ATT	159.
32	55	3	5	10	10	25	30	1	1	3TF4411-0ATT	180.
38	55	3	7 1/2	10	15	25	30	1	1	3TF4511-0ATT	206.
Auxiliary Contacts may be added to 3TF46-3TF56 for maximum 4 NO and 4 NC [Ⓞ]											
45	80	5	10	15	20	40	50	1	1	3TF4611-0ATT	276.
63	80	5	15	20	25	50	60	1	1	3TF4711-0ATT	348.
75	100	7 1/2	15	25	30	60	75	1	1	3TF4811-0ATT	420.
85	175	—	—	30	40	75	100	1	1	3TF4911-0ATT	520.

3TF Contactors—Auxiliary Contact
 Replace 6th (NO Aux. Contact) and 7th (NC Aux. Contact) digit in Catalog Number per chart. Example: 3TF4411-0AK6.

Contactors	Auxiliary Contacts		Price Adder \$
	NO 6th Digit	NC 7th Digit	
3TF40-3TF43	1	0	STD
	0	1	No Adder
	1	1	12.
3TF44-3TF45	2	2	24.
	1	1	STD
3TF46-3TF49	2	2	24.
	1	1	STD
	4 [Ⓞ]	4 [Ⓞ]	48.

Ⓞ See Auxiliary Contact table for standard and optional Auxiliary Contact Configurations. Ⓞ Field assembled kit.

IEC Control

World Series Contactors

Technical

3TF3, 3TF4, CRLOF3 and CRLOF4

Technical Data

NEMA Size			00		0		1	
Contactor	Type	Units of Measure	3TF30/40 CRLOF30/40	3TF31/41 CRLOF31/41	3TF32/42 CRLOF32/42	3TF33/43 CRLOF33/43	3TF34/44 CRLOF34/44	3TF35/45 CRLOF35/45
Mechanical life	make/break operations	Mil	15		15		10	
Insulation rating		V	690					
Ambient temperature range		°C	-25 to +55 in operation, -55 to +80 when stored					
Coil ratings (cold coil 1.0 x U ₁)	AC operation	Hz	50	60			50	60
		VA	68	75			87	115
DC operation	Inrush = Sealed	p.f.	0.82	0.76			0.82	0.75
		VA	10	9.4			13	13
DC operation	Inrush = Sealed	p.f.	0.29	0.29			0.27	0.27
		W	6.5				11.7	
Coil voltage range:	AC		0.85 to 1.1 x U ₁				0.85 to 1.1 U ₁	
	at DC 24V		0.8 to 1.2 x U ₁				0.8 to 1.1 U ₁	
Operating times ^① (Valid for 20% undervoltage to 10% overvoltage cold or warm coil)			(Values are applicable up to and including 20% undervoltage, 10% overvoltage as well as with the coil in cold state and operating temperature)					
AC operation	closing delay	ms	8-35		10-35		13-57	
	opening delay	ms	4-18		5-20		5-10	
DC operation	closing delay	ms	20-170		35-180		54-182	
	opening delay	ms	10-25		10-25		13-17	
Operating times at 1.0 x U ₁ ^②	AC operation	closing delay	10-15		10-25		13-32	
		opening delay	4-18		5-20		5-10	
DC operation		closing delay	30-70		40-80		58-107	
		opening delay	12-20		10-25		13-17	
Resistance to shock (rectangular pulse)	AC	g/ms	7.7/5, 4.4/10		5.8/5, 3.4/10		6.2/5, 3.6/10	
Conductor sizes								
For contactors without overload relay	main	AWG	(2) 18-12		(2) 18-12		(1) 14-3 or (2) 16-6	
auxiliary conductor, solid or stranded	aux	AWG	(2) 18-12		(2) 18-12		(2) 18-12	
Switching frequency in make/break operations per hour								
Contactors without overload relay								
	to AC-1	ops./h	1500		1500		1200	
	to AC-2	ops./h	1000		750		750	
	to AC-3	ops./h	1000		750		750	
	to AC-4	ops./h	250		250		250	
Contactor with overload relay (avg. value)		1/h	15		15		15	
Auxiliary contacts								
①. I_n and ratings ② for auxiliary contacts								
Auxiliary Contacts within 3TF30 and 3TF31 and 3TF40 through 3TF45	Rated voltage switching capacity continuous current: 10 Amp (AC/DC)	AC 600V max NEMA A600		24V	120V	240V	450V	600V
		Make	A	60	60	30	15	12
		Break	A	6	6	3	1.5	1.2
		DC 600V max NEMA P600		24V	125V	250V	300V	600V
		Make	A	1.1	1.1	0.55	0.20	0.20
		Break	A	1.1	1.1	0.55	0.20	0.20
Auxiliary contact blocks for 3TF30 to 3TF35, Cat. 3TX40		AC 600V max NEMA A600		24V	125V	200V	300V	600V
		DC 600V max NEMA Q600		24V	125V	200V	300V	600V
		Make	A	0.55	0.55	0.27	0.10	0.10
		Break	A	0.55	0.55	0.27	0.10	0.10

Load/Life Curves shown with 3TF contactor technical data page XXX

①The opening time delay is increased when the contactor coil is protected against voltage peaks (diode 6 to 9 times; diode combination 2 to 6 times; varistor + 2 to 6 ms).

World Series Contactors

Technical

3TF4 and CRLOF4

NEMA Size		2		3		
Contactor	Type	Unit of Measure	3TF48 CRLOF48	3TF47 CRLOF47	3TF48 CRLOF48	3TF49 CRLOF49
Mechanical life	make/break operations	Mil	10	10	10	10
Insulation rating		V	1000	1000	1000	1000
Ambient temperature range		°C	-25 to +55 in operation, -50 to +80 when stored			
Coil ratings (cold coil, $1.0 \times U_c$)		Hz	50	60	50	60
AC operation	Inrush	VA	183	185	345	360
	p.f.		0.5	0.54	0.5	0.4
	Sealed	VA	17	15	35	31
DC economy circuit	p.f.		0.29	0.29	0.23	0.24
	Inrush	W	400	—	420	—
DC solenoid system	Sealed	W	2.1	—	2.7	—
	Closing = Closed	W	15	—	—	—
Coil voltage range	AC		0.85 to $1.1 \times U_c$			
Operating times (valid for 20% undervoltage to 10% overvoltage, cold or warm coil)						
AC operation	Total break time = opening delay + arcing time					
	closing delay	ms	15-40		20-50	
	opening delay ¹	ms	5-25		5-30	
	arcing time	ms	10-15		10-15	
Operating times at $1.0 \times U_c$						
AC operation	closing delay	ms	17-30		22-35	
	opening delay ²	ms	5-25		5-30	
Resistance to shock (rectangular pulse)		g/ms	11.2/5	6.6/10	8.6/5	4.8/10
Conductor sizes						
For contactors without overload relay	main conductor: solid or stranded	AWG	max 1/0		max 1/0	
	auxiliary conductor: solid or stranded	AWG	2 x (18 to 12)		2 x (18 to 12)	
Switching frequency in make/break operations per hour (1/h)						
Contactors without overload relay	duty AC-1	1/h	1000	1000	500	900
	duty AC-2	1/h	600	400	400	350
	duty AC-3	1/h	1200	1200	1000	850
	duty AC-4	1/h	400	300	300	250
Contactors with overload relay (average value)		1/h	15	15	15	15

Auxiliary contacts								
④, ⑤ and ⑥ ratings for auxiliary contacts								
3TF40 thru 3TF57	Rated voltage switching capacity	AC 600V maximum NEMA A600	A	24V	120V	240V	480V	600V
	Continuous current 10A (AC/DC)	DC 600V maximum NEMA P600	A	24V	120V	240V	480V	600V
				60	60	30	15	12
			A	6	6	3	1.5	1.2
			A	24V	150V	250V	300V	600V
			A	1.1	1.1	0.55	0.20	0.20
			A	1.1	1.1	0.55	0.20	0.20


¹The opening delay can increase if the coils have voltage spike protection. Diodes may only be attached to contactors up to 3TF44.




IEC 60947-1

Non-Reversing Starters — Type 3TF

Without Control Power Transformer




With Control Power Transformer



Standard Pilot Control

Wire "C" omitted on starters with coils rated 120V or less.



Note: Starters with Contactor Sizes 3TF40 through 3TF44 are provided with the overload relays which mount directly to the contactor. These overload relays are provided with a contactor coil A2 repeat terminal. Wire "D" is integral with the overload relay. Jumper wire "E" is provided on the overload relay.

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-048-TP-048D	
Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.:SSRY, BLPDY, TLPDY	Page 2 of 4

In-Situ Inspection Procedure

ORIGINAL

Inspection Procedure Approval (Obtain prior to inspection):

This procedure documents the visual verification of the identification critical characteristics of the remaining specimen which were in-situ tested on a sampling basis as identified in the Commercial Grade Dedication. Any changes to this procedure must be made with approval from the Design Authority or his representative.

Design Authority (signature) ^{EPK} Larry W. Price Date: 4-6-00

TEST PERSONNEL REQUIRED:

Title	Print Name	Company	Signature	Initials
Electrician	N/A	N/A	N/A	N/A
Electrician Quality Control	N/A	N/A	N/A	N/A
Design Authority Representative	Larry W. Price	XWEST	<i>[Signature]</i>	<i>[Initials]</i>

SAFETY INSTRUCTIONS: PERSONNEL SAFETY – personnel shall exercise caution around energized electrical equipment.

INSPECTION PROCEDURE:

1.0 Record the following Test Specimen identification information:

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	SSRY	SSRY	
Manufacturer:	SIEMENS	Siemens	
Model:	3TF4222-0A1	3TF42	
Contact Configuration:	3PMC / 2 NO & 2 NC Aux Cont	3 pole Main Contacts and 2 NO & 2 NC auxiliary contacts	22E
Serial No./Lot No./Date Code:	N/A	N/A	
Coil:	K6	K6	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	BLPDY	BLPDY	
Manufacturer:	SIEMENS	Siemens	

Dedication Test Plan – IST		Rev. No. 0	
Test Plan No.: CGI-SNF-D-MHM-048-TP-048D			
Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.:SSRY, BLPDY, TLPDY			Page 3 of 4
Model:	3TF4222 0A1	3TF42	
Contact Configuration:	3PMC / 2 NO & NC AUX CONT	3 pole Main Contacts and 2 NO & 2 NC auxiliary contacts	22E
Serial No./Lot No./Date Code:	N/A	N/A	
Coil:	K6	K6	

Description	Record Data	Acceptance Criteria	Comments/Deviations
Equipment ID No.:	TLPDY	TLPDY	
Manufacturer:	SIEMENS	Siemens	
Model:	3TF4222 0A1	3TF42	22E
Contact Configuration:	3PMC / 2 NO & NC AUX CONT	3 pole Main Contacts and 2 NO & 2 NC auxiliary contacts	
Serial No./Lot No./Date Code:	N/A	N/A	
Coil:	K6	K6	

2.0 Record: Date /Time of Test Beginning: 4/7/00 820AM

2.1 Record: Date /Time of Test End: 4/7/00 826 AM

3.0 References

3.1 Elementary Wiring Drawings: EB-33056 Sheet 28, 30, 32A

Summary of Results (e.g.: Acceptance Criteria has been met, Anomalies, Deviations, etc.):

ACCEPTANCE CRITERIA MET.

Dedication Test Plan – IST	Rev. No. 0
Test Plan No.: CGI-SNF-D-MHM-048-TP-048D	
Test Specimen: Siemens 3TF4222-0A..1, Eqmt. No.:SSRY, BLPDY, TLPDY	Page 4 of 4

Notes: N/A

Design Authority Representative (signature) [Signature] Date: 4/7/00

Completed Test Evaluation Approval:

Inspection and test results are documented herein and their conformance with acceptance criteria has been evaluated and the test requirements have been satisfied.



Design Authority (signature) [Signature] Date: 4/7/00

QA/QC (signature) [Signature] Date: 4-7-2000

World Series Contactors

Selection

3TF4 3-Pole with AC Coil

 <p>3TF43</p>  <p>3TF48</p>	Ordering Information • Select Contactor from table below. ▶ Complete Catalog Number from coil code table. Example: 3TF4010-0AK6	Additional References ▶ Overload Relays see pages 361-363. ▶ Accessories see pages 357-360. ▶ Replacement Parts see pages 912-913. ▶ Technical Data see pages 378-379. ▶ Electrical Life Curves see page 381. ▶ Dimensions see page 394. ▶ Wiring Diagrams see page 302.	Coil Voltage Codes <table border="1"> <thead> <tr> <th>AC Voltage</th> <th>60Hz</th> <th>50Hz</th> <th>Code</th> </tr> </thead> <tbody> <tr><td>24</td><td></td><td>24</td><td>C2</td></tr> <tr><td>120</td><td></td><td>110</td><td>K6</td></tr> <tr><td>208</td><td></td><td>208</td><td>M2</td></tr> <tr><td>277</td><td></td><td>220</td><td>U1</td></tr> <tr><td>240</td><td></td><td>220</td><td>P6</td></tr> <tr><td>480</td><td></td><td>380-415</td><td>V0</td></tr> <tr><td>600</td><td></td><td>500</td><td>S0</td></tr> </tbody> </table>	AC Voltage	60Hz	50Hz	Code	24		24	C2	120		110	K6	208		208	M2	277		220	U1	240		220	P6	480		380-415	V0	600		500	S0
	AC Voltage	60Hz	50Hz	Code																															
24		24	C2																																
120		110	K6																																
208		208	M2																																
277		220	U1																																
240		220	P6																																
480		380-415	V0																																
600		500	S0																																

Ampere Rating Enclosed		1 Phase HP Ratings						3 Phase HP Ratings		Auxiliary Contacts Type		Catalog No.	Price \$
IEC AC-3	UL	115V	230V	200V	230V	460V	575V	NO	NC				
9	20	1/2	1 1/2	2	3	5	7 1/2	1	0	3TF4010-0A11	105.		
12	20	1	2	3	3	7 1/2	10	1	0	3TF4110-0A11	135.		
16	30	1	3	5	5	10	15	1	0	3TF4210-0A11	150.		
22	30	2	3	7 1/2	7 1/2	15	20	1	0	3TF4310-0A11	159.		
32	55	3	5	10	10	25	30	1	1	3TF4411-0A11	180.		
38	55	3	7 1/2	10	15	25	30	1	1	3TF4511-0A11	208.		
Auxiliary Contacts may be added to 3TF46-3TF56 for maximum 4 NO and 4 NC.													
45	80	5	10	15	20	40	50	1	1	3TF4611-0A11	278.		
63	80	5	15	20	25	50	60	1	1	3TF4711-0A11	348.		
75	100	7 1/2	15	25	30	60	75	1	1	3TF4811-0A11	428.		
85	105	—	—	30	40	75	100	1	1	3TF4911-0A11	520.		

3TF Contactors—Auxiliary Contact
 Replace 6th (NO Aux. Contact) and 7th (NC Aux. Contact) digit in Catalog Number per chart. Example: 3TF4411-0AK6.

Contactors	Auxiliary Contacts		
	NO 6th Digit	NC 7th Digit	Price Adder \$
3TF40-3TF43	1	0	STD
	0	1	No Adder
	1	1	12.
	2	2	24.
3TF44-3TF45	1	1	STD
	2	2	24.
3TF46-3TF49	1	1	STD
	2	2	24.
	4 [Ⓞ]	4 [Ⓞ]	48.

Ⓞ See Auxiliary Contact table for standard and optional Auxiliary Contact Configurations. Ⓞ Field assembled kit.

IEC Control