

11F

NUREG/CR-2369
PNL-4059

Power Histories for Fuel Codes

Prepared by E. R. Gilbert, W. N. Rausch, F. E. Panisko

Pacific Northwest Laboratory
Operated by
Battelle Memorial Institute

Prepared for
U.S. Nuclear Regulatory
Commission

NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

GPO Sales Program
Division of Technical Information and Document Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Printed copy price: \$3.25

and

National Technical Information Service
Springfield, Virginia 22161

Power Histories for Fuel Codes

Manuscript Completed: October 1981

Date Published: January 1982

Prepared by

E. R. Gilbert, W. N. Rausch, F. E. Panisko

Pacific Northwest Laboratory

Richland, WA 99352

Prepared for

Division of Systems Integration

Office of Nuclear Reactor Regulation

U.S. Nuclear Regulatory Commission

Washington, D.C. 20555

NRC FIN B2343

ACKNOWLEDGMENTS

The authors acknowledge the helpful discussions with colleagues in the Nuclear Fuels Section of the Materials Department at Pacific Northwest Laboratory. Especially valuable was the encouragement and guidance provided by J. C. Voglewede of the Core Performance Branch of the U.S. Nuclear Regulatory Commission. The computer-generated tables and figures in this report were prepared by W. D. Bennett, and the report was edited by S. K. Edler.

ABSTRACT

Computations of power history effects on the pre-loss-of-coolant accident (LOCA) conditions of generic pressurized water reactor (PWR) and boiling water reactor (BWR) fuel rods were performed at Pacific Northwest Laboratory using the U.S. Nuclear Regulatory Commission (NRC) code FRAPCON-2. Comparisons were made between cases where the fuel operated at a high ("LOCA-limited") power throughout life (20,000 MWd/MTU) and those where the fuel was at a lower power for most of its burnup and ramped to the high power at 10,000 or 20,000 MWd/MTU burnup.

The PWR rod was calculated to have more cladding creepdown during the lower power cases, which resulted in slightly lower centerline temperatures (as much as 100°C). This result was insensitive to the method used to increase the power during the ramps (i.e., by increasing the average rod power or by changing the peak-to-average (P/A) ratio of the axial power shape). The calculations also indicate that the highest fuel centerline temperatures were reached at startup.

The BWR rod, however, demonstrated a substantial dependence on the power history. In this case, the constant high-power rod released considerably more fission gas than the lower power cases (21% versus 0.4%), which resulted in temperature differences of up to 350°C. The highest temperature was reached at end-of-life (EOL) in the constant high-power case.

SUMMARY

The objective of this Pacific Northwest Laboratory (PNL) program was to assess the impact of some power history assumptions on end-of-life (EOL) fuel temperature calculations and recommend appropriate assumptions for safety analysis.

Two generic fuel rods were simulated with the U.S. Nuclear Regulatory Commission (NRC) audit code FRAPCON-2 to determine the effects of power history assumptions on pre-LOCA fuel temperatures. The fuel rods chosen for the study correspond to a commercial pressurized water reactor (PWR) (15 x 15) design and a commercial boiling water reactor (BWR) (8 x 8) design. The base case calculation for each rod was performed by extending the computer code to 20,000 MWD/MTU at the "loss-of-coolant accident (LOCA)-limited" linear heat generation rate (LHGR).^(a) Computer runs were made to simulate the behavior of each fuel rod at 0.5 and 0.7 times the peak power. At various burnups, the code then modeled ramps to the LOCA-limited LHGR (12.6 kW/ft and 13.4 kW/ft were chosen as typical values for the PWR and BWR rods, respectively). The PWR rods were ramped in two ways: by increasing the average power or by modifying the peak-to-average (P/A) ratio. The BWR rods were ramped by raising the average power to the LOCA-limited peak.

The PWR calculations gave very similar results regardless of the power history or method of ramping. The final temperature of the constant high-power case was higher than for the rods run at low powers and then ramped. This difference was less than 100°C and apparently resulted from increased cladding creepdown that was calculated to occur early in the life of the low-power rods. The lower power rod experienced more creepdown than the higher power rod because fuel thermal expansion was less; thus, more cladding creepdown was allowed before the fuel supported the cladding.

(a) The highest power licensable due to considerations of potential cladding temperatures during a postulated LOCA.

The BWR rod showed a definite power history effect. The most significant disparity between the high- and low-power cases occurred in the fission gas release fraction (21% versus 0.4%). Temperatures calculated in the low-power case ranged from 150°C at 10,000 MWd/MTU to 350°C at 20,000 MWd/MTU less than the temperatures calculated for the constant high-power case.

CONTENTS

ACKNOWLEDGMENTS	iii
ABSTRACT	v
SUMMARY	vii
INTRODUCTION	1
CONCLUSIONS	2
ANALYSIS OF POWER HISTORY EFFECTS	3
APPROACH	3
RESULTS	6
DISCUSSION	9
REFERENCES	13
APPENDIX A	A.1

FIGURES

1	Calculated Effect of Power History on Pre-LOCA Fuel Centerline Temperature for a 15 x 15 PWR Rod with a Constant Peak-to-Average Power Ratio of 1.2	7
2	Calculated Effect of Power History on Pre-LOCA Fuel Centerline Temperature for a 8 x 8 BWR Rod with a Constant Peak-to-Average Power Ratio of 1.3	8
3	Calculated Effect of Power History on Pre-LOCA Fuel Centerline Temperature a for 15 x 15 PWR Rod with Constant Average Rod Power	10
4	Effect of Creepdown in the FRAPCON-2 Code When Compared with the Creepdown-Deficient GAPCON-2 Code for a 15 x 15 PWR	12

TABLES

1	Computer Code Input	5
A.1	FRAPCON-2 Prediction for 15 x 15 PWR with 12.6 kW/ft to 20 Gwd/MTM, P/A = 1.2	A.1
A.2	FRAPCON-2 Prediction for 8 x 8 BWR with 13.4 kW/ft to 20 Gwd/MTM, P/A = 1.3	A.2
A.3	FRAPCON-2 Prediction for 15 x 15 PWR with 6.3 kW/ft for 1 Day, Ramp to 12.6 kW/ft, P/A = 1.2	A.3
A.4	FRAPCON-2 Prediction for 15 x 15 PWR with 6.3 kW/ft for 10 Gwd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2	A.4
A.5	FRAPCON-2 Prediction for 15 x 15 PWR with 6.3 kW/ft for 20 Gwd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2	A.5
A.6	FRAPCON-2 Prediction for 8 x 8 BWR with 6.7 kW/ft for 1 Day, Ramp to 13.4 kW/ft, P/A = 1.3	A.6

A.7	FRAPCON-2 Prediction for 8 x 8 BWR with 6.7 kW/ft for 10 Gwd/MTM, Ramp to 13.4 kW/ft, P/A = 1.3	A.7
A.8	FRAPCON-2 Prediction for 8 x 8 BWR with 6.7 kW/ft for 20 Gwd/MTM, Ramp to 13.4 kW/ft, P/A = 1.3	A.8
A.9	FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 1 Day, Ramp to 12.6 kW/ft P/A = 1.2	A.9
A.10	FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 2 Gwd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2	A.10
A.11	FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 10 Gwd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2	A.11
A.12	FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 20 Gwd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2	A.12
A.13	FRAPCON-2 Prediction for 8 x 8 BWR with 9.4 kW/ft for 1 Day, Ramp to 13.4 kW/ft, P/A = 1.3	A.13
A.14	FRAPCON-2 Prediction for 8 x 8 BWR with 9.4 kW/ft for 10 Gwd/MTM, Ramp to 13.4 kW/ft, P/A = 1.3	A.14
A.15	FRAPCON-2 Prediction for 8 x 8 BWR with 9.4 kW/ft for 20 Gwd/MTM, Ramp to 13.4 kW/ft, P/A = 1.3	A.15
A.16	FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 1 Day, Ramp to 12.6 kW/ft, Constant Rod Average Power	A.16
A.17	FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 10 Gwd/MTM, Ramp to 12.6 kW/ft, Constant Rod Average Power	A.17
A.18	FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 20 Gwd/MTM, Ramp to 12.6 kW/ft, Constant Rod Average Power	A.18
A.19	GAPCON-2 Prediction for 15 x 15 with 12.6 kW/ft to 20 Gwd/MTM, P/A = 1.2	A.19
A.20	GAPCON-2 Prediction for 15 x 15 with 8.8 kW/ft for 20 Gwd/MTM Ramp to 12.6 kW/ft, P/A = 1.2	A.20

INTRODUCTION

Steady-state fuel performance codes like FRAPCON-2,⁽¹⁾ a U.S. Nuclear Regulatory Commission (NRC) audit code, have their major impact on loss-of-coolant accident (LOCA) analysis. Fuel rod temperatures, which are calculated as the starting point for the emergency core cooling system (ECCS) analysis, have a dominant effect on LOCA peak cladding temperature and are subject to large variations due to power history effects. The power history assumptions vary from vendor to vendor; therefore, there is a need to review some of the vendor assumptions to confirm their adequacy.

In reviewing safety analyses as part of the licensing of nuclear power plants, the NRC performs calculations of fuel parameters and response using fuel performance computer codes. The predictions of these codes are dependent on not only the conditions at the time of a hypothetical accident but also the conditions prior to the event. The purpose of this Pacific Northwest Laboratory (PNL)^(a) program was to provide assistance in determining power history effects in fuel performance codes used for plant safety analyses.

Generic pressurized water reactor (PWR) and boiling water reactor (BWR) fuel rods were simulated using FRAPCON-2 to determine the effects of certain power history assumptions on pre-LOCA fuel temperatures. The base case calculation for each rod was performed by extending the computer code to 20,000 MWD/MTU at the LOCA-limited linear heat generation rate (LHGR). Computer runs simulated the behavior of each fuel rod at 0.5 and 0.7 times the peak power. At various burnups, the calculations then modeled ramps to the LOCA-limited LHGR.

The remainder of this report consists of the conclusions that were reached and a presentation of the approach that was used, the results that were obtained, and a discussion of those results. The appendix contains power history data and code output for the generic PWR and BWR rods.

(a) Operated for the U.S. Department of Energy (DOE) by Battelle Memorial Institute.

CONCLUSIONS

The results calculated by FRAPCON-2 showed that the specific choices of power history had very little effect on the EOL centerline temperatures for the PWR cases. In all PWR cases, the fuel rod was predicted to reach its highest temperature at beginning of life (BOL). The method of ramping the fuel rod--changing the peak-to-average (P/A) ratio or increasing the average power--did not influence the results.

The BWR cases, however, demonstrated a significant dependence upon power history. The constant high-power rod released considerably more fission gas than the lower power cases; this resulted in EOL temperatures that were as much as 350°C higher for the constant high-power case.

It appears that in the case of PWR fuel the method of modeling fuel performance by operating the fuel at typical commercial powers (6 to 9 kW/ft) and then ramping to the peak licensable LHGR may be a suitable substitute for calculating fuel thermal performance by modeling a constant high-power history. For the BWR, however, the constant high-power history case was more conservative at higher burnup conditions than the low-power/ramp technique. Although this does not necessarily invalidate the low-power method, it does indicate that more work would be necessary to assess which power history is more realistic with respect to licensing for modeling commercial fuel performance.

ANALYSIS OF POWER HISTORY EFFECTS

This section includes a description of the approach that was used in the analysis, a presentation of the results, and a discussion of those results.

APPROACH

Representative power histories consisted of operation at a fixed power level followed by an instantaneous increase to a LOCA-limited peak power at which critical output parameters (e.g., volume average fuel temperature, rod internal pressure) were calculated. The calculational matrix included two fuel designs--a PWR 15 x 15 and a BWR 8 x 8 design^(a)--three steady-state power levels--0.5, 0.7, and 1.0 times the fuel rod LOCA-limited peak power level. The power was increased by changing the rod average power while maintaining a constant P/A power ratio for both PWR and BWR cases. An additional set of cases was produced by changing the axial power distribution for some special PWR cases.

The specific cases used to assess the impact of power history assumptions on LOCA-limited fuel temperature cladding calculations were as follows: The power history effects on pre-LOCA conditions were computed for a generic 15 x 15 PWR fuel rod with a peak LHGR of 12.6 kW/ft^(b) and a steady-state pre-LOCA LHGR of 8.8 kW/ft (0.7 times the peak LHGR) and 6.3 kW/ft (0.5 times the peak LHGR) for burnups of 26 MWd/MTU (i.e., BOL), 10,000 MWd/MTU, and 20,000 MWd/MTU using the FRAPCON-2 code with FRACAS-2 mechanical model and the ANS 5.4 fission gas release model. A special case was conducted with a steady-state pre-LOCA LHGR of 8.8 kW/ft for a burnup of 2000 MWd/MTU. In all cases, the power was ramped to 12.6 kW/ft at the specified burnup. The computer outputs are tabulated in Appendix A.

Similar computations were conducted for a generic 8 x 8 BWR fuel rod with a peak LHGR of 13.4 kW/ft^(b) and a steady-state pre-LOCA LHGR of 9.4 kW/ft (0.7 times the peak LHGR) and 6.7 kW/ft (0.5 times the peak LHGR) for burnups of BOL, 10,000 MWd/MTU, and 20,000 MWd/MTU.

(a) See Reference 2 for physical descriptions of the fuel rods.

(b) Peak power values were chosen to represent typical PWR and BWR LOCA-limited LHGRs.

Computations were made for conditions of constant P/A power ratios of 1.2 (PWR) and 1.3 (BWR). The power was increased at the specified burnup by increasing the rod power and maintaining the same P/A power ratios. An alternate method of power ramping to LOCA conditions--maintaining a constant rod average power but altering the axial power distribution to enable attainment of the LOCA conditions in a segment of the rod--was performed for PWR burnups at BOL, 10,000 MWd/MTU, and 20,000 MWd/MTU with pre-LOCA power of 8.8 kW/ft (0.7 times the peak LHGR). The power histories for these cases are also described in the appendix.

The FRAPCON-2 code, which is described in Reference 1, is a steady-state model developed jointly by EG&G Idaho^(a) and PNL for the Fuel Behavior Research Branch of the NRC. The FRACAS-2 mechanical subcode was selected to compute the fuel-cladding interactions, while fission gas release was computed with the ANS 5.4 option. FRACAS-2 uses the effective fuel conductivity and the relocated fuel-cladding gap size for thermal calculations. The relocated fuel surface is used in the mechanics calculations. A model is included for time-dependent hot pressing of misaligned fuel fragments. The FRAPCON-2 code includes cladding creepdown under the external pressure of the coolant. Code verification is presented in References 3 and 4. The selection of code options as described in Reference 1 for these computations is presented in Table 1.

(a) Idaho National Engineering Laboratory is operated for DDE by EG&G Idaho, Inc.

TABLE 1. Computer Code Input

WESTINGHOUSE 15 X 15
\$FRPCN
IM = 33, MECHAN = 1, NA = 10, NC = 4, NF = 5, NR = 11, NGASR = 6,
MECHAN = 3,
\$END
\$FRPCUN
CPL = 0,21, UCI = ,00948, DCU = ,010714, DP = ,00929, DELTAZ = 10*0,366,0,21,
DEN = 95,0, DISHSD = 0,001, HDISH = 0,001, ENRCH = 2,8, FA = 1,2,
FGPAV = 3,04E6, FLUX = 6,0E17, HPLT = 0,01524, ICM = 4, IDXGAS = 1,
IPLANT = 1, IQ = 1, NUNITS = 0, P2 = 15,5E6, TUTL = 3,66, TW = 547,3,
HSNTR = 109,7,
QMPY = 0,01,3,6,9,12,15,18,21,24,27,30,33,36,39,41,34,18*41,34,
TIME = 0,01,0,1,,15,,2,,25,,3,,35,,4,,45,,5,,55,,6,,7,,8,,9,,2,,5,,10,,
30,,50,,70,,90,,110,,130,,150,,170,,190,,210,,230,,250,,270,,290,,300,
JDLPR = 1,
\$END

TITLE, GE 6,7 TO 1 DAY
GENERAL ELECTRIC 8 X 8
\$FRPCN
IM = 38, MECHAN = 3, NA = 10, NC = 4, NF = 5, NR = 11, NGASR = 6,
IM = 18,
\$END
\$FRPCUN
CPL = 0,36, UCI = 0,0108, DCU = 0,012528, DP = 0,01057, DELTAZ = 10*0,371,0,36,
DEN = 95, DISHSD = ,001, HDISH = ,001, ENRCH = 1,8, FA = 1,3,
FGPAV = 1,01E5, FLUX = 6E17, HPLT = 0,01067, ICM = 2, IDXGAS = 1,
IPLANT = 2, IQ = 1, NUNITS = 0, P2 = 7,14E6, TUTL = 3,71, TW = 551,3,
HSNTR = 109,7,
QMPY = 0,01,3,6,9,12,15,18,21,22,22,
24,27,30,33,36,39,42,43,96,
TIME = 0,01,0,1,,15,,2,,25,,3,,35,,4,,45,,1,,
1,03,1,06,1,09,1,12,1,15,1,18,1,21,1,24,
\$END

RESULTS

The results of the base test matrix for both PWR and BWR generic cases are listed in the Appendix (Tables A.1 through A.15) for constant P/A power ratios, and the results for the 15 x 15 PWR cases are plotted in Figure 1. The power ramps executed at BOL from the 0.5 pre-LOCA power level ended precisely on the 1.0 power level curve and passed through the 0.7 level curve during the ramp. The 0.7 case also ended precisely on the 1.0 level curve.

At 2000 MWd/MTU, the 0.7 case fell short of reaching the 1.0 level curve by approximately 25°C. At 10,000 MWd/MTU, the 0.5 case fell short of reaching the 0.7 level curve during the transient by approximately 15°C and fell short of reaching the 1.0 level curve at the end of the transient by approximately 100°C. The 0.7 case fell short of reaching the 1.0 case by approximately 45°C. At 20,000 MWd/MTU, the 0.5 case fell short of reaching the 0.7 level curve during the transient by approximately 10°C and fell short of reaching the 1.0 level curve at the end of the transient by approximately 95°C. The 0.7 case fell short of reaching the 1.0 level curve at the end of the transient by approximately 50°C. The fuel centerline temperatures in Figure 1 were predicted to decrease by 100 to 150°C within the first 10,000 MWd/MTU and then to stabilize during the second half of the computational period (to 20,000 MWd/MTU).

The results for the 8 x 8 BWR cases are plotted in Figure 2. The 0.5 case at BOL passed through the 0.7 curve during the ramp to the 1.0 level curve with which it agreed precisely. The 0.7 case agreed precisely with the 1.0 curve after being ramped at BOL. At 10,000 MWd/MTU, the 0.5 case fell short of the 0.7 curve by 50°C as it was being ramped to the 1.0 curve where it fell short by 190°C. The ramped 0.7 case fell short of the 1.0 curve by 100°C. At 20,000 MWd/MTU, the 0.5 case fell 60°C short of the 0.7 curve as it was being ramped to the 1.0 level where it fell short by 390°C. The 0.7 case fell short by 280°C of the 1.0 curve at the end of its ramp. The fuel centerline temperatures in Figure 2 were predicted to decrease by 100 to 140°C within the first 10,000 MWd/MTU and then to stabilize during the second half of the computational period, except for the steady-state case, at 13.4 kW/ft. In this case the centerline temperature increased by 200°C during the second half of the computational period.




FIGURE 1. Calculated Effect of Power History on Pre-LOCA Fuel Centerline Temperature for a 15 x 15 PWR Rod with a Constant Peak-to-Average Power Ratio of 1.2




FIGURE 2. Calculated Effect of Power History on Pre-LOCA Fuel Centerline Temperature for a 8 x 8 BWR Rod with a Constant Peak-to-Average Power Ratio of 1.3

The results of power ramping while maintaining a constant rod average power and altering the axial power distribution are shown in Figure 3. At 10,000 MWd/MTU, the predicted fuel centerline temperature at the end of the ramp was low by 50°C with respect to the constant power 12.6-kW/ft curve. After the ramp at 20,000 MWd/MTU burnup, the predicted centerline temperature was 40°C below the constant power 12.6-kW/ft curve.

DISCUSSION

This discussion is directed toward developing the physical bases for the predicted effects of power history on the pre-LOCA fuel centerline temperature in Figures 1 to 3 and the predicted trends with burnup.

For the 15 x 15 PWR rod, the decrease in predicted fuel centerline temperatures that predominantly occurs prior to 7500 MWd/MTU is associated with cladding creepdown. This is characterized by the third from the last column of the appendix tables titled "CLAD RADIUS (%) PERM." A close correspondence between the trends of the numbers in this column with the predicted decreasing centerline temperature is apparent in Tables A.1, A.3 through A.5, A.9 through A.12, and A.16 through A.18. The inability of the computed fuel centerline temperatures after a power ramp to reach the peak temperatures of the 12.6-kW/ft curve shown in Figure 1 and 3 is attributed to the greater extent of creepdown that occurs in the larger hot gap associated with the lower power cases, e.g. -0.4% versus -0.9% creep in Case 1 versus Cases 4 and 5. The creepdown increases the thermal conductance due to smaller fuel-to-cladding radial gaps. Beyond 7500 MWd/MTU, fuel swelling and cladding accommodation establish stability in the predicted fuel centerline temperature.

The initial increase in predicted centerline temperature for the BWR cases shown in Figure 2 is associated with fuel densification determined by inspection of the columns of data in Tables A.2, A.6 through A.8, and A.13 through A.15. This initial increase is followed by a significant decrease that is associated with cladding creepdown. The fuel centerline temperatures stabilize for peak burnup values above 10,000 MWd/MTU in the low-power cases




FIGURE 3. Calculated Effect of Power History on Pre-LOCA Fuel Centerline Temperature for a 15 x 15 PWR Rod with Constant Average Rod Power

but not for the constant power 13.4-kW/ft case (see Table A.2). The temperatures associated with this case are sufficiently high to permit extensive release of fission gas, which reduces the gas conductivity of the gap and results in a significant predicted increase in fuel centerline temperature beyond 10,000 MWd/MTU. Except for power ramps occurring at BOL (before the onset of cladding creepdown), all power ramps lead to predicted fuel centerline temperatures that are below the higher power cases.

An independent demonstration of the influence of cladding creepdown is displayed in Figure 4. The data used for FRAPCON-2 in Tables A.1 and A.12 were also used for GAPCON-2 as described in Tables A.19 and A.20. One of the primary differences between FRAPCON-2 and GAPCON-2 is that GAPCON-2 is a creepdown-deficient code. When the predictions of the two codes are compared (see Figure 4), it can be seen that GAPCON-2 does not predict the decreasing fuel centerline temperature that has been attributed to cladding creepdown.

The level of creepdown predicted for 0.5 and 0.7 times the LOCA-limited peak power level is on the order of 0.9% and stabilizes after a burnup of approximately 8000 MWd/MTU. This level of creepdown agrees with the 0.9% creepdown reported for light water reactor (LWR) fuel rods for burnups up to 40,000 MWd/MTU.⁽⁵⁾




FIGURE 4. Effect of Creepdown in the FRAPCON-2 Code When Compared with the Creepdown-Deficient GAPCON-2 Code for a 15 x 15 PWR

REFERENCES

1. Berna, G. A., et al. 1981. FRAPCON-2: A Computer Code for the Calculation of Steady State Thermal-Mechanical Behavior of Oxide Fuel Rods. NUREG/CR-1845, U.S. Nuclear Regulatory Commission, Washington, D.C. *
2. Acey, D. L. and J. C. Voglewede. 1980. A Comparative Analysis of LWR Fuel Designs. NUREG-0559, U.S. Nuclear Regulatory Commission, Washington, D.C. *
3. Berna, G. A., D. D. Lanning, and W. N. Rausch. 1981. FRAPCON-2 Developmental Assessment. NUREG/CR-1949, U.S. Nuclear Regulatory Commission, Washington, D.C. *
4. Laats, E. T., et al. 1981. Independent Assessment of the Steady-State Fuel Rod Analysis Code FRAPCON-2. EGG-CAAP-5335, EG&G Idaho, Inc., Idaho Falls, Idaho.
5. Mayer, J. T., et al. 1981. "B&W Fuel Performance to 40,000 Mwd/MTU Burnup." ANS Transactions 38:286.

*Available for purchase from the NRC/GPO Sales Program, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and/or the National Technical Information Service, Springfield, VA 22161.

APPENDIX A

SUMMARY OF COMPUTER CODE OUTPUT

TABLE A.1. FRAPCON-2 Prediction for 15 x 15 PWR with 12.6 kW/ft to 20 GWd/MTM, P/A = 1.2

BURN UP (MWd/MTU)	TIME (DAYS)	POWER (kW/h)	FUEL CENTER TEMP (C)	AVE TEMP (C)	AVE STORED ENERGY (J/kg)	RADIAL GAP WIDTH (CM)	RADIAL CONTACT GAP (CM)	FRACTION OF CUMMULATIVE ROD ROD	INTERNAL FIBR GAS (MPA)	XENON CHOLE DENS (%)	FUEL SWELL (%)	CLAD RADIUS (%)	AXIAL PERM RECOVER TOTAL (%)
36	0.90	41.06	1516	906	0.24E+06	.0047	.000	0.999	0.00	10.271	.000	-0.026	0.000
113	2.00	41.06	1516	906	0.24E+06	.0048	.000	0.999	0.14	10.192	.000	-0.072	0.000
321	5.00	41.06	1523	910	0.24E+06	.0052	.000	0.999	0.28	10.043	.000	-0.160	0.000
667	10.00	41.06	1522	910	0.24E+06	.0054	.000	0.999	0.44	9.916	.000	-0.231	0.000
2054	30.00	41.06	1510	906	0.24E+06	.0056	.000	0.999	0.78	9.809	.001	-0.278	0.000
3440	50.00	41.06	1480	893	0.24E+06	.0052	.000	0.999	0.93	9.874	.002	-0.279	0.000
4826	70.00	41.06	1452	881	0.25E+06	.0048	.000	0.999	1.07	9.934	.002	-0.279	0.000
6213	90.00	41.06	1418	864	0.25E+06	.0041	.018	0.981	1.13	10.060	.003	-0.279	0.098
7599	110.00	41.06	1399	853	0.25E+06	.0040	.026	0.973	1.19	10.156	.004	-0.279	0.174
8986	130.00	41.06	1391	849	0.24E+06	.0039	.031	0.968	1.27	10.225	.005	-0.279	0.236
10372	150.00	41.06	1386	849	0.24E+06	.0039	.030	0.969	1.37	10.317	.007	-0.279	0.290
11759	170.00	41.06	1376	844	0.24E+06	.0039	.034	0.965	1.48	10.367	.008	-0.279	0.336
13145	190.00	41.06	1374	846	0.24E+06	.0038	.028	0.971	1.61	10.447	.010	-0.279	0.379
14531	210.00	41.06	1368	844	0.24E+06	.0037	.032	0.967	1.76	10.502	.012	-0.279	0.418
15198	230.00	41.06	1369	846	0.24E+06	.0038	.028	0.971	1.95	10.565	.014	-0.279	0.456
17304	250.00	41.06	1369	846	0.24E+06	.0037	.026	0.973	2.16	10.638	.017	-0.279	0.491
18691	270.00	41.06	1369	849	0.24E+06	.0037	.026	0.973	2.41	10.720	.021	-0.279	0.524
20077	290.00	41.06	1371	851	0.25E+06	.0037	.026	0.973	2.69	10.811	.025	-0.279	0.559
20770	300.00	41.06	1374	854	0.25E+06	.0037	.022	0.977	2.85	10.870	.027	-0.279	0.576

TABLE A.2. FRAPCON-2 Prediction for 8 x 8 BWR with 13.4 kW/ft to 20 Gwd/MTM, P/A = 1.3

BURN UP (MWD/MTU)	TIME (DAYs)	POWER (kW/m)	FUEL	AVE	RADIAL FRACTION OF CUMMULATIVE			ROD INTERNAL XENON	FUEL	FUEL	CLAD RADIUS	AXIAL	
			CENTER TEMP (C)	FUEL TEMP (C)	STORED ENERGY (J/kg)	GAP WIDTH (CM)	CONTACT GAP		FISH BAG (%)	GAS PRES (MPA)	DENS (%)	SWELL (%)	(%)
0	0.01	0.01	278	278	0.68E+05	.0108	.000 0.999	0.00	0.216 .000	0.000 0.000	0.000 0.000	.105 .11	0.11
0	0.10	2.97	355	155	0.80E+05	.0105	.000 0.999	0.00	0.223 .000	0.000 0.000	0.001 0.001	.106 .11	0.11
1	0.15	5.94	437	366	0.98E+05	.0102	.000 0.999	0.00	0.230 .000	0.000 0.000	0.001 0.001	.108 .11	0.11
1	0.20	8.91	524	413	0.11E+06	.0099	.000 0.999	0.00	0.236 .000	0.000 0.000	0.001 0.001	.110 .12	0.12
2	0.25	11.88	617	461	0.12E+06	.0095	.000 0.999	0.00	0.243 .000	0.000 0.000	0.001 0.001	.111 .12	0.12
3	0.30	14.85	713	510	0.14E+06	.0091	.000 0.999	0.00	0.249 .000	0.000 0.000	0.002 0.002	.113 .12	0.12
4	0.35	17.83	814	560	0.15E+06	.0088	.000 0.999	0.00	0.256 .000	0.000 0.000	0.002 0.002	.114 .12	0.12
6	0.40	20.80	918	612	0.17E+06	.0084	.000 0.999	0.00	0.262 .000	0.000 0.000	0.002 0.002	.116 .12	0.12
7	0.45	23.77	1026	663	0.19E+06	.0079	.000 0.999	0.00	0.268 .000	0.000 0.000	0.003 0.003	.118 .12	0.12
9	0.50	26.74	1134	716	0.20E+06	.0075	.000 0.999	0.00	0.274 .000	0.000 0.000	0.003 0.003	.119 .12	0.12
11	0.55	29.71	1245	769	0.22E+06	.0070	.000 0.999	0.00	0.279 .000	0.000 0.000	0.003 0.003	.121 .12	0.12
13	0.60	32.68	1326	821	0.23E+06	.0066	.000 0.999	0.00	0.285 .000	0.000 0.000	0.004 0.004	.122 .12	0.12
16	0.65	35.65	1417	872	0.25E+06	.0062	.000 0.999	0.00	0.290 .000	0.000 0.000	0.004 0.004	.124 .12	0.12
18	0.70	38.62	1512	923	0.27E+06	.0058	.000 0.999	0.00	0.295 .000	0.000 0.000	0.004 0.004	.125 .13	0.13
24	0.80	41.59	1617	974	0.29E+06	.0056	.024 0.975	0.00	0.300 .000	-.018 0.000	0.005 0.173	.173 .16	0.16
30	0.90	43.53	1700	1014	0.30E+06	.0057	.050 0.949	0.00	0.302 .000	-.022 0.000	0.004 0.236	.236 0.22	0.22
93	2.00	43.53	1703	1018	0.30E+06	.0057	.037 0.982	0.47	0.302 .000	-.063 0.000	0.005 0.203	.203 0.20	0.20
268	5.00	43.53	1709	1026	0.30E+06	.0058	.023 0.976	0.95	0.301 .002	-.146 0.000	0.021 0.152	.152 0.16	0.16
558	10.00	43.53	1718	1033	0.31E+06	.0059	.000 0.999	1.30	0.301 .007	-.222 0.000	0.052 0.137	.137 0.14	0.14
1719	30.00	43.53	1729	1044	0.31E+06	.0061	.000 0.998	3.03	0.313 .043	-.285 0.000	0.111 0.143	.143 0.15	0.15
2880	50.00	43.53	1730	1049	0.31E+06	.0058	.030 0.968	4.15	0.335 .093	-.288 0.000	0.154 0.184	.184 0.15	0.15
4042	70.00	43.53	1737	1059	0.31E+06	.0057	.032 0.966	5.25	0.366 .153	-.288 0.000	0.161 0.202	.202 0.16	0.16
5203	90.00	43.53	1752	1075	0.32E+06	.0057	.045 0.958	6.31	0.409 .220	-.297 0.000	0.198 0.212	.212 0.18	0.18
6364	110.00	43.53	1705	1041	0.31E+06	.0055	.146 0.853	7.46	0.453 .279	-.297 0.241	0.193 0.210	.210 0.38	0.38
7526	130.00	43.53	1651	1020	0.30E+06	.0048	.126 0.871	7.66	0.486 .317	-.297 0.404	0.139 0.214	.214 0.51	0.51
8687	150.00	43.53	1623	1008	0.30E+06	.0041	.135 0.862	7.76	0.516 .348	-.297 0.525	0.134 0.210	.210 0.58	0.58
9848	170.00	43.53	1599	999	0.29E+06	.0036	.137 0.859	7.78	0.549 .375	-.297 0.618	0.126 0.211	.211 0.69	0.69
11009	190.00	43.53	1601	1006	0.30E+06	.0033	.136 0.860	7.96	0.586 .403	-.297 0.696	0.092 0.214	.214 0.79	0.79
12171	210.00	43.53	1607	1015	0.30E+06	.0030	.139 0.856	8.30	0.632 .433	-.297 0.764	0.090 0.232	.232 0.84	0.84
13332	230.00	43.53	1599	1014	0.30E+06	.0028	.149 0.846	8.64	0.677 .461	-.297 0.822	0.052 0.213	.213 0.92	0.92
14493	250.00	43.53	1616	1030	0.30E+06	.0026	.153 0.841	9.18	0.738 .491	-.297 0.875	0.002 0.216	.216 1.00	1.00
15655	270.00	43.53	1639	1049	0.31E+06	.0025	.165 0.828	10.06	0.821 .526	-.297 0.923	0.052 0.216	.216 1.08	1.08
16816	290.00	43.53	1663	1070	0.32E+06	.0024	.177 0.816	11.26	0.929 .562	-.297 0.969	0.110 0.217	.217 1.17	1.17
17977	310.00	43.53	1691	1093	0.32E+06	.0023	.190 0.802	12.78	1.067 .597	-.297 1.012	0.169 0.217	.217 1.25	1.25
19138	330.00	43.53	1719	1117	0.33E+06	.0023	.202 0.789	14.60	1.237 .631	-.297 1.053	0.231 0.218	.218 1.33	1.33
20300	350.00	43.53	1747	1142	0.34E+06	.0022	.211 0.778	16.63	1.438 .660	-.297 1.092	0.294 0.216	.216 1.41	1.41
21461	370.00	43.53	1773	1167	0.35E+06	.0021	.217 0.770	18.84	1.670 .685	-.297 1.128	0.356 0.216	.216 1.48	1.48
22622	390.00	43.53	1799	1191	0.36E+06	.0021	.222 0.763	21.19	1.932 .707	-.297 1.163	0.416 0.216	.216 1.55	1.55

TABLE A.3. FRAPCON-2 Prediction for 15 x 15 PWR with 6.3 kW/ft for 1 Day, Ramp to 12.6 kW/ft, P/A = 1.2

BURN UP (MWD/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL	AVE	AVE	RADIAL FRACTION OF CUMMULATIVE ROD	INTERNAL XENON	FUEL	FUEL	CLAD RADIUS	AXIAL	
			CENTER FUEL TEMP (C)	STDRED TEMP (C)	GAP ENERGY (J/kg)	GAP WIDTH (CM)	CONTACT GAS (%)	ROD FIBB GAS (%)	GAS PRES (MPA)	DENS (MOLE FRACTION)	SHELL (%)	(X) PERM RECOVER TOTAL
0	0.01	0.01	274	274	0.67E+05	.0086	,000 0.999	0.00	6.733	,000	0.000 0.000	0.000 ,070 0.10
0	0.03	2.98	303	312	0.78E+05	.0085	,000 0.999	0.00	6.986	,000	0.000 0.000	0.000 ,074 0.10
0	0.06	5.96	416	352	0.89E+05	.0083	,000 0.999	0.00	7.241	,000	0.000 0.000	0.000 ,078 0.11
1	0.09	8.94	493	279	0.10E+06	.0080	,000 0.999	0.00	7.498	,000	0.000 0.000	=.001 ,082 0.11
1	0.12	11.92	376	436	0.11E+06	.0078	,000 0.999	0.00	7.756	,000	0.000 0.000	=.001 ,085 0.11
2	0.15	14.90	663	481	0.13E+06	.0075	,000 0.999	0.00	8.015	,000	0.000 0.000	=.001 ,089 0.11
3	0.18	17.88	755	526	0.14E+06	.0072	,000 0.999	0.00	8.275	,000	0.000 0.000	=.001 ,093 0.11
4	0.21	20.86	842	568	0.16E+06	.0069	,000 0.999	0.00	8.514	,000	0.000 0.000	=.002 ,096 0.11
14	0.30	20.59	842	568	0.16E+06	.0069	,000 0.999	0.00	8.513	,000	0.000 0.000	=.004 ,096 0.11
32	1.00	23.34	933	613	0.17E+06	.0070	,000 0.999	0.00	8.730	,000	=.019 0.000	=.007 ,097 0.11
35	1.03	26.32	1034	661	0.18E+06	.0064	,000 0.999	0.00	8.993	,000	=.023 0.000	=.007 ,104 0.12
37	1.06	29.30	1139	711	0.20E+06	.0061	,000 0.999	0.00	9.255	,000	=.025 0.000	=.008 ,108 0.12
38	1.09	32.28	1246	761	0.22E+06	.0057	,000 0.999	0.00	9.517	,000	=.026 0.000	=.008 ,111 0.12
40	1.12	35.26	1329	809	0.23E+06	.0053	,000 0.999	0.01	9.771	,000	=.028 0.000	=.008 ,115 0.12
42	1.15	38.24	1421	858	0.25E+06	.0050	,000 0.999	0.02	10.022	,000	=.029 0.000	=.008 ,119 0.12
44	1.18	41.07	1516	906	0.26E+06	.0046	,000 0.999	0.04	10.264	,000	=.031 0.000	=.008 ,122 0.12

TABLE A.4. FRAPCON-2 Prediction for 15 x 15 PWR with 6.3 kW/ft for 10 Gwd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2

BURN UP (MWd/MTU)	TIME (DAYs)	POWER (kW/m)	FUEL CENTER (C)	AVE FUEL TEMP (C)	AVE STORED ENERGY (J/kg)	RADIAL WIDTH (cm)	FRACTION OF CONTACT GAS (%)	CUMMULATIVE GAP CONDUCTANCE ROD FISH GAS INTERNAL GAS PRES (MPA)	ROD XENON (MOLE FRAC)	FUEL DENB (%)	FUEL SHELL (%)	CLAD RADIUS (%)	AXIAL PERM RECOVER TOTAL (%)		
0	0.01	0.01	274	274	0.67E+05	.0086	.000	0.999	0.00	6.733	.000	0.000	0.000	.070	0.10
0	0.03	2.98	343	312	0.78E+05	.0083	.000	0.999	0.00	6.986	.000	0.000	0.000	.074	0.10
0	0.06	5.96	416	392	0.89E+05	.0083	.000	0.999	0.00	7.241	.000	0.000	0.000	.078	0.11
1	0.09	8.94	493	279	0.10E+06	.0080	.000	0.999	0.00	7.448	.000	0.000	0.000	.081	0.11
1	0.12	11.92	576	436	0.11E+06	.0078	.000	0.999	0.00	7.756	.000	0.000	0.000	.085	0.11
2	0.15	14.90	663	481	0.13E+06	.0075	.000	0.999	0.00	8.015	.000	0.000	0.000	.089	0.11
3	0.18	17.88	755	526	0.14E+06	.0072	.000	0.999	0.00	8.275	.000	0.000	0.000	.093	0.11
4	0.21	20.59	842	568	0.16E+06	.0069	.000	0.999	0.00	8.514	.000	0.000	0.000	.096	0.11
14	0.50	20.59	842	568	0.16E+06	.0069	.000	0.999	0.00	8.513	.000	0.000	0.000	.096	0.11
32	1.00	20.59	842	568	0.16E+06	.0070	.000	0.999	0.00	8.494	.000	-.019	0.000	.097	0.11
866	25.00	20.59	844	570	0.16E+06	.0078	.000	0.999	0.00	8.216	.000	-.207	0.000	.178	.101
1735	50.00	20.59	822	561	0.15E+06	.0072	.000	0.999	0.01	8.307	.000	-.228	0.000	.349	.103
2604	75.00	20.59	800	551	0.15E+06	.0065	.000	0.999	0.02	8.452	.000	-.230	0.000	.515	.106
3473	100.00	20.59	780	543	0.15E+06	.0058	.000	0.999	0.03	8.613	.000	-.230	0.000	.676	.108
4342	125.00	20.59	762	536	0.15E+06	.0051	.000	0.999	0.04	8.785	.000	-.230	0.000	.837	.110
5211	150.00	20.59	746	528	0.14E+06	.0044	.000	0.999	0.05	8.966	.000	-.230	0.000	.973	.113
6080	175.00	20.59	739	526	0.14E+06	.0043	.020	0.979	0.05	9.008	.000	-.230	0.020	.880	.131
6949	200.00	20.59	736	524	0.14E+06	.0042	.019	0.980	0.06	9.022	.000	-.230	0.039	.888	.154
7818	225.00	20.59	733	522	0.14E+06	.0042	.018	0.981	0.07	9.035	.000	-.230	0.059	.888	.169
8687	250.00	20.59	730	521	0.14E+06	.0042	.020	0.979	0.08	9.043	.000	-.230	0.078	.882	.179
9556	275.00	20.59	728	519	0.14E+06	.0041	.023	0.976	0.09	9.060	.000	-.230	0.098	.881	.193
10541	300.00	23.34	798	553	0.15E+06	.0042	.039	0.960	0.10	9.123	.000	-.230	0.120	.628	.182
10543	300.03	26.32	879	594	0.16E+06	.0040	.034	0.965	0.10	9.373	.000	-.230	0.120	.627	.239
10544	300.06	29.30	962	633	0.18E+06	.0041	.046	0.954	0.10	9.523	.000	-.230	0.120	.627	.292
10546	300.09	32.28	1048	672	0.19E+06	.0040	.054	0.948	0.10	9.669	.000	-.230	0.120	.627	.336
10548	300.12	35.26	1133	711	0.20E+06	.0040	.058	0.941	0.10	9.811	.000	-.230	0.120	.626	.363
10550	300.15	38.24	1213	748	0.21E+06	.0038	.061	0.939	0.10	9.951	.000	-.230	0.120	.626	.376
10552	300.18	41.07	1283	781	0.22E+06	.0035	.061	0.938	0.10	10.075	.000	-.230	0.120	.625	.379

TABLE A.5. FRAPCON-2 Prediction for 15 x 15 PWR with 6.3 kW/ft for 20 GWd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2

BURN UP (GWd/MTU)	TIME (DAYs)	POWER (kW/m)	FUEL CENTER TEMP (C)	AVE TEMP (C)	AVE ENERGY (J/kg)	RADIAL GAP WIDTH (CM)	FRACTION OF CONDUCTANCE CONTACT GAS (%)	CUMMULATIVE ROD FIRE GAS (%)	INTERNAL GAS PRES (MPA)	XENON (MOLE FRAC)	FUEL DENS (%)	FUEL SHELL (%)	CLAD RADIUS (%)	AXIAL PERM RECOVER TOTAL	
0	0.01	0.01	274	274	0.67E+05	.0086	.000	0.999	0.00	6.733	.000	0.000	0.000	.070	0.10
0	0.03	2.98	343	312	0.78E+05	.0085	.000	0.999	0.00	6.986	.000	0.000	0.000	.074	0.10
0	0.06	5.96	416	392	0.89E+05	.0083	.000	0.999	0.00	7.241	.000	0.000	0.000	.078	0.11
1	0.09	8.94	493	393	0.10E+06	.0080	.000	0.999	0.00	7.498	.000	0.000	0.000	.082	0.11
1	0.12	11.92	576	436	0.11E+06	.0078	.000	0.999	0.00	7.756	.000	0.000	0.000	.085	0.11
2	0.15	14.90	663	481	0.13E+06	.0075	.000	0.999	0.00	8.015	.000	0.000	0.000	.089	0.11
3	0.18	17.88	755	526	0.14E+06	.0072	.000	0.999	0.00	8.275	.000	0.000	0.000	.093	0.11
4	0.21	20.86	842	568	0.16E+06	.0069	.000	0.999	0.00	8.514	.000	0.000	0.000	.096	0.11
14	0.30	20.59	842	568	0.16E+06	.0069	.000	0.999	0.00	8.513	.000	0.000	0.000	.096	0.11
32	1.00	20.59	842	568	0.16E+06	.0070	.000	0.999	0.00	8.494	.000	-.019	0.000	.097	0.11
866	25.00	20.59	844	570	0.16E+06	.0078	.000	0.999	0.00	8.210	.000	-.207	0.000	.178	.101
1735	50.00	20.59	822	561	0.15E+06	.0072	.000	0.999	0.01	8.307	.000	-.228	0.000	.349	.103
2604	75.00	20.59	800	551	0.15E+06	.0065	.000	0.999	0.02	8.452	.000	-.230	0.000	.515	.106
3473	100.00	20.59	780	543	0.15E+06	.0058	.000	0.999	0.03	8.613	.000	-.230	0.000	.678	.108
4342	125.00	20.59	762	536	0.15E+06	.0051	.000	0.999	0.04	8.785	.000	-.230	0.000	.817	.110
5211	150.00	20.59	746	528	0.14E+06	.0044	.000	0.999	0.05	8.966	.000	-.230	0.000	.973	.113
6080	175.00	20.59	739	526	0.14E+06	.0043	.020	0.979	0.05	9.008	.000	-.230	0.020	.880	.131
6949	200.00	20.59	736	524	0.14E+06	.0042	.019	0.980	0.06	9.022	.000	-.230	0.039	.888	.154
7818	225.00	20.59	733	522	0.14E+06	.0042	.018	0.981	0.07	9.035	.000	-.230	0.059	.888	.169
8687	250.00	20.59	730	521	0.14E+06	.0042	.020	0.979	0.08	9.043	.000	-.230	0.078	.882	.179
9556	275.00	20.59	728	519	0.14E+06	.0041	.023	0.976	0.09	9.060	.000	-.230	0.098	.881	.193
10425	300.00	20.59	726	518	0.14E+06	.0042	.027	0.972	0.10	9.070	.000	-.230	0.117	.849	.177
11294	325.00	20.59	726	519	0.14E+06	.0042	.023	0.976	0.10	9.081	.001	-.230	0.137	.829	.175
12136	350.00	20.59	726	519	0.14E+06	.0042	.023	0.977	0.11	9.094	.001	-.230	0.156	.812	.175
13032	375.00	20.59	726	519	0.14E+06	.0042	.022	0.977	0.12	9.108	.001	-.230	0.176	.794	.175
13901	400.00	20.59	726	519	0.14E+06	.0041	.022	0.977	0.13	9.122	.001	-.230	0.195	.776	.175
14770	425.00	20.59	726	520	0.14E+06	.0041	.022	0.977	0.14	9.137	.001	-.230	0.215	.759	.175
15639	450.00	20.59	726	520	0.14E+06	.0041	.022	0.977	0.14	9.152	.001	-.230	0.234	.741	.175
16509	475.00	20.59	726	521	0.14E+06	.0041	.022	0.976	0.15	9.167	.001	-.230	0.253	.724	.175
17378	500.00	20.59	726	521	0.14E+06	.0041	.022	0.976	0.16	9.183	.001	-.230	0.273	.706	.175
18247	525.00	20.59	727	521	0.14E+06	.0041	.022	0.976	0.17	9.199	.001	-.230	0.292	.688	.175
19116	550.00	20.59	727	522	0.14E+06	.0041	.022	0.976	0.18	9.215	.002	-.230	0.312	.670	.175
19985	575.00	20.59	728	522	0.14E+06	.0040	.022	0.976	0.19	9.232	.002	-.230	0.331	.652	.175
20970	600.00	23.34	799	557	0.15E+06	.0041	.036	0.963	0.19	9.397	.002	-.230	0.353	.603	.182
20971	600.03	26.32	882	599	0.16E+06	.0040	.034	0.964	0.20	9.369	.002	-.230	0.353	.603	.240
20973	600.06	29.80	966	638	0.18E+06	.0041	.026	0.953	0.20	9.725	.002	-.230	0.353	.603	.293
20974	600.09	32.28	1051	677	0.19E+06	.0040	.054	0.943	0.20	9.879	.002	-.230	0.353	.602	.336
20976	600.12	35.26	1134	716	0.20E+06	.0039	.059	0.940	0.20	10.029	.002	-.230	0.353	.602	.362
20978	600.15	38.24	1213	753	0.21E+06	.0037	.061	0.938	0.20	10.173	.002	-.230	0.353	.601	.373
20980	600.18	41.07	1281	786	0.22E+06	.0035	.062	0.937	0.20	10.302	.002	-.230	0.353	.601	.376

TABLE A.6. FRAPCON-2 Prediction for 8 x 8 BWR with 6.7 kW/ft for 1 Day, Ramp to 13.4 kW/ft,
P/A = 1.3

BURN UP (MHD/MTU)	TIME (DAYs)	POWER (kW/m)	FUEL CENTER TEMP (C)	AVE FUEL TEMP (C)	AVE STORED ENERGY (J/kg)	RADIAL GAP WIDTH (cm)	CONTACT GAS	FRACTION OF CUMMULATIVE ROD GAP	FISH GAS (%)	INTERNAL GAS PRES (MPA)	XENON (MOLE FRAC)	FUEL DENs (%)	FUEL SMELL (%)	CLAD RADIUS (%)	AXIAL PEMH RECOVER TOTAL
0	0.01	0.01	278	278	0.68E+05	.0108	,000	0.999	0.00	0.216	,000	0.000	0.000	,105	0.11
0	0.10	2.97	355	322	0.80E+05	.0105	,000	0.999	0.00	0.223	,000	0.000	0.000	,101	0.11
1	0.19	5.94	437	368	0.94E+05	.0102	,000	0.999	0.00	0.230	,000	0.000	0.000	,108	0.11
1	0.20	6.91	524	413	0.11E+06	.0099	,000	0.999	0.00	0.236	,000	0.000	0.000	,110	0.12
2	0.25	11.88	617	461	0.12E+06	.0095	,000	0.999	0.00	0.243	,000	0.000	0.000	,111	0.12
3	0.30	14.85	713	510	0.14E+06	.0091	,000	0.999	0.00	0.249	,000	0.000	0.000	,113	0.12
4	0.35	17.83	814	560	0.15E+06	.0088	,000	0.999	0.00	0.256	,000	0.000	0.000	,114	0.12
6	0.40	20.80	918	612	0.17E+06	.0084	,000	0.999	0.00	0.262	,000	0.000	0.000	,116	0.12
7	0.45	21.79	954	629	0.17E+06	.0082	,000	0.999	0.00	0.264	,000	0.000	0.000	,117	0.12
23	1.00	21.79	955	629	0.17E+06	.0083	,000	0.999	0.00	0.264	,000	-0.015	0.000	,117	0.12
24	1.03	23.77	1026	664	0.19E+06	.0080	,000	0.999	0.00	0.268	,000	-0.016	0.000	,118	0.12
25	1.06	26.74	1136	717	0.20E+06	.0076	,000	0.999	0.00	0.273	,000	-0.017	0.000	,120	0.12
29	1.09	29.71	1247	769	0.22E+06	.0071	,000	0.999	0.00	0.279	,000	-0.018	0.000	,121	0.12
26	1.12	32.68	1327	821	0.23E+06	.0067	,000	0.999	0.01	0.284	,000	-0.020	0.000	,123	0.12
29	1.15	35.65	1418	872	0.25E+06	.0063	,000	0.999	0.02	0.290	,000	-0.021	0.000	,124	0.13
31	1.18	38.62	2758	924	0.27E+06	.0058	,000	0.999	0.04	0.295	,000	-0.022	0.000	,126	0.13
32	1.21	41.59	1617	974	0.29E+06	.0057	,022	0.977	0.08	0.299	,000	-0.024	0.000	,127	0.16
34	1.24	43.53	1700	1014	0.30E+06	.0056	,049	0.950	0.14	0.302	,000	-0.025	0.000	,127	0.22

TABLE A.7. FRAPCON-2 Prediction for 8 x 8 BWR with 6.7 kW/ft for 10 Gwd/MTM, Ramp to 13.4 kW/ft, P/A = 1.3

BURN UP (MWD/MTU)	TIME (DAYs)	POWER (kW/m)	FUEL CENTER TEMP (C)	AVE TEMP (C)	AVE ENERGY (J/kg)	RADIAL WIDTH (cm)	GAP CONTACT GAS	RADIAL FRACTION OF CUMMULATIVE ROD			INTERNAL FIBR GAS (%)	XENON GAS PRES (MPA)	FUEL DENs (MOLE FRAC)	FUEL SWELL (%)	CLAD (%)	RADIUS (X)	AXIAL PERM RECOVER TOTAL
								GAP WIDTH (cm)	ROD CONDUCTANCE (W/cm)	ROD INTERNAL FIBR GAS (%)							
0	0.01	0.01	278	278	0.68E+05	.0108	.000	0.999	0.00	0.214	.000	0.000	0.000	0.000	.105	0.11	
0	0.10	2.97	355	322	0.80E+05	.0105	.000	0.999	0.00	0.223	.000	0.000	0.000	-.001	.106	0.11	
1	0.15	5.94	437	366	0.94E+05	.0102	.000	0.999	0.00	0.230	.000	0.000	0.000	-.001	.108	0.11	
1	0.20	8.91	524	413	0.11E+06	.0099	.000	0.999	0.00	0.236	.000	0.000	0.000	-.001	.110	0.12	
2	0.25	11.88	617	461	0.12E+06	.0095	.000	0.999	0.00	0.243	.000	0.000	0.000	-.001	.111	0.12	
3	0.30	14.85	713	510	0.14E+06	.0091	.000	0.999	0.00	0.249	.000	0.000	0.000	-.002	.113	0.12	
4	0.35	17.83	814	560	0.15E+06	.0088	.000	0.999	0.00	0.256	.000	0.000	0.000	-.002	.114	0.12	
6	0.40	20.80	918	612	0.17E+06	.0084	.000	0.999	0.00	0.262	.000	0.000	0.000	-.002	.116	0.12	
7	0.45	21.79	954	629	0.17E+06	.0082	.000	0.999	0.00	0.264	.000	0.000	0.000	-.003	.117	0.12	
23	1.00	21.79	955	629	0.17E+06	.0083	.000	0.999	0.00	0.264	.000	-.015	0.000	-.006	.117	0.12	
52	2.00	21.79	956	629	0.17E+06	.0084	.000	0.999	0.00	0.263	.000	-.032	0.000	-.012	.118	0.12	
139	5.00	21.79	958	631	0.17E+06	.0086	.000	0.999	0.00	0.262	.000	-.076	0.000	-.030	.120	0.13	
285	10.00	21.79	960	631	0.17E+06	.0088	.000	0.999	0.00	0.261	.000	-.130	0.000	-.059	.122	0.13	
866	30.00	21.79	961	632	0.18E+06	.0091	.000	0.999	0.01	0.259	.000	-.221	0.000	-.172	.126	0.14	
1447	50.00	21.79	943	624	0.17E+06	.0087	.000	0.999	0.01	0.260	.000	-.240	0.000	-.281	.127	0.14	
2028	70.00	21.79	924	617	0.17E+06	.0082	.000	0.999	0.02	0.261	.000	-.245	0.000	-.390	.128	0.15	
2609	90.00	21.79	907	609	0.17E+06	.0077	.000	0.999	0.02	0.263	.000	-.245	0.000	-.499	.128	0.15	
3191	110.00	21.79	890	602	0.17E+06	.0071	.000	0.999	0.03	0.265	.001	-.246	0.000	-.608	.129	0.15	
3772	130.00	21.79	874	595	0.16E+06	.0066	.000	0.999	0.03	0.267	.001	-.246	0.000	-.717	.129	0.16	
4533	150.00	21.79	859	588	0.16E+06	.0061	.000	0.999	0.04	0.269	.001	-.246	0.000	-.765	.130	0.16	
4934	170.00	21.79	851	586	0.16E+06	.0059	.000	0.999	0.04	0.270	.002	-.246	0.000	-.769	.130	0.16	
5915	190.00	21.79	848	584	0.16E+06	.0058	.000	0.999	0.05	0.270	.002	-.246	0.000	-.772	.130	0.17	
6096	210.00	21.79	844	582	0.16E+06	.0058	.026	0.973	0.05	0.270	.003	-.246	0.013	-.786	.132	0.17	
6678	230.00	21.79	842	581	0.16E+06	.0058	.025	0.974	0.06	0.271	.003	-.246	0.027	-.795	.134	0.17	
7259	250.00	21.79	839	579	0.16E+06	.0058	.025	0.974	0.06	0.271	.004	-.246	0.040	-.795	.139	0.18	
7840	270.00	21.79	837	578	0.16E+06	.0058	.028	0.971	0.07	0.271	.005	-.246	0.053	-.793	.188	0.19	
8421	290.00	21.79	834	577	0.16E+06	.0058	.032	0.967	0.08	0.272	.006	-.246	0.067	-.793	.197	0.19	
9002	310.00	21.79	832	576	0.16E+06	.0057	.036	0.963	0.08	0.272	.006	-.246	0.080	-.776	.190	0.21	
9583	330.00	21.79	832	577	0.16E+06	.0058	.034	0.965	0.09	0.273	.007	-.246	0.093	-.775	.199	0.21	
10165	350.00	21.79	830	576	0.16E+06	.0057	.037	0.961	0.09	0.273	.008	-.246	0.106	-.753	.187	0.23	
10600	365.00	21.79	830	576	0.16E+06	.0057	.032	0.967	0.10	0.274	.009	-.246	0.116	-.762	.187	0.24	
10601	365.03	23.77	891	604	0.17E+06	.0057	.047	0.952	0.10	0.276	.009	-.246	0.116	-.742	.228	0.27	
10602	365.06	26.74	984	649	0.18E+06	.0058	.071	0.928	0.10	0.280	.009	-.246	0.116	-.742	.286	0.32	
10604	365.09	29.71	1078	693	0.19E+06	.0057	.088	0.911	0.10	0.283	.009	-.246	0.116	-.742	.323	0.37	
10605	365.12	32.68	1167	734	0.21E+06	.0055	.097	0.902	0.10	0.287	.009	-.246	0.116	-.741	.337	0.42	
10606	365.15	35.65	1245	772	0.22E+06	.0052	.100	0.899	0.10	0.290	.009	-.246	0.116	-.741	.339	0.45	
10608	365.18	38.62	1318	779	0.23E+06	.0049	.101	0.898	0.10	0.293	.009	-.246	0.116	-.741	.338	0.49	
10610	365.21	41.59	1370	841	0.24E+06	.0046	.102	0.897	0.10	0.295	.009	-.246	0.116	-.740	.336	0.52	
10611	365.24	43.53	1811	861	0.25E+06	.0043	.099	0.900	0.10	0.297	.009	-.246	0.116	-.740	.327	0.54	
10669	366.24	43.53	1396	857	0.25E+06	.0041	.091	0.907	0.20	0.300	.018	-.246	0.115	-.740	.227	0.52	

TABLE A.8. FRAPCON-2 Prediction for 8 x 8 BWR with 6.7 kW/ft for 20 GWD/MTM, Ramp to 13.4 kW/ft, P/A = 1.3

BURN UP (HHD/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL	AVE	AVE	RADIAL	FRACTION OF CUMULATIVE	ROU	FUEL DENS	FUEL SHELL (%)	CLAD RADIUS	AXIAL
			CENTER TEMP (C)	FUEL TEMP (C)	STORED ENERGY (J/kg)	GAP WIDTH (cm)	GAP CONTACT GAS (%)	F188 GAS (%)		(%)	(%)	PERM RECOVER TOTAL
0	0.01	0.01	278	278	0.68E+05	.0108	.000 0.999	0.00	0.216	.000	0.000 0.000	0.000 .105
0	0.10	2.97	355	322	0.80E+05	.0105	.000 0.999	0.00	0.223	.000	0.000 0.000	=.001 .106
1	0.15	5.94	437	366	0.94E+05	.0102	.000 0.999	0.00	0.230	.000	0.000 0.000	=.001 .108
1	0.20	8.91	524	413	0.11E+06	.0099	.000 0.999	0.00	0.236	.000	0.000 0.000	=.001 .110
2	0.25	11.88	617	461	0.12E+06	.0095	.000 0.999	0.00	0.243	.000	0.000 0.000	=.001 .111
3	0.30	14.85	713	510	0.14E+06	.0091	.000 0.999	0.00	0.249	.000	0.000 0.000	=.002 .113
4	0.35	17.83	814	560	0.15E+06	.0088	.000 0.999	0.00	0.256	.000	0.000 0.000	=.002 .114
6	0.40	20.80	918	612	0.17E+06	.0084	.000 0.999	0.00	0.262	.000	0.000 0.000	=.002 .116
7	0.45	21.79	950	629	0.17E+06	.0082	.000 0.999	0.00	0.264	.000	0.000 0.000	=.003 .117
23	1.00	21.79	955	629	0.17E+06	.0083	.000 0.999	0.00	0.264	.000	=.015 0.000	=.006 .117
52	2.00	21.79	956	629	0.17E+06	.0084	.000 0.999	0.00	0.263	.000	=.032 0.000	=.012 .118
139	5.00	21.79	958	631	0.17E+06	.0086	.000 0.999	0.00	0.262	.000	=.076 0.000	=.030 .120
285	10.00	21.79	960	631	0.17E+06	.0088	.000 0.999	0.00	0.261	.000	=.130 0.000	=.059 .122
866	30.00	21.79	961	632	0.18E+06	.0091	.000 0.999	0.01	0.259	.000	=.221 0.000	=.172 .126
1447	50.00	21.79	943	624	0.17E+06	.0087	.000 0.999	0.01	0.260	.000	=.240 0.000	=.281 .127
2026	70.00	21.79	924	617	0.17E+06	.0082	.000 0.999	0.02	0.261	.000	=.245 0.000	=.390 .128
2609	90.00	21.79	907	609	0.17E+06	.0077	.000 0.999	0.02	0.263	.000	=.245 0.000	=.499 .126
3191	110.00	21.79	890	602	0.17E+06	.0071	.000 0.999	0.03	0.265	.001	=.246 0.000	=.608 .129
3772	130.00	21.79	874	595	0.16E+06	.0066	.000 0.999	0.03	0.267	.001	=.246 0.000	=.717 .129
4533	150.00	21.79	859	588	0.16E+06	.0061	.000 0.999	0.04	0.269	.001	=.246 0.000	=.765 .130
4934	170.00	21.79	851	586	0.16E+06	.0059	.000 0.999	0.04	0.270	.002	=.246 0.000	=.769 .130
5515	190.00	21.79	848	584	0.16E+06	.0056	.000 0.999	0.05	0.270	.002	=.246 0.000	=.792 .130
6096	210.00	21.79	844	582	0.16E+06	.0056	.026 0.973	0.05	0.270	.003	=.246 0.013	=.786 .152
6678	230.00	21.79	842	581	0.16E+06	.0058	.025 0.974	0.06	0.271	.003	=.246 0.027	=.795 .169
7259	250.00	21.79	839	579	0.16E+06	.0056	.025 0.974	0.06	0.271	.004	=.246 0.040	=.795 .179
7840	270.00	21.79	837	578	0.16E+06	.0056	.028 0.971	0.07	0.271	.005	=.246 0.053	=.793 .188
8421	290.00	21.79	834	577	0.16E+06	.0058	.032 0.967	0.08	0.272	.006	=.246 0.067	=.793 .197
9002	310.00	21.79	832	576	0.16E+06	.0057	.036 0.963	0.08	0.272	.006	=.246 0.080	=.776 .190
9583	330.00	21.79	832	577	0.16E+06	.0056	.038 0.965	0.09	0.273	.007	=.246 0.093	=.775 .199
10165	350.00	21.79	830	576	0.16E+06	.0057	.037 0.961	0.09	0.273	.008	=.246 0.106	=.753 .187
10600	365.00	21.79	830	576	0.16E+06	.0057	.032 0.967	0.10	0.274	.009	=.246 0.116	=.742 .187
10891	375.00	21.79	831	577	0.16E+06	.0057	.030 0.969	0.10	0.274	.009	=.246 0.122	=.737 .187
11617	400.00	21.79	828	576	0.16E+06	.0057	.033 0.965	0.10	0.274	.011	=.246 0.139	=.721 .185
12344	425.00	21.79	828	576	0.16E+06	.0057	.033 0.966	0.11	0.275	.012	=.246 0.155	=.707 .185
13070	450.00	21.79	827	576	0.16E+06	.0056	.033 0.965	0.12	0.275	.013	=.246 0.171	=.692 .185
13797	475.00	21.79	826	576	0.16E+06	.0057	.033 0.965	0.13	0.276	.015	=.246 0.188	=.678 .185
14523	500.00	21.79	826	576	0.16E+06	.0057	.033 0.965	0.13	0.277	.016	=.246 0.204	=.663 .185
15250	525.00	21.79	825	576	0.16E+06	.0057	.033 0.965	0.14	0.277	.018	=.246 0.220	=.649 .185
15976	550.00	21.79	825	576	0.16E+06	.0057	.034 0.965	0.15	0.278	.020	=.246 0.237	=.634 .185
16703	575.00	21.79	824	577	0.16E+06	.0054	.034 0.964	0.15	0.279	.022	=.246 0.253	=.620 .185
17429	600.00	21.79	824	577	0.16E+06	.0056	.034 0.964	0.16	0.280	.024	=.246 0.269	=.605 .185
18156	625.00	21.79	824	577	0.16E+06	.0057	.034 0.964	0.17	0.281	.026	=.246 0.285	=.591 .185
18882	650.00	21.79	824	577	0.16E+06	.0057	.034 0.964	0.17	0.282	.028	=.246 0.302	=.576 .185
19609	675.00	21.79	824	578	0.16E+06	.0057	.035 0.964	0.18	0.283	.030	=.246 0.318	=.561 .185
20335	700.00	21.79	824	578	0.16E+06	.0056	.035 0.963	0.19	0.284	.032	=.246 0.334	=.546 .185
20916	720.00	21.79	824	578	0.16E+06	.0056	.034 0.964	0.19	0.284	.034	=.246 0.347	=.535 .186
21207	730.00	21.79	826	579	0.16E+06	.0056	.031 0.967	0.20	0.285	.035	=.246 0.353	=.529 .187
21208	730.03	23.77	884	608	0.17E+06	.0057	.049 0.969	0.20	0.288	.035	=.246 0.353	=.529 .227
21209	730.06	26.74	971	650	0.18E+06	.0056	.074 0.924	0.20	0.292	.035	=.246 0.354	=.529 .284
21210	730.09	29.71	1065	693	0.19E+06	.0055	.092 0.906	0.20	0.293	.035	=.246 0.354	=.529 .321
21211	730.12	32.68	1150	734	0.21E+06	.0054	.101 0.897	0.20	0.299	.035	=.246 0.354	=.528 .336
21213	730.15	35.65	1226	772	0.22E+06	.0052	.105 0.894	0.20	0.302	.035	=.246 0.354	=.528 .338
21214	730.18	38.62	1297	807	0.23E+06	.0049	.106 0.893	0.20	0.305	.035	=.246 0.354	=.527 .336
21216	730.21	41.59	1349	841	0.24E+06	.0045	.107 0.892	0.20	0.308	.035	=.246 0.354	=.527 .335
21218	730.24	43.53	1387	861	0.25E+06	.0042	.104 0.895	0.20	0.310	.035	=.246 0.354	=.527 .325
21276	731.24	43.53	1380	861	0.25E+06	.0040	.103 0.896	0.42	0.324	.071	=.246 0.355	=.526 .228

TABLE A.9. FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 1 Day, Ramp to 12.6 kW/ft
P/A = 1.2

BURN UP (MWD/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL CENTER TEMP (C)	AVE FUEL TEMP (C)	AVE STORED ENERGY (J/kg)	RADIAL FRACTION OF CUMMULATIVE ROD CONTACT GAS	ROD CONDUCTANCE GAP WIDTH (CM)	INTERNAL FISS GAS GAS FRES (MOLE FRAC)	XENON (MPA)	FUEL DENS (%)	AXIAL PERM RECOVER TOTAL		
											ROD INTERNAL XENON (%)	FUEL FUEL CLAD RADIUS (%)	
0	0.01	0.01	274	274	0.67E+05	.0086	.000 0.999	0.00	6,733	.000	0.000 0.000	0.000 .070	0.10
0	0.03	2.98	343	312	0.78E+05	.0085	.000 0.999	0.00	6,986	.000	0.000 0.000	0.000 .074	0.10
0	0.06	5.96	416	352	0.89E+05	.0083	.000 0.999	0.00	7,241	.000	0.000 0.000	0.000 .078	0.11
1	0.09	8.94	493	393	0.10E+06	.0080	.000 0.999	0.00	7,498	.000	0.000 0.000	-.001 .082	0.11
1	0.12	11.92	576	436	0.11E+06	.0078	.000 0.999	0.00	7,756	.000	0.000 0.000	-.001 .085	0.11
2	0.15	14.90	663	481	0.13E+06	.0075	.000 0.999	0.00	8,015	.000	0.000 0.000	-.001 .089	0.11
3	0.18	17.88	755	526	0.14E+06	.0072	.000 0.999	0.00	8,275	.000	0.000 0.000	-.001 .093	0.11
4	0.21	20.86	850	573	0.16E+06	.0070	.000 0.999	0.00	8,538	.000	0.000 0.000	-.002 .097	0.11
5	0.24	23.84	949	621	0.17E+06	.0068	.000 0.999	0.00	8,801	.000	0.000 0.000	-.002 .100	0.11
7	0.27	26.82	1051	669	0.19E+06	.0063	.000 0.999	0.00	9,066	.000	0.000 0.000	-.002 .104	0.11
8	0.30	28.76	1119	701	0.20E+06	.0060	.000 0.999	0.00	9,238	.000	0.000 0.000	-.002 .107	0.12
16	0.50	28.76	1119	701	0.20E+06	.0060	.000 0.999	0.00	9,237	.000	0.000 0.000	-.004 .107	0.12
42	1.00	28.76	1121	702	0.20E+06	.0061	.000 0.999	0.00	9,400	.000	-.027 0.000	-.007 .107	0.12
44	1.03	31.29	1211	744	0.21E+06	.0058	.000 0.999	0.01	9,424	.000	-.029 0.000	-.007 .110	0.12
45	1.06	34.27	1317	794	0.23E+06	.0055	.000 0.999	0.01	9,482	.000	-.031 0.000	-.007 .114	0.12
47	1.09	37.25	1391	842	0.24E+06	.0051	.000 0.999	0.02	9,932	.000	-.033 0.000	-.008 .118	0.12
49	1.12	40.23	1488	892	0.26E+06	.0047	.000 0.999	0.03	10,189	.000	-.034 0.000	-.008 .121	0.12
52	1.15	43.09	1516	907	0.26E+06	.0046	.000 0.999	0.05	10,256	.000	-.036 0.000	-.008 .122	0.12
121	2.15	41.07	1513	908	0.26E+06	.0046	.000 0.999	0.14	10,186	.000	-.076 0.000	-.014 .123	0.12
129	2.30	30.79	1145	732	0.21E+06	.0062	.000 0.999	0.16	9,264	.000	-.080 0.000	-.015 .110	0.12
132	2.40	20.86	817	569	0.16E+06	.0073	.000 0.999	0.16	8,393	.000	-.081 0.000	-.016 .097	0.12
134	2.50	10.93	532	420	0.11E+06	.0082	.000 0.999	0.16	7,550	.000	-.082 0.000	-.016 .085	0.11
138	2.60	0.99	295	287	0.70E+06	.0089	.000 0.999	0.16	6,729	.000	-.082 0.000	-.017 .073	0.11
136	2.70	10.93	532	420	0.11E+06	.0082	.000 0.999	0.16	7,351	.000	-.082 0.000	-.018 .065	0.11
140	2.80	20.86	817	569	0.16E+06	.0073	.000 0.999	0.16	8,393	.000	-.084 0.000	-.019 .097	0.12
145	2.90	30.79	1144	731	0.21E+06	.0061	.000 0.999	0.16	9,257	.000	-.086 0.000	-.019 .110	0.12
152	3.00	41.07	1518	907	0.26E+06	.0049	.000 0.999	0.17	10,167	.000	-.092 0.000	-.020 .123	0.12

TABLE A.10. FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 2 Gwd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2

BURN UP (MHD/MTU)	TIME (DAY8)	POWER (kW/m)	FUEL	AVE	AVE	RADIAL FRACTION OF CUMULATIVE ROD			FUEL DENS	FUEL SHELL (%)	CLAD (%)	RADIIUM (%)	AXIAL PERM TOTAL		
			CENTER	TEMP (C)	TEMP (C)	STORED ENERGY (J/kg)	GAP WIDTH (cm)	GAP CONDUCTANCE (%)	ROD F188 GAS (%)	INTERNAL GAS PRES (MPA)	XENON MOLE FRC				
0	0.01	0.01	274	274	0.67E+05	.0086	.000	0.999	0.00	6.733	.000	0.000	0.000	.070	0.10
0	0.03	2.96	343	276	0.78E+05	.0085	.000	0.999	0.00	6.986	.000	0.000	0.000	.074	0.10
0	0.06	5.96	416	352	0.89E+05	.0083	.000	0.999	0.00	7.241	.000	0.000	0.000	.082	0.11
1	0.09	8.94	493	393	0.10E+06	.0080	.000	0.999	0.00	7.496	.000	0.000	0.000	.085	0.11
1	0.12	11.92	576	436	0.11E+06	.0078	.000	0.999	0.00	7.756	.000	0.000	0.000	.085	0.11
2	0.15	14.90	663	481	0.13E+06	.0075	.000	0.999	0.00	8.015	.000	0.000	0.000	.089	0.11
3	0.18	17.88	755	526	0.14E+06	.0072	.000	0.999	0.00	8.275	.000	0.000	0.000	.093	0.11
4	0.21	20.86	850	573	0.16E+06	.0070	.000	0.999	0.00	8.536	.000	0.000	0.000	.097	0.11
5	0.24	23.84	749	621	0.17E+06	.0066	.000	0.999	0.00	8.801	.000	0.000	0.000	.100	0.11
7	0.27	26.82	1051	669	0.19E+06	.0063	.000	0.999	0.00	9.066	.000	0.000	0.000	.102	0.11
8	0.30	28.76	1119	701	0.20E+06	.0060	.000	0.999	0.00	9.236	.000	0.000	0.000	.102	0.12
16	0.50	25.76	1119	701	0.20E+06	.0060	.000	0.999	0.00	9.237	.000	0.000	0.000	.107	0.12
42	1.00	28.76	1121	702	0.20E+06	.0061	.000	0.999	0.00	9.200	.000	-.027	0.000	.107	0.12
91	2.00	28.76	1122	702	0.20E+06	.0063	.000	0.999	0.01	9.162	.000	-.055	0.000	.107	0.12
236	5.00	28.76	1123	703	0.20E+06	.0065	.000	0.999	0.01	9.071	.000	-.120	0.000	.109	0.12
625	13.00	28.76	1126	703	0.20E+06	.0068	.000	0.999	0.02	8.943	.000	-.209	0.000	.111	0.13
1207	25.00	28.76	1116	700	0.20E+06	.0068	.000	0.999	0.03	8.901	.000	-.248	0.000	.113	0.13
2033	42.00	28.76	1099	693	0.19E+06	.0066	.000	0.999	0.03	8.925	.000	-.257	0.000	.119	0.14
2034	42.03	31.29	1172	728	0.21E+06	.0059	.000	0.999	0.03	9.269	.000	-.268	0.000	.122	0.14
2036	42.06	34.27	1275	777	0.22E+06	.0055	.000	0.999	0.04	9.441	.000	-.266	0.000	.122	0.14
2038	42.09	37.25	1354	824	0.24E+06	.0052	.000	0.999	0.04	9.673	.000	-.278	0.000	.126	0.14
2040	42.12	40.23	1446	873	0.25E+06	.0048	.000	0.999	0.05	9.902	.000	-.278	0.000	.129	0.14
2042	42.15	41.07	1474	887	0.26E+06	.0047	.000	0.999	0.05	9.967	.000	-.278	0.000	.130	0.14

TABLE A.11. FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 10 Gwd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2

BURN UP (HWD/HTU)	TIME (DAYS)	POWER (kW/m)	CENTER FUEL TEMP (C)	AVE TEMP (C)	AVE ENERGY (J/kg)	RADIAL FRACTION OF CUMMULATIVE ROD WIDTH (CM)	GAP CONTACT GAS (%)	CONDUCTANCE GAP (%)	ROD FIBER GAS (%)	INTERNAL GAS PRESSURE (MPA)	XENON MOLE DENS (X)	CLAD RADIUS (%)		AXIAL PERM RECOVER TOTAL		
												FUEL DENS (%)	FUEL SWELL (%)			
0	0.01	0.01	274	274	0.67E+05	.0086	.000	0.999	0.00	6.733	.000	0.000	0.000	0.000	.070	0.10
0	0.03	2.98	343	312	0.78E+05	.0085	.000	0.999	0.00	6.986	.000	0.000	0.000	0.000	.074	0.10
0	0.06	5.96	416	392	0.89E+05	.0083	.000	0.999	0.00	7.241	.000	0.000	0.000	0.000	.078	0.11
1	0.09	8.94	493	393	0.10E+06	.0080	.000	0.999	0.00	7.498	.000	0.000	0.000	0.001	.082	0.11
1	0.12	11.92	576	436	0.11E+06	.0076	.000	0.999	0.00	7.756	.000	0.000	0.000	0.001	.085	0.11
2	0.15	14.90	663	481	0.13E+06	.0075	.000	0.999	0.00	8.015	.000	0.000	0.000	0.001	.089	0.11
3	0.18	17.88	755	526	0.14E+06	.0072	.000	0.999	0.00	8.275	.000	0.000	0.000	0.001	.093	0.11
4	0.21	20.86	850	573	0.16E+06	.0070	.000	0.999	0.00	8.538	.000	0.000	0.000	0.002	.097	0.11
5	0.24	23.84	949	621	0.17E+06	.0066	.000	0.999	0.00	8.801	.000	0.000	0.000	0.002	.100	0.11
7	0.27	26.82	1051	669	0.19E+06	.0063	.000	0.999	0.00	9.066	.000	0.000	0.000	0.002	.104	0.11
8	0.30	28.76	1119	701	0.20E+06	.0060	.000	0.999	0.00	9.238	.000	0.000	0.000	0.002	.107	0.12
18	0.50	28.76	1119	701	0.20E+06	.0060	.000	0.999	0.00	9.237	.000	0.000	0.000	0.004	.107	0.12
42	1.00	28.76	1121	702	0.20E+06	.0061	.000	0.999	0.00	9.200	.000	-0.027	0.000	-0.007	.107	0.12
139	3.00	28.76	1123	703	0.20E+06	.0064	.000	0.999	0.01	9.126	.000	-0.080	0.000	-0.020	.108	0.12
382	8.00	28.76	1126	704	0.20E+06	.0067	.000	0.999	0.01	9.007	.000	-0.164	0.000	-0.054	.110	0.12
722	15.00	28.76	1123	702	0.20E+06	.0068	.000	0.999	0.02	8.918	.000	-0.220	0.000	-0.099	.112	0.13
1693	35.00	28.76	1111	698	0.20E+06	.0068	.000	0.999	0.03	8.884	.000	-0.255	0.000	-0.227	.114	0.14
2664	55.00	28.76	1085	688	0.19E+06	.0063	.000	0.999	0.04	8.965	.000	-0.258	0.000	-0.351	.116	0.14
3635	75.00	28.76	1061	678	0.19E+06	.0058	.000	0.999	0.04	9.060	.000	-0.258	0.000	-0.472	.118	0.15
4605	95.00	28.76	1039	669	0.19E+06	.0053	.000	0.999	0.05	9.163	.000	-0.258	0.000	-0.502	.119	0.15
5576	115.00	28.76	1018	661	0.18E+06	.0049	.000	0.999	0.05	9.273	.000	-0.258	0.000	-0.710	.121	0.15
6547	135.00	28.76	997	652	0.18E+06	.0042	.000	0.999	0.06	9.406	.000	-0.258	0.024	-0.715	.123	0.16
7518	155.00	28.76	992	649	0.18E+06	.0042	.019	0.980	0.07	9.425	.000	-0.258	0.047	-0.721	.142	0.14
8489	175.00	28.76	986	647	0.18E+06	.0041	.018	0.981	0.08	9.450	.000	-0.258	0.070	-0.732	.170	0.15
9460	195.00	28.76	981	644	0.18E+06	.0041	.018	0.981	0.08	9.496	.000	-0.258	0.093	-0.729	.182	0.16
10432	215.00	28.76	977	642	0.18E+06	.0042	.021	0.978	0.09	9.537	.000	-0.258	0.116	-0.718	.189	0.18
10432	215.03	31.29	1053	677	0.19E+06	.0041	.033	0.967	0.10	9.677	.000	-0.258	0.116	-0.718	.242	0.22
10434	215.06	34.27	1146	718	0.20E+06	.0041	.045	0.954	0.10	9.824	.000	-0.258	0.116	-0.718	.303	0.28
10436	215.09	37.25	1239	759	0.22E+06	.0040	.054	0.954	0.10	9.970	.000	-0.258	0.116	-0.717	.350	0.34
10438	215.12	40.23	1329	799	0.23E+06	.0040	.059	0.941	0.10	10.110	.000	-0.258	0.116	-0.717	.376	0.39
10440	215.15	41.07	1341	806	0.23E+06	.0038	.057	0.943	0.10	10.144	.000	-0.258	0.116	-0.716	.380	0.39
10510	216.15	41.07	1329	802	0.23E+06	.0037	.054	0.946	0.14	10.142	.001	-0.258	0.118	-0.710	.261	0.37
10517	216.30	30.79	1002	659	0.18E+06	.0037	.000	0.999	0.14	9.540	.001	-0.258	0.118	-0.711	.127	0.18
10521	216.40	20.86	730	523	0.14E+06	.0047	.000	0.999	0.14	8.791	.001	-0.258	0.116	-0.711	.116	0.18
10523	216.50	10.93	493	398	0.10E+06	.0053	.000	0.999	0.14	8.057	.001	-0.258	0.116	-0.712	.105	0.18
10523	216.60	0.99	292	289	0.70E+05	.0059	.000	0.999	0.14	7.331	.001	-0.258	0.116	-0.713	.094	0.17
10525	216.70	10.93	493	398	0.10E+06	.0053	.000	0.999	0.14	8.059	.001	-0.258	0.116	-0.713	.105	0.18
10528	216.80	20.86	730	523	0.14E+06	.0047	.000	0.999	0.14	8.795	.001	-0.258	0.116	-0.714	.116	0.18
10533	216.90	30.79	1001	659	0.18E+06	.0037	.000	0.999	0.14	9.803	.001	-0.258	0.119	-0.714	.127	0.18
10540	217.00	41.07	1303	798	0.23E+06	.0033	.033	0.966	0.14	10.134	.001	-0.258	0.119	-0.714	.248	0.27

TABLE A.12. FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 20 GWd/MTM, Ramp to 12.6 kW/ft, P/A = 1.2

BURN UP (MWD/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL	AVE	AVE	RADIAL FRACTION OF CUMMULATIVE ROD	ROD INTERNAL XENON	FUEL	FUEL	CLAD RADIUS	AZIAL
			CENTER FUEL TEMP (C)	STORED FUEL TEMP (C)	ENERGY (J/kg)			GAP WIDTH (cm)	CONTACT GAP (E)	FI88 GAS (MPA)	GAS PREC (MOLE FRAC)
8	0.30	28.76	1119	701	0.20E+06	.0060	.000	0.999	0.00	9.838	.000 0.000 0.000
10	0.50	28.76	1119	701	0.20E+06	.0060	.000	0.999	0.00	9.237	.000 0.000 0.000
42	1.00	28.76	1121	702	0.20E+06	.0061	.000	0.999	0.00	9.200	.000 0.000 0.000
139	3.00	28.76	1123	703	0.20E+06	.0064	.000	0.999	0.01	9.124	.000 0.000 0.000
382	8.00	28.76	1126	704	0.20E+06	.0067	.000	0.999	0.01	9.007	.000 0.164 0.000
722	15.00	28.76	1123	702	0.20E+06	.0068	.000	0.999	0.02	8.938	.000 0.220 0.000
1693	35.00	28.76	1111	698	0.20E+06	.0068	.000	0.999	0.03	8.884	.000 0.255 0.000
2664	55.00	28.76	1088	688	0.19E+06	.0063	.000	0.999	0.04	8.965	.000 0.256 0.000
3635	75.00	28.76	1061	678	0.19E+06	.0058	.000	0.999	0.04	9.060	.000 0.258 0.000
4605	95.00	28.76	1039	669	0.19E+06	.0053	.000	0.999	0.05	9.163	.000 0.258 0.000
5576	115.00	28.76	1010	661	0.18E+06	.0049	.000	0.999	0.05	9.273	.000 0.258 0.000
6547	135.00	28.76	997	652	0.18E+06	.0042	.000	0.999	0.06	9.406	.000 0.258 0.024
7518	155.00	28.76	992	649	0.18E+06	.0042	.019	0.980	0.07	9.425	.000 0.258 0.047
8489	175.00	28.76	986	647	0.18E+06	.0041	.018	0.981	0.08	9.450	.000 0.258 0.070
9460	195.00	28.76	981	644	0.18E+06	.0041	.018	0.981	0.09	9.496	.000 0.258 0.093
10432	215.00	28.76	977	642	0.18E+06	.0042	.021	0.978	0.09	9.517	.000 0.258 0.116
11402	235.00	28.76	974	641	0.18E+06	.0042	.021	0.976	0.10	9.560	.001 0.258 0.138
12373	255.00	28.76	973	641	0.18E+06	.0042	.022	0.977	0.11	9.571	.001 0.258 0.160
13344	275.00	28.76	972	641	0.18E+06	.0042	.022	0.977	0.12	9.587	.001 0.258 0.182
14314	295.00	28.76	971	641	0.18E+06	.0042	.022	0.977	0.13	9.604	.001 0.258 0.204
15285	315.00	28.76	971	641	0.18E+06	.0041	.022	0.977	0.14	9.623	.001 0.258 0.226
16256	335.00	28.76	970	641	0.18E+06	.0041	.022	0.977	0.15	9.642	.001 0.258 0.248
17227	355.00	28.76	970	641	0.18E+06	.0041	.022	0.977	0.16	9.661	.001 0.258 0.270
18198	375.00	28.76	969	642	0.18E+06	.0040	.022	0.977	0.17	9.681	.001 0.258 0.292
19169	395.00	28.76	970	642	0.18E+06	.0040	.022	0.977	0.18	9.701	.002 0.258 0.313
20140	415.00	28.76	970	642	0.18E+06	.0040	.022	0.977	0.19	9.722	.002 0.258 0.335
20866	430.00	28.76	971	643	0.18E+06	.0041	.021	0.978	0.19	9.740	.002 0.258 0.351
20870	430.03	31.29	1047	678	0.19E+06	.0040	.032	0.967	0.20	9.877	.002 0.258 0.358
20871	430.06	34.87	1136	719	0.20E+06	.0040	.043	0.954	0.20	10.030	.002 0.258 0.358
20873	430.09	37.29	1287	760	0.22E+06	.0040	.054	0.945	0.20	10.183	.002 0.258 0.352
20875	430.12	40.23	1314	799	0.23E+06	.0039	.059	0.940	0.20	10.331	.002 0.258 0.352
20877	430.15	41.07	1326	906	0.23E+06	.0037	.057	0.942	0.20	10.365	.002 0.258 0.352

TABLE A.13. FRAPCON-2 Prediction for 8 x B BWR with 9.4 kW/ft for 1 Day, Ramp to 13.4 kW/ft,
P/A = 1.3

BURN UP (MHED/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL	AVE	AVE	RADIAL FRACTION OF CUMMULATIVE		ROD	INTERNAL	XENON	FUEL	FUEL	CLAD	RADIUS	AXIAL
			CENTER TEMP (C)	FUEL TEMP (C)	STORED ENERGY (J/kg)	GAP WIDTH (cm)	GAP CONDUCTANCE CONTACT GAS (%)				DENS (g/mole)	SHELL (%)	PERM (%)	RECOVER (%)	TOTAL (%)
0	0.01	0.01	276	276	0.68E+05	.0108	.000 0.999	0.00	0.216	.000	0.000	0.000	0.000	,103	0.11
0	0.10	2.97	391	382	0.80E+05	.0105	.000 0.999	0.00	0.283	.000	0.000	0.000	~.001	,106	0.11
1	0.18	5.94	437	366	0.94E+05	.0102	.000 0.999	0.00	0.230	.000	0.000	0.000	~.001	,104	0.11
1	0.20	6.91	524	413	0.11E+06	.0101	.000 0.999	0.00	0.236	.000	0.000	0.000	~.001	,110	0.12
2	0.25	11.88	617	461	0.12E+06	.0095	.000 0.999	0.00	0.263	.000	0.000	0.000	~.001	,111	0.12
3	0.30	14.15	713	510	0.14E+06	.0091	.000 0.999	0.00	0.249	.000	0.000	0.000	~.002	,113	0.12
4	0.35	17.83	814	560	0.15E+06	.0088	.000 0.999	0.00	0.256	.000	0.000	0.000	~.002	,114	0.12
6	0.40	20.80	918	612	0.17E+06	.0084	.000 0.999	0.00	0.262	.000	0.000	0.000	~.002	,116	0.12
7	0.45	23.77	1026	663	0.19E+06	.0079	.000 0.999	0.00	0.268	.000	0.000	0.000	~.003	,118	0.12
9	0.50	26.74	1134	714	0.20E+06	.0075	.000 0.999	0.00	0.274	.000	0.000	0.000	~.003	,119	0.12
11	0.55	29.71	1243	769	0.22E+06	.0070	.000 0.999	0.00	0.279	.000	0.000	0.000	~.003	,121	0.12
13	0.60	30.50	1274	783	0.22E+06	.0069	.000 0.999	0.00	0.281	.000	0.000	0.000	~.004	,121	0.12
29	1.00	30.50	1277	784	0.22E+06	.0070	.000 0.999	0.01	0.280	.000	~.020	0.000	~.006	,122	0.12
31	1.03	32.68	1327	821	0.23E+06	.0067	.000 0.999	0.01	0.284	.000	~.032	0.000	~.006	,123	0.12
32	1.06	34.69	1418	872	0.25E+06	.0066	.000 0.999	0.02	0.209	.000	~.023	0.000	~.007	,124	0.13
34	1.09	36.62	1514	924	0.27E+06	.0058	.000 0.999	0.04	0.295	.000	~.025	0.000	~.007	,126	0.13
35	1.12	41.99	1617	974	0.29E+06	.0057	.028 0.977	0.08	0.299	.000	~.026	0.000	~.007	,166	0.16
37	1.15	43.53	1700	1015	0.30E+06	.0056	.049 0.950	0.14	0.302	.000	~.037	0.000	~.007	,235	0.22
93	2.19	43.53	1703	1010	0.30E+06	.0057	.037 0.961	0.50	0.302	.000	~.064	0.000	~.007	,805	0.20

TABLE A.14. FRAPCON-2 Prediction for 8 x 8 BWR with 9.4 kW/ft for 10 GWD/MTM, Ramp to 13.4 kW/ft, P/A = 1.3

BURN UP (HWD/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL CENTER TEMP (C)	AVE TEMP (C)	AVE STORED ENERGY (J/kg)	RADIAL WIDTH (CM)	FRACTION OF CONTACT GAS	CUMMULATIVE ROD CONDUCTANCE GAP	ROD FISH GAS (%)	INTERNAL GAS PRES (MPA)	XENON (MOLE FRAC)	FUEL DENs (%)	FUEL SMELL (%)	CLAD RADIUS (%)	AXIAL PERM RECOVER	AXIAL TOTAL
0	0.01	0.01	276	276	0.68E+05	.0108	.000	0.999	0.00	0.216	.000	0.000	0.000	0.000	.105	0.11
0	0.10	2.97	351	322	0.80E+05	.0105	.000	0.999	0.00	0.223	.000	0.000	0.000	0.001	.106	0.11
1	0.15	3.94	437	366	0.94E+05	.0102	.000	0.999	0.00	0.230	.000	0.000	0.000	0.001	.106	0.11
1	0.20	4.91	524	413	0.11E+06	.0101	.000	0.999	0.00	0.236	.000	0.000	0.000	0.001	.110	0.12
2	0.25	11.88	617	461	0.12E+06	.0095	.000	0.999	0.00	0.243	.000	0.000	0.000	0.001	.111	0.12
3	0.30	14.15	713	510	0.14E+06	.0091	.000	0.999	0.00	0.249	.000	0.000	0.000	0.002	.113	0.12
4	0.35	17.83	814	560	0.15E+06	.0088	.000	0.999	0.00	0.256	.000	0.000	0.000	0.002	.114	0.12
6	0.40	20.80	918	612	0.17E+06	.0084	.000	0.999	0.00	0.262	.000	0.000	0.000	0.002	.116	0.12
7	0.45	23.77	1026	663	0.19E+06	.0079	.000	0.999	0.00	0.268	.000	0.000	0.000	0.003	.118	0.12
9	0.50	26.74	1134	716	0.20E+06	.0075	.000	0.999	0.00	0.274	.000	0.000	0.000	0.003	.119	0.12
11	0.55	29.71	1243	769	0.22E+06	.0070	.000	0.999	0.00	0.279	.000	0.000	0.000	0.003	.121	0.12
13	0.60	30.50	1274	783	0.22E+06	.0069	.000	0.999	0.00	0.281	.000	0.000	0.000	0.004	.121	0.12
29	1.00	30.50	1277	784	0.22E+06	.0070	.000	0.999	0.01	0.280	.000	0.000	0.000	0.006	.122	0.12
70	2.00	30.50	1279	785	0.22E+06	.0071	.000	0.999	0.02	0.280	.000	0.046	0.000	0.015	.123	0.13
192	5.00	30.50	1286	787	0.22E+06	.0074	.000	0.999	0.04	0.278	.000	0.107	0.000	0.031	.125	0.13
396	10.00	30.50	1290	789	0.22E+06	.0077	.000	0.999	0.06	0.277	.000	0.172	0.000	0.061	.128	0.13
1209	30.00	30.50	1292	789	0.23E+06	.0080	.000	0.999	0.12	0.275	.001	0.255	0.000	0.174	.134	0.14
2023	50.00	30.50	1266	779	0.22E+06	.0076	.000	0.999	0.14	0.276	.002	0.268	0.000	0.284	.135	0.15
2036	70.00	30.50	1241	769	0.22E+06	.0071	.000	0.999	0.15	0.278	.004	0.269	0.000	0.303	.136	0.15
3680	90.00	30.50	1216	759	0.22E+06	.0066	.000	0.999	0.16	0.279	.005	0.269	0.000	0.302	.136	0.15
4464	110.00	30.50	1192	749	0.21E+06	.0060	.000	0.999	0.16	0.281	.006	0.269	0.000	0.324	.137	0.16
5277	130.00	30.50	1179	744	0.21E+06	.0059	.000	0.999	0.17	0.283	.008	0.269	0.000	0.363	.137	0.16
6091	150.00	30.50	1172	741	0.21E+06	.0058	.025	0.973	0.17	0.283	.009	0.269	0.026	0.386	.173	0.16
6905	170.00	30.50	1164	736	0.21E+06	.0058	.024	0.973	0.18	0.284	.011	0.269	0.050	0.389	.191	0.16
7718	190.00	30.50	1160	734	0.21E+06	.0057	.032	0.966	0.19	0.286	.013	0.269	0.073	0.376	.194	0.14
8532	210.00	30.50	1157	733	0.21E+06	.0057	.035	0.964	0.20	0.288	.015	0.269	0.095	0.374	.208	0.21
9346	230.00	30.50	1153	731	0.21E+06	.0057	.041	0.958	0.21	0.289	.017	0.269	0.117	0.356	.205	0.22
10159	250.00	30.50	1151	731	0.21E+06	.0057	.040	0.950	0.22	0.290	.019	0.269	0.138	0.359	.214	0.23
10566	260.00	30.50	1146	729	0.21E+06	.0056	.040	0.959	0.23	0.290	.021	0.269	0.148	0.354	.215	0.24
10567	260.03	32.68	1220	762	0.22E+06	.0056	.060	0.938	0.23	0.293	.021	0.269	0.148	0.354	.266	0.28
10569	260.06	32.68	1324	800	0.23E+06	.0055	.084	0.915	0.23	0.296	.021	0.269	0.148	0.353	.322	0.34
10570	260.09	32.68	1384	849	0.24E+06	.0055	.096	0.903	0.23	0.300	.021	0.269	0.148	0.353	.344	0.38
10572	260.12	41.89	1462	888	0.26E+06	.0052	.101	0.890	0.24	0.303	.022	0.269	0.148	0.393	.381	0.42
10574	260.15	43.83	1502	909	0.26E+06	.0049	.098	0.900	0.25	0.305	.023	0.269	0.149	0.392	.349	0.44
10632	261.15	43.83	1488	904	0.26E+06	.0047	.091	0.907	0.43	0.310	.038	0.269	0.151	0.350	.238	0.43

TABLE A.15. FRAPCON-2 Prediction for 8 x 8 BWR with 9.4 kW/ft for 20 Gwd/MTM, Ramp to 13.4 kW/ft, P/A = 1.3

BURN UP (HHD/HTU)	TIME (DAYS)	POWER (kW/m)	FUEL CENTER TEMP (C)	AVE FUEL TEMP (C)	AVE STORED ENERGY (J/kg)	RADIAL GAP WIDTH (cm)	FRACTION OF CONTACT GAP (%)	CUMMULATIVE ROD FISS GAS (X)	INTERNAL GAS PRES (MPA)	XENON (MOLE FRAC)	FUEL DENS (X)	FUEL SHELL (%)	CLAD RADIUS (X)	AXIAL PERM (%)	RECOVER TOTAL
0	0.01	0.01	278	278	0.68E+05	.0105	.000	0.999	0.00	0.216	.000	0.000	0.000	.109	0.11
0	0.10	2.97	351	322	0.80E+05	.0105	.000	0.999	0.00	0.223	.000	0.000	0.000	.106	0.11
1	0.15	5.94	437	366	0.94E+05	.0102	.000	0.999	0.00	0.230	.000	0.000	0.000	.101	0.10
1	0.20	8.91	524	413	0.11E+06	.0101	.000	0.999	0.00	0.236	.000	0.000	0.000	.110	0.12
2	0.25	11.88	617	461	0.12E+06	.0095	.000	0.999	0.00	0.243	.000	0.000	0.000	.101	0.12
3	0.30	14.15	713	510	0.14E+06	.0091	.000	0.999	0.00	0.249	.000	0.000	0.000	.002	0.13
4	0.35	17.83	814	560	0.15E+06	.0086	.000	0.999	0.00	0.256	.000	0.000	0.000	.002	0.12
6	0.40	20.80	918	612	0.17E+06	.0084	.000	0.999	0.00	0.262	.000	0.000	0.000	.002	0.12
7	0.45	23.77	1026	663	0.19E+06	.0079	.000	0.999	0.00	0.268	.000	0.000	0.000	.003	0.12
9	0.50	26.74	1134	716	0.20E+06	.0075	.000	0.999	0.00	0.274	.000	0.000	0.000	.003	0.12
11	0.55	29.71	1245	769	0.22E+06	.0070	.000	0.999	0.00	0.279	.000	0.000	0.000	.003	0.12
13	0.60	30.50	1274	783	0.227E+06	.0069	.000	0.999	0.00	0.281	.000	0.000	0.000	.004	0.12
24	1.00	30.50	1277	784	0.22E+06	.0070	.000	0.999	0.01	0.280	.000	-.020	0.000	.006	0.12
70	2.00	30.50	1279	785	0.22E+06	.0071	.000	0.999	0.02	0.280	.000	-.046	0.000	.013	0.13
192	5.00	30.50	1286	787	0.22E+06	.0074	.000	0.999	0.04	0.278	.000	-.107	0.000	.031	0.13
396	10.00	30.50	1290	789	0.22E+06	.0077	.000	0.999	0.06	0.277	.000	-.175	0.000	.061	0.13
1209	30.00	30.50	1292	789	0.23E+06	.0080	.000	0.999	0.12	0.275	.001	-.258	0.000	.174	0.14
2023	50.00	30.50	1266	779	0.22E+06	.0076	.000	0.999	0.14	0.276	.002	-.268	0.000	.284	0.15
2836	70.00	30.50	1241	769	0.22E+06	.0071	.000	0.999	0.15	0.278	.004	-.269	0.000	.393	0.15
3650	90.00	30.50	1216	759	0.22E+06	.0066	.000	0.999	0.16	0.279	.005	-.269	0.000	.502	0.15
4464	110.00	30.50	1192	749	0.21E+06	.0060	.000	0.999	0.16	0.281	.006	-.269	0.000	.554	0.16
5277	130.00	30.50	1179	744	0.21E+06	.0059	.000	0.999	0.17	0.283	.008	-.269	0.000	.563	0.16
6091	150.00	30.50	1172	741	0.21E+06	.0058	.025	0.973	0.17	0.283	.009	-.269	0.026	.586	0.16
6905	170.00	30.50	1164	736	0.21E+06	.0058	.024	0.975	0.18	0.284	.011	-.269	0.030	.589	0.16
7718	190.00	30.50	1160	734	0.21E+06	.0057	.032	0.966	0.19	0.286	.013	-.269	0.073	.576	0.16
8532	210.00	30.50	1157	733	0.21E+06	.0057	.035	0.964	0.20	0.288	.015	-.269	0.095	.574	0.21
9346	230.00	30.50	1153	731	0.21E+06	.0057	.041	0.958	0.21	0.289	.017	-.269	0.117	.556	0.22
10159	250.00	30.50	1151	731	0.21E+06	.0057	.040	0.958	0.22	0.290	.019	-.269	0.138	.553	0.23
10566	260.00	30.50	1146	729	0.21E+06	.0056	.040	0.959	0.23	0.290	.021	-.269	0.148	.554	0.24
11176	275.00	30.50	1142	728	0.21E+06	.0056	.042	0.956	0.24	0.291	.023	-.269	0.163	.531	0.25
12193	300.00	30.50	1140	728	0.21E+06	.0055	.040	0.958	0.25	0.293	.026	-.269	0.188	.506	0.26
13210	325.00	30.50	1139	729	0.21E+06	.0055	.038	0.960	0.27	0.294	.031	-.269	0.212	.484	0.30
14227	350.00	30.50	1139	729	0.21E+06	.0056	.038	0.960	0.30	0.296	.035	-.269	0.237	.462	0.33
15244	375.00	30.50	1138	731	0.21E+06	.0056	.039	0.959	0.32	0.299	.041	-.269	0.260	.441	0.35
16261	400.00	30.50	1138	731	0.21E+06	.0055	.039	0.959	0.34	0.301	.046	-.269	0.284	.420	0.37
17279	425.00	30.50	1138	732	0.21E+06	.0055	.040	0.958	0.37	0.304	.053	-.269	0.307	.399	0.39
18296	450.00	30.50	1138	733	0.21E+06	.0055	.041	0.957	0.41	0.308	.060	-.269	0.330	.377	0.41
19313	475.00	30.50	1139	735	0.21E+06	.0054	.042	0.956	0.44	0.311	.068	-.269	0.354	.356	0.44
20330	500.00	30.50	1140	737	0.21E+06	.0054	.043	0.955	0.48	0.315	.077	-.269	0.377	.334	0.46
21143	520.00	30.50	1142	739	0.21E+06	.0054	.042	0.956	0.51	0.319	.086	-.269	0.395	.314	0.48
21151	520.15	43.53	1494	919	0.27E+06	.0049	.113	0.885	0.56	0.337	.092	-.269	0.395	.314	0.48
21209	521.15	43.53	1492	923	0.27E+06	.0047	.117	0.881	1.00	0.367	.152	-.269	0.397	.311	0.47

TABLE A.16. FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 1 Day, Ramp to 12.6 kW/ft, Constant Rod Average Power

BURN UP (HWD/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL	AVE	AVE	RADIAL FRACTION OF CUMMULATIVE ROD		INTERNAL XENON	FUEL	FUEL	CLAD RADIUS	AXIAL	
			CENTER FUEL TEMP (C)	STORED TEMP (C)	ENERGY (J/kg)	WIDTH (CM)	GAP (CM)	CONTACT GAS (%)	ROD FIBR GAS (%)	GAS FRES (MOLE)	DENS (MPA)	BHELL (X)	PERM RECOVER TOTAL (%)
0	0.01	0.01	274	274	0.67E+05	.0086	.000	0.999	0.00	6.733	.000	0.000	0.000 .070 0.10
0	0.03	3.61	358	321	0.80E+05	.0085	.000	0.999	0.00	7.039	.000	0.000	0.000 .075 0.10
0	0.06	7.21	448	369	0.74E+05	.0082	.000	0.999	0.00	7.339	.000	0.000	0.000 .079 0.11
1	0.09	10.82	545	420	0.11E+06	.0079	.000	0.999	0.00	7.645	.000	0.000	-.001 .084 0.11
2	0.12	14.43	649	473	0.13E+06	.0075	.000	0.999	0.00	7.952	.000	0.000	-.001 .088 0.11
3	0.15	18.04	760	528	0.14E+06	.0072	.000	0.999	0.00	8.261	.000	0.000	-.001 .093 0.11
4	0.18	21.64	876	585	0.16E+06	.0069	.000	0.999	0.00	8.571	.000	0.000	-.001 .097 0.11
5	0.21	25.25	997	643	0.18E+06	.0065	.000	0.999	0.00	8.883	.000	0.000	-.002 .102 0.11
7	0.24	28.74	1118	701	0.20E+06	.0060	.000	0.999	0.00	9.185	.000	0.000	-.002 .106 0.11
19	0.50	28.74	1118	701	0.20E+06	.0060	.000	0.999	0.00	9.184	.000	0.000	-.004 .106 0.12
43	1.00	28.74	1120	702	0.20E+06	.0062	.000	0.999	0.00	9.147	.000	-.028	0.000 .007 .106 0.12
49	1.10	32.26	1352	810	0.23E+06	.0053	.000	0.999	0.01	9.061	.000	-.034	0.000 .008 .108 0.12
56	1.20	40.95	1510	903	0.26E+06	.0047	.000	0.999	0.04	8.978	.000	-.039	0.000 .006 .110 0.12
112	2.00	40.95	1512	904	0.26E+06	.0048	.000	0.999	0.12	9.749	.000	-.071	0.000 .014 .111 0.12

TABLE A.17. FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 10 GWd/MTM, Ramp to 12.6 kW/ft, Constant Rod Average Power

BURN UP (MWd/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL	AVE	AVE	RADIAL FRACTION OF CUMMULATIVE ROD			INTERNAL XENON	FUEL	FUEL	CLAD RADIUS	AXIAL		
			CENTER TEMP (C)	FUEL TEMP (C)	STORED ENERGY (J/kg)	GAP WIDTH (cm)	CONTACT GAP (cm)	CONDUTANCE (%)	FISS GAS (%)	GAS PRES (MPA)	(MOLE FRACT)	DENS (%)	BHELL (%)	(%)	
0	0.01	0.01	274	274	0.67E+05	.0086	.000	0.999	0.00	6.733	.000	0.000	0.000	.070	0.10
0	0.03	3.61	358	321	0.80E+05	.0085	.000	0.999	0.00	7.035	.000	0.000	0.000	.075	0.10
0	0.06	7.21	448	369	0.94E+05	.0082	.000	0.999	0.00	7.339	.000	0.000	0.000	.079	0.11
1	0.09	10.82	545	420	0.11E+06	.0079	.000	0.999	0.00	7.645	.000	0.000	0.000	.084	0.11
2	0.12	14.43	649	473	0.13E+06	.0075	.000	0.999	0.00	7.952	.000	0.000	0.000	.088	0.11
3	0.15	18.04	760	528	0.14E+06	.0072	.000	0.999	0.00	8.261	.000	0.000	0.000	.091	0.11
4	0.18	21.64	876	585	0.16E+06	.0069	.004	0.999	0.00	8.571	.000	0.000	0.000	.097	0.11
5	0.21	25.25	997	643	0.18E+06	.0065	.000	0.999	0.00	8.883	.000	0.000	0.000	.102	0.11
7	0.24	28.74	1118	701	0.20E+06	.0060	.000	0.999	0.00	9.185	.000	0.000	0.000	.106	0.11
19	0.50	28.74	1118	701	0.20E+06	.0060	.000	0.999	0.00	9.184	.000	0.000	0.000	.106	0.12
43	1.00	28.74	1120	702	0.20E+06	.0062	.000	0.999	0.00	9.187	.000	-.028	0.000	.107	0.12
48	1.10	28.74	1120	701	0.20E+06	.0062	.000	0.999	0.00	9.145	.000	-.031	0.000	.108	0.12
53	1.20	28.74	1120	702	0.20E+06	.0062	.000	0.999	0.01	9.142	.000	-.034	0.000	.107	0.12
42	2.00	28.74	1121	702	0.20E+06	.0063	.000	0.999	0.01	9.111	.000	-.036	0.000	.108	0.12
237	5.00	28.74	1124	703	0.20E+06	.0065	.000	0.999	0.01	9.022	.000	-.120	0.000	.104	0.12
480	10.00	28.74	1124	703	0.20E+06	.0067	.000	0.999	0.02	8.937	.000	-.186	0.000	.110	0.13
965	20.00	28.74	1119	701	0.20E+06	.0068	.000	0.999	0.02	8.866	.000	-.238	0.000	.112	0.13
1936	40.00	28.74	1104	695	0.20E+06	.0067	.000	0.999	0.03	8.857	.000	-.257	0.000	.114	0.14
2906	60.00	28.74	1078	685	0.19E+06	.0062	.000	0.999	0.04	8.984	.000	-.258	0.000	.116	0.14
3876	80.00	28.74	1054	675	0.19E+06	.0056	.000	0.999	0.04	9.043	.000	-.258	0.000	.118	0.15
4847	100.00	28.74	1032	666	0.19E+06	.0052	.000	0.999	0.05	9.149	.000	-.258	0.000	.119	0.15
6059	125.00	28.74	1009	657	0.18E+06	.0045	.000	0.999	0.06	9.270	.000	-.258	0.030	.121	0.15
7272	150.00	28.74	993	650	0.18E+06	.0042	.019	0.980	0.06	9.368	.000	-.258	0.060	.124	0.14
8485	175.00	28.74	984	645	0.18E+06	.0042	.018	0.981	0.07	9.430	.000	-.258	0.089	.125	0.15
9698	200.00	28.74	979	643	0.18E+06	.0041	.021	0.979	0.09	9.460	.000	-.258	0.117	.124	0.17
10426	215.00	28.74	977	642	0.18E+06	.0042	.022	0.978	0.09	9.501	.000	-.258	0.134	.121	0.18
10432	215.10	35.26	1178	732	0.21E+06	.0041	.049	0.950	0.10	9.417	.000	-.258	0.134	.100	.308
10439	215.20	40.95	1337	809	0.23E+06	.0040	.061	0.939	0.10	9.327	.000	-.258	0.134	.098	.347
10494	216.00	40.95	1306	798	0.23E+06	.0036	.052	0.948	0.12	9.322	.010	-.258	0.136	.093	.260

TABLE A.18. FRAPCON-2 Prediction for 15 x 15 PWR with 8.8 kW/ft for 20 Gwd/MTM, Ramp to 12.6 kW/ft, Constant Rod Average Power

BURN UP (MWD/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL	AVE	AVE	RADIAL	FRACTION OF	CUMMULATIVE	ROD	INTERNAL	XENON	FUEL	FUEL	CLAD RADIUS	AXIAL	
			CENTER FUEL TEMP	STORED TEMP	ENERGY (J/kg)	GAP WIDTH (cm)	CONTACT GAP (%)	FI88 GAP (%)	GAS PRES (MPA)	(MOLE FRAC)	DENS (%)	BWELL (%)	(%)	PENH RECOVER	TOTAL	
0	0.01	0.01	274	274	0.67E+05	.0086	.000	0.999	0.00	6.733	.000	0.000	0.000	0.000	.070	0.10
0	0.03	3.61	358	321	0.80E+05	.0085	.000	0.999	0.00	7.035	.000	0.000	0.000	0.000	.075	0.10
0	0.06	7.21	448	369	0.94E+05	.0082	.000	0.999	0.00	7.339	.000	0.000	0.000	0.000	.079	0.11
1	0.09	10.82	545	420	0.11E+06	.0079	.000	0.999	0.00	7.645	.000	0.000	0.000	0.001	.084	0.11
2	0.12	14.43	649	473	0.13E+06	.0075	.000	0.999	0.00	7.952	.000	0.000	0.000	0.001	.088	0.11
3	0.15	18.04	760	528	0.14E+06	.0072	.000	0.999	0.00	8.261	.000	0.000	0.000	0.001	.093	0.11
4	0.18	21.64	876	585	0.16E+06	.0069	.000	0.999	0.00	8.571	.000	0.000	0.000	0.001	.097	0.11
5	0.21	25.25	997	643	0.18E+06	.0065	.000	0.999	0.00	8.883	.000	0.000	0.000	0.002	.102	0.11
7	0.24	28.74	1118	701	0.20E+06	.0060	.000	0.999	0.00	9.185	.000	0.000	0.000	0.002	.106	0.11
19	0.50	28.74	1118	701	0.20E+06	.0060	.000	0.999	0.00	9.184	.000	0.000	0.000	0.004	.106	0.12
43	1.00	28.74	1120	702	0.20E+06	.0062	.000	0.999	0.00	9.147	.000	0.028	0.000	0.007	.106	0.12
48	1.10	28.74	1120	701	0.20E+06	.0062	.000	0.999	0.00	9.145	.000	0.031	0.000	0.008	.107	0.12
53	1.20	28.74	1120	702	0.20E+06	.0062	.000	0.999	0.01	9.142	.000	0.034	0.000	0.008	.107	0.12
92	2.00	28.74	1121	702	0.20E+06	.0063	.000	0.999	0.01	9.111	.000	0.056	0.000	0.014	.107	0.12
237	5.00	28.74	1124	703	0.20E+06	.0065	.000	0.999	0.01	9.022	.000	0.120	0.000	0.034	.108	0.12
480	10.00	28.74	1124	703	0.20E+06	.0067	.000	0.999	0.02	8.937	.000	0.186	0.000	0.067	.110	0.13
965	20.00	28.74	1119	701	0.20E+06	.0068	.000	0.999	0.02	8.866	.000	0.238	0.000	0.132	.112	0.13
1936	40.00	28.74	1104	695	0.20E+06	.0067	.000	0.999	0.03	8.857	.000	0.257	0.000	0.259	.114	0.14
2906	60.00	28.74	1078	685	0.19E+06	.0062	.000	0.999	0.04	8.944	.000	0.258	0.000	0.383	.116	0.14
3876	80.00	28.74	1054	675	0.19E+06	.0056	.000	0.999	0.04	9.043	.000	0.258	0.000	0.506	.116	0.15
4847	100.00	28.74	1032	666	0.19E+06	.0052	.000	0.999	0.05	9.149	.000	0.258	0.000	0.626	.119	0.15
6059	125.00	28.74	1009	657	0.18E+06	.0049	.000	0.999	0.06	9.270	.000	0.258	0.030	0.699	.121	0.15
7272	150.00	28.74	993	650	0.18E+06	.0042	.019	0.980	0.06	9.368	.000	0.258	0.060	0.724	.127	0.14
8485	175.00	28.74	984	645	0.18E+06	.0042	.018	0.981	0.07	9.430	.000	0.258	0.089	0.725	.127	0.15
9698	200.00	28.74	979	643	0.18E+06	.0041	.021	0.979	0.09	9.460	.000	0.258	0.117	0.714	.127	0.17
10911	225.00	28.74	975	641	0.18E+06	.0041	.024	0.975	0.10	9.507	.000	0.258	0.145	0.696	.192	0.19
12124	250.00	28.74	972	640	0.18E+06	.0041	.025	0.974	0.11	9.536	.001	0.258	0.173	0.665	.183	0.22
13337	275.00	28.74	972	640	0.18E+06	.0041	.024	0.975	0.12	9.552	.001	0.258	0.200	0.639	.183	0.24
14550	300.00	28.74	971	641	0.18E+06	.0036	.023	0.976	0.13	9.573	.001	0.258	0.220	0.614	.183	0.27
15763	325.00	28.74	970	641	0.18E+06	.0041	.023	0.976	0.14	9.595	.001	0.258	0.255	0.590	.183	0.29
16976	350.00	28.74	969	641	0.18E+06	.0041	.023	0.976	0.15	9.619	.001	0.258	0.282	0.565	.183	0.32
18189	375.00	28.74	969	641	0.18E+06	.0041	.023	0.976	0.17	9.643	.001	0.258	0.310	0.541	.183	0.34
19401	400.00	28.74	969	642	0.18E+06	.0040	.023	0.976	0.18	9.668	.002	0.258	0.337	0.516	.183	0.37
20614	425.00	28.74	970	642	0.18E+06	.0037	.023	0.976	0.19	9.693	.002	0.258	0.364	0.491	.183	0.39
20857	430.00	28.74	972	644	0.18E+06	.0041	.018	0.980	0.20	9.705	.002	0.258	0.369	0.487	.186	0.40
20863	430.10	35.26	1167	733	0.21E+06	.0040	.049	0.950	0.20	9.639	.002	0.258	0.370	0.486	.303	0.52
20870	430.20	40.95	1339	810	0.23E+06	.0039	.061	0.938	0.20	9.551	.002	0.258	0.370	0.485	.345	0.61
20925	431.00	40.95	1306	800	0.23E+06	.0035	.052	0.947	0.25	9.550	.002	0.258	0.371	0.480	.259	0.59

TABLE A.19. GAPCON-2 Prediction for 15 x 15 with 12.6 kW/ft to 20 GWd/MTM, P/A = 1.2

BURN UP (HWD/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL	AVE	AVE	RADIAL FRACTION OF CUMMULATIVE ROD			FUEL DENS	FUEL SHELL	CLAD RADIUS	AXIAL
			CENTER FUEL TEMP (C)	STORED FUEL TEMP (C)	ENERGY (J/Kg)	GAP WIDTH (CM)	GAP CONDUCTANCE CONTACT GAS (%)	PISS GAS (%)	INTERNAL GAS PRES (MPA)	XENON (HOLE FRAC)	(%)	PERM RECOVER TOTAL
0	0,00	41,33	1650	1039	0,31E+06	,0033	,000 0,998	0,00	9,055	,000	0,000 0,000	0,000 ,001
1978	29,60	41,33	1528	945	0,28E+06	,0021	,000 0,991	0,01	9,465	,001	-,004 0,000	0,000 ,001
3956	59,10	41,33	1518	937	0,28E+06	,0019	,000 0,991	0,01	9,560	,003	-,004 0,000	0,000 ,001
5934	88,70	41,33	1516	935	0,28E+06	,0020	,000 0,991	0,01	9,558	,004	-,004 0,000	0,000 ,001
7912	118,30	41,33	1516	935	0,28E+06	,0019	,000 0,991	0,01	9,589	,006	-,004 0,000	0,000 ,001
9890	147,80	41,33	1517	936	0,28E+06	,0019	,000 0,991	0,01	9,620	,008	-,004 0,000	0,000 ,001
11868	177,40	41,33	1518	936	0,28E+06	,0019	,000 0,991	0,01	9,652	,011	-,004 0,000	0,000 ,001
13846	206,90	41,33	1519	937	0,28E+06	,0019	,000 0,991	0,01	9,687	,013	-,004 0,000	0,000 ,001
15824	236,50	41,33	1487	913	0,27E+06	,0016	,000 0,993	0,01	9,754	,016	-,004 0,001	0,000 ,001
17804	266,10	41,33	1455	882	0,26E+06	,0013	,000 0,993	0,01	9,838	,018	-,004 0,002	0,000 ,001
19780	295,60	41,33	1447	882	0,26E+06	,0012	,000 1,000	0,02	9,924	,020	-,004 0,003	0,000 ,001

TABLE A.20. GAPCON-2 Prediction for 15 x 15 with 8.8 kW/ft for 20 Gwd/MTM Ramp to 12.6 kW/ft, P/A = 1.2

BURN UP (MWD/MTU)	TIME (DAYS)	POWER (kW/m)	FUEL CENTER TEMP (C)	AVE FUEL TEMP (C)	AVE STORED ENERGY (J/kg)	RADIAL FRACTION OF CUMULATIVE GAP WIDTH (CM)	ROD CONTACT GAP (%)	INTERNAL FIBR GAS GAS PRES (MPA)	XENON (MOLE FRAC)	FUEL DENs (%)	FUEL SHELL (%)	CLAD RADIUS (%)	AXIAL PERM RECOVER TOTAL
0	0.00	28.93	1230	847	0.25E+06	.0050	.000 0.997	0.00	8.226	.000	0.000 0.000	0.000	.001
1978	42.20	28.93	1142	779	0.21E+06	.0035	.000 0.997	0.00	8.626	.000	=.004 0.000	0.000	.001
3956	84.50	28.93	1135	772	0.22E+06	.0034	.000 0.997	0.00	8.667	.000	=.004 0.000	0.000	.001
5934	126.70	28.93	1133	772	0.22E+06	.0034	.000 0.997	0.00	8.691	.001	=.004 0.000	0.000	.001
7912	168.90	28.93	1133	772	0.22E+06	.0034	.000 0.997	0.00	8.706	.001	=.004 0.000	0.000	.001
9890	211.20	28.93	1133	772	0.22E+06	.0034	.000 0.997	0.00	8.721	.002	=.004 0.000	0.000	.001
11868	253.40	28.93	1134	773	0.22E+06	.0033	.000 0.997	0.00	8.736	.004	=.004 0.000	0.000	.001
13846	295.60	28.93	1134	773	0.22E+06	.0033	.000 0.997	0.01	8.756	.005	=.004 0.000	0.000	.001
15824	337.90	28.93	1113	796	0.22E+06	.0030	.000 0.997	0.01	8.816	.007	=.004 0.001	0.000	.001
17802	380.10	28.93	1092	740	0.21E+06	.0026	.000 1.000	0.01	8.902	.009	=.004 0.002	0.000	.001
19780	422.30	28.93	1447	882	0.20E+06	.0012	.000 1.005	0.01	9.892	.017	=.004 0.003	0.000	.001
19878	463.80	41.33	1446	882	0.20E+06	.0012	.000 1.000	0.01	9.895	.017	=.004 0.003	0.000	.001

DISTRIBUTION

No. of
Copies

No. of
Copies

OFFSITE

A. A. Churm DOE Patent Division 9800 S. Cass Avenue Argonne, IL 60439	H. H. Scott Fuel Behavior Research Branch Division of Reactor Safety Research Office of Nuclear Regulatory Research U.S. Nuclear Regulatory Commission Washington, DC 20555
400 U.S. Nuclear Regulatory Commission Division of Technical Information and Document Control 7920 Norfolk Avenue Bethesda, MD 20014	M. Tokar Reactor Fuels Section Core Performance Branch Department of Licensing U.S. Nuclear Regulatory Commission Washington, DC 20555
2 OOE Technical Information Center C. Berlinger Chief, Core Performance Branch Division of Systems Safety U.S. Nuclear Regulatory Commission Washington, DC 20555	10 J. C. Voglewede Reactor Fuels Section Core Performance Branch Division of Systems Safety U.S. Nuclear Regulatory Commission Washington, DC 20555
G. P. Marino Fuel Behavior Research Branch Division of Reactor Safety Research Office of Nuclear Regulatory Research U.S. Nuclear Regulatory Commission Washington, DC 20555	G. A. Berna EG&G Idaho, Inc. 550 2nd St. Idaho Falls, ID 83401

R. O. Meyer

Core Performance Branch
Division of Systems Safety
U.S. Nuclear Regulatory Commission
Washington, DC 20555

ONSITE

33 Pacific Northwest Laboratory

W. D. Bennett
C. E. Beyer
E. R. Bradley
M. E. Cunningham

No. of
Copies

S. K. Edler
M. D. Freshley
E. R. Gilbert (5)
R. J. Guenther
C. R. Hann
D. D. Lanning
C. L. Mohr
F. E. Panisko (5)
W. N. Rausch (5)
R. E. Williford
Technical Information YO(5)
Publishing Coordination (2)

U.S. NUCLEAR REGULATORY COMMISSION
BIBLIOGRAPHIC DATA SHEET

1. REPORT NUMBER (Assigned by DDC)

NUREG/CR-2369

PNL-4059

4. TITLE AND SUBTITLE (Add Volume No., if appropriate)

Power Histories for Fuel Codes

2. (Leave blank)

3. RECIPIENT'S ACCESSION NO.

7. AUTHOR(S)

E. R. Gilbert, W. N. Rausch and F.E. Panisko

5. DATE REPORT COMPLETED

MONTH	YEAR
October	1981

9. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Pacific Northwest Laboratory
Richland, Washington 99352

DATE REPORT ISSUED

MONTH	YEAR
January	1982

6. (Leave blank)

8. (Leave blank)

10. PROJECT/TASK/WORK UNIT NO.

11. CONTRACT NO.

FIN B2346

13. TYPE OF REPORT

PERIOD COVERED (Inclusive dates)

Contractor Report

15. SUPPLEMENTARY NOTES

14. (Leave blank)

16. ABSTRACT (200 words or less)

Computations of power history effects on the pre-loss-of-coolant accident conditions of generic pressurized water reactor and boiling water reactor fuel rods were performed at Pacific Northwest Laboratory using the U. S. Nuclear Regulatory Commission code FRAPCON-2. Comparisons were made between cases where the fuel operated at a high power throughout life and those where the fuel was at a lower power for most of its burnup and ramped to the high power at 10,000 or 20,000 MWd/MTU burnup.

The PWR rod was calculated to have more cladding creepdown during the lower power cases, which resulted in slightly lower centerline temperatures. This result was insensitive to the method used to increase the power during the ramps. The calculations also indicate that the highest fuel centerline temperatures were reached at startup.

The BWR rod, however, demonstrated a substantial dependence on the power history. In this case, the constant high-power rod released considerable more fission gas than the lower power cases, which resulted in temperature differences of up to 350°C. The highest temperature was reached at end-of-life in the constant high-power case.

17. KEY WORDS AND DOCUMENT ANALYSIS

17a. DESCRIPTORS

17b. IDENTIFIERS/OPEN-ENDED TERMS

18. AVAILABILITY STATEMENT

Unlimited

19. SECURITY CLASS (This report)
UNCLASSIFIED

21. NO. OF PAGES

20. SECURITY CLASS (This page)
UNCLASSIFIED22. PRICE
S

