

City of Klamath Falls, Oregon

Geothermal Power Plant Feasibility Study



**Prepared for:
The City of Klamath Falls,
The US Department of Energy, and
The Energy Trust of Oregon**

Prepared By:
Stephen F. Anderson, PE
Brian Brown, PE
Betty Riley



July 2011

ACKNOWLEDGMENT

“This material is based upon work supported by the US Department of Energy under Award Number DE-EE0002857”

DISCLAIMER

“This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.”

Table of Contents

1. Introduction to the Klamath Falls District Heating System	1
2. Project Objectives	2
3. Technology Alternatives.....	3
4. System Selection Criteria	4
5. Equipment Options: Packaged Power Plant Modules.....	4
6. Equipment Options: Custom Designed Power Plants.....	6
7. Preliminary Design of the Proposed Geothermal Project.....	7
8. Projections for the Pratt & Whitney PureCycle 280 kW Module	11
8a. Capital Cost Estimate-for the Installation of a PureCycle 280 kW Module	11
8b. Estimated Power Sales Volume, PureCycle 280 kW Module.....	12
8c. Revenue Projection-PureCycle 280 kW Module.....	12
8e. Sources of Financing and Project Incentives-PureCycle 280 kW Module.....	15
8f. Financial Projections-PureCycle 280 kW Module	15
9. Single 350 kW Magnetic Bearing Turbine/Generator Module	17
9a. Capital Cost Estimate-350 kW Magnetic Bearing Turbine/Generator Module	17
9b. Estimated Power Sales-350 kW Magnetic Bearing Turbine/Generator Module.....	18
9c. Revenue Projection-350 kW Magnetic Bearing Turbine/Generator Module.....	19
9d. Operating Cost Projection-350 kW Magnetic Bearing Turbine/Generator Module	20
9e. Sources of Financing and Incentives-350 kW Turbine/Generator Module	22
9f. Financial Projections-350 kW Magnetic Bearing Turbine/Generator Module	23
10. 700 kW Magnetic Bearing Turbine/Generator Module	24
10a. Capital Cost for a 700 kW Magnetic Bearing Turbine/Generator Module.....	24
10b. Estimated Power Production from a 700 kW Turbine/Generator Module.....	25
10c. Revenue Projection from a-700 kW Magnetic Bearing Turbine/Generator Module.....	26
10d. Operating Cost Projection-700 kW Magnetic Bearing Turbine/Generator Module.....	27
10e. Sources of Financing and Project Incentives-700 kW Turbine / Generator Module.....	28
10f. Financial Projections-700 kW Magnetic Bearing Turbine/Generator Module.....	29
11. System Comparisons	31
11a. Capital Cost Estimates.....	31
11b. Estimated Power Sales Volumes	32
11c. Revenue Projections	32
11d. Operating Cost Projections	33
11e. Sources of Financing and Project Incentives.....	33
11f. Financial Projections	34
12. Conclusions and Recommendations.....	34

Attachment A: Financial Projections for a PureCycle 280 kW Module..... 35
Attachment B: Financial Projections for a 350 kW Turbine/Generator Module 37
Attachment C: Financial Projections for a 700 kW Turbine/Generator Module..... 39
Attachment D: Thermodynamic Projections for a PureCycle 280 kW Module..... 41
Attachment E: Thermodynamic Projections for a 350 kW Module 43
Attachment F: Thermodynamic Projections for a 700 kW Module..... 45

1. Introduction to the Klamath Falls District Heating System

The City of Klamath Falls (City) operates a geothermal district heating system, providing hot water to businesses in the city's core area and also to melt ice from sidewalks and bridges. The system was initiated in 1981 and improvements to the system enabled reliable deliveries of hot water by 1992. Continued improvements and expansion since 1992 have allowed the system to currently heat over 400,000 square feet of building space, 150,000 square feet of greenhouses and 130,000 square feet of sidewalk snowmelt systems.




Figure 1. Geothermal Heating System Aerial View

Pumps in the heat exchanger building circulate geothermally heated city water to customers through a closed-loop distribution piping network totaling about 4.5 miles of piping. Heating water is supplied at a seasonally adjusted 170°F to 190°F. Return water at 140°-150°F is reheated by the geothermal supply through plate-and-frame heat exchangers and recirculated to the customers.



Figure 2. District Heating System Photos

This district heating system is supplied by two geothermal wells the City owns and operates, located about 3/4 mile east of the heat exchanger building. These wells are about 370 and 900 feet deep respectively, and can each deliver up to 800 gallons per minute of water at 210 to 220 degrees Fahrenheit. After passing through the heat exchangers, the geothermal water is injected back into the aquifer at typical temperatures of 150°F to 160°F.




Figure 3. District Heating Schematic

The original design heating capacity of the district heating system was 20 MMBH (million Btu/hr) (5.9 MWt). System thermal capacity has been increased through a series of renovations and improvements to an estimated 40 MMBH. (11.7 MWt) Current connected heating load peaks at about 16 MMBH (4.7MWt). The peak heating load is expected to grow to about 25 MMBH in the next 5-10 years.

The primary operating revenue from the district heating system is derived from sales of thermal energy sales to commercial buildings and greenhouses. These heating loads are by nature seasonal, with a resulting low overall annual load factor for the district heating system. To supplement revenue from operation of the district heating system, the City is contemplating the installation of a small power plant to produce power with a portion of their geothermal water resource.

2. Project Objectives

The City recognized that they have an attractive resource of geothermal energy that could be used for power generation, and chose to investigate this opportunity in more detail. The nearby Oregon Institute of Technology had recently installed a power generation module, and the City believed it might be possible to benefit from use of the same type of equipment.

At the same time, it was recognized that the priority would be the delivery of thermal energy to customers, as opposed to power generation. The value of direct use geothermal heating energy,

which offsets natural gas purchases, is much higher per million BTU than the value of the electricity that could be generated.

The project concept was to design a power plant that would operate using surplus geothermal energy and produce marketable electricity when there is reduced market for direct-use heat. Some of that power would offset electricity used for the district heating pumps; most would be sold to PacifiCorp under a long term Power Purchase Agreement (PPA).

Figure 4 shows an estimated district heating system heat load as a function of outdoor air temperature, based on projected load growth in the next 5 years. The source energy devoted to power production is based on a nominal 280 kW unit, with power generation shut down below 30°F to provide adequate thermal energy for the district heating system.




Figure 4. Projected Klamath Falls District Heating Load, ~2015

3. Technology Alternatives

There are three approaches in common usage for converting geothermal energy to electric power. The earliest geothermal power plants used steam from high-temperature steam-dominated resources. The power plants at the geysers geothermal field in California are examples of plants that used hot dry steam to generate power by direct expansion through a steam turbine. High temperature liquid-dominated geothermal resources can produce power using a flash tank to separate steam from liquid, with the steam run through a steam turbine. For the lowest temperature geothermal resources, the hot geothermal water can be used to boil a refrigerant which is then used to power a turbine or screw expander. This technology is known as an Organic Rankine cycle (or "ORC") plant. ORC power plants have been used for over thirty years in various geothermal sites, and the technology has been improved during this period.

The geothermal resource at Klamath Falls is not hot enough or large enough for direct steam turbine power generation. However, the recent development of compact ORC power plant

modules has enabled power production from lower-temperature resources. In general, these new modular power plants can operate wherever there is a temperature difference of at least 100 to 120°F between the geothermal source and the condensing water. This was demonstrated in Chena Hot Springs in Alaska in 2006 with a 250 kW unit, operating on 160°F geothermal water, with 40°F condensing water. At Oregon Institute of Technology, a 280 kW nominal capacity power plant is operating with 194°F geothermal water, using a cooling tower to produce 50° to 70° condensing water.

Modular power plants built using mass production techniques, along with the utilization of standardized chiller equipment components have led to significant cost reductions for some applications. These modules have the potential to reduce the total capital cost of a geothermal power plant, and also reduce the time to complete installation. It is the purpose of this study to determine if such cost reductions would enable a project in Klamath Falls to be economically feasible where purchase power rates are relatively low.

4. System Selection Criteria

The primary objective for the City of Klamath Falls geothermal district heating system is to deliver reliable geothermal heat at a competitive cost. Geothermal power generation can be considered to the extent that it can provide increased revenue and does not detract from reliable district heating system operation. With that in mind, the following design criteria were developed for the power plant selection:

Minimum Requirements:

- Capable of operation on 210°F geothermal resource at 600 to 1400 gallons per minute available flow.
- Generator module size of 250 kW to 700 kW.
- Allow seasonally adjusted 170°F to 190°F district heating system supply temperature.
- Available in the United States.

Preferred:

- 800 gallons per minute or less design flow to allow operation with only one geothermal production pump.
- Ability to utilize 160°F discharge geothermal heat in the power cycle.
- Option for dry or hybrid cooling to save water cost for power plant cooling.
- Oil-free and gearbox-free turbine or expander for reduced maintenance cost.
- Refrigerant selection that allows design pressures less than 200 psig for greater safety.
- Working units in similar service.

5. Equipment Options: Packaged Power Plant Modules

Pratt & Whitney PureCycle 280: The original basis-of-design for the project was the PureCycle 280 unit supplied by Pratt & Whitney division of United Technologies Corporation (UTC). This unit is based on the on their chiller/refrigeration technology, which leverages the manufacturing and cost efficiencies of that high-volume industry. The unit has a gross power

rating of 280 kilowatts and has proven to operate reliably in commercial sites in Alaska, New Mexico and Utah, and at the Oregon Institute of Technology in Klamath Falls.

The Pure Cycle 280 unit meets the minimum design criteria, although meeting the winter maximum district heating supply temperature of 190°F will require shutting off power generation below about 30°F ambient air temperature. The turbine is a fixed-speed, fixed geometry, which does not allow modulation of power production to accommodate varying district heating demands. The turbine-generator includes an oil-lubricated gearbox, with a recommended major rebuild interval of 5 years at an estimated cost of \$75,000.

As a modular pre-packaged unit, there is no option for air or hybrid-cooled condensers or use of waste geothermal water for power cycle preheat. The unit uses R245fa as a working fluid, with a typical working pressure of less than 100 psig and an evaporator pressure rating of about 250 psig.



*Figure 5. Pratt & Whitney
PureCycle 280kW Module*

ElectraTherm Green Machine: ElectraTherm of Reno, Nevada builds a 50 kW module called **The Green Machine**. It has been tested at the Southern Methodist University and units operate using a solar heat source in Hawaii and at the Kalamazoo Valley Community College in Michigan. The Green Machine unit does not meet the minimum size requirements for the Klamath Falls project.

General Electric Calnetix CleanCycle: General Electric entered the marketplace by purchasing a company named Calnetix Power Solutions which developed a 125 kW ORC unit. Calnetix has offices in the UK and in Stuart, Florida. The Calnetix module is called the **CleanCycle**, and features a high speed (26,500 RPM) turbine-expander coupled to a high efficiency alternator in one sealed unit, with no gearbox or lubricated bearings. It uses highly efficient magnetic bearings, and thus eliminates lubricating oil that might contaminate the refrigerant working fluid. According to the company website, Calnetix is focused on the heat recovery market, with

resource temperatures of 250°F and higher. The direct-drive turbine-expander is a positive feature, but the unit does not meet the temperature and size requirements for the Klamath Falls project.

Opcon Power Box: A Swedish company called Opcon makes an ORC module called a **Power Box**. With a peak rating of 800 kW and a compact size equivalent to that of a shipping container, the product is very attractive. However, we found that it is not yet available for use in America.

6. Equipment Options: Custom Designed Power Plants

In addition to the commercially produced modules described above, two companies have substantial experience with the fabrication of custom-designed ORC power plants

Ormat Technologies Inc.: Ormat has been the industry leader in ORC equipment for many years. They are well established in the geothermal market, and have typically constructed units larger than that envisioned for the city of Klamath Falls. When contacted by the investigators for the Klamath Falls project, they declined to provide a proposal for a combined heat-power project in this size range.

Turbine Air Systems: TAS fabricates custom ORC systems to meet the specific energy resource available. TAS is located in the Houston, Texas area, and has been responsive to inquiries about their product line. However, the plants they have built are substantially larger than envisioned for the city of Klamath Falls, and they did not provide a specific proposal.

Self-Designed Custom Power Plant. As an alternative to commercially available modular or custom power plants, the investigators considered designing a custom power plant specifically optimized for the requirements of the Klamath Falls geothermal district heating system. The power plant could incorporate all the required and preferred design criteria except having existing working units in similar service. Specific design features included:

- Variable-geometry turbine expander, direct coupled to a high-speed frictionless magnetic bearing, variable-speed generator.
 - The turbine-generator assembly would be hermetically sealed, with no gearbox or oil system, thus reducing oil system maintenance.
 - Variable turbine geometry and variable speed generator operation allow modulated capacity to match power production with district heating system requirements.
- The power plant would be designed with one or two generators, providing 350 kW or 700 kW gross capacity.
- A preheat heat exchanger would be included in the refrigerant circuit, utilizing 160°F discharge geothermal water to provide about 25% to 30% of the heat input to the power cycle.
- The plant could be designed for an air-cooled or hybrid air/water cooled condenser. However, the investigators found that a water cooled unit with a standard cooling tower was more cost effective for this project.




Figure 6. 320kW Magnetic Bearing Generator

The investigators narrowed the field to two approaches in order to investigate specific approaches in more detail. The first approach considered was the 280 kW UTC PureCycle unit, because it seems to have the greatest market acceptance to date. The second alternative considered was to construct a custom designed module using a magnetic bearing generator. The improved efficiency and reduced long term maintenance cost suggested this might be a good potential approach.

The investigators evaluated the following three installation scenarios for City of Klamath Falls installation:

- One (1) UTC / Pratt & Whitney PureCycle 280kW Module
- A module constructed using (1) magnetic bearing 320kW turbine-generator
- A module constructed using (2) magnetic bearing 320kW turbine-generators

The purpose of this Feasibility Study is to determine if any of these power generation module scenarios would likely be technically and economically successful at this site. Construction costs estimates and budgets were assembled based on budget quotes and estimated component costs. Actual costs associated with a similar project located at OIT in Klamath Falls have been used as a reference.

7. Preliminary Design of the Proposed Geothermal Project

The City Public Works Department operates a geothermal pumping station and heat exchanger system in a building located at the corner of North Spring Street and Wall Street near the downtown core area of Klamath Falls. This is the proposed location for the new power plant.

In order to complete cost estimates and financial projections, the investigators prepared conceptual drawings to enable estimates of key component cost and installation cost estimates.



Figure 7. Proposed Site of Geothermal Power Plant.




Figure 8. Proposed Site Plan.



Figure 9. Exterior view of the Geothermal District Heat Center

Common to all three power generation module design options, the facility will consist of the following key components:

- A power generation module
- A cooling tower to discharge heat in order to re-condense the refrigerant
- Circulating water pump(s) for the cooling tower
- An electronic control system
- A new PacifiCorp electrical service, with metering system, switchgear, and transformer to interconnect the power plant
- A new building to house the power plant with a structure satisfactory to support the installation of the cooling tower on the roof

Drawings have been prepared to identify the proposed layout and location of major components. Construction budget estimates have been prepared to enable completion of this feasibility study. No detailed engineering or firm construction quotes have been obtained.




Figure 10. Preliminary site plan for the proposed new geothermal power plant.

8. Projections for the Pratt & Whitney PureCycle 280 kW Module

The Pratt & Whitney PureCycle 280kW module is a well-designed and proven generation module. The costs to complete a system are easy to estimate since there is experience with these units. The preliminary capital cost estimate totals about \$1.6 million, as itemized below.

Brian Brown Engineering has estimated the annual net power production to be in the range of 1,655 megawatt-hours per year. The 2012 annual revenue generated is estimated at nearly \$83,000. The operating and ownership expenses are estimated to be about \$84,000.

8a. Capital Cost Estimate-for the Installation of a PureCycle 280 kW Module

A preliminary estimate of the cost to develop and construct the project with the PureCycle 280kW module has been completed. These costs include the permitting, engineering and contract applications and negotiations necessary to place the system in service. A summary of these costs is presented below.

CAPITAL COST ESTIMATES	
Technical Feasibility Study	40,000
Financial Feasibility Study	36,000
ODOE BETC Application Fee	6,000
PacifiCorp Interconnection Fee	1,000
Travel	8,000
Administrative Costs	5,000
Feasibility Study & Development Costs	\$96,000
Engineering (civil, electrical & mech.)	100,000
Purchasing & Project Management	60,000
Site civil work; Building	200,000
280 kW module, del.& inst.	360,000
Cooling tower & installation	120,000
Geothermal Heat Exchangers	0
Piping materials & installation	175,000
Control systems; safety monitoring	30,000
Electrical panel, wiring, 480 v svc	180,000
PP&L Interconnection	50,000
Spare Parts	20,000
Contingency	200,000
Interest during construction	0
Insurance during construction	4,000
Design & Construction Costs	\$1,499,078
TOTAL FUNDS REQUIRED:	\$1,595,078

These cost estimates are based on the known cost to install a PureCycle unit at a nearby facility. This installation would be comparable in scope. Though detailed design work has not been completed, these estimates are believed to be adequate for decision making purposes. Firm construction quotations would be obtained upon completion of detailed design in the event that a decision to proceed is obtained.

8b. Estimated Power Sales Volume, PureCycle 280 kW Module

Brian Brown Engineering has prepared a projection of the expected net power production for the project. This analysis takes into account the power needed to operate the geothermal pumps when needed for thermal applications and the additional operation when they otherwise would not operate except for power production. In addition, the power required for operating the circulating water pumps and cooling tower needed solely for power production has been reduced from the total.

The power generated by the project will first offset the power used in the pumping of geothermal fluid and operation of the heat exchanger building. The additional power generated will be sold to Pacific Power & Light Company under a long term power sales agreement. Shown below is the projected operating plan:

OPERATING PROJECTION	Year 1
Gross Plant Output Average, kW	274
Capacity Factor	82%
Annual Gross Power Generated, MWh	1,961
Less Cooling Tower Pump Load, MWh	-183
Less Cooling Tower Fan Load, MWh	-106
Less Geothermal Pumping Load, MWh	-322
Plus Geothermal Baseline Pumping, MWh	224
Net Annual Power Generated, MWh	1,575

8c. Revenue Projection-PureCycle 280 kW Module

For moderate quantities of power generation such as this, the serving utility represents the only viable purchaser. A portion of the power is valued based on the current retail rate at the City's electric service at the heat exchanger building. The remaining portion will be valued based on the avoided costs approved by the Oregon Public Utilities Commission. Currently, the City is paying about 8.0 cents per kilowatt-hour for power at the building. This is what they will save as they generate power to offset those purchases. For the remaining portion of power generated, the project will earn about 5.2 cents per kilowatt-hour during 2012. This rate is calculated based on the melded value of peak and off-peak power purchased by Pacific Power. The project will also produce Renewable Energy Credits (RECs) valued at \$5.00 per credit. One credit is equivalent to one gross mega-watt hour generated. As we evaluated this revenue source, it became apparent that an up-front incentive payment from the Energy Trust of Oregon would be more advantageous than selling the RECs to a third party. The revenue projections are shown on the following page:

REVENUE	Year 1
POWER OFFSET:	
Retail Power Purchases Offset, MWh	100
Retail Power Rate, \$/MWh	80.00
Subtotal, Value of Power Offset	\$8,016
POWER SALES:	
Wholesale Power to Sell, MWh	1,475
Wholesale Power Rate, \$/MWh	51.9
Subtotal, Value of Wholesale Power	\$76,638
RENEWABLE ENERGY CREDIT SALES:	
Credits to Sell, RECs	1,475
REC Rate, \$/REC	0.00
Subtotal, Value of RECs	\$0.00
Total Revenue	\$84,654

The net average retail power rate during this period is 8.0 cents per kilowatt-hour (\$80/MWh). The proposed plant will produce approximately 15 times the amount of power used at the heat exchanger building during the past year. The majority of the power generated will be sold at PP&L's avoided cost, indicated by their current Schedule 37. These contractual prices are noted below:

PP&L Avoided Cost Purchase Rates, Schedule 37					
Year	2012	2013	2014	2015	2016
On-Peak (c/kWh)	5.87	6.14	7.96	8.16	8.39
Off-Peak (c/kWh)	4.36	4.50	6.10	6.27	6.46
Weight. Avg. (\$/kWh)	5.20	5.41	7.13	7.32	7.53
Year	2017	2018	2019	2020	2021
On-Peak (c/kWh)	8.60	8.87	8.76	8.85	9.33
Off-Peak (c/kWh)	6.65	6.87	6.74	6.79	7.23
Weight. Avg. (c/kWh)	7.73	7.98	7.86	7.93	8.39

The revenue to be derived from the proposed project then will be the sum of the value of power not purchased from Pacific Power & Light (\$8,000), the value of the remaining amount of power (1,475 MWh), times the weighted average yearly price (\$74,944 in 2012).

Since the Energy Trust of Oregon offers to provide a project incentive payment of \$100,000 or more, they would claim the value of Green Energy Credits or 'tags'. Thus, the value of the renewable energy credits to be sold is zero.

The total revenue expected if complete and operating during 2012 will be about \$84,654.

8d. Operating Cost Projection-PureCycle 280 kW Module

The operating costs for a PureCycle 280 project are expected to be virtually equivalent to the expected revenue during the early years. The following represent the current projections:

OPERATING EXPENSE ASSUMPTIONS		Year 1
FIXED O&M:		
Salaries & OH-Operations		12,000
Salaries & OH-Management		0
Routine Repairs, Maintenance		6,000
Major Maintenance Reserve		15,000
Remote Monitoring		4,000
PP&L Meter /Testing		3,000
Subtotal, Fixed O&M		\$40,000
VARIABLE O&M:		
Supplies/consumables		4,000
Water Supply & Disposal		24,000
Subtotal, Variable O&M		\$28,000
Total, Operations & Maintenance		\$68,000
GENERAL & ADMINISTRATIVE:		
Legal/Audit		2,000
Property Tax	0.0%	0
Insurance	0.5%	7,975
General & Admin. Expense		6,000
Total, General & Administrative		\$15,975
Total O&M and G&A		\$83,975

The labor required to inspect and maintain the system is expected to be minimal, requiring only occasional inspections and routine maintenance of the cooling tower.

The unit will require significant major maintenance and refurbishment at five year intervals, budgeted to be about \$75,000.

Remote monitoring by local support personnel is expected to cost \$4,000 per year. Monitoring by UTC costs \$12,000 per year, and is not considered cost effective.

Pacific Power & Light Company requires that the meter and protection equipment be tested on regular intervals. These expenses will be required under their interconnection agreement, but may be reduced as they become routine and the testing intervals are extended.

Water and water disposal services from the city for the cooling tower makeup is estimated to be \$24,000 yearly. This is based upon an estimated purchase of 11,400 hundred cubic feet (ccf) at a cost of \$1.50 per ccf and a disposal of 2,277 ccf at a cost of \$2.92 per ccf.

8e. Sources of Financing and Project Incentives-PureCycle 280 kW Module

A project of this magnitude and cost may be financed in a number of ways and structures. Third party ownership and financing may be considered, which would enable the use of federal tax credits and depreciation benefits, or it may be owned by the city and financed with either municipal bonding authority or the Oregon Department of Energy's Small Energy Loan Funds.

Third party financing is a viable alternative which would enable the City to limit its debt liability and reduce its risk associated with the project. This transaction structure would also increase the overall cost of the project (due to legal and contractual costs), but may reduce the overall cost to the city. It would also reduce the City's control of the asset and the associated maintenance activities. This structure also adds complexity to the overall project evaluation. For these reasons review and consideration of alternative ownership structures has not been considered, but is recommended at a later time.

With the assumption that the project will be owned and operated by the City, the following estimates of capital participation are assumed:

Potential Sources of Funds (All Values in \$000's)	
TOTAL FUNDS REQUIRED:	1,595
ODOE Feasibility Grant; City Study	36
Energy Trust of Oregon Feasibility Grant	15
USDOE Geothermal Grant	816
Oregon BETC (33.5%)	261
Energy Trust of Oregon Incentive	100
Blue Sky Program Incentive	0
Klamath Falls Cash Contribution	367
TOTAL FUNDS SUPPLIED:	1,595

8f. Financial Projections-PureCycle 280 kW Module

Based on the projections for revenue and expense, it appears that the proposed UTC PureCycle 280 project yields inadequate returns to support repayment of the anticipated investment. With a first year revenue projection of \$84,700 and operating costs of \$84,000, the operating income would be only \$700. In future years, the income improves but would still be inadequate to repay an investment of \$367,000 by the City.

As power costs escalate, the cash flow levels would increase. However, the project will not pay an acceptable return on the proposed capital investment of the City, even through the 20th year. The project would offer more favorable returns if: (A) PacifiCorp power purchase rate were to be higher; and/or (B) the project could generate revenue from the sale of Green Energy Credits; and/or (C) the operating and maintenance cost would be lower. The largest operating cost element is for cooling water supply and disposal.

Project Financial Performance (All Values in \$000's)					
Year	2012	2016	2021	2026	2031
Revenue	84.7	120.0	134.1	139.3	158.8
Fixed O&M	40.0	45.0	52.2	60.5	70.1
Variable O&M	28.0	31.5	36.5	42.4	49.1
G&A	16.0	18.0	20.8	24.2	28.0
Tot. O&M & G&A	84.0	94.5	109.6	127.0	147.3
Operating Income	0.7	25.5	24.5	12.3	11.5
Internal Rate of Return		-31.7	-8.9-	-3.2	-1.0

A detailed financial projection for the PureCycle option may be found in Attachment A.

9. Single 350 kW Magnetic Bearing Turbine/Generator Module

The initial idea behind implementing the magnetic bearing turbine/generator system was that it would increase efficiency and decrease cost. This proposed system represents a potential improvement to the current state of the art through use of a high speed direct-drive generator, eliminating the need for gearing and reducing maintenance costs. The proposed system would also be designed to operate at part load conditions, providing greater power generation potential than the UTC unit which operates only at or near full load. Projected capital costs for the magnetic bearing generator turned out to be higher than anticipated because of the need for a custom built refrigerant turbine and the uncertainty of costs to assemble a custom power module. In particular, it has been difficult to obtain firm quotes for the cost of refrigerant heat exchangers.

The preliminary capital cost estimate totals about \$1.9 million.

Brian Brown Engineering has estimated the annual net power production to be in the range of 1,750 megawatt-hours per year. The annual revenue generated is estimated at nearly \$105,000.

9a. Capital Cost Estimate-350 kW Magnetic Bearing Turbine/Generator Module

A preliminary estimate of the cost to develop and construct the project with the magnetic bearing turbine/ generator module has been completed. These costs include the permitting, engineering and contract applications and negotiations necessary to place the system in service.

The estimated cost of the generator module was based on estimates of the engineering and design cost of the module, cost of various turbine, generator, heat exchanger and control components and assembly costs. Since this would be a single-unit, custom design, the costs may be higher than that associated with the purchase of a commercially produced module (such as the PureCycle unit). The potential for improved performance and equipment longevity prompted the investigators to pursue this option.

A summary of these capital cost estimates is presented below.

CAPITAL COST ESTIMATES	
Technical Feasibility Study	40,000
Financial Feasibility Study	36,000
ODOE BETC Application Fee	6,000
PacifiCorp Interconnection Fee	1,000
Travel	8,000
Administrative Costs	5,000
Feasibility Study & Development Costs	\$96,000
Engineering (civil, electrical & mech.)	120,000
Purchasing & Project Management	100,000
Site civil work; Building	200,000
320 kW module (x1), del.& inst.	600,000
Cooling tower & installation	120,000
Geothermal Heat Exchangers	0
Piping materials & installation	175,000
Control systems; safety monitoring	30,000
Electrical panel, wiring, 480 v svc	180,000
PP&L Interconnection	50,000
Spare Parts	20,000
Contingency	200,000
Interest during construction	0
Insurance during construction	4,000
Design & Construction Costs	\$1,799,173
TOTAL FUNDS REQUIRED:	\$1,895,173

Without detailed design work, it will be difficult to obtain firm construction quotations.

9b. Estimated Power Sales-350 kW Magnetic Bearing Turbine/Generator Module

Brian Brown Engineering has prepared a projection of the expected net power production for the project. This analysis takes into account the power needed to operate the geothermal pumps when needed for thermal applications, and the additional operation when they otherwise would not operate, except for power production. In addition, the power required for operating the circulating water pumps and cooling tower needed solely for power production has been reduced from the total.

The power generated by the project will first offset the power used in the pumping of geothermal fluid and operation of the heat exchanger building. The additional power generated will be sold to Pacific Power & Light Company under a long term power sales agreement. Shown below is the projected net power production estimate:

OPERATING PROJECTION	Year 1
Net Gross Plant Output Average, kW	317.6
Capacity Factor	89%
Annual Power Generated, MWh	2,642
Less Cooling Tower Pump Load, MWh	-224
Less Cooling Tower Fan Load, MWh	-150
Less Geothermal Pumping Load, MWh	-438
Plus Geothermal Baseline Pumping, MWh	291
Net Annual Power Generated, MWh	2,121

9c. Revenue Projection-350 kW Magnetic Bearing Turbine/Generator Module

For moderate quantities of power generation such as this, the serving utility represents the only viable purchaser. A portion of the power generated is valued based on the current retail rate at the City's electric service at the heat exchanger building. The remaining portion will be valued based on the filed utility avoided costs approved by the Oregon Public Utilities Commission.

Currently, the City is paying about 8.0 cents per kilowatt-hour for power at the building. This is what they will save as they generate power to offset those purchases. For the remaining portion of power generated, the project will earn about 5.2 cents per kilowatt-hour during 2012. This rate is calculated based on the melded value of peak and off-peak power purchased by Pacific Power and Light Company. The project will also produce Renewable Energy Credits (RECs) which would be transferred to the Energy Trust of Oregon pursuant to an agreement associated with an incentive payment. The revenue projections are shown below:

REVENUE	Year 1
POWER OFFSET:	
Retail Power Purchases Offset, MWh	100
Retail Power Rate, \$/MWh	80.00
Subtotal, Value of Power Offset	\$8,016
POWER SALES:	
Wholesale Power to Sell, MWh	2,020
Wholesale Power Rate, \$/MWh	52.00
Subtotal, Value of Wholesale Power	\$105,022
RENEWABLE ENERGY CREDIT SALES:	
Credits to Sell, RECs	2,020
REC Rate, \$/REC	0.00
Subtotal, Value of RECs	\$0.00
Total Revenue	\$113,038

The value of offset power used at the site is estimated at \$8,000. The net average power rate during this period is 8.0 cents per kilowatt-hour. The proposed plant will produce

approximately 15 times the amount of power used at the heat exchanger building during the past year. The majority of the power generated will be sold at PP&L's avoided cost, indicated by their current Schedule 37. These contractual prices are noted below:

PP&L Avoided Cost Purchase Rates, Schedule 37					
Year	2012	2013	2014	2015	2016
On-Peak (\$/kWh)	5.87	6.14	7.96	8.16	8.39
Off-Peak (\$/kWh)	4.36	4.50	6.10	6.27	6.46
Weight. Avg. (\$/kWh)	5.20	5.41	7.13	7.32	7.53
Year	2017	2018	2019	2020	2021
On-Peak (\$/kWh)	8.60	8.87	8.76	8.85	9.33
Off-Peak (\$/kWh)	6.65	6.87	6.74	6.79	7.23
Weight. Avg. (\$/kWh)	7.73	7.98	7.86	7.93	8.39

The revenue to be derived from the proposed project will be the sum of the value of power not purchased from Pacific Power & Light (\$8,000), the value of the remaining amount of power (2,020 MWh) times the weighted average yearly price (\$105,022), and the value of the renewable energy credits sold (\$0.00).

The total revenue expected if complete and operating during 2012 will be about \$113,038.

9d. Operating Cost Projection-350 kW Magnetic Bearing Turbine/Generator Module

The operating costs for the single-magnetic bearing turbine generator project are expected to be modest. The routine operating and maintenance costs appear to be similar to those associated with the operation of the PureCycle unit. It will normally operate un-manned with daily inspections. Routine tests and fluid replenishments should be the only operating necessity. The cost of operating the cooling tower will be similar to that of other modules.

The long-term major maintenance cost should be lower than those of the UTC module, since there will be no gearbox and the high speed system would operate on magnetic bearings. This will eliminate the need for routine and long-term maintenance work on the gearbox.

The following table presents the anticipated operating and maintenance cost projections:

OPERATING EXPENSE PROJECTIONS		Year 1
FIXED O&M:		
Salaries & OH-Operations		12,000
Salaries & OH-Management		0
Routine Repairs & Maint.		6,000
Major Maintenance Reserve		10,000
Remote Monitoring		4,000
PP&L Meter /Testing		3,000
Subtotal, Fixed O&M		\$35,000
VARIABLE O&M:		
Supplies/consumables		4,000
Water Supply & Disposal		28,400
Subtotal, Variable O&M		\$32,400
Total, Operations & Maintenance		\$67,400
GENERAL & ADMINISTRATIVE:		
Legal/Audit		2,000
Property Tax	0.0%	0
Insurance	0.5%	9,475
General & Admin. Expense		6,000
Total, General & Administrative		\$17,475
Total O&M and G&A		\$84,875

The labor required to inspect and maintain the system is expected to be minimal, requiring only occasional inspections and routine maintenance of the cooling tower.

No precise projections of major maintenance can be made. However, existing refrigeration units using the magnetic bearing motor have experienced extended life and minimal maintenance requirements. A conservative estimate would be that some maintenance on the power train will be required at five year intervals, budgeted to be about \$50,000.

Remote monitoring by local support personnel is expected to cost \$4,000 per year.

Pacific Power & Light Company requires that the meter and protection equipment be tested on regular intervals. These expenses will be required under their interconnection agreement, but may be reduced as they become routine and the testing intervals are extended.

Water and water disposal services from the city for the cooling tower makeup is estimated to be \$28,400 yearly. This is based upon an estimated purchase of 13,672 hundred cubic feet (ccf) at a cost of \$1.50 per ccf and a disposal of 2,670 ccf at a cost of \$2.92 per ccf.

9e. Sources of Financing and Incentives-350 kW Turbine/Generator Module

A project of this magnitude and cost may be financed in a number of ways and structures. The City has access to low cost bond financing but has limited interest in adding to its debt. The City has considered financing the project with either municipal bonding authority or the Oregon Department of Energy's Small Energy Loan Funds. Neither appears to be attractive to the City at this time.

Third party private ownership and financing may be considered, which would enable the use of federal tax credits and depreciation benefits. Such a financial structure could take the form of a lease transaction or a partnership in which the private taxpayer-owner could own the facility for a fixed number of years, after which the facility ownership would be turned over to the City for its long-term operation.

Third party financing is a viable alternative which would enable the City to limit its debt liability and reduce its risk associated with the project. This transaction structure would also increase the overall cost of the project (due to legal and contractual costs) but may reduce the direct capital cost to the city. It would also reduce the City's control of the asset and the associated maintenance activities. This structure also adds complexity to the overall project evaluation.

During the period of time in which this study has been completed, the Oregon Business Energy Tax Credit has been partially phased out. This incentive has for a number of years provided needed financial support for renewable energy projects. Without this option, the project is even more economically questionable.

For these reasons, detailed review and consideration of alternative private ownership structures has not been evaluated. If the incentives for renewable projects become available at a point in the future, the project may be evaluated again at a later time.

With the assumption that the project will be owned and operated by the City, the following estimates of capital sources are assumed:

Potential Sources of Funds (All Values in \$000's)	
TOTAL FUNDS REQUIRED:	1,895
ODOE Feasibility Grant; City Study	36
Energy Trust of Oregon Feasibility Grant	15
USDOE Geothermal Grant	816
Oregon BETC (33.5% of non-Fed \$)	362
Energy Trust of Oregon Incentive	100
Blue Sky Program Incentive	0
Klamath Falls Cash Contribution	567
TOTAL FUNDS SUPPLIED:	1,895

9f. Financial Projections-350 kW Magnetic Bearing Turbine/Generator Module

Based on the projections for revenue and expense, it appears that the proposed single magnetic bearing turbine / generator 320 kW project yields inadequate returns to represent an attractive return of the anticipated investment to the City. With a first-year revenue projection of \$113,038 and operating costs of \$84,875, the operating income of \$28,163 would be inadequate to be attractive to the City, based on its investment of the \$567,000. As power costs escalate, the cash flow levels would increase, resulting in a positive rate of return after the 10th year.

The project would offer more favorable returns if: (A) if the revenue from power sales were higher; and/or (B) the construction cost could be lower; and/or (C) the operating and maintenance cost (specifically water and water disposal costs) would be lower.

Project Financial Performance (All Values in \$000's)					
Year	2012	2016	2021	2026	2031
Revenue	113.0	161.1	179.9	186.4	212.4
Fixed O&M	35.0	39.4	45.7	52.9	61.4
Variable O&M	32.4	36.5	42.3	49.0	56.8
G&A	17.5	19.7	22.8	26.4	30.6
Tot. O&M & G&A	84.9	95.5	110.7	128.4	148.8
Operating Income	28.2	65.6	69.2	58.0	63.6
Internal Rate of Return:		-20.2%	0.5%	5.9%	7.9%

A detailed financial projection for the single magnetic bearing turbine/generator module option may be found in Attachment B.

10. 700 kW Magnetic Bearing Turbine/Generator Module

The concept of building a module that would utilize two magnetic bearing turbine / generators arose when it was learned that the standard size 400 kW magnetic motor-generator could only be rated to operate at 350 kW in the mode we are considering. For this reason, and recognizing that there is an adequate geothermal resource available to operate a power plant at 700 kW, this option had the potential of being cost effective.

The idea behind implementing the magnetic bearing turbine / generator is that it would increase efficiency and decrease operating cost. A potential improvement to the current state of the art for this technology by the proposed plan is that the high speed generator would eliminate the need for a gear box, reducing lubricating oil use and long-term maintenance costs. This module would also be designed to operate at part load conditions when only a portion of the geothermal water supply is available. Since the UTC unit only operates when there is a full supply of geothermal heat available, there are periods when the plant would have to be shut down, even though there may be a partial supply of geothermal heat available.

The investigators learned that the turbine-generator would require a custom designed and constructed turbine wheel which added significantly to the total estimated cost of the proposed module. As a result, the proposed 700 kW project became too expensive to be attractive to the City.

The preliminary capital cost estimate totals about \$2.64 million.

Brian Brown Engineering estimated the annual net power production to be in the range of 3,700 megawatt-hours per year. The first year annual revenue is estimated at \$194,000.

10a. Capital Cost for a 700 kW Magnetic Bearing Turbine/Generator Module

A preliminary estimate of the cost to develop and construct the project with the two magnetic bearing turbine / generators has been completed. These costs include the permitting, engineering and contract applications and negotiations necessary to place the system in service. A summary of these costs is presented below.

CAPITAL COST ESTIMATES	
Technical Feasibility Study	40,000
Financial Feasibility Study	36,000
ODOE BETC Application Fee	6,000
PacifiCorp Interconnection Fee	1,000
Travel	8,000
Administrative Costs	5,000
Feasibility Study & Development Costs	\$96,000
Engineering (civil, electrical & mech.)	140,000
Purchasing & Project Management	100,000
Site civil work; Building	250,000
320 kW module (x2), del.& inst.	900,000
Cooling tower & installation	240,000
Geothermal Heat Exchangers	0
Piping materials & installation	225,000
Control systems; safety monitoring	50,000
Electrical panel, wiring, 480 v svc	240,000
PP&L Interconnection	75,000
Spare Parts	20,000
Contingency	300,000
Interest during construction	0
Insurance during construction	4,000
Design & Construction Costs	\$2,544,160
TOTAL FUNDS REQUIRED:	\$2,640,160

These cost estimates are based on budget quotes obtained for the purchase of key components, engineering and fabrication. Until detailed design work has been completed, it will be difficult to obtain more precise and firm construction quotations.

10b. Estimated Power Production from a 700 kW Turbine/Generator Module

Brian Brown Engineering has prepared a projection of the expected net power production for the proposed twin-turbine project. This analysis takes into account the power needed to operate the geothermal pumps when needed for thermal applications and the additional operation when they otherwise would not operate, except for power production. In addition, the power required for operating the circulating water pumps and cooling tower needed solely for power production has been reduced from the total.

The power generated by the project will first offset the power used in the pumping of geothermal fluid and operation of the heat exchanger building. The additional power generated will be sold to Pacific Power & Light Company under a long term power sales agreement.

OPERATING PROJECTION	Year 1
Net Gross Plant Output Average, kW	604
Operating Hours:	95%
Annual Gross Power Generated, MWh	5,026
Less Cooling Tower Pump Load, MWh	-551
Less Cooling Tower Fan Load, MWh	-293
Less Geothermal Pumping Load, MWh	-730
Plus Geothermal Baseline Pumping, MWh	291
Net Annual Power Generated, MWh	3,743

10c. Revenue Projection from a-700 kW Magnetic Bearing Turbine/Generator Module

For moderate quantities of power generation such as this, the serving utility represents the only viable purchaser. A portion of the power is valued based on the current retail rate at the City's electric service at the heat exchanger building. The remaining portion will be valued based on the avoided costs approved by the Oregon Public Utilities Commission. Currently, the City is paying about 8.0 cents per kilowatt-hour for power at the building. This is what they will save as they generate power to offset those purchases. For the remaining portion of power generated, they will be paid about 5.2 cents per kilowatt-hour in the first year. This rate is calculated based on the melded value of peak and off-peak power purchased by Pacific Power. The project will also produce Renewable Energy Credits (RECs) which would be transferred to the Energy Trust of Oregon. The revenue projections are shown below:

REVENUE	Year 1
POWER OFFSET:	
Retail Power Purchases Offset, MWh	100
Retail Power Rate, \$/MWh	80.00
Subtotal, Value of Power Offset	\$8,016
POWER SALES:	
Wholesale Power to Sell, MWh	3,643
Wholesale Power Rate, \$/MWh	52.0
Subtotal, Value of Wholesale Power	\$189,451
RENEWABLE ENERGY CREDIT SALES:	
Credits to Sell, RECs	3,643
REC Rate, \$/REC	0.00
Subtotal, Value of RECs	\$0.00
Total Revenue	\$197,467

The value of offset power used at the site is estimated at \$8,000.

The net average power rate during this period is 8.0 cents per kilowatt-hour. The proposed plant will produce approximately 36 times the amount of power used at the heat exchanger building during the past year. The majority of the power generated will be sold at PP&L's avoided cost, indicated by their current Schedule 37. These contractual prices are noted below:

PP&L Avoided Cost Purchase Rates, Schedule 37					
Year	2012	2013	2014	2015	2016
On-Peak (\$/kWh)	5.87	6.14	7.96	8.16	8.39
Off-Peak (\$/kWh)	4.36	4.50	6.10	6.27	6.46
Weight. Avg. (\$/kWh)	5.20	5.41	7.13	7.32	7.53
Year	2017	2018	2019	2020	2021
On-Peak (\$/kWh)	8.60	8.87	8.76	8.85	9.33
Off-Peak (\$/kWh)	6.65	6.87	6.74	6.79	7.23
Weight. Avg. (\$/kWh)	7.73	7.98	7.86	7.93	8.39

The revenue to be derived from the proposed project, then will be the sum of the value of power not purchased from Pacific Power & Light (\$8,000), the value of the remaining amount of power (3,643 MWh) times the weighted average yearly price of \$5.20 (\$189,451), and the value of the renewable energy credits sold (\$0.00).

The total revenue expected in the first 12 months of operation will be about \$197,467.

10d. Operating Cost Projection-700 kW Magnetic Bearing Turbine/Generator Module

The labor required to inspect and maintain the system is expected to be minimal, requiring only occasional inspections and routine maintenance of the cooling tower.

No precise projections of major maintenance can be made. However, existing refrigeration units using the magnetic bearing motor have experienced long service intervals, and minimal long-term maintenance requirements. A conservative estimate would be that some maintenance on the power train will be required at five year intervals, budgeted to be about \$100,000.

Remote monitoring by local support personnel is expected to cost \$4,000 per year.

Pacific Power & Light Company requires that the meter and protection equipment be tested on regular intervals. These expenses will be required under their interconnection agreement, but may be reduced as they become routine and the testing intervals are extended.

Water and water disposal services from the city for the cooling tower makeup is estimated to be \$57,500 yearly. This is based upon an estimated purchase of 27,658 hundred cubic feet (ccf) at a cost of \$1.50 per ccf and a disposal of 5,532 ccf at a cost of \$2.92 per ccf.

OPERATING EXPENSE ASSUMPTIONS		Year 1
FIXED O&M:		
Salaries & OH-Opns		12,000
Salaries & OH-Mgmt		0
Routine Repairs & Maint		6,000
Major Maintenance Reserve		20,000
Remote Monitoring		4,000
PP&L Meter /Testing		3,000
Subtotal, Fixed O&M		\$45,000
VARIABLE O&M:		
Supplies/consumables		4,000
Water Supply & Disposal		57,500
Subtotal, Variable O&M		\$61,500
Total, Operations & Maintenance		\$106,500
GENERAL & ADMINISTRATIVE:		
Legal/Audit		2,000
Property Tax	0.0%	0
Insurance	0.5%	13,201
General & Admin. Expense		6,000
Total, General & Administrative		\$21,201
Total O&M and G&A		\$127,701

10e. Sources of Financing and Project Incentives-700 kW Turbine / Generator Module

A project costing upwards of \$2.6 million may be financed in a number of ways and structures. The City has access to low cost bond financing but has limited interest in adding to its debt. The City has considered financing the project with either municipal bonding authority or the Oregon Department of Energy's Small Energy Loan Funds. Neither appears to be attractive to the City at this time.

Third party private ownership and financing may be considered, which would enable the use of federal tax credits and depreciation benefits. Such a financial structure could take the form of a lease transaction or a partnership in which the private taxpayer-owner could own the facility for a fixed number of years, after which the facility ownership would be turned over to the City for its long-term operation.

Third party financing is a viable alternative which would enable the City to limit its debt liability and reduce its risk associated with the project. This transaction structure would also increase the overall cost of the project (due to legal and contractual costs), but may reduce the direct capital cost to the city. It would also reduce the City's control of the asset and the associated maintenance activities. This structure also adds complexity to the overall project evaluation.

During the period of time in which this study has been completed, the Oregon Business Energy Tax Credit has been partially phased out. This incentive has for a number of years provided needed financial support for renewable energy projects. Without this option, the project is even more economically questionable.

For these reasons, detailed review and consideration of alternative private ownership structures has not been evaluated. If the incentives for renewable projects become available at a point in the future, the project may be evaluated again at a later time.

With the assumption that the project would be owned and operated by the City, the following estimates of capital sources are assumed:

Potential Sources of Funds (All Values in \$000's)	
TOTAL FUNDS REQUIRED:	2,640
ODOE Feasibility Grant; City Study	36
Energy Trust of Oregon Feasibility Grant	15
USDOE Geothermal Grant	816
Oregon BETC (33.5% of non-Fed \$)	611
Energy Trust of Oregon Incentive	100
Blue Sky Program Incentive	0
Klamath Falls Cash Contribution	1,062
TOTAL FUNDS SUPPLIED:	2,640

10f. Financial Projections-700 kW Magnetic Bearing Turbine/Generator Module

Based on the projections for revenue and expense, it appears that the proposed 700 kW magnetic bearing turbine/generator project yields inadequate returns to support repayment of the anticipated investment, whether financed with debt or cash. With a first-year revenue projection of \$197,467 and operating costs of \$127,700, the operating income of \$69,767 would be inadequate to return much of the \$1,062,000 of capital required by the city. As power costs escalate, the cash flow levels would increase. However, the project will still not result in a positive internal rate of return before the 9th year. After 15 years, the projected returns are around 8%.

The project would offer more favorable returns if: (A) If the utility power purchase rate were higher; and/or (B) the construction cost could be lower; and/or (C) the operating and maintenance cost (including water supply and disposal) would be lower.

Project Financial Performance (All Values in \$000's)					
Year	2012	2016	2021	2026	2031
Revenue	197.4	283.4	316.1	326.5	371.8
Fixed O&M	45.0	50.6	58.7	68.1	78.9
Variable O&M	61.5	69.2	80.2	93.0	107.8
G&A	21.2	23.9	27.7	32.1	37.2
Tot. O&M & G&A	127.7	143.7	166.6	193.2	223.9
Operating Income	69.7	139.6	149.5	133.4	147.9
Internal Rate of Return:		-16.9%	3.1%	8.2%	10.1%

A detailed financial projection may be found in Attachment C.

11. System Comparisons

The following charts summarize the capital costs, power sales, revenue, operating costs, sources of financing, and financial projections associated with the three power plant options at the Klamath Falls site:

11a. Capital Cost Estimates

CAPITAL COST ESTIMATES	PureCycle	Magnetic Bearing T/G	Magnetic Bearing T/G
	280 kW	320 kW	640 kW
Technical Feasibility Study	40,000	40,000	40,000
Financial Feasibility Study	36,000	36,000	36,000
ODOE BETC Application Fee	6,000	6,000	6,000
PacifiCorp Interconnection Fee	1,000	1,000	1,000
Travel	8,000	8,000	8,000
Administrative Costs	5,000	5,000	5,000
Feasibility Study & Development Costs	96,000	96,000	96,000
Engineering (civil, electrical & mech.)	100,000	120,000	140,000
Purchasing & Project Management	60,000	100,000	100,000
Site civil work; Building	200,000	200,000	250,000
280 kW module, del.& inst.	360,000	600,000	900,000
Cooling tower & installation	120,000	120,000	240,000
Geothermal Heat Exchangers	0	0	0
Piping materials & installation	175,000	175,000	225,000
Control systems; safety monitoring	30,000	30,000	50,000
Electrical panel, wiring, 480 v svc	180,000	180,000	240,000
PP&L Interconnection	50,000	50,000	75,000
Spare Parts	20,000	20,000	20,000
Contingency	200,000	200,000	300,000
Interest during construction	0	0	0
Insurance during construction	4,000	4,000	4,000
Design & Construction Costs	1,499,078	1,799,173	2,544,160
TOTAL FUNDS REQUIRED:	1,595,078	1,895,173	2,640,160

11b. Estimated Power Sales Volumes

OPERATING PLAN (Year 1)	PureCycle 280kw	Magnetic Bearing T/G 350 kW	2 X Magnetic Bearing T/G 700 kW
Gross Plant Output Average, kW	273	317	604
Operating hours:	82%	95%	95%
Annual Gross Power Generated, MWh	1,961	2,641	5,026
Less Cooling Tower Pump Load, MWh	-183	-224	-551
Less Cooling Tower Fan Load, MWh	-106	-150	-293
Less Geothermal Pumping Load, MWh	-322	-438	-730
Plus Baseline Pumping, MWh	224	291	291
Net Annual Power Generated, MWh	1,574	2,120	3,743

11c. Revenue Projections

REVENUE (Year 1)	PureCycle 280kw	Magnetic Bearing T/G 350 kW	2 X Magnetic Bearing T/G 700 kW
POWER OFFSET:			
Retail Power Purchases Offset, MWh	100	100	100
Retail Power Rate, \$/MWh	80.00	80.00	80.00
Subtotal, Value of Power Offset	8,016.00	8,016.00	8,016.00
POWER SALES:			
Wholesale Power to Sell, MWh	1,474	2,020	3,643
Wholesale Power Rate, \$/MWh	52.0	52.0	52.0
Subtotal, Value of Wholesale Power	\$76,638	\$105,022	\$189,451
RENEWABLE ENERGY CREDIT SALES:			
Credits to Sell, RECs	1,474	2,020	3,643
REC Rate, \$/REC	0.00	0.00	0.00
Subtotal, Value of RECs	\$0.00	\$0.00	\$0.00
Total Revenue	\$84,654	\$113,038	\$197,467

11d. Operating Cost Projections

OPERATING EXPENSE ASSUMPTIONS (Year 1)	PureCycle	Magnetic Bearing T/G	Magnetic Bearing T/G
	280kw	350 kW	700 kW
FIXED O&M:			
Salaries & OH-Operations	12,000	12,000	12,000
Salaries & OH-Mgmt	0	0	0
Routine Repairs & Maint	6,000	6,000	6,000
Major Maintenance Reserve	15,000	10,000	20,000
Remote Monitoring	4,000	4,000	4,000
PP&L Meter /Testing	3,000	3,000	3,000
Subtotal, Fixed O&M	40,000	35,000	45,000
VARIABLE O&M:			
Supplies/Consumables	4,000	4,000	4,000
Water Supply & Disposal	24,000	28,400	57,500
Subtotal, Variable O&M	28,000	32,400	61,500
Total, Operations & Maintenance	68,000	73,400	106,500
GENERAL & ADMINISTRATIVE:			
Legal/Audit	2,000	2,000	2,000
Property Tax 0.0%	0	0	0
Insurance 0.5%	7,975	9,475	13,201
General & Admin. Expense	6,000	6,000	6,000
Total, General & Administrative	15,975	17,475	21,201
Total O&M and G&A	83,975	84,875	127,700

11e. Sources of Financing and Project Incentives

Potential Sources of Funds (All Values in \$000's)	PureCycle	Magnetic Bearing T/G	Magnetic Bearing T/G
	280kw	350kW	700 kW
TOTAL FUNDS REQUIRED:	1,595	1,895	2,640
	0	0	0
ODOE Feasibility Grant; City Study	36	36	36
Energy Trust of Oregon Feasibility Grant	15	15	15
USDOE Geothermal Grant	816	816	816
Oregon BETC (33.5%)	261	362	611
Energy Trust of Oregon Incentive	100	100	100
Blue Sky Program Incentive	0	0	0
Klamath Falls Cash Contribution	367	567	1,062
TOTAL FUNDS SUPPLIED:	1,595	1,895	2,640

11f. Financial Projections

		Project Financial Performance (All Values in \$000's Except IRR)						
		Capital Cost	Year	2012	2016	2021	2026	2031
PureCycle 280kw	\$1,595,000	Operating Income	0.7	25.5	24.5	12.3	11.5	
		IRR, %:	-31.7	-8.9	-3.2	-1.0		
Magnetic Bearing T/G 350kW	\$1,895,000	Operating Income	28.2	65.6	69.2	58.0	63.6	
		IRR, %:	-20.2	0.5	5.9	7.9		
Magnetic Bearing T/G 700 kW	\$2,640,000	Operating Income	69.8	139.6	149.5	133.4	147.9	
		IRR, %:	-16.9	3.1	8.2	10.1		

12. Conclusions and Recommendations

The city of Klamath Falls operates a geothermal district heating system which would appear to be an attractive opportunity to install a power generation system. Since the two wells have operated reliably and consistently over many years, no new sources or resource exploration would be necessary.

It appears that it will cost more to construct, operate, maintain and amortize a proposed geothermal facility than the long-term value of the power it would produce. The success of a future project will be determined by whether utility power production costs will remain low and whether costs of construction, operations, or financing may be reduced.

There are areas that it would be possible to reduce construction cost. More detailed design could enable the city to obtain more precise quotes for components and construction, resulting in reduction in contingency projections. The current level of the contingency for uncertainty of costs is between \$200,000 and \$300,000.

Another key issue with this project appears to be operation cost. While it is expected that only minimal routine monitoring and operating expenses will occur, the cost of water supply and waste water disposal represents nearly one quarter of the value of the power. If the cost of water alone could be reduced, the project could become viable. In addition, the projected cost of insurance may be lower than estimated under a city-wide policy.

No provisions have been made for utilization of federal tax incentives. If a transaction with a third-party owner/taxpayer were to be negotiated, perhaps the net cost of ownership could be reduced.

It is recommended that these options be investigated to determine if the costs and benefits could be brought together. The project has good potential, but like many alternative energy projects today, they only work economically if the federal tax incentives come into play.

Attachment A: Financial Projections for a PureCycle 280 kW Module

Financial Projection for Pratt & Whitney PureCycle 280 kW Plant at the City of Klamath Falls

7/5/2011 15:22

SCHEDULE & MILESTONES ASSUMPTION		Year 1	Year 2	RESULTS										
Description	Date	Operating Hours	Gross Plant Output, kW	Annual Energy Generated, MWh	Less Cooling Tower Pump Ld, MWh	Less Cooling Tower Fan Ld, MWh	Less Geothermal Pumping Ld, MWh	Plus Baseline Pumping, MWh	Annual power prod., MWh	5 yr IRR	10 yr IRR	15 yr IRR	20 yr IRR	25 yr IRR
Decision to Proceed	Jan-11		82.0%	273.0	82.0%	273.0	82.0%	273.0	82.0%	82.0%	82.0%	82.0%	82.0%	82.0%
Complete Engineering and Permitting	Mar-11		273.0	823.0	823.0	823.0	823.0	823.0	823.0	823.0	823.0	823.0	823.0	823.0
Order Equipment & Initiate Construction	Mar-11		1,961	1,961	1,961	1,961	1,961	1,961	1,961	1,961	1,961	1,961	1,961	1,961
Complete Construction and Startup	Dec-11		-183	-183	-183	-183	-183	-183	-183	-183	-183	-183	-183	-183
CAPITAL COST ESTIMATES										120.0	134.1	139.3	158.8	184
Technical Feasibility Study		40								120.0	134.1	139.3	158.8	184
Financial Feasibility Study		36								45.0	52.2	60.5	70.1	81
ODOE BETC Application Fee		6								31.5	36.5	42.4	49.1	57
PacifiCorp Interconnection Fee		1								18.0	20.8	24.2	28.0	32
Travel		8								94.5	109.6	127.0	147.3	171
Administrative Costs		5								25.5	24.5	12.3	11.5	13
Feasibility Study & Development Costs		100								#NUM!	-10.3%	-4.3%	-2.0%	-0.3%
Engineering (civil, electrical & mech.)		60								-31.7%	-8.9%	-3.2%	-1.0%	0.6%
Purchasing & Project Management		200								-23.2%	-2.0%	2.9%	4.5%	5.6%
Site civil work; Cooling tower structure		360								\$50	-25.6%	-4.0%	1.2%	4.2%
280 kW module, del. & inst.		120								\$100	-27.9%	-5.8%	-0.5%	2.9%
Cooling tower & installation		175								\$150	-29.9%	-7.5%	-1.9%	1.7%
Geothermal Heat Exchangers		30								\$250	#NUM!	-10.3%	-4.3%	-0.3%
Piping materials & installation		180								Major Maint	-31.7%	-8.9%	-3.2%	-1.0%
Control systems; safety monitoring		50								\$5,000	-24.0%	-2.6%	3.0%	5.2%
Electrical panel, wiring, 480 v svc		20								\$10,000	-27.7%	-5.5%	0.2%	3.9%
PP&L Interconnection		200								\$12,000	-29.2%	-6.8%	-1.1%	2.7%
Spare Parts		0								\$20,000	#NUM!	-13.0%	-7.7%	-5.1%
Project contingency		4								Water	-31.7%	-8.9%	-3.2%	-1.0%
Interest during construction		\$1,499								\$5,000	-18.2%	2.1%	7.2%	9.1%
Insurance during construction		\$1,595								\$10,000	-21.3%	-0.4%	5.0%	7.0%
		\$1,595								\$20,000	-28.4%	-6.2%	-0.4%	1.9%
TOTAL FUNDS REQUIRED:										3.3%	3.3%	3.3%	3.3%	3.3%
SOURCES OF FUNDS										0.6%	0.6%	0.6%	0.6%	0.6%
ODOE feasibility grant; city study		36								Oper. Hrs	-31.7%	-8.9%	-3.2%	-1.0%
USDOE Geothermal Grant		816								85.0%	-29.0%	-0.4%	1.8%	3.3%
Energy Trust of Oregon, Incentive		261								88.0%	-26.6%	-3.9%	1.8%	5.4%
Blue Sky program		100								91.0%	-24.3%	1.8%	3.8%	7.1%
Klamath Falls Cash Contribution		367								94.0%	-22.3%	0.1%	5.5%	8.6%
		\$1,595								Ret Pwr Rate	-31.7%	-8.9%	-3.2%	-1.0%
TOTAL FUNDS SUPPLIED:										\$80	-31.7%	-8.9%	-3.2%	-1.0%
										\$85	-31.3%	-8.6%	-2.8%	-0.6%
										\$90	-30.9%	-8.2%	-2.4%	1.4%
										ETO Incent.	-31.7%	-8.9%	-3.2%	-1.0%
										50	#NUM!	-10.6%	-2.2%	-0.4%
										150	-29.3%	-7.0%	-1.5%	2.0%
										300	-17.5%	2.7%	6.9%	8.6%



Financial Projection for Pratt & Whitney PureCycle 280 kW Plant at the City of Klamath Falls

7/6/2011 17:20

Year Number:	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
Year:	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	
Retail power offset (MWh)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
Retail power price/MWh	80.0	82.4	84.9	87.4	90.0	92.7	95.5	98.4	101.3	104.4	107.5	110.7	114.1	117.5	121.0	124.6	128.4	132.2	136.2	140.3	144.7	
Retail power value offset (1,000's)	8,02	8,26	8,50	8,76	9,02	9,29	9,57	9,86	10,15	10,46	10,77	11,10	11,43	11,77	12,12	12,49	12,86	13,25	13,65	14,06	14,51	
Wholesale power sales, (MWh)	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	1,474	
Wholesale power value/MWh	52.0	54.1	56.3	58.5	60.8	63.1	65.5	67.9	70.3	72.8	75.3	77.8	80.4	83.0	85.6	88.3	91.0	93.8	96.5	99.3	102.1	
Wholesale power value (1,000's)	76.6	79.7	82.8	85.9	89.1	92.3	95.6	98.9	102.3	105.7	109.1	112.6	116.1	119.6	123.2	126.8	130.5	134.3	138.1	142.0	145.9	
REVENUE																						
Retail power offset	8.0	8.3	8.5	8.8	9.0	9.3	9.6	9.9	10.2	10.5	10.8	11.1	11.4	11.8	12.1	12.5	12.9	13.2	13.6	14.1	14.7	
Wholesale power sales	76.6	79.7	82.8	85.9	89.1	92.3	95.6	98.9	102.3	105.7	109.1	112.6	116.1	119.6	123.2	126.8	130.5	134.3	138.1	142.0	145.9	
Total Revenue:	84.7	88.0	91.3	94.7	98.1	101.6	105.1	108.8	112.5	116.2	120.0	123.7	127.5	131.4	135.4	139.5	143.7	148.0	152.4	156.9	161.5	
OPERATING AND OWNERSHIP EXPENSES																						
FIXED OPERATIONS & MAINTENANCE																						
Salaries & OH-Opns @:	12.0	12.4	12.7	13.1	13.5	13.9	14.3	14.8	15.2	15.7	16.1	16.6	17.1	17.6	18.2	18.7	19.3	19.8	20.4	21.0	21.6	
Routine Repairs & Maint	6.0	6.2	6.4	6.6	6.8	7.0	7.2	7.4	7.6	7.8	8.1	8.3	8.6	8.8	9.1	9.3	9.6	9.9	10.2	10.5	10.8	
Major Maintenance Reserve	15.0	15.5	15.9	16.4	16.9	17.4	17.9	18.4	19.0	19.6	20.2	20.8	21.4	22.0	22.7	23.4	24.1	24.8	25.5	26.3	27.0	
Remote Monitoring	4.0	4.1	4.2	4.4	4.5	4.6	4.8	4.9	5.1	5.2	5.4	5.5	5.7	5.9	6.1	6.2	6.4	6.6	6.8	7.0	7.2	
PP&L Meter /Testing	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0	4.2	4.3	4.4	4.5	4.7	4.8	5.0	5.1	5.3	5.5	
Total, Fixed O&M:	40.0	41.2	42.4	43.7	45.0	46.4	47.8	49.2	50.7	52.2	53.8	55.4	57.0	58.7	60.5	62.3	64.2	66.1	68.1	70.1	72.1	
VARIABLE OPERATIONS & MAINTENANCE																						
Supplies/consumables	4.0	4.1	4.2	4.4	4.5	4.6	4.8	4.9	5.1	5.2	5.4	5.5	5.7	5.9	6.1	6.2	6.4	6.6	6.8	7.0	7.2	
Water Supply & Disposal	24.0	24.7	25.5	26.2	27.0	27.8	28.7	29.5	30.4	31.3	32.3	33.2	34.2	35.2	36.3	37.4	38.5	39.7	40.9	42.1	43.4	
Subtotal Variable O&M:	28.0	28.8	29.7	30.6	31.5	32.5	33.4	34.4	35.5	36.5	37.6	38.8	39.9	41.1	42.4	43.6	44.9	46.3	47.7	49.1	50.5	
GENERAL & ADMINISTRATIVE EXPENSES																						
Legal/Audit	2.0	2.1	2.1	2.2	2.3	2.3	2.4	2.5	2.5	2.6	2.7	2.8	2.9	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	
Property Tax	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance	8.0	8.2	8.5	8.7	9.0	9.2	9.5	9.8	10.1	10.4	10.7	11.0	11.4	11.7	12.1	12.4	12.8	13.2	13.6	14.0	14.4	
Management & Supervisory Expense	6.0	6.2	6.4	6.6	6.8	7.0	7.2	7.4	7.6	7.8	8.1	8.3	8.6	8.8	9.1	9.3	9.6	9.9	10.2	10.5	10.8	
Total, General & Administrative:	16.0	16.5	16.9	17.5	18.0	18.5	19.1	19.5	20.2	20.8	21.5	22.1	22.8	23.5	24.2	24.9	25.6	26.4	27.2	28.0	28.8	
TOTAL O&M and G&A:	84.0	86.5	89.1	91.8	94.5	97.4	100.3	103.3	106.4	109.6	112.9	116.2	119.7	123.3	127.0	130.8	134.8	138.8	143.0	147.3	151.7	
Operating Cash Flow:	-367.0	0.7	1.5	24.5	24.9	25.5	25.9	26.9	27.4	28.5	29.9	31.3	32.8	34.3	35.8	37.4	39.0	40.5	42.1	43.7	45.3	
Net Present Value @:	8.0%	-339.3	-338.1	-320.1	-303.1	-287.1	-272.0	-257.4	-243.2	-229.1	-214.6	-200.0	-185.5	-171.5	-158.0	-145.0	-132.5	-120.5	-109.0	-97.9	-87.2	
Net Present Value @:	6.0%	-345.7	-344.4	-325.0	-306.4	-288.4	-271.2	-254.3	-238.1	-222.5	-207.2	-192.8	-179.3	-166.3	-153.8	-142.0	-130.7	-120.0	-109.7	-100.0	-90.7	
IRR	#NUM!	#NUM!	#NUM!	#NUM!	#NUM!	-31.7%	-23.9%	-18.1%	-14.4%	-11.6%	-8.5%	-5.2%	-4.8%	-3.8%	-3.2%	-2.7%	-2.2%	-1.8%	-1.4%	-1.0%	-0.6%	



Attachment B: Financial Projections for a 350 kW Turbine/Generator Module

Financial Projection for Custom Magnetic Bearing T/G 350 kW Plant at the City of Klamath Falls

7/5/2011 17:37

SCHEDULE & MILESTONES ASSUMPTION	Jan-11	Mar-11	Mar-11	Dec-11
Decision to Proceed				
Complete Engineering and Permitting	36	317.0	317.0	
Order Equipment & Initiate Construction	6	2,641	2,641	
Complete Construction and Startup	1	-224	-224	

CAPITAL COST ESTIMATES	Year 1	Year 2
Technical Feasibility Study	95%	95%
Financial Feasibility Study	317.0	317.0
ODOE BETC Application Fee	2,641	2,641
PacificCorp Interconnection Fee	-224	-224
Travel	-150	-150
Administrative Costs	-438	-438
Feasibility Study & Development Costs	291	291
Engineering (civil, electrical & mech.)	2,120	2,120
Purchasing & Project Management		
Site civil work; Cooling tower structure		
320 kW module, design & install		
Cooling tower & installation		
Geothermal Heat Exchangers		
Piping materials & installation		
Control systems; safety monitoring		
Electrical panel, wiring, 480 v svc		
PP&L interconnection		
Spare Parts:		
Project contingency:		
Interest during construction		
Insurance during construction		
TOTAL FUNDS REQUIRED:		
	\$1,799	\$1,895

SOURCES OF FUNDS	Year 1	Year 2
ODOE feasibility grant; city study	36	36
Energy Trust of Oregon; Feasibility Study	15	15
USDOE Geothermal Grant:	816	816
Oregon BETC	33.5%	1,079
Energy Trust of Oregon; Incentive	100	100
Blue Sky program	0	0
Klamath Falls Cash Contribution	567	567
TOTAL FUNDS SUPPLIED:		
	\$1,895	\$1,895

OPERATING PLAN	Year 1	Year 2
Operating Hours:	95%	95%
Gross Plant Output, Avg., kW:	317.0	317.0
Annual Energy Generated, MWh:	2,641	2,641
Less Cooling Tower Pump Ld, MWh:	-224	-224
Less Cooling Tower Fan Ld, MWh:	-150	-150
Less Geothermal Pumping Ld, MWh:	-438	-438
Plus Baseline Pumping: MWh:	291	291
Annual power prod., MWh:	2,120	2,120

REVENUE	Year 1	Year 2
Retail Pwr Purchase offset, mWh:	100.2	100.2
Retail power rate, \$/mWh:	\$80.00	\$82.40
Value of power offset:	\$8,016	\$8,256
Wholesale power to sell, mWh:	2,020	2,020
Wholesale power rate:	\$52.00	\$54.10
Value of wholesale power:	\$105,022	\$109,263
Total Revenue:	\$113,038	\$117,520

OPERATING AND OWNERSHIP EXPENSES	Year 1	Year 2
FIXED OPERATIONS & MAINTENANCE		
Salaries & OH-Opns @:	12,000	12,360
Routine Repairs & Maint	6,000	6,180
Major Maintenance Reserve	10,000	10,300
Remote Monitoring	4,000	4,120
PP&L Meter /Testing	3,000	3,090
Total Fixed O&M:	\$35,000	\$36,050
VARIABLE OPERATIONS & MAINTENANCE		
Supplies, consumables	4,000	4,120
Water Supply & Disposal	28,400	29,252
Total Variable O&M:	\$32,400	\$33,372
GENERAL AND ADMINISTRATIVE EXPENSES		
Legal/Audit	2,000	2,060
Property Tax	0	0
Insurance	9,475	9,759
Management & Supervisory Expense	6,000	6,180
Total, General & Administrative:	\$17,475	\$17,999
TOTAL O&M and G&A:	\$84,875	\$87,421
Operating Income:	\$28,163	\$30,099

INFLATION ASSUMPTIONS	Year 1	Year 2
PP&L Retail	3.00%	3.00%
PP&L Whsl	3.00%	3.00%
General Initiation	3.00%	3.00%

RESULTS	5 yr IRR	10 yr IRR	15 yr IRR	20 yr IRR	25 yr IRR
Project Financial Performance					
Revenue	161.1	179.9	186.4	212.4	218.7
Fixed O&M	39.4	45.7	52.9	61.4	63.2
Variable O&M	36.5	42.3	49.0	56.8	58.5
Admin. Exp.	19.7	22.8	26.4	30.6	31.6
Tot. Expense	95.5	110.7	128.4	148.8	153.3
Oper Income	65.6	69.2	58.0	63.6	65.4
Cash flow					
Sensitivity	5 yr IRR	10 yr IRR	15 yr IRR	20 yr IRR	25 yr IRR
Contingency	-20.2%	0.5%	5.9%	7.9%	9.0%
\$5	-14.0%	5.4%	10.1%	11.7%	12.5%
\$50	-15.7%	4.1%	8.9%	10.7%	11.6%
\$100	-17.3%	2.8%	7.8%	9.7%	10.7%
\$150	-18.8%	1.6%	6.8%	8.8%	9.8%
\$250	-21.5%	-0.6%	5.0%	7.2%	8.3%
Major Maint	-20.2%	0.5%	5.9%	7.9%	9.0%
\$5,000	-18.2%	2.1%	7.3%	9.3%	10.3%
\$10,000	-20.2%	0.5%	5.9%	7.9%	9.0%
\$12,000	-21.1%	-0.2%	5.3%	7.4%	8.5%
\$20,000	-24.6%	-3.0%	2.7%	5.0%	6.3%
Water	-20.2%	0.5%	5.9%	7.9%	9.0%
\$5,000	-11.4%	7.4%	12.0%	13.6%	14.3%
\$10,000	-13.2%	6.0%	10.8%	12.5%	13.3%
\$20,000	-16.9%	3.1%	8.2%	10.1%	11.1%
Oper Hrs	-20.2%	0.5%	5.9%	7.9%	9.0%
85.0%	-28.5%	-6.1%	0.0%	2.6%	4.2%
88.0%	-25.8%	-4.0%	2.0%	4.4%	5.8%
91.0%	-23.3%	-2.0%	3.7%	6.0%	7.2%
94.0%	-21.0%	-0.2%	5.3%	7.4%	8.6%
Ret Pwr Rate	-20.2%	0.5%	5.9%	7.9%	9.0%
\$80	-20.2%	0.5%	5.9%	7.9%	9.0%
\$85	-20.0%	0.6%	6.0%	8.1%	9.2%
\$90	-19.8%	0.8%	6.1%	8.2%	9.3%
ETO Incent:	-20.2%	0.5%	5.9%	7.9%	9.0%
50	-22.0%	-0.9%	4.7%	6.9%	8.1%
150	-18.3%	2.0%	7.2%	9.1%	10.1%
300	-10.3%	8.4%	12.6%	14.0%	14.7%



Financial Projection for Custom Magnetic Bearing T/G 350 kW Plant at the City of Klamath Falls

Year Number:	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
Year:	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	
Retail power offset (MWh)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
Retail power price/MMWh	80.0	82.4	84.9	87.4	90.0	92.7	95.5	98.4	101.3	104.4	107.5	110.7	114.1	117.5	121.0	124.6	128.4	132.2	136.2	140.3	
Retail power value offset (1,000's)	8.02	8.26	8.50	8.76	9.02	9.29	9.57	9.86	10.15	10.46	10.77	11.10	11.43	11.77	12.12	12.49	12.86	13.25	13.65	14.06	
Wholesale power sales, (MWh)	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020	2,020
Wholesale power value, \$/MWh	52.0	54.1	71.3	73.2	75.3	77.3	79.8	78.6	79.3	83.9	88.9	83.6	80.4	84.7	86.3	86.4	89.8	92.5	95.3	96.2	
Wholesale power value (1,000's)	105.0	109.3	144.0	147.8	152.1	156.1	161.2	158.7	160.2	169.4	179.5	168.8	162.4	171.1	174.3	174.5	181.4	186.8	192.5	196.3	
REVENUE (\$ 000's except otherwise noted)																					
Retail power offset	8.0	8.3	8.5	8.8	9.0	9.3	9.6	9.9	10.2	10.5	10.8	11.1	11.4	11.8	12.1	12.5	12.9	13.2	13.6	14.1	
Wholesale power sales	105.0	109.3	144.0	147.8	152.1	156.1	161.2	158.7	160.2	169.4	179.5	168.8	162.4	171.1	174.3	174.5	181.4	186.8	192.5	196.3	
Total Revenue:	113.0	117.5	152.5	156.6	161.1	165.4	170.7	168.6	170.3	179.9	190.3	179.9	173.8	182.8	186.4	187.0	194.2	200.1	206.1	212.4	
OPERATING AND OWNERSHIP EXPENSES																					
FIXED OPERATIONS & MAINTENANCE																					
Salaries & OH-Opnrs @:	12.0	12.4	12.7	13.1	13.5	13.9	14.3	14.8	15.2	15.7	16.1	16.6	17.1	17.6	18.2	18.7	19.3	19.8	20.4	21.0	
Routine Repairs & Maint	6.0	6.2	6.4	6.6	6.8	7.0	7.2	7.4	7.6	7.8	8.1	8.3	8.6	8.8	9.1	9.3	9.6	9.9	10.2	10.5	
Major Maintenance Reserve	10.0	10.3	10.6	10.9	11.3	11.6	11.9	12.3	12.7	13.0	13.4	13.8	14.3	14.7	15.1	15.6	16.0	16.5	17.0	17.5	
Remote Monitoring	4.0	4.1	4.2	4.4	4.5	4.6	4.8	4.9	5.1	5.2	5.4	5.5	5.7	5.9	6.1	6.2	6.4	6.6	6.8	7.0	
PP&L Meter Testing	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0	4.2	4.3	4.4	4.5	4.7	4.8	5.0	5.1	5.3	
Total, Fixed O&M:	35.0	36.1	37.1	38.2	39.4	40.6	41.8	43.0	44.3	45.7	47.0	48.4	49.9	51.4	52.9	54.5	56.2	57.8	59.6	61.4	
VARIABLE OPERATIONS & MAINTENANCE																					
Supplies/consumables	4.0	4.1	4.2	4.4	4.5	4.6	4.8	4.9	5.1	5.2	5.4	5.5	5.7	5.9	6.1	6.2	6.4	6.6	6.8	7.0	
Water Supply & Disposal	28.4	29.3	30.1	31.0	32.0	32.9	33.9	34.9	36.0	37.1	38.2	39.3	40.5	41.7	43.0	44.2	45.6	46.9	48.3	49.8	
Subtotal Variable O&M:	32.4	33.4	34.4	35.4	36.5	37.6	38.7	39.8	41.0	42.3	43.5	44.8	46.2	47.6	49.0	50.5	52.0	53.6	55.2	56.8	
GENERAL & ADMINISTRATIVE EXPENSES																					
Legal/Audit	2.0	2.1	2.1	2.2	2.3	2.3	2.4	2.5	2.5	2.6	2.7	2.8	2.9	2.9	3.0	3.1	3.2	3.3	3.4	3.5	
Property Tax	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Insurance	9.5	9.8	10.1	10.4	10.7	11.0	11.3	11.7	12.0	12.4	12.7	13.1	13.5	13.9	14.3	14.8	15.2	15.7	16.1	16.6	
Management & Supervisory Expense	6.0	6.2	6.4	6.6	6.8	7.0	7.2	7.4	7.6	7.8	8.1	8.3	8.6	8.8	9.1	9.3	9.6	9.9	10.2	10.5	
Total, General & Administrative:	17.5	18.0	18.5	19.1	19.7	20.3	20.9	21.5	22.1	22.8	23.5	24.2	24.9	25.7	26.4	27.2	28.0	28.9	29.8	30.6	
TOTAL O&M and G&A:	84.9	87.4	90.0	92.7	95.5	98.4	101.3	104.4	107.5	110.7	114.1	117.5	121.0	124.6	128.4	132.2	136.2	140.3	144.5	148.8	
Operating Cash Flow:	-566.5	30.1	62.5	63.9	65.6	67.0	69.4	64.2	62.8	69.2	76.3	62.5	52.8	58.2	58.0	54.8	58.0	59.8	61.6	63.6	
Net Present Value @:	8.0%	-500.4	-476.5	-430.6	-387.2	-345.8	-306.7	-269.2	-237.1	-208.0	-178.4	-148.1	-125.1	-107.1	-88.8	-71.9	-57.1	-42.5	-28.7	-15.5	-2.8
Net Present Value @:	6.0%	-509.4	-484.1	-434.7	-386.9	-340.7	-296.1	-252.6	-214.6	-179.5	-143.1	-105.2	-75.9	-52.6	-38.3	-24.9	-11.9	3.2	16.1	29.9	44.2
IRR				-30.7%	-20.2%	-13.1%	-7.9%	-4.4%	-1.8%	0.5%	2.3%	3.6%	4.4%	5.2%	5.9%	6.4%	6.8%	7.3%	7.6%	7.9%	



Attachment C: Financial Projections for a 700 kW Turbine/Generator Module

Financial Projection for Custom Magnetic Bearing T/G 700 kW Plant for the City of Klamath Falls

7/5/2011 17:44

SCHEDULE & MILESTONES ASSUMPTION	Jan-11	Mar-11	Dec-11
Decision to Proceed			
Complete Engineering and Permitting			
Order Equipment & Initiate Construction			
Complete Construction and Startup			

CAPITAL COST ESTIMATES	SUBTOTAL, \$000
Technical Feasibility Study	40
Financial Feasibility Study	36
ODOE BETC Application Fee	6
PacificCorp Interconnection Fee	1
Travel	8
Administrative Costs	5
Feasibility Study & Development Costs	\$96
Engineering (civil, electrical & mech.)	140
Purchasing & Project Management	100
Site civil work; Cooling tower structure	250
320 kW X 2 module, design & install	900
Cooling tower & installation	240
Geothermal Heat Exchangers	0
Piping materials & installation	225
Control systems; safety monitoring	50
Electrical panel, wiring, 480 v svc	240
PP&L Interconnection	75
Spare Parts:	20
Project contingency:	300
Interest during construction	0
Insurance during construction	0
TOTAL FUNDS REQUIRED:	\$2,544
	\$2,640

SOURCES OF FUNDS	
ODOE feasibility grant; city study	36
Energy Trust of Oregon, Feasibility Study	15
USDOE Geothermal Grant:	816
Oregon BETC	611
Energy Trust of Oregon, Incentive	1,824
Blue Sky program	100
Klamath Falls Cash Contribution	0
TOTAL FUNDS SUPPLIED:	1,052
	\$2,640

OPERATING PLAN	Year 1	Year 2
Operating Hours:	95%	95%
Gross Plant Output, Avg., kW:	604.0	604.0
Annual Energy Generated, MWh:	5,026	5,026
Less Cooling Tower Pump Ld, MWh:	-551	-551
Less Cooling Tower Fan Ld, MWh:	-293	-293
Less Geothermal Pumping Ld, MWh:	-730	-730
Plus Baseline Pumping, MWh:	291	291
Annual power prod., MWh:	3,743	3,743

REVENUE	100.2	100.2
Retail Pwr Purchase offset, mWh:	\$80.00	\$82.40
Retail power rate, \$/mWh:	\$8.016	\$8.256
Value of power offset:	3,643	3,643
Wholesale power to sell, mWh:	\$52.00	\$54.10
Wholesale power rate:	\$189.451	\$197.102
Value of wholesale power:	\$197.467	\$205.358
Total Revenue:		

OPERATING AND OWNERSHIP EXPENSES	
FIXED OPERATIONS & MAINTENANCE	
Salaries & OH-Oprns @:	12,360
Routine Repairs & Maint	6,180
Major Maintenance Reserve	20,600
Remote Monitoring	4,000
PP&L Meter /Testing	3,000
Total Fixed O&M:	\$45,000
VARIABLE OPERATIONS & MAINTENANCE	
Supplies/consumables	4,000
Water Supply & Disposal	57,500
Legal/Audit	\$61,500
Property Tax	2,060
Insurance	0
Management & Supervisory Expense	13,200
Total, General & Administrative:	\$21,200
TOTAL O&M and G&A:	\$127,700
Operating Income:	\$89,767

GENERAL AND ADMINISTRATIVE EXPENSES	
Legal/Audit	2,060
Property Tax	0
Insurance	0.5%
Management & Supervisory Expense	6,000
Total, General & Administrative:	\$21,200
TOTAL O&M and G&A:	\$127,700
Operating Income:	\$89,767

INFLATION ASSUMPTIONS	PP&L	PP&L	General
Retail	3.00%	Whsl	General
Wholesale	3.00%	Initiation	Initiation
Construction	3.00%	3.00%	3.00%

RESULTS	yr. 15	yr. 20	yr. 25
Project Financial Performance			
Revenue	326.5	371.8	430.9
Fixed O&M	58.7	78.9	91.5
Variable O&M	69.2	107.8	125.0
Admin. Exp.	23.9	37.2	43.1
Tot. Expense	143.7	223.9	259.6
Oper Income	133.4	147.9	171.3
Cash flow			
Sensitivity	5 yr. IRR	10 yr. IRR	15 yr. IRR
Contingency	-16.9%	3.1%	8.2%
\$5	-11.8%	7.1%	11.7%
\$50	-12.7%	6.4%	11.1%
\$100	-13.6%	5.7%	10.4%
\$150	-14.5%	5.0%	9.8%
\$250	-16.2%	3.7%	8.7%
Major Maint	-16.9%	3.1%	8.2%
\$5,000	-13.9%	5.4%	10.3%
\$10,000	-14.9%	4.7%	9.6%
\$12,000	-15.3%	4.4%	9.3%
\$20,000	-16.9%	3.1%	8.2%
Water	-16.9%	3.1%	8.2%
\$5,000	-7.1%	10.8%	15.0%
\$10,000	-8.0%	10.1%	14.4%
\$20,000	-9.7%	8.7%	13.1%
Oper Hrs	-16.9%	3.1%	8.2%
85.0%	-24.5%	-2.9%	3.0%
88.0%	-22.1%	-1.0%	4.7%
91.0%	-19.8%	0.8%	6.2%
94.0%	-17.6%	2.5%	7.7%
Rel Pwr Rate	-16.9%	3.1%	8.2%
\$80	-16.9%	3.1%	8.2%
\$85	-16.8%	3.2%	8.3%
\$90	-16.7%	3.2%	8.3%
ETO Incent.	-16.9%	3.1%	8.2%
50	-18.0%	2.3%	7.5%
150	-15.8%	3.9%	8.9%
300	-12.0%	7.0%	11.5%
	20 yr. IRR	25 yr. IRR	
	10.1%	11.1%	
	13.2%	14.0%	
	12.7%	13.5%	
	12.1%	12.9%	
	11.6%	12.4%	
	10.6%	11.5%	
	10.1%	11.1%	
	12.0%	12.9%	
	11.4%	12.0%	
	10.1%	11.1%	
	10.1%	11.1%	
	16.3%	16.9%	
	15.8%	16.4%	
	14.7%	15.4%	
	10.1%	11.1%	
	5.4%	6.8%	
	6.9%	8.1%	
	8.3%	9.4%	
	9.7%	10.7%	
	10.1%	11.1%	
	10.1%	11.1%	
	10.2%	11.1%	
	10.2%	11.2%	
	10.1%	11.1%	
	9.5%	10.5%	
	10.8%	11.7%	
	13.1%	13.8%	



Financial Projection for Custom Magnetic Bearing T/G 700 kW Plant for the City of Klamath Falls

7/5/2011 17:43

Year Number:	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
Year:		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
Retail power offset (MWh)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
Retail power price/MWh	80.0	82.4	84.9	87.4	90.0	92.7	95.5	98.4	101.3	104.4	107.5	110.7	114.1	117.5	121.0	124.6	128.4	132.2	136.2	140.3	
Retail power value offset (1,000's)	8.02	8.26	8.50	8.76	9.02	9.29	9.57	9.86	10.15	10.46	10.77	11.10	11.43	11.77	12.12	12.49	12.86	13.25	13.65	14.06	

Wholesale power sales, (MWh)	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643	3,643
Wholesale power value (1,000's)	52.0	54.1	56.1	58.2	60.3	62.4	64.5	66.6	68.7	70.8	72.9	75.0	77.1	79.2	81.3	83.4	85.5	87.6	89.7	91.8	93.9
Wholesale power value (1,000's)	189.5	197.1	204.7	212.3	219.9	227.5	235.1	242.7	250.3	257.9	265.5	273.1	280.7	288.3	295.9	303.5	311.1	318.7	326.3	333.9	341.5

REVENUE

(\$ 000's except otherwise noted)

Retail power offset	8.0	8.3	8.5	8.8	9.0	9.3	9.6	9.9	10.2	10.5	10.8	11.1	11.4	11.8	12.1	12.5	12.9	13.2	13.6	14.1	
Wholesale power sales:	189.5	197.1	204.7	212.3	219.9	227.5	235.1	242.7	250.3	257.9	265.5	273.1	280.7	288.3	295.9	303.5	311.1	318.7	326.3	333.9	
Total Revenue:	197.5	205.4	213.2	221.1	229.0	236.8	244.7	252.6	260.5	268.4	276.3	284.2	292.1	300.0	307.9	315.8	323.7	331.6	339.5	347.4	355.3

OPERATING AND OWNERSHIP EXPENSES

FIXED OPERATIONS & MAINTENANCE

Salaries & OH-Ops @:	12.0	12.4	12.7	13.1	13.5	13.9	14.3	14.8	15.2	15.7	16.1	16.6	17.1	17.6	18.2	18.7	19.3	19.8	20.4	21.0
Routine Repairs & Maint	6.0	6.2	6.4	6.6	6.8	7.0	7.2	7.4	7.6	7.8	8.1	8.3	8.6	8.8	9.1	9.3	9.6	9.9	10.2	10.5
Major Maintenance Reserve	20.0	20.6	21.2	21.9	22.5	23.2	23.9	24.6	25.3	26.1	26.9	27.7	28.5	29.4	30.3	31.2	32.1	33.1	34.0	35.1
Remote Monitoring	4.0	4.1	4.2	4.4	4.5	4.6	4.8	4.9	5.1	5.2	5.4	5.5	5.7	5.9	6.1	6.2	6.4	6.6	6.8	7.0
PP&L Meter/Testing	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0	4.2	4.3	4.4	4.5	4.7	4.8	5.0	5.1	5.3
Total, Fixed O&M:	45.0	46.4	47.7	49.2	50.6	52.2	53.7	55.3	57.0	58.7	60.5	62.3	64.2	66.1	68.1	70.1	72.2	74.4	76.6	78.9

VARIABLE OPERATIONS & MAINTENANCE

Supplies/consumables	4.0	4.1	4.2	4.4	4.5	4.6	4.8	4.9	5.1	5.2	5.4	5.5	5.7	5.9	6.1	6.2	6.4	6.6	6.8	7.0
Water Supply & Disposal	57.5	59.2	61.0	62.8	64.7	66.7	68.7	70.7	72.8	75.0	77.3	79.6	82.0	84.4	87.0	89.6	92.3	95.0	97.9	100.8
Subtotal Variable O&M:	61.5	63.3	65.2	67.2	69.2	71.3	73.4	75.6	77.9	80.2	82.7	85.1	87.7	90.3	93.0	95.8	98.7	101.7	104.7	107.8

GENERAL & ADMINISTRATIVE EXPENSES

Legal/Audit	2.0	2.1	2.1	2.2	2.3	2.3	2.4	2.5	2.5	2.6	2.7	2.8	2.9	2.9	3.0	3.1	3.2	3.3	3.4	3.5
Property Tax	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Insurance	13.2	13.6	14.0	14.4	14.9	15.3	15.8	16.2	16.7	17.2	17.7	18.3	18.8	19.4	20.0	20.6	21.2	21.8	22.5	23.1
Management & Supervisory Expense	6.0	6.2	6.4	6.6	6.8	7.0	7.2	7.4	7.6	7.8	8.1	8.3	8.6	8.8	9.1	9.3	9.6	9.9	10.2	10.5
Total, General & Administrative:	21.2	21.8	22.5	23.2	23.9	24.6	25.3	26.1	26.9	27.7	28.5	29.3	30.2	31.1	32.1	33.0	34.0	35.0	36.1	37.2
TOTAL O&M and G&A:	127.7	131.5	135.5	139.5	143.7	148.0	152.5	157.1	161.8	166.6	171.6	176.8	182.1	187.5	193.2	199.0	204.9	211.1	217.4	223.9

Operating Cash Flow:	-1,062.0	69.8	73.8	132.8	135.9	139.6	142.9	147.8	139.2	137.3	149.5	163.0	138.9	122.3	132.8	133.4	128.3	135.1	139.2	143.5	147.9
Net Present Value @:	8.0%	-923.5	-864.9	-767.3	-674.8	-586.8	-503.4	-423.5	-353.9	-290.3	-226.2	-161.5	-110.4	-68.8	-26.9	12.1	46.7	80.5	112.8	143.6	173.0
Net Present Value @:	6.0%	-939.8	-877.8	-772.6	-671.0	-572.6	-477.6	-384.8	-302.4	-225.8	-147.0	-66.0	-0.9	53.2	106.6	161.1	208.8	256.1	302.1	346.9	390.4
IRR					-16.9%	-10.0%	-5.0%	-1.6%	1.0%	3.1%	4.8%	6.0%	6.8%	7.6%	8.2%	8.7%	9.1%	9.5%	9.8%	10.1%	



Attachment D: Thermodynamic Projections for a PureCycle 280 kW Module

Klamath Falls Geothermal Power; PureCycle 280 Generator Module

WEATHER			POWER PLANT OPERATION										NET POWER PRODUCTION					EXISTING GEO								
Temp Bin °F	Bin Hours	MCWB °F	UTC flow gpm	GEO to HX °F	UTC Disch °F	Cooling T °F	Turbine Eff %	Flow gpm	Generator kW	Gross Power kWh	Refrig Flow lbs/s	Cond Pump kW	Tower kW	Geo Pump kW	Net kW	Net Power kWh	GEO Flow gpm	Pump Power kW	Pump Power kWh							
97	1	63	575	170.0	170.0	70.0	79%	1775	244.2	234	33.7	28.0	19.1	30.9	166.2	159	120	10.8	10							
92	39	61	575	170.0	170.0	68.6	79%	1770	248.3	9,261	33.5	27.8	19.1	30.9	170.6	6,360	120	10.8	403							
87	124	59	575	170.1	170.1	67.2	79%	1764	252.4	29,922	33.3	27.6	19.0	30.9	174.8	20,730	120	10.8	1,281							
82	234	58	575	170.1	170.1	66.5	79%	1761	254.4	57,156	33.2	27.5	19.0	30.9	177.0	39,765	120	10.8	2,427							
77	312	56	575	170.2	170.2	65.1	79%	1755	258.3	77,309	33.0	27.3	18.9	30.9	181.2	54,223	120	10.8	3,232							
72	372	54	575	170.2	170.2	63.7	79%	1748	262.2	93,516	32.7	27.1	18.8	30.9	185.3	66,100	130	11.7	4,173							
67	466	52	575	170.3	170.3	62.3	79%	1743	266.0	119,048	32.5	26.9	18.8	30.9	189.4	84,771	180	16.2	7,249							
62	549	50	575	170.4	170.4	60.9	79%	1737	269.8	142,149	32.3	26.7	18.7	30.9	193.5	101,938	230	20.7	10,906							
57	655	48	575	170.5	170.5	59.4	79%	1731	273.5	172,089	32.1	26.5	18.7	30.9	197.5	124,245	280	25.2	15,855							
52	780	45	575	170.6	172.2	57.3	79%	1721	279.0	208,864	31.8	26.2	18.6	30.9	200.9	150,431	330	29.7	22,236							
47	823	41	575	170.8	178.7	55.0	79%	1706	284.3	224,573	31.3	25.7	17.2	30.9	194.7	153,792	380	34.2	27,011							
42	927	37	575	183.5	183.5	55.0	79%	1683	281.4	250,507	30.9	24.9	12.1	30.9	185.7	165,282	430	38.7	34,451							
37	1040	33	575	185.9	185.9	55.0	79%	1659	278.4	277,942	30.4	24.1	9.3	30.9	184.3	184,001	480	43.2	43,125							
32	1127	30	575	185.9	185.9	55.0	79%	1641	276.2	298,926	30.1	23.6	8.0	30.9	184.0	199,136	530	47.7	51,630							
27	672	25	0	210.0	210.0	55.0	79%	0	0.0	-	-	0.0	0.0	52.2	-52.2	-	580	52.2	-							
22	351	21	0	210.0	210.0	55.0	79%	0	0.0	-	-	0.0	0.0	56.7	-56.7	-	630	56.7	-							
17	149	16	0	210.0	210.0	55.0	79%	0	0.0	-	-	0.0	0.0	61.2	-61.2	-	680	61.2	-							
12	82	12	0	210.0	210.0	55.0	79%	0	0.0	-	-	0.0	0.0	65.7	-65.7	-	730	65.7	-							
7	39	7	0	210.0	210.0	55.0	79%	0	0.0	-	-	0.0	0.0	70.2	-70.2	-	780	70.2	-							
2	17	3	0	210.0	210.0	55.0	79%	0	0.0	-	-	0.0	0.0	74.7	-74.7	-	830	74.7	-							
-3	6	-2	0	210.0	210.0	55.0	79%	0	0.0	-	-	0.0	0.0	79.2	-79.2	-	880	79.2	-							
-8	2	-7	0	210.0	210.0	55.0	79%	0	0.0	-	-	0.0	0.0	83.7	-83.7	-	930	83.7	-							
-13	0	-11	0	210.0	210.0	55.0	79%	0	0.0	-	-	0.0	0.0	88.2	-88.2	-	980	88.2	-							
8766 Total annual hours			82%			Gross kWh			1,961,494	kWh			182,772	105,785			322,003			1,350,934			Geo kWh			223,989
7150 Operating hours						Avg kW			274.3	Avg kW			25.6	14.8			45.0			188.9			Avg kW			31.3

Analysis is an engineering estimate based on an Excel spreadsheet, linked to NIST RefProp 8 for thermodynamic analysis. Power generation is suspended below 30°F to conserve heat for district heating. Assumed 96% availability when conditions allow generator operation.

Net power with exist GEO pump kW

Sewer	Water
2,277	11,386 ccf
2,9155	1,496 \$/ccf
\$ 6,639	\$ 17,033
\$	\$ 23,673

Attachment E: Thermodynamic Projections for a 350 kW Module

Klamath Falls Geothermal Power; 350 kW Magnetic Bearing Generator

WEATHER		POWER PLANT OPERATION										NET POWER PRODUCTION				EXISTING GEO			
Temp Bin °F	Bin Hours	MCWB °F	UTC flow gpm	GEO to Disch °F	HX °F	Cooling T °F	Turbine Eff %	Flow gpm	Generator kW	Gross Power kWh	Refrig Flow lbs/s	Cond Pump kW	Tower kW	Geo Pump kW	Net kW	Net Power kWh	GEO Flow gpm	Pump Power kW	Pump Power kWh
97	1	63	700	185.2	185.2	70.0	79%	1854	279.0	264	35.1	30.9	20.0	44.3	183.8	174	120	10.8	10
92	39	61	700	185.2	185.2	68.6	79%	1846	283.0	10,443	34.8	30.6	19.9	44.3	188.2	6,945	120	10.8	399
87	124	59	700	185.3	185.3	67.2	79%	1837	286.9	33,662	34.6	30.3	19.8	44.3	192.5	22,588	120	10.8	1,267
82	234	58	700	185.4	185.4	66.5	79%	1833	288.8	64,224	34.4	30.1	19.7	44.3	194.6	43,280	120	10.8	2,402
77	312	56	700	185.4	185.4	65.1	79%	1825	292.6	86,663	34.1	29.8	19.7	44.3	198.8	58,886	120	10.8	3,199
72	372	54	700	185.5	185.5	63.7	79%	1816	296.3	104,565	33.9	29.5	19.6	44.3	202.9	71,628	130	11.7	4,129
67	466	52	700	185.6	185.6	62.3	79%	1807	300.0	132,829	33.6	29.1	19.5	44.3	207.0	91,661	180	16.2	7,174
62	549	50	700	185.7	185.7	60.9	79%	1798	303.5	158,237	33.3	28.8	19.4	44.3	211.0	109,965	230	20.7	10,792
57	655	48	700	185.8	185.8	59.4	79%	1789	307.0	191,124	33.1	28.5	19.3	44.3	214.8	133,763	280	25.2	15,690
52	780	45	700	185.9	185.9	57.3	79%	1775	312.0	231,168	32.7	28.0	19.1	44.3	220.5	163,384	330	29.7	22,004
47	823	41	700	186.1	186.1	54.5	79%	1756	318.4	248,886	32.1	27.3	18.9	46.8	225.4	176,131	380	34.2	26,730
42	927	37	700	186.3	190.2	51.7	79%	1736	324.5	285,879	31.6	26.7	18.7	58.7	220.4	194,143	430	38.7	34,092
37	1040	33	700	186.5	191.7	48.9	79%	1716	330.2	326,230	31.0	26.0	18.5	60.6	225.1	222,373	480	43.2	42,675
32	1127	30	700	186.6	191.8	46.8	79%	1700	334.3	358,068	30.6	25.5	18.4	60.6	229.8	246,183	530	47.7	51,093
27	672	25	700	187.0	192.1	45.0	79%	1668	334.4	213,569	29.4	24.4	15.0	60.6	234.3	149,650	580	52.2	33,340
22	351	21	700	187.4	192.4	45.0	79%	1638	329.2	109,655	29.4	23.5	11.6	60.6	233.5	77,774	630	56.7	18,885
17	149	16	700	187.9	192.8	45.0	79%	1600	322.7	45,802	28.7	22.3	9.0	60.6	230.8	32,752	680	61.2	8,686
12	62	12	700	188.3	193.2	45.0	79%	1569	317.4	24,629	28.1	21.4	7.6	60.6	227.7	17,279	730	65.7	5,098
7	39	7	700	188.9	193.6	45.0	79%	1531	310.8	11,468	27.4	20.3	6.4	70.2	213.8	7,891	780	70.2	2,591
2	17	3	700	189.3	193.9	45.0	79%	1500	305.4	4,912	26.9	19.5	5.6	74.7	205.5	3,306	830	74.7	1,202
-3	6	-2	0	189.8	210.0	45.0	79%	0	0.0	-	-	0.0	0.0	-	-79.2	-	880	79.2	-
-8	2	-7	0	190.3	210.0	45.0	79%	0	0.0	-	-	0.0	0.0	-	-83.7	-	930	83.7	-
-13	0	-11	0	190.8	210.0	45.0	79%	0	0.0	-	-	0.0	0.0	-	-88.2	-	980	88.2	-
8766 Total annual hours		8320 Operating hours		95%				Gross kWh		2,642,297		kWh	150,012	438,343	1,829,777		Geo kWh	291,457	
								Avg kW		317.6		Avg kW	18.0	52.7	219.9		Avg kW	201,457	35.0

Analysis is an engineering estimate based on an Excel spreadsheet linked to NIST RefProp 8 for thermodynamic analysis. Power generation is based on 350 kW gross generator capacity, with heat recovery from return geothermal water supplying 28% of the power generation heat rate. Assumed 95% availability.

Net power with exist GEO pump kW
 Sewer 2.734
 Water 13,672 ccf
 \$ 2,9155
 \$ 7,972 \$ 20,453 \$ 28,425

Attachment F: Thermodynamic Projections for a 700 kW Module

Klamath Falls Geothermal Power; (2) - 350 kW Magnetic Bearing Generators																				
WEATHER			POWER PLANT OPERATION					NET POWER PRODUCTION					EXISTING GEO							
Temp Bin °F	Bin Hours	MCWB °F	UTC flow gpm	UTC Disch gpm	UTC GEO to HX °F	Cooling T °F	Turbine Eff %	Flow Cooling gpm	Generator kW	Gross Power kWh	Refrig Flow lb/s	Cond Pump kW	Tower kW	Geo Pump kW	Net kW	Net Power kWh	GEO Flow gpm	Pump Power kW	Pump Power kWh	
																			1.5 W/gal	
97	1	63	1,200	1,200	182.9	182.9	70.0	79%	3574	519.4	67.8	74.3	38.5	75.5	331.1	313	120	10.8	10	
92	39	61	1,200	1,200	183.0	183.0	68.6	79%	3562	527.8	67.4	73.7	38.4	75.5	340.2	12,654	120	10.8	399	
87	124	59	1,200	1,200	183.0	183.0	67.2	79%	3550	536.1	66.9	73.1	38.2	75.5	349.2	40,872	120	10.8	1,267	
82	234	58	1,200	1,200	183.1	183.1	66.5	79%	3543	540.1	66.7	72.8	38.2	75.5	353.7	78,641	120	10.8	2,402	
77	312	56	1,200	1,200	183.1	183.1	65.1	79%	3530	548.2	66.2	72.1	38.0	75.5	362.5	107,358	120	10.8	3,199	
72	372	54	1,200	1,200	183.2	183.2	63.7	79%	3517	556.1	65.8	71.5	37.9	75.5	371.2	131,014	130	11.7	4,129	
67	466	52	1,200	1,200	183.2	183.2	62.3	79%	3504	563.9	65.3	70.8	37.8	75.5	379.8	168,189	180	16.2	7,174	
62	549	50	1,200	1,200	183.3	183.3	60.9	79%	3491	571.6	64.9	70.2	36.988	75.5	388.3	202,437	230	20.7	10,792	
57	655	48	1,200	1,200	183.3	183.3	59.4	79%	3477	579.2	64.4	69.5	36.5	75.5	396.6	246,949	280	25.2	15,690	
52	780	45	1,200	1,214	183.4	183.8	57.3	79%	3455	590.2	63.7	68.5	37.3	76.6	407.9	302,227	330	29.7	22,004	
47	823	41	1,200	1,276	183.6	185.2	54.5	79%	3426	604.5	62.8	67.1	36.9	81.3	419.1	327,563	380	34.2	26,730	
42	927	37	1,200	1,345	183.7	186.6	51.7	79%	3396	618.2	61.9	65.7	36.6	87.4	428.4	377,406	430	38.7	34,092	
37	1040	33	1,200	1,422	183.9	188.0	48.9	79%	3365	631.3	61.0	64.3	36.3	95.4	435.3	430,055	480	43.2	42,675	
32	1127	30	1,200	1,486	184.0	189.0	46.8	79%	3341	640.7	60.3	63.2	36.1	103.0	438.5	469,719	530	47.7	51,093	
27	672	25	1,200	1,500	184.3	189.5	45.0	79%	3288	643.5	59.1	60.9	36.877	104.7	448.3	486,314	580	52.2	33,340	
22	351	21	1,200	1,500	184.7	189.8	45.0	79%	3238	635.4	58.2	58.7	36.7	104.7	449.1	449,566	630	56.7	18,865	
17	149	16	1,200	1,500	185.2	190.2	45.0	79%	3174	625.2	57.0	56.0	36.5	104.7	446.6	438,389	680	61.2	8,666	
12	82	12	1,200	1,500	185.6	190.5	45.0	79%	3123	616.9	56.1	53.9	36.4	104.7	443.1	34,382	730	65.7	5,088	
7	39	7	1,200	1,500	186.0	190.8	45.0	79%	3072	608.6	55.1	51.9	36.4	104.7	439.1	16,205	780	70.2	2,591	
2	17	3	1,200	1,500	186.0	190.8	45.0	79%	3022	608.6	55.1	51.9	36.4	104.7	439.1	7,084	830	74.7	1,202	
-3	6	-2	0	880	186.0	210.0	45.0	79%	0	0.0	-	0.0	0.0	-	-79.2	-	880	79.2	-	
-8	2	-7	0	930	186.0	210.0	45.0	79%	0	0.0	-	0.0	0.0	-	-83.7	-	930	83.7	-	
-13	0	-11	0	980	186.0	210.0	45.0	79%	0	0.0	-	0.0	0.0	-	-88.2	-	980	88.2	-	
8766 Total annual hours			8320 Operating hours		95%				Gross kWh		kWh		292,901		3,452,338		Geo kWh		291,457	
									Avg kW		Avg kW		35.2		414.9		Avg kW		35.0	

Net power with exist GEO pump kW
Sewer Water

Analysis is an engineering estimate based on an Excel spreadsheet linked to NIST RefProp 8 for thermodynamic analysis. Power generation is based on (2) 350 kW generators capacity, with heat recovery from return geothermal water supplying 30% of the power generation heat rate. Assumed