

EVALUATION OF MERCURY EMISSIONS FROM COAL-FIRED
FACILITIES WITH SCR AND FGD SYSTEMS

Topical Report No. 10 (Plant 4)

U.S. DOE NETL Cooperative Agreement DE-FC26-02NT41589

Issued: January 2006



J. A. Withum
J. E. Locke

CONSOL Energy Inc.,
Research & Development
4000 Brownsville Rd.
South Park, PA 15129
(412) 854-6600

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

ABSTRACT

CONSOL Energy Inc., Research & Development (CONSOL), with support from the U.S. Department of Energy, National Energy Technology Laboratory (DOE) and the Electric Power Research Institute (EPRI), is evaluating the effects of selective catalytic reduction (SCR) on mercury (Hg) capture in coal-fired plants equipped with an electrostatic precipitator (ESP) - wet flue gas desulfurization (FGD) combination or a spray dryer absorber – fabric filter (SDA-FF) combination. In this program CONSOL is determining mercury speciation and removal at 10 coal-fired facilities. The principal purpose of this work is to develop a better understanding of the potential mercury removal "co-benefits" achieved by NO_x, and SO₂ control technologies. It is expected that this data will provide the basis for fundamental scientific insights into the nature of mercury chemistry in flue gas, the catalytic effect of SCR systems on mercury speciation and the efficacy of different FGD technologies for mercury capture. Ultimately, this insight could help to design and operate SCR and FGD systems to maximize mercury removal.

The objectives are 1) to evaluate the effect of SCR on mercury capture in the ESP-FGD and SDA-FF combinations at coal-fired power plants, 2) evaluate the effect of SCR catalyst degradation on mercury capture; 3) evaluate the effect of low load operation on mercury capture in an SCR-FGD system, and 4) collect data that could provide the basis for fundamental scientific insights into the nature of mercury chemistry in flue gas, the catalytic effect of SCR systems on mercury speciation and the efficacy of different FGD technologies for mercury capture.

This document, the tenth in a series of topical reports, describes the results and analysis of mercury sampling performed on two 468 MW units burning bituminous coal containing 1.3–1.7% sulfur. Unit 2 is equipped with an SCR, ESP, and wet FGD to control NO_x, particulate, and SO₂ emissions, respectively. Unit 1 is similar to Unit 2, except that Unit 1 has no SCR for NO_x control. Four sampling tests were performed on both units in January 2005; flue gas mercury speciation and concentrations were determined at the economizer outlet, air heater outlet (ESP inlet), ESP outlet (FGD inlet), and at the stack (FGD outlet) using the Ontario Hydro method. Process samples for material balances were collected with the flue gas measurements.

The results show that the SCR increased the oxidation of the mercury at the air heater outlet. At the exit of the air heater, a greater percentage of the mercury was in the oxidized and particulate forms on the unit equipped with an SCR compared to the unit without an SCR (97.4% vs 91%). This higher level of oxidation resulted in higher mercury removals in the scrubber. Total mercury removal averaged 97% on the unit with the SCR, and 87% on the unit without the SCR.

The average mercury mass balance closure was 84% on Unit 1 and 103% on Unit 2.

TABLE OF CONTENTS

	<u>Page</u>
DISCLAIMER	i
ABSTRACT	ii
TABLE OF CONTENTS	iii
LIST OF TABLES	iv
LIST OF FIGURES	v
LIST OF APPENDICES	v
LIST OF ABBREVIATIONS	vi
LIST OF ABBREVIATIONS	vii
INTRODUCTION	1
HOST UTILITY DESCRIPTION	1
MERCURY SAMPLING RESULTS	2
I. Test Matrix	2
II. Flue Gas Mercury Sampling Results	3
A. Economizer Outlet	3
B. Air heater outlet	4
C. FGD inlet	5
D. Stack	6
III. SCR/FGD System Hg Removal	8
IV. Mercury Material Balance	9
EXPERIMENTAL AND SAMPLING METHODS	10
I. Flue Gas Sampling Locations and Sampling Points	11
A. Economizer outlet	11
B. Air heater outlet	11
C. FGD inlet	12
D. Stack	12
II. Flue Gas Mercury Measurements	12
III. Coal Sampling and Analysis	14
A. Coal samples	14
B. Results of analyses of coal samples	14
IV. Process Sample Collection and Analysis	17
A. Coal Mill Rejects	17
B. Boiler Bottom ash	18
C. Limestone slurry	18
D. ESP hopper ash	22
E. FGD slurry	32
F. FGD makeup water	37
QUALITY ASSURANCE/QUALITY CONTROL	38
I. Blank Samples	39
II. NIST Standard Reference Material Checks	40
III. Spike Sample Recoveries	40
IV. Duplicate Analyses	40
V. Flue Gas Mercury Concentration Detection Limits	40
VI. Mercury Material Balance Closure	41
HEAT INPUT-BASED MERCURY EMISSION	43

LIST OF TABLES

Table 1. Coal-fired facilities in program	1
Table 2. Sampling test matrix.....	3
Table 3. Flue gas mercury speciation at the Economizer Outlet	4
Table 4. Flue gas mercury speciation at the air heater outlet.....	5
Table 5. Flue gas mercury speciation at the FGD inlet.....	6
Table 6. Flue gas mercury speciation at the stack	7
Table 7. Flue gas mercury removal.....	8
Table 8. Mercury material balance closure, Unit 1 (no SCR)	9
Table 9. Mercury material balance closure, Unit 2 (with SCR)	9
Table 12. Mercury speciation by train component.....	13
Table 13. List of coal samples.....	14
Table 14. Coal sample analyses – Unit 1 samples.....	15
Table 15. Coal sample analyses – Unit 2 samples.....	16
Table 16. Coal mill reject sample analyses – both units.....	17
Table 17. Results of analyses of bottom ash samples	18
Table 18. Results of analyses of limestone slurry solids samples – Unit 1.....	19
Table 19. Results of analyses of limestone slurry solids samples – Unit 2.....	20
Table 20. Results of analyses of limestone slurry filtrate samples – Unit 1	21
Table 21. Results of analyses of limestone slurry filtrate samples – Unit 2	22
Table 22. Results of analyses of ESP hopper ash samples – Unit 1, Test 1.....	24
Table 23. Results of analyses of ESP hopper ash samples – Unit 1, Test 2.....	25
Table 24. Results of analyses of ESP hopper ash samples – Unit 1, Test 3.....	26
Table 25. Results of analyses of ESP hopper ash samples – Unit 1, Test 4.....	27
Table 25. Results of analyses of ESP hopper ash samples – Unit 1, Test 4.....	27
Table 26. Results of analyses of ESP hopper ash samples – Unit 2, Test 1.....	28
Table 27. Results of analyses of ESP hopper ash samples – Unit 2, Test 2.....	29
Table 28. Results of analyses of ESP hopper ash samples – Unit 2, Test 3.....	30
Table 29. Results of analyses of ESP hopper ash samples – Unit 2, Test 4.....	31
Table 32. Results of analyses of FGD slurry filtrate samples – Unit 1 tests	35
Table 33. Results of analyses of FGD slurry filtrate samples – Unit 2 tests	36
Table 34. Results of analyses of FGD makeup water samples – Unit 1	37
Table 35. Results of analyses of FGD makeup water samples – Unit 2.....	38
Table 36. NIST SRM analyses	40
Table 37. Flue gas mercury detection limits	41
Table 38. Summary of material balance closure for mercury, Unit 1.....	42
Table 39. Summary of material balance closure for mercury, Unit 2.....	42
Table 40. Heat input-based mercury emission	43

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
Figure 1. Mercury speciation by location, Unit 1 (with no SCR)	A
Figure 2. Mercury speciation by location, Unit 2 (with SCR)	A
Figure 3. Process flow schematic and sampling locations	B
Figure 4. Economizer outlet probe and sampling train	C
Figure 5. ESP inlet (air heater outlet) probe and sampling train.....	D
Figure 6. FGD inlet probe (in background), sampling train, and meter box	E
Figure 7. Stack sampling port.....	F
Figure 8. Ontario-Hydro sampling train schematic	7
Figure 9. ESP ash hoppers, showing pipes used for transferring ash to the silo.....	A
Figure 10. ESP ash mercury vs. Carbon plot, Unit 1	B
Figure 11. ESP ash mercury vs. Carbon plot, Unit 2.....	C

LIST OF APPENDICES

APPENDIX A	Mercury Sampling Data	A-1
APPENDIX B	Plant Process Data	B-1
APPENDIX C	Flue Gas Hg Data	C-1
APPENDIX D	Process Material Data	D-1

LIST OF ABBREVIATIONS

acfm	- actual cubic feet per minute (wet)
am	- morning
Btu	- heating value in British Thermal Units
Ca/S	- calcium-sulfur ratio
cfm	- cubic feet per minute
CO ₂	- carbon dioxide
CONSOL R&D	- CONSOL Energy Inc., Research and Development
CVAA	- cold vapor atomic absorption
DI	- deionized water
DOE	- U.S. Department of Energy
dscf	- dry standard cubic feet
dscfm	- dry standard cubic feet per minute
EPA	- U.S. Environmental Protection Agency
EPRI	- Electric Power Research Institute
ESP	- electrostatic precipitator
FGD	- flue gas desulphurization
ft	- feet
ft ²	- square feet
ft ³	- cubic feet
gm	- grams
gpm	- gallons per minute
gr	- grains
HCl	- hydrochloric acid
Hg	- mercury
Hg ^{part}	- mercury in particulate form
Hg ^{total}	- total mercury in particulate, oxidized, and elemental forms
Hg ⁺⁺	- mercury in oxidized form
Hg ⁰	- mercury in elemental form
HNO ₃	- nitric acid
H ₂ O	- water
H ₂ O ₂	- hydrogen peroxide
hr	- hour
ICP-AES	- inductively coupled plasma-atomic emission spectrometer
in	- inch
KCl	- potassium chloride
KMnO ₄	- potassium permanganate
L	- liter
lb	- pound
m	- meter
m ³	- cubic meter
ME	- mist eliminator
mg	- milligram, 10 ⁻³ gram

LIST OF ABBREVIATIONS (continued)

min	- minute
mL	- milliliter
M	- molar, mol/L
MM	- million
mol	- mole
ng	- nanogram, 10^{-9} gram
N ₂	- molecular nitrogen
NIST	- National Institute of Standards and Technology
NO	- nitric oxide
NO ₂	- nitrogen dioxide
O ₂	- molecular oxygen
O ₃	- ozone
pm	- afternoon
PM	- particulate matter
ppb	- parts per billion (10^9)
ppm	- parts per million
ppmv	- parts per million by volume
PRSD	- percent relative standard deviation
QA	- quality assurance
QC	- quality control
rpm	- revolutions per minute
scf	- standard cubic feet (68°F and 29.92"Hg)
scfm	- standard cubic feet per minute
SRM	- Standard Reference Material
temp	- temperature
tph	- tons per hour
TBtu	- trillion (10^{12}) British thermal unit
wt	- weight
v	- volts
vs	- versus
° F	- temperature in degrees Fahrenheit
<	- less than
>	- more than
µg	- microgram, 10^{-6} gram

INTRODUCTION

CONSOL Energy Inc. Research and Development (CONSOL R&D) is determining mercury speciation and removal at 10 coal-fired facilities with SCR/FGD combinations (Table 1). CONSOL R&D conducted flue gas mercury (Hg) measurements on Units 1 and 2 at Plant 4 in January 2005. The two units are similar except that Unit 2 is equipped with a selective catalytic reduction (SCR) unit for NO_x control. The tests were performed under U. S. Department of Energy (DOE) Cooperative Agreement No. DE-FC26-02NT41589, and the Electric Power Research Institute (EPRI) Agreement No. EP-P13687/C6820. The test program on each unit consisted of four sets of measurements across the combustion emission control system that consists of the SCR (Unit 2 only), electrostatic precipitator (ESP), and flue gas desulfurization (FGD) systems.

The mercury measurements were made using the Ontario-Hydro Flue Gas Hg Speciation Method. The testing conducted by CONSOL R&D is documented in this report.

Table 1. Coal-fired facilities in program

Site #	MW	Air Pollution Control Devices	Coal	Ozone Unit
1	330	SCR / Spray Dryer / Baghouse	Bit	year round
2	245	SCR / Spray Dryer / Baghouse	Bit	year round
3	508	SCR / ESP/ Limestone FGD, inhibited oxidation	Bit	Yes
4 Unit 1	468	ESP/ Limestone FGD, natural oxidation	Bit	(¹)
4 Unit 2	468	SCR / ESP/ Limestone FGD, natural oxidation	Bit	year round
5 Unit 1	1,300	SCR / ESP/ Limestone FGD, in-situ oxidation	Bit	Yes
5 Unit 2	1,300	ESP/ Limestone FGD, in-situ oxidation	Bit	(¹)
6 (²)	544	SCR / ESP/ Limestone FGD, ex-situ oxidation	Bit	Yes
7 (²)	566	SCR / ESP/ Limestone FGD, ex-situ oxidation	Bit	Yes
8	684	SCR / ESP / Lime FGD, ex-situ oxidation	Bit	Yes
9	640	SCR / ESP/ Lime FGD, inhibited oxidation	Bit	Yes
10	1,300	SCR / ESP/ Lime FGD, inhibited oxidation	Bit	Yes

(¹) SCR was not installed when tests were conducted.

(²) Tests were also conducted during non-ozone seasons while flue gases bypassed SCR.

HOST UTILITY DESCRIPTION¹

Plant 4 is a 936 MW pulverized bituminous coal-fired generation facility operating two units. The plant typically burns bituminous coal containing less than 2.5% sulfur. Both units are equipped with ESP and limestone-based wet FGD to control the emissions of

¹ Per facility's Title V permit.

particulate matter and sulfur dioxide (SO₂). The FGDs are natural oxidation systems equipped with adipic acid feed to assist in SO₂ removal and are designed for 90% reduction. Unit 2 is equipped with a Siemens plate-type SCR; anhydrous ammonia is injected in front of the SCR catalyst beds to react with NO_x. The SCR unit is operated year-round.

Each unit is a dry-bottom wall-fired boiler with a nominal design heat input of 4,286 MM Btu per hour. Particulate matter is removed by a six-field, cold-side ESP. The ESP has 24 ash hoppers arranged in six rows of four hoppers each, one row per ESP field. The limestone-based wet FGD system has three 50%-capacity scrubber modules; only two modules are in service at any one time. The scrubber sludge is dewatered using gravity-settling type thickeners and vacuum filters and stabilized by mixing the solids with flyash and lime. The stabilized solids are landfilled. The scrubbed flue gas exits through a 550-ft stack.

MERCURY SAMPLING RESULTS

I. Test Matrix

Each set of mercury measurements consisted of a total of four tests over three days. The test matrix is shown in Table 2. A total of 16 flue gas mercury measurements were conducted at four locations (economizer outlet, air heater outlet, FGD inlet, and stack) on each unit. The two units were tested in separate weeks. The Ontario Hydro Method (ASTM Method D-6784-02) was used to perform the measurements. Mercury measurements were performed with a net sampling time of 120 minutes. Details of sampling conditions are provided later in this report.

To calculate the material balance, CONSOL R&D and plant personnel obtained process samples (coal, coal mill rejects, bottom ash, ESP ash, limestone slurry, FGD slurry, and FGD makeup/mist eliminator wash water) simultaneously during the gas sampling periods. CONSOL R&D performed all the sample laboratory analyses; no analysis was sub-contracted out. Detailed results of analyses are included in this report.

Table 2. Sampling test matrix

Date	Activity	Flue Gas Sampling				Process Sampling						
		Economizer Outlet	Air Heater Outlet	FGD Inlet	Stack	Coal	Coal Mill Rejects	Bottom Ash	Limestone Slurry	ESP Ash	FGD Slurry	FGD Makeup + ME Wash Water
18-Jan	Setup on Unit 1	---	---	---	---	---	---	---	---	---	---	---
19-Jan	Test 1	X	X	X	X	X	X	X	X	X	X	---
20-Jan	Test 2	X	X	X	X	X	---	X	X	X	X	---
	Test 3	X	X	X	X		---		X	X	X	X
21-Jan	Test 4, Move to Unit 2	X	X	X	X	X	---	---	X	X	X	X
Week-end	None	---	---	---	---	---	---	---	---	---	---	---
24-Jan	Setup on Unit 2, Test 1	X	X	X	X	X	X	---	X	X	X	X
25-Jan	Test 2	X	X	X	X	X	X	X	X	X	X	X
	Test 3	X	X	X	X		X		X	X	X	X
26-Jan	Test 4	X	X	X	X	X	X	X	X	X	X	X
27-Jan	Pack, Demobilize	---	---	---	---	---	---	---	---	---	---	---

II. Flue Gas Mercury Sampling Results

Figures 1 and 2 show the mercury speciation for the four tests conducted at each location on Units 1 (no SCR) and 2 (with SCR), respectively. All tests were conducted isokinetically. A complete listing of mercury analyses is in Appendix C. The results at each location are discussed in the following sections. The associated tables list the measured Ontario Hydro sampling train concentrations and the mercury throughput for the respective location with the concentrations applied to the stack flow rate corrected to the locations' oxygen concentration. Adjusting the mercury throughput to the stack flow rate is more accurate as this is the only location where flow could be measured accurately.

A. Economizer Outlet

Four mercury measurements were conducted at the economizer outlet (air heater inlet on Unit 1 and SCR inlet on Unit 2) on both units. Table 3 summarizes the results, which show that about 99% of the mercury was in the gas phase and about 1% of the mercury was in the particulate form (Hg^{part}). The high percentage of gas phase mercury is expected due to the gas temperature (673-714°F) at this location. About forty percent of the total mercury was in the elemental form (Hg^0) at both units.

Table 3. Flue gas mercury speciation at the Economizer Outlet

Date	Test No.	Hg Concentration, $\mu\text{g}/\text{m}^3$ (dry std conditions)				Hg Flow, mg/sec			
		Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}	Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}
1/19	Unit 1, Test 1	0.061	4.82	4.50	9.37	0.025	1.98	1.85	3.85
1/20	Unit 1, Test 2	0.073	4.97	3.36	8.41	0.031	2.07	1.40	3.49
1/20	Unit 1, Test 3	0.073	4.85	2.97	7.89	0.031	2.06	1.26	3.35
1/21	Unit 1, Test 4	0.096	3.57	1.58	5.25	0.041	1.53	0.68	2.25
Average		0.076	4.55	3.10	7.73	0.032	1.91	1.30	3.24
Standard Deviation		0.014	0.66	1.20	1.76	0.007	0.26	0.48	0.69
PRSD		19%	14%	39%	23%	21%	13%	37%	21%
Date	Test No.	Hg Concentration, $\mu\text{g}/\text{m}^3$ (dry std conditions)				Hg Flow, mg/sec			
		Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}	Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}
1/24	Unit 2, Test 1	0.079	5.76	4.58	10.4	0.033	2.42	1.92	4.38
1/25	Unit 2, Test 2	0.074	6.11	4.55	10.7	0.032	2.63	1.96	4.62
1/25	Unit 2, Test 3	0.082	5.96	3.23	9.28	0.034	2.50	1.36	3.89
1/26	Unit 2, Test 4	0.106	4.57	3.84	8.52	0.046	2.00	1.68	3.72
Average		0.085	5.60	4.05	9.74	0.036	2.39	1.73	4.15
Standard Deviation		0.014	0.70	0.64	1.03	0.007	0.27	0.28	0.42
PRSD		17%	12%	16%	11%	19%	11%	16%	10%

B. Air heater outlet

Four mercury measurements were conducted at the air heater outlet location in on both units. Table 4 summarizes the results. The majority (87-96%) of the mercury was vapor-phase Hg⁺⁺. On both units, a substantial portion of the elemental mercury was oxidized in the air heater or SCR/air heater combination. Compared to about 40% elemental mercury at the economizer outlet, only 9% was elemental at Unit 1's air heater outlet and only 2.6% was elemental at Unit 2's air heater outlet. The results also show that the SCR-air heater combination on Unit 2 oxidized more mercury than the air

heater (with no SCR) on Unit 1. The elemental mercury reduction from the economizer exit to the air heater exit was 77% on Unit 1 (1.30 to 0.30 mg/sec) and 95% on Unit 2 (1.73 to 0.09 mg/sec).

Table 4. Flue gas mercury speciation at the air heater outlet

Date	Test No.	Hg Concentration, $\mu\text{g}/\text{m}^3$ (dry std conditions)				Hg Flow, mg/sec			
		Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}	Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}
1/19	Unit 1, Test 1	0.63	5.65	0.23	6.52	0.28	2.56	0.11	2.95
1/20	Unit 1, Test 2	0.05	6.88	0.90	7.83	0.01	3.18	0.41	3.61
1/20	Unit 1, Test 3	0.17	6.55	1.05	7.77	0.08	3.04	0.49	3.61
1/21	Unit 1, Test 4	0.13	4.62	0.38	5.12	0.06	2.18	0.18	2.41
Average		0.24	5.93	0.64	6.81	0.11	2.74	0.30	3.15
Standard Deviation		0.26	1.01	0.39	1.28	0.12	0.46	0.18	0.58
PRSD		108%	17%	62%	19%	106%	17%	62%	18%
Date	Test No.	Hg Concentration, $\mu\text{g}/\text{m}^3$ (dry std conditions)				Hg Flow, mg/sec			
		Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}	Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}
1/24	Unit 2, Test 1	0.27	6.97	0.19	7.43	0.12	3.20	0.09	3.41
1/25	Unit 2, Test 2	1.25	6.31	0.19	7.75	0.58	2.92	0.09	3.59
1/25	Unit 2, Test 3	0.62	6.57	0.24	7.42	0.29	3.07	0.11	3.47
1/26	Unit 2, Test 4	1.56	5.25	0.14	6.95	0.73	2.44	0.06	3.22
Average		0.92	6.27	0.19	7.39	0.43	2.91	0.09	3.42
Standard Deviation		0.59	0.74	0.04	0.33	0.27	0.34	0.02	0.15
PRSD		64%	12%	23%	4%	64%	12%	23%	4%

C. FGD inlet

Four mercury measurements were conducted at the FGD inlet location at both units. Table 5 summarizes the results. In both units, nearly 100% of the flue gas mercury was in the gaseous phase because this location is downstream of the ESP. On Unit 1, 93%

of the mercury entering the scrubber was in the oxidized form, while 98% was in the oxidized form entering Unit 2's scrubber.

Table 5. Flue gas mercury speciation at the FGD inlet

Date	Test No.	Hg Concentration, $\mu\text{g}/\text{m}^3$ (dry std conditions)				Hg Flow, mg/sec			
		Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}	Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}
1/19	Unit 1, Test 1	2.63×10^{-3}	6.25	0.38	6.63	1.27×10^{-3}	3.03	0.18	3.21
1/20	Unit 1, Test 2	2.56×10^{-3}	6.52	0.27	6.79	1.22×10^{-3}	3.11	0.13	3.24
1/20	Unit 1, Test 3	2.71×10^{-3}	7.46	0.37	7.83	1.32×10^{-3}	3.63	0.18	3.81
1/21	Unit 1, Test 4	2.52×10^{-3}	3.43	0.46	3.90	1.23×10^{-3}	1.67	0.23	1.90
Average		2.60×10^{-3}	5.92	0.37	6.29	1.26×10^{-3}	2.86	0.18	3.04
Standard Deviation		8.29×10^{-5}	1.73	0.08	1.68	4.55×10^{-5}	0.83	0.04	0.81
PRSD		3%	29%	22%	27%	4%	29%	23%	27%
Date	Test No.	Hg Concentration, $\mu\text{g}/\text{m}^3$ (dry std conditions)				Hg Flow, mg/sec			
		Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}	Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}
1/24	Unit 2, Test 1	2.88×10^{-3}	7.18	0.13	7.31	1.37×10^{-3}	3.40	0.061	3.47
1/25	Unit 2, Test 2	3.14×10^{-3}	7.91	0.13	8.05	1.49×10^{-3}	3.76	0.064	3.83
1/25	Unit 2, Test 3	3.22×10^{-3}	7.85	0.13	7.98	1.54×10^{-3}	3.74	0.060	3.81
1/26	Unit 2, Test 4	3.10×10^{-3}	6.35	0.15	6.50	1.50×10^{-3}	3.06	0.070	3.13
Average		3.09×10^{-3}	7.32	0.13	7.46	1.47×10^{-3}	3.49	0.064	3.56
Standard Deviation		1.45×10^{-4}	0.73	0.01	0.72	7.34×10^{-5}	0.33	0.004	0.33
PRSD		5%	10%	7%	10%	5%	9%	7%	9%

D. Stack

Four mercury measurements were conducted at the stack on both units. Table 6 summarizes the results. On Unit 1, elemental mercury increased by 83%, from 0.18 mg/sec at the FGD inlet to 0.33 mg/sec at the stack. On Unit 2, the elemental mercury was essentially the same, 0.06 at the FGD inlet and 0.07 at the stack. An increase of

Hg⁰ across wet scrubbers has been observed by CONSOL R&D at many other plants^{2,3}. It is not clear why an increase did not occur in Unit 2's scrubber.

Table 6. Flue gas mercury speciation at the stack

Date	Test No.	Hg Concentration, µg/m ³ (dry std conditions)				Hg Flow, mg/sec			
		Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}	Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}
1/19	Unit 1, Test 1	2.26 x10 ⁻³	0.45	0.32	0.77	1.11 x10 ⁻³	0.22	0.16	0.38
1/20	Unit 1, Test 2	2.24 x10 ⁻³	0.35	0.80	1.16	1.11 x10 ⁻³	0.17	0.40	0.57
1/20	Unit 1, Test 3	2.24 x10 ⁻³	0.32	1.06	1.39	1.11 x10 ⁻³	0.16	0.52	0.69
1/21	Unit 1, Test 4	2.21 x10 ⁻³	0.26	0.52	0.79	1.10 x10 ⁻³	0.13	0.26	0.39
Average Standard Deviation PRSD		2.24x10 ⁻³ 2.44 x10 ⁻⁵ 1%	0.35 0.08 23%	0.68 0.33 48%	1.03 0.30 29%	1.11 x10 ⁻³ 4.79 x10 ⁻⁶ 0.4%	0.17 0.04 22%	0.33 0.16 48%	0.51 0.15 29%
Date	Test No.	Hg Concentration, µg/m ³ (dry std conditions)				Hg Flow, mg/sec			
		Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}	Hg ^{part}	Hg ⁺⁺	Hg ⁰	Hg ^{total}
1/24	Unit 2, Test 1	2.30x10 ⁻³	0.21	0.16	0.38	1.11 x10 ⁻³	0.101	0.079	0.18
1/25	Unit 2, Test 2	2.29 x10 ⁻³	0.35	0.16	0.52	1.11 x10 ⁻³	0.172	0.077	0.25
1/25	Unit 2, Test 3	2.26 x10 ⁻³	0.12	0.14	0.25	1.11 x10 ⁻³	0.056	0.067	0.12
1/26	Unit 2, Test 4	2.23 x10 ⁻³	0.16	0.10	0.27	1.10 x10 ⁻³	0.079	0.051	0.13
Average Standard Deviation PRSD		2.27 x10 ⁻³ 3.21 x10 ⁻⁵ 1%	0.21 0.10 50%	0.14 0.03 19%	0.35 0.12 34%	1.11 x10 ⁻³ 7.03 x10 ⁻⁶ 0.6%	0.102 0.050 49%	0.069 0.013 19%	0.17 0.06 34%

² DeVito, M. S., Withum, J. A., and Statnick, R. M., "Flue Gas Measurements from Coal-Fired Boilers Equipped with Wet Scrubbers," Int. J. of Environ. Pollution 17 (1/2), 2002, p. 126-142

³ Evaluation of Mercury Emissions from Coal-Fired Facilities with SCR and FGD Systems - Topical Report Nos. 1, and 4 through 9, U.S. DOE Cooperative Agreement DE-FC26-02NT41589

III. SCR/FGD System Hg Removal

Table 7 summarizes the flue gas mercury removal across the SCR/FGD system for the two units. In Unit 2 (with SCR), the air heater outlet-to-stack mercury removal ranged from 93 to 96% and the average was 95.0%. The coal-to-stack mercury removal ranged from 96 to 98% and the average coal-to-stack mercury removal was 97.1%. In Unit 1 (no SCR), the air heater outlet-to-stack mercury removal ranged from 81 to 87% and the average was 84.0%. The coal-to-stack mercury removal ranged from 85 to 90% and the average coal-to-stack mercury removal was 87.1%.

Table 7. Flue gas mercury removal

Date	Test No.	System Mercury Reduction					
		Ontario Hydro Results, mg Hg ^{total} /sec			Coal Feed Based Reduction, mg Hg ^{total} /sec		
		Air Heater Outlet	Stack Emissions	% Reduction	Coal Feed	Stack Emissions	% Reduction
1/19	Unit 1, Test 1	2.95	0.38	87	3.85	0.38	90
1/20	Unit 1, Test 2	3.61	0.57	84	4.54	0.57	87
1/20	Unit 1, Test 3	3.61	0.69	81	4.50	0.69	85
1/21	Unit 1, Test 4	2.41	0.39	84	2.79	0.39	86
Average		3.15	0.51	84.0	3.92	0.51	87.1
Standard Deviation		0.58	0.15	2.5	0.81	0.15	2.3
PRSD		18%	29%	3%	21%	29%	3%
Date	Test No.	System Mercury Reduction					
		Ontario Hydro Results, mg Hg ^{total} /sec			Coal Feed Based Reduction, mg Hg ^{total} /sec		
		Air Heater Outlet	Stack Emissions	% Reduction	Coal Feed	Stack Emissions	% Reduction
1/24	Unit 2, Test 1	3.41	0.18	95	5.87	0.18	97
1/25	Unit 2, Test 2	3.59	0.25	93	6.70	0.25	96
1/25	Unit 2, Test 3	3.47	0.12	96	6.67	0.12	98
1/26	Unit 2, Test 4	3.22	0.13	96	4.60	0.13	97
Average		3.42	0.17	95.0	5.96	0.17	97.1
Standard Deviation		0.15	0.06	1.5	0.99	0.06	0.8
PRSD		4%	34%	1.6%	17%	34%	0.8%

IV. Mercury Material Balance

An important criterion to gauge the overall quality of the tests is to conduct a mercury mass balance to account for the mercury entering and leaving the plant during the tests. The mercury material balance closure is the total mercury output from the plant divided by the total mercury input (expressed as %). The total mercury input is the sum of the amounts of mercury entering the system from coal, limestone slurry, and FGD make-up water. The total mercury output is the sum of the amounts of mercury leaving the system via coal mill rejects, boiler bottom ash, ESP hopper ash, FGD slurry, and stack flue gas.

Tables 8 and 9 summarize the mercury material balance closures for the tests conducted at Units 1 and 2, respectively. The mercury material balance closures ranged from 72% to 104% on Unit 1 and between 93 and 109% on Unit 2. The material balance closures for mercury for all individual tests are within our QA/QC criterion of 70-130% for a single test. The average material balance closure was 84% on Unit 1 and 103% on Unit 2, which are within our QA/QC criterion of 80-120% for multiple tests. The measurements, calculations, and assumptions for calculating the material balances are described later in this report.

Table 8. Mercury material balance closure, Unit 1 (no SCR)

Test No.	1	2	3	4
Total Hg Input (mg/sec)	3.91	4.60	4.55	2.87
Total Hg Output (mg/sec)	3.15	3.31	3.61	2.96
Hg Material Balance Closure (output / input)	81%	72%	79%	104%
Average Hg Material Balance Closure (%)	84%±13%			

Table 9. Mercury material balance closure, Unit 2 (with SCR)

Test No.	1	2	3	4
Total Hg Input (mg/sec)	3.36	3.89	3.84	4.00
Total Hg Output (mg/sec)	3.67	4.08	4.10	3.70
Hg Material Balance Closure (output / input)	109%	105%	107%	93%
Average Hg Material Balance Closure (%)	103%±7%			

V. SCR/Non-SCR Test Comparison

At the inlet to the ESP and at the inlet to the FGD, the percentage of flue gas elemental mercury was lower in the SCR-equipped unit compared to the non-SCR unit. This is important because these two pollution control devices are efficient at removing particulate and oxidized mercury, but not elemental mercury. Table 10 compares the average mercury speciation of the flue gas in the air heater outlet (ESP inlet) duct and in the ESP outlet (FGD inlet) duct for both units.

Table 10. Comparisons of Average Flue Gas Mercury Speciation, SCR Unit vs. Non-SCR Unit, at the Air Heater Outlet and at the FGD Inlet

Mercury Species	Percent of Total Mercury at the Air Heater Outlet (ESP Inlet)		Percent of Total Mercury at the ESP Outlet (FGD Inlet)	
	Unit 1 (with no SCR)	Unit 2 (with SCR)	Unit 1 (with no SCR)	Unit 2 (with SCR)
Hg^{part}	3%	12%	0%	0%
Hg⁺⁺	87%	85%	94%	98%
Hg⁰	10%	3%	6%	2%

Mercury removal in Unit 2's FGD scrubber was different from that of Unit 1. Table 11 shows that 94-97% of the oxidized mercury exiting the ESP was removed in the FGD scrubber in both units. However, the amount of elemental mercury increased across the scrubber, and the increase was greater in Unit 1 than in Unit 2; an increase in elemental mercury in wet scrubbers has been observed in tests at other plants in this program³. The reason for the greater effect in the Unit 1 scrubber compared to the Unit 2 scrubber is not clear; scrubber sulfite concentration is believed to play a role but this has not been verified. Scrubber sulfite concentration was not measured in this test program.

Table 11. Comparison of Average Mercury Reductions Across the FGD Scrubber

Mercury Species	Unit 1 (with no SCR)			Unit 2 (with SCR)		
	FGD Inlet, mg Hg/sec	Stack, mg Hg/sec	Reduction Across FGD Scrubber	FGD Inlet, mg Hg/sec	Stack, mg Hg/sec	Reduction Across FGD Scrubber
Hg^{part}	<0.002	<0.002	--	<0.002	<0.002	--
Hg⁺⁺	2.86	0.17	94%	3.49	0.10	97%
Hg⁰	0.18	0.33	-83%	0.064	0.069	-8%
Total Hg	3.04	0.51	83%	3.56	0.17	95%

EXPERIMENTAL AND SAMPLING METHODS

CONSOL R&D performed flue gas mercury determinations using the Ontario-Hydro sampling method. As a quality assurance/quality control (QA/QC) measure, samples of

the coal, bottom ash, FGD slurry, limestone slurry, and ESP ash, were taken to determine a mercury balance across the system.

I. Flue Gas Sampling Locations and Sampling Points

Four sampling locations, the economizer outlet, air heater outlet (upstream of the ESP), FGD inlet, and stack outlet, were tested. Figure 3 is a flow schematic indicating the sampling locations at these units.

At each unit, flue gas exits the economizer through two ducts (designated Ducts A and B) and passes through the SCR, air heater, ESP, and FGD, before it combines to form a single flue tube at the stack. All sampling at points leading to the stack was conducted in Duct A of each unit. Individual sampling locations are detailed in the following sections.

A. Economizer outlet

On each unit, the economizer outlet consists of two horizontal, rectangular ducts, measuring 14.5 feet deep by 25 wide at the sampling plane. Eight sample ports are spaced across the top of each duct.

Preliminary pitot surveys indicated that the gas flow was straight, not cyclonic or swirling. The flue gas was sampled through the middle test port at a single point in each duct, 60 minutes per duct for each test. Parametric readings were recorded every ten minutes. Total test duration was 120 minutes. Mercury measurements were conducted with the sampling nozzle oriented parallel to and directly into the flow.

Four mercury measurements were performed isokinetically at the economizer outlet on each unit. The sample train was prepared in EPA Method 17 configuration using an in-stack 19 mm x 90 mm quartz-fiber thimble filter. The filter apparatus was attached to a heated probe that was connected to the impinger train with a flexible heated Teflon sample line. Figure 4 is a photograph of the mercury sampling train at the economizer outlet.

B. Air heater outlet

On each unit, the air heater outlet duct consists of four horizontal ducts, each approximately 11 feet 8 inches deep and 11 feet 8 inches wide. Six test ports are located across the top of each duct. Preliminary pitot surveys indicated that the gas flow was parallel to the duct walls.

The flue gas was sampled through the middle test port at a single point in each duct, 30 minutes per duct for each test. Total test durations were 120 minutes with parametric readings recorded every ten minutes. Mercury measurements were conducted with the sampling nozzle oriented parallel to and directly into the flow.

Four mercury measurements were performed isokinetically at the air heater outlet on each unit. The sample train was prepared in EPA Method 17 configuration using an in-stack 19 mm x 90 mm quartz-fiber thimble filter. The filter apparatus was attached to a heated probe that was connected to the impinger train with a flexible heated Teflon

sample line. Figure 5 is a photograph of the mercury sampling train at the air heater outlet location.

C. FGD inlet

The FGD inlet at each unit consists of two horizontal ducts leading from the ID fans to the scrubbers. A single test port was available in each duct, downstream of the induced draft fan. A single point near the center of each duct was sampled, 60 minutes per duct, for each test. A preliminary pitot survey indicated that the gas flow was parallel to the duct walls at this point.

Parametric readings were recorded every ten minutes for each test period, which was 120 minutes net sampling time. Mercury measurements were conducted isokinetically with the sampling nozzle oriented parallel to and directly into the flow.

Four mercury measurements were performed at the FGD inlet on each unit. The sample train was prepared in EPA Method 17 configuration using an in-stack 47-mm quartz-fiber disc filter. The filter apparatus was attached to a heated probe that was connected to the impinger train with a flexible heated Teflon sample line. Figure 6 is a photograph of the mercury sampling train on the FGD inlet location.

D. Stack

Both stacks are approximately 19 feet in diameter. On each stack, three points were sampled in each of four sample access ports for a total of 12 traverse points. Each point was sampled for a period of 10 minutes resulting in 120-minute tests.

Preliminary pitot surveys indicated that the gas flow was axial. Mercury measurements were conducted with the nozzle oriented horizontally, directly into the flow. Four measurements were performed isokinetically at this location on each unit. A standard EPA Method 5 sample train configuration was utilized for this location. Figure 7 is a photograph of the mercury sampling train on the stack location.

II. Flue Gas Mercury Measurements

Flue gas mercury measurements were conducted using the Ontario-Hydro mercury speciation train. A schematic of the sampling train is shown in Figure 8.

The flue gas was extracted from the duct and pulled through a heated glass-lined probe and quartz filter. Total particulate matter mass loading was calculated from the solids collected prior to and on the filter. Probe temperatures were set at 325 ± 25 °F at the SCR inlet and outlet, the air heater outlet and the FGD inlet. Probe and filter temperatures were maintained at 250 ± 25 °F at the stack. Where particle loading is high, the probe and filter are maintained as close as practical to the flue gas temperature.

Mercury collected prior to and on the filter is assumed to be Hg^{part} . The flue gas exits the quartz filter and passes through a series of chilled impingers. The first three impingers are filled with 100 mL of a 1M-potassium chloride (KCl) solution. It is assumed that these impingers capture Hg^{++} in the flue gas. The next impinger is filled

with 100 mL of a 5% nitric acid and 10% hydrogen peroxide (H₂O₂) solution. The purpose of this impinger is to remove SO₂ from the flue gas to preserve the oxidizing strength of the two downstream impingers with acidic potassium permanganate (KMnO₄) solution. Mercury collected in this impinger is assumed to be Hg⁰. The next two impingers are filled with 100 mL of an acidic KMnO₄ solution. It is assumed that these impingers capture Hg⁰. The next impinger is blank to catch any excess moisture. The gas exits the impinger train through a silica gel-filled impinger that removes the moisture from the flue gas. The mercury species collected by the Ontario-Hydro sampling train component are listed in Table 12.

Table 12. Mercury speciation by train component

Train Component	Species Measured
Probe & Nozzle Rinse	Hg ^{part}
Quartz Filter	Hg ^{part}
KCl Impingers	Hg ⁺⁺
HNO ₃ /H ₂ O ₂ Impinger	Hg ⁰
KMnO ₄ Impingers	Hg ⁰
HCl Rinse of KMnO ₄ Impingers	Hg ⁰

The absorbing solutions were made fresh daily. The impingers were charged and the sampling components were transported to the required locations. The sampling trains were assembled, pre-heated, and checked for pitot and sample line leaks as detailed in EPA Methods 2 and 5, respectively. After passing the leak-check procedure, the sampling probes were inserted into their respective ducts, in-stack filters were allowed to heat to stack temperature, and sampling was initiated. Leak checks were also performed during port changes.

Oxygen readings were monitored at the outlet of the sampling train using a Teledyne Model Max 5 portable analyzer (electrochemical O₂ sensor). At the completion of the sampling period, the sample trains were checked for leaks, purged for 10 min, and then disassembled. The components were transported back to the lab trailer for recovery. The mercury concentration of the individual impinger solutions was determined by cold vapor atomic absorption (CVAA) as specified in the methodology. The concentration of mercury on the solids was determined by acid digestion followed by CVAA.

The amount of mercury collected in the impinger solutions was determined as outlined in EPA Method 29 and the Ontario-Hydro Draft Method. An aliquot of the impinger solution was acidified and the mercury is determined using cold vapor-atomic absorption spectroscopy. The atomic absorption spectrometer was calibrated with commercial mercury standard. The calibration was verified using NIST Standard

Reference Materials (SRM) 1641D and 1633b. The calibration was reassessed periodically by analyzing a quality control standard. The instrument was recalibrated as required. Each sample matrix was analyzed as a set and an individual calibration curve was used for each set. Depending on sample type, selected samples were spiked with 2, 5, 10, or 15 ng/ml (ppb) of mercury and reanalyzed. Spike recovery must be within $\pm 30\%$ or the sample is diluted and reanalyzed. Selected samples were analyzed in duplicate. The duplicates must be within $\pm 30\%$ or the analyses are repeated.

Where sufficient solids were collected, particulate mercury was analyzed using a 0.5-1.0 gm ash sample with the direct combustion method (ASTM Method D6722). In cases where the particulate catch was low (primarily stack filters), the entire filter sample was digested with aqua-regia in pressure vessels prior to analysis by CVAA.

III. Coal Sampling and Analysis

A. Coal samples

Plant personnel collected coal samples from coal being fed to the top of the coal bunkers. The samples were collected between midnight and 6:00 am the morning of each test day. This lead time was required because of the 6-12 hour residence time in the coal bunkers before the coal reaches the burners. Listed in Table 13 are the coal samples collected.

Table 13. List of coal samples

Unit 1 Test No.	1	2 & 3	4
Sample Date	1/19/2005	1/20/2005	1/21/2005
Sample I.D.	COAL-U1T1	COAL-U1T2T3	COAL-U1T4
Unit 2 Test No.	1	2 & 3	4
Sample Date	1/24/2005	1/25/2005	1/26/2005
Sample I.D.	COAL-U2T1	COAL-U2T2T3	COAL-U2T4

B. Results of analyses of coal samples

Coal samples were analyzed using a direct mercury analyzer following the procedures prescribed in ASTM Method D6722. Detailed analyses of the coal samples collected in each test are presented in Appendix D and the results are summarized in Tables 14 and 15. The mercury measured in the Unit 1 coal samples ranged from 0.066 to 0.110 ppm and in the Unit 2 coal samples ranged from 0.080 to 0.095 ppm.

Table 14. Coal sample analyses – Unit 1 samples

Sample I.D.	Coal-U1T1	Coal-U1T2T3	Coal-U1T4
Sample Date	01/19/2005	01/20/2005	01/21/2005
Test No.	1	2 & 3	4
Analytical No.	20050682	20050683	20050684
Residual moisture, as det'd (%)	2.00	1.89	1.37
Volatile matter (% _{dry})	38.08	38.40	37.32
Ash (% _{dry})	7.77	8.24	11.85
Total carbon (% _{dry})	77.74	77.01	74.83
Fixed carbon (% _{dry})	54.15	53.36	50.83
Hydrogen (% _{dry})	4.63	4.81	4.65
Nitrogen (% _{dry})	1.56	1.61	1.58
Total sulfur (% _{dry})	1.39	1.45	1.19
Oxygen (% _{dry}), by diff.	6.77	6.74	5.74
HHV (Btu/lb, dry)	13,683	13,686	13,205
HHV (Btu/lb, MAF)	14,836	14,915	14,980
Chlorine (% _{dry})	0.144	0.143	0.157
Hg (ppm, as det'd)	0.091	0.110	0.066
Major Ash Elements (% _{dry})			
SiO ₂	50.01	50.46	54.52
Al ₂ O ₃	27.77	26.57	26.87
TiO ₂	1.29	1.34	1.09
Fe ₂ O ₃	12.63	12.73	9.17
CaO	1.73	1.69	1.50
MgO	1.00	0.98	1.17
Na ₂ O	0.55	0.53	0.63
K ₂ O	2.28	2.29	2.90
P ₂ O ₅	0.18	0.25	0.11
SO ₃	1.68	1.62	1.24

Table 15. Coal sample analyses – Unit 2 samples

Sample Description	As-fired Coal		
	Coal-U2T1	Coal-U2T2T3	Coal-U2T4
Sample I.D.	Coal-U2T1	Coal-U2T2T3	Coal-U2T4
Test No.	1	2 & 3	4
Test Date	01/24/2005	01/25/2005	01/26/2005
Analytical No.	20050685	20050686	20050687
Moisture, as det'd (%)	1.83	1.49	1.61
VM (% dry)	38.57	36.26	35.46
Ash (% dry)	8.40	8.69	8.28
Total Carbon (% dry)	77.39	76.66	77.44
Fixed Carbon (% dry)	53.03	55.05	56.26
Hydrogen (% dry)	4.72	4.67	4.77
Nitrogen (% dry)	1.52	1.46	1.53
Total Sulfur (% dry)	1.66	1.59	1.38
Oxygen (% dry), by diff.	6.17	6.80	6.45
HHV (Btu/lb, dry)	13,764	13,663	13,761
HHV (Btu/lb, MAF)	15,026	14,963	15,003
Chlorine (% dry)	0.141	0.135	0.151
Hg (ppm, as det'd)	0.080	0.090	0.095
Major Ash Elements (% dry)			
SiO ₂	49.70	51.13	50.50
Al ₂ O ₃	24.10	23.98	28.16
TiO ₂	1.15	1.05	1.41
Fe ₂ O ₃	16.77	15.05	11.76
CaO	1.68	2.81	1.58
MgO	1.16	0.72	0.95
Na ₂ O	0.57	0.65	0.53
K ₂ O	2.58	1.86	2.35
P ₂ O ₅	0.22	0.35	0.47
SO ₃	1.52	1.54	1.39
UND	0.55	0.86	0.90

IV. Process Sample Collection and Analysis

CONSOL R&D and plant personnel collected samples of coal mill rejects, boiler bottom ash, ESP hopper ash, limestone slurry, FGD slurry, and FGD makeup water. CONSOL R&D analyzed the samples using a direct mercury analyzer and following prescribed in the procedures of ASTM Method D6722. Detailed results of the analyses of those process samples are presented in Appendix D.

A. Coal Mill Rejects

Plant operators collected coal mill reject samples during the first test on Unit 1 and all of the tests on Unit 2. Although the mercury content of these samples is high (0.4 to 3.0 ppm) the contribution to the overall mercury balance is insignificant, since the flow rate is only about 0.5% of the coal flow rate.

Table 16. Coal mill reject sample analyses – both units

Sample I.D.	Rejects U1T1	Rejects U2T1	Rejects U2T2	Rejects U2T3	Rejects U2T4
Sample Date	01/19/2005	01/24/2005	01/25/2005	01/25/2005	01/26/2005
Test No.	1	1	2	3	4
Analytical No.	20050688	20050689	20050690	20050691	20050692
Residual moisture, as det'd (%)	1.50	0.82	0.68	0.44	0.48
Volatile matter (% dry)	35.77	28.78	30.88	26.31	26.69
Ash (% dry)	14.88	39.74	46.20	58.31	52.38
Total carbon (% dry)	69.43	46.83	39.74	24.51	32.41
Fixed carbon (% dry)	49.35	31.48	22.92	15.38	20.93
Hydrogen (% dry)	4.25	2.82	2.37	1.45	1.95
Nitrogen (% dry)	1.32	0.81	0.66	0.38	0.53
Total sulfur (% dry)	3.20	6.07	8.74	17.98	14.97
Oxygen (% dry), by diff.	6.84	3.66	2.23	2.66	2.28
HHV (Btu/lb, dry)	12,413	8,456	6,899	4,502	5,954
HHV (Btu/lb, MAF)	14,583	14,033	12,823	10,799	12,503
Chlorine (% dry)	0.085	0.074	0.060	0.040	0.040
Hg (ppm, as det'd)	0.426	0.783	2.330	2.630	3.000
Major Ash Elements (% dry)					
SiO ₂	45.98	45.27	28.75	25.07	23.91
Al ₂ O ₃	22.24	17.97	11.82	6.85	6.99
TiO ₂	1.22	0.88	0.46	0.33	0.40
Fe ₂ O ₃	21.31	24.07	40.41	52.03	49.64
CaO	2.18	4.66	8.41	7.45	7.58
MgO	0.81	0.85	0.89	0.68	0.50
Na ₂ O	0.48	0.28	0.21	0.17	0.13
K ₂ O	1.63	1.03	0.81	0.72	0.59
P ₂ O ₅	0.35	0.22	0.13	0.04	0.04
SO ₃	1.62	3.81	8.17	7.95	8.54

B. Boiler Bottom ash

Plant personnel and CONSOL personnel collected bottom ash samples at the end of the first two test days on Unit 1 (samples U1T1 and U1T2T3) and the last two test days on Unit 2 (samples U2T2T3 and U2T4). Listed in Table 17 are the results of analyses of the bottom ash samples.

Table 17. Results of analyses of bottom ash samples

Sample I.D.	BTMASH-U1T1	BTMASH-U1T2T3	BTMASH-U2T2T3	BTMASH-U2T4
Test No.	1	2	2 & 3	4
Sample Date	01/19/2005	01/20/2005	01/25/2005	01/26/2005
Sampling Time	16:30-16:40	16:30	16:00-16:30	11:15-11:45
Analytical No.	20050693	20050694	20050697	20050698
Residual moisture, as det'd (%)	0.01	0.01	0.10	0.01
Ash (% dry)	99.73	99.99	98.16	99.03
Total carbon (% dry)	0.39	0.20	1.93	1.12
Total sulfur (% dry)	0.02	0.00	0.32	0.10
Chlorine (% dry)	0.025	0.027	0.035	0.048
Hg (ppm, as det'd)	0.011	0.011	0.074	0.017
Major Ash Elements (% dry)				
SiO ₂	51.91	52.37	51.02	52.96
Al ₂ O ₃	25.87	25.86	24.66	26.12
TiO ₂	1.36	1.38	1.33	1.44
Fe ₂ O ₃	13.81	14.13	14.96	12.62
CaO	1.45	1.47	1.35	1.45
MgO	0.89	0.90	0.92	0.91
Na ₂ O	0.48	0.47	0.46	0.47
K ₂ O	2.18	2.19	2.23	2.25
P ₂ O ₅	0.14	0.16	0.22	0.30
SO ₃	0.04	0.01	0.80	0.24
UND	1.87	1.06	2.05	1.24

C. Limestone slurry

The plant's FGD operators collected a limestone slurry sample of approximately 500 mL during each test. Upon arrival at CONSOL R&D's analytical labs, the limestone slurry samples were filtered to generate a filtrate and a solid residue (i.e., filter cake). The air-dried solids and the filtrates were analyzed separately. Listed in Table 18 and 19 are the results of analyses of the limestone slurry solids samples. The mercury content of the solids of the limestone slurry samples ranged from 0.038 to 0.068 ppm. Listed in Table 20 and 21 are the results of analyses of the limestone slurry filtrate samples. The mercury in all of

the limestone filtrate samples was below the detection limit of 1.0 µg/L (1.0 ppb) for all but one sample (test 2 on Unit 2), which contained 1.3 µg/L.

Table 18. Results of analyses of limestone slurry solids samples – Unit 1

Sample I.D.	LS U1T1	LS U1T2	LS U1T3	LS U1T4
Test No.	1	2	3	4
Sample Date	01/19/2005	01/20/2005	01/20/2005	01/21/2005
Sampling Time	9:35	9:45	13:45	9:15
Analytical No.	20050699	20050700	20050701	20050702
% Solids in original sample	20.3	28.5	21.0	22.0
Density of original sample (g/mL)	1.08			
Residual moisture, as det'd (%)	0.60	0.60	0.73	0.76
Ash (% dry)	56.69	56.52	56.76	56.92
Total carbon (% dry)	11.67	11.34	11.58	11.55
Chlorine (% dry)	0.05	0.07	0.04	0.11
Hg (ppm, as det'd)	0.044	0.045	0.038	0.063
Major Ash Elements (% as det'd)				
SiO ₂	1.49	1.45	1.17	1.76
Al ₂ O ₃	0.15	0.22	0.16	0.18
TiO ₂	0.01	0.01	0.01	0.01
Fe ₂ O ₃	0.14	0.17	0.18	0.18
CaO	53.60	53.39	53.23	53.58
MgO	1.15	1.31	1.47	1.51
Na ₂ O	0.06	0.08	0.06	0.05
K ₂ O	0.03	0.07	0.02	0.03
P ₂ O ₅	0.08	0.10	0.09	0.10
SO ₃	0.29	0.26	0.24	0.34
UND	43.00	42.94	43.37	42.26

Table 19. Results of analyses of limestone slurry solids samples – Unit 2

Sample I.D.	LS U2T1	LS U2T2	LS U2T3	LS U2T4
Test No.	1	2	3	4
Sample Date	01/24/2005	01/25/2005	01/25/2005	01/26/2005
Sampling Time				
Analytical No.	20050703	20050704	20050705	20050706
% Solids in original sample	14.0	17.2	15.4	13.5
Density of original sample (g/mL)				1.055
Residual moisture, as det'd (%)	0.40	0.49	0.52	0.37
Ash (% , dry)	56.84	56.95	56.93	57.02
Total carbon (% , dry)	11.69	11.27	11.62	11.65
Chlorine (% , dry)	0.07	0.11	0.08	0.08
Hg (ppm, as det'd)	0.063	0.068	0.060	0.048
Major Ash Elements (% , as det'd)				
SiO ₂	1.49	1.67	1.62	1.70
Al ₂ O ₃	0.09	0.11	0.12	0.08
TiO ₂	0.00	0.00	0.01	0.00
Fe ₂ O ₃	0.11	0.11	0.13	0.09
CaO	54.88	55.01	55.15	55.01
MgO	0.78	0.91	0.95	0.70
Na ₂ O	0.04	0.05	0.04	0.03
K ₂ O	0.02	0.01	0.00	0.02
P ₂ O ₅	0.06	0.09	0.08	0.07
SO ₃	0.20	0.25	0.25	0.21
UND	42.23	41.79	41.65	42.09

Table 20. Results of analyses of limestone slurry filtrate samples – Unit 1

Sample ID	LS U1T1	LS U1T2	LS U1T3	LS U1T4
Test No.	1	2	3	4
Sample Date	01/19/2005	01/20/2005	01/20/2005	01/21/2005
Analytical No.	20050784	20050785	20050786	20050787
Hardness (ppm), calc'd	2,445	1,657	1,259	1,716
Al (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25
Ca (µg/mL)	462	441	334	395
Total Iron (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25
Mg (µg/mL)	313	135	103	177
Mn (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25
K (µg/mL)	90.4	73.5	54.1	71.0
P (µg/mL)	1.74	2.00	2.04	2.34
Si (µg/mL)	1.72	1.51	< 1.25	< 1.25
Na (µg/mL)	629	466	382	479
Cr (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25
Ammonia as NH ₃ (µg/mL)	< 10	< 10	< 10	< 10
NO ₃ as N (µg/mL)	0.11	< 0.02	< 0.02	0.07
Cl (µg/mL)	2,150	1,475	1,225	1,575
SO ₄ (µg/mL)	787	594	460	608
Hg (µg/L)	< 1.0	< 1.0	< 1.0	< 1.0

Table 21. Results of analyses of limestone slurry filtrate samples – Unit 2

Sample ID	LS U2T1	LS U2T2	LS U2T3	LS U2T4
Test No.	1	2	3	4
Test Date	01/24/2005	01/25/2005	01/25/2005	01/26/2005
Analytical No.	20050788	20050789	20050790	20050791
Hardness (ppm), calc'd	3,692	3,668	3,515	3,969
Al (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25
Ca (µg/mL)	652	659	611	698
Total Iron (µg/mL)	2.30	< 1.25	< 1.25	< 1.25
Mg (µg/mL)	500	490	483	540
Mn (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25
K (µg/mL)	117.80	118.30	114.30	128.96
P (µg/mL)	1.39	2.08	3.51	2.47
Si (µg/mL)	4.87	3.73	3.48	5.53
Na (µg/mL)	844	836	824	914
Cr (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25
Ammonia as NH ₃ (µg/mL)	< 10	< 10	< 10	<10
NO ₃ as N (µg/mL)	3.32	< 0.02	0.07	4.17
Cl (µg/mL)	3,100	2,975	3,000	3,350
SO ₄ (µg/mL)	1,085	1,109	1,104	1,202
Hg (µg/L)	< 1.0	1.3	< 1.0	< 1.0

D. ESP hopper ash

CONSOL personnel collected ESP ash samples, with assistance from the plant boiler operator. There is one ESP for each unit. Each ESP is divided into six fields and there are four ash hoppers in each field. One set of six field hoppers is shown in Figure 9. About 10 lb of ash was collected using an ash sampling bucket which was lowered into the fly ash silo immediately after a row of field hoppers was “dumped” to the silo. The procedure for sampling during a test is as follows. The plant operators dumped the hoppers prior to the start of a test. About 30 minutes after the start of a test, the operators would dump the first field hoppers to the silo and a sample would be collected (sample “F1”). After the sample was collected, the operators would dump the second field, and a sample was again collected (sample “F2”). This procedure was repeated for each field until samples from all six fields were collected. At the end of the test day, each sample was double-bagged in one-gallon plastic bags and labeled. Listed in Tables 22-25 are the results of analyses of the ESP ash samples collected during the

tests on Unit 1. ESP ash from only three of the six fields were sampled during Test 2 (Table 23) due to time limitations prior to the start of Test 3; for all other tests, ESP ash from all six fields were sampled. The mercury measured in the samples ranged from 0.098 to 0.217 ppm. Listed in Tables 26-29 are the results of analyses of the ESP ash samples collected during the tests on Unit 2. The mercury measured in the samples ranged from 0.179 to 0.271 ppm.

In tests conducted at other plants, CONSOL R&D has observed that the mercury content in the ESP ash samples tend to correlate with the carbon content in the samples. In Unit 1, the carbon content and the mercury content were correlated, with an R^2 of 0.76 for the linear regression line between ESP ash carbon concentration and mercury concentration, as shown in Figure 10. In the tests on Unit 2, however, the correlation was not very strong. Figure 11 shows an R^2 of only 0.22 for the linear regression line between ESP ash carbon concentration and mercury concentration.

Table 22. Results of analyses of ESP hopper ash samples – Unit 1, Test 1

Sample I.D.	ESP Ash U1T1F1	ESP Ash U1T1F2	ESP Ash U1T1F3	ESP Ash U1T1F4	ESP Ash U1T1F5	ESP Ash U1T1F6
Electric Field No.	1	2	3	4	5	6
Test No.	1					
Test Date	01/19/2005					
Sampling Time	11:30- 11:45	12:00- 12:10	12:20- 12:45	13:30- 14:00	14:25- 14:30	14:05- 14:15
Analytical No.	20050723	20050724	20050725	20050726	20050727	20050728
Residual Moisture (%)	0.21	0.23	0.24	0.25	0.19	0.22
Ash (% dry)	94.32	94.90	94.73	95.38	95.36	95.38
Carbon (% dry)	4.98	4.36	4.71	4.09	4.04	4.17
Total S (% dry)	0.19	0.20	0.17	0.20	0.18	0.19
Chlorine (% dry)	0.002	0.002	0.002	0.003	0.003	0.003
Hg (ppm, as det'd)	0.204	0.210	0.217	0.186	0.185	0.188
Major Ash Elements (% dry)						
SiO ₂	48.79	48.94	50.95	49.97	49.83	50.50
Al ₂ O ₃	26.85	26.79	26.86	26.94	26.53	26.80
TiO ₂	1.40	1.42	1.49	1.46	1.44	1.46
Fe ₂ O ₃	11.56	11.43	9.87	11.05	11.03	11.21
CaO	1.57	1.61	1.68	1.66	1.63	1.64
MgO	0.95	0.95	0.95	0.97	0.95	0.96
Na ₂ O	0.51	0.52	0.49	0.53	0.51	0.52
K ₂ O	2.38	2.37	2.31	2.37	2.33	2.34
P ₂ O ₅	0.23	0.24	0.36	0.29	0.26	0.25
SO ₃	0.48	0.51	0.43	0.50	0.46	0.48
UND	5.28	5.22	4.61	4.26	5.03	3.84

Table 23. Results of analyses of ESP hopper ash samples – Unit 1, Test 2

Sample I.D.	ESP Ash U1T2F1	ESP Ash U1T2F2	ESP Ash U1T2F3
Electric Field No.	1	2	3
Test No.	2		
Test Date	01/20/2005		
Sampling Time	09:40-09:45	10:00-10:05	10:20-10:25
Analytical No.	20050729	20050730	20050731
Residual Moisture (%)	0.19	0.13	0.18
Ash (% dry)	95.96	95.79	95.82
Carbon (% dry)	3.66	3.82	3.74
Total S (% dry)	0.19	0.18	0.19
Chlorine (% dry)	0.002	0.003	0.003
Hg (ppm, as det'd)	0.162	0.166	0.098
Major Ash Elements (% dry)			
SiO ₂	49.82	49.23	50.03
Al ₂ O ₃	26.35	25.79	26.61
TiO ₂	1.43	1.42	1.45
Fe ₂ O ₃	12.23	12.02	12.04
CaO	1.59	1.52	1.60
MgO	0.94	0.90	0.94
Na ₂ O	0.51	0.50	0.52
K ₂ O	2.25	2.22	2.31
P ₂ O ₅	0.23	0.21	0.20
SO ₃	0.46	0.46	0.47
UND	4.19	5.73	3.83

Table 24. Results of analyses of ESP hopper ash samples – Unit 1, Test 3

Sample I.D.	ESP Ash U1T3F1	ESP Ash U1T3F2	ESP Ash U1T3F3	ESP Ash U1T3F4	ESP Ash U1T3F5	ESP Ash U1T3F6
Electric Field No.	1	2	3	4	5	6
Test No.	3					
Test Date	01/20/2005					
Sampling Time	14:00-14:05	14:20-14:25	14:40-14:45	14:55-15:00	15:15-15:20	15:30-15:35
Analytical No.	20050732	20050733	20050734	20050735	20050736	20050737
Residual Moisture (%)	0.16	0.09	0.12	0.07	0.07	0.12
Ash (% dry)	96.22	96.17	96.12	96.14	96.05	95.93
Carbon (% dry)	3.27	3.30	3.47	3.33	3.48	3.61
Total S (% dry)	0.17	0.16	0.16	0.17	0.17	0.18
Chlorine (% dry)	0.002	0.003	0.003	0.002	0.003	0.003
Hg (ppm, as det'd)	0.143	0.151	0.156	0.147	0.160	0.157
Major Ash Elements (% dry)						
SiO ₂	50.79	50.15	49.86	49.83	49.67	49.46
Al ₂ O ₃	26.42	26.16	26.06	26.00	25.92	25.85
TiO ₂	1.47	1.45	1.45	1.46	1.45	1.46
Fe ₂ O ₃	11.53	11.77	11.76	11.70	11.70	11.72
CaO	1.66	1.62	1.61	1.61	1.61	1.62
MgO	0.96	0.94	0.94	0.94	0.93	0.93
Na ₂ O	0.52	0.50	0.49	0.49	0.49	0.48
K ₂ O	2.30	2.25	2.26	2.25	2.25	2.21
P ₂ O ₅	0.24	0.23	0.25	0.23	0.22	0.22
SO ₃	0.43	0.41	0.41	0.42	0.43	0.45
UND	3.68	4.52	4.91	5.07	5.33	5.60

Table 25. Results of analyses of ESP hopper ash samples – Unit 1, Test 4

Sample I.D.	ESP Ash U1T4F1	ESP Ash U1T4F2	ESP Ash U1T4F3	ESP Ash U1T4F4	ESP Ash U1T4F5	ESP Ash U1T4F6
Electric Field No.	1	2	3	4	5	6
Test No.	4					
Test Date	01/21/2005					
Sampling Time	09:20-09:25	09:40-09:45	10:00-10:05	10:20-10:25	10:40-10:45	11:00-11:05
Analytical No.	20050738	20050739	20050740	20050741	20050742	20050743
Residual Moisture (%)	0.11	0.11	0.14	0.05	0.05	0.13
Ash (% , dry)	96.43	96.47	96.62	96.45	96.49	96.54
Carbon (% , dry)	3.14	3.04	2.99	2.98	3.13	2.97
Total S (% , dry)	0.18	0.18	0.18	0.18	0.16	0.18
Chlorine (% , dry)	0.003	0.003	0.004	0.004	0.003	0.003
Hg (ppm, as det'd)	0.115	0.120	0.118	0.119	0.116	0.118
Major Ash Elements (% , dry)						
SiO ₂	52.31	52.00	51.53	52.02	51.64	51.70
Al ₂ O ₃	25.63	25.38	25.39	25.71	25.21	25.68
TiO ₂	1.44	1.45	1.45	1.46	1.45	1.47
Fe ₂ O ₃	10.16	10.56	10.27	10.40	10.55	10.38
CaO	1.50	1.54	1.53	1.53	1.54	1.57
MgO	0.97	0.97	0.96	0.98	0.97	0.97
Na ₂ O	0.55	0.53	0.53	0.54	0.52	0.53
K ₂ O	2.41	2.35	2.36	2.39	2.32	2.38
P ₂ O ₅	0.15	0.15	0.17	0.18	0.16	0.19
SO ₃	0.44	0.44	0.44	0.45	0.39	0.46
UND	4.44	4.63	5.37	4.34	5.25	4.67

Table 26. Results of analyses of ESP hopper ash samples – Unit 2, Test 1

Sample I.D.	ESP Ash U2T1F1	ESP Ash U2T1F2	ESP Ash U2T1F3	ESP Ash U2T1F4	ESP Ash U2T1F5	ESP Ash U2T1F6
Electric Field No.	1	2	3	4	5	6
Test No.	1					
Test Date	01/24/2005					
Sampling Time	13:54	14:00	14:16	14:26	14:36	14:50
Analytical No.	20050744	20050745	20050746	20050747	20050748	20050749
Residual Moisture (%)	0.17	0.17	0.21	0.15	0.15	0.04
Ash (% , dry)	93.03	93.15	93.06	93.06	93.15	93.03
Carbon (% , dry)	6.01	5.99	6.21	6.08	6.25	6.18
Total S (% , dry)	0.24	0.24	0.24	0.26	0.26	0.25
Chlorine (% , dry)	0.003	0.003	0.004	0.004	0.003	0.004
Hg (ppm, as det'd)	0.247	0.239	0.246	0.179	0.240	0.230
Major Ash Elements (% , dry)						
SiO ₂	49.86	49.30	49.63	49.65	49.92	49.65
Al ₂ O ₃	24.01	23.89	23.91	24.08	24.55	24.47
TiO ₂	1.40	1.39	1.39	1.32	1.33	1.33
Fe ₂ O ₃	10.71	10.69	10.77	10.46	10.73	10.75
CaO	1.51	1.52	1.51	1.50	1.51	1.50
MgO	0.95	0.94	0.95	0.94	0.95	0.94
Na ₂ O	0.49	0.49	0.50	0.53	0.53	0.52
K ₂ O	2.25	2.25	2.28	2.29	2.32	2.29
P ₂ O ₅	0.21	0.21	0.19	0.21	0.21	0.20
SO ₃	0.61	0.59	0.61	0.66	0.65	0.62
UND	8.00	8.73	8.26	8.36	7.30	7.73

Table 27. Results of analyses of ESP hopper ash samples – Unit 2, Test 2

Sample I.D.	ESP Ash U2T1F1	ESP Ash U2T1F2	ESP Ash U2T1F3	ESP Ash U2T1F4	ESP Ash U2T1F5	ESP Ash U2T1F6
Electric Field No.	1	2	3	4	5	6
Test No.	2					
Test Date	01/25/2005					
Sampling Time	10:23	10:44	10:59	11:12	11:23	11:37
Analytical No.	20050750	20050751	20050752	20050753	20050754	20050755
Residual Moisture (%)	0.09	0.09	0.09	0.09	0.05	0.17
Ash (% dry)	92.84	92.81	92.82	92.86	92.86	92.86
Carbon (% dry)	6.40	6.36	6.31	6.12	6.24	6.49
Total S (% dry)	0.26	0.27	0.28	0.26	0.25	0.25
Chlorine (% dry)	0.002	0.002	0.002	0.004	0.002	0.002
Hg (ppm, as det'd)	0.246	0.268	0.268	0.262	0.251	0.245
Major Ash Elements (% dry)						
SiO ₂	46.66	48.96	48.76	48.64	48.43	48.92
Al ₂ O ₃	23.67	24.50	24.42	24.33	24.23	24.30
TiO ₂	1.28	1.34	1.34	1.33	1.33	1.34
Fe ₂ O ₃	10.88	11.68	11.48	11.41	11.55	11.51
CaO	1.42	1.49	1.49	1.49	1.49	1.49
MgO	0.94	0.96	0.96	0.96	0.96	0.95
Na ₂ O	0.49	0.51	0.51	0.50	0.49	0.50
K ₂ O	2.24	2.30	2.31	2.29	2.29	2.30
P ₂ O ₅	0.23	0.24	0.23	0.23	0.23	0.22
SO ₃	0.64	0.67	0.69	0.64	0.63	0.63
UND	11.55	7.35	7.81	8.18	8.37	7.84

Table 28. Results of analyses of ESP hopper ash samples – Unit 2, Test 3

Sample I.D.	ESP Ash U2T3F1	ESP Ash U2T3F2	ESP Ash U2T3F3	ESP Ash U2T3F4	ESP Ash U2T3F5	ESP Ash U2T3F6
Electric Field No.	1	2	3	4	5	6
Test No.	3					
Test Date	01/25/2005					
Sampling Time	14:35	14:49	14:59	15:10	15:24	15:35
Analytical No.	20050756	20050757	20050758	20050759	20050760	20050761
Residual Moisture (%)	0.15	0.11	0.15	0.13	0.11	0.11
Ash (% dry)	92.67	92.68	92.66	92.68	92.61	92.67
Carbon (% dry)	6.49	6.44	6.43	6.50	6.49	6.47
Total S (% dry)	0.26	0.26	0.26	0.26	0.25	0.26
Chlorine (% dry)	0.003	0.002	0.002	0.003	0.003	0.003
Hg (ppm, as det'd)	0.257	0.258	0.249	0.263	0.271	0.266
Major Ash Elements (% dry)						
SiO ₂	48.95	48.89	49.39	49.25	48.72	48.88
Al ₂ O ₃	24.42	24.30	24.89	24.64	24.36	24.50
TiO ₂	1.34	1.33	1.36	1.35	1.34	1.34
Fe ₂ O ₃	11.33	11.45	11.17	11.33	11.37	11.40
CaO	1.49	1.49	1.50	1.47	1.46	1.47
MgO	0.95	0.96	0.97	0.95	0.95	0.96
Na ₂ O	0.50	0.49	0.51	0.51	0.49	0.51
K ₂ O	2.29	2.28	2.35	2.31	2.31	2.34
P ₂ O ₅	0.24	0.24	0.25	0.24	0.24	0.24
SO ₃	0.64	0.66	0.65	0.66	0.62	0.64
UND	7.85	7.91	6.96	7.29	8.14	7.72

Table 29. Results of analyses of ESP hopper ash samples – Unit 2, Test 4

Sample I.D.	ESP Ash U2T4F1	ESP Ash U2T4F2	ESP Ash U2T4F3	ESP Ash U2T4F4	ESP Ash U2T4F5	ESP Ash U2T4F6
Electric Field No.	1	2	3	4	5	6
Test No.	4					
Test Date	01/26/2005					
Sampling Time	10:15	10:02	10:27	10:37	10:47	10:58
Analytical No.	20050762	20050763	20050764	20050765	20050766	20050767
Residual Moisture (%)	0.09	0.12	0.15	0.09	0.22	0.18
Ash (% dry)	92.95	92.96	92.96	92.98	93.02	93.02
Carbon (% dry)	6.09	6.10	6.03	5.97	5.90	6.03
Total S (% dry)	0.25	0.25	0.25	0.24	0.25	0.25
Chlorine (% dry)	0.003	0.002	0.003	0.003	0.003	0.003
Hg (ppm, as det'd)	0.253	0.248	0.245	0.238	0.246	0.240
Major Ash Elements (% dry)						
SiO ₂	49.21	48.58	50.16	49.57	49.82	50.09
Al ₂ O ₃	25.14	25.52	25.45	25.16	25.61	25.63
TiO ₂	1.40	1.40	1.41	1.38	1.41	1.41
Fe ₂ O ₃	10.38	10.45	10.43	10.30	10.25	10.41
CaO	1.48	1.46	1.48	1.46	1.47	1.46
MgO	0.92	0.93	0.93	0.92	0.93	0.94
Na ₂ O	0.49	0.52	0.52	0.53	0.53	0.53
K ₂ O	2.28	2.38	2.33	2.35	2.39	2.38
P ₂ O ₅	0.29	0.31	0.29	0.30	0.30	0.30
SO ₃	0.62	0.63	0.63	0.61	0.62	0.62
UND	7.79	6.82	6.37	7.42	6.66	6.23

E. FGD slurry

Each unit has two scrubber modules in operation at all times. On Unit 1, modules A and B were in use; on Unit 2, modules A and C were in use. The scrubber blowdown from each module was sampled once during each test by CONSOL personnel.

Upon arrival at CONSOL R&D's analytical lab, each slurry sample was filtered to generate a filtrate and a solid residue (i.e., filter cake) samples. The air-dried solids and the filtrates were analyzed separately. Listed in Tables 30 and 31 are the results of analyses of the FGD slurry solids samples. Listed in Tables 32 and 33 are the results of analyses of the limestone slurry filtrate samples.

Table 30. Results of analyses of FGD slurry solids samples – Unit 1 tests

Sample I.D.	U1T1 FGDS-1A	U1T1 FGDS-1B	U1T2 FGDS-1A	U1T2 FGDS-1B	U1T3 FGDS-1A	U1T3 FGDS-1B	U1T4 FGDS-1A	U1T4 FGDS-1B
FGD Module	A	B	A	B	A	B	A	B
Test No.	1		2		3		4	
Sample Date	01/19/2005	01/19/2005	01/20/2005	01/20/2005	01/20/2005	01/20/2005	01/21/2005	01/21/2005
Sample Time	13:05	13:05	11:00	11:05	15:45	15:50	11:20	11:25
Analytical No.	20050707	20050708	20050709	20050710	20050711	20050712	20050713	20050714
% Solids in original sample	13.0	11.1	12.9	7.4	12.8	7.0	13.1	6.9
Density of original sample (g/mL)	1.115	1.098	1.113	1.070	1.117	1.070	1.120	1.074
Residual moisture, as det'd (%)	4.47	4.12	4.03	5.32	4.03	5.46	4.06	5.83
Ash (% dry)	99.92	90.24	103.14	91.54	99.81	92.24	99.3	93.02
Total carbon (% dry)	0.62	2.85	0.84	2.39	0.68	2.31	0.78	2.06
Chlorine (% dry)	0.60	0.35	0.63	0.36	0.61	0.40	0.56	0.48
Hg (ppm, as det'd)	0.827	0.609	0.871	0.712	0.908	0.744	0.888	0.744
Major Ash Elements (% as det'd)								
SiO ₂	0.74	0.79	0.87	0.73	0.77	0.74	0.86	0.77
Al ₂ O ₃	0.11	0.08	0.14	0.08	0.12	0.10	0.14	0.10
TiO ₂	0	0.01	0.01	0	0.01	0.01	0.01	0.01
Fe ₂ O ₃	0.10	0.11	0.13	0.11	0.12	0.12	0.13	0.12
CaO	41.53	43.80	42.15	43.20	40.64	41.98	41.77	41.64
MgO	0.34	0.33	0.36	0.31	0.40	0.34	0.33	0.31
Na ₂ O	0.24	0.16	0.25	0.16	0.30	0.20	0.23	0.19
K ₂ O	0.06	0.04	0.06	0.03	0.07	0.05	0.06	0.06
P ₂ O ₅	0.03	0.04	0.02	0.04	0.03	0.05	0.05	0.04
SO ₃	50.18	41.13	49.68	41.41	49.37	41.79	49.64	43.23

Table 31. Results of analyses of FGD slurry solids samples – Unit 2 tests

Sample I.D.	U2T1 FGDS-2A	U2T1 FGDS-2C	U2T2 FGDS-2A	U2T2 FGDS-2C	U2T3 FGDS-2A	U2T3 FGDS-2C	U2T4 FGDS-2A	U2T4 FGDS-2C
FGD Module	A	C	A	C	A	C	A	C
Test No.	1		2		3		4	
Test Date	01/24/2005		01/25/2005		01/25/2005		01/26/2005	
Sampling Time	12:53	12:58	10:11	10:16	14:02	14:07	09:38	9:40
Analytical No.	20050715	20050716	20050717	20050718	20050719	20050720	20050721	20050722
% Solids of original sample	9.5	10.9	10.1	11.0	9.6	10.5	8.4	9.4
Density of original sample (g/mL)	1.077	1.098	1.088	1.084	1.093	1.084		1.090
Residual moisture (%)	4.52	6.12	4.60	3.42	2.51	2.69	2.95	3.25
Ash (% dry)	96.99	99.90	95.23	97.80	94.29	97.56	97.50	97.70
Carbon (% dry)	1.32	0.62	1.83	0.63	1.69	0.66	0.79	0.59
Chlorine (% dry)	0.54	0.62	0.48	0.63	0.62	0.59	0.64	0.64
Hg (ppm, as det'd)	0.607	0.562	0.592	0.562	0.639	0.575	0.592	0.616
Major Ash Elements (% as det'd)								
SiO ₂	0.99	1.27	1.27	1.15	1.24	1.18	1.19	1.18
Al ₂ O ₃	0.06	0.12	0.07	0.06	0.06	0.07	0.07	0.05
TiO ₂	0	0.01	0	0	0	0	0	0
Fe ₂ O ₃	0.05	0.08	0.07	0.05	0.06	0.07	0.06	0.05
CaO	41.87	40.12	43.37	40.81	42.21	41.34	40.71	40.23
MgO	0.29	0.33	0.40	0.29	0.31	0.33	0.31	0.33
Na ₂ O	0.22	0.30	0.29	0.24	0.22	0.26	0.26	0.28
K ₂ O	0.04	0.07	0.05	0.04	0.03	0.03	0.05	0.04
P ₂ O ₅	0.02	0	0.03	0.01	0	0.01	0.01	0.01
SO ₃	46.67	50.62	45.43	51.29	46.15	51.73	49.97	51.01

Table 32. Results of analyses of FGD slurry filtrate samples – Unit 1 tests

Sample ID	U1T1 FGDS-1A	U1T1 FGDS-1B	U1T2 FGDS-1A	U1T2 FGDS-1B	U1T3 FGDS-1A	U1T3 FGDS-1B	U1T4 FGDS-1A	U1T4 FGDS-1B
FGD Module	1A	1B	1A	1B	1A	1B	1A	1B
Test No.	1		2		3		4	
Sample Date	01/19/2005	01/19/2005	01/20/2005	01/20/2005	01/20/2005	01/20/2005	01/21/2005	01/21/2005
Sample Time	13:05	13:05	11:00	11:05	15:45	15:50	11:20	11:25
Analytical No.	20050792	20050793	20050794	20050795	20050796	20050797	20050798	20050799
Hardness (ppm), calc'd	28,422	19,861	25,108	20,044	26,800	18,612	24,696	18,202
Al (µg/mL)	< 1.25	13.9	< 1.25	15.6	< 1.25	14.2	< 1.25	14.3
Ca (µg/mL)	3,910	2,981	3,447	3,044	3,673	2,834	3,390	2,768
Total Iron (µg/mL)	1.42	3.99	< 1.25	4.53	2.29	4.17	2.14	3.63
Mg (µg/mL)	4,526	3,012	4,003	3,018	4,279	2,798	3,937	2,738
Mn (µg/mL)	6.36	6.58	5.87	6.63	6.42	6.17	6.03	6.47
K (µg/mL)	754	506	659	505	698	472	640	454
P (µg/mL)	103.3	52.9	49.4	11.7	55.8	11.0	32.1	22.3
Si (µg/mL)	27.2	50.4	25.0	56.4	27.3	53.8	23.6	52.0
Na (µg/mL)	5,021	3,336	4,384	3,380	4,635	3,175	4,259	3,038
Cr (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25
Ammonia as NH ₃ (µg/mL)	< 10	< 10	< 10	10	10	< 10	< 10	10
NO ₃ as N (µg/mL)	44.0	99.5	13.8	97.5	11.2	84.2	4.26	82.5
Cl (µg/mL)	32,500	24,000	34,500	21,500	33,500	22,500	33,500	20,500
SO ₄ (µg/mL)	4,060	3,937	3,618	4,479	3,795	4,231	3,474	3,615
Hg (µg/L)	4.0	4.5	4.8	5.7	2.7	3.6	4.0	4.2

Table 33. Results of analyses of FGD slurry filtrate samples – Unit 2 tests

Sample ID	U2T1 FGDS-2A	U2T1 FGDS-2C	U2T2 FGDS-2A	U2T2 FGDS-2C	U2T3 FGDS-2A	U2T3 FGDS-2C	U2T4 FGDS-2A	U2T4 FGDS-2C
FGD Module	2A	2C	2A	2C	2A	2C	2A	2C
Test No.	1		2		3		4	
Test Date	01/24/2005		01/25/2005		01/25/2005		01/26/2005	
Sampling Time	12:53	12:58	10:11	10:16	14:02	14:07	09:38	9:40
Analytical No.	20050800	20050801	20050802	20050803	20050804	20050805	20050806	20050807
Hardness (ppm), calc'd	24,046	25,433	21,932	29,657	20,779	27,984	26,578	23,891
Al (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25
Ca (µg/mL)	3,640	3,796	3,313	4,367	3,123	4,145	3,928	3,542
Total Iron (µg/mL)	1.98	< 1.25	1.69	< 1.25	< 1.25	< 1.25	1.61	< 1.25
Mg (µg/mL)	3,628	3,870	3,313	4,548	3,148	4,277	4,067	3,650
Mn (µg/mL)	5.30	5.73	4.64	6.91	4.37	6.42	5.68	5.60
K (µg/mL)	668	707	611	837	587	784	753	682
P (µg/mL)	48.9	51.4	52.6	86.8	58.7	68.4	63.3	63.0
Si (µg/mL)	30.0	29.5	26.3	35.7	24.7	32.3	34.0	29.1
Na (µg/mL)	4,447	4,685	4,098	5,651	4,001	5,252	5,122	4,585
Cr (µg/mL)	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25	< 1.25
Ammonia as NH ₃ (µg/mL)	10	10	< 10	< 10	< 10	10	< 10	10
NO ₃ as N (µg/mL)	44.7	45.8	46.3	44.3	32.8	35.0	44.3	38.0
Cl (µg/mL)	29,500	33,000	27,500	31,000	24,500	30,500	29,000	35,000
SO ₄ (µg/mL)	2,882	2,897	2,673	3,336	2,566	3,150	3,218	2,788
Hg (µg/L)	< 1.0	1.9	1.3	< 1.0	1.3	1.0	1.0	1.3

F. FGD makeup water

FGD makeup water and mist eliminator wash water came from the thickener overflow. CONSOL R&D personnel collected an FGD makeup water sample of about 250 mL during each test. Listed in Tables 34 and 35 are the results of analyses of the makeup water samples. The concentration of mercury detected in these samples was below the detection limit of 1.0 µg/L.

Table 34. Results of analyses of FGD makeup water samples – Unit 1

Sample ID	FGD Makeup-U1T1	FGD Makeup-U1T2	FGD Makeup-U1T3	FGD Makeup-U1T4
Test No.	1	2	3	4
Sample Date	01/19/2005	01/20/2005	01/20/2005	01/21/2005
Sample Time	13:00	11:00	15:40	11:15
Analytical No.	20050808	20050809	20050810	20050811
Hardness (ppm), calc'd	5,091	4,585	4,483	3,781
Al (µg/mL)	0.09	0.11	< 0.05	0.06
Ca (µg/mL)	917	829	811	695
Total Iron (µg/mL)	0.10	0.13	0.07	0.08
Mg (µg/mL)	679	610	596	496
Mn (µg/mL)	0.86	0.73	0.70	0.53
K (µg/mL)	199	170	165	154
P (µg/mL)	3.42	3.76	3.82	3.68
SiO ₂ (µg/mL)	8.01	9.92	9.62	9.05
Na (µg/mL)	1,141	1,070	1,041	1,005
Cr (µg/mL)	< 0.05	< 0.05	< 0.05	< 0.05
Ammonia as NH ₃ (µg/mL)	< 10	< 10	< 10	< 10
NO ₃ as N (µg/mL)	3.2	8.1	9.8	10.1
Cl (µg/mL)	4,500	3,950	3,900	3,250
SO ₄ (µg/mL)	1,853	1,763	1,722	1,650
Hg (µg/L)	< 1.0	< 1.0	< 1.0	< 1.0

Table 35 Results of analyses of FGD makeup water samples – Unit 2

Sample ID	FGD Makeup-U2T1	FGD Makeup-U2T2	FGD Makeup-U2T3	FGD Makeup-U2T4
Test No.	1	2	3	4
Sample Date	01/24/2005	01/25/2005	01/25/2005	01/26/2005
Sample Time	11:45	9:17	13:30	9:00
Analytical No.	20050812	20050813	20050814	20050815
Hardness (ppm), calc'd	17,567	20,040	16,641	13,801
Al (µg/mL)	< 0.53	< 0.53	0.81	< 0.53
Ca (µg/mL)	2,798	3,174	2,694	2,225
Total Iron (µg/mL)	0.64	0.94	0.97	0.77
Mg (µg/mL)	2,566	2,938	2,405	1,999
Mn (µg/mL)	3.55	4.14	3.52	2.93
K (µg/mL)	490	550	453	392
P (µg/mL)	55.1	47.1	35.3	35.9
SiO ₂ (µg/mL)	29.8	33.4	28.1	23.1
Na (µg/mL)	3,260	3,643	3,007	2,649
Cr (µg/mL)	< 0.53	< 0.53	< 0.53	< 0.53
Ammonia as NH ₃ (µg/mL)	< 10	10	10	< 10
NO ₃ as N (µg/mL)	< 0.02	< 0.02	< 0.02	< 0.02
Cl (µg/mL)	19,500	21,000	17,000	15,500
SO ₄ (µg/mL)	3,034	3,292	2,898	2,533
Hg (µg/L)	< 1.0	< 1.0	< 1.0	< 1.0

QUALITY ASSURANCE/QUALITY CONTROL

The sampling and analysis QA/QC procedures are described below.

- Personnel specifically trained and experienced in power plant sampling methods, including the Ontario-Hydro mercury sampling method, conducted all sampling,
- The sampling equipment was maintained and calibrated as required,
- Consistent sample preparation and recovery procedures were used,
- Samples were logged and tracked under the direction of sample team Group Leader,
- Individual calibration curves were developed for each sample matrix,

- NIST Standard Reference Material (SRM) and lab QC samples were analyzed to verify calibration curves,
- Duplicates of selected samples were analyzed to assure repeatability,
- Analyses of selected “spiked” samples were analyzed to assure sample recovery, and
- Interim data were reviewed to assure sample completeness.

All samples were obtained using the procedures described in EPA Method 5 and the Ontario-Hydro mercury speciation draft method. Data were recorded on standard forms, which are included in Appendix A. The field data were reduced using standard “in-house” spreadsheets. Copies of the summary sheets are included in Appendix A. To assure consistency, all of the Ontario-Hydro train components were prepared and recovered under the supervision of a senior technician experienced in the Ontario-Hydro mercury speciation lab techniques. Copies of the recovery sheets are included in Appendix C.

The Ontario-Hydro sampling train analysis consisted of eight sub-samples. Each sub-sample analysis consisted of developing a calibration curve (absorbance versus mercury concentration in solution), checks of field and lab blanks, calibration checks against SRM and lab standards, selected duplicates and selected sample spikes. The laboratory summaries for each of these runs are contained in Appendix C.

A total of 346 individual Ontario-Hydro mercury determinations were completed, including 30 blank samples, 71 NIST SRM or lab QC checks, 35 sample spikes, and 34 duplicate analyses.

I. Blank Samples

A total of 30 blank liquid samples (14 reagent blanks and 4 sets of field impinger blanks) were analyzed. All of the blanks were below the detection limit (<0.2 ng/mL for all samples except KMnO₄ acid rinse, which is <1.0 ng/mL). Consequently, in this report, blank concentrations were not subtracted from any mercury determination.

II. NIST Standard Reference Material Checks

Seventy-one NIST SRM checks were conducted throughout the mercury determinations. Two standards were used in the determinations as detailed in Table 36.

Table 36. NIST SRM analyses

NIST SRM	Standard Value (ng/mL)	Sample Fraction	Samples Analyzed	Average Result (ng/mL)	Percent of Standard	Standard Deviation (ng/mL)	Percent Relative Standard Deviation
1641D	8.0	Ontario Hydro Liquids	57	8.07	100.9	0.24	3.0
		Ontario Hydro Filters	8	8.23	102.8	0.046	0.6
1633b	141.0	Ontario Hydro Filters	6	145	102.6	12.9	8.9

III. Spike Sample Recoveries

A total of 35 samples were spiked with a 2 or 10 µg/L mercury standard and then re-analyzed to determine the percent spike recovery. The result of this QA/QC procedure was an average spike recovery of 91.8% recovery with a ±6.1% standard deviation.

IV. Duplicate Analyses

A total of 34 duplicate analyses were conducted periodically throughout the mercury determinations. The result of this QA/QC procedure was an average mercury determination that was within 6.6% of the original mercury determination, with a ±9.0% standard deviation.

V. Flue Gas Mercury Concentration Detection Limits

For liquid samples, the flue gas mercury concentration was calculated using the following equation:

$$Hg [\mu g / m^3] = \frac{(C_{imp} \times V_{imp})}{(V_{gas} \times 1000)}$$

where: C_{imp} = Mercury concentration of impinger solution [ng/mL (ppb)]
 V_{imp} = Liquid volume of impinger solution [mL]
 V_{gas} = Flue gas sample volume [dry standard m^3]
1000= Conversion factor [1000 ng per µg]

The flue gas mercury detection limit is reduced when the flue gas sample volume is increased or liquid volume of impinger solution is decreased. The CVAA is calibrated between 0 and 20 ng/mL. Over this range, the calibration curve between absorbance and concentration is linear. The lowest concentration standard used to develop the calibration curve is 0.500 ng/mL. In addition, the detection limit of the liquid CVAA

analysis was 0.2 ng/mL for all samples except KMnO₄ acid rinse, which is 1.0 ng/mL. The prescribed sampling and recovery procedures result in final liquid volumes varying between 64 and 698 mL. The volume of flue gas collected varied between 1.083 and 2.228 dscm. The sampling variables result in sample-specific flue gas detection limit. The flue gas mercury detection limit for each sample matrix is listed in Table 37. Depending on the matrix, the flue gas mercury detection limit ranged from 0.1 to 0.6 µg/m³.

Table 37. Flue gas mercury detection limits

Matrix	Maximum Liquid Volume (mL)	Minimum Gas Volume (dscm)	Flue Gas Detection Limit (µg/m ³)
Probe Rinse	227	1.083	0.04
KCl Impinger	698	1.083	0.13
HNO ₃ /H ₂ O ₂ Impingers	183	1.083	0.03
KMnO ₄ Impingers	250	1.083	0.05
HCl Rinse	100	1.083	0.09

VI. Mercury Material Balance Closure

One important criterion to gauge the overall quality of the tests is to conduct a mass balance to account for the mercury entering and leaving the plant during the time of the tests. The total mercury input is the sum of the mass flow rates of mercury entering the unit from coal, limestone slurry, and FGD makeup water. The total mercury output is the sum of the mass flow rates of mercury leaving the unit through the coal mill rejects, boiler bottom ash, ESP hopper ash, FGD slurry, and stack flue gas. Tables 38 and 39 summarize the results of the mercury material balance closure calculations. For the four tests conducted on Unit 1, the calculated mercury material balance closures ranged from 72% to 104% with an average of 84%. For the four tests conducted on Unit 2, the calculated mercury material balance closures ranged from 93% to 109% with an average of 103%. The mercury material balance closures for all individual tests are within the QA/QC criterion of 70-130% for a single test. The average mercury material balance closures of 84% and 103% are within the QA/QC criterion of 80-120% for multiple tests.

Table 38. Summary of material balance closure for mercury, Unit 1.

Test No.	1	2	3	4
Hg input from Coal (mg/sec)	3.84	4.52	4.48	2.78
Hg input limestone slurry (mg/sec)	0.06	0.06	0.05	0.07
Hg input from FGD makeup water (mg/sec)	0.01	0.01	0.01	0.01
Total Hg Input (mg/sec)	3.91	4.60	4.55	2.87
Hg output via Coal Mill Rejects (mg/sec)	0.18	0.18	0.17	0.18
Hg output via Bottom Ash (mg/sec)	0.01	0.01	0.01	0.14
Hg output via ESP Hopper Ash (mg/sec)	0.78	0.43	0.39	0.46
Hg output via FGD Slurry Solids (mg/sec)	1.73	2.00	2.27	1.70
Hg output via FGD Slurry Filtrate *mg/sec)	0.07	0.13	0.08	0.08
Hg output via stack gas (mg/sec)	0.38	0.57	0.69	0.39
Total Hg Output (mg/sec)	3.15	3.31	3.61	2.96
Hg Material Balance Closure (output / input)	81%	72%	79%	104%
Average Hg Material Balance Closure (%)	84 ± 13 %			

Table 39. Summary of material balance closure for mercury, Unit 2.

Test No.	1	2	3	4
Hg input from Coal (mg/sec)	3.23	3.74	3.72	3.91
Hg input limestone slurry (mg/sec)	0.12	0.13	0.10	0.07
Hg input from FGD makeup water (mg/sec)	0.01	0.01	0.01	0.02
Total Hg Input (mg/sec)	3.36	3.89	3.84	4.00
Hg output via Coal Mill Rejects	0.16	0.48	0.54	0.61
Hg output via Bottom Ash (mg/sec)	0.03	0.05	0.05	0.01
Estimated Hg output via ESP Hopper Ash (mg/sec)	0.68	0.73	0.75	0.70
Hg output via FGD Slurry Solids (mg/sec)	2.55	2.52	2.59	2.21
Hg output via FGD Slurry Filtrate *mg/sec)	0.07	0.05	0.04	0.04
Hg output via stack gas (mg/sec)	0.18	0.25	0.12	0.13
Total Hg Output (mg/sec)	3.67	4.08	4.10	3.70
Hg Material Balance Closure (output / input)	109%	105%	107%	93%
Average Hg Material Balance Closure (%)	103 ± 7 %			

HEAT INPUT-BASED MERCURY EMISSION

The heat input based mercury emission rates were calculated by using the Ontario-Hydro data and the heat input to the boiler, and the results are summarized in Table 51. The mercury emissions ranged from 1.70 to 2.27 lb/TBtu with an average emission rate of 1.77 lb/TBtu during the ozone season tests. The mercury emissions ranged from 2.01 to 3.11 lb/TBtu with an average emission rate of 2.34 lb/TBtu during the ozone season tests.

Table 40. Heat input-based mercury emission

Unit 1 Test No.	1	2	3	4
Stack Hg Flow [mg/sec]	0.38	0.57	0.69	0.39
Stack Hg Flow [lb/hr]	3.01×10^{-3}	4.54×10^{-3}	5.44×10^{-3}	3.14×10^{-3}
Heat Input (MM Btu/Hr)	4,490	4,370	4,330	4,350
Stack Hg Emissions (lb/TBtu)	0.67	1.04	1.26	0.72
Average Stack Hg Emissions (lb/TBtu)	0.92			
Unit 2 Test No.	1	2	3	4
Stack Hg Flow [mg/sec]	0.18	0.25	0.12	0.13
Stack Hg Flow [lb/hr]	1.44×10^{-3}	1.99×10^{-3}	9.89×10^{-4}	1.04×10^{-3}
Heat Input (MM Btu/Hr)	4,320	4,440	4,420	4,420
Stack Hg Emissions (lb/TBtu)	0.33	0.45	0.22	0.24
Average Stack Hg Emissions (lb/TBtu)	0.31			

Plant 4, Unit #1 (with no SCR)
Mercury Speciation By Location




Figure 1. Mercury speciation by location, Unit 1 (with no SCR)

Plant 4, Unit #2 (with SCR)
Mercury Speciation By Location




Figure 2. Mercury speciation by location, Unit 2 (with SCR)




Figure 3. Process flow schematic and sampling locations



Figure 4. Economizer outlet probe and sampling train



Figure 5. ESP inlet (air heater outlet) probe and sampling train



Figure 6. FGD inlet probe (in background), sampling train, and meter box



Figure 7. Stack sampling port




Figure 8. Ontario-Hydro sampling train schematic



Figure 9. ESP ash hoppers, showing pipes used for transferring ash to the silo




Figure 10. ESP ash mercury vs. Carbon plot, Unit 1




Figure 11. ESP ash mercury vs. Carbon plot, Unit 2

APPENDIX A

Mercury Sampling Data

- Field Data Sheets
- Mercury Measurement Data Sheets

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID
PLANT
LOCATION
DATE
OPERATOR(S)
AMBIENT TEMP [°F]
BAR. PRESS. [in. Hg]

ECON-1
SCR/FGD Plant 4
Economizer Outlet
1/19/05
GLC/ST
90
29.96

METER BOX	N-1
PITOT TUBE DESC	E-15
PROBE LENGTH [ft]	
NOZZLE ID [inch]	3/16 0.091
%H ₂ O (Assumed)	8
FILTER ID	1
K FACTOR	0.632

CAL. DATA: delta H	1.976
Y	0.987
C(p)	0.838
FILTER BOX SETTING	325
PROBE HTR SETTING	325
DUCT X-SECTION	circ ? rect ? other:
DUCT DIMENSIONS	2@25"x14.5"

Comments: * DISCOVERED SLIGHT KINK IN ONE PITOT TUBE @ ~1145. AP'S @ 1130 + 1140 MAY BE LOW. * SUSPECT SPOT BLEWING @ ~1210-1230 O₂ READINGS @ 4-4.5%

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in. H ₂ O]	PITOT HEAD [in. H ₂ O]	METER DIFF PRESSURE [in. H ₂ O]	METER VACUUM [in. Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								⑥ inlet	⑦ outlet					O ₂ [% vol]	CO ₂ [% vol]	
	1100	0					509.00									
		10		0.90	0.57	4.0	513.14	90	88	693	324		64	2.8	17.3	
SOUTH DUCT		20		0.72	0.45	4.0	516.89	93	89	698	330		63	2.7	17.2	
		30		0.66	0.42	4.0	520.50	96	91	697	330		63	2.7	17.2	
1-PORT POINT		40	-4.26	0.55	0.35	4.0	523.84	98	92	697	332		65	2.6	17.3	
		50		0.80	0.50	5.0	527.63	99	94	699	318		62	2.7	17.2	
		60		0.78	0.48	6.0	531.64	101	95	694	324		60	2.7	17.2	
				POST LEAK @ SOUTH DUCT - 0 @ 10" Hg												
				PRE LEAK @ NORTH DUCT - 0 @ 10" Hg												
RESET	1215						532.10									
		70		1.00	0.63	5.0	536.45	104	99	711	329		63	4.0	15.9	
		80		1.00	0.63	5.5	540.81	106	100	710	320		60	3.0	16.9	
NORTH DUCT		90	-4.81	1.05	0.66	6.0	545.27	106	101	707	320		60	4.0	16.0	
		100		1.05	0.66	7.0	549.73	107	101	706	331		60	3.7	16.3	
1-PORT POINT		110	-4.55	1.00	0.63	7.5	554.22	107	102	707	332		61	4.1	15.9	
		120		1.00	0.63	8.0	558.60	108	102	708	332		61	4.0	16.0	
AVERAGE			-4.54	0.868	0.551		49.14	98.7		702.83				3.3	16.7	

Sample Train Pre Test 0.010 ft³ @ 10.0 in. Hg
Leak Checks: Post Test 0 ft³ @ 10 in. Hg

Pitot Tube Pre Test 0 @ 5 in. H₂O
Leak Checks: Post Test 0 @ 5 in. H₂O

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

Ull

TEST ID	AHO-1
PLANT	SCR/FGD Plant 4
LOCATION	Air Heater Outlet/ESP Inlet
DATE	1-19-05
OPERATOR(S)	JL, PL, DO
AMBIENT TEMP [°F]	70
BAR. PRESS. [in Hg]	29.96

METER BOX	N-5
PITOT TUBE DESC	E-3
PROBE LENGTH [ft]	12
NOZZLE ID [inch]	9/16 B 0.188
%H ₂ O (Assumed)	8
FILTER ID	9
K FACTOR	0.93

CAL. DATA: delta H	2.015
Y	1.01
C(p)	0.846
FILTER BOX SETTING	325
PROBE HTR SETTING	325
DUCT X-SECTION	circ ? rect ? other: _____
DUCT DIMENSIONS	DUCT AREA _____

Comments: _____

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³ / 15]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	11:00	0					833.746									
A-1	11:10	10	-3.95	0.45	0.42	2.0	837.11	72	67	295	289	NA	65	5.2	14.9	
A-1	11:20	20		0.45	0.42	2.0	840.49	70	74	296	291		63	4.7	15.3	
A-1	11:30	30		0.42	0.39	2.0	843.735	74	76	296	292		66	4.6	15.5	
						Leak check 0.005 @ 6" Hg										
	11:33:30	30					843.908									
B-1	11:43	40		0.50	0.46	2.5	847.47	75	73	273	297		47	4.8	15.4	
B-1	11:53	50		0.54	0.50	3.00	851.21	78	79	291	301		45	4.3	15.9	
B-1	12:03	60		0.54	0.50	3.00	854.94	80	81	291	300		44	4.5	15.7	
						Leak check 0.000 @ 6.0										
	12:17	70					855.03									
C-1	12:27	80	-8.9	0.59	0.54	3.0	858.89	82	81	261	292		43			
C-1	12:37	90		0.65	0.60	3.0	862.94	85	83	270	304		46	4.4	15.6	
C-1	12:47	100		0.60	0.55	3.0	866.76	87	84	270	302		44	4.6	15.5	
						ck ck 0.000 @ 6" Hg										
	12:55	100					866.90									
D-1	13:05	100		0.45	0.42	2.5	870.29	87	84	235	282		55	5.6	14.4	
D-1	13:15	110		0.48	0.44	2.5	873.88	89	87	252	281		50	5.9	14.2	
D-1	13:25	120	-9.3	0.44	0.41	2.5	877.12	89	84	254	288		49	5.2	14.9	
				Rus												
AVERAGE			-9.0	0.507	0.471		42.96	80.3		273.7				4.9	15.2	

Sample Train Pre Test 0.005 ft³ @ 11.0 in. Hg
 Leak Checks: Post Test 0.000 ft³ @ 5.0 in. Hg

Pitot Tube Pre Test OK @ 8 in. H₂O
 Leak Checks: Post Test OK @ 7 in. H₂O



NOTE: Purge for 10 minutes at end of sampling.

Ull

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	STK - 1
PLANT	SCR/FGD Plant 4
LOCATION	Stack
DATE	1-19-05
OPERATOR(S)	K.C., B.S.
AMBIENT TEMP [°F]	68°
BAR. PRESS. [in Hg]	29.96

METER BOX	N-3
PITOT TUBE DESC	E-11
PROBE LENGTH [ft]	10
NOZZLE ID [inch]	7/32" 0.214
%H ₂ O (Assumed)	13.5
FILTER ID	# 2
K FACTOR	1.47

CAL. DATA: delta H	1.982	Comments: _____
Y	1.026	
C(p)	0.806	
FILTER BOX SETTING	325	
PROBE HTR SETTING	250	
DUCT X-SECTION	circ ?	rect ? other: _____
DUCT DIMENSIONS	19 ft ID	DUCT AREA 283.53 ft ²

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	1100	0					464.60									
	-10.00	10		.74	1.23	3.5	470.54	75	74	129	251	305	55	6.3	13.8	
A	-33.33	20	-.4452	1.00	1.65	4	477.13	81	75	129	261	327	49	6.2	13.9	
	-67.50	30		1.10	1.82	5	484.04	86	77	129	261	335	51	5.8	14.3	
				L.C. RESTART			484.16									
	-10.00	40		.70	1.15	3.5	489.76	83	77	127	247	307	49	6.3	13.8	
B	-33.33	50	-.4996	1.00	1.65	4	496.33	85	77	127	253	322	46	5.8	14.3	
	-67.50	60		1.10	1.82	5	503.24	86	78	126	255	333	47	6.0	14.1	
				L.C. RESTART			503.36									
	-10.00	70		.66	1.10	3.5	508.85	84	78	125	256	329	50	6.3	13.8	
C	-33.33	80	-.3980	1.05	1.75	5	515.66	87	80	126	248	329	49	6.0	14.1	
	-67.50	90		1.10	1.82	5	522.62	90	81	126	252	330	52	6.3	13.8	
				L.C. RESTART			522.74									
	-10.00	100		.78	1.30	4	528.66	87	81	126	255	329	54	6.3	13.8	
D	-33.33	110	-.4651	1.10	1.82	5	535.60	89	82	126	253	328	52	6.3	13.8	
	-67.50	120		1.10	1.82	5	542.58	91	84	126	256	330	54	6.2	13.9	
		1320														
AVERAGE			-0.45	0.944	1.57		77.62	88.2		126.8				6.2	14.0	

Sample Train Pre Test OK ft³ @ 10 in. Hg
 Leak Checks: Post Test OK ft³ @ 10 in. Hg

Pitot Tube PreTest OK @ 7 in. H₂O
 Leak Checks: Post Test OK @ 7 in. H₂O



NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	ECON- <u>2</u>
PLANT	SCR/FGD Plant 4
LOCATION	Economizer Outlet
DATE	<u>1/20/05</u>
OPERATOR(S)	<u>GLC/ST</u>
AMBIENT TEMP [°F]	<u>90</u>
BAR. PRESS. [° Hg]	<u>29.79</u>

METER BOX	<u>N-1</u>
PITOT TUBE DESC	<u>E-15</u>
PROBE LENGTH [ft]	<u>8'</u>
NOZZLE ID [inch]	<u>3/16" DIA, 0.191"</u>
%H ₂ O (Assumed)	
FILTER ID	<u>2</u>
K FACTOR	<u>0.632</u> <u>(0.632)</u>

CAL. DATA: delta H	<u>1.976</u>	Comments: _____
Y	<u>0.987</u>	
C(p)	<u>0.838</u>	
FILTER BOX SETTING	325	
PROBE HTR SETTING	325	
DUCT X-SECTION	circ ? rect ? other: _____	
DUCT DIMENSIONS	<u>2@25'x14.5'</u>	DUCT AREA 725 ft ²

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [° H ₂ O]	PITOT HEAD [° H ₂ O]	METER DIFF PRESSURE [° H ₂ O]	METER VACUUM [° Hg]	METER READING [ft]	METER TEMP [°F]		STACK TEMP [°F] ①	PROBE TEMP [°F] ②	FILTER BOX [°F]	LAST IMP TEMP [°F] ④	METER EXHAUST		
								⑥ inlet	⑦ outlet					O ₂ [% vol]	CO ₂ [% vol]	
	<u>0936</u>	0					<u>564.10</u>									
<u>N</u>		10		<u>1.00</u>	<u>0.63</u>	<u>4.0</u>	<u>568.50</u>	<u>84</u>	<u>87</u>	<u>709</u>	<u>320</u>		<u>50</u>	<u>3.7</u>	<u>16.3</u>	
<u>O</u>		20	<u>-4.56</u>	<u>1.05</u>	<u>0.66</u>	<u>4.5</u>	<u>572.91</u>	<u>86</u>	<u>83</u>	<u>711</u>	<u>330</u>		<u>47</u>	<u>3.7</u>	<u>16.3</u>	
<u>R</u>		30		<u>1.05</u>	<u>0.66</u>	<u>5.0</u>	<u>577.34</u>	<u>89</u>	<u>85</u>	<u>710</u>	<u>329</u>		<u>48</u>	<u>4.2</u>	<u>15.9</u>	
<u>T</u>		40		<u>1.05</u>	<u>0.66</u>	<u>5.0</u>	<u>581.78</u>	<u>92</u>	<u>86</u>	<u>711</u>	<u>321</u>		<u>49</u>	<u>4.0</u>	<u>16.0</u>	
<u>H</u>		50	<u>-4.65</u>	<u>1.05</u>	<u>0.66</u>	<u>6.0</u>	<u>586.23</u>	<u>94</u>	<u>88</u>	<u>713</u>	<u>321</u>		<u>50</u>	<u>3.8</u>	<u>16.2</u>	
		60		<u>1.05</u>	<u>0.66</u>	<u>6.5</u>	<u>590.66</u>	<u>95</u>	<u>89</u>	<u>714</u>	<u>318</u>		<u>51</u>	<u>4.2</u>	<u>15.9</u>	
				<u>POST</u>	<u>NORTH</u>	<u>LEAK CHECK</u>	<u>OK</u>	<u>0" @ 10" Hg</u>								
	<u>1054</u>						<u>594.50</u>									
<u>S</u>		70		<u>0.90</u>	<u>0.56</u>	<u>7.0</u>	<u>598.71</u>	<u>98</u>	<u>94</u>	<u>713</u>	<u>320</u>		<u>55</u>	<u>3.1</u>	<u>16.9</u>	
<u>O</u>		80	<u>-4.49</u>	<u>0.80</u>	<u>0.50</u>	<u>7.0</u>	<u>602.68</u>	<u>99</u>	<u>94</u>	<u>712</u>	<u>320</u>		<u>52</u>	<u>3.7</u>	<u>16.7</u>	
<u>U</u>		90		<u>0.80</u>	<u>0.50</u>	<u>8.0</u>	<u>606.64</u>	<u>100</u>	<u>95</u>	<u>710</u>	<u>330</u>		<u>52</u>	<u>3.7</u>	<u>16.3</u>	
<u>T</u>		100		<u>0.80</u>	<u>0.50</u>	<u>8.5</u>	<u>610.60</u>	<u>101</u>	<u>96</u>	<u>711</u>	<u>330</u>		<u>54</u>	<u>3.5</u>	<u>16.5</u>	
<u>H</u>		110		<u>0.80</u>	<u>0.50</u>	<u>9.0</u>	<u>614.52</u>	<u>102</u>	<u>97</u>	<u>712</u>	<u>329</u>		<u>54</u>	<u>3.6</u>	<u>16.4</u>	
		120		<u>0.80</u>	<u>0.50</u>	<u>10.0</u>	<u>618.51</u>	<u>102</u>	<u>97</u>	<u>713</u>	<u>316</u>		<u>54</u>	<u>3.1</u>	<u>16.9</u>	
							<u>50.57</u>		<u>92.8</u>	<u>711.6</u>				<u>3.7</u>	<u>16.4</u>	
AVERAGE			<u>-4.57</u>	<u>0.925</u>	<u>0.583</u>											

Sample Train Pre Test 2.02 ft³ @ 11 in. Hg
 Leak Checks: Post Test 0 ft³ @ 11 in. Hg

Pitot Tube Pre Test 0 @ 5 in. H₂O
 Leak Checks: Post Test 6 @ 5 in. H₂O

NOTE: Purge for 10 minutes at end of sampling.

1.005 ft³
18 5

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	AHO-2
PLANT	SCR/FGD Plant 4
LOCATION	Air Heater Outlet/ESP Inlet
DATE	1-20-05
OPERATOR(S)	JL, DO, PR
AMBIENT TEMP [°F]	
BAR. PRESS. [in Hg]	22.79

METER BOX	N-5
PITOT TUBE DESC	
PROBE LENGTH [ft]	10
NOZZLE ID [inch]	
%H ₂ O (Assumed)	6
FILTER ID	10
K FACTOR	0.93

CAL. DATA: delta H	2.015	Comments: _____
Y	1.011	
C(p)		
FILTER BOX SETTING	325	
PROBE HTR SETTING	325	
DUCT X-SECTION	circ ?	rect ? other: _____
DUCT DIMENSIONS		DUCT AREA _____

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST	
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]
	0735	0					836.000								
D-1	0745	10		0.30	0.28	1.0	888.84	58	61	254	306	NA	55		
D-1	0755	20	-9.08	0.30	0.28	1.0	891.57	60	62	254	291		47	5.7	14.4
D-1	1005	30		0.30	0.28	1.0	894.33	62	65	254	294		48	6.1	14.0
		40													
	10:12	50					894.700								
C-1	1022	40		0.45	0.42	1.5	898.12	65	68	254	303		51		
C-1	1032	50	-9.27	0.50	0.46	1.5	901.66	67	68	270	300		47	5.1	15.0
C-1	1042	60		0.50	0.46	1.5	905.18	68	69	270	305		47	5.1	14.9
	10:57	70		0.82			905.47								
B-1	11:01	70		0.95 0.76	0.67	2.0	910.00	70	72	288	322		55		
B-1	1111	80		0.95	0.87	2.0	914.68	72	71	293	314		51	5.5	14.5
B-1	1121	90		0.95	0.89	2.0	919.39	74	72	293	323		51	5.0	15.2
		100													
	1130	110					919.50								
A-1	1140	100		0.45	0.41	1.5	922.97	73	74	295	274		61		
A-1	1150	110	-9.14	0.41	0.38	1.5	926.24	74	74	299	308		55	5.4	14.6
A-1	1200	120		0.53	0.49	2.0	929.985	75	74	300	317		56	5.6	14.6
AVERAGE			-9.16	0.516	0.497		43.215	68.7		277.0				5.4	14.7

Sample Train	Pre Test <u>0.012</u> ft ³ @ <u>10.0</u> in. Hg	Pitot Tube	PreTest <u>OK</u> @ <u>8</u> in. H ₂ O
Leak Checks:	Post Test <u>0.000</u> ft ³ @ <u>5.0</u> in. Hg	Leak Checks:	Post Test <u>OK</u> @ <u>8</u> in. H ₂ O

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	STK- <u>42</u>
PLANT	SCR/FGD Plant 4
LOCATION	Stack
DATE	1-20-05
OPERATOR(S)	K.C. B.S.
AMBIENT TEMP [°F]	~55°
BAR. PRESS. [in Hg]	29.79

METER BOX	<u>N-3</u>
PITOT TUBE DESC	<u>E-11</u>
PROBE LENGTH [ft]	<u>10</u>
NOZZLE ID [inch]	<u>7/32A 0.24</u>
%H ₂ O (Assumed)	
FILTER ID	<u>#3</u>
K FACTOR	<u>1.67</u>

CAL. DATA: delta H	<u>1.982</u>	Comments: _____
Y	<u>1.026</u>	
C(p)	<u>0.806</u>	
FILTER BOX SETTING	<u>325</u>	
PROBE HTR SETTING	<u>250</u>	
DUCT X-SECTION	circ ? <input type="checkbox"/> rect ? <input type="checkbox"/> other: _____	
DUCT DIMENSIONS	19 ft ID	DUCT AREA <u>283.53 ft²</u>

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [in ²]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	<u>0935</u>	<u>0</u>					<u>548.80</u>									
<u>-10.00</u>		<u>10</u>		<u>.70</u>	<u>1.15</u>	<u>3</u>	<u>554.34</u>	<u>71</u>	<u>69</u>	<u>129</u>	<u>248</u>	<u>328</u>	<u>52</u>	<u>6.6</u>	<u>13.6</u>	
<u>-33.33</u>		<u>20</u>	<u>-.6590</u>	<u>1.10</u>	<u>1.82</u>	<u>4.5</u>	<u>561.22</u>	<u>74</u>	<u>70</u>	<u>128</u>	<u>255</u>	<u>332</u>	<u>52</u>	<u>6.2</u>	<u>13.9</u>	
<u>-67.50</u>		<u>30</u>		<u>1.10</u>	<u>1.82</u>	<u>4.5</u>	<u>568.18</u>	<u>77</u>	<u>71</u>	<u>128</u>	<u>257</u>	<u>334</u>	<u>54</u>	<u>6.4</u>	<u>13.7</u>	
				<u>L.C. RESTART</u>			<u>568.30</u>									
<u>-10.00</u>		<u>40</u>		<u>.76</u>	<u>1.25</u>	<u>3.5</u>	<u>574.11</u>	<u>76</u>	<u>71</u>	<u>128</u>	<u>257</u>	<u>330</u>	<u>57</u>	<u>6.4</u>	<u>13.8</u>	
<u>-33.33</u>		<u>50</u>	<u>-.5694</u>	<u>1.00</u>	<u>1.65</u>	<u>4</u>	<u>580.73</u>	<u>78</u>	<u>71</u>	<u>127</u>	<u>260</u>	<u>332</u>	<u>57</u>	<u>6.6</u>	<u>13.6</u>	
<u>-67.50</u>		<u>60</u>		<u>1.10</u>	<u>1.82</u>	<u>5</u>	<u>587.73</u>	<u>80</u>	<u>72</u>	<u>127</u>	<u>261</u>	<u>332</u>	<u>59</u>	<u>6.3</u>	<u>13.9</u>	
				<u>L.C. RESTART</u>			<u>587.88</u>	<u>80</u>	<u>74</u>	<u>127</u>	<u>257</u>	<u>332</u>	<u>54</u>	<u>6.5</u>	<u>13.7</u>	
<u>-10.00</u>		<u>70</u>		<u>.73</u>	<u>1.20</u>	<u>3.5</u>	<u>593.62</u>	<u>80</u>	<u>74</u>	<u>127</u>	<u>257</u>	<u>332</u>	<u>54</u>	<u>6.5</u>	<u>13.7</u>	
<u>-33.33</u>		<u>80</u>	<u>-.5058</u>	<u>1.10</u>	<u>1.82</u>	<u>5</u>	<u>600.61</u>	<u>84</u>	<u>75</u>	<u>127</u>	<u>251</u>	<u>332</u>	<u>51</u>	<u>6.4</u>	<u>13.8</u>	
<u>-67.50</u>		<u>90</u>		<u>1.15</u>	<u>1.90</u>	<u>5</u>	<u>607.77</u>	<u>85</u>	<u>76</u>	<u>126</u>	<u>257</u>	<u>332</u>	<u>49</u>	<u>6.5</u>	<u>13.7</u>	
				<u>L.C. RESTART</u>			<u>607.90</u>									
<u>-10.00</u>		<u>100</u>		<u>.70</u>	<u>1.15</u>	<u>3.5</u>	<u>613.49</u>	<u>83</u>	<u>77</u>	<u>126</u>	<u>252</u>	<u>325</u>	<u>50</u>	<u>6.4</u>	<u>13.8</u>	
<u>-33.33</u>		<u>110</u>	<u>-.6109</u>	<u>1.00</u>	<u>1.65</u>	<u>4.5</u>	<u>620.16</u>	<u>84</u>	<u>77</u>	<u>126</u>	<u>258</u>	<u>329</u>	<u>49</u>	<u>6.4</u>	<u>13.8</u>	
<u>-67.50</u>		<u>120</u>		<u>1.10</u>	<u>1.82</u>	<u>5</u>	<u>627.21</u>	<u>86</u>	<u>78</u>	<u>126</u>	<u>253</u>	<u>331</u>	<u>49</u>	<u>6.5</u>	<u>13.7</u>	
	<u>1154</u>															
AVERAGE			<u>-0.59</u>	<u>0.953</u>	<u>1.588</u>		<u>78.01</u>	<u>76.6</u>		<u>127.1</u>				<u>6.4</u>	<u>13.8</u>	
Sample Train	Pre Test	<u>OK ft³ @ 10 in. Hg</u>						Pitot Tube	Pre Test	<u>OK @ 7 in. H₂O</u>						
Leak Checks:	Post Test	<u>OK ft³ @ 10 in. Hg</u>						Leak Checks:	Post Test	<u>OK @ 7 in. H₂O</u>						

D
C
B
A



ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	ECON- <u>3</u>
PLANT	SCR/FGD Plant 4
LOCATION	Economizer Outlet
DATE	<u>1/20/05</u>
OPERATOR(S)	<u>GLC/ST</u>
AMBIENT TEMP [°F]	<u>95</u>
BAR. PRESS. [° Hg]	<u>29.72</u>

METER BOX	<u>N-1</u>
PITOT TUBE DESC	<u>E-15</u>
PROBE LENGTH [ft]	<u>8'</u>
NOZZLE ID [inch]	<u>3/16" dia, 0.191"</u>
%H ₂ O (Assumed)	
FILTER ID	<u>3</u>
K FACTOR	<u>0.632</u>

CAL. DATA: delta H	<u>1.976</u>	Comments: <u>REAR PANEL REMOVED @ ~ 1500</u> <u>PAUSE TEST @ 1513</u> <u>RESTART TEST @ 1520</u> <u>INSPECTED / LEAK TESTED FIRST</u> <u>LINES - OK</u>	
Y	<u>0.987</u>		
C(p)	<u>0.838</u>		
FILTER BOX SETTING	<u>325</u>		
PROBE HTR SETTING	<u>325</u>		
DUCT X-SECTION	circ ?	rect ?	other:
DUCT DIMENSIONS	<u>2@25x14.5</u>	DUCT AREA	<u>725 ft²</u>

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [° H ₂ O]	PITOT HEAD [° H ₂ O]	METER DIFF PRESSURE [° H ₂ O]	METER VACUUM [° Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								⑥ inlet	⑦ outlet					O ₂ [% vol]	CO ₂ [% vol]	
	<u>1335</u>	0					<u>623.60</u>									
<u>S</u>		10		<u>0.82</u>	<u>0.52</u>	<u>4.0</u>	<u>627.66</u>	<u>99</u>	<u>97</u>	<u>712</u>	<u>315</u>		<u>63</u>	<u>3.5</u>	<u>16.5</u>	
<u>O</u>		20		<u>0.82</u>	<u>0.52</u>	<u>4.0</u>	<u>631.67</u>	<u>100</u>	<u>97</u>	<u>710</u>	<u>324</u>		<u>60</u>	<u>3.2</u>	<u>16.8</u>	
<u>U</u>		30	<u>-4.25</u>	<u>2.82</u>	<u>0.52</u>	<u>4.5</u>	<u>635.68</u>	<u>102</u>	<u>98</u>	<u>712</u>	<u>331</u>		<u>60</u>	<u>3.4</u>	<u>16.6</u>	
<u>T</u>		40		<u>0.76</u>	<u>0.48</u>	<u>5.0</u>	<u>639.60</u>	<u>103</u>	<u>98</u>	<u>711</u>	<u>328</u>		<u>60</u>	<u>3.7</u>	<u>16.3</u>	
<u>H</u>		50	<u>-4.54</u>	<u>0.76</u>	<u>0.48</u>	<u>5.0</u>	<u>643.51</u>	<u>104</u>	<u>99</u>	<u>712</u>	<u>322</u>		<u>61</u>	<u>3.6</u>	<u>16.4</u>	
		60		<u>0.76</u>	<u>0.48</u>	<u>5.5</u>	<u>647.41</u>	<u>105</u>	<u>100</u>	<u>712</u>	<u>318</u>		<u>62</u>	<u>3.8</u>	<u>16.2</u>	
				<u>POST SOUTH</u>		<u>Leak check OK - @ 10" Hg</u>										
				<u>PRE-NORTH</u>		<u>"</u>										
	<u>1453</u>						<u>647.70</u>									
<u>N</u>		70		<u>0.54</u>	<u>0.34</u>	<u>4.0</u>	<u>651.11</u>	<u>104</u>	<u>101</u>	<u>714</u>	<u>322</u>		<u>67</u>	<u>4.2</u>	<u>15.9</u>	
<u>O</u>		80		<u>0.54</u>	<u>0.34</u>	<u>4.5</u>	<u>654.50</u>	<u>100</u>	<u>99</u>	<u>713</u>	<u>315</u>		<u>65</u>	<u>4.7</u>	<u>15.4</u>	
<u>R</u>		90		<u>0.60</u>	<u>0.38</u>	<u>5.0</u>	<u>658.06</u>	<u>98</u>	<u>99</u>	<u>711</u>	<u>315</u>		<u>67</u>	<u>3.7</u>	<u>16.3</u>	
<u>T</u>		100	<u>-4.62</u>	<u>0.50</u>	<u>0.35</u>	<u>5.5</u>	<u>661.47</u>	<u>98</u>	<u>99</u>	<u>716</u>	<u>320</u>		<u>67</u>	<u>3.9</u>	<u>16.1</u>	
<u>H</u>		110	<u>-4.46</u>	<u>0.54</u>	<u>0.34</u>	<u>6.0</u>	<u>664.83</u>	<u>98</u>	<u>99</u>	<u>717</u>	<u>327</u>		<u>67</u>	<u>3.4</u>	<u>16.6</u>	
		120		<u>0.60</u>	<u>0.38</u>	<u>6.5</u>	<u>668.32</u>	<u>98</u>	<u>98</u>	<u>721</u>	<u>330</u>		<u>68</u>	<u>3.1</u>	<u>16.9</u>	
AVERAGE			<u>-4.47</u>	<u>0.672</u>	<u>0.428</u>		<u>44.43</u>	<u>99.7</u>		<u>713.4</u>				<u>3.7</u>	<u>16.3</u>	

Sample Train Pre Test 0 ft³ @ 10 in. Hg
Leak Checks: Post Test 0 ft³ @ 11 in. Hg

Pitot Tube Pre Test 0 @ 5 in. H₂O
Leak Checks: Post Test @ in. H₂O



ASIDE = ~~FROM 5" TO 4.5"~~
LEAK FROM 5" → 4.5", ~ 30 SEC
POST TEST

NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	AHO-3
PLANT	SCR/FGD Plant 4
LOCATION	Air Heater Outlet/ESP Inlet
DATE	1-20-05
OPERATOR(S)	JL RR DO
AMBIENT TEMP [°F]	
BAR. PRESS. [in. Hg]	29.72

METER BOX	N-5
PITOT TUBE DESC	
PROBE LENGTH [ft]	10
NOZZLE ID [inch]	
%H ₂ O (Assumed)	
FILTER ID	11
K FACTOR	0.93

CAL. DATA: delta H	2.015	Comments: _____	
Y	1.011		
C(p)			
FILTER BOX SETTING	325		
PROBE HTR SETTING	325		
DUCT X-SECTION	circ ?	rect ?	other: _____
DUCT DIMENSIONS		DUCT AREA	

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in. H ₂ O]	PITOT HEAD [in. H ₂ O]	METER DIFF PRESSURE [in. H ₂ O]	METER VACUUM [in. Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	13:35	0					435.44									
A-1	1345	10		0.65	0.60	2.0	939.41	78	78	298	286	NA	49	5.4	14.8	
A-1	1355	20	-9.29	0.65	0.60	2.0	943.51	81	80	299	289		46	5.1	14.9	
A-1	1405	30		0.65	0.60	2.0	947.556	82	81	299	290		46	5.5	14.9	
		60				leak check OK @ 7 in. Hg										
	1414	60		0.45	0.41		947.702	80	79							
B-1	1424	90		0.48	0.44	2.0	957.21	80	79	294	294		51	5.4	14.7	
B-1	1434	90	-8.55	0.48	0.44	2.0	954.73	81	80	294	310		49	4.9	15.2	
B-1	1444	60		0.48	0.44	2.0	958.243	83	83	291	319		49	5.1	14.9	
						leak check OK @ 6 in. Hg										
	1450	120		0.52			958.332									
C-1	1500	90		0.52	0.48	2.0	961.96	84	81	267	300		55			
C-1	1510	90	-8.48	0.56	0.52	2.0	965.70	86	86	275	306		49	4.8	15.4	
C-1	1520	90		0.56	0.52	2.0	969.317	86	86	275	317		48	5.0	14.9	
		120				leak check OK @ 7 in. Hg										
	1529	120					969.431									
D-1	1539	100		0.42	0.39	1.5	972.67	83	85	254	303		60			
D-1	1549	110	-9.28	0.42	0.39	1.5	976.05	85	85	257	323		47	5.6	14.5	
D-1	1559	120		0.38	0.35	1.5	979.295	87	87	258	323		47	5.3	14.8	
AVERAGE			-8.90	0.514	0.478		43.506	83.0		280.3				5.2	14.9	

Sample Train Pre Test 0.000 ft³ @ 11.0 in. Hg
 Leak Checks: Post Test 0.500 ft³ @ 5.0 in. Hg

Pitot Tube Pre Test OK @ 7 in. H₂O
 Leak Checks: Post Test OK @ 7 in. H₂O



NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	STK - <u>#3</u>
PLANT	SCR/FGD Plant 4
LOCATION	Stack
DATE	1-20-05
OPERATOR(S)	K.C., B.S.
AMBIENT TEMP [°F]	~64°
BAR. PRESS. [in Hg]	29.72

METER BOX	2-3
PITOT TUBE DESC	E-11
PROBE LENGTH [ft]	10
NOZZLE ID [inch]	7/32A 0.217
%H ₂ O (Assumed)	
FILTER ID	#4
K FACTOR	1.67

CAL. DATA: delta H	1.982
Y	1.026
C(p)	0.806
FILTER BOX SETTING	325
PROBE HTR SETTING	250
DUCT X-SECTION	circ ? rect ? other: _____
DUCT DIMENSIONS	19 ft ID DUCT AREA 283.53 ft ²

Comments: _____

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ²]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	1335	0					633.00									
-10.00		10		.73	1.20	3.5	638.78	79	77	127	255	325	55	6.3	13.9	
-33.33		20	-.5556	1.05	1.75	4.5	645.67	83	78	127	259	333	50	6.2	14.0	
-67.50		30		1.10	1.82	5	652.72	86	78	127	252	333	50	5.9	14.2	
				L.C. RESTART			652.85									
-10.00		40		.70	1.15	3.5	658.47	86	80	127	257	330	52	6.1	14.0	
-33.33		50	-.5375	1.10	1.82	5	665.52	89	81	127	259	331	52	6.1	14.0	
-67.50		60		1.15	1.90	5	672.73	90	81	126	254	331	52	6.2	14.0	
				L.C. RESTART			672.86									
-10.00		70		.73	1.20	4	678.68	87	82	125	246	327	54	6.1	14.0	
-33.33		80	-.6511	1.05	1.75	5	685.58	90	83	126	253	333	55	6.2	14.0	
-67.50		90		1.10	1.82	5	692.64	90	83	126	256	334	56	6.0	14.1	
				L.C. RESTART			692.77									
-10.00		100		.66	1.10	3.5	698.35	89	84	127	255	330	55	6.1	14.0	
-33.33		110	-.5822	1.10	1.82	5	705.43	92	84	126	255	331	53	6.3	13.9	
-67.50		120		1.15	1.90	5	712.70	92	84	124	256	329	54	6.1	14.0	
	1553															
AVERAGE			-0.58	0.958	1.60		79.31	84.5		126.3				6.1	14.0	

Sample Train Pre Test OK ft³ @ 10 in. Hg
 Leak Checks: Post Test OK ft³ @ 10 in. Hg

Pitot Tube Pre Test OK @ 7 in. H₂O
 Leak Checks: Post Test OK @ 7 in. H₂O



NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	AHO-4	METER BOX	N-5	CAL. DATA: delta H	2.015	Comments: _____ _____ _____
PLANT	SCR/FGD Plant 4	PITOT TUBE DESC		Y	1.01	
LOCATION	Air Heater Outlet/ESP Inlet <i>unit</i>	PROBE LENGTH [ft]	10	C(p)		
DATE	1-21-05	NOZZLE ID [inch]		FILTER BOX SETTING	325	
OPERATOR(S)	JLUR 70	%H ₂ O (Assumed)	6	PROBE HTR SETTING	325	
AMBIENT TEMP [°F]		FILTER ID	12	DUCT X-SECTION	circ ? rect ? other: _____	
BAR. PRESS. [in. Hg]	29.65	K FACTOR	0.93	DUCT DIMENSIONS	35.176 118x113x4	
				DUCT AREA	54.44	

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in. H ₂ O]	PITOT HEAD [in. H ₂ O]	METER DIFF PRESSURE [in. H ₂ O]	METER VACUUM [in. Hg]	METER READING [ft]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST				
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]			
	0900	0					987.415											
D-1	0910	10		0.44	0.41	2.0	987.78	55	54	254	326	NA	51					
D-1	0920	20	-8.94	0.44	0.41	2.0	991.12	55	57	254	327		45	6.0	14.1			
D-1	0930	30		0.44	0.41	2.0	994.443	58	59	254	325		44	5.8	14.3			
							<i>leak check OK @ 6" H₂O</i>											
E-1	0937	50					994.560											
C-1	0947	80		0.44	0.41	2.0	997.800	59	63	259	324		50					
C-1	0957	50	-8.67	0.41	0.38	2.0	1001.000	63	64	270	324		44	4.7	15.4			
C-1	1007	60		0.41	0.38	2.5	1004.237	64	65	270	325		44					
							<i>leak check OK @ 6" H₂O</i>											
	10:13			57			1004.360											
B-1	10:23	80		0.44	0.53	2.5	1008.17	65	68	285	324		51					
B-1	10:33	90	-8.95	0.62	0.58	3.0	1012.14	68	69	293	322		49	5.0	15.1			
B-1	10:43	100		0.62	0.58	3.0	1016.113	70	71	293	325		51					
							<i>leak check OK @ 6" H₂O</i>											
	10:50	120					1016.25											
A-1	11:00	100		0.51	0.47	2.5	1019.85	76	73	294	322		60					
A-1	11:10	110	-9.10	0.51	0.47	2.5	1023.39	73	73	301	316		54	5.3	14.8			
A-1	11:20	120		0.51	0.47	3.0	1027.016	74	75	301	318		54	4.9	16.2			
				0.491														
AVERAGE			-8.92		0.458		42.229	65.3		277.3				5.3	14.8			

Sample Train	Pre Test	0.000 ft ³ @ 11 in. Hg	Pitot Tube	PreTest	OK @ 8 in. H ₂ O
Leak Checks:	Post Test	0.000 ft ³ @ 5 in. Hg	Leak Checks:	Post Test	_____ @ _____ in. H ₂ O



NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID
PLANT
LOCATION
DATE
OPERATOR(S)
AMBIENT TEMP [°F]
BAR. PRESS. [in. Hg]

FGD- 4
SCR/FGD Plant 4
FGD Inlet
1/21/05
JTW
57
29.65

METER BOX	N4
PITOT TUBE DESC	E-12
PROBE LENGTH [ft]	8
NOZZLE ID [inch]	3/16 @ 0.193
%H ₂ O (Assumed)	7.5
FILTER ID	4
K FACTOR	1.06

CAL. DATA: delta H	1.983	Comments:	
Y	0.960		
C(p)	0.835		
FILTER BOX SETTING	325		
PROBE HTR SETTING	325		
DUCT X-SECTION	circ ?	rect ?	other:
DUCT DIMENSIONS		DUCT AREA	

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES (5.6) [in. H ₂ O]	PITOT HEAD (1.1) [in. H ₂ O]	METER DIFF PRESSURE [in. H ₂ O]	METER VACUUM [in. Hg]	METER READING [ft ³]	METER TEMP [°F] (75°)		STACK TEMP [°F] 272	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ (6) [% vol]	CO ₂ (4) [% vol]	
	09:00	0					155.20									
	09:10	10	5.5	1.20	1.25	4.0	161.43	65	62	270	325	NA	51	5.9	14.2	
	09:20	20	5.6	1.20	1.25	4.0	167.50	69	63	270	325		51	5.9	14.2	
	09:30	30	5.6	1.20	1.25	4.0	173.54	72	64	270	325		52	6.0	14.1	
	09:40	40	5.7	1.30	1.35	4.5	179.86	74	65	270	325		53	5.7	14.4	
	09:50	50	5.6	1.30	1.35	4.5	186.19	75	66	270	325		52	5.9	14.2	
	10:00	60	5.6	1.30	1.35	4.5	192.50	77	67	270	325		52	5.7	14.4	
	10:10	70	5.7	1.15	1.20	4.5	198.70	78	68	271	325		52	5.6	14.2	
	10:20	80	5.6	1.15	1.20	4.5	204.79	79	69	271	325		54	5.9	14.2	
	10:30	90	5.5	1.15	1.20	4.5	210.86	80	69	272	325		54	5.7	14.4	
	10:40	100	5.6	1.20	1.25	4.5	216.95	81	70	272	325		55	5.9	14.2	
	10:50	110	5.8	1.20	1.25	4.5	223.14	81	71	272	325		55	5.8	14.3	
	11:00	120	5.8	1.20	1.25	4.5	229.15	82	72	273	325		56	5.9	14.2	
		100														
		110														
		120														
				(RUC)												
AVERAGE			5.63	1.212	1.263		73.95		71.8	270.9				5.83	14.28	

Sample Train Pre Test *head slip* ft³ @ -12 in. Hg
Leak Checks: Post Test *OK* ft³ @ -8 in. Hg

Pitot Tube Pre Test *OK* @ -8 in. H₂O
Leak Checks: Post Test *OK* @ -8 in. H₂O

Post-test air purge for 10 min @ ΔH = 1.0

NOTE: Purge for 10 minutes at end of sampling.



ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID
PLANT
LOCATION
DATE
OPERATOR(S)
AMBIENT TEMP [°F]
BAR. PRESS. [in. Hg]

STK - 1 TEST #4
SCR/FGD Plant 4
Stack
1-21-05
K.C. & ISO BABY
~53°
29.65

METER BOX	N-3
PITOT TUBE DESC	E-11
PROBE LENGTH [ft]	10
NOZZLE ID [inch]	7/32 A 0.214
%H ₂ O (Assumed)	
FILTER ID	#5
K FACTOR	1.67

CAL. DATA: delta H	1.982
Y	1.026
C(p)	0.806
FILTER BOX SETTING	325
PROBE HTR SETTING	250
DUCT X-SECTION	circ ? rect ? other:
DUCT DIMENSIONS	19 ft ID DUCT AREA 283.53 ft ²

Comments: _____

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in. H ₂ O]	PITOT HEAD [in. H ₂ O]	METER DIFF PRESSURE [in. H ₂ O]	METER VACUUM [in. Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	0900	0					718.50									
-10.00		10		.73	1.20	3.5	724.28	73	72	127	247	328	46	6.5	13.7	
-33.33		20	-.665	1.10	1.82	5	731.28	77	72	127	250	333	46	6.1	14.0	
-67.50		30		1.15	1.90	5	738.49	80	73	126	250	333	46	6.1	14.0	
				L.C. RESTART			738.61									
-10.00		40		.73	1.20	3.5	744.38	78	73	126	251	330	47	6.1	14.0	
-33.33		50	-.5008	1.05	1.75	5	751.25	81	74	126	257	330	49	5.9	14.2	
-67.50		60		1.10	1.82	5	758.29	82	75	126	252	331	51	6.1	14.0	
				L.C. RESTART			758.40									
-10.00		70		.76	1.25	4	764.27	81	75	126	255	330	52	6.2	14.0	
-33.33		80	-.5228	1.10	1.82	5	771.33	83	76	126	254	331	53	6.1	14.0	
-67.50		90		1.15	1.90	5	778.56	85	77	127	253	332	48	6.2	14.0	
				L.C. RESTART			778.70									
-10.00		100		.76	1.25	4	784.57	84	78	127	255	327	46	6.2	14.0	
-33.33		110	-.4812	1.10	1.82	5	791.60	86	78	127	254	331	46	6.2	14.0	
-67.50		120		1.15	1.90	5	798.83	89	80	127	259	332	47	6.1	14.0	
	1115															
AVERAGE				-0.54	0.982	1.64	79.96	78.4		126.5				6.2	14.0	

Sample Train Pre Test OK ft³ @ 10 in. Hg
Leak Checks: Post Test OK ft³ @ 10 in. Hg

Pitot Tube Pre Test OK @ 7 in. H₂O
Leak Checks: Post Test OK @ 7 in. H₂O



SCR/FGD Hg SAMPLING PROGRAM, PLANT 4 - ONTARIO HYDRO SAMPLING TRAIN DATA

Location	Econ Out Unit 1	AirHtr Out Unit 1	FGD Inlet Unit 1	Stack Unit 1	Econ Out Unit 1	AirHtr Out Unit 1	FGD Inlet Unit 1	Stack Unit 1	Econ Out Unit 1	AirHtr Out Unit 1	FGD Inlet Unit 1	Stack Unit 1	Econ Out Unit 1	AirHtr Out Unit 1	FGD Inlet Unit 1	Stack Unit 1	Econ Out Unit 1	AirHtr Out Unit 1	FGD Inlet Unit 1	Stack Unit 1	
Date	19-Jan	19-Jan	19-Jan	19-Jan	20-Jan	20-Jan	20-Jan	20-Jan	20-Jan	20-Jan	20-Jan	20-Jan	20-Jan	20-Jan	20-Jan	20-Jan	01/21/2005	01/21/2005	01/21/2005	01/21/2005	
Start Time	1100	1100	1100	1100	935	1154	935	935	1154	1335	1553	1335	1553	1113	900	1113	900	1113	900	1113	
Stop Time	1315	1325	1300	1320	1154	1200	935	935	1154	1335	1553	1335	1553	1113	900	1113	900	1113	900	1113	
Test Number	ECON-1	AHO-1	FGD-1	STK-1	ECON-2	AHO-2	FGD-2	STK-2	ECON-3	AHO-3	FGD-3	STK-3	ECON-4	AHO-4	FGD-4	STK-4					
Sample Type	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	
Y factor of dry gas meter	-	0.987	1.010	0.960	1.026	0.987	1.010	0.960	1.026	0.987	1.010	0.960	1.026	0.987	1.010	0.960	1.026	0.987	1.010	0.960	1.026
Gas Volume	- ft ³	49.14	42.96	70.68	77.62	50.57	43.22	73.82	78.01	44.43	43.51	69.07	79.31	50.47	42.23	73.95	79.96				
Delta H of dry gas meter	- °H ₂ O	0.55	0.47	1.18	1.57	0.58	0.50	1.27	1.59	0.43	0.48	1.10	1.60	0.59	0.46	1.26	1.64				
Meter Temperature	- °F	98.7	80.3	75.7	82.0	92.8	68.7	80.7	76.6	99.7	83.0	74.5	84.5	89.9	65.3	71.8	78.4				
C Factor of pitot tube	-	0.838	0.846	0.835	0.806	0.838	0.846	0.835	0.806	0.838	0.846	0.835	0.806	0.838	0.846	0.835	0.806				
Nozzle Diameter	- inches	0.191	0.188	0.193	0.214	0.191	0.188	0.193	0.214	0.191	0.188	0.193	0.214	0.191	0.188	0.193	0.214				
A n (area of nozzle)	- ft ²	0.00020	0.00019	0.00020	0.00025	0.00020	0.00019	0.00020	0.00025	0.00020	0.00019	0.00020	0.00025	0.00020	0.00019	0.00020	0.00025				
Area of Stack (Single of Dual)	- ft ²	725.0	544.4	283.5	725.0	544.4	283.5	725.0	544.4	283.5	725.0	544.4	283.5	725.0	544.4	283.5	725.0				
H ₂ O Weight	- gm	90.7	76.4	114.1	239.2	91.5	71.7	107.5	243.3	77.3	74.0	124.9	241.4	90.1	89.7	121.6	245.3				
Sample Time	- minutes	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120				
Barometric Pressure	- °Hg	29.96	29.96	29.96	29.96	29.79	29.79	29.79	29.79	29.72	29.72	29.72	29.72	29.65	29.65	29.65	29.65				
Static Pressure	- °H ₂ O	-4.54	-9.00	5.68	-0.45	-4.57	-9.16	5.58	-0.59	-4.47	-8.90	4.29	-0.58	-4.40	-8.92	5.63	-0.54				
% Oxygen	-	3.3	4.9	6.0	6.2	3.7	5.4	5.9	6.4	3.7	5.2	6.1	3.7	5.3	5.8	6.2					
% Carbon Dioxide	-	16.7	15.2	14.1	14.0	16.4	14.7	14.3	13.8	16.3	14.9	14.2	14.0	16.4	14.8	14.3					
% N ₂ + CO	-	80.0	79.9	79.9	79.8	79.9	79.9	79.8	79.9	80.0	79.9	79.9	79.9	79.9	79.9	79.9					
Stack Temp (Dry Bulb)	- °F	702	274	269	127	712	277	274	127	713	280	272	126	714	277	271	127				
Stack Temp (Wet Bulb)	- °F																				
"S" sample (rms vel head)	- °H ₂ O	0.868	0.507	1.123	0.944	0.925	0.516	1.216	0.953	0.672	0.514	1.052	0.958	0.945	0.491	1.212	0.982				
Dust Wt.	- gm	5.300	1.638	0.0024	0.0002	6.576	0.698	0.004	0.0030	6.039	2.135	0.0115	0.0012	7.128	1.597	0.0134	0.0017				
Sample Volume	- DSCF	45.94	42.49	67.13	77.95	47.52	43.44	69.09	78.69	41.12	42.47	65.21	78.66	47.45	42.51	70.04	80.02				
Sample Volume	- dscm	1.301	1.203	1.901	2.208	1.346	1.230	1.957	2.228	1.164	1.203	1.847	2.228	1.344	1.204	1.984	2.266				
ABS ST PRES	- °Hg	29.63	29.30	30.38	29.93	29.45	29.12	30.20	29.75	29.39	29.07	30.04	29.68	29.33	28.99	30.06	29.61				
ABS ST TEMP	- °R	1162	734	729	587	1172	737	734	587	1173	740	732	586	1174	737	731	587				
H ₂ O - % by Vol	- vapor	8.5	7.8	7.4	12.6	8.3	7.2	6.8	12.7	8.1	7.6	8.3	12.6	8.2	9.0	7.6	12.6				
Water Volume	- std ft ³	4.27	3.60	5.37	11.27	4.31	3.38	5.06	11.46	3.64	3.49	5.88	11.37	4.24	4.22	5.73	11.55				
Dry Molecular Weight	- lb/lb-mole	30.80	30.63	30.50	30.49	30.77	30.57	30.46	30.76	30.59	30.51	30.48	30.77	30.58	30.52	30.49					
Wet Molecular Weight	- lb/lb-mole	29.71	29.64	29.57	28.91	29.71	28.66	29.67	28.88	29.72	29.64	29.47	29.92	29.72	29.44	29.57	28.91				
% EXCESS AIR	-	18.5	30.3	39.4	41.7	21.3	34.4	38.9	43.6	21.2	32.7	38.8	40.7	21.3	33.6	37.9	41.7				
Dry Mole Frac.	-	0.915	0.922	0.926	0.874	0.917	0.928	0.932	0.873	0.919	0.924	0.917	0.874	0.918	0.910	0.924	0.874				
Wet Mole Frac.	-	0.085	0.078	0.074	0.126	0.083	0.072	0.068	0.127	0.081	0.076	0.083	0.126	0.082	0.080	0.126	0.126				
Gas Velocity, Direct	- ft/sec	76.69	47.33	68.16	77.95	79.73	47.99	71.26	78.69	68.07	48.07	66.57	78.66	80.82	47.10	71.25	80.02				
ACFM	-	3,336,140	1,546,234	0	1,326,070	3,468,059	1,567,764	0	1,338,659	2,960,969	1,570,237	0	1,338,148	3,515,756	1,538,526	0	1,361,284				
DSCFM (FGD inlet = Air Heater Outlet)	-	1,372,962	1,004,537	1,004,537	1,042,760	1,410,646	1,014,161	1,014,161	1,044,777	1,202,357	1,005,445	1,005,445	1,044,352	1,422,593	971,175	971,175	1,059,801				
DSCFM (rounded)	-	1,373,000	1,004,500	1,004,500	1,042,800	1,410,600	1,014,200	1,014,200	1,044,800	1,202,400	1,005,400	1,005,400	1,044,400	1,422,600	971,200	971,200	1,059,800				
DSCMM	-	38,882	28,448	28,448	29,531	39,950	28,721	28,721	29,588	34,051	28,474	28,474	40,288	27,504	27,504	30,014					
Excess Air Free DSCFM	-	1,156,179	769,023	718,075	733,425	1,160,915	752,129	727,867	724,845	989,500	755,286	721,611	739,541	1,170,747	724,896	701,662	745,410				
CALCULATED FIRING RATE:																					
Dry	- lb/min	8,648	5,752	5,371	5,486	8,710	5,643	5,461	5,438	7,424	5,667	5,414	5,549	9,028	5,590	5,411	5,748				
Wet	- lb/min	8,825	5,870	5,481	5,598	8,878	5,752	5,566	5,543	7,567	5,776	5,518	5,655	9,154	5,668	5,485	5,828				
Dry	- lb/hr	518,885	345,132	322,267	329,156	522,600	338,580	327,658	326,298	445,436	340,002	324,842	332,914	541,699	335,406	324,856	344,898				
Wet	- lb/hr	529,474	352,176	328,844	335,873	532,668	345,103	333,970	332,584	454,017	346,551	331,100	339,327	549,223	340,065	329,165	349,688				
CALCULATED FIRING RATE:																					
Dry	- tons/hr	259.4	172.6	161.1	164.6	261.3	169.3	163.8	163.1	222.7	170.0	162.4	166.5	270.8	167.7	162.3	172.4				
Wet	- tons/hr	264.7	176.1	164.4	167.3	266.3	172.6	167.0	166.3	227.0	173.3	165.6	169.7	274.6	170.0	164.6	174.8				
HEAT INPUT:																					
MM Btu/hr	-	7100	4722	4410	4504	7152	4634	4484	4466	6096	4653	4446	4556	7153	4429	4287	4554				
PARTICULATE LOADING:																					
Grains/DSCF	-	1.7799	0.5946	0.0006	0.0000	2.1356	0.2480	0.0001	0.0006	2.2660	0.7754	0.0027	0.0002	2.3179	0.5797	0.0030	0.0003				
lb/hr	-	20,955	5,122	5	0.35	25,830	2,157	1	5.27	23,363	6,685	23.5	2.11	28,273	4,828	24.6	2.98				
lb/MM Btu	-	2.95	1.08	0.00	0.00	3.61	0.47	0.00	0.00	3.83	1.44	0.01	0.00	3.95	1.09	0.01	0.00				
Ash Production	- lb/hr	40,317	26,817	25,040	25,575	43,062	27,899	26,999	26,887	36,704	28,016	26,767	27,432	64,191	39,746	38,472	40,870				
Baghouse Ash	-	20,955	5,122	5	0.35	25,830	2,157	1	5.27	23,363	6,685	23	2.11	28,273	4,82						

Impinger Components Wts & Volumes	ECON-1	AHO-1	FGD-1	STK-1	ECON-2	AHO-2	FGD-2	STK-2	ECON-3	AHO-3	FGD-3	STK-3	ECON-4	AHO-4	FGD-4	STK-4
Filter Wt., g	5.2995	1.6375	0.0024	0.3278	6.5763	0.6981	0.0004	0.3375	6.0387	2.1345	0.0115	0.3303	7.1277	1.5973	0.0134	0.3297
ppb Hg	15	462	<5.0	<5.0	15	80	<5.0	<5.0	14	98	<5.0	<5.0	18	95	<5.0	<5.0
total ug	0.08	0.76	<5.00E-03	<5.00E-03	0.10	0.06	<5.00E-03	<5.00E-03	0.08	0.21	<5.00E-03	<5.00E-03	0.13	0.15	<5.00E-03	<5.00E-03
ug/dscm	0.06	0.63	<2.63E-03	<2.26E-03	0.07	0.05	<2.56E-03	<2.24E-03	0.07	0.17	<2.71E-03	<2.24E-03	0.10	0.13	<2.52E-03	<2.21E-03
Probe Rinse volume, ml	177	143	64	109	188	120	77	105	170	121	135	111	227	88	127	109
Analytical Hg, ng/ml	<1.0	1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
ug/dscm	<0.14	0.12	<0.03	<0.05	<0.14	<0.10	<0.04	<0.05	<0.15	<0.10	<0.07	<0.05	<0.17	<0.07	<0.06	<0.05
Heated Umbilical Line Rinse volume, ml	75	98	84	NA	111	106	80	NA	115	118	112	NA	173	139	107	NA
Analytical Hg, ng/ml	<1.0	1.7	<1.0		<1.0	5.1	<1.0		<1.0	<1.0	<1.0		<1.0	<1.0	<1.0	<1.0
ug/dscm	<0.06	0.14	<0.04		<0.08	0.44	<0.04		<0.10	<0.10	<0.06		<0.13	<0.12	<0.05	
KCl volume, ml	537	528	559	680	537	524	555	683	526	523	566	684	537	539	562	690
Analytical Hg, ng/ml	11.2	12.3	21.0	1.3	11.9	14.9	22.7	1.0	10.2	14.6	23.9	0.9	8.2	9.9	11.7	0.7
ug/dscm	4.62	5.40	6.17	0.40	4.75	6.35	6.44	0.31	4.61	6.35	7.32	0.28	3.28	4.43	3.32	0.21
Nitric Peroxide volume, ml	176	174	175	177	175	173	175	177	175	175	176	175	174	175	176	175
Analytical Hg, ng/ml	0.5	<0.2	<0.2	<0.20	0.5	0.9	0.4	<0.20	0.4	0.3	0.2	0.2	0.4	<0.2	<1.0	<0.20
ug/dscm	0.07	<0.03	<0.02	<0.02	0.07	0.13	0.04	<0.02	0.06	0.04	0.02	0.02	0.05	<0.03	<0.09	<0.02
KMnO4 volume, ml	244	243	244	245	246	242	243	246	245	246	247	245	245	245	247	244
Analytical Hg, ng/ml	23.2	0.4	2.4	2.3	17.3	3.5	1.4	6.3	13.4	4.5	2.0	9.1	8.0	1.3	2.6	4.3
ug/dscm	4.35	0.08	0.31	0.26	3.16	0.69	0.17	0.70	2.82	0.92	0.27	1.00	1.46	0.26	0.32	0.46
KMnO4-Acid Rinse volume, ml	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
Analytical Hg, ng/ml	<1.0	1.5	<1.0	<1.0	1.8	<1.0	1.1	2.0	<1.0	<1.0	1.5	<1.0	<1.0	<1.0	<1.0	<1.0
ug/dscm	<0.08	0.12	<0.05	<0.05	0.13	<0.08	0.06	0.09	<0.09	<0.08	0.08	<0.04	<0.07	<0.08	<0.05	<0.04
Particulate, ug/m ³	0.0611	0.6287	2.63E-03	2.26E-03	0.0733	0.0454	2.56E-03	2.24E-03	0.0726	0.1739	2.71E-03	2.24E-03	0.0955	0.1260	2.52E-03	2.21E-03
Particulate, mg/sec	0.0251	0.2843	1.27E-03	1.11E-03	0.0305	0.0209	1.22E-03	1.11E-03	0.0308	0.0808	1.32E-03	1.11E-03	0.0408	0.0594	1.23E-03	1.10E-03
Percent of Total	0.6519	9.6464	0.0396	0.2947	0.8721	0.5801	0.0376	0.1939	0.9202	2.2388	0.0346	0.1615	1.8169	2.4600	0.0647	0.2807
Oxidized Fraction, ug/m ³	4.8164	5.6543	6.2523	0.4498	4.9711	6.8841	6.5191	0.3536	4.8521	6.5466	7.4582	0.3262	3.5746	4.6204	3.4330	0.2612
Oxidized Fraction, mg/sec	1.9800	2.5568	3.0279	0.2214	2.0666	3.1758	3.1077	0.1744	2.0580	3.0420	3.6274	0.1608	1.5282	2.1779	1.6718	0.1307
Percent of Total	51.3863	86.7578	94.2470	58.5185	59.1385	87.9653	96.0454	30.5640	61.4972	84.2812	95.2679	23.4682	68.0243	90.1879	88.0609	33.2360
Elemental Fraction, ug ³	4.4954	0.2343	0.3790	0.3166	3.3614	0.8964	0.2659	0.8011	2.9652	1.0471	0.3678	1.0615	1.5848	0.3767	0.4629	0.5226
Elemental Fraction, mg/sec	1.8480	0.1060	0.1836	0.1558	1.3974	0.4135	0.1267	0.3950	1.2577	0.4865	0.1789	0.5232	0.6775	0.1775	0.2254	0.2614
Percent of Total	47.9618	3.5958	5.7133	41.1869	39.9894	11.4545	3.9170	69.2421	37.5827	13.4800	4.6976	76.3703	30.1588	7.3521	11.8744	66.4833
Total ug/m ³	9.3730	6.5173	6.6340	0.7687	8.4058	7.8260	6.7876	1.1569	7.8999	7.7676	7.8287	1.3899	5.2549	5.1231	3.8985	0.7860
Total mg/sec	3.8531	2.9471	3.2127	0.3783	3.4945	3.6103	3.2356	0.5705	3.3465	3.6094	3.8076	0.6851	2.2466	2.4149	1.8985	0.3932

Axial Flow Check

Location <u>FRONT OUT</u>	Duct Ht, "		Barometric	<u>30.15</u>
Date <u>1/18/05</u>	Duct ID, "		Static	
Time <u>1530</u>	Duct Area	ft ²	Dry Bulb	
Tube I.D.	% O ₂		Wet Bulb	
C-Factor	% CO ₂		% H ₂ O	
Operator(s)	% N ₂		W.M.Wt	

PORT/ POINT	DISTANCE [" From Wall]	TEMP [°F]	DELTA P [" H ₂ O]	VELOCITY [Ft/Sec]	Null Angle
<u>South</u>					
	<u>1/3</u>	<u>710</u>	<u>0.32</u>		<u>-4.0</u>
	<u>1/2</u>	<u>718</u>	<u>0.47</u>		<u>-4.0</u>
	<u>Full (8-10")</u>	<u>718</u>	<u>0.930</u>		<u>-4.8</u>
<u>North</u>					
				<u>0.95</u>	
	<u>1/3</u>	<u>714</u>	<u>0.16</u>		
	<u>1/2</u>	<u>724</u>	<u>0.925</u>		<u>-4.1</u>
	<u>Full (8-10")</u>	<u>730</u>	<u>0.947</u>		<u>-5.1</u>
Average					
Maximum					
Minimum					
SDEV					

1
2
3

DATA SUMMARY	
Velocity, [fps]	
acfm	
scfm	
dscfm	
Ex Air Free cfm	
Est. MM Btu/hr Heat Input	
Est. Firing Rate, lb/hr	

@ Location

Make Box N-1

$\gamma = 0.987$

AH = 1.976

E-15 = 0.838


3/16 D = 0.181

K = 0.632

Axial Flow Check

Location <u>AHO</u>	Duct Ht, "	Barometric	
Date <u>1-19-05</u>	Duct ID, "	Static	
Time	Duct Area _____ ft ²	Dry Bulb	
Tube I.D.	% O ₂	Wet Bulb	
C-Factor	% CO ₂	% H ₂ O	
Operator(s)	% N ₂	W.M.Wt	

PORT/ POINT	DISTANCE [" From Wall]	TEMP [°F]	DELTA P [" H ₂ O]	VELOCITY [Ft/Sec]	Null Angle
A-1		299	0.72		
2		300	0.30		-8.2
3		300	0.32		
4		300	0.72		
B-1		292	0.79		
2		293	0.55		-8.2
3		293	0.50		
4		293	0.72		
C-1		271	0.92		
2		271	0.62		-8.3
3		271	0.42		
4		271	0.70		
D-1		256	0.65		
2		255	0.54		-8.3
3		256	0.27		
4		255	0.63		
Average					
Maximum					
Minimum					
SDEV					



DATA SUMMARY	
Velocity, [fps]	
acfm	
scfm	
dscfm	
Ex Air Free cfm	
Est. MM Btu/hr Heat Input	
Est. Firing Rate, lb/hr	

N=5
 γ = 1.01
 ΔH₀ = 2.015
 E = 0.846
 3/16 B = 0.188
 K = 0.93

Axial Flow Check

Location FGD IN Duct Ht, " _____ Barometric 30.15
 Date 1-18-05 Duct ID, " _____ Static _____
 Time _____ Duct Area _____ ft² Dry Bulb _____
 Tube I.D. 3-54 % O₂ _____ Wet Bulb _____
 C-Factor _____ % CO₂ _____ % H₂O _____
 Operator(s) _____ % N₂ _____ W.M.Wt _____

PORT/ POINT	DISTANCE [" From Wall]	TEMP [°F]	DELTA P [" H ₂ O]	VELOCITY [Ft/Sec]	Null Angle
8'		220	1.22	use this pt	
7'			1.57		
6'			1.27		
5'			1.15		
4'		263	0.90		
8'		277	0.12		
7'		275	0.14		
6'		276	0.15		
5'		276	0.08		
4'		276	?		
Average					
Maximum					
Minimum					
SDEV					

North

South

DATA SUMMARY	
Velocity, [fps]	
acfm	
scfm	
dscfm	
Ex Air Free cfm	
Est. MM Btu/hr Heat Input	
Est. Firing Rate, lb/hr	


N-4
 Y = 0.960
 ΔH@ = 1.983
~~E-5 = 0.832~~
 E-12 = 0.835
 3/16C = 0.193
 K = 1.04

Axial Flow Check

Location	Stack	Duct Ht, "		Barometric	30.15
Date	1-18-05	Duct ID, "		Static	-0.5603
Time	1445-1500	Duct Area	ft ²	Dry Bulb	
Tube I.D.	5-19.5-53	% O ₂		Wet Bulb	
C-Factor		% CO ₂		% H ₂ O	
Operator(s)	K.C., B.S.	% N ₂		W.M.Wt	

PORT/ POINT	DISTANCE [" From Wall]	TEMP [°F]	DELTA P [" H ₂ O]	VELOCITY [Ft/Sec]	Null Angle
A-1	10.0	123.3		.5466	
A-2	33.3	123.2		1.275	-.5054
A-3	67.5	122.5		1.427	
B-1	10	123.7		1.5092	
B-2	33.3	122.8		1.301	-.4255
B-3	67.5	124.0		1.413	
C-1	10	121.6		1.1729	+2" .7300
C-2	33.3	120.9		1.337	-.7538
C-3	67.5	122.8		1.292	
D-1	10	124.2		1.7002	
D-2	33.3	124.1		1.243	-.5564
D-3	67.5	123.2		1.268	
		123.025		1.04	
Average				1.056	
Maximum				(RMS)	
Minimum					
SDEV					

DATA SUMMARY	
Velocity, [fps]	
acfm	
scfm	
dscfm	
Ex Air Free cfm	
Est. MM Btu/hr Heat Input	
Est. Firing Rate, lb/hr	



N-3
 Y = 1.026
 ΔH@ = 1.982
 E-11 = 0.806
 7/8 A = 0.214
 K = 1.67

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	ECON- 1
PLANT	SCR/FGD Plant 4 -
LOCATION	Economizer Outlet #2
DATE	1/24/05
OPERATOR(S)	GLC/MLF
AMBIENT TEMP [°F]	60
BAR. PRESS. [in Hg]	29.92

METER BOX	N-1
PITOT TUBE DESC	
PROBE LENGTH [ft]	8'
NOZZLE ID [inch]	3/16" 0.191"
%H ₂ O (Assumed)	
FILTER ID	5
K FACTOR	0.632

CAL. DATA: delta H	1.976	Comments: _____
Y	0.987	
C(p)		_____
FILTER BOX SETTING	325	_____
PROBE HTR SETTING	325	_____
DUCT X-SECTION	circ ?	rect ? other: _____
DUCT DIMENSIONS	2@25"x14.5'	DUCT AREA 725 ft ²

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F] ①	PROBE TEMP [°F] ②	FILTER BOX [°F]	LAST IMP TEMP [°F] ④	METER EXHAUST		
								⑥ inlet	⑦ outlet					O ₂ [% vol]	CO ₂ [% vol]	
	1130	0					739.10								4.3	15.7
N		10		0.60	0.38	3.0	742.46	63	60	671	325		49	4.3	15.7	
O		20	-4.50	0.60	0.38	3.0	745.81	66	62	674	320		49	4.2	15.8	
R		30		0.60	0.38	3.5	749.18	69	64	675	320		51	4.2	15.8	
T		40	-4.20	0.60	0.38	4.0	752.56	71	65	675	320		52	4.3	15.7	
H		50		0.60	0.38	4.0	755.93	73	67	677	323		53	4.2	15.8	
		60		0.60	0.38	4.5	759.33	74	69	679	323		53	4.3	15.7	
Post Next H Leak Check OK - 0 @ 10" Hg																
	1241						759.45									
S		70		0.65	0.41	4.5	762.94	75	71	685	327		55	3.1	16.9	
O		80	-4.58	0.70	0.44	5.0	766.56	77	72	688	323		54	3.0	16.9	
U		90		0.70	0.44	6.0	770.22	78	73	687	322		56	2.8	17.1	
T		100	-4.43	0.70	0.44	6.5	773.86	79	74	689	318		56	2.9	17.0	
H		110		0.70	0.44	7.0	777.51	79	74	689	327		58	3.0	17.0	
		120		0.70	0.45	8.0	781.14	80	75	690	322		57	3.0	17.0	

AVERAGE			-4.4	0.647	0.408		41.92		71.3	681.6				3.6	16.4	

Sample Train Pre Test <u>0</u> ft ³ @ <u>10</u> in. Hg	Pitot Tube Pre Test <u>0</u> @ <u>6</u> in. H ₂ O
Leak Checks: Post Test <u>0</u> ft ³ @ <u>10</u> in. Hg	Leak Checks: Post Test <u>0</u> @ <u>5</u> in. H ₂ O



✓ NOTE: Purge for 10 minutes at end of sampling.

29.92

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	AHO- 1
PLANT	SCR/FGD Plant 4
LOCATION	Air Heater Outlet/ESP Inlet #2
DATE	1-24-05
OPERATOR(S)	JR LR TD
AMBIENT TEMP [°F]	42
BAR. PRESS. [in Hg]	29.92

METER BOX	NS
PITOT TUBE DESC	
PROBE LENGTH [ft]	10
NOZZLE ID [inch]	
%H ₂ O (Assumed)	8
FILTER ID	
K FACTOR	0.90

CAL. DATA: delta H	2.015	Comments:
Y	1.011	
C(p)		
FILTER BOX SETTING	325	
PROBE HTR SETTING	325	
DUCT X-SECTION	circ ?	rect ?
DUCT DIMENSIONS		other:

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST			
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]		
	11:30	0					31.765										
D-1	11:40	10		0.45	0.40	2.0	35.060	51	58	265	246	NSA	46				
D-1	11:50	20		0.44	0.39	2.0	34.320	55	58	266	248		43	6.3	13.8		
D-1	12:00	30		0.44	0.39	2.0	41.596	58	59	265	258		44	6.3	13.8		
							leak check OK @ 4" Hg										
	12:07	00					41.800										
C-1	12:17	00		0.60	0.54	2.5	45.1	53	59	279	303		50				
C-1	12:27	50	-12.57	0.58	0.52	2.5	49.29	61	60	281	307		46	4.9	15.2		
C-1	12:37	60		0.58	0.52	2.5	53.022	63	60	282	326		47	4.9	15.3		
							leak check OK @ 6" Hg										
	12:50	00					53.150										
B-1	13:00	00		0.70	0.63	2.5	57.23	62	62	299	313		51				
B-1	13:10	00	-13.15	0.70	0.63	3.0	61.31	65	63	299	320		46	4.4	15.7		
B-1	13:20	00		0.67	0.60	3.5	65.300	67	65	299	325		46	4.4	15.7		
							leak check OK @ 7" Hg										
	13:29	00					65.400										
A-1	13:39	100		0.43	0.39	2.0	68.67	66	67	291	326		55				
A-1	13:49	110	-12.95	0.40	0.36	2.0	71.86	69	68	302	329		52	5.0	15.1		
A-1	13:59	120		0.40	0.36	2.0	75.052	72	71	301	323		53	4.8	15.3		
AVERAGE			-12.97	0.527	0.478		42.855	62.4		285.8				5.1	14.15.0		



Sample Train Pre Test 0.000 ft³ @ 11 in. Hg
 Leak Checks: Post Test 0.000 ft³ @ 5 in. Hg

Pitot Tube Pre Test OK @ 9 in. H₂O
 Leak Checks: Post Test @ in. H₂O

NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID
PLANT
LOCATION
DATE
OPERATOR(S)
AMBIENT TEMP [°F]
BAR. PRESS. [in Hg]

STK - 2 TEST #1
SCR/FGD Plant 4
Stack
1-24-05
K.C., B.S.
~ 46.0
29.90

METER BOX
PITOT TUBE DESC
PROBE LENGTH [ft]
NOZZLE ID [inch]
%H₂O (Assumed)
FILTER ID
K FACTOR

N-3
E-11
108
7/32A
#1
1.59

CAL. DATA: delta H
Y
C(p)
FILTER BOX SETTING
PROBE HTR SETTING
DUCT X-SECTION
DUCT DIMENSIONS

1.982	Comments: _____		
1.026	_____		
325	_____		
250	_____		
circ ?	rect ?	other: _____	
19 ft ID	DUCT AREA	283.53 ft ²	

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	1130	0					808.30									
	-10.00	10		.70	1.10	3.5	813.79	69	66	127	253	328	49	5.9	14.2	
	-33.33	20	-.5832	1.00	1.59	4.5	820.27	74	67	127	257	331	52	5.9	14.2	
	-67.50	30		1.05	1.67	5	826.92	77	68	125	257	331	57	5.9	14.2	
				L.C. RESTART			827.03									
	-10.00	40		.70	1.10	3.5	832.51	76	69	125	226	320	51	6.0	14.1	
	-33.33	50	-.7267	1.00	1.59	4.5	839.02	78	70	125	235	325	47	5.9	14.2	
	-67.50	60		1.05	1.67	5	845.76	80	71	124	256	331	49	5.8	14.3	
				L.C. RESTART			845.90									
	-10.00	70		.73	1.15	3.5	851.48	78	72	125	226	325	49	6.0	14.1	
	-33.33	80	-.6246	1.05	1.67	5	858.02	81	73	125	250	330	51	5.8	14.3	
	-67.50	90		1.10	1.74	5	865.05	82	74	124	256	332	54	5.8	14.3	
				L.C. RESTART			865.15									
	-10.00	100		.70	1.10	3.5	870.68	80	74	124	253	329	52	6.0	14.1	
	-33.33	110	-.5543	1.00	1.59	5	877.21	81	74	124	252	329	54	5.9	14.2	
	-67.50	120		1.10	1.74	5	884.05	83	75	124	254	331	58	5.8	14.3	
	1345															
AVERAGE			-.062	0.924	1.48		75.400	74.7		124.9				5.9	14.2	

Sample Train Pre Test OK ft³ @ 10 in. Hg
Leak Checks: Post Test OK ft³ @ 10 in. Hg

Pitot Tube Pre Test OK @ 7 in. H₂O
Leak Checks: Post Test OK @ 7 in. H₂O



ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	ECON-2
PLANT	SCR/FGD Plant 4-42
LOCATION	Economizer Outlet
DATE	1/25/05
OPERATOR(S)	GC/MLF
AMBIENT TEMP [°F]	75
BAR. PRESS. [in Hg]	29.79

METER BOX	N-1
PITOT TUBE DESC	E-015
PROBE LENGTH [ft]	8'
NOZZLE ID [inch]	3/16" 0.191
%H ₂ O (Assumed)	
FILTER ID	7
K FACTOR	0.632

CAL. DATA: delta H	1.976	Comments:	
Y	0.987		
C(p)			
FILTER BOX SETTING	325		
PROBE HTR SETTING	325		
DUCT X-SECTION	circ ?	rect ?	other:
DUCT DIMENSIONS	2@25x14.5	DUCT AREA	725 ft ²

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	902	0					793.90									
S		10		0.66	0.42	3.0	797.46	70	66	673	324		68	3.5	16.5	
D		20	-4.47	0.65	0.41	3.0	800.95	72	66	675	326		67	3.6	16.4	
O		30		0.62	0.40	3.5	804.40	73	68	676	318		64	3.6	16.4	
T		40	-4.65	0.62	0.40	4.0	807.89	74	68	676	328		62	3.7	16.3	
H		50		0.62	0.40	4.5	811.35	74	69	676	318		61	3.6	16.4	
		60		0.62	0.40	5.0	814.84	75	70	676	320		61	3.6	16.4	
			POST-SOUTH / PRE-NORTH				LEAK CHECK OK		0 @ 10" Hg							
	1009						815.00									
N		70		0.50	0.32	3.0	818.16	76	72	669	318		62	4.5	15.6	
D		80	-4.72	0.50	0.32	3.5	821.29	77	72	671	326		60	4.6	15.5	
R		90		0.50	0.32	4.0	824.44	78	73	672	321		60	4.5	15.6	
T		100	-4.54	0.50	0.32	4.0	827.60	79	74	670	318		60	4.5	15.6	
H		110		0.50	0.32	4.5	830.76	80	75	671	320		59	4.5	15.5	
		120		0.50	0.32	5.0	833.92	80	75	671	321		59	4.6	15.5	
AVERAGE			-4.60	0.564	0.363		39.86	73.2		673				4.1	16.0	

Sample Train	Pre Test	0	ft ³	@	10	in. Hg	Pitot Tube	Pre Test	0	@	8	in. H ₂ O
Leak Checks:	Post Test	0	ft ³	@	10	in. Hg	Leak Checks:	Post Test	~0	@	6	in. H ₂ O



✓ NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID
PLANT
LOCATION
DATE
OPERATOR(S)
AMBIENT TEMP [°F]
BAR. PRESS. [in. Hg]

AHO- <u>2</u>
SCR/FGD Plant 4
Air Heater Outlet/ESP Inlet <u>#2</u>
<u>1-25-05</u>
<u>JL LR 00</u>
<u>29.72</u>

METER BOX	<u>N-5</u>
PITOT TUBE DESC	
PROBE LENGTH [ft]	<u>10</u>
NOZZLE ID [inch]	<u>0.188</u>
%H ₂ O (Assumed)	<u>3</u>
FILTER ID	<u>14</u>
K FACTOR	<u>0.40</u>

CAL. DATA: delta H	<u>29.5</u>
Y	<u>1.011</u>
C(p)	
FILTER BOX SETTING	325
PROBE HTR SETTING	325
DUCT X-SECTION	circ ? rect ? other: _____
DUCT DIMENSIONS	
DUCT AREA	

Comments: _____

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [in. H ₂ O]	PITOT HEAD [in. H ₂ O]	METER DIFF PRESSURE [in. H ₂ O]	METER VACUUM [in. Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	<u>0900</u>	<u>0</u>					<u>71.150</u>									
<u>A-1</u>	<u>0910</u>	<u>10</u>		<u>0.59</u>	<u>0.53</u>	<u>2.0</u>	<u>84.99</u>	<u>51</u>	<u>52</u>	<u>235</u>	<u>302</u>	<u>NA</u>	<u>41</u>	<u>5.0</u>	<u>14.7</u>	
<u>A-1</u>	<u>0920</u>	<u>20</u>	<u>-13.13</u>	<u>0.59</u>	<u>0.53</u>	<u>2.0</u>	<u>88.66</u>	<u>54</u>	<u>53</u>	<u>296</u>	<u>284</u>	<u>/</u>	<u>40</u>	<u>5.4</u>	<u>14.7</u>	
<u>A-1</u>	<u>0930</u>	<u>30</u>		<u>0.59</u>	<u>0.53</u>	<u>2.0</u>	<u>92.400</u>	<u>56</u>	<u>55</u>	<u>296</u>	<u>284</u>		<u>40</u>	<u>5.4</u>	<u>14.7</u>	
	<u>0935</u>	<u>40</u>					<u>92.500</u>									
	<u>0945</u>	<u>50</u>		<u>0.59</u>	<u>0.53</u>	<u>2.0</u>	<u>96</u>	<u>55</u>	<u>56</u>	<u>235</u>	<u>306</u>		<u>44</u>			
<u>B-1</u>	<u>0955</u>	<u>50</u>	<u>-13.50</u>	<u>0.59</u>	<u>0.53</u>	<u>2.5</u>	<u>99.93</u>	<u>58</u>	<u>57</u>	<u>294</u>	<u>311</u>		<u>41</u>	<u>4.6</u>	<u>15.5</u>	
<u>B-1</u>	<u>1005</u>	<u>60</u>		<u>0.59</u>	<u>0.53</u>	<u>2.5</u>	<u>103.653</u>	<u>60</u>	<u>58</u>	<u>294</u>	<u>304</u>		<u>42</u>	<u>4.6</u>	<u>15.5</u>	
	<u>1015</u>	<u>70</u>					<u>103.740</u>									
<u>C-1</u>	<u>1025</u>	<u>80</u>		<u>0.502</u>	<u>0.46</u>	<u>2.5</u>	<u>107.29</u>	<u>59</u>	<u>60</u>	<u>270</u>	<u>302</u>		<u>46</u>			
<u>C-1</u>	<u>1035</u>	<u>90</u>	<u>-13.10</u>	<u>0.50</u>	<u>0.45</u>	<u>2.5</u>	<u>110.765</u>	<u>60</u>	<u>61</u>	<u>276</u>	<u>309</u>		<u>44</u>	<u>5.0</u>	<u>15.1</u>	
<u>C-1</u>	<u>1045</u>	<u>100</u>		<u>0.47</u>	<u>0.42</u>	<u>2.5</u>	<u>114.245</u>	<u>62</u>	<u>61</u>	<u>277</u>	<u>312</u>		<u>44</u>	<u>4.9</u>	<u>15.2</u>	
	<u>1048</u>	<u>110</u>					<u>114.310</u>									
<u>D-1</u>	<u>1053</u>	<u>120</u>		<u>0.50</u>	<u>0.455</u>	<u>2.5</u>	<u>117.903</u>	<u>62</u>	<u>61</u>	<u>255</u>	<u>317</u>		<u>48</u>			
<u>D-1</u>	<u>1103</u>	<u>110</u>	<u>-13.48</u>	<u>0.47</u>	<u>0.47</u>	<u>2.5</u>	<u>121.31</u>	<u>63</u>	<u>63</u>	<u>263</u>	<u>319</u>		<u>46</u>	<u>6.2</u>	<u>14.0</u>	
<u>D-1</u>	<u>1118</u>	<u>120</u>		<u>0.47</u>	<u>0.42</u>	<u>2.5</u>	<u>124.714</u>	<u>64</u>	<u>63</u>	<u>264</u>	<u>314</u>		<u>46</u>	<u>6.2</u>	<u>14.0</u>	
															<u>5.3</u>	
AVERAGE			<u>-13.30</u>	<u>0.538</u>	<u>0.483</u>		<u>43.317</u>		<u>58.5</u>	<u>279.6</u>					<u>6.8</u>	<u>14.8</u>

Sample Train Pre Test 0.700 ft³ @ 10 in. Hg
Leak Checks: Post Test 0.620 ft³ @ 4.5 in. Hg

Pitot Tube Pre Test OK @ 9 in. H₂O
Leak Checks: Post Test OK @ 7 in. H₂O



NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

UNIT 2

TEST ID	FGD- 2
PLANT	SCR/FGD Plant 4
LOCATION	FGD Inlet
DATE	1/25/05
OPERATOR(S)	JAW
AMBIENT TEMP [°F]	55
BAR. PRESS. [in. Hg]	29.79

METER BOX	NY
PITOT TUBE DESC	J-54
PROBE LENGTH [ft]	6
NOZZLE ID [inch]	3/16 0.188
%H ₂ O (Assumed)	7.5
FILTER ID	2
K FACTOR	0.836 756 (S) (N)

CAL. DATA: delta H	1.983	Comments:	
Y	0.960		
C(p)	0.807		
FILTER BOX SETTING	325		
PROBE HTR SETTING	325		
DUCT X-SECTION	circ.?	rect?	other:
DUCT DIMENSIONS		DUCT AREA	

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [" H ₂ O]	PITOT HEAD [" H ₂ O]	METER DIFF PRESSURE [" H ₂ O]	METER VACUUM [" Hg]	METER READING ["]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	09:00	0					309.70									
South	09:10	10	8.4	1.17	1.05	4.0	315.35	65	58	150	323	325	43	5.5	14.6	
	09:20	20				4.0	320.92	72	62		323	325	43	5.5	14.6	
	09:30	30				4.0	326.47	77	63		324	325	46	5.4	14.7	
	09:40	40				4.0	332.08	79	65		329	325	47	5.4	14.7	
	09:50	50				4.0	337.68	80	66		324	325	48	5.5	14.6	
	10:00	60				4.0	343.29	82	68		325	325	49	5.5	14.6	
							(33.59)									
	10:15						343.60									
No. 14	10:25	70	8.9	0.78	0.59	2.5	347.96	76	69	276	329	325	47	6.0	14.1	
	10:35	80				2.5	352.23	79	70		328	325	47	6.0	14.1	
	10:45	90				2.5	356.52	81	71		328	325	47	6.0	14.1	
	10:55	100				2.5	360.77	82	72		323	325	48	6.1	14.0	
	11:05	110				2.5	365.02	83	73		324	325	49	6.0	14.1	
	11:15	120				2.5	369.26	83	74		328	326	49	6.0	14.1	
							(25.60)									
AVERAGE			8.65	0.965	0.82		59.25	72.9	713					5.74	14.36	

	Sample Train Pre Test <u>dead stop</u> @ <u>10</u> in. Hg	Pitot Tube Pre Test <u>NA</u> @ _____ in. H ₂ O
	Leak Checks: Post Test <u>dead stop</u> @ <u>10</u> in. Hg	Leak Checks: Post Test <u>NA</u> @ _____ in. H ₂ O

CONSOL ENERGY. post-test air purge for 10 min @ ΔT = 1.0

NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID
PLANT
LOCATION
DATE
OPERATOR(S)
AMBIENT TEMP [°F]
BAR. PRESS. [in Hg]

STK - 2 TEST # 2
SCR/FGD Plant 4
Stack
1-25-05
K.C. B.S.
~50°
29.72

METER BOX
PITOT TUBE DESC
PROBE LENGTH [ft]
NOZZLE ID [inch]
%H₂O (Assumed)
FILTER ID
K FACTOR

N-3
E-11
108
7/32A
#2
1.59

CAL. DATA: delta H
Y
C(p)
FILTER BOX SETTING
PROBE HTR SETTING
DUCT X-SECTION
DUCT DIMENSIONS

1.982
1.026
325
250
circ ?
19 ft ID
rect ?
other:
283.53 ft ²

Comments: _____

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	0900	0					889.90									
	-10.00	10		.70	1.10	3.5	895.40	69	66	127	253	329	49	6.2	13.9	
	-33.33	20	.7326	1.05	1.67	4.5	902.04	74	68	126	257	333	49	6.1	14.0	
	-67.50	30		1.10	1.72	5	908.83	77	69	126	258	333	49	6.1	14.0	
				L.C. RESTART			908.94									
	-10.00	40		.70	1.10	3.5	914.46	77	70	126	252	329	46	6.1	14.0	
	-33.33	50	.661	1.10	1.72	5	921.23	80	71	126	257	330	47	6.0	14.1	
	-67.50	60		1.15	1.80	5	928.22	81	72	124	253	331	49	6.0	14.1	
				L.C. RESTART			928.34									
	-10.00	70		.66	1.05	3	933.71	79	73	126	224	309	44	6.1	14.0	
	-33.33	80	.487	1.05	1.67	4.5	940.43	81	74	126	246	322	44	6.0	14.1	
	-67.50	90		1.10	1.72	5	947.23	83	74	124	256	329	46	6.0	14.1	
				L.C. RESTART			947.35									
	-10.00	100		.73	1.15	3.5	952.98	81	75	125	244	326	46	6.0	14.1	
	-33.33	110	.706	1.05	1.67	5	959.70	83	75	125	256	331	49	5.9	14.2	
	-67.50	120		1.10	1.72	5	966.53	84	76	124	255	330	51	5.9	14.2	
	1117															
AVERAGE			-0.647	0.948	1.508		76.28	75.5		125.4				6.0	14.1	

Sample Train Pre Test OK ft³ @ 10 in. Hg
Leak Checks: Post Test OK ft³ @ 10 in. Hg

Pitot Tube Pre Test OK @ 7 in. H₂O
Leak Checks: Post Test OK @ 7 in. H₂O



Unit #2

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	ECON-3
PLANT	SCR/FGD Plant 4 #2
LOCATION	Economizer Outlet
DATE	1/25/05
OPERATOR(S)	GIC/MLF
AMBIENT TEMP [°F]	75
BAR. PRESS. [in. Hg]	29.76

METER BOX	N-1
PITOT TUBE DESC	E-15 E-15
PROBE LENGTH [ft]	8'
NOZZLE ID [inch]	3/16 DIA, 0.911
%H ₂ O (Assumed)	
FILTER ID	6
K FACTOR	0.632

CAL DATA: delta H	1.976	Comments:	
Y	0.987		
C(p)			
FILTER BOX SETTING	325		
PROBE HTR SETTING	325		
DUCT X-SECTION	circ ?	rect ?	other:
DUCT DIMENSIONS	2@25'x14.5'	DUCT AREA	725 ft ²

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [in. H ₂ O]	PITOT HEAD [in. H ₂ O]	METER DIFF PRESSURE [in. H ₂ O]	METER VACUUM [in. Hg]	METER READING [in.]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	1255	0					838.70									
N		10		0.50	0.32	3.0	841.88	81	78	672	320		53	4.2	15.8	
O		20	-4.53	0.49	0.32	3.0	845.02	83	79	673	318		52	4.0	16.0	
R		30		0.49	0.32	3.5	848.16	84	80	673	322		52	4.0	16.0	
T		40		0.49	0.31	3.5	851.28	85	80	674	320		53	3.9	16.1	
H		50	-4.56	0.49	0.31	4.0	854.49	86	81	673	325		55	4.0	16.0	
		60		0.49	0.31	4.0	857.56	86	81	674	327		54	3.9	16.1	
POST-NORTH / PRE-SOUTH LEAK CHECK OK - 0 @ 110" Hg																
	1404						857.70									
S		70		0.70	0.44	4.0	861.38	87	83	676	327		52	3.2	16.8	
O		80	-4.77	0.68	0.43	5.0	865.04	88	83	676	328		50	3.1	16.9	
U		90		0.70	0.44	5.5	868.74	89	84	677	325		50	3.0	16.9	
T		100	-4.79	0.70	0.44	6.0	872.40	90	84	677	317		51	3.1	16.9	
H		110		0.70	0.44	6.5	876.11	90	85	675	318		51	3.0	16.9	
		120		0.70	0.44	7.5	879.78	91	86	677	328		52	3.1	16.9	
AVERAGE																
			-4.66	0.590	0.376		40.94	84.3		674.8				3.5	16.4	

Sample Train	Pre Test	0	ft ³	@	10	in. Hg	Pitot Tube	Pre Test	0	@	6	in. H ₂ O
Leak Checks:	Post Test	0	ft ³	@	10	in. Hg	Leak Checks:	Post Test	0	@	6	in. H ₂ O



✓ NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	AHO-3
PLANT	SCR/FGD Plant 4
LOCATION	Air Heater Outlet/ESP Inlet #2
DATE	1-25-05
OPERATOR(S)	JL LR DJ
AMBIENT TEMP [°F]	
BAR. PRESS. [in Hg]	29.76

METER BOX	N-5
PITOT TUBE DESC	
PROBE LENGTH [ft]	10
NOZZLE ID [inch]	0.138 3/16"
%H ₂ O (Assumed)	8
FILTER ID	15
K FACTOR	0.90

CAL. DATA: delta H	2.015	Comments: _____
Y	1.011	
C(p)		_____
FILTER BOX SETTING	325	_____
PROBE HTR SETTING	325	_____
DUCT X-SECTION	circ ?	rect ? other: _____
DUCT DIMENSIONS		DUCT AREA _____

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ²]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	1255	0					129.148									
D-1	1305	10		0.50	0.45	2.0	132.72	65	68	265	326	NA	67			
D-1	1315	20	-13.07	0.43	0.43	2.0	136.15	69	69	264	324		52	5.7	14.4	
D-1	1325	30		0.50	0.45	2.0	139.79	71	71	264	305		52	6.1	14.0	
	1337	50					137.770									
C-1	1340	40		0.85	0.76	3.0	144.15	74	74	274	312		55			
C-1	1350	50	-13.35	0.85	0.74	3.5	148.75	76	74	279	304		52	4.9	15.2	
C-1	1400	60		0.85	0.76	4.0	153.238	77	73	279	301		53	4.3	15.3	
	1407	70					153.350									
B-1	1417	80		0.82	0.73	3.5	157.85	77	77	290	305		57			
B-1	1427	90	-13.5	0.80	0.72	4.0	162.23	81	78	297	292		54	4.8	15.3	
B-1	1437	100		0.80	0.72	4.5	166.821	83	80	297	286		53	4.9	15.2	
	1442	110					166.930									
A-1	1452	120		0.62	0.56	3.0	170.905	84	81	302	305		57			
A-1	1502	110		0.56	0.50	3.0	174.680	84	80	302	314		57	5.5	14.7	
A-1	1512	120		0.58	0.52	3.0	178.645	83	78	302	310		57	5.4	14.7	
AVERAGE			-13.31	0.676	0.613		49.146	76.3		284.6				5.3	14.9	

Sample Train Pre Test 0.000 ft³ @ 10 in. Hg
 Leak Checks: Post Test 0.000 ft³ @ 5 in. Hg

Pitot Tube Pre Test OK @ 7 in. H₂O
 Leak Checks: Post Test OK @ 6 in. H₂O



NOTE: Purge for 10 minutes at end of sampling.

0

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

UNIT 2

TEST ID	FGD-3
PLANT	SCR/FGD Plant 4
LOCATION	FGD Inlet
DATE	1/25/05
OPERATOR(S)	JAW
AMBIENT TEMP [°F]	
BAR. PRESS. [in. Hg]	29.75

METER BOX	N4
PITOT TUBE DESC	S-54
PROBE LENGTH [ft]	6
NOZZLE ID [in. ch]	3/16 0.1875
%H ₂ O (Assumed)	7.5
FILTER ID	3
K FACTOR	0.828 0.824

(N) (S)

CAL. DATA: delta H	1.983
Y	0.960
C(p)	0.807
FILTER BOX SETTING	325
PROBE HTR SETTING	325
DUCT X-SECTION	circ ? rect ? other:
DUCT DIMENSIONS	DUCT AREA

Comments: _____

TRAVERSE POINT [port-inch]	CLOCK TIME [24-hr]	SAMPLE TIME [minute]	STATIC PRES [" H ₂ O]	PITOT HEAD [" H ₂ O]	METER DIFF PRESSURE [" H ₂ O]	METER VACUUM [" Hg]	METER READING [ft ²]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	12:55	0					375.00									
No.4	13:05	10	9.2	0.79	0.65	2.0	379.56	78	74	284	323	325	57	6.0	14.1	
	13:15	20				2.0	384.06	84	75		329	325	52	5.9	14.2	
	13:25	30				2.0	388.59	86	77		327	326	54	5.8	14.3	
	13:35	40				2.0	393.09	87	78		328	325	57	5.8	14.3	
	13:45	50				2.0	397.62	88	78		328	325	53	5.9	14.2	
	13:55	60				2.0	402.14	89	79		327	324	54	5.9	14.2	
							(27.19)									
	14:15						402.40									
Soupt	14:25	70	8.8	0.12	0.92	2.5	407.68	87	80	305	328	325	55	5.4	14.7	
	14:35	80				2.5	413.01	90	80		327	326	51	5.4	14.7	
	14:45	90				2.5	418.32	92	81		323	325	52	5.4	14.7	
	14:55	100				2.5	423.63	93	82		326	321	52	5.4	14.7	
	15:05	110				2.5	429.00	94	83		326	325	53	5.4	14.7	
	15:15	120				2.5	434.36	95	84		324	325	54	5.3	14.8	
							(31.96)									
AVERAGE			9.0	0.998	0.785		59.10		83.9	299.5				5.63	14.47	

Sample Train	Pre Test	Leak Checks:	Post Test	Pitot Tube	Pre Test	Leak Checks:	Post Test
	lead shop ft ² @ 10 in. Hg		lead shop ft ² @ 10 in. Hg		NA @ _____ in. H ₂ O		NA @ _____ in. H ₂ O



post-test air purge for 10 min @ ΔH=1.0

NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID
PLANT
LOCATION
DATE
OPERATOR(S)
AMBIENT TEMP [°F]
BAR. PRESS. [in Hg]

STK-2 TEST #3
SCR/FGD Plant 4
Stack
1-25-05
K.C., B.S.
~60°
29.76

METER BOX	N-3
PITOT TUBE DESC	E-11
PROBE LENGTH [ft]	108
NOZZLE ID [inch]	7/32A
%H ₂ O (Assumed)	
FILTER ID	#3
K FACTOR	1.59

CAL. DATA: delta H	1.982		
Y	1.026		
C(p)			
FILTER BOX SETTING	325		
PROBE HTR SETTING	250		
DUCT X-SECTION	circ ?	rect ?	other: _____
DUCT DIMENSIONS	19 ft ID	DUCT AREA	283.53 ft ²

Comments: _____

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	1255	0					972.40									
		10		.70	1.10	3.5	977.96	76	74	127	257	329	46	6.0	14.1	
		20	-.482	1.10	1.72	5	984.74	80	74	126	251	331	46	5.9	14.2	
		30		1.15	1.80	5	991.76	83	75	125	256	329	49	5.8	14.3	
				L.C. RESTART			991.90									
		40		.73	1.15	3.5	997.58	82	75	126	229	316	46	6.0	14.1	
		50	-.445	1.10	1.72	5	1004.36	84	76	125	252	329	44	5.9	14.2	
		60		1.15	1.80	5	1011.36	86	77	123	254	331	46	5.9	14.2	
				L.C. RESTART			1011.49									
		70		.76	1.20	4	1017.23	83	77	124	254	327	43	6.3	13.8	
		80	-.636	1.10	1.72	5	1024.06	82	77	123	251	328	39	6.3	13.8	
		90		1.15	1.80	5	1031.07	84	78	124	256	330	41	6.2	13.9	
				L.C. RESTART			1031.20									
		100		.76	1.20	4	1037.00	84	80	125	252	329	46	6.2	13.9	
		110	-.519	1.10	1.72	5	1043.82	87	80	125	248	329	46	6.0	14.1	
		120		1.15	1.80	5	1050.84	89	81	125	250	332	46	6.0	14.1	
	1533															
AVERAGE			-.0521	0.987	1.561		78.04	80.2		124.8				6.0	14.1	

Sample Train	Pre Test	OK ft ³ @ 10 in. Hg	Pitot Tube	PreTest	OK @ 7 in. H ₂ O
Leak Checks:	Post Test	OK ft ³ @ 10 in. Hg	Leak Checks:	Post Test	OK @ 7 in. H ₂ O



NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	ECON-4
PLANT	SCR/FGD Plant 4-#2
LOCATION	Economizer Outlet
DATE	1/26/05
OPERATOR(S)	GLC/MLF
AMBIENT TEMP [°F]	75
BAR. PRESS. [in. Hg]	29.73

METER BOX	N-1
PITOT TUBE DESC	E-15
PROBE LENGTH [ft]	8'
NOZZLE ID [inch]	3/16" DIA, 0.191"
%H ₂ O (Assumed)	
FILTER ID	B
K FACTOR	0.632

CAL. DATA: delta H	1.976	Comments: _____
Y	0.987	
C(p)		_____
FILTER BOX SETTING	325	_____
PROBE HTR SETTING	325	_____
DUCT X-SECTION	circ ?	rect ? other: _____
DUCT DIMENSIONS	2@25'x14.5'	DUCT AREA 725 ft ²

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in. H ₂ O]	PITOT HEAD [in. H ₂ O]	METER DIFF PRESSURE [in. H ₂ O]	METER VACUUM [in. Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST			
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]		
	837	0					387.10										
S		10		0.64	0.40	3.0	890.59	79	76	691	325		65	3.8	16.2		
O		20	-4.43	0.64	0.40	3.0	894.07	81	77	691	325		65	3.7	16.3		
U		30		0.64	0.40	3.5	897.57	83	78	691	323		65	3.8	16.2		
T		40	-4.50	0.62	0.39	4.0	901.04	85	79	691	320		64	3.7	16.3		
H		50		0.64	0.40	4.5	904.55	86	81	691	320		63	3.7	16.3		
		60		0.64	0.40	5.0	908.09	87	81	691	326		63	3.7	16.3		
				Post-South / PRE-NORTH LEAK CHECK OK - 0.010 in. Hg													
	944						908.30										
N		70		0.50	0.32	3.0	911.49	87	83	684	322		67	4.5	15.6		
O		80	-4.34	0.50	0.32	4.0	914.69	88	83	684	323		63	4.4	15.7		
R		90		0.50	0.32	4.0	917.88	89	84	684	317		64	4.3	15.8		
T		100	-4.69	0.50	0.32	4.5	921.08	90	85	685	320		64	4.4	15.7		
H		110		0.50	0.32	5.0	924.27	90	86	687	326		65	4.3	15.8		
		120		0.50	0.32	5.0	927.48	91	86	686	317		65	4.3	15.8		
							<u>927.48</u>										
AVERAGE			-4.47	0.566	0.359		90.17	84.0		688				4.1	16.0		

Sample Train	Pre Test	40.02 ft ³	@	10	in. Hg	Pitot Tube	Pre Test	0	@	5	in. H ₂ O	
Leak Checks:	Post Test	0	ft ³	@	10	in. Hg	Leak Checks:	Post Test	0	@	5	in. H ₂ O



✓ NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID	AHO-4	METER BOX	N-5	CAL. DATA: delta H	2.015	Comments:
PLANT	SCR/FGD Plant 4	PITOT TUBE DESC		Y	1.211	
LOCATION	Air Heater Outlet/ESP Inlet <i>B2</i>	PROBE LENGTH [ft]	6	C(p)		
DATE	1-24-05	NOZZLE ID [inch]	0.138	FILTER BOX SETTING	325	
OPERATOR(S)	JL LR DJ	%H ₂ O (Assumed)		PROBE HTR SETTING	325	
AMBIENT TEMP [°F]	29.73	FILTER ID	16	DUCT X-SECTION	circ ? rect ? other: _____	
BAR. PRESS. [in. Hg]		K FACTOR	0.020	DUCT DIMENSIONS	DUCT AREA _____	

85.9

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in. H ₂ O]	PITOT HEAD [in. H ₂ O]	METER DIFF PRESSURE [in. H ₂ O]	METER VACUUM [in. Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	835	0					187.100									
A-1	845	10		0.50	0.45	2.0	187.525	57	58	302	293	47NA	47	5.4	14.7	
A-1	855	20	-13.20	0.49	0.44	2.0	190.892	57	58	302	293		47	5.4	14.9	
A-1	905	30		0.47	0.42	2.0	174.345	59	60	304	291		47			
							<i>leak check OK @ 5 in Hg</i>									
	0910	30					194.600									
B-1	920	40		0.77	0.69	3.5	198.845	61	63	287	294		51	4.6	15.6	
B-1	930	50		0.80	0.72	4.0	203.145	65	65	301	289		49	4.5	15.6	
B-1	940	60		0.77	0.69	4.5	207.652	67	66	301	295		49	4.5	15.6	
							<i>leak check OK @ 6 in Hg</i>									
	946	70					207.800									
C-1	956	80		0.82	0.73	4.0	212.214	68	68	278	313		52			
C-1	1006	90	-13.34	0.82	0.73	5.0	216.61	70	69	284	283		49	4.6	15.5	
C-1	1016	100		0.82	0.73	5.0	221.028	71	70	285	281		52	4.6	15.5	
							<i>leak check OK @ 7 in Hg</i>									
	1022	110					221.300									
D-1	1032	100		0.45	0.41	2.5	224.73	71	71	270	288		55	5.8	14.3	
D-1	1042	110		0.45	0.41	3.0	228.07	72	71	270	280		54	5.8	14.3	
D-1	1052	120	-13.53	0.45	0.41	3.0	231.526	72	72	270	284		54	5.8	14.3	
AVERAGE			-13.37	0.623	0.569		46.751	65.9		287.8				5.1	15.0	

Sample Train	Pre Test	0.000	ft ³ @	10	in. Hg	Pitot Tube	PreTest	OK	@	7	in. H ₂ O
Leak Checks:	Post Test	0.000	ft ³ @	7	in. Hg	Leak Checks:	Post Test	OK	@	7	in. H ₂ O



NOTE: Purge for 10 minutes at end of sampling.

CO

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

UNIT 2

TEST ID	FGD- 4
PLANT	SCR/FGD Plant 4
LOCATION	FGD Inlet
DATE	1/26/05
OPERATOR(S)	JAW
AMBIENT TEMP [°F]	60
BAR. PRESS. [in Hg]	29.73

METER BOX	N 4
PITOT TUBE DESC	S-54
PROBE LENGTH [ft]	6
NOZZLE ID [inch]	3/16 0.1875
%H ₂ O (Assumed)	7.0
FILTER ID	4
K FACTOR	0.805 0.848 (5)

CAL. DATA: delta H	1.983	Comments:	
Y	0.960		
C(p)	0.807		
FILTER BOX SETTING	325		
PROBE HTR SETTING	325		
DUCT X-SECTION	circ ?	rect ?	other:
DUCT DIMENSIONS		DUCT AREA	

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	08:35	0					441.00									
South	08:45	10	8.3	1.17	0.94	3.0	446.38	71	65	305	325	327	47	5.5	14.6	
	08:55	20				3.0	451.76	78	67	<	326	326	47	5.4	14.7	
	09:05	30				3.0	457.14	83	69		328	325	51	5.4	14.7	
	09:15	40				3.0	462.51	86	72		324	325	52	5.4	14.7	
	09:25	50				3.0	467.96	87	74		328	325	49	5.4	14.7	
	09:35	60				3.0	473.36	89	76		324	326	50	5.4	14.7	
							322.36									
North	09:55						473.60									
	10:05	70	8.6	0.82	0.70	3.0	478.44	84	78	285	321	325	48	6.2	13.9	
	10:15	80				2.5	483.16	88	78	?	329	324	46	6.0	14.1	
	10:25	90				2.5	487.95	90	80		329	325	47	6.1	14.0	
	10:35	100				2.5	492.73	90	80		327	326	49	6.0	14.1	
	10:45	110				2.5	497.49	91	81		323	325	49	6.0	14.1	
	10:55	120				2.5	502.24	92	81		323	326	49	5.9	14.2	
							28.64									
AVERAGE			8.45	0.987	0.82		61.00		80.4	295				5.73	14.38	

Sample Train	Pre Test	dead stop ³ @ 10 in. Hg	Pitot Tube	Pre Test	NA @ _____ in. H ₂ O
Leak Checks:	Post Test	dead stop ³ @ 10 in. Hg	Leak Checks:	Post Test	NA @ _____ in. H ₂ O



Air-purge for 10 min @ ΔH=1.0

NOTE: Purge for 10 minutes at end of sampling.

ONTARIO HYDRO Hg SAMPLING AND SPECIATION FIELD DATA SHEET

TEST ID
PLANT
LOCATION
DATE
OPERATOR(S)
AMBIENT TEMP [°F]
BAR. PRESS. [in Hg]

STK-2 TEST #4
SCR/FGD Plant 4
Stack
1-26-05
K.C. B.S.
~54°
29.73

METER BOX	N-3
PITOT TUBE DESC	E-11
PROBE LENGTH [ft]	1/8
NOZZLE ID [inch]	7/32 A
%H ₂ O (Assumed)	
FILTER ID	#4
K FACTOR	1.59

CAL. DATA: delta H	1.982		
Y	1.026		
C(p)			
FILTER BOX SETTING	325		
PROBE HTR SETTING	250		
DUCT X-SECTION	circ ?	rect ?	other:
DUCT DIMENSIONS	19 ft ID	DUCT AREA	283.53 ft ²

Comments: _____

TRAVERSE POINT [port-inch]	CLOCK TIME (24-hr)	SAMPLE TIME [minute]	STATIC PRES [in H ₂ O]	PITOT HEAD [in H ₂ O]	METER DIFF PRESSURE [in H ₂ O]	METER VACUUM [in Hg]	METER READING [ft ³]	METER TEMP [°F]		STACK TEMP [°F]	PROBE TEMP [°F]	FILTER BOX [°F]	LAST IMP TEMP [°F]	METER EXHAUST		
								inlet	outlet					O ₂ [% vol]	CO ₂ [% vol]	
	0835	0					056.80									
-10.00		10		.76	1.20	3.5	062.56	69	66	126	221	240	55	6.1	14.0	
-33.33		20	-.742	1.10	1.72	4.5	069.34	73	68	125	244	291	49	5.9	14.2	
-67.50		30		1.15	1.80	5	076.27	75	69	125	259	317	47	5.9	14.2	
				L.C. RESTART			076.40									
-10.00		40		.76	1.20	3.5	082.12	74	70	127	255	328	46	6.1	14.0	
-33.33		50	-.809	1.10	1.72	5	088.93	78	71	127	258	333	49	6.1	14.0	
-67.50		60		1.15	1.80	5	095.92	80	72	127	250	332	50	6.0	14.1	
				L.C. RESTART			096.05									
-10.00		70		.82	1.30	5	102.00	81	74	128	255	329	50	6.1	14.0	
-33.33		80	-.650	1.10	1.72	5	108.88	83	75	126	257	331	44	6.0	14.1	
-67.50		90		1.15	1.80	5	115.91	85	76	127	258	333	44	6.0	14.1	
				L.C. RESTART			116.04									
-10.00		100		.76	1.20	4	121.84	83	76	126	251	327	44	6.0	14.1	
-33.33		110	-.635	1.10	1.72	5	128.67	86	78	127	256	330	46	5.9	14.2	
-67.50		120		1.15	1.80	5	135.70	86	78	127	256	330	47	5.9	14.2	
	1057															

AVERAGE		-0.709	1.001	1.582		78.51	76.1	126.5					6.0	14.1
Sample Train	Pre Test	OK ft ³ @ 10 in. Hg				Pitot Tube	Pre Test	OK @ 7 in. H ₂ O						
Leak Checks:	Post Test	OK ft ³ @ 10 in. Hg				Leak Checks:	Post Test	OK @ 7 in. H ₂ O						



NOTE: Purge for 10 minutes at end of sampling.

SCR/FGD Hg SAMPLING PROGRAM, PLANT 4 - ONTARIO HYDRO SAMPLING TRAIN DATA

Location	Econ Out		AirHr Out		FGD Inlet		Stack		Econ Out		AirHr Out		FGD Inlet		Stack		Econ Out		AirHr Out		FGD Inlet		Stack	
	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2	Unit 1	Unit 2
Date	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005	01/24/2005
Start Time	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130	1130
Stop Time	1341	1359	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345	1345
Test Number	ECON-1	AHO-1	FGD-1	STK-1	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg
Sample Type	OH-Hg	AHO-1	FGD-1	STK-1	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg	OH-Hg
Y factor of dry gas meter	0.987	1.010	0.987	1.010	0.987	1.010	0.987	1.010	0.987	1.010	0.987	1.010	0.987	1.010	0.987	1.010	0.987	1.010	0.987	1.010	0.987	1.010	0.987	1.010
Gas Volume	41.92	42.86	64.18	75.40	39.86	43.32	59.25	68.28	76.28	40.94	49.15	59.10	78.04	40.17	46.75	61.00	61.00	40.17	46.75	61.00	61.00	40.17	46.75	61.00
Delta H of dry gas meter	0.41	0.48	0.97	1.48	0.36	0.46	0.82	1.51	1.51	0.38	0.61	0.79	1.56	0.36	0.57	0.82	0.82	0.36	0.57	0.82	0.82	0.36	0.57	0.82
Meter Temperature	71.3	62.4	71.8	74.7	58.5	58.5	72.9	75.5	75.5	84.3	76.3	83.9	80.2	84.0	65.9	80.4	80.4	84.0	65.9	80.4	80.4	84.0	65.9	80.4
C Factor of pitot tube	0.838	0.846	0.835	0.846	0.838	0.846	0.835	0.846	0.835	0.838	0.846	0.835	0.846	0.838	0.846	0.835	0.846	0.838	0.846	0.835	0.846	0.838	0.846	0.835
Nozzle Diameter	0.191	0.188	0.185	0.214	0.191	0.188	0.185	0.214	0.191	0.191	0.188	0.185	0.214	0.191	0.188	0.185	0.214	0.191	0.188	0.185	0.214	0.191	0.188	0.185
A n (area of nozzle)	0.0020	0.0019	0.0019	0.0025	0.0020	0.0019	0.0019	0.0025	0.0025	0.0020	0.0019	0.0019	0.0025	0.0020	0.0019	0.0019	0.0025	0.0025	0.0020	0.0019	0.0019	0.0025	0.0020	0.0019
Area of Stack (Single of Dual)	725.0	544.4	283.5	338.1	725.0	544.4	283.5	338.1	283.5	72.7	87.3	98.3	245.8	72.7	85.9	105.4	105.4	72.7	85.9	105.4	105.4	72.7	85.9	105.4
H ₂ O Weight	78.1	75.6	99.0	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120
Sample Time	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120	120
Barometric Pressure	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92	29.92
Static Pressure	-4.40	-12.97	8.50	-0.62	-4.60	-13.30	8.65	-0.65	-0.65	-4.66	-13.31	9.00	-0.52	-4.49	-13.37	8.45	8.45	-4.49	-13.37	8.45	8.45	-13.37	8.45	-0.71
% Oxygen	3.6	5.1	5.6	5.9	4.1	5.3	5.7	6.0	6.0	3.5	5.3	5.6	6.0	4.1	5.1	5.7	5.7	6.0	4.1	5.1	5.7	6.0	6.0	6.0
% Carbon Dioxide	16.4	15.0	14.5	14.2	16.4	14.8	14.4	14.1	14.1	16.4	14.9	14.5	14.1	14.1	16.0	15.0	14.4	14.1	16.0	15.0	14.4	14.1	14.1	14.1
% N ₂ + CO	80.0	79.9	80.0	79.9	79.9	79.9	79.9	79.9	79.9	80.1	79.8	79.9	79.9	79.9	79.9	79.9	79.9	79.9	79.9	79.9	79.9	79.9	79.9	79.9
Stack Temp (Dry Bulb)	682	286	673	280	673	280	213	125	125	675	285	285	125	688	288	295	295	688	288	295	295	688	288	295
Stack Temp (Wet Bulb)	0.647	0.527	1.000	0.924	0.564	0.538	0.965	0.948	0.948	0.590	0.676	0.948	0.987	0.566	0.623	0.987	0.987	0.566	0.623	0.987	0.987	0.566	0.623	0.987
"S" sample (rms vel head)	5.4040	1.1700	0.0005	0.0000	5.3822	2.3936	0.0001	0.0005	0.0005	5.6953	2.7024	0.0011	0.0081	6.0508	5.0822	0.0002	0.0002	6.0508	5.0822	0.0002	0.0002	6.0508	5.0822	0.0002
Dust WL	41.14	43.78	61.29	76.64	38.81	44.39	56.20	77.09	77.09	39.01	48.86	54.87	78.11	38.26	47.15	56.95	56.95	38.26	47.15	56.95	56.95	38.26	47.15	56.95
Sample Volume	1.165	1.240	1.736	2.170	1.099	1.257	1.592	2.183	2.183	1.105	1.378	1.554	2.212	1.083	1.613	2.340	2.340	1.083	1.613	2.340	2.340	1.083	1.613	2.340
ABS ST PRES	29.60	28.97	30.55	29.87	29.45	28.81	30.43	29.74	29.74	29.42	28.78	30.42	29.72	29.40	28.75	30.35	30.35	29.40	28.75	30.35	30.35	29.40	28.75	30.35
ABS ST TEMP	11.42	7.46	6.79	5.85	11.33	7.40	6.73	5.85	5.85	11.35	7.45	6.75	5.85	11.48	7.48	7.55	7.55	11.48	7.48	7.55	7.55	11.48	7.48	7.55
H ₂ O - % by Vol	8.2	7.5	7.1	12.3	9.2	7.1	7.1	12.6	12.6	8.7	7.8	7.8	12.9	8.7	7.9	8.0	8.0	8.7	7.9	8.0	8.0	8.7	7.9	8.0
Water Volume	3.56	3.56	4.66	11.21	3.94	3.41	4.22	11.11	11.11	3.71	4.11	4.63	11.58	3.65	4.05	4.96	4.96	3.71	4.05	4.96	4.96	3.71	4.05	4.96
Dry Molecular Weight	30.77	30.60	30.54	30.51	30.72	30.58	30.53	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50	30.50
Wet Molecular Weight	29.72	29.66	29.65	28.91	29.55	29.68	29.66	28.92	28.92	29.66	29.66	29.66	28.92	29.66	29.62	29.61	29.61	29.66	29.62	29.61	29.61	29.66	29.62	29.61
% EXCESS AIR	20.5	31.9	36.1	38.8	24.1	33.6	37.0	39.8	39.8	19.8	33.6	36.1	39.8	24.1	31.9	37.0	37.0	33.6	31.9	37.0	37.0	33.6	31.9	37.0
Dry Mole Frac.	0.918	0.925	0.929	0.872	0.908	0.929	0.930	0.874	0.874	0.913	0.922	0.922	0.871	0.913	0.921	0.920	0.920	0.913	0.921	0.920	0.920	0.913	0.921	0.920
Wet Mole Frac.	0.082	0.075	0.071	0.128	0.092	0.071	0.070	0.126	0.126	0.087	0.078	0.078	0.129	0.087	0.079	0.080	0.080	0.087	0.079	0.080	0.080	0.087	0.079	0.080
Gas Velocity, Direct	65.65	48.92	61.81	76.64	61.39	49.33	60.56	77.09	77.09	62.76	55.58	63.66	78.11	61.89	53.51	65.09	65.09	61.89	53.51	65.09	65.09	61.89	53.51	65.09
ACFM	2,855,699	1,598,087	1,012,944	1,012,944	1,112,000	1,028,839	1,028,839	1,027,702	1,027,702	1,140,529	1,141,944	1,141,944	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529
DSCFM	1,199,300	1,012,900	1,025,100	1,025,100	1,112,000	1,028,800	1,028,800	1,027,700	1,027,700	1,140,529	1,141,944	1,141,944	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529	1,140,529
DSCFM (rounded)	33,964	28,687	28,687	28,687	31,492	29,137	29,137	29,105	29,105	32,300	32,340	32,340	29,384	31,457	30,927	30,927	30,927	31,457	30,927	30,927	30,927	31,457	30,927	30,927
Excess Air Free DSCFM	992,704	765,766	741,533	735,751	893,847	767,937	748,246	732,668	732,668	949,531	852,360	852,360	739,967	892,880	825,564	794,233	794,233	825,564	794,233	794,233	825,564	794,233	794,233	825,564
CALCULATED FIRING RATE:																								
Dry	7,413	5,719	5,538	5,494	6,758	5,806	5,657	5,539	5,539	7,179	6,444	6,444	5,594	6,669	6,167	5,932	5,932	6,669	6,167	5,932	5,932	6,669	6,167	5,932
Wet	7,552	5,825	5,641	5,597	6,860	5,894	5,742	5,623	5,623	7,287	6,542	6,542	5,679	6,778	6,268	6,030	6,030	6,778	6,268	6,030	6,030	6,778	6,268	6,030
Dry	444,799	343,115	332,257	329,666	405,461	348,246	339,414	332,248	332,248	430,720	386,642	379,206	335,659	400,156	369,997	355,946	355,946	400,156	369,997	355,946	355,946	400,156	369,997	355,946
Wet	453,090																							

Impinger Components Wts & Volumes	ECON-1	AHO-1	FGD-1	STK-1	ECON-2	AHO-2	FGD-2	STK-2	ECON-3	AHO-3	FGD-3	STK-3	ECON-4	AHO-4	FGD-4	STK-4
Filter Wt, g	5.4040	1.1700	0.0005	0.3278	5.3862	2.3896	0.0001	0.3375	5.6593	2.7024	0.0011	0.3303	6.0508	5.5082	0.0002	0.3297
ppb Hg	17	283	<5.0	<5.0	15	653	<5.0	<5.0	16	314	<5.0	<5.0	19	379	<5.0	<5.0
total ug	0.09	0.33	<5.00E-03	<5.00E-03	0.08	1.57	<5.00E-03	<5.00E-03	0.09	0.85	<5.00E-03	<5.00E-03	0.11	2.09	<5.00E-03	<5.00E-03
ug/dscm	0.08	0.27	<2.88E-03	<2.30E-03	0.07	1.25	<3.14E-03	<2.29E-03	0.08	0.82	<3.22E-03	<2.26E-03	0.11	1.56	<3.10E-03	<2.23E-03
Probe Rinse volume, ml	182	160	108	109	170	126	101	100	198	123	95	117	166	128	104	116
Analytical Hg, ng/ml	<1.0	1.6	1.5	1.7	<1.0	1.1	<1.0	1.7	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	1.9
ug/dscm	<0.16	0.21	0.09	0.09	<0.15	0.11	<0.06	0.08	<0.18	<0.09	<0.06	<0.05	<0.15	<0.10	<0.06	0.10
Heated Umbilical Line Rinse volume, ml	121	148	109	NA	98	209	89	NA	106	130	121	NA	88	129	88	NA
Analytical Hg, ng/ml	1.7	2.5	<1.0	2.1	3.5	1.5	2.1	2.1	1.3	1.1	2.6	2.6	2.2	2.2	2.6	1.4
ug/dscm	0.18	0.30	<0.06	0.31	0.31	0.25	0.12	0.20	0.12	0.10	0.20	0.20	0.18	0.25	0.08	0.08
KCl volume, ml	523	524	544	672	539	523	535	672	525	529	543	687	522	532	550	698
Analytical Hg, ng/ml	12.1	15.3	22.4	<0.4	11.5	14.3	23.0	0.9	11.9	16.6	21.7	<0.2	8.8	12.3	18.2	<0.2
ug/dscm	5.43	6.47	7.02	<0.12	5.64	5.95	7.73	0.28	5.66	6.37	7.58	<0.06	4.24	4.90	6.21	<0.06
Nitric Peroxide volume, ml	175	175	175	182	175	175	177	183	176	176	175	176	175	175	175	175
Analytical Hg, ng/ml	2.7	<0.2	<0.2	<0.2	0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	0.3	<0.2	<0.2	<0.2
ug/dscm	0.41	<0.03	<0.02	<0.02	0.03	<0.03	<0.02	<0.02	<0.03	<0.03	<0.02	<0.02	0.05	<0.03	<0.02	<0.02
KMnO4 volume, ml	247	246	247	244	246	244	245	245	248	250	248	247	249	247	247	247
Analytical Hg, ng/ml	19.3	<0.2	<0.2	0.9	19.8	0.4	0.2	0.7	13.7	0.8	<0.2	0.6	15.9	<0.2	0.2	0.4
ug/dscm	4.09	<0.04	<0.03	0.10	4.43	0.08	0.03	0.08	3.08	0.15	<0.03	0.07	3.65	<0.04	0.03	0.04
KMnO4-Acid Rinse volume, ml	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
Analytical Hg, ng/ml	<1.0	1.5	1.4	<1.0	<1.0	1.1	1.3	1.4	1.4	<1.0	1.1	1.2	1.5	<1.0	1.5	<1.0
ug/dscm	<0.09	0.12	0.08	<0.05	<0.09	0.09	0.08	0.06	0.13	<0.07	0.07	0.05	0.14	<0.07	0.09	<0.04
Particulate, ug/m ³	0.079	0.267	2.88E-03	2.30E-03	0.074	1.246	3.14E-03	2.29E-03	0.082	0.616	3.22E-03	2.26E-03	0.106	1.563	3.10E-03	2.23E-03
Particulate, mg/sec	0.0331	0.1227	1.37E-03	1.11E-03	0.0316	0.5774	1.49E-03	1.11E-03	0.0344	0.2881	1.54E-03	1.11E-03	0.0463	0.7255	1.50E-03	1.10E-03
Percent of Total	0.76	3.60	0.04	0.61	0.68	16.09	0.04	0.44	0.88	8.29	0.04	0.89	1.25	22.50	0.05	0.84
Oxidized Fraction, ug/m ³	5.76	6.97	7.18	0.21	6.11	6.31	7.91	0.35	5.96	6.97	7.85	0.12	4.57	5.25	6.35	0.16
Oxidized Fraction, mg/sec	2.4182	3.2022	3.4043	0.101	2.6272	2.9227	3.7620	0.172	2.5000	3.0720	3.7437	0.056	1.9954	2.4351	3.0622	0.079
Percent of Total	55.29	93.86	98.19	55.71	56.89	81.42	98.29	68.69	64.25	88.43	98.39	45.20	53.67	75.51	97.71	60.12
Elemental Fraction, ug ³	4.58	0.19	0.13	0.16	4.55	0.19	0.13	0.16	3.23	0.24	0.13	0.14	3.84	0.14	0.15	0.10
Elemental Fraction, mg/sec	1.9226	0.0866	0.0613	0.079	1.9395	0.0894	0.0641	0.077	1.3568	0.1138	0.0598	0.067	1.6765	0.0641	0.0701	0.051
Percent of Total	43.96	2.54	1.77	43.68	42.43	2.49	1.67	30.86	34.87	3.28	1.57	53.91	45.09	1.99	2.24	39.04
Total ug/m ³	10.43	7.43	7.75	0.38	10.73	7.75	8.05	0.5166	9.28	7.42	7.98	0.2544	8.52	6.95	6.50	0.2673
Total mg/sec	4.3739	3.4117	3.4670	0.182	4.6183	3.5996	3.8276	0.251	3.8912	3.4739	3.8050	0.12	3.7182	3.2247	3.1338	0.132

FGN in Airtel Survey 1/24/05

offset = 36"

North Port

static = 8.56

	w/offset			Null Angle
64"	28"	0.8557	285° F	0°
52"	16"	0.8460	286	9°
41"	5"	1.175	285	0°
30"	—	0.	285	—

South Port

static = 8.51

64"	28"	1.195	151° F	0°
58"	16"	1.080	157° F	0°
41"	5"	1.110	153° F	0°
30"	—	0	152	—

Axial Flow Check

Location	Stack <u>Z</u>	Duct Ht, "		Barometric	<u>29.65</u>
Date	<u>1-21-05</u>	Duct ID, "		Static	
Time	<u>1400-1405</u>	Duct Area		Dry Bulb	
Tube I.D.	<u>S-S3</u>	% O ₂		Wet Bulb	
C-Factor	<u>K.C., B.S.</u>	% CO ₂		% H ₂ O	
Operator(s)		% N ₂		W.M.Wt	

PORT/ POINT	DISTANCE [" From Wall]	TEMP [°F]	DELTA P [" H ₂ O]	VELOCITY [Ft/Sec]	Null Angle
A-1	10.0	127.1		0.7500	
A-2	33.3	127.1		1.281	
A-3	67.5	127.0		1.361	
B-1	10				
B-2	33.3				
B-3	67.5				
C-1	10				
C-2	33.3				
C-3	67.5				
D-1	10				
D-2	33.3				
D-3	67.5				
Average					
Maximum					
Minimum					
SDEV					

- .4486

DATA SUMMARY	
Velocity, [fps]	
acfm	
scfm	
dscfm	
Ex Air Free cfm	
Est. MM Btu/hr Heat Input	
Est. Firing Rate, lb/hr	

APPENDIX B

Plant Process Data

CONSOL Energy - DOE / EPRI Mercury Tests

Plant 4 Operating Data - Unit 1 (1/19/05 - 1/21/05)

Description	Units	Test # 1	Test # 2	Test # 3	Test # 4
Total Coal Flow	TPH	168.1	163.7	162.2	168.0
Gross Generation	MW	460	460	458	459
Feedwater Flow	KLBH	3125.41	3091.33	3063.07	3134.92
Main Steam Flow	KLBH	3343.78	3344.49	3325.81	3337.82
Feedwater Pressure	PSIG	2826.4	2824.7	2818.6	2822.2
SH Outlet Pressure	PSIG	2547.6	2548.7	2545.7	2544.2
Economizer Gas Out Temp	deg F	709.9	716.2	720.4	723.2
Air Heater Gas Out Temp	deg F	280.5	284.0	288.0	285.3
Economizer Outlet O2	%	3.30	3.38	3.33	3.35
FGD Inlet Temp	deg F	280.0	282.0	296.0	284.0
FGD Blowdown Flow	GPM	~ 1000	~ 1000	~ 1000	~ 1000
FGD ME Wash Flow	Gallons	11660	14625	26325	0
FGD Makeup Water Flow	Gallons	2992	3658	3995	3000
FGD Additive Feed Flow	GPM	112	94	99	88
FGD Inlet SO2	PPM	885	814.2	769.6	654
FGD Inlet NOx	PPM				
Stack Temp	deg F	121.2	122.5	122.1	122.9
Stack SO2	PPM	156.9	146.8	141.2	118.4
Stack NOx	PPM	220.0	254.6	266.8	248.4
Stack O2	PPM	6.1	5.85	5.85	5.8
Stack CO2	PPM	11.5	11.5	11.6	11.4
Stack Gas Flow	SCFM	1126500	1144446	1139283	1137875

CONSOL Energy - DOE / EPRI Mercury Tests

Plant 4 Operating Data - Unit 2 (1/24/05 - 1/26/05)

Description	Units	Test # 1	Test # 2	Test # 3	Test # 4
Total Coal Flow	TPH	160.8	163.2	162.4	161.4
Gross Generation	MW	459	458	458	457
Feedwater Flow	KLBH	2,965.1	3,024.9	3,002.4	3,010.1
Main Steam Flow	KLBH	3,288.2	3,288.0	3,288.0	3,285.7
Feedwater Pressure	PSIG	2,761.5	2,765.9	2,765.0	2,763.2
SH Outlet Pressure	PSIG	2,533.3	2,534.0	2,534.4	2,532.3
Economizer Gas Out Temp	deg F	693.7	682.4	687.5	700.5
Air Heater Gas Out Temp	deg F	280.2	276.8	281.1	284.4
Economizer Outlet O2	%	3.20	3.24	3.19	3.19
SCR NH3 Feed Rate	LBH	220	238	236	256
FGD Inlet Temp	deg F	294	291	295	296
FGD Blowdown Flow	GPM	1,000	979	987	965
FGD ME Wash Flow	Gallons	56,000	61,600	56,000	56,000
FGD Makeup Water Flow	Gallons	0	0	0	0
FGD Additive Feed Flow	GPM	79.5	114.0	105.5	89.8
FGD Inlet SO2	PPM	840	769	735	621
FGD Inlet NOx	PPM				
Stack Temp	deg F	122.3	122.7	122.3	123.4
Stack SO2	PPM	70.8	56.0	53.3	54.7
Stack NOx	PPM	83.7	85.2	89.4	86.9
Stack O2	PPM				
Stack CO2	PPM	11.6	11.7	11.8	11.4
Stack Gas Flow	SCFM	1,111,992	1,129,667	1,123,488	1,143,206

APPENDIX C

Flue Gas Mercury Data

- Summary of Ontario-Hydro Impinger Analyses Data Sheets
- Recovery Data Sheets

Distribution: Midwest - Lodge
 Project No.: 1621-87
 Sample Date: 1-19-05

Unit 1

Location: Econ Out Task: 1 Test: 1 Operator: Gay

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
1	1A	Probe & Filter Rinse				177		
2	1B	Heated Line Rinse				75		
3	2	KCl Impingers	300	150	87	537		
4	3	HNO ₃ /H ₂ O ₂ Impinger	100	75	1	176		
5	4	KMnO ₄ Impingers	200	50	-6	244		
6	5	KMnO ₄ Acid Rinse		100		100		

Filter Gross wt: 6.8257 g Filter Net wt: 5.2995 g
 Filter Tare wt: 1.5262 g Probe/Line Rinse wt: 0 g Condensate Total: 90.7 ml
 Filter Net wt: 5.2995 g Total Particulate wt: 5.2995 g

Recovered By: Ju Date: 1-19-05

Location: AHO Task: 1 Test: 1 Operator: Ju

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids 9						
7	1A	Probe & Filter Rinse				143		
8	1B	Heated Line Rinse				98		
9	2	KCl Impingers	300	150	78	528		
10	3	HNO ₃ /H ₂ O ₂ Impinger	100	75	-1	174		
11	4	KMnO ₄ Impingers	200	50	-7	243		
12	5	KMnO ₄ Acid Rinse		100		100		

Filter Gross wt: 2.4433 g Filter Net wt: 1.6375 g
 Filter Tare wt: 1.8058 g Probe/Line Rinse wt: 0 g Condensate Total: 75.4 ml
 Filter Net wt: 1.6375 g Total Particulate wt: 1.6375 g

Recovered By: Ju Date: 1-19-05

Location: FGD In Task: 1 Test: 1 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids 17						
13	1A	Probe & Filter Rinse				64		
14	1B	Heated Line Rinse				84		
15	2	KCl Impingers	300	150	109	559		
16	3	HNO ₃ /H ₂ O ₂ Impinger	100	75	0	175		
17	4	KMnO ₄ Impingers	200	50	-6	244		
18	5	KMnO ₄ Acid Rinse		100		100		

Filter Gross wt: 0.1499 g Filter Net wt: 0.0024 g
 Filter Tare wt: 0.1475 g Probe/Line Rinse wt: 0 g Condensate Total: 114.1 ml
 Filter Net wt: 0.0024 g Total Particulate wt: 0.0024 g

Recovered By: Ju Date: 1-19-05

Location: Stack Task: 1 Test: 1 Operator: Keith

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids 23						
19	1A	Probe & Filter Rinse				109		
	1B	Heated Line Rinse						
20	2	KCl Impingers	300	150	230	680		
21	3	HNO ₃ /H ₂ O ₂ Impinger	100	75	2	177		
22	4	KMnO ₄ Impingers	200	50	-5	245		
23	5	KMnO ₄ Acid Rinse		100		100		

Filter Gross wt: 0.4066 g Filter Net wt: 0.0002 g
 Filter Tare wt: 0.4064 g Probe/Line Rinse wt: 0 g Condensate Total: 239.2 ml
 Filter Net wt: 0.0002 g Total Particulate wt: 0.0002 g

Recovered By: Ju Date: 1-19-05

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
24	KCl Blank		
25	HNO ₃ / H ₂ O ₂ Blank		
26	KMnO ₄ Blank		
27	HNO ₃ / HCl Blank		

Distribution: Waltham - Locke
 Project No.: 1621-87
 Sample Date: 1-20-05

Unit 1

Location: Econ Out Unit 1 Task: 1 Test: 2 Operator: Gary

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>2</u>						
<u>28</u>	1A	Probe & Filter Rinse				<u>188</u>		
<u>29</u>	1B	Heated Line Rinse				<u>111</u>		
<u>30</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>87</u>	<u>537</u>		
<u>31</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>32</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-4</u>	<u>246</u>		
<u>33</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 8.6967 g Filter Net wt: 6.5763 g
 Filter Tare wt: 1.5204 g Probe/Line Rinse wt: 0 g Condensate Total: 91.5 ml
 Filter Net wt: 6.5763 g Total Particulate wt: 6.5763 g

Recovered By: Ju Date: 1-20-05

Location: AHO Unit 1 Task: 1 Test: 2 Operator: Jim

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>10</u>						
<u>34</u>	1A	Probe & Filter Rinse				<u>120</u>		
<u>35</u>	1B	Heated Line Rinse				<u>106</u>		
<u>36</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>74</u>	<u>524</u>		
<u>37</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>-2</u>	<u>173</u>		
<u>38</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-8</u>	<u>242</u>		
<u>39</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 2.3274 g Filter Net wt: 0.6981 g
 Filter Tare wt: 1.6293 g Probe/Line Rinse wt: 0 g Condensate Total: 71.7 ml
 Filter Net wt: 0.6981 g Total Particulate wt: 0.6981 g

Recovered By: Ju Date: 1-20-05

Location: FGD In Unit 1 Task: 1 Test: 2 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>18</u>						
<u>40</u>	1A	Probe & Filter Rinse				<u>77</u>		
<u>41</u>	1B	Heated Line Rinse				<u>80</u>		
<u>42</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>10.5</u>	<u>555</u>		
<u>43</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>44</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-7</u>	<u>243</u>		
<u>45</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.1476 g Filter Net wt: 0.0004 g
 Filter Tare wt: 0.1472 g Probe/Line Rinse wt: 0 g Condensate Total: 107.5 ml
 Filter Net wt: 0.0004 g Total Particulate wt: 0.0004 g

Recovered By: Ju Date: 1-20-05

Location: Stack Unit 1 Task: 1 Test: 2 Operator: Keith

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>24</u>						
<u>46</u>	1A	Probe & Filter Rinse				<u>105</u>		
<u>47</u>	1B	Heated Line Rinse				<u>—</u>		
<u>47</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>233</u>	<u>683</u>		
<u>48</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>2</u>	<u>177</u>		
<u>49</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-4</u>	<u>246</u>		
<u>50</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.4146 g Filter Net wt: 0.0030 g
 Filter Tare wt: 0.4116 g Probe/Line Rinse wt: 0 g Condensate Total: 243.3 ml
 Filter Net wt: 0.0030 g Total Particulate wt: 0.0030 g

Recovered By: Ju Date: 1-20-05

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
	KCl Blank		
	HNO ₃ / H ₂ O ₂ Blank		
<u>51</u>	KMnO ₄ Blank		
	HNO ₃ / HCl Blank		

Unit 1

Distribution: William - Locke
 Project No.: 1621-87
 Sample Date: 1-20-05

Location: Econ Out Unit Task: 1 Test: 3 Operator: Gary

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>3</u>						
<u>52</u>	1A	Probe & Filter Rinse				<u>170</u>		
<u>53</u>	1B	Heated Line Rinse				<u>115</u>		
<u>54</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>76</u>	<u>524</u>		
<u>55</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>56</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-5</u>	<u>245</u>		
<u>57</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 7.6839 g Filter Net wt: 6.0387 g
 Filter Tare wt: 1.6452 g Probe/Line Rinse wt: 0 g Condensate Total: 77.3 ml
 Filter Net wt: 6.0387 g Total Particulate wt: 6.0387 g

Recovered By: Ju Date: 1-20-05

Location: AHO Unit Task: 1 Test: 3 Operator: Jeani

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>11</u>						
<u>58</u>	1A	Probe & Filter Rinse				<u>121</u>		
<u>59</u>	1B	Heated Line Rinse				<u>118</u>		
<u>60</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>73</u>	<u>523</u>		
<u>61</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>62</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-4</u>	<u>246</u>		
<u>63</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 3.5523 g Filter Net wt: 2.1345 g
 Filter Tare wt: 1.4178 g Probe/Line Rinse wt: 0 g Condensate Total: 74.0 ml
 Filter Net wt: 2.1345 g Total Particulate wt: 2.1345 g

Recovered By: Ju Date: 1-20-05

Location: FGD In Unit Task: 1 Test: 3 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>19</u>						
<u>64</u>	1A	Probe & Filter Rinse				<u>135</u>		
<u>65</u>	1B	Heated Line Rinse				<u>112</u>		
<u>66</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>114</u>	<u>564</u>		
<u>67</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>1</u>	<u>176</u>		
<u>68</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-3</u>	<u>247</u>		
<u>69</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.588 g Filter Net wt: 0.0115 g
 Filter Tare wt: 0.1473 g Probe/Line Rinse wt: 0 g Condensate Total: 124.9 ml
 Filter Net wt: 0.0115 g Total Particulate wt: 0.0115 g

Recovered By: Ju Date: 1-20-05

Location: Stack Unit Task: 1 Test: 3 Operator: Kathy

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>25</u>						
<u>70</u>	1A	Probe & Filter Rinse				<u>111</u>		
<u>71</u>	1B	Heated Line Rinse				<u>111</u>		
<u>71</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>234</u>	<u>684</u>		
<u>72</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>73</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-5</u>	<u>245</u>		
<u>74</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.4153 g Filter Net wt: 0.0012 g
 Filter Tare wt: 0.4141 g Probe/Line Rinse wt: 0 g Condensate Total: 241.4 ml
 Filter Net wt: 0.0012 g Total Particulate wt: 0.0012 g

Recovered By: Ju Date: 1-26-05

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
	KCl Blank		
	HNO ₃ / H ₂ O ₂ Blank		
<u>75</u>	KMnO ₄ Blank		
	HNO ₃ / HCl Blank		

Distribution: Washburn - Locke
 Project No.: 1621-87
 Sample Date: 1-21-05

Unit 1

Location: Econ Out Task: 1 Test: 4 Operator: Gray

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>4</u>						
<u>76</u>	1A	Probe & Filter Rinse				<u>227</u>		
<u>77</u>	1B	Heated Line Rinse				<u>173</u>		
<u>78</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>87</u>	<u>537</u>		
<u>79</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>-1</u>	<u>174</u>		
<u>80</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-5</u>	<u>245</u>		
<u>81</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 8.5924 g Filter Net wt: 7.1277 g
 Filter Tare wt: 1.4647 g Probe/Line Rinse wt: 0 g Condensate Total: 90.1 ml
 Filter Net wt: 7.1277 g Total Particulate wt: 7.1277 g

Recovered By: Ju Date: 1-21-05

Location: AHO Task: 1 Test: 4 Operator: Juni

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>12</u>						
<u>82</u>	1A	Probe & Filter Rinse				<u>88</u>		
<u>83</u>	1B	Heated Line Rinse				<u>139</u>		
<u>84</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>89</u>	<u>539</u>		
<u>85</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>86</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-5</u>	<u>245</u>		
<u>87</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 3.0672 g Filter Net wt: 1.5973 g
 Filter Tare wt: 1.4699 g Probe/Line Rinse wt: 0 g Condensate Total: 89.7 ml
 Filter Net wt: 1.5973 g Total Particulate wt: 1.5973 g

Recovered By: Ju Date: 1-21-05

Location: FGD In Task: 1 Test: 4 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>20</u>						
<u>88</u>	1A	Probe & Filter Rinse				<u>127</u>		
<u>89</u>	1B	Heated Line Rinse				<u>107</u>		
<u>90</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>112</u>	<u>562</u>		
<u>91</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>1</u>	<u>176</u>		
<u>92</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-3</u>	<u>247</u>		
<u>93</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.1613 g Filter Net wt: 0.0134 g
 Filter Tare wt: 0.1479 g Probe/Line Rinse wt: 0 g Condensate Total: 121.4 ml
 Filter Net wt: 0.0134 g Total Particulate wt: 0.0134 g

Recovered By: Ju Date: 1-21-05

Location: Stack Task: 1 Test: 4 Operator: Keith

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>26</u>						
<u>94</u>	1A	Probe & Filter Rinse				<u>109</u>		
<u>95</u>	1B	Heated Line Rinse				<u>-</u>		
<u>95</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>240</u>	<u>690</u>		
<u>96</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>97</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-4</u>	<u>244</u>		
<u>98</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.4151 g Filter Net wt: 0.0017 g
 Filter Tare wt: 0.4134 g Probe/Line Rinse wt: 0 g Condensate Total: 245.3 ml
 Filter Net wt: 0.0017 g Total Particulate wt: 0.0017 g

Recovered By: Ju Date: 1-21-05

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
	KCl Blank		
	HNO ₃ / H ₂ O ₂ Blank		
	KMnO ₄ Blank		
	HNO ₃ / HCl Blank		

Project No	Test	Date	Loc.	Operator	Sample ID #	Task	Description	Anal No.	Hg
1621-87	1	02/01/05	ECONOUT	#VALUE!	1	1	PROBE & FILTER RINSE	20050377	<1.0 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	2	1	HEATED LINE RINSE	20050378	<1.0 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	3	1	KCL IMPINGER	20050379	11.2 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	4	1	HNO3/H2O2 IMPINGER	20050380	0.5 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	5	1	KMNO4 IMPINGER	20050381	23.2 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	6	1	KMNO4 ACID RINSE	20050382	<1.0 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	7	1	PROBE & FILTER RINSE	20050383	1.0 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	8	1	HEATED LINE RINSE	20050384	1.7 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	9	1	KCL IMPINGER	20050385	12.3 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	10	1	HNO3/H2O2 IMPINGER	20050386	<0.2 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	11	1	KMNO4 IMPINGER	20050387	0.4 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	12	1	KMNO4 ACID RINSE	20050388	1.5 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	13	1	PROBE & FILTER RINSE	20050389	<1.0 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	14	1	HEATED LINE RINSE	20050390	<1.0 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	15	1	KCL IMPINGER	20050391	21.0 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	16	1	HNO3/H2O2 IMPINGER	20050392	<0.2 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	17	1	KMNO4 IMPINGER	20050393	2.4 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	18	1	KMNO4 ACID RINSE	20050394	<1.0 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	19	1	PROBE & FILTER RINSE	20050395	<1.0 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	20	1	KCL IMPINGER	20050396	1.3 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	21	1	HNO3/H2O2 IMPINGER	20050397	<0.2 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	22	1	KMNO4 IMPINGER	20050398	2.3 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	23	1	KMNO4 ACID RINSE	20050399	<1.0 ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	24	#VALUE!	KCL BLANK	20050400	<0.2 ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	25	#VALUE!	HNO3/H2O2 BLANK	20050401	<0.2 ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	26	#VALUE!	KMNO4 BLANK	20050402	<0.2 ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	27	#VALUE!	HNO3/HCL BLANK	20050403	<0.2 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	28	1	PROBE & FILTER RINSE	20050404	<1.0 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	29	1	HEATED LINE RINSE	20050405	<1.0 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	30	1	KCL IMPINGER	20050406	11.9 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	31	1	HNO3/H2O2 IMPINGER	20050407	0.5 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	32	1	KMNO4 IMPINGER	20050408	17.3 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	33	1	KMNO4 ACID RINSE	20050409	1.8 ng/ml

1621-87	2	02/01/05	AHO	#VALUE!	34	1	PROBE & FILTER RINSE	20050410	<1.0	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	35	1	HEATED LINE RINSE	20050411	5.1	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	36	1	KCL IMPINGER	20050412	14.9	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	37	1	HNO3/H2O2 IMPINGER	20050413	0.9	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	38	1	KMNO4 IMPINGER	20050414	3.5	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	39	1	KMNO4 ACID RINSE	20050415	<1.0	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	40	1	PROBE & FILTER RINSE	20050416	<1.0	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	41	1	HEATED LINE RINSE	20050417	<1.0	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	42	1	KCL IMPINGER	20050418	22.7	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	43	1	HNO3/H2O2 IMPINGER	20050419	0.4	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	44	1	KMNO4 IMPINGER	20050420	1.4	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	45	1	KMNO4 ACID RINSE	20050421	1.1	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	46	1	PROBE & FILTER RINSE	20050422	<1.0	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	47	1	KCL IMPINGER	20050423	1.0	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	48	1	HNO3/H2O2 IMPINGER	20050424	<0.2	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	49	1	KMNO4 IMPINGER	20050425	6.3	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	50	1	KMNO4 ACID RINSE	20050426	2.0	ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	51	#VALUE!	KMNO4 BLANK	20050427	<0.2	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	52	1	PROBE & FILTER RINSE	20050428	<1.0	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	53	1	HEATED LINE RINSE	20050429	<1.0	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	54	1	KCL IMPINGER	20050430	10.2	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	55	1	HNO3/H2O2 IMPINGER	20050431	0.4	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	56	1	KMNO4 IMPINGER	20050432	13.4	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	57	1	KMNO4 ACID RINSE	20050433	<1.0	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	58	1	PROBE & FILTER RINSE	20050434	<1.0	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	59	1	HEATED LINE RINSE	20050435	<1.0	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	60	1	KCL IMPINGER	20050436	14.6	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	61	1	HNO3/H2O2 IMPINGER	20050437	0.3	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	62	1	KMNO4 IMPINGER	20050438	4.5	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	63	1	KMNO4 ACID RINSE	20050439	<1.0	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	64	1	PROBE & FILTER RINSE	20050440	<1.0	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	65	1	HEATED LINE RINSE	20050441	<1.0	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	66	1	KCL IMPINGER	20050442	23.9	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	67	1	HNO3/H2O2 IMPINGER	20050443	0.2	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	68	1	KMNO4 IMPINGER	20050444	2.0	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	69	1	KMNO4 ACID RINSE	20050445	1.5	ng/ml

1621-87	3	02/01/05	STACK	#VALUE!	70	1	PROBE & FILTER RINSE	20050446	<1.0	ng/ml
1621-87	3	02/01/05	STACK	#VALUE!	71	1	KCL IMPINGER	20050447	0.9	ng/ml
1621-87	3	02/01/05	STACK	#VALUE!	72	1	HNO3/H2O2 IMPINGER	20050448	0.2	ng/ml
1621-87	3	02/01/05	STACK	#VALUE!	73	1	KMNO4 IMPINGER	20050449	9.1	ng/ml
1621-87	3	02/01/05	STACK	#VALUE!	74	1	KMNO4 ACID RINSE	20050450	<1.0	ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	75	#VALUE!	KMNO4 BLANK	20050451	<0.2	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	76	1	PROBE & FILTER RINSE	20050452	<1.0	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	77	1	HEATED LINE RINSE	20050453	<1.0	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	78	1	KCL IMPINGER	20050454	8.2	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	79	1	HNO3/H2O2 IMPINGER	20050455	0.4	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	80	1	KMNO4 IMPINGER	20050456	8.0	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	81	1	KMNO4 ACID RINSE	20050457	<1.0	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	82	1	PROBE & FILTER RINSE	20050458	<1.0	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	83	1	HEATED LINE RINSE	20050459	<1.0	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	84	1	KCL IMPINGER	20050460	9.9	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	85	1	HNO3/H2O2 IMPINGER	20050461	<0.2	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	86	1	KMNO4 IMPINGER	20050462	1.3	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	87	1	KMNO4 ACID RINSE	20050463	<1.0	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	88	1	PROBE & FILTER RINSE	20050464	<1.0	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	89	1	HEATED LINE RINSE	20050465	<1.0	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	90	1	KCL IMPINGER	20050466	11.7	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	91	1	HNO3/H2O2 IMPINGER	20050467	<1.0	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	92	1	KMNO4 IMPINGER	20050468	2.6	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	93	1	KMNO4 ACID RINSE	20050469	<1.0	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	94	1	PROBE & FILTER RINSE	20050470	<1.0	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	95	1	KCL IMPINGER	20050471	0.7	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	96	1	HNO3/H2O2 IMPINGER	20050472	<0.2	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	97	1	KMNO4 IMPINGER	20050473	4.3	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	98	1	KMNO4 ACID RINSE	20050474	<1.0	ng/ml
1621-87	4	02/01/05	IMP	#VALUE!	99	1	KCL IMPINGER	20050475	<0.2	ng/ml
1621-87	4	02/01/05	IMP	#VALUE!	100	1	HNO3/H2O2 IMPINGER	20050476	<0.2	ng/ml
1621-87	4	02/01/05	IMP	#VALUE!	101	1	KMNO4 IMPINGER	20050477	<0.2	ng/ml
1621-87	4	02/01/05	IMP	#VALUE!	102	1	KMNO4 ACID RINSE	20050478	<1.0	ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	103	#VALUE!	KMNO4 BLANK	20050479	<0.2	ng/ml
1621-87	4	02/01/05	IMP	#VALUE!	104	1	KCL IMPINGER	20050480	<0.2	ng/ml
1621-87	4	02/01/05	IMP	#VALUE!	105	1	HNO3/H2O2 IMPINGER	20050481	<0.2	ng/ml
1621-87	4	02/01/05	IMP	#VALUE!	106	1	KMNO4 IMPINGER	20050482	<0.2	ng/ml
1621-87	4	02/01/05	IMP	#VALUE!	107	1	KMNO4 ACID RINSE	20050483	<1.0	ng/ml

Run 1 Particulate in Thimbles by ASTM D6722, Direct Combustion

ANALNUM	SAMPLE	DATE	DESCR	Hg	
20050611	1	01/19/05	ECON OUT 1 THIMBLE	0.015	PPM
20050612	9	01/19/05	AHO-1 THIMBLE	0.462	PPM
20050615	2	01/20/05	ECON OUT 2 THIMBLE	0.015	PPM
20050616	10	01/20/05	AHO-2 THIMBLE	0.080	PPM
20050619	3	01/20/05	ECON OUT 3 THIMBLE	0.014	PPM
20050620	11	01/20/05	AHO-3 THIMBLE	0.098	PPM
20050623	4	01/21/05	ECON OUT 4 THIMBLE	0.018	PPM
20050624	12	01/21/05	AHO-4 THIMBLE	0.095	PPM

NIST 1633B (also used as Continuing Calibration Verification)

PPM

1633B					0.153	109%	good
1633B					0.153	109%	good

Run 2 Filters by ASTM 6414, Acid Digestion/CVAA

ANALNUM	SAMPLE	DATE	DESCR	Hg	
20050613	17	01/19/05	FGD-1 47 MM	<5.0	ng/filter
20050614	23	01/19/05	STK-1 3-IN FILTER	<5.0	ng/filter
20050617	18	01/20/05	FGD-2 47 MM FILTER	<5.0	ng/filter
20050618	24	01/20/05	STK-2 3-IN FILTER	<5.0	ng/filter
20050621	19	01/20/05	FGD-3 47 MM FILTER	<5.0	ng/filter
20050622	25	01/20/05	STK-3 3-IN FILTER	<5.0	ng/filter
20050625	20	01/21/05	FGD-4 47 MM FILTER	<5.0	ng/filter
20050626	26	01/21/05	STK-4 3-IN FILTER	<5.0	ng/filter

NIST 1633B

PPM

1633B					0.128	91%	good
-------	--	--	--	--	-------	-----	------

Continuing Calibration Verification

ng/ml

1641d 8 ppb					8.2	103%	good
1641d 8ppb					8.2	103%	good
1641d 8ppb					8.2	103%	good
1641d 8ppb					8.3	104%	good

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ECON OUT 1 THIMBLE
 UNIT 1
 DATE SAMPLED 01/19/05
 SAMPLE NUMBER 1

DATE LOGGED 02/03/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050611

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	94.18	Carbon	5.36	Silicon	49.39
		Ash	94.18	Al2O3	27.19
<u>MISC. (As Det.)</u>				TiO2	1.41
				Fe2O3	10.76
MERCURY	0.015 PPM			CaO	1.70
				MgO	0.99
				Na2O	0.54
				K2O	2.52
				P2O5	0.27
				SO3	0.57
				UND	4.66

AS DETERMINED MOISTURE: 0.06 %

DISTRIBUTION:
 J. WITHUM
 J. LOCKE
 S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AHO-1 THIMBLE
 UNIT 1

DATE SAMPLED 01/19/05
 SAMPLE NUMBER 9

DATE LOGGED 02/03/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050612

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.82	Carbon	5.66	Silicon	47.81
		Ash	93.82	Al2O3	25.91
<u>MISC. (As Det.)</u>				TiO2	1.31
				Fe2O3	11.31
MERCURY	0.462 PPM			CaO	1.53
				MgO	0.91
				Na2O	0.48
				K2O	2.36
				P2O5	0.22
				SO3	0.45
				UND	7.71

AS DETERMINED MOISTURE: 0.30 %

DISTRIBUTION:
 J. WITHUM
 J. LOCKE
 S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION FGD-1 47 MM
UNIT 1
DATE SAMPLED 01/19/05
SAMPLE NUMBER 17


DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050613

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal 

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION STK-1 3-IN FILTER
UNIT 1

DATE SAMPLED 01/19/05
SAMPLE NUMBER 23

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050614

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA. 15129

DESCRIPTION ECON OUT 2 THIMBLE
 UNIT 1
 DATE SAMPLED 01/20/05
 SAMPLE NUMBER 2

DATE LOGGED 02/03/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050615

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.44	Carbon	3.18	Silicon	51.04
		Ash	96.44	Al2O3	26.56
<u>MISC. (As Det.)</u>				TiO2	1.45
				Fe2O3	10.98
MERCURY	0.015 PPM			CaO	1.69
				MgO	0.96
				Na2O	0.58
				K2O	2.35
				P2O5	0.29
				SO3	0.55
				UND	3.55

AS DETERMINED MOISTURE: 0.12 %

DISTRIBUTION:
 J. WITHUM
 J. LOCKE
 S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AHO-2 THIMBLE
 UNIT 1
 DATE SAMPLED 01/20/05
 SAMPLE NUMBER 10

DATE LOGGED 02/03/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050616

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	97.02	Carbon	2.56	Silicon	51.34
		Ash	97.02	Al2O3	26.30
<u>MISC. (As Det.)</u>				TiO2	1.45
				Fe2O3	11.74
MERCURY	0.080 PPM			CaO	1.72
				MgO	0.95
				Na2O	0.54
				K2O	2.30
				P2O5	0.28
				SO3	0.56
				UND	2.82

AS DETERMINED MOISTURE: 0.31 %

DISTRIBUTION:
 J. WITHUM
 J. LOCKE
 S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION FGD-2 47 MM FILTER
UNIT 1

DATE SAMPLED 01/20/05
SAMPLE NUMBER 18


DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050617

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal 

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION STK-2 3-IN FILTER
UNIT 1

DATE SAMPLED 01/20/05
SAMPLE NUMBER 24

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050618

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ECON OUT 3 THIMBLE
 UNIT 1

DATE SAMPLED 01/20/05
 SAMPLE NUMBER 3

DATE LOGGED 02/03/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050619

ANALYSIS REPORT

<u>PROXIMATE</u> (Dry)%	<u>ULTIMATE</u> (Dry)%	<u>MAJOR ASH ELEM</u> (Dry)%
Ash 96.94	Carbon 2.95	Silicon 51.79
	Ash 96.94	Al2O3 26.34
<u>MISC. (As Det.)</u>		TiO2 1.46
		Fe2O3 10.82
MERCURY 0.014 PPM		CaO 1.75
		MgO 0.97
		Na2O 0.56
		K2O 2.42
		P2O5 0.31
		SO3 0.45
		UND 3.13

AS DETERMINED MOISTURE: 0.10 %

DISTRIBUTION:
 J. WITHUM
 J. LOCKE
 S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AHO-3 THIMBLE
UNIT 1

DATE SAMPLED 01/20/05
SAMPLE NUMBER 11

DATE LOGGED 02/03/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050620

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.91	Carbon	2.84	Silicon	51.83
		Ash	96.91	Al2O3	26.21
<u>MISC. (As Det.)</u>				TiO2	1.43
				Fe2O3	11.04
MERCURY	0.098 PPM			CaO	1.71
				MgO	0.96
				Na2O	0.54
				K2O	2.34
				P2O5	0.27
				SO3	0.36
				UND	3.31

AS DETERMINED MOISTURE: 0.27 %

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION FGD-3 47 MM FILTER
UNIT 1

DATE SAMPLED 01/20/05
SAMPLE NUMBER 19

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050621

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION STK-3 3-IN FILTER
UNIT 1
DATE SAMPLED 01/20/05
SAMPLE NUMBER 25


DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050622

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal 

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ECON OUT 4 THIMBLE
UNIT 1
DATE SAMPLED 01/21/05
SAMPLE NUMBER 4

DATE LOGGED 02/03/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050623

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	95.87	Carbon	3.47	Silicon	53.34
		Ash	95.87	Al2O3	25.73
<u>MISC. (As Det.)</u>				TiO2	1.43
MERCURY	0.018 PPM			Fe2O3	9.03
				CaO	1.55
				MgO	1.02
				Na2O	0.61
				K2O	2.53
				P2O5	0.13
				SO3	0.55
				UND	4.08

AS DETERMINED MOISTURE: 0.08 %

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AHO-4 THIMBLE
 UNIT 1
 DATE SAMPLED 01/21/05
 SAMPLE NUMBER 12

DATE LOGGED 02/03/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050624

ANALYSIS REPORT

<u>PROXIMATE</u> (Dry)%	<u>ULTIMATE</u> (Dry)%	<u>MAJOR ASH ELEM</u> (Dry)%
Ash 96.98	Carbon 2.45	Silicon 53.89
	Ash 96.98	Al2O3 25.81
<u>MISC. (As Det.)</u>		TiO2 1.41
MERCURY 0.095 PPM		Fe2O3 9.16
		CaO 1.48
		MgO 1.01
		Na2O 0.61
		K2O 2.51
		P2O5 0.11
		SO3 0.44
		UND 3.57

AS DETERMINED MOISTURE: 0.18 %

DISTRIBUTION:
 J. WITHUM
 J. LOCKE
 S. TSENG

Approved for transmittal

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION FGD-4 47 MM FILTER
UNIT 1
DATE SAMPLED 01/21/05
SAMPLE NUMBER 20

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050625

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION STK-4 3-IN FILTER
UNIT 1
DATE SAMPLED 01/21/05
SAMPLE NUMBER 26

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050626

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal _____

Distribution: William Roche
 Project No.: 1621-87
 Sample Date: 1-24-05

unit 2

Location: Econ Out Task: 2 Test: 1 Operator: Gay

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>5</u>						
<u>1</u>	1A	Probe & Filter Rinse				<u>182</u>		
<u>2</u>	1B	Heated Line Rinse				<u>121</u>		
<u>3</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>73</u>	<u>523</u>		
<u>4</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>5</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-3</u>	<u>247</u>		
<u>6</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 7.0514 g Filter Net wt: 5.4040 g
 Filter Tare wt: 1.6474 g Probe/Line Rinse wt: 0 g
 Filter Net wt: 5.4040 g Total Particulate wt: 5.4040 g
 Condensate Total: 78.1 ml

Recovered By: Ju Date: 1-24-05
 Location: AHO Task: 2 Test: 1 Operator: Ju

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>13</u>						
<u>7</u>	1A	Probe & Filter Rinse				<u>160</u>		
<u>8</u>	1B	Heated Line Rinse				<u>148</u>		
<u>9</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>74</u>	<u>524</u>		
<u>10</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>11</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-4</u>	<u>246</u>		
<u>12</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 2.6802 g Filter Net wt: 1.1700 g
 Filter Tare wt: 1.5102 g Probe/Line Rinse wt: 0 g
 Filter Net wt: 1.1700 g Total Particulate wt: 1.1700 g
 Condensate Total: 75.6 ml

Recovered By: Ju Date: 1-24-05
 Location: FGD In Task: 2 Test: 1 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>34</u>						
<u>13</u>	1A	Probe & Filter Rinse				<u>108</u>		
<u>14</u>	1B	Heated Line Rinse				<u>109</u>		
<u>15</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>94</u>	<u>544</u>		
<u>16</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>17</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-3</u>	<u>247</u>		
<u>18</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.4030 g Filter Net wt: 0.0005 g
 Filter Tare wt: 0.4025 g Probe/Line Rinse wt: 0 g
 Filter Net wt: 0.0005 g Total Particulate wt: 0.0005 g
 Condensate Total: 99.0 ml

Recovered By: Ju Date: 1-24-05
 Location: Stack Task: 2 Test: 1 Operator: Kurtz

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>27</u>						
<u>19</u>	1A	Probe & Filter Rinse				<u>109</u>		
<u>20</u>	1B	Heated Line Rinse				<u>—</u>		
<u>20</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>222</u>	<u>672</u>		
<u>21</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>7</u>	<u>182</u>		
<u>22</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-4</u>	<u>244</u>		
<u>23</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.4085 g Filter Net wt: 0.0080 g
 Filter Tare wt: 0.4005 g Probe/Line Rinse wt: 0 g
 Filter Net wt: 0.0080 g Total Particulate wt: 0.0080 g
 Condensate Total: 238.1 ml

Recovered By: Ju Date: 1-24-05

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
<u>24</u>	KCl Blank		
<u>25</u>	HNO ₃ / H ₂ O ₂ Blank		
<u>26</u>	KMnO ₄ Blank		
<u>27</u>	HNO ₃ / HCl Blank		

Distribution: Mathum - Locke
Project No.: 1621-87
Sample Date: 1-25-05

Unit 2

Location: Econ Out Task: 2 Test: 2 Operator: Gay

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>7</u>						
<u>28</u>	1A	Probe & Filter Rinse				<u>170</u>		
<u>29</u>	1B	Heated Line Rinse				<u>98</u>		
<u>30</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>89</u>	<u>539</u>		
<u>31</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>32</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-4</u>	<u>246</u>		
<u>33</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 6.7910 g Filter Net wt: 5.3862 g
Filter Tare wt: 1.4048 g Probe/Line Rinse wt: 0 g
Filter Net wt: 5.3862 g Total Particulate wt: 5.3862 g
Condensate Total: 83.7 ml

Recovered By: Ju Date: 1-25-05

Location: AHO Task: 2 Test: 2 Operator: Juan

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>14</u>						
<u>34</u>	1A	Probe & Filter Rinse				<u>126</u>		
<u>35</u>	1B	Heated Line Rinse				<u>209</u>		
<u>36</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>73</u>	<u>523</u>		
<u>37</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>38</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-4</u>	<u>244</u>		
<u>39</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 4.0315 g Filter Net wt: 2.3996 g
Filter Tare wt: 1.6319 g Probe/Line Rinse wt: 0 g
Filter Net wt: 2.3996 g Total Particulate wt: 2.3996 g
Condensate Total: 72.4 ml

Recovered By: Ju Date: 1-25-05

Location: FGD In Task: 2 Test: 2 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>35</u>						
<u>40</u>	1A	Probe & Filter Rinse				<u>101</u>		
<u>41</u>	1B	Heated Line Rinse				<u>89</u>		
<u>42</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>85</u>	<u>535</u>		
<u>43</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>2</u>	<u>177</u>		
<u>44</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-5</u>	<u>245</u>		
<u>45</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.3988 g Filter Net wt: 0.0001 g
Filter Tare wt: 0.3987 g Probe/Line Rinse wt: 0 g
Filter Net wt: 0.0001 g Total Particulate wt: 0.0001 g
Condensate Total: 89.5 ml

Recovered By: Ju Date: 1-25-05

Location: Stack Task: 2 Test: 2 Operator: Kuth

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>31</u>						
<u>46</u>	1A	Probe & Filter Rinse				<u>100</u>		
<u>47</u>	1B	Heated Line Rinse				<u>-</u>		
<u>47</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>222</u>	<u>672</u>		
<u>48</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>8</u>	<u>183</u>		
<u>49</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-5</u>	<u>245</u>		
<u>50</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.4089 g Filter Net wt: 0.0055 g
Filter Tare wt: 0.4034 g Probe/Line Rinse wt: 0 g
Filter Net wt: 0.0055 g Total Particulate wt: 0.0055 g
Condensate Total: 235.9 ml

Recovered By: Ju Date: 1-25-05

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
	KCl Blank		
	HNO ₃ / H2O2 Blank		
	KMnO ₄ Blank		
	HNO ₃ / HCl Blank		

Distribution: Moham-Loche
Project No.: 1621-87
Sample Date: 1-25-05

Location: Econ Out Task: 2 Test: 3 Operator: Jay

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>6</u>						
<u>56</u>	1A	Probe & Filter Rinse				<u>198</u>		
<u>57</u>	1B	Heated Line Rinse				<u>106</u>		
<u>58</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>75</u>	<u>525</u>		
<u>59</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>1</u>	<u>176</u>		
<u>60</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-2</u>	<u>248</u>		
<u>61</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 7.3005 g Filter Net wt: 5.6593 g
Filter Tare wt: 1.6412 g Probe/Line Rinse wt: 0 g
Filter Net wt: 5.6593 g Total Particulate wt: 5.6593 g
Condensate Total: 78.7 ml

Recovered By: Ju Date: 1-25-05

Location: AHO Task: 2 Test: 3 Operator: Jenn

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>15</u>						
<u>62</u>	1A	Probe & Filter Rinse				<u>123</u>		
<u>63</u>	1B	Heated Line Rinse				<u>130</u>		
<u>64</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>79</u>	<u>529</u>		
<u>65</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>1</u>	<u>176</u>		
<u>66</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>0</u>	<u>250</u>		
<u>67</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 4.4486 g Filter Net wt: 2.7024 g
Filter Tare wt: 1.7462 g Probe/Line Rinse wt: 0 g
Filter Net wt: 2.7024 g Total Particulate wt: 2.7024 g
Condensate Total: 87.3 ml

Recovered By: Ju Date: 1-25-05

Location: FGD In Task: 2 Test: 3 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>36</u>						
<u>68</u>	1A	Probe & Filter Rinse				<u>95</u>		
<u>69</u>	1B	Heated Line Rinse				<u>121</u>		
<u>70</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>93</u>	<u>543</u>		
<u>71</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>72</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-2</u>	<u>248</u>		
<u>73</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.5981 g Filter Net wt: 0.0011 g
Filter Tare wt: 0.3770 g Probe/Line Rinse wt: 0 g
Filter Net wt: 0.0011 g Total Particulate wt: 0.0011 g
Condensate Total: 98.3 ml

Recovered By: Ju Date: 1-25-05

Location: Stack Task: 2 Test: 3 Operator: Keith

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>32</u>						
<u>74</u>	1A	Probe & Filter Rinse				<u>117</u>		
<u>75</u>	1B	Heated Line Rinse				<u>117</u>		
<u>75</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>237</u>	<u>687</u>		
<u>76</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>1</u>	<u>176</u>		
<u>77</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-3</u>	<u>247</u>		
<u>78</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.4020 g Filter Net wt: 0.0081 g
Filter Tare wt: 0.3939 g Probe/Line Rinse wt: 0 g
Filter Net wt: 0.0081 g Total Particulate wt: 0.0081 g
Condensate Total: 245.8 ml

Recovered By: Ju Date: 1-25-05

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
	KCl Blank		
	HNO ₃ / H ₂ O ₂ Blank		
<u>79</u>	KMnO ₄ Blank		
	HNO ₃ / HCl Blank		

Distribution: Western-Loche
Project No.: 1621-87
Sample Date: 1-26-05

unit 2

Location: Econ Out Task: 2 Test: 4 Operator: Jay

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>8</u>						
<u>80</u>	1A	Probe & Filter Rinse				<u>166</u>		
<u>81</u>	1B	Heated Line Rinse				<u>88</u>		
<u>82</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>72</u>	<u>522</u>		
<u>83</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>84</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-1</u>	<u>249</u>		
<u>85</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 7.6215 g Filter Net wt: 6.0508 g
Filter Tare wt: 1.5707 g Probe/Line Rinse wt: 6 g
Filter Net wt: 6.0508 g Total Particulate wt: 6.0508 g
Condensate Total: 77.4 ml

Recovered By: Ju Date: 1-26-05

Location: AHO Task: 2 Test: 4 Operator: Jenni

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>16</u>						
<u>86</u>	1A	Probe & Filter Rinse				<u>128</u>		
<u>87</u>	1B	Heated Line Rinse				<u>129</u>		
<u>88</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>82</u>	<u>532</u>		
<u>89</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>90</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-3</u>	<u>247</u>		
<u>91</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 6.9845 g Filter Net wt: 5.5082 g
Filter Tare wt: 1.4763 g Probe/Line Rinse wt: 0 g
Filter Net wt: 5.5082 g Total Particulate wt: 5.5082 g
Condensate Total: 85.9 ml

Recovered By: Ju Date: 1-26-05

Location: FGD In Task: 2 Test: 4 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>37</u>						
<u>92</u>	1A	Probe & Filter Rinse				<u>104</u>		
<u>93</u>	1B	Heated Line Rinse				<u>88</u>		
<u>94</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>100</u>	<u>550</u>		
<u>95</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>96</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-3</u>	<u>247</u>		
<u>97</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.3960 g Filter Net wt: 0.0002 g
Filter Tare wt: 0.3958 g Probe/Line Rinse wt: 0 g
Filter Net wt: 0.0002 g Total Particulate wt: 0.0002 g
Condensate Total: 105.4 ml

Recovered By: Ju Date: 1-26-05

Location: Stack Task: 2 Test: 4 Operator: Keith

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids <u>33</u>						
<u>98</u>	1A	Probe & Filter Rinse				<u>116</u>		
<u>99</u>	1B	Heated Line Rinse				<u>—</u>		
<u>100</u>	2	KCl Impingers	<u>300</u>	<u>150</u>	<u>248</u>	<u>698</u>		
<u>101</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>	<u>0</u>	<u>175</u>		
<u>102</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>	<u>-3</u>	<u>247</u>		
<u>102</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: 0.4080 g Filter Net wt: 0.0040 g
Filter Tare wt: 0.4040 g Probe/Line Rinse wt: 0 g
Filter Net wt: 0.0040 g Total Particulate wt: 0.0040 g
Condensate Total: 256.4 ml

Recovered By: Ju Date: 1-26-05

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
	KCl Blank		
	HNO ₃ / H ₂ O ₂ Blank		
	KMnO ₄ Blank		
	HNO ₃ / HCl Blank		

Project No	Test	Date	Loc.	Operator	Sample ID #	Task	Description	Anal No.	Hg
1621-87	1	02/01/05	ECONOUT	#VALUE!	1	2	PROBE & FILTER RINSE	20050484	<1.0 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	2	2	HEATED LINE RINSE	20050485	1.7 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	3	2	KCL IMPINGER	20050486	12.1 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	4	2	HNO3/H2O2 IMPINGER	20050487	2.7 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	5	2	KMNO4 IMPINGER	20050488	19.3 ng/ml
1621-87	1	02/01/05	ECONOUT	#VALUE!	6	2	KMNO4 ACID RINSE	20050489	<1.0 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	7	2	PROBE & FILTER RINSE	20050490	1.6 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	8	2	HEATED LINE RINSE	20050491	2.5 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	9	2	KCL IMPINGER	20050492	15.3 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	10	2	HNO3/H2O2 IMPINGER	20050493	<0.2 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	11	2	KMNO4 IMPINGER	20050494	<0.2 ng/ml
1621-87	1	02/01/05	AHO	#VALUE!	12	2	KMNO4 ACID RINSE	20050495	1.5 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	13	2	PROBE & FILTER RINSE	20050496	1.5 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	14	2	HEATED LINE RINSE	20050497	<1.0 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	15	2	KCL IMPINGER	20050498	22.4 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	16	2	HNO3/H2O2 IMPINGER	20050499	<0.2 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	17	2	KMNO4 IMPINGER	20050500	<0.2 ng/ml
1621-87	1	02/01/05	FGDIN	#VALUE!	18	2	KMNO4 ACID RINSE	20050501	1.4 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	19	2	PROBE & FILTER RINSE	20050502	1.7 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	20	2	KCL IMPINGER	20050503	0.4 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	21	2	HNO3/H2O2 IMPINGER	20050504	<0.2 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	22	2	KMNO4 IMPINGER	20050505	0.9 ng/ml
1621-87	1	02/01/05	STACK	#VALUE!	23	2	KMNO4 ACID RINSE	20050506	<1.0 ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	24	#VALUE!	KCL BLANK	20050507	<0.2 ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	25	#VALUE!	HNO3/H2O2 BLANK	20050508	<0.2 ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	26	#VALUE!	KMNO4 BLANK	20050509	<0.2 ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	27	#VALUE!	HNO3/HCL BLANK	20050510	<0.2 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	28	2	PROBE & FILTER RINSE	20050511	<1.0 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	29	2	HEATED LINE RINSE	20050512	3.5 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	30	2	KCL IMPINGER	20050513	11.5 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	31	2	HNO3/H2O2 IMPINGER	20050514	0.2 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	32	2	KMNO4 IMPINGER	20050515	19.8 ng/ml
1621-87	2	02/01/05	ECONOUT	#VALUE!	33	2	KMNO4 ACID RINSE	20050516	<1.0 ng/ml

1621-87	2	02/01/05	AHO	#VALUE!	34	2	PROBE & FILTER RINSE	20050517	1.1	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	35	2	HEATED LINE RINSE	20050518	1.5	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	36	2	KCL IMPINGER	20050519	14.3	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	37	2	HNO3/H2O2 IMPINGER	20050520	<0.2	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	38	2	KMNO4 IMPINGER	20050521	0.4	ng/ml
1621-87	2	02/01/05	AHO	#VALUE!	39	2	KMNO4 ACID RINSE	20050522	1.1	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	40	2	PROBE & FILTER RINSE	20050523	<1.0	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	41	2	HEATED LINE RINSE	20050524	2.1	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	42	2	KCL IMPINGER	20050525	23.0	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	43	2	HNO3/H2O2 IMPINGER	20050526	<0.2	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	44	2	KMNO4 IMPINGER	20050527	0.2	ng/ml
1621-87	2	02/01/05	FGDIN	#VALUE!	45	2	KMNO4 ACID RINSE	20050528	1.3	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	46	2	PROBE & FILTER RINSE	20050529	1.7	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	47	2	KCL IMPINGER	20050530	0.9	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	48	2	HNO3/H2O2 IMPINGER	20050531	<0.2	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	49	2	KMNO4 IMPINGER	20050532	0.7	ng/ml
1621-87	2	02/01/05	STACK	#VALUE!	50	2	KMNO4 ACID RINSE	20050533	1.4	ng/ml
1621-87	#VALUE!	02/01/05	ECONOUT	#VALUE!	51	IMP	KCL IMPINGER	20050534	<0.2	ng/ml
1621-87	#VALUE!	02/01/05	ECONOUT	#VALUE!	52	IMP	HNO3/H2O2 IMPINGER	20050535	<0.2	ng/ml
1621-87	#VALUE!	02/01/05	ECONOUT	#VALUE!	53	IMP	KMNO4 IMPINGER	20050536	<0.2	ng/ml
1621-87	#VALUE!	02/01/05	ECONOUT	#VALUE!	54	IMP	KMNO4 ACID RINSE	20050537	<1.0	ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	55	#VALUE!	KMNO4 BLANK	20050538	<0.2	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	56	2	PROBE & FILTER RINSE	20050539	<1.0	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	57	2	HEATED LINE RINSE	20050540	1.3	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	58	2	KCL IMPINGER	20050541	11.9	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	59	2	HNO3/H2O2 IMPINGER	20050542	<0.2	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	60	2	KMNO4 IMPINGER	20050543	13.7	ng/ml
1621-87	3	02/01/05	ECONOUT	#VALUE!	61	2	KMNO4 ACID RINSE	20050544	1.4	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	62	2	PROBE & FILTER RINSE	20050545	<1.0	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	63	2	HEATED LINE RINSE	20050546	1.1	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	64	2	KCL IMPINGER	20050547	16.6	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	65	2	HNO3/H2O2 IMPINGER	20050548	<0.2	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	66	2	KMNO4 IMPINGER	20050549	0.8	ng/ml
1621-87	3	02/01/05	AHO	#VALUE!	67	2	KMNO4 ACID RINSE	20050550	<1.0	ng/ml

1621-87	3	02/01/05	FGDIN	#VALUE!	68	2	PROBE & FILTER RINSE	20050551	<1.0	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	69	2	HEATED LINE RINSE	20050552	2.6	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	70	2	KCL IMPINGER	20050553	21.7	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	71	2	HNO3/H2O2 IMPINGER	20050554	<0.2	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	72	2	KMNO4 IMPINGER	20050555	<0.2	ng/ml
1621-87	3	02/01/05	FGDIN	#VALUE!	73	2	KMNO4 ACID RINSE	20050556	1.1	ng/ml
1621-87	3	02/01/05	STACK	#VALUE!	74	2	PROBE & FILTER RINSE	20050557	<1.0	ng/ml
1621-87	3	02/01/05	STACK	#VALUE!	75	2	KCL IMPINGER	20050558	<0.2	ng/ml
1621-87	3	02/01/05	STACK	#VALUE!	76	2	HNO3/H2O2 IMPINGER	20050559	<0.2	ng/ml
1621-87	3	02/01/05	STACK	#VALUE!	77	2	KMNO4 IMPINGER	20050560	0.6	ng/ml
1621-87	3	02/01/05	STACK	#VALUE!	78	2	KMNO4 ACID RINSE	20050561	1.2	ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	79	#VALUE!	KMNO4 BLANK	20050562	<0.2	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	80	2	PROBE & FILTER RINSE	20050563	<1.0	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	81	2	HEATED LINE RINSE	20050564	2.2	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	82	2	KCL IMPINGER	20050565	8.8	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	83	2	HNO3/H2O2 IMPINGER	20050566	0.3	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	84	2	KMNO4 IMPINGER	20050567	15.9	ng/ml
1621-87	4	02/01/05	ECONOUT	#VALUE!	85	2	KMNO4 ACID RINSE	20050568	1.5	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	86	2	PROBE & FILTER RINSE	20050569	<1.0	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	87	2	HEATED LINE RINSE	20050570	2.6	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	88	2	KCL IMPINGER	20050571	12.3	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	89	2	HNO3/H2O2 IMPINGER	20050572	<0.2	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	90	2	KMNO4 IMPINGER	20050573	<0.2	ng/ml
1621-87	4	02/01/05	AHO	#VALUE!	91	2	KMNO4 ACID RINSE	20050574	<1.0	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	92	2	PROBE & FILTER RINSE	20050575	<1.0	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	93	2	HEATED LINE RINSE	20050576	1.4	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	94	2	KCL IMPINGER	20050577	18.2	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	95	2	HNO3/H2O2 IMPINGER	20050578	<0.2	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	96	2	KMNO4 IMPINGER	20050579	0.2	ng/ml
1621-87	4	02/01/05	FGDIN	#VALUE!	97	2	KMNO4 ACID RINSE	20050580	1.5	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	98	2	PROBE & FILTER RINSE	20050581	1.9	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	99	2	KCL IMPINGER	20050582	<0.2	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	100	2	HNO3/H2O2 IMPINGER	20050583	<0.2	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	101	2	KMNO4 IMPINGER	20050584	0.4	ng/ml
1621-87	4	02/01/05	STACK	#VALUE!	102	2	KMNO4 ACID RINSE	20050585	<1.0	ng/ml
1621-87	#VALUE!	02/01/05	FGDIN	#VALUE!	103	IMP	KCL IMPINGER	20050586	<0.2	ng/ml
1621-87	#VALUE!	02/01/05	FGDIN	#VALUE!	104	IMP	HNO3/H2O2 IMPINGER	20050587	<0.2	ng/ml
1621-87	#VALUE!	02/01/05	FGDIN	#VALUE!	105	IMP	KMNO4 IMPINGER	20050588	<0.2	ng/ml
1621-87	#VALUE!	02/01/05	FGDIN	#VALUE!	106	IMP	KMNO4 ACID RINSE	20050589	<1.0	ng/ml
1621-87	#VALUE!	02/01/05	#VALUE!	#VALUE!	107	#VALUE!	KMNO4 BLANK	20050590	<0.2	ng/ml

Run 1 Particulate in Thimbles by ASTM D6722, Direct Combustion

ANALNUM	SAMPLE	DATE	DESCR	Hg	
20050627	5	01/24/05	ECON OUT 1 THIMBLE	0.017	PPM
20050628	13	01/24/05	AHO-1 THIMBLE	0.283	PPM
20050631	7	01/25/05	ECON OUT 2 THIMBLE	0.015	PPM
20050632	14	01/25/05	AHO-2 THIMBLE	0.653	PPM
20050635	6	01/25/05	ECON OUT 3 THIMBLE	0.016	PPM
20050636	15	01/25/05	AHO-3 THIMBLE	0.314	PPM
20050639	8	01/26/05	ECON OUT 4 THIMBLE	0.019	PPM
20050640	16	01/26/05	AHO-4 THIMBLE	0.379	PPM

NIST 1633B (also used as Continuing Calibration Verification)

						PPM		
1633B						0.153	109%	good
1633B						0.153	109%	good

Run 2 Filters by ASTM 6414, Acid Digestion/CVAA

ANALNUM	SAMPLE	DATE	DESCR	Hg	
20050629	34	01/24/05	FGD-1 3-IN FILTER	<5.0	ng/filter
20050630	27	01/24/05	STK-1 3-IN FILTER	<5.0	ng/filter
20050633	35	01/25/05	FGD-2 3-IN FILTER	<5.0	ng/filter
20050634	31	01/25/05	STK-2 3-IN FILTER	<5.0	ng/filter
20050637	36	01/25/05	FGD-3 3-IN FILTER	<5.0	ng/filter
20050638	32	01/25/05	STK-3 3-IN FILTER	<5.0	ng/filter
20050641	37	01/26/05	FGD-4 3-IN FILTER	<5.0	ng/filter
20050642	33	01/26/05	STK-4 3-IN FILTER	<5.0	ng/filter
20050644	47-B	01/26/05	47-B 47 MM FILTER	<5.0	ng/filter
20050645	3IN-B	01/26/05	3IN-B 3-IN FILTER	<5.0	ng/filter
20050643	THM-B	01/26/05	THM-B THIMBLE	<0.005	PPM

NIST 1633B

						PPM		
1633B						0.128	91%	good

Continuing Calibration Verification

						ng/ml		
1641d 8 ppb						8.2	103%	good
1641d 8ppb						8.2	103%	good
1641d 8ppb						8.2	103%	good
1641d 8ppb						8.3	104%	good

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ECON OUT 1 THIMBLE
UNIT 2
DATE SAMPLED 01/24/05
SAMPLE NUMBER 5

DATE LOGGED 02/03/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050627

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	95.52	Carbon	4.19	Silicon	49.24
		Ash	95.52	Al2O3	24.14
<u>MISC. (As Det.)</u>				TiO2	1.40
MERCURY	0.017 PPM			Fe2O3	12.98
				CaO	1.64
				MgO	1.05
				Na2O	0.54
				K2O	2.39
				P2O5	0.30
				SO3	0.53
				UND	5.79

AS DETERMINED MOISTURE: 0.19 %

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AHO-1 THIMBLE
UNIT 2
DATE SAMPLED 01/24/05
SAMPLE NUMBER 13


DATE LOGGED 02/03/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050628

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.28	Carbon	5.52	Silicon	48.07
		Ash	93.28	Al2O3	23.35
<u>MISC. (As Det.)</u>				TiO2	1.32
MERCURY	0.283 PPM			Fe2O3	12.81
				CaO	1.50
				MgO	1.01
				Na2O	0.53
				K2O	2.33
				P2O5	0.28
				SO3	0.78
				UND	8.02

AS DETERMINED MOISTURE: 0.35 %

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal 

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION FGD-1 3-IN FILTER
UNIT 2

DATE SAMPLED 01/24/05
SAMPLE NUMBER 34


DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050629

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal  _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION STK-1 3-IN FILTER
UNIT 2

DATE SAMPLED 01/24/05
SAMPLE NUMBER 27


DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050630

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal 

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ECON OUT 2 THIMBLE
UNIT 2
DATE SAMPLED 01/25/05
SAMPLE NUMBER 7


DATE LOGGED 02/03/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050631

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.83	Carbon	5.68	Silicon	47.65
		Ash	93.83	Al2O3	26.35
<u>MISC. (As Det.)</u>				TiO2	1.37
MERCURY	0.015 PPM			Fe2O3	9.91
				CaO	1.44
				MgO	0.93
				Na2O	0.50
				K2O	2.41
				P2O5	0.35
				SO3	0.53
				UND	8.56

AS DETERMINED MOISTURE: 0.27 %

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal 

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AHO-2 THIMBLE
UNIT 2
DATE SAMPLED 01/25/05
SAMPLE NUMBER 14

DATE LOGGED 02/03/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050632

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.18	Carbon	6.45	Silicon	48.11
		Ash	93.18	Al2O3	26.00
<u>MISC. (As Det.)</u>				TiO2	1.37
				Fe2O3	10.23
MERCURY	0.653 PPM			CaO	1.46
				MgO	0.92
				Na2O	0.47
				K2O	2.38
				P2O5	0.33
				SO3	0.65
				UND	8.08

AS DETERMINED MOISTURE: 0.37 %

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal



CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION FGD-2 3-IN FILTER
UNIT 2

DATE SAMPLED 01/25/05
SAMPLE NUMBER 35

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050633

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal



CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION STK-2 3-IN FILTER
UNIT 2
DATE SAMPLED 01/25/05
SAMPLE NUMBER 31

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050634


ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ECON OUT 3 THIMBLE
 UNIT 2
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER 6

DATE LOGGED 02/03/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050635


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.64	Carbon	6.24	Silicon	49.70
		Ash	93.64	Al2O3	26.71
<u>MISC. (As Det.)</u>				TiO2	1.42
MERCURY	0.016 PPM			Fe2O3	9.71
				CaO	1.45
				MgO	0.95
				Na2O	0.49
				K2O	2.47
				P2O5	0.39
				SO3	0.42
				UND	6.29

AS DETERMINED MOISTURE: 0.22 %

DISTRIBUTION:
 J. WITHUM
 J. LOCKE
 S. TSENG

Approved for transmittal



CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AHO-3 THIMBLE
UNIT 2
DATE SAMPLED 01/25/05
SAMPLE NUMBER 15

DATE LOGGED 02/03/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050636

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	91.72	Carbon	7.45	Silicon	48.48
		Ash	91.72	Al2O3	26.48
<u>MISC. (As Det.)</u>				TiO2	1.38
MERCURY	0.314 PPM			Fe2O3	9.74
				CaO	1.37
				MgO	0.92
				Na2O	0.51
				K2O	2.49
				P2O5	0.38
				SO3	0.73
				UND	7.52

AS DETERMINED MOISTURE: 0.28 %

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION FGD-3 3-IN FILTER
UNIT 2
DATE SAMPLED 01/25/05
SAMPLE NUMBER 36


DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050637

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal 

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION STK-3 3-IN FILTER
UNIT 2
DATE SAMPLED 01/25/05
SAMPLE NUMBER 32

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050638

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ECON OUT 4 THIMBLE
 UNIT 2

DATE SAMPLED 01/26/05
 SAMPLE NUMBER 8

DATE LOGGED 02/03/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050639

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	94.96	Carbon	5.00	Silicon	50.78
		Ash	94.96	Al2O3	26.93
<u>MISC. (As Det.)</u>				TiO2	1.53
MERCURY	0.019 PPM			Fe2O3	8.69
				CaO	1.52
				MgO	0.91
				Na2O	0.52
				K2O	2.36
				P2O5	0.50
				SO3	0.42
				UND	5.84

AS DETERMINED MOISTURE: 0.19 %

DISTRIBUTION:
 J. WITHUM
 J. LOCKE
 S. TSENG

Approved for transmittal: _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH 'PARK, PA 15129

DESCRIPTION AHO-4 THIMBLE
UNIT 2
DATE SAMPLED 01/26/05
SAMPLE NUMBER 16


DATE LOGGED 02/03/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050640

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.91	Carbon	6.49	Silicon	50.68
		Ash	92.91	Al2O3	25.89
<u>MISC. (As Det.)</u>				TiO2	1.47
MERCURY	0.379 PPM			Fe2O3	9.00
				CaO	1.51
				MgO	0.89
				Na2O	0.46
				K2O	2.26
				P2O5	0.46
				SO3	0.58
				UND	6.80

AS DETERMINED MOISTURE: 0.28 %

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal 

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION FGD-4 3-IN FILTER
UNIT 2
DATE SAMPLED 01/26/05
SAMPLE NUMBER 37

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050641


ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal



CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION STK-4 3-IN FILTER
UNIT 2

DATE SAMPLED 01/26/05
SAMPLE NUMBER 33


DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050642

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal 

Unit 1

Thumb + filter numbers

Test	Exc Out Day: Thumb	AWH Out Jimm Thumb	FGD in Jeff 47 AM	Stack Keith 3"
1	1	9	17	23
2	2	10	18	24
3	3	11	19	25
4	4	12	20	26

Unit 2

Test	Exc Out Day:	AH. Out Jimm	FGD in Jeff	Stack Keith
1	5	13	34	27
2	7	14	35	31
3	8	15	36	32
4	8	16	37	33
	Thumb	Thumb	3"	3"

34 Jeff Unit 2 test 1-2-3-4

34 0.4025

25 0.3987

35 0.3970

37 0.3958

Unit 1

Distribution: Wether-Loche
Project No.: 1621-87
Sample Date: 1-21-05

Location: Blow Unit Task: 1 Test: 4 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
<u>99</u>	2	KCl Impingers	<u>300</u>	<u>150</u>		<u>450</u>		
<u>100</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>		<u>175</u>		
<u>101</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>		<u>250</u>		
<u>102</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: _____g Filter Net wt: _____g
Filter Tare wt: _____g Probe/Line Rinse wt: _____g Condensate Total: _____ml
Filter Net wt: _____g Total Particulate wt: _____g

Recovered By: Ju Date: 1-21-05
Location: Blow Unit Task: 1 Test: 4 Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
<u>104</u>	2	KCl Impingers	<u>300</u>	<u>150</u>		<u>450</u>		
<u>105</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>		<u>175</u>		
<u>106</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>		<u>250</u>		
<u>107</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: _____g Filter Net wt: _____g
Filter Tare wt: _____g Probe/Line Rinse wt: _____g Condensate Total: _____ml
Filter Net wt: _____g Total Particulate wt: _____g

Recovered By: Ju Date: 1-21-05
Location: FGD In Task: _____ Test: _____ Operator: _____

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
	2	KCl Impingers						
	3	HNO ₃ /H ₂ O ₂ Impinger						
	4	KMnO ₄ Impingers						
	5	KMnO ₄ Acid Rinse						

Filter Gross wt: _____g Filter Net wt: _____g
Filter Tare wt: _____g Probe/Line Rinse wt: _____g Condensate Total: _____ml
Filter Net wt: _____g Total Particulate wt: _____g

Recovered By: _____ Date: _____
Location: Stack Task: _____ Test: _____ Operator: _____

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
	2	KCl Impingers						
	3	HNO ₃ /H ₂ O ₂ Impinger						
	4	KMnO ₄ Impingers						
	5	KMnO ₄ Acid Rinse						

Filter Gross wt: _____g Filter Net wt: _____g
Filter Tare wt: _____g Probe/Line Rinse wt: _____g Condensate Total: _____ml
Filter Net wt: _____g Total Particulate wt: _____g

Recovered By: _____ Date: _____

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
	KCl Blank		
	HNO ₃ / H ₂ O ₂ Blank		
<u>103</u>	KMnO ₄ Blank		
	HNO ₃ / HCl Blank		

Unit 2

Distribution: Matthew Locke
Project No.: 1621-87
Sample Date: 1-26-05

Location: FGD IN Task: Blank Test: _____ Operator: Jeff

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
<u>103</u>	2	KCl Impingers	<u>300</u>	<u>150</u>		<u>450</u>		
<u>104</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>		<u>175</u>		
<u>105</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>		<u>250</u>		
<u>106</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: _____ g Filter Net wt: _____ g
Filter Tare wt: _____ g Probe/Line Rinse wt: _____ g Condensate Total: _____ ml
Filter Net wt: _____ g Total Particulate wt: _____ g

Recovered By: J Date: 1-26-05

Location: AHO Task: _____ Test: _____ Operator: _____

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
	2	KCl Impingers						
	3	HNO ₃ /H ₂ O ₂ Impinger						
	4	KMnO ₄ Impingers						
	5	KMnO ₄ Acid Rinse						

Filter Gross wt: _____ g Filter Net wt: _____ g
Filter Tare wt: _____ g Probe/Line Rinse wt: _____ g Condensate Total: _____ ml
Filter Net wt: _____ g Total Particulate wt: _____ g

Recovered By: _____ Date: _____

Location: FGD In Task: _____ Test: _____ Operator: _____

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
	2	KCl Impingers						
	3	HNO ₃ /H ₂ O ₂ Impinger						
	4	KMnO ₄ Impingers						
	5	KMnO ₄ Acid Rinse						

Filter Gross wt: _____ g Filter Net wt: _____ g
Filter Tare wt: _____ g Probe/Line Rinse wt: _____ g Condensate Total: _____ ml
Filter Net wt: _____ g Total Particulate wt: _____ g

Recovered By: _____ Date: _____

Location: Stack Task: _____ Test: _____ Operator: _____

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
	2	KCl Impingers						
	3	HNO ₃ /H ₂ O ₂ Impinger						
	4	KMnO ₄ Impingers						
	5	KMnO ₄ Acid Rinse						

Filter Gross wt: _____ g Filter Net wt: _____ g
Filter Tare wt: _____ g Probe/Line Rinse wt: _____ g Condensate Total: _____ ml
Filter Net wt: _____ g Total Particulate wt: _____ g

Recovered By: _____ Date: _____

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
	KCl Blank		
	HNO ₃ / H2O2 Blank		
<u>107</u>	KMnO ₄ Blank		
	HNO ₃ / HCl Blank		

Distribution: Whiskum - Roche
Project No.: 1621-87
Sample Date: 1-25-05

Location: Econ Out Task: 2nd rinse Test: _____ Operator: Jerry

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
<u>51</u>	2	KCl Impingers	<u>300</u>	<u>150</u>		<u>450</u>		
<u>52</u>	3	HNO ₃ /H ₂ O ₂ Impinger	<u>100</u>	<u>75</u>		<u>175</u>		
<u>53</u>	4	KMnO ₄ Impingers	<u>200</u>	<u>50</u>		<u>250</u>		
<u>54</u>	5	KMnO ₄ Acid Rinse		<u>100</u>		<u>100</u>		

Filter Gross wt: _____ g Filter Net wt: _____ g
Filter Tare wt: _____ g Probe/Line Rinse wt: _____ g Condensate Total: _____ ml
Filter Net wt: _____ g Total Particulate wt: _____ g

Recovered By: J Date: 1-25-05

Location: AHO Task: _____ Test: _____ Operator: _____

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
	2	KCl Impingers						
	3	HNO ₃ /H ₂ O ₂ Impinger						
	4	KMnO ₄ Impingers						
	5	KMnO ₄ Acid Rinse						

Filter Gross wt: _____ g Filter Net wt: _____ g
Filter Tare wt: _____ g Probe/Line Rinse wt: _____ g Condensate Total: _____ ml
Filter Net wt: _____ g Total Particulate wt: _____ g

Recovered By: _____ Date: _____

Location: FGD In Task: _____ Test: _____ Operator: _____

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
	2	KCl Impingers						
	3	HNO ₃ /H ₂ O ₂ Impinger						
	4	KMnO ₄ Impingers						
	5	KMnO ₄ Acid Rinse						

Filter Gross wt: _____ g Filter Net wt: _____ g
Filter Tare wt: _____ g Probe/Line Rinse wt: _____ g Condensate Total: _____ ml
Filter Net wt: _____ g Total Particulate wt: _____ g

Recovered By: _____ Date: _____

Location: Stack Task: _____ Test: _____ Operator: _____

Sample ID	Bottle #	Description	Initial Vol mL	Rinse Vol mL	Gain mL	Final Vol mL	ppb Hg	Total ug of Hg
	S	Filter/Solids						
	1A	Probe & Filter Rinse						
	1B	Heated Line Rinse						
	2	KCl Impingers						
	3	HNO ₃ /H ₂ O ₂ Impinger						
	4	KMnO ₄ Impingers						
	5	KMnO ₄ Acid Rinse						

Filter Gross wt: _____ g Filter Net wt: _____ g
Filter Tare wt: _____ g Probe/Line Rinse wt: _____ g Condensate Total: _____ ml
Filter Net wt: _____ g Total Particulate wt: _____ g

Recovered By: _____ Date: _____

Sample ID	Description	ppb Hg	Total ug of Hg
	3 in. Filter Blank		
	Thimble Blank		
	KCl Blank		
	HNO ₃ / H ₂ O ₂ Blank		
<u>55</u>	KMnO ₄ Blank		
	HNO ₃ / HCl Blank		

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION THM-B THIMBLE
BLANK
DATE SAMPLED 01/26/05
SAMPLE NUMBER THM-B

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050643

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <0.005 PPM

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION 47-B 47 MM FILTER
BLANK

DATE SAMPLED 01/26/05
SAMPLE NUMBER 47-B

DATE LOGGED 02/03/05
DATE COMPLETED 03/04/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050644

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:
J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION 3IN-B 3-IN FILTER
BLANK

DATE SAMPLED 01/26/05
SAMPLE NUMBER 3IN-B

DATE LOGGED 02/03/05
DATE COMPLETED 02/11/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050645

ANALYSIS REPORT

MISC. (As Det.)

MERCURY <5.0 NG/FIL

DISTRIBUTION:

J. WITHUM
J. LOCKE
S. TSENG

Approved for transmittal _____

APPENDIX D

Process Material Data

- Coal Analysis Data Sheets
- Bottom Ash Analysis Data Sheets
- Limestone Slurry Solids Analysis Data Sheets
- Limestone Slurry Filtrate Analysis Data Sheets
- Ash Analysis Data Sheets
- FGD Slurry Solids Analysis Data Sheets
- FGD Slurry Filtrate Data Sheets
- FGD Makeup Water Analysis Data Sheets

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AS-FIRED COAL
 UNIT 1 TEST 1
 DATE SAMPLED 01/19/05
 SAMPLE NUMBER COAL-UIT1

DATE LOGGED 02/07/05
 DATE COMPLETED 02/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050682

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	7.77	Carbon	77.74	Ignited at 750 C	
Volatile Matter	38.08	Hydrogen	4.63	Silicon	50.01
Fixed Carbon	54.15	Nitrogen	1.56	Al2O3	27.77
		Chlorine	0.144	TiO2	1.29
Sulfur, Total	1.39	Sulfur, Total	1.39	Fe2O3	12.63
BTU/lb	13683	Ash	7.77	CaO	1.73
MAF BTU/lb	14836	Oxygen (DIFF)	6.77	MgO	1.00
				Na2O	0.55
				K2O	2.28
				P2O5	0.18
				SO3	1.68
				UND	0.88
<u>MISC. (As Det.)</u>					
Hg	0.091 PPM				

AS DETERMINED MOISTURE: 2.00 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AS-FIRED COAL
 UNIT 1 TESTS 2&3
 DATE SAMPLED 01/20/05
 SAMPLE NUMBER COAL-U1T2T3

DATE LOGGED 02/07/05
 DATE COMPLETED 02/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050683

ANALYSIS REPORT

<u>PROXIMATE</u> (Dry)%	<u>ULTIMATE</u> (Dry)%	<u>MAJOR ASH ELEM</u> %
		Ignited at 750 C
Ash 8.24	Carbon 77.01	Silicon 50.46
Volatile Matter 38.40	Hydrogen 4.81	Al2O3 26.57
Fixed Carbon 53.36	Nitrogen 1.61	TiO2 1.34
	Chlorine 0.143	Fe2O3 12.73
Sulfur, Total 1.45	Sulfur, Total 1.45	CaO 1.69
BTU/lb 13686	Ash 8.24	MgO 0.98
MAF BTU/lb 14915	Oxygen (DIFF) 6.74	Na2O 0.53
		K2O 2.29
		P2O5 0.25
		SO3 1.62
		UND 1.54
<u>MISC. (As Det.)</u>		
Hg 0.110 PPM		

AS DETERMINED MOISTURE: 1.89 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

Stanton

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AS-FIRED COAL
UNIT 1 TEST 4
DATE SAMPLED 01/21/05
SAMPLE NUMBER COAL-UIT4

DATE LOGGED 02/07/05
DATE COMPLETED 02/15/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050684

ANALYSIS REPORT

<u>PROXIMATE</u> (Dry)%		<u>ULTIMATE</u> (Dry)%		<u>MAJOR ASH ELEM</u> %	
Ash	11.85	Carbon	74.83	Ignited at 750 C	
Volatile Matter	37.32	Hydrogen	4.65	Silicon	54.52
Fixed Carbon	50.83	Nitrogen	1.58	Al2O3	26.87
		Chlorine	0.157	TiO2	1.09
Sulfur, Total	1.19	Sulfur, Total	1.19	Fe2O3	9.17
BTU/lb	13205	Ash	11.85	CaO	1.50
MAF BTU/lb	14980	Oxygen (DIFF)	5.74	MgO	1.17
				Na2O	0.63
<u>MISC. (As Det.)</u>				K2O	2.90
Hg	0.066 PPM			P2O5	0.11
				SO3	1.24
				UND	0.80

AS DETERMINED MOISTURE: 1.37 %

DISTRIBUTION:
S. TSENG
J. LOCKE
J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AS-FIRED COAL
 UNIT 2 TEST 1
 DATE SAMPLED 01/24/05
 SAMPLE NUMBER COAL-U2T1


DATE LOGGED 02/07/05
 DATE COMPLETED 02/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050685

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
				Ignited at 750 C	
Ash	8.40	Carbon	77.39	Silicon	49.70
Volatile Matter	38.57	Hydrogen	4.72	Al2O3	24.10
Fixed Carbon	53.03	Nitrogen	1.52	TiO2	1.15
		Chlorine	0.141	Fe2O3	16.77
Sulfur, Total	1.66	Sulfur, Total	1.66	CaO	1.68
BTU/lb	13764	Ash	8.40	MgO	1.16
MAF BTU/lb	15026	Oxygen (DIFF)	6.17	Na2O	0.57
				K2O	2.58
<u>MISC. (As Det.)</u>				P2O5	0.22
Hg	0.145 PPM			SO3	1.52
				UND	0.55

AS DETERMINED MOISTURE: 1.83 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AS-FIRED COAL
 UNIT 2 TESTS 2&3
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER COAL-U2T2T3

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050686

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
				Ignited at 75 C	
Ash	8.69	Carbon	76.66	Silicon	51.13
Volatile Matter	36.26	Hydrogen	4.67	Al2O3	23.98
Fixed Carbon	55.05	Nitrogen	1.46	TiO2	1.05
		Chlorine	0.135	Fe2O3	15.05
Sulfur, Total	1.59	Sulfur, Total	1.59	CaO	2.81
BTU/lb	13663	Ash	8.69	MgO	0.72
MAF BTU/lb	14963	Oxygen (DIFF)	6.80	Na2O	0.65
				K2O	1.86
<u>MISC. (As Det.)</u>				P2O5	0.35
Hg	0.163 PPM			SO3	1.54
				UND	0.86

AS DETERMINED MOISTURE: 1.49 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION AS-FIRED COAL
 UNIT 2 TEST 4
 DATE SAMPLED 01/26/05
 SAMPLE NUMBER COAL-U2T4

DATE LOGGED 02/07/05
 DATE COMPLETED 03/02/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050687

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
				Ignited at 75 C	
Ash	8.28	Carbon	77.44	Silicon	50.50
Volatile Matter	35.46	Hydrogen	4.77	Al2O3	28.16
Fixed Carbon	56.26	Nitrogen	1.53	TiO2	1.41
		Chlorine	0.151	Fe2O3	11.76
Sulfur, Total	1.38	Sulfur, Total	1.38	CaO	1.58
BTU/lb	13761	Ash	8.28	MgO	0.95
MAF BTU/lb	15003	Oxygen (DIFF)	6.45	Na2O	0.53
				K2O	2.35
<u>MISC. (As Det.)</u>				P2O5	0.47
Hg	0.113 PPM			SO3	1.39
				UND	0.90

AS DETERMINED MOISTURE: 1.61 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION MILL REJECTS
 UNIT 1 TEST 1
 DATE SAMPLED 01/19/05
 SAMPLE NUMBER REJECTS U1T1

DATE LOGGED 02/07/05
 DATE COMPLETED 02/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050688

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
				Ignited at 750 C	
Ash	14.88	Carbon	69.43	Silicon	45.98
Volatile Matter	35.77	Hydrogen	4.25	Al2O3	22.24
Fixed Carbon	49.35	Nitrogen	1.32	TiO2	1.22
		Chlorine	0.085	Fe2O3	21.31
Sulfur, Total	3.20	Sulfur, Total	3.20	CaO	2.18
BTU/lb	12413	Ash	14.88	MgO	0.81
MAF BTU/lb	14583	Oxygen (DIFF)	6.84	Na2O	0.48
				K2O	1.63
<u>MISC. (As Det.)</u>				P2O5	0.35
Hg	0.426 PPM			SO3	1.62
				UND	2.18

AS DETERMINED MOISTURE: 1.50 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION MILL REJECTS
 UNIT 2 TEST 1
 DATE SAMPLED 01/24/05
 SAMPLE NUMBER REJECTS U2T1


DATE LOGGED 02/07/05
 DATE COMPLETED 02/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050689

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	39.74	Carbon	46.83	Ignited at 750 C	
Volatile Matter	28.78	Hydrogen	2.82	Silicon	45.27
Fixed Carbon	31.48	Nitrogen	0.81	Al2O3	17.97
		Chlorine	0.074	TiO2	0.88
Sulfur, Total	6.07	Sulfur, Total	6.07	Fe2O3	24.07
BTU/lb	8456	Ash	39.74	CaO	4.66
MAF BTU/lb	14033	Oxygen (DIFF)	3.66	MgO	0.85
				Na2O	0.28
<u>MISC. (As Det.)</u>				K2O	1.03
Hg	0.783 PPM			P2O5	0.22
				SO3	3.81
				UND	0.96

AS DETERMINED MOISTURE: 0.82 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION MILL REJECTS
 UNIT 2 TEST 2
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER REJECTS U2T2


DATE LOGGED 02/07/05
 DATE COMPLETED 02/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050690

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	46.20	Carbon	39.74	Ignited at 750 C	
Volatile Matter	30.88	Hydrogen	2.37	Silicon	28.75
Fixed Carbon	22.92	Nitrogen	0.66	Al2O3	11.82
		Chlorine	0.059	TiO2	0.46
Sulfur, Total	8.74	Sulfur, Total	8.74	Fe2O3	40.41
BTU/lb	6899	Ash	46.20	CaO	8.41
MAF BTU/lb	12823	Oxygen (DIFF)	2.23	MgO	0.89
				Na2O	0.21
<u>MISC. (As Det.)</u>				K2O	0.81
Hg	2.33 PPM			P2O5	0.13
				SO3	8.17
				UND	-0.06

AS DETERMINED MOISTURE: 0.68 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION MILL REJECTS 17:00
 UNIT 2 TEST 3
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER REJECTS U2T3

DATE LOGGED 02/07/05
 DATE COMPLETED 02/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050691

ANALYSIS REPORT

<u>PROXIMATE</u> (Dry)%	<u>ULTIMATE</u> (Dry)%	<u>MAJOR ASH ELEM</u> %
		Ignited at 750 C
Ash 58.31	Carbon 24.51	Silicon 25.07
Volatile Matter 26.31	Hydrogen 1.45	Al2O3 6.85
Fixed Carbon 15.38	Nitrogen 0.38	TiO2 0.33
	Chlorine 0.035	Fe2O3 52.03
Sulfur, Total 17.98	Sulfur, Total 17.98	CaO 7.45
BTU/lb 4502	Ash 58.31	MgO 0.68
MAF BTU/lb 10799	Oxygen (DIFF) 2.66	Na2O 0.17
		K2O 0.72
<u>MISC. (As Det.)</u>		P2O5 0.04
Hg 2.63 PPM		SO3 7.95
		UND -1.29

AS DETERMINED MOISTURE: 0.44 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION MILL REJECTS
 UNIT 2 TEST 4
 DATE SAMPLED 01/26/05
 SAMPLE NUMBER REJECTS U2T4

DATE LOGGED 02/07/05
 DATE COMPLETED 02/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050692

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
				Ignited at 750 C	
Ash	52.38	Carbon	32.41	Silicon	23.91
Volatile Matter	26.69	Hydrogen	1.95	Al2O3	6.99
Fixed Carbon	20.93	Nitrogen	0.53	TiO2	0.40
		Chlorine	0.036	Fe2O3	49.64
Sulfur, Total	14.97	Sulfur, Total	14.97	CaO	7.58
BTU/lb	5954	Ash	52.38	MgO	0.50
MAF BTU/lb	12503	Oxygen (DIFF)	2.28	Na2O	0.13
				K2O	0.59
<u>MISC. (As Det.)</u>				P2O5	0.04
Hg	3.00 PPM			SO3	8.54
				UND	1.68

AS DETERMINED MOISTURE: 0.48 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION BOTTOM ASH 16:30-16:40
UNIT 1 TEST 1
DATE SAMPLED 01/19/05
SAMPLE NUMBER BTMASH-UIT1

DATE LOGGED 02/07/05
DATE COMPLETED 03/16/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050693

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	99.73	Carbon	0.39	Silicon	51.91
Total Sulfur	0.02	Chlorine	0.025	Al2O3	25.87
		Ash	99.73	TiO2	1.36
<u>MISC. (As Det.)</u>				Fe2O3	13.81
Hg	0.011 PPM			CaO	1.45
				MgO	0.89
				Na2O	0.48
				K2O	2.18
				P2O5	0.14
				SO3	0.04
				UND	1.87

AS DETERMINED MOISTURE: 0.01 %

DISTRIBUTION:
S. TSENG
J. LOCKE
J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION BOTTOM ASH 16:30
 UNIT 1 TESTS 2&3

DATE SAMPLED 01/20/05
 SAMPLE NUMBER BTMASH-U1T2T3

DATE LOGGED 02/07/05
 DATE COMPLETED 03/16/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050694

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	99.99	Carbon	0.20	Silicon	52.37
Total Sulfur	0.00	Chlorine	0.027	Al2O3	25.86
		Ash	99.99	TiO2	1.38
<u>MISC. (As Det.)</u>				Fe2O3	14.13
Hg	0.011 PPM			CaO	1.47
				MgO	0.90
				Na2O	0.47
				K2O	2.19
				P2O5	0.16
				SO3	0.01
				UND	1.06

AS DETERMINED MOISTURE: 0.01 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION BOTTOM ASH 16:00-16:30
 UNIT 2 TESTS 2&3

DATE SAMPLED 01/25/05
 SAMPLE NUMBER BTMASH-U2T2T3

DATE LOGGED 02/07/05
 DATE COMPLETED 03/16/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050697


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	98.16	Carbon	1.93	Silicon	51.02
Total Sulfur	0.32	Chlorine	0.035	Al2O3	24.66
		Ash	98.16	TiO2	1.33
<u>MISC. (As Det.)</u>				Fe2O3	14.96
Hg	0.074 PPM			CaO	1.35
				MgO	0.92
				Na2O	0.46
				K2O	2.23
				P2O5	0.22
				SO3	0.80
				UND	2.05

AS DETERMINED MOISTURE: 0.10 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION BOTTOM ASH 11:15-11:45
 UNIT 2 TEST 4

DATE SAMPLED 01/26/05
 SAMPLE NUMBER BTMASH-U2T4

DATE LOGGED 02/07/05
 DATE COMPLETED 03/16/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050698

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	99.03	Carbon	1.12	Silicon	52.96
Total Sulfur	0.10	Chlorine	0.048	Al2O3	26.12
		Ash	99.03	TiO2	1.44
<u>MISC. (As Det.)</u>				Fe2O3	12.62
Hg	0.017 PPM			CaO	1.45
				MgO	0.91
				Na2O	0.47
				K2O	2.25
				P2O5	0.30
				SO3	0.24
				UND	1.24

AS DETERMINED MOISTURE: 0.01 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



BOTTOM ASH FILTRATE 16:30-16:40

Sample No.: BTMASH-U1T1

Date Received: 02/07/2005

Date Completed: 04/05/2005

Analytical No.: 20050780

Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 3452.19
Acidity, CaCO ₃					Cation Sum 57.07
Alkalinity, CaCO ₃					Anion Sum 60.87
Hydroxide, CaCO ₃					Ion Balance 3.62
Carbonate, CaCO ₃					% Ion Imbalance -3.22
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg</i> <1.0 <i>ng/ml</i>
Calcium	326.80				
Iron	<1.25				
Magnesium	217.38				
Manganese					
Potassium	68.44				
Phosphorous					
Silicon					
Sodium	485.84				
Chromium					
Anions:					
Sulfate	711.98				
Chloride	1620				
Nitrate, N	4.91				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

BOTTOM ASH FILTRATE 16:30

Sample No.: BTMASH-U1T2T3
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: **20050781**
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 3441.35
Acidity, CaCO ₃					Cation Sum 60.18
Alkalinity, CaCO ₃					Anion Sum 58.53
Hydroxide, CaCO ₃					Ion Balance -1.63
Carbonate, CaCO ₃					% Ion Imbalance 1.39
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg <1.0 ng/ml</i>
Calcium	344.97				
Iron	<1.25				
Magnesium	229.51				
Manganese					
Potassium	70.65				
Phosphorous					
Silicon					
Sodium	512.34				
Chromium					
Anions:					
Sulfate	762.09				
Chloride	1500				
Nitrate, N	4.92				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

BOTTOM ASH FILTRATE 16:00-16:30

Sample No.: BTMASH-U2T2T3

Date Received: 02/07/2005

Date Completed: 04/05/2005

Analytical No.: 20050782

Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result

(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 3022.40
Acidity, CaCO ₃					Cation Sum 51.73
Alkalinity, CaCO ₃					Anion Sum 51.14
Hydroxide, CaCO ₃					Ion Balance -0.66
Carbonate, CaCO ₃					% Ion Imbalance 0.57
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg</i> <1.0 <i>mg/l</i>
Calcium	309.00				
Iron	<1.25				
Magnesium	184.56				
Manganese					
Potassium	62.99				
Phosphorous					
Silicon					
Sodium	448.86				
Chromium					
Anions:					
Sulfate	748.34				
Chloride	1250				
Nitrate, N	4.21				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

BOTTOM ASH FILTRATE 11:15-11:45

Sample No.: BTMASH-U2T4
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: **20050783**
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 2706.68
Acidity, CaCO ₃					Cation Sum 49.56
Alkalinity, CaCO ₃					Anion Sum 43.56
Hydroxide, CaCO ₃					Ion Balance -7.67
Carbonate, CaCO ₃					% Ion Imbalance 6.44
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg</i> <1.0 <i>ng/ml</i>
Calcium	297.14				
Iron	<1.25				
Magnesium	175.00				
Manganese					
Potassium	60.95				
Phosphorous					
Silicon					
Sodium	431.88				
Chromium					
Anions:					
Sulfate	722.89				
Chloride	1000				
Nitrate, N	4.25				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

LIMESTONE SLURRY SOLIDS 09:35

Date Completed: 04/01/2005
Date Received: 2/7/05
Submitted by: S. TSENG

Project No.: 1621 - 087 - 000

UNIT 1 TEST 1

Analytical No.: 20050699

Sample No.: LS U1T1

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	56.69	Carbon	11.67	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.0500	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	56.69	
		Oxygen (DIFF)		
				<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
				Soft.
				Hemi.
				Fluid

Grindability

HGI
 At Moisture % 0.60
 0.00

Free Swelling Index

FSI

Trace Elements

Sulfur Form (Dry)

Pyritic Sulfur
 Sulfate
 Organic
 Sulfur, Total

Major Ash Elem.

as Def
 SiO2 1.49
 Al2O3 0.15
 TiO2 0.01
 Fe2O3 0.14
 CaO 53.60
 MgO 1.15
 Na2O 0.06
 K2O 0.03
 P2O5 0.08
 SO3 0.29

Misc.

Analysis Value

Hg 0.044 ppm
 Fluorine

Undetermined 43.00

As Determined Moisture 0.60 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

LIMESTONE SLURRY SOLIDS 09:45

Date Completed: 04/04/2005
 Date Received: 2/7/05
 Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
 Analytical No.: 20050700

UNIT 1 TEST 2

Sample No.: LS U1T2

<u>Proximate (Dry)</u> %	<u>Ultimate (Dry)</u> %	<u>Ash Fusion Reducing Temp.</u> °F
Ash 56.52	Carbon 11.34	I.D.
Volatile Matter	Hydrogen	Soft.
Fixed Carbon	Nitrogen	Hemi.
	Chlorine 0.0700	Fluid
BTU/lb	Sulfur, Total	
MAF BTU/lb	Ash 56.52	
	Oxygen (DIFF)	
		<u>Ash Fusion Oxidizing Temp.</u> °F
		I.D.
		Soft.
		Hemi.
		Fluid
<u>Grindability</u>	<u>Free Swelling Index</u>	
HGI	FSI	
At Moisture % 0.60		
0.00		
	<u>Trace Elements</u>	
<u>Sulfur Form (Dry)</u>		<u>Major Ash Elem.</u>
Pyritic Sulfur		as det.
Sulfate		SiO2 1.45
Organic		Al2O3 0.22
Sulfur, Total		TiO2 0.01
		Fe2O3 0.17
		CaO 53.39
		MgO 1.31
		Na2O 0.08
		K2O 0.07
		P2O5 0.10
		SO3 0.26
		Undetermined 42.94
<u>Misc.</u>		
<u>Analysis</u> <u>Value</u>		
	Hg 0.045 ppm	
	Fluorine	

As Determined Moisture 0.60 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 

Research and Development
www.consolenergy.com
4000 Brownsville Rd.
South Park, PA 15129

LIMESTONE SLURRY SOLIDS 13:45

Date Completed: 04/04/2005
Date Received: 2/7/05
Submitted by: S. TSENG

Project No.: 1621 - 087 - 000

UNIT 1 TEST 3

Analytical No.: **20050701**

Sample No.: LS U1T3

<u>Proximate (Dry)</u> %	<u>Ultimate (Dry)</u> %	<u>Ash Fusion Reducing Temp. °F</u>
Ash 56.76	Carbon 11.58	I.D.
Volatile Matter	Hydrogen	Soft.
Fixed Carbon	Nitrogen	Hemi.
	Chlorine 0.0400	Fluid
BTU/lb	Sulfur, Total	
MAF BTU/lb	Ash 56.76	
	Oxygen (DIFF)	
	<u>Free Swelling Index</u>	<u>Ash Fusion Oxidizing Temp. °F</u>
<u>Grindability</u>	FSI	I.D.
HGI		Soft.
At Moisture % 0.73		Hemi.
0.00		Fluid
<u>Sulfur Form (Dry)</u>	<u>Trace Elements</u>	
Pyritic Sulfur		<u>Major Ash Elem.</u>
Sulfate		<i>AS Det.</i>
Organic		SiO2 1.17
Sulfur, Total		Al2O3 0.16
		TiO2 0.01
		Fe2O3 0.18
		CaO 53.23
		MgO 1.47
		Na2O 0.06
		K2O 0.02
		P2O5 0.09
		SO3 0.24
		Undetermined 43.37
<u>Misc.</u>		
<u>Analysis</u> <u>Value</u>		
	Hg 0.038 ppm	
	Fluorine	

As Determined Moisture 0.73 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
J. LOCKE
J. WITHUM

Approved: 

Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

LIMESTONE SLURRY SOLIDS 09:15

Date Completed: 04/04/2005
 Date Received: 2/7/05
 Submitted by: S. TSENG

Project No.: 1621 - 087 - 000

UNIT 1 TEST 4

Analytical No.: 20050702

Sample No.: LS U1T4

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	56.92	Carbon	11.55	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.1100	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	56.92	
		Oxygen (DIFF)		

Ash Fusion Oxidizing Temp. °F
Grindability

HGI
 At Moisture % 0.76
 0.00

Free Swelling Index

FSI

I.D.

Soft.

Hemi.

Fluid

Sulfur Form (Dry)

Pyritic Sulfur
 Sulfate
 Organic
 Sulfur, Total

Major Ash Elem.

95 pct
 SiO2 1.76
 Al2O3 0.18
 TiO2 0.01
 Fe2O3 0.18
 CaO 53.58
 MgO 1.51
 Na2O 0.05
 K2O 0.03
 P2O5 0.10
 SO3 0.34

Misc.

Analysis Value

Hg 0.063 ppm

Fluorine

Undetermined 42.26

As Determined Moisture 0.76 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: _____





Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

LIMESTONE SLURRY SOLIDS

Date Completed: 04/04/2005
 Date Received: 2/7/05
 Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
 Analytical No.: 20050703

UNIT 2 TEST 1


Sample No.: LS U2T1

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	56.84	Carbon	11.69	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.0700	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	56.84	
		Oxygen (DIFF)		
				<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
				Soft.
				Hemi.
				Fluid
<u>Grindability</u>		<u>Free Swelling Index</u>		
HGI		FSI		
At Moisture %	0.40			
	0.00			
		<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				
Pyritic Sulfur				<u>Major Ash Elem.</u>
Sulfate				as det.
Organic				SiO2 1.49
Sulfur, Total				Al2O3 0.09
				TiO2 0.00
				Fe2O3 0.11
				CaO 54.88
				MgO 0.78
				Na2O 0.04
				K2O 0.02
				P2O5 0.06
				SO3 0.20
<u>Misc.</u>				
<u>Analysis</u>	<u>Value</u>			
		Hg	0.063 ppm	
		Fluorine		Undetermined 42.33

As Determined Moisture 0.40 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

LIMESTONE SLURRY SOLIDS

Date Completed: 04/04/2005
 Date Received: 2/7/05
 Submitted by: S. TSENG

Project No.: 1621 - 087 - 000

UNIT 2 TEST 2

Analytical No.: 20050704


Sample No.: LS U2T2

<u>Proximate</u>	<u>%</u>	<u>Ultimate</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	56.95	Carbon	11.27	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.1100	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	56.95	
		Oxygen (DIFF)		<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
<u>Grindability</u>		<u>Free Swelling Index</u>		Soft.
HGI		FSI		Hemi.
At Moisture %	0.49			Fluid
	0.00	<u>Trace Elements</u>		
<u>Sulfur Form</u>				<u>Major Ash Elem.</u>
Pyritic Sulfur				as Def.
Sulfate				SiO2 1.67
Organic				Al2O3 0.11
Sulfur, Total				TiO2 0.00
				Fe2O3 0.11
				CaO 55.01
				MgO 0.91
				Na2O 0.05
				K2O 0.01
				P2O5 0.09
				SO3 0.25
<u>Misc.</u>				Undetermined 41.79
<u>Analysis</u>	<u>Value</u>			
		Hg	0.068 ppm	
		Fluorine		

As Determined Moisture 0.49 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

LIMESTONE SLURRY SOLIDS

UNIT 2 TEST 3

Sample No.: LS U2T3

Date Completed: 04/04/2005
 Date Received: 2/7/05
 Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
 Analytical No.: 20050705

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	56.93	Carbon	11.62	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.0800	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	56.93	
		Oxygen (DIFF)		

Ash Fusion Oxidizing Temp. °F

Grindability

HGI
 At Moisture % 0.52
 0.00

Free Swelling Index

FSI

I.D.

Soft.

Hemi.

Fluid

Sulfur Form (Dry)

Pyritic Sulfur
 Sulfate
 Organic
 Sulfur, Total

Major Ash Elem.

as Det.

SiO2 1.62
 Al2O3 0.12
 TiO2 0.01
 Fe2O3 0.13
 CaO 55.15
 MgO 0.95
 Na2O 0.04
 K2O 0.00
 P2O5 0.08
 SO3 0.25

Misc.

Analysis Value

Hg 0.060 ppm
 Fluorine

Undetermined 41.65

As Determined Moisture 0.52 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

LIMESTONE SLURRY SOLIDS

UNIT 2 TEST 4

Sample No.: LS U2T4

Date Completed: 04/04/2005
Date Received: 2/7/05
Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
Analytical No.: 20050706

<u>Proximate (Dry)</u> %	<u>Ultimate (Dry)</u> %	<u>Ash Fusion Reducing Temp. °F</u>
Ash 57.02	Carbon 11.65	I.D.
Volatile Matter	Hydrogen	Soft.
Fixed Carbon	Nitrogen	Hemi.
	Chlorine 0.0800	Fluid
BTU/lb	Sulfur, Total	
MAF BTU/lb	Ash 57.02	
	Oxygen (DIFF)	
		<u>Ash Fusion Oxidizing Temp. °F</u>
		I.D.
		Soft.
		Hemi.
		Fluid
<u>Grindability</u>	<u>Free Swelling Index</u>	
HGI	FSI	
At Moisture % 0.37		
0.00		
	<u>Trace Elements</u>	
<u>Sulfur Form (Dry)</u>		
Pyritic Sulfur		
Sulfate		
Organic		
Sulfur, Total		
		<u>Major Ash Elem.</u>
		as def.
		SiO2 1.70
		Al2O3 0.08
		TiO2 0.00
		Fe2O3 0.09
		CaO 55.01
		MgO 0.70
		Na2O 0.03
		K2O 0.02
		P2O5 0.07
		SO3 0.21
		Undetermined 42.09
<u>Misc.</u>		
<u>Analysis</u> <u>Value</u>		
% SOLIDS 13.5		
DENSITY 1.055	Hg 0.048 ppm	
	Fluorine	

As Determined Moisture 0.37 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 

LIMESTONE SLURRY FILTRATE 09:35

Sample No.: LS U1T1
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: **20050784**
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value
pH				
Acidity, CaCO ₃				
Alkalinity, CaCO ₃				
Hydroxide, CaCO ₃				
Carbonate, CaCO ₃				
Bicarbonate, CaCO ₃				
Total Suspended Solids				
Total Dissolved Solids				
Specific Conductivity				
Hardness				
Turbidity				
Osmotic Pressure				
Dissolved Oxygen				
Ammonia, N	<10			
Total Elements				
Aluminum				
Calcium	461.88			
Iron	<1.25			
Magnesium	313.30			
Manganese				
Potassium	90.40			
Phosphorous				
Silicon				
Sodium	629.36			
Chromium				
Anions:				
Sulfate	786.60			
Chloride	2150			
Nitrate, N	0.11			
Nitrite, N				
Bromide				
Fluoride				

Quality Control Calculations

Ion Sum	4432.03
Cation Sum	78.50
Anion Sum	77.03
Ion Balance	-1.13
% Ion Imbalance	0.95

Hg <1.0 ng/mL

These values have been reviewed and are approved for transmission.

LIMESTONE SLURRY FILTRATE 09:45

Sample No.: LS U1T2
 Date Received: 02/07/2005
 Date Completed: 04/05/2005

Analytical No.: **20050785**
 Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
 (mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 3184.42
Acidity, CaCO ₃					Cation Sum 55.24
Alkalinity, CaCO ₃					Anion Sum 53.97
Hydroxide, CaCO ₃					Ion Balance -1.34
Carbonate, CaCO ₃					% Ion Imbalance 1.16
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg <1.0 ng/ml</i>
Calcium	441.02				
Iron	<1.25				
Magnesium	134.67				
Manganese					
Potassium	73.54				
Phosphorous					
Silicon					
Sodium	466.13				
Chromium					
Anions:					
Sulfate	594.06				
Chloride	1475				
Nitrate, N	<0.02				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

LIMESTONE SLURRY FILTRATE 13:45

Sample No.: LS U1T3
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050786
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value
pH				
Acidity, CaCO ₃				
Alkalinity, CaCO ₃				
Hydroxide, CaCO ₃				
Carbonate, CaCO ₃				
Bicarbonate, CaCO ₃				
Total Suspended Solids				
Total Dissolved Solids				
Specific Conductivity				
Hardness				
Turbidity				
Osmotic Pressure				
Dissolved Oxygen				
Ammonia, N	<10			
Total Elements				
Aluminum				
Calcium	333.63			
Iron	<1.25			
Magnesium	103.17			
Manganese				
Potassium	54.14			
Phosphorous				
Silicon				
Sodium	381.99			
Chromium				
Anions:				
Sulfate	460.32			
Chloride	1225			
Nitrate, N	<0.02			
Nitrite, N				
Bromide				
Fluoride				

Quality Control Calculations

Ion Sum	2558.25
Cation Sum	43.13
Anion Sum	44.14
Ion Balance	1.27
% Ion Imbalance	-1.15

Hg <1.0 *ng/mL*

These values have been reviewed and are approved for transmission.


LIMESTONE SLURRY FILTRATE 09:15

Sample No.: LS U1T4
 Date Received: 02/07/2005
 Date Completed: 04/05/2005

Analytical No.: **20050787**
 Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
 (mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 3305.04
Acidity, CaCO ₃					Cation Sum 56.89
Alkalinity, CaCO ₃					Anion Sum 57.09
Hydroxide, CaCO ₃					Ion Balance 0.21
Carbonate, CaCO ₃					% Ion Imbalance -0.18
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					
Calcium	395.13				
Iron	<1.25				
Magnesium	176.80				
Manganese					
Potassium	70.99				
Phosphorous					
Silicon					
Sodium	478.53				
Chromium					
Anions:					
Sulfate	608.28				
Chloride	1575				
Nitrate, N	0.07				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

LIMESTONE SLURRY FILTRATE

Sample No.: LS U2T1
 Date Received: 02/07/2005
 Date Completed: 04/05/2005

Analytical No.: **20050788**
 Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
 (mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 3219.97
Acidity, CaCO ₃					Cation Sum 113.51
Alkalinity, CaCO ₃					Anion Sum 22.93
Hydroxide, CaCO ₃					Ion Balance -196.08
Carbonate, CaCO ₃					% Ion Imbalance 66.39
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					
Calcium	651.97				
Iron	2.30				
Magnesium	500.46				
Manganese					
Potassium	117.80				
Phosphorous					
Silicon					
Sodium	844.41				
Chromium					
Anions:					
Sulfate	1085.33				
Chloride	3.00				
Nitrate, N	3.32				
Nitrite, N					
Bromide					
Fluoride					

Hg <1.0 *ng/ml*

These values have been reviewed and are approved for transmission.

LIMESTONE SLURRY FILTRATE

Sample No.: LS U2T2
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050789
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 6187.72
Acidity, CaCO ₃					Cation Sum 112.61
Alkalinity, CaCO ₃					Anion Sum 107.00
Hydroxide, CaCO ₃					Ion Balance -3.18
Carbonate, CaCO ₃					% Ion Imbalance 2.55
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					Hg 1.3 <i>ng/mL</i>
Calcium	658.89				
Iron	<1.25				
Magnesium	490.49				
Manganese					
Potassium	118.30				
Phosphorous					
Silicon					
Sodium	836.10				
Chromium					
Anions:					
Sulfate	1108.94				
Chloride	2975				
Nitrate, N	<0.02				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

LIMESTONE SLURRY FILTRATE

Sample No.: LS U2T3
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050790
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 6136.12
Acidity, CaCO ₃					Cation Sum 108.92
Alkalinity, CaCO ₃					Anion Sum 107.61
Hydroxide, CaCO ₃					Ion Balance -0.74
Carbonate, CaCO ₃					% Ion Imbalance 0.60
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg</i> <1.0 <i>ng/ml</i>
Calcium	610.69				
Iron	<1.25				
Magnesium	482.56				
Manganese					
Potassium	114.30				
Phosphorous					
Silicon					
Sodium	823.98				
Chromium					
Anions:					
Sulfate	1104.28				
Chloride	3000				
Nitrate, N	0.07				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

LIMESTONE SLURRY FILTRATE

Sample No.: LS U2T4
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050791
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 6850.93
Acidity, CaCO ₃					Cation Sum 122.29
Alkalinity, CaCO ₃					Anion Sum 119.81
Hydroxide, CaCO ₃					Ion Balance -1.26
Carbonate, CaCO ₃					% Ion Imbalance 1.02
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg <1.0 ng/mL</i>
Calcium	697.63				
Iron	<1.25				
Magnesium	540.12				
Manganese					
Potassium	128.96				
Phosphorous					
Silicon					
Sodium	914.02				
Chromium					
Anions:					
Sulfate	1201.73				
Chloride	3350				
Nitrate, N	4.17				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 11:30-11:45
 UNIT 1 FIELD 1 SILO 2
 DATE SAMPLED 01/19/05
 SAMPLE NUMBER ESP ASH U1T1F1

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050723

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	94.32	Carbon	4.98	Ignited at	a C
Total Sulfur	0.19	Chlorine	0.002	SiO2	48.79
		Ash	94.32	Al2O3	26.85
<u>MISC. (As Det.)</u>				TiO2	1.40
Hg	0.204 ppm			Fe2O3	11.56
				CaO	1.57
				MgO	0.95
				Na2O	0.51
				K2O	2.38
				P2O5	0.23
				SO3	0.48
				UND	5.28

AS DETERMINED MOISTURE: 0.21 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 12:00-12:10
 UNIT 1 FIELD 2 SILO 2
 DATE SAMPLED 01/19/05
 SAMPLE NUMBER ESP ASH U1T1F2


DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050724

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	94.90	Carbon	4.36	Ignited at	a C
Total Sulfur	0.20	Chlorine	0.002	SiO2	48.94
		Ash	94.90	Al2O3	26.79
<u>MISC. (As Det.)</u>				TiO2	1.42
Hg	0.210 ppm			Fe2O3	11.43
				CaO	1.61
				MgO	0.95
				Na2O	0.52
				K2O	2.37
				P2O5	0.24
				SO3	0.51
				UND	5.22

AS DETERMINED MOISTURE: 0.23 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 12:20-12:45
 UNIT 1 FIELD 3 SILO 2
 DATE SAMPLED 01/19/05
 SAMPLE NUMBER ESP ASH U1T1F3

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050725

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	94.73	Carbon	4.71	Ignited at	a C
Total Sulfur	0.17	Chlorine	0.002	SiO2	50.95
		Ash	94.73	Al2O3	26.86
<u>MISC. (As Det.)</u>				TiO2	1.49
Hg	0.217 ppm			Fe2O3	9.87
				CaO	1.68
				MgO	0.95
				Na2O	0.49
				K2O	2.31
				P2O5	0.36
				SO3	0.43
				UND	4.61

AS DETERMINED MOISTURE: 0.24 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 13:30-14:00
 UNIT 1 FIELD 4 SILO 2
 DATE SAMPLED 01/19/05
 SAMPLE NUMBER ESP ASH U1T1F4

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050726


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	95.38	Carbon	4.09	Ignited at	a C
Total Sulfur	0.20	Chlorine	0.003	SiO2	49.97
		Ash	95.38	Al2O3	26.94
<u>MISC. (As Det.)</u>				TiO2	1.46
Hg	0.186 ppm			Fe2O3	11.05
				CaO	1.66
				MgO	0.97
				Na2O	0.53
				K2O	2.37
				P2O5	0.29
				SO3	0.50
				UND	4.26

AS DETERMINED MOISTURE: 0.25 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:25-14:30
 UNIT 1 FIELD 5 SILO 2
 DATE SAMPLED 01/19/05
 SAMPLE NUMBER ESP ASH U1T1F5

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050727

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	95.36	Carbon	4.04	Ignited at	a C
Total Sulfur	0.18	Chlorine	0.003	SiO ₂	49.83
		Ash	95.36	Al ₂ O ₃	26.53
<u>MISC. (As Det.)</u>				TiO ₂	1.44
Hg	0.185 ppm			Fe ₂ O ₃	11.03
				CaO	1.63
				MgO	0.95
				Na ₂ O	0.51
				K ₂ O	2.33
				P ₂ O ₅	0.26
				SO ₃	0.46
				UND	5.03

AS DETERMINED MOISTURE: 0.19 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:05-14:15
 UNIT 1 FIELD 6 SILO 2
 DATE SAMPLED 01/19/05
 SAMPLE NUMBER ESP ASH U1T1F6


DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050728

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	95.38	Carbon	4.17	Ignited at	a C
Total Sulfur	0.19	Chlorine	0.003	SiO2	50.50
		Ash	95.38	Al2O3	26.80
<u>MISC. (As Det.)</u>				TiO2	1.46
Hg	0.188 ppm			Fe2O3	11.21
				CaO	1.64
				MgO	0.96
				Na2O	0.52
				K2O	2.34
				P2O5	0.25
				SO3	0.48
				UND	3.84

AS DETERMINED MOISTURE: 0.22 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 09:40-09:45
 UNIT 1 FIELD 1 SILO 2
 DATE SAMPLED 01/20/05
 SAMPLE NUMBER ESP ASH U1T2F1


DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050729

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	95.96	Carbon	3.66	Ignited at	a C
Total Sulfur	0.18	Chlorine	0.002	SiO2	49.82
		Ash	95.96	Al2O3	26.35
<u>MISC. (As Det.)</u>				TiO2	1.43
Hg	0.162 ppm			Fe2O3	12.23
				CaO	1.59
				MgO	0.94
				Na2O	0.51
				K2O	2.25
				P2O5	0.23
				SO3	0.46
				UND	4.19

AS DETERMINED MOISTURE: 0.19 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal, 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA' 15129

DESCRIPTION ESP HOPPER ASH 10:00-10:05
 UNIT 1 FIELD 2 SILO 2
 DATE SAMPLED 01/20/05
 SAMPLE NUMBER ESP ASH U1T2F2

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050730

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	95.79	Carbon	3.82	Ignited at a C	
Total Sulfur	0.18	Chlorine	0.003	SiO2	49.23
		Ash	95.79	Al2O3	25.79
<u>MISC. (As Det.)</u>				TiO2	1.42
Hg	0.166 ppm			Fe2O3	12.02
				CaO	1.52
				MgO	0.90
				Na2O	0.50
				K2O	2.22
				P2O5	0.21
				SO3	0.46
				UND	5.73

AS DETERMINED MOISTURE: 0.13 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:20-10:25
 UNIT 1 FIELD 3 SILO 2

DATE SAMPLED 01/20/05
 SAMPLE NUMBER ESP ASH U1T2F3

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050731


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	95.82	Carbon	3.74	Ignited at	a C
Total Sulfur	0.19	Chlorine	0.003	SiO2	50.03
		Ash	95.82	Al2O3	26.61
<u>MISC. (As Det.)</u>				TiO2	1.45
Hg	0.098 ppm			Fe2O3	12.04
				CaO	1.60
				MgO	0.94
				Na2O	0.52
				K2O	2.31
				P2O5	0.20
				SO3	0.47
				UND	3.83

AS DETERMINED MOISTURE: 0.18 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:00-14:05
 UNIT 1 FIELD 1 SILO 2
 DATE SAMPLED 01/20/05
 SAMPLE NUMBER ESP ASH U1T3F1


DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050732

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>%</u>
Ash	96.22	Carbon	3.27	Ignited at	a C
Total Sulfur	0.17	Chlorine	0.002	SiO2	50.79
		Ash	96.22	Al2O3	26.42
<u>MISC. (As Det.)</u>				TiO2	1.47
Hg	0.143 ppm			Fe2O3	11.53
				CaO	1.66
				MgO	0.96
				Na2O	0.52
				K2O	2.30
				P2O5	0.24
				SO3	0.43
				UND	3.68

AS DETERMINED MOISTURE: 0.16 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:20-14:25
 UNIT 1 FIELD 2 SILO 2
 DATE SAMPLED 01/20/05
 SAMPLE NUMBER ESP ASH U1T3F2


DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050733

ANALYSIS REPORT

<u>PROXIMATE</u> (Dry)%	<u>ULTIMATE</u> (Dry)%	<u>MAJOR ASH ELEM</u> %
Ash	96.17	Ignited at a C
Total Sulfur	0.16	SiO2 50.15
		Al2O3 26.16
		TiO2 1.45
		Fe2O3 11.77
		CaO 1.62
		MgO 0.94
		Na2O 0.50
		K2O 2.25
		P2O5 0.23
		SO3 0.41
		UND 4.52
<u>MISC. (As Det.)</u>		
Hg 0.151 ppm		

AS DETERMINED MOISTURE: 0.09 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:40-14:45
 UNIT 1 FIELD 3 SILO 2
 DATE SAMPLED 01/20/05
 SAMPLE NUMBER ESP ASH U1T3F3


DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050734

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.12	Carbon	3.47	SiO2	49.86
Total Sulfur	0.16	Chlorine	0.003	Al2O3	26.06
		Ash	96.12	TiO2	1.45
<u>MISC. (As Det.)</u>				Fe2O3	11.76
Hg	0.156 ppm			CaO	1.61
				MgO	0.94
				Na2O	0.49
				K2O	2.26
				P2O5	0.25
				SO3	0.41
				UND	4.91

AS DETERMINED MOISTURE: 0.12 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:55-15:00
UNIT 1 FIELD 4 SILO 2
DATE SAMPLED 01/20/05
SAMPLE NUMBER ESP ASH U1T3F4

DATE LOGGED 02/07/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050735


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.14	Carbon	3.33	SiO2	49.83
Total Sulfur	0.17	Chlorine	0.002	Al2O3	26.00
		Ash	96.14	TiO2	1.46
<u>MISC. (As Det.)</u>				Fe2O3	11.70
Hg	0.147 ppm			CaO	1.61
				MgO	0.94
				Na2O	0.49
				K2O	2.25
				P2O5	0.23
				SO3	0.42
				UND	5.07

AS DETERMINED MOISTURE: 0.07 %

DISTRIBUTION:
S. TSENG
J. LOCKE
J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 15:15-15:20
 UNIT 1 FIELD 5 SILO 2

DATE SAMPLED 01/20/05
 SAMPLE NUMBER ESP ASH U1T3F5

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050736

ANALYSIS REPORT

<u>PROXIMATE</u> (Dry)%	<u>ULTIMATE</u> (Dry)%	<u>MAJOR ASH ELEM</u> (Dry)%
Ash 96.05	Carbon 3.48	SiO2 49.67
Total Sulfur 0.17	Chlorine 0.003	Al2O3 25.92
	Ash 96.05	TiO2 1.45
<u>MISC. (As Det.)</u>		Fe2O3 11.70
Hg 0.160 ppm		CaO 1.61
		MgO 0.93
		Na2O 0.49
		K2O 2.25
		P2O5 0.22
		SO3 0.43
		UND 5.33

AS DETERMINED MOISTURE: 0.07 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 15:30-15:35
UNIT 1 FIELD 6 SILO 2
DATE SAMPLED 01/20/05
SAMPLE NUMBER ESP ASH U1T3F6

DATE LOGGED 02/07/05
DATE COMPLETED 03/09/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050737

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	95.93	Carbon	3.61	SiO2	49.46
Total Sulfur	0.18	Chlorine	0.003	Al2O3	25.85
		Ash	95.93	TiO2	1.46
<u>MISC. (As Det.)</u>				Fe2O3	11.72
Hg	0.157 ppm			CaO	1.62
				MgO	0.93
				Na2O	0.48
				K2O	2.21
				P2O5	0.22
				SO3	0.45
				UND	5.60

AS DETERMINED MOISTURE: 0.12 %

DISTRIBUTION:
S. TSENG
J. LOCKE
J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 09:20-09:25
 UNIT 1 FIELD 1 SILO 2
 DATE SAMPLED 01/21/05
 SAMPLE NUMBER ESP ASH U1T4F1

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050738


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.43	Carbon	3.14	SiO2	52.31
Total Sulfur	0.18	Chlorine	0.003	Al2O3	25.63
		Ash	96.43	TiO2	1.44
<u>MISC. (As Det.)</u>				Fe2O3	10.16
Hg	0.115 ppm			CaO	1.50
				MgO	0.97
				Na2O	0.55
				K2O	2.41
				P2O5	0.15
				SO3	0.44
				UND	4.44

AS DETERMINED MOISTURE: 0.11 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 09:40-09:45
 UNIT 1 FIELD 2 SILO 2
 DATE SAMPLED 01/21/05
 SAMPLE NUMBER ESP ASH U1T4F2

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050739

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.47	Carbon	3.04	SiO2	52.00
Total Sulfur	0.18	Chlorine	0.003	Al2O3	25.38
		Ash	96.47	TiO2	1.45
<u>MISC. (As Det.)</u>				Fe2O3	10.56
Hg	0.120 ppm			CaO	1.54
				MgO	0.97
				Na2O	0.53
				K2O	2.35
				P2O5	0.15
				SO3	0.44
				UND	4.63

AS DETERMINED MOISTURE: 0.11 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA. 15129

DESCRIPTION ESP HOPPER ASH 10:00-10:05
 UNIT 1 FIELD 3 SILO 2
 DATE SAMPLED 01/21/05
 SAMPLE NUMBER ESP ASH U1T4F3

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050740


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.62	Carbon	2.99	SiO2	51.53
Total Sulfur	0.18	Chlorine	0.004	Al2O3	25.39
		Ash	96.62	TiO2	1.45
<u>MISC. (As Det.)</u>				Fe2O3	10.27
Hg	0.118 ppm			CaO	1.53
				MgO	0.96
				Na2O	0.53
				K2O	2.36
				P2O5	0.17
				SO3	0.44
				UND	5.37

AS DETERMINED MOISTURE: 0.14 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:20-10:25
 UNIT 1 FIELD 4 SILO 2
 DATE SAMPLED 01/21/05
 SAMPLE NUMBER ESP ASH U1T4F4


DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050741

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.45	Carbon	2.98	SiO2	52.02
Total Sulfur	0.18	Chlorine	0.004	Al2O3	25.71
		Ash	96.45	TiO2	1.46
<u>MISC. (As Det.)</u>				Fe2O3	10.40
Hg	0.119 ppm			CaO	1.53
				MgO	0.98
				Na2O	0.54
				K2O	2.39
				P2O5	0.18
				SO3	0.45
				UND	4.34

AS DETERMINED MOISTURE: 0.05 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:40-10:45
 UNIT 1 FIELD 5 SILO 2
 DATE SAMPLED 01/21/05
 SAMPLE NUMBER ESP ASH U1T4F5

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050742

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.49	Carbon	3.13	SiO2	51.64
Total Sulfur	0.16	Chlorine	0.003	Al2O3	25.21
		Ash	96.49	TiO2	1.45
<u>MISC. (As Det.)</u>				Fe2O3	10.55
Hg	0.116 ppm			CaO	1.54
				MgO	0.97
				Na2O	0.52
				K2O	2.32
				P2O5	0.16
				SO3	0.39
				UND	5.25

AS DETERMINED MOISTURE: 0.05 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 11:00-11:05
 UNIT 1 FIELD 6 SILO 2

DATE SAMPLED 01/21/05
 SAMPLE NUMBER ESP ASH U1T4F6

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050743

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	96.54	Carbon	2.97	SiO2	51.70
Total Sulfur	0.18	Chlorine	0.003	Al2O3	25.68
		Ash	96.54	TiO2	1.47
<u>MISC. (As Det.)</u>				Fe2O3	10.38
Hg	0.118 ppm			CaO	1.57
				MgO	0.97
				Na2O	0.53
				K2O	2.38
				P2O5	0.19
				SO3	0.46
				UND	4.67

AS DETERMINED MOISTURE: 0.13 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 13:54
 UNIT 2 TEST 1 FIELD 1 SILO 1
 DATE SAMPLED 01/24/05
 SAMPLE NUMBER ESP ASH U2T1F1

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050744


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.03	Carbon	6.01	SiO2	49.86
Total Sulfur	0.24	Chlorine	0.003	Al2O3	24.01
		Ash	93.03	TiO2	1.40
<u>MISC. (As Det.)</u>				Fe2O3	10.71
Hg	0.247 ppm			CaO	1.51
				MgO	0.95
				Na2O	0.49
				K2O	2.25
				P2O5	0.21
				SO3	0.61
				UND	8.00

AS DETERMINED MOISTURE: 0.17 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:00
 UNIT 2 TEST 1 FIELD 2 SILO 1
 DATE SAMPLED 01/24/05
 SAMPLE NUMBER ESP ASH U2T1F2

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050745


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.15	Carbon	5.99	SiO2	49.30
Total Sulfur	0.24	Chlorine	0.003	Al2O3	23.89
		Ash	93.15	TiO2	1.39
<u>MISC. (As Det.)</u>				Fe2O3	10.69
Hg	0.239 ppm			CaO	1.52
				MgO	0.94
				Na2O	0.49
				K2O	2.25
				P2O5	0.21
				SO3	0.59
				UND	8.73

AS DETERMINED MOISTURE: 0.17 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:16
 UNIT 2 TEST 1 FIELD 3 SILO 1
 DATE SAMPLED 01/24/05
 SAMPLE NUMBER ESP ASH U2T1F3

DATE LOGGED 02/07/05
 DATE COMPLETED 03/09/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050746


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.06	Carbon	6.21	SiO2	49.63
Total Sulfur	0.24	Chlorine	0.004	Al2O3	23.91
		Ash	93.06	TiO2	1.39
<u>MISC. (As Det.)</u>				Fe2O3	10.77
Hg	0.246 ppm			CaO	1.51
				MgO	0.95
				Na2O	0.50
				K2O	2.28
				P2O5	0.19
				SO3	0.61
				UND	8.26

AS DETERMINED MOISTURE: 0.21 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:26
 UNIT 2 TEST 1 FIELD 4 SILO 1
 DATE SAMPLED 01/24/05
 SAMPLE NUMBER ESP ASH U2T1F4


DATE LOGGED 02/07/05
 DATE COMPLETED 03/16/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050747

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.06	Carbon	6.08	Silicon	49.65
Total Sulfur	0.26	Chlorine	0.004	Al2O3	24.08
		Ash	93.06	TiO2	1.32
<u>MISC. (As Det.)</u>				Fe2O3	10.46
Hg	0.179 PPM			CaO	1.50
				MgO	0.94
				Na2O	0.53
				K2O	2.29
				P2O5	0.21
				SO3	0.66
				UND	8.36

AS DETERMINED MOISTURE: 0.15 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:36
 UNIT 2 TEST 1 FIELD 5 SILO 1
 DATE SAMPLED 01/24/05
 SAMPLE NUMBER ESP ASH U2T1F5

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050748

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.15	Carbon	6.25	Silicon	49.92
Total Sulfur	0.26	Chlorine	0.003	Al2O3	24.55
		Ash	93.15	TiO2	1.33
<u>MISC. (As Det.)</u>				Fe2O3	10.73
Hg	0.240 PPM			CaO	1.51
				MgO	0.95
				Na2O	0.53
				K2O	2.32
				P2O5	0.21
				SO3	0.65
				UND	7.30

AS DETERMINED MOISTURE: 0.15 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:50
 UNIT 2 TEST 1 FIELD 6 SILO 1
 DATE SAMPLED 01/24/05
 SAMPLE NUMBER ESP ASH U2T1F6

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050749

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.03	Carbon	6.18	Silicon	49.65
Total Sulfur	0.25	Chlorine	0.004	Al2O3	24.47
		Ash	93.03	TiO2	1.33
<u>MISC. (As Det.)</u>				Fe2O3	10.75
Hg	0.230 PPM			CaO	1.50
				MgO	0.94
				Na2O	0.52
				K2O	2.29
				P2O5	0.20
				SO3	0.62
				UND	7.73

AS DETERMINED MOISTURE: 0.04 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:23
 UNIT 2 TEST 2 FIELD 1 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T2F1

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050750

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.84	Carbon	6.40	Silicon	46.66
Total Sulfur	0.26	Chlorine	0.002	Al2O3	23.67
		Ash	92.84	TiO2	1.28
<u>MISC. (As Det.)</u>				Fe2O3	10.88
Hg	0.246 PPM			CaO	1.42
				MgO	0.94
				Na2O	0.49
				K2O	2.24
				P2O5	0.23
				SO3	0.64
				UND	11.55

AS DETERMINED MOISTURE: 0.09 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:44
 UNIT 2 TEST 2 FIELD 2 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T2F2
 DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050751

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.81	Carbon	6.36	Silicon	48.96
Total Sulfur	0.27	Chlorine	0.002	Al2O3	24.50
		Ash	92.81	TiO2	1.34
<u>MISC. (As Det.)</u>				Fe2O3	11.68
Hg	0.268 PPM			CaO	1.49
				MgO	0.96
				Na2O	0.51
				K2O	2.30
				P2O5	0.24
				SO3	0.67
				UND	7.35

AS DETERMINED MOISTURE: 0.09 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:59
 UNIT 2 TEST 2 FIELD 3 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T2F3


DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050752

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.82	Carbon	6.31	Silicon	48.76
Total Sulfur	0.28	Chlorine	0.002	Al2O3	24.42
		Ash	92.82	TiO2	1.34
<u>MISC. (As Det.)</u>				Fe2O3	11.48
Hg	0.268 PPM			CaO	1.49
				MgO	0.96
				Na2O	0.51
				K2O	2.31
				P2O5	0.23
				SO3	0.69
				UND	7.81

AS DETERMINED MOISTURE: 0.09 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 11:12
 UNIT 2 TEST 2 FIELD 4 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T2F4

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050753


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.86	Carbon	6.12	Silicon	48.64
Total Sulfur	0.26	Chlorine	0.004	Al2O3	24.33
		Ash	92.86	TiO2	1.33
<u>MISC. (As Det.)</u>				Fe2O3	11.41
Hg	0.262 PPM			CaO	1.49
				MgO	0.96
				Na2O	0.50
				K2O	2.29
				P2O5	0.23
				SO3	0.64
				UND	8.18

AS DETERMINED MOISTURE: 0.09 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 11:23
 UNIT 2 TEST 2 FIELD 5 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T2F5

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050754

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.86	Carbon	6.24	Silicon	48.43
Total Sulfur	0.25	Chlorine	0.002	Al2O3	24.23
		Ash	92.86	TiO2	1.33
<u>MISC. (As Det.)</u>				Fe2O3	11.55
Hg	0.251 PPM			CaO	1.49
				MgO	0.96
				Na2O	0.49
				K2O	2.29
				P2O5	0.23
				SO3	0.63
				UND	8.37

AS DETERMINED MOISTURE: 0.05 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 11:37
 UNIT 2 TEST 2 FIELD 6 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T2F6

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050755

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.86	Carbon	6.49	Silicon	48.92
Total Sulfur	0.25	Chlorine	0.002	Al2O3	24.30
		Ash	92.86	TiO2	1.34
<u>MISC. (As Det.)</u>				Fe2O3	11.51
Hg	0.245 PPM			CaO	1.49
				MgO	0.95
				Na2O	0.50
				K2O	2.30
				P2O5	0.22
				SO3	0.63
				UND	7.84

AS DETERMINED MOISTURE: 0.17 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:35
 UNIT 2 TEST 3 FIELD 1 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T3F1


DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050756

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.67	Carbon	6.49	Silicon	48.95
Total Sulfur	0.26	Chlorine	0.003	Al2O3	24.42
		Ash	92.67	TiO2	1.34
<u>MISC. (As Det.)</u>				Fe2O3	11.33
Hg	0.257 PPM			CaO	1.49
				MgO	0.95
				Na2O	0.50
				K2O	2.29
				P2O5	0.24
				SO3	0.64
				UND	7.85

AS DETERMINED MOISTURE: 0.15 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:49
 UNIT 2 TEST 3 FIELD 2 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T3F2

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050757


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.68	Carbon	6.44	Silicon	48.89
Total Sulfur	0.26	Chlorine	0.002	Al2O3	24.30
		Ash	92.68	TiO2	1.33
<u>MISC. (As Det.)</u>				Fe2O3	11.45
Hg	0.258 PPM			CaO	1.49
				MgO	0.96
				Na2O	0.49
				K2O	2.28
				P2O5	0.24
				SO3	0.66
				UND	7.91

AS DETERMINED MOISTURE: 0.11 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 14:59
 UNIT 2 TEST 3 FIELD 3 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T3F3

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050758


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.66	Carbon	6.43	Silicon	49.39
Total Sulfur	0.26	Chlorine	0.002	Al2O3	24.89
		Ash	92.66	TiO2	1.36
<u>MISC. (As Det.)</u>				Fe2O3	11.17
Hg	0.249 PPM			CaO	1.50
				MgO	0.97
				Na2O	0.51
				K2O	2.35
				P2O5	0.25
				SO3	0.65
				UND	6.96

AS DETERMINED MOISTURE: 0.15 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA. 15129

DESCRIPTION ESP HOPPER ASH 15:10
 UNIT 2 TEST 3 FIELD 4 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T3F4


DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050759

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.68	Carbon	6.50	Silicon	49.25
Total Sulfur	0.26	Chlorine	0.003	Al2O3	24.64
		Ash	92.68	TiO2	1.35
<u>MISC. (As Det.)</u>				Fe2O3	11.33
				CaO	1.47
Hg	0.263 PPM			MgO	0.95
				Na2O	0.51
				K2O	2.31
				P2O5	0.24
				SO3	0.66
				UND	7.29

AS DETERMINED MOISTURE: 0.13 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 15:24
 UNIT 2 TEST 3 FIELD 5 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T3F5

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050760

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.61	Carbon	6.49	Silicon	48.72
Total Sulfur	0.25	Chlorine	0.003	Al2O3	24.36
		Ash	92.61	TiO2	1.34
<u>MISC. (As Det.)</u>				Fe2O3	11.37
Hg	0.271 PPM			CaO	1.46
				MgO	0.95
				Na2O	0.49
				K2O	2.31
				P2O5	0.24
				SO3	0.62
				UND	8.14

AS DETERMINED MOISTURE: 0.11 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 15:35
 UNIT 2 TEST 3 FIELD 6 SILO 1
 DATE SAMPLED 01/25/05
 SAMPLE NUMBER ESP ASH U2T3F6

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050761

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.67	Carbon	6.47	Silicon	48.88
Total Sulfur	0.26	Chlorine	0.003	Al2O3	24.50
		Ash	92.67	TiO2	1.34
<u>MISC. (As Det.)</u>				Fe2O3	11.40
Hg	0.266 PPM			CaO	1.47
				MgO	0.96
				Na2O	0.51
				K2O	2.34
				P2O5	0.24
				SO3	0.64
				UND	7.72

AS DETERMINED MOISTURE: 0.11 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal

CONSOL ENERGY INC.
RESEARCH & DEVELOPMENT
ANALYTICAL LABORATORY
4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:15
UNIT 2 TEST 4 FIELD 1 SILO 1
DATE SAMPLED 01/26/05
SAMPLE NUMBER ESP ASH U2T4F1

DATE LOGGED 02/07/05
DATE COMPLETED 03/15/05
PROJECT NUMBER 1621-87 -
ANALYTICAL NUMBER 050762


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.95	Carbon	6.09	Silicon	49.21
Total Sulfur	0.25	Chlorine	0.003	Al2O3	25.14
		Ash	92.95	TiO2	1.40
<u>MISC. (As Det.)</u>				Fe2O3	10.38
Hg	0.253 PPM			CaO	1.48
				MgO	0.92
				Na2O	0.49
				K2O	2.28
				P2O5	0.29
				SO3	0.62
				UND	7.79

AS DETERMINED MOISTURE: 0.09 %

DISTRIBUTION:
S. TSENG
J. LOCKE
J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:02
 UNIT 2 TEST 4 FIELD 2 SILO 1
 DATE SAMPLED 01/26/05
 SAMPLE NUMBER ESP ASH U2T4F2

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050763

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.96	Carbon	6.10	Silicon	49.58
Total Sulfur	0.25	Chlorine	0.002	Al2O3	25.52
		Ash	92.96	TiO2	1.40
<u>MISC. (As Det.)</u>				Fe2O3	10.45
Hg	0.248 PPM			CaO	1.46
				MgO	0.93
				Na2O	0.52
				K2O	2.38
				P2O5	0.31
				SO3	0.63
				UND	6.82

AS DETERMINED MOISTURE: 0.12 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal _____

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:27
 UNIT 2 TEST 4 FIELD 3 SILO 1
 DATE SAMPLED 01/26/05
 SAMPLE NUMBER ESP ASH U2T4F3

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050764

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.96	Carbon	6.03	Silicon	50.16
Total Sulfur	0.25	Chlorine	0.003	Al2O3	25.45
		Ash	92.96	TiO2	1.41
<u>MISC. (As Det.)</u>				Fe2O3	10.43
Hg	0.245 PPM			CaO	1.48
				MgO	0.93
				Na2O	0.52
				K2O	2.33
				P2O5	0.29
				SO3	0.63
				UND	6.37

AS DETERMINED MOISTURE: 0.15 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:37
 UNIT 2 TEST 4 FIELD 4 SILO 1
 DATE SAMPLED 01/26/05
 SAMPLE NUMBER ESP ASH U2T4F4

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050765


ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	92.98	Carbon	5.97	Silicon	49.57
Total Sulfur	0.24	Chlorine	0.003	Al2O3	25.16
		Ash	92.98	TiO2	1.38
<u>MISC. (As Det.)</u>				Fe2O3	10.30
Hg	0.238 PPM			CaO	1.46
				MgO	0.92
				Na2O	0.53
				K2O	2.35
				P2O5	0.30
				SO3	0.61
				UND	7.42

AS DETERMINED MOISTURE: 0.09 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:47
 UNIT 2 TEST 4 FIELD 5 SILO 1
 DATE SAMPLED 01/26/05
 SAMPLE NUMBER ESP ASH U2T4F5


DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050766

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.02	Carbon	5.90	Silicon	49.82
Total Sulfur	0.25	Chlorine	0.003	Al2O3	25.61
		Ash	93.02	TiO2	1.41
<u>MISC. (As Det.)</u>				Fe2O3	10.25
Hg	0.246 PPM			CaO	1.47
				MgO	0.93
				Na2O	0.53
				K2O	2.40
				P2O5	0.30
				SO3	0.62
				UND	6.66

AS DETERMINED MOISTURE: 0.22 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal 

CONSOL ENERGY INC.
 RESEARCH & DEVELOPMENT
 ANALYTICAL LABORATORY
 4000 BROWNSVILLE ROAD, SOUTH PARK, PA 15129

DESCRIPTION ESP HOPPER ASH 10:58
 UNIT 2 TEST 4 FIELD 6 SILO 1
 DATE SAMPLED 01/26/05
 SAMPLE NUMBER ESP ASH U2T4F6

DATE LOGGED 02/07/05
 DATE COMPLETED 03/15/05
 PROJECT NUMBER 1621-87 -
 ANALYTICAL NUMBER 050767

ANALYSIS REPORT

<u>PROXIMATE</u>	<u>(Dry)%</u>	<u>ULTIMATE</u>	<u>(Dry)%</u>	<u>MAJOR ASH ELEM</u>	<u>(Dry)%</u>
Ash	93.02	Carbon	6.03	Silicon	50.09
Total Sulfur	0.25	Chlorine	0.003	Al2O3	25.63
		Ash	93.02	TiO2	1.41
<u>MISC. (As Det.)</u>				Fe2O3	10.41
Hg	0.240 PPM			CaO	1.46
				MgO	0.94
				Na2O	0.53
				K2O	2.38
				P2O5	0.30
				SO3	0.62
				UND	6.23

AS DETERMINED MOISTURE: 0.18 %

DISTRIBUTION:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved for transmittal



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 13:05

UNIT 1 TEST 1 MODULE 1A

Sample No.: U1T1 FGDS-1A

Date Completed: 04/04/2005

Date Received: 2/7/05

Submitted by: S. TSENG

Project No.: 1621 - 087 - 000

Analytical No.: 20050707

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	99.92	Carbon	0.62	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.6000 OK	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	99.92	
		Oxygen (DIFF)		<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
<u>Grindability</u>		<u>Free Swelling Index</u>		Soft.
HGI		FSI		Hemi.
At Moisture %	4.47			Fluid
	0.00	<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				<u>Major Ash Elem.</u>
Pyritic Sulfur				<i>as determined.</i>
Sulfate				SiO2 0.74
Organic				Al2O3 0.11
Sulfur, Total				TiO2 0.00
				Fe2O3 0.10
				CaO 41.53
				MgO 0.34
				Na2O 0.24
				K2O 0.06
				P2O5 0.03
				SO3 50.18
<u>Misc.</u>				Undetermined 6.67
<u>Analysis</u>	<u>Value</u>			
% SOLIDS	13.0			
DENSITY	1.115	Hg	0.827 ppm	
		Fluorine		

As Determined Moisture 4.47 %

These values have been reviewed and are approved for transmission.

Distribution:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved:



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 13:05
UNIT 1 TEST 1 MODULE 1B
Sample No.: U1T1 FGDS-1B

Date Completed: 04/04/2005
Date Received: 2/7/05
Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
Analytical No.: 20050708

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	90.24	Carbon	2.85	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.3500	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	90.24	
		Oxygen (DIFF)		<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
<u>Grindability</u>		<u>Free Swelling Index</u>		Soft.
HGI		FSI		Hemi.
At Moisture %	4.12			Fluid
	0.00	<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				<u>Major Ash Elem.</u>
Pyritic Sulfur				<i>as det.</i>
Sulfate				SiO2
Organic				Al2O3
Sulfur, Total				TiO2
				Fe2O3
				CaO
				MgO
				Na2O
				K2O
				P2O5
				SO3
				Undetermined
<u>Misc.</u>				
<u>Analysis</u>	<u>Value</u>			
% SOLIDS	11.1			
DENSITY	1.098	Hg	0.609 ppm	
		Fluorine		

As Determined Moisture 4.12 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 11:00
UNIT 1 TEST 2 MODULE 1A
Sample No.: U1T2 FGDS-1A

Date Completed: 04/04/2005
Date Received: 2/7/05
Submitted by: S. TSENG


Project No.: 1621 - 087 - 000
Analytical No.: 20050709

<u>Proximate (Dry)</u> %	<u>Ultimate (Dry)</u> %	<u>Ash Fusion Reducing Temp. °F</u>
Ash 103.14	Carbon 0.84	I.D.
Volatile Matter	Hydrogen	Soft.
Fixed Carbon	Nitrogen	Hemi.
	Chlorine 0.6300	Fluid
BTU/lb	Sulfur, Total	
MAF BTU/lb	Ash 103.14	
	Oxygen (DIFF)	
		<u>Ash Fusion Oxidizing Temp. °F</u>
		I.D.
		Soft.
		Hemi.
		Fluid
<u>Grindability</u>	<u>Free Swelling Index</u>	
HGI	FSI	
At Moisture % 4.03		
0.00		
	<u>Trace Elements</u>	
<u>Sulfur Form (Dry)</u>		
Pyritic Sulfur		<u>Major Ash Elem.</u>
Sulfate		As Det.
Organic		SiO2 0.87
Sulfur, Total		Al2O3 0.14
		TiO2 0.01
		Fe2O3 0.13
		CaO 42.15
		MgO 0.36
		Na2O 0.25
		K2O 0.06
		P2O5 0.02
		SO3 49.68
		Undetermined 6.33
<u>Misc.</u>		
<u>Analysis</u> <u>Value</u>		
% SOLIDS 12.9		
DENSITY 1.113	Hg 0.871 ppm	
	Fluorine	

As Determined Moisture 4.03 %

These values have been reviewed and are approved for transmission.

Distribution:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 

Research and Development
www.consolenergy.com
4000 Brownsville Rd.
South Park, PA 15129

FGD SLURRY SOLIDS 11:05

Date Completed: 04/04/2005
Date Received: 2/7/05
Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
Analytical No.: 20050710

UNIT 1 TEST 2 MODULE 1B

Sample No.: U1T2 FGDS-1B


<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	91.54	Carbon	2.39	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.3600	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	91.54	
		Oxygen (DIFF)		
				<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
				Soft.
				Hemi.
				Fluid
<u>Grindability</u>		<u>Free Swelling Index</u>		
HGI		FSI		
At Moisture %	5.32			
	0.00			
		<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				
Pyritic Sulfur				<u>Major Ash Elem.</u>
Sulfate				<i>as Def.</i>
Organic				
Sulfur, Total				SiO2 0.73
				Al2O3 0.08
				TiO2 0.00
				Fe2O3 0.11
				CaO 43.20
				MgO 0.31
				Na2O 0.16
				K2O 0.03
				P2O5 0.04
				SO3 41.41
				Undetermined 13.93
<u>Misc.</u>				
<u>Analysis</u>	<u>Value</u>			
% SOLIDS	7.4			
DENSITY	1.070	Hg	0.712 ppm	
		Fluorine		

As Determined Moisture 5.32 %

These values have been reviewed and are approved for transmission.

Distribution:
S. TSENG
J. LOCKE
J. WITHUM

Approved:





Research and Development
www.consolenergy.com
4000 Brownsville Rd.
South Park, PA 15129

FGD SLURRY SOLIDS 15:45

Date Completed: 04/04/2005
Date Received: 2/7/05
Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
Analytical No.: 20050711

UNIT 1 TEST 3 MODULE 1A

Sample No.: U1T3 FGDS-1A

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	99.81	Carbon	0.68	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.6100	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	99.81	
		Oxygen (DIFF)		

<u>Ash Fusion Oxidizing Temp. °F</u>
I.D.
Soft.
Hemi.
Fluid

<u>Grindability</u>	
HGI	
At Moisture %	4.03
	0.00

<u>Free Swelling Index</u>	
FSI	

Trace Elements

Sulfur Form (Dry)

Pyritic Sulfur	
Sulfate	
Organic	
Sulfur, Total	

Major Ash Elem.
as det.

SiO2	0.77
Al2O3	0.12
TiO2	0.01
Fe2O3	0.12
CaO	40.64
MgO	0.40
Na2O	0.30
K2O	0.07
P2O5	0.03
SO3	49.37

<u>Misc.</u>	
<u>Analysis</u>	<u>Value</u>
% SOLIDS	12.8
DENSITY	1.117

Hg	0.908 ppm
Fluorine	

Undetermined	8.17
--------------	------

As Determined Moisture 4.03 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
J. LOCKE
J. WITHUM

Approved:



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 15:50

Date Completed: 04/04/2005

Project No.: 1621 - 087 - 000

UNIT 1 TEST 3 MODULE 1B

Date Received: 2/7/05

Analytical No.: 20050712

Sample No.: U1T3 FGDS-1B

Submitted by: S. TSENG

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	92.24	Carbon	2.31	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.4000	Fluid
		Sulfur, Total		
BTU/lb		Ash	92.24	
MAF BTU/lb		Oxygen (DIFF)		
				<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
				Soft.
				Hemi.
				Fluid
<u>Grindability</u>		<u>Free Swelling Index</u>		
HGI		FSI		
At Moisture %	5.46			
	0.00			
		<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				
Pyritic Sulfur				
Sulfate				
Organic				
Sulfur, Total				
				<u>Major Ash Elem.</u>
				<i>as Det.</i>
				SiO2 0.74
				Al2O3 0.10
				TiO2 0.01
				Fe2O3 0.12
				CaO 41.98
				MgO 0.34
				Na2O 0.20
				K2O 0.05
				P2O5 0.05
				SO3 41.79
				Undetermined 14.62
<u>Misc.</u>				
<u>Analysis</u>	<u>Value</u>			
% SOLIDS	7.0			
DENSITY	1.070	Hg	0.744 ppm	
		Fluorine		

As Determined Moisture 5.46 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 11:20

Date Completed: 04/04/2005

Project No.: 1621 - 087 -000

UNIT 1 TEST 4 MODULE 1A

Date Received: 2/7/05

Analytical No.: 20050713

Sample No.: U1T4 FGDS-1A


Submitted by: S. TSENG

<u>Proximate (Dry)</u> %	<u>Ultimate (Dry)</u> %	<u>Ash Fusion Reducing Temp.</u> °F
Ash 99.30	Carbon 0.78	I.D.
Volatile Matter	Hydrogen	Soft.
Fixed Carbon	Nitrogen	Hemi.
	Chlorine 0.5600	Fluid
BTU/lb	Sulfur, Total	
MAF BTU/lb	Ash 99.30	
	Oxygen (DIFF)	
<u>Grindability</u>	<u>Free Swelling Index</u>	<u>Ash Fusion Oxidizing Temp.</u> °F
HGI	FSI	I.D.
At Moisture % 4.06		Soft.
0.00		Hemi.
	<u>Trace Elements</u>	Fluid
<u>Sulfur Form (Dry)</u>		
Pyritic Sulfur		
Sulfate		
Organic		
Sulfur, Total		
<u>Misc.</u>		<u>Major Ash Elem.</u>
		as det.
		SiO2 0.86
		Al2O3 0.14
		TiO2 0.01
		Fe2O3 0.13
		CaO 41.77
		MgO 0.33
		Na2O 0.23
		K2O 0.06
		P2O5 0.05
		SO3 49.64
		Undetermined 6.78
<u>Analysis</u>	<u>Value</u>	
% SOLIDS	13.1	
DENSITY	1.120	
	Hg 0.888 ppm	
	Fluorine	

As Determined Moisture 4.06 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 11:25
 UNIT 1 TEST 4 MODULE 1B
 Sample No.: U1T4 FGDS-1B

Date Completed: 04/04/2005
 Date Received: 2/7/05
 Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
 Analytical No.: 20050714

<u>Proximate (Dry) %</u>	<u>Ultimate (Dry) %</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash 93.02	Carbon 2.06	I.D.
Volatile Matter	Hydrogen	Soft.
Fixed Carbon	Nitrogen	Hemi.
	Chlorine 0.4800	Fluid
	Sulfur, Total	
BTU/lb	Ash 93.02	
MAF BTU/lb	Oxygen (DIFF)	

Ash Fusion Oxidizing Temp. °F

<u>Grindability</u>	<u>Free Swelling Index</u>	
HGI	FSI	I.D.
At Moisture % 5.83		Soft.
0.00		Hemi.
		Fluid

Sulfur Form (Dry)

	<u>Major Ash Elem.</u>
Pyritic Sulfur	<i>a> Del.</i>
Sulfate	
Organic	
Sulfur, Total	SiO2 0.77

Misc.

<u>Analysis</u>	<u>Value</u>	
% SOLIDS	6.9	
DENSITY	1.074	Hg 0.744 ppm
		Fluorine
		Undetermined 13.53

As Determined Moisture 5.83 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 12:53

Date Completed: 04/04/2005
Date Received: 2/7/05
Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
Analytical No.: 20050715

UNIT 2 TEST 1 MODULE 2A

Sample No.: U2T1 FGDS-2A

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	96.99	Carbon	1.32	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.5400	Fluid
		Sulfur, Total		
BTU/lb		Ash	96.99	
MAF BTU/lb		Oxygen (DIFF)		<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
		<u>Free Swelling Index</u>		Soft.
		FSI		Hemi.
<u>Grindability</u>				Fluid
HGI		<u>Trace Elements</u>		
At Moisture %	4.52			
	0.00			
<u>Sulfur Form (Dry)</u>				<u>Major Ash Elem.</u>
Pyritic Sulfur				<i>as Del.</i>
Sulfate				SiO2 0.99
Organic				Al2O3 0.06
Sulfur, Total				TiO2 0.00
				Fe2O3 0.05
				CaO 41.87
				MgO 0.29
				Na2O 0.22
				K2O 0.04
				P2O5 0.02
				SO3 46.67
<u>Misc.</u>				Undetermined 9.79
<u>Analysis</u>	<u>Value</u>			
% SOLIDS	9.5	Hg	0.607 ppm	
DENSITY	1.077	Fluorine		

As Determined Moisture 4.52 %

These values have been reviewed and are approved for transmission.

Distribution:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 12:58

Date Completed: 04/04/2005

Project No.: 1621 - 087 - 000

UNIT 2 TEST 1 MODULE 2C

Date Received: 2/7/05

Analytical No.: 20050716

Sample No.: U2T1 FGDS-2C

Submitted by: S. TSENG

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	99.90	Carbon	0.60	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.6200	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	99.90	
		Oxygen (DIFF)		<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
<u>Grindability</u>		<u>Free Swelling Index</u>		Soft.
HGI		FSI		Hemi.
At Moisture %	6.12			Fluid
	0.00	<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				<u>Major Ash Elem.</u>
Pyritic Sulfur				as det.
Sulfate				SiO2
Organic				1.27
Sulfur, Total				Al2O3
				0.12
				TiO2
				0.01
				Fe2O3
				0.08
				CaO
				40.12
				MgO
				0.33
				Na2O
				0.30
				K2O
				0.07
				P2O5
				0.00
				SO3
				50.62
				Undetermined
				7.08

Misc.

<u>Analysis</u>	<u>Value</u>
% SOLIDS	10.9
DENSITY	1.098

Hg 0.562 ppm
 Fluorine

As Determined Moisture 6.12 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 10:11

Date Completed: 04/04/2005

Project No.: 1621 - 087 - 000

UNIT 2 TEST 2 MODULE 2A

Date Received: 2/7/05

Analytical No.: 20050717

Sample No.: U2T2 FGDS-2A

Submitted by: S. TSENG

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	95.23	Carbon	1.83	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.4800	Fluid
		Sulfur, Total		
BTU/lb		Ash	95.23	
MAF BTU/lb		Oxygen (DIFF)		
				<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
				Soft.
				Hemi.
				Fluid
<u>Grindability</u>		<u>Free Swelling Index</u>		
HGI		FSI		
At Moisture %	4.60			
	0.00			
		<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				
Pyritic Sulfur				<u>Major Ash Elem.</u>
Sulfate				as det.
Organic				
Sulfur, Total				SiO2 1.27
				Al2O3 0.07
				TiO2 0.00
				Fe2O3 0.07
				CaO 43.37
				MgO 0.40
				Na2O 0.29
				K2O 0.05
				P2O5 0.03
				SO3 45.43
				Undetermined 9.02
<u>Misc.</u>				
<u>Analysis</u>	<u>Value</u>			
% SOLIDS	10.1			
DENSITY	1.088	Hg	0.592 ppm	
		Fluorine		

As Determined Moisture 4.60 %

These values have been reviewed and are approved for transmission.

Distribution:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 10:16

UNIT 2 TEST 2 MODULE 2C

Sample No.: U2T2 FGDS-2C

Date Completed: 04/04/2005

Date Received: 2/7/05

Submitted by: S. TSENG

Project No.: 1621 - 087 - 000


Analytical No.: 20050718

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	97.80	Carbon	0.60	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.6300	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	97.80	
		Oxygen (DIFF)		<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
<u>Grindability</u>		<u>Free Swelling Index</u>		Soft.
HGI		FSI		Hemi.
At Moisture %	3.42			Fluid
	0.00	<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				<u>Major Ash Elem.</u>
Pyritic Sulfur				als det
Sulfate				SiO2 1.15
Organic				Al2O3 0.06
Sulfur, Total				TiO2 0.00
				Fe2O3 0.05
				CaO 40.81
				MgO 0.29
				Na2O 0.24
				K2O 0.04
				P2O5 0.01
				SO3 51.29
<u>Misc.</u>				Undetermined 6.06
<u>Analysis</u>	<u>Value</u>			
% SOLIDS	11.0			
DENSITY	1.084	Hg	0.562 ppm	
		Fluorine		

As Determined Moisture 3.42 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 14:02

UNIT 2 TEST 3 MODULE 2A

Sample No.: U2T3 FGDS-2A

Date Completed: 04/04/2005

Date Received: 2/7/05

Submitted by: S. TSENG

Project No.: 1621 - 087 - 000


Analytical No.: 20050719

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	94.29	Carbon	1.69	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.6200	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	94.29	
		Oxygen (DIFF)		<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
<u>Grindability</u>		<u>Free Swelling Index</u>		Soft.
HGI		FSI		Hemi.
At Moisture %	2.51			Fluid
	0.00	<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				<u>Major Ash Elem.</u>
Pyritic Sulfur				as det.
Sulfate				SiO2 1.24
Organic				Al2O3 0.06
Sulfur, Total				TiO2 0.00
				Fe2O3 0.06
				CaO 42.21
				MgO 0.31
				Na2O 0.22
				K2O 0.03
				P2O5 0.00
				SO3 46.15
				Undetermined 9.72
<u>Misc.</u>				
<u>Analysis</u>	<u>Value</u>			
% SOLIDS	9.5			
DENSITY	1.093	Hg	0.639 ppm	
		Fluorine		

As Determined Moisture 2.51 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
www.consolenergy.com
4000 Brownsville Rd.
South Park, PA 15129

FGD SLURRY SOLIDS 14:07

Date Completed: 04/04/2005

Project No.: 1621 - 087 - 000

UNIT 2 TEST 3 MODULE 2C

Date Received: 2/7/05

Analytical No.: 20050720

Sample No.: U2T3 FGDS-2C

Submitted by: S. TSENG

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	97.56	Carbon	0.66	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.5900	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	97.56	
		Oxygen (DIFF)		

<u>Grindability</u>	<u>Free Swelling Index</u>	<u>Ash Fusion Oxidizing Temp. °F</u>
HGI	FSI	I.D.
At Moisture % 2.69		Soft.
0.00		Hemi.
		Fluid

Sulfur Form (Dry)

Pyritic Sulfur
Sulfate
Organic
Sulfur, Total

Major Ash Elem.

as Del.

SiO2	1.18
Al2O3	0.07
TiO2	0.00
Fe2O3	0.07
CaO	41.34
MgO	0.33
Na2O	0.26
K2O	0.03
P2O5	0.01
SO3	51.73

Misc.

<u>Analysis</u>	<u>Value</u>
% SOLIDS	10.5
DENSITY	1.084

Hg 0.575 ppm
Fluorine

Undetermined 4.98

As Determined Moisture 2.69 %

These values have been reviewed and are approved for transmission.

Distribution:
S. TSENG
J. LOCKE
J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 09:38
UNIT 2 TEST 4 MODULE 2A
Sample No.: U2T4 FGDS-2A

Date Completed: 04/04/2005
Date Received: 2/7/05
Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
Analytical No.: 20050721

<u>Proximate (Dry)</u>	<u>%</u>	<u>Ultimate (Dry)</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	97.50	Carbon	0.79	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.6400	Fluid
BTU/lb		Sulfur, Total		
MAF BTU/lb		Ash	97.50	
		Oxygen (DIFF)		<u>Ash Fusion Oxidizing Temp. °F</u>
				I.D.
<u>Grindability</u>		<u>Free Swelling Index</u>		Soft.
HGI		FSI		Hemi.
At Moisture %	2.95			Fluid
	0.00	<u>Trace Elements</u>		
<u>Sulfur Form (Dry)</u>				<u>Major Ash Elem.</u>
Pyritic Sulfur				as det
Sulfate				SiO2 1.19
Organic				Al2O3 0.07
Sulfur, Total				TiO2 0.00
				Fe2O3 0.06
				CaO 40.71
				MgO 0.31
				Na2O 0.26
				K2O 0.05
				P2O5 0.01
				SO3 49.97
<u>Misc.</u>				Undetermined 7.37
<u>Analysis</u>	<u>Value</u>			
		Hg	0.592 ppm	
		Fluorine		

As Determined Moisture 2.95 %

These values have been reviewed and are approved for transmission.

Distribution:
 S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 



Research and Development
 www.consolenergy.com
 4000 Brownsville Rd.
 South Park, PA 15129

FGD SLURRY SOLIDS 09:40
UNIT 2 TEST 4 MODULE 2C
Sample No.: U2T4 FGDS-2C

Date Completed: 04/04/2005
Date Received: 2/7/05
Submitted by: S. TSENG

Project No.: 1621 - 087 - 000
Analytical No.: 20050722

<u>Proximate</u>	<u>%</u>	<u>Ultimate</u>	<u>%</u>	<u>Ash Fusion Reducing Temp. °F</u>
Ash	97.70	Carbon	0.59	I.D.
Volatile Matter		Hydrogen		Soft.
Fixed Carbon		Nitrogen		Hemi.
		Chlorine	0.6400	Fluid
		Sulfur, Total		
BTU/lb		Ash	97.70	
MAF BTU/lb		Oxygen (DIFF)		

Ash Fusion Oxidizing Temp. °F

<u>Grindability</u>		<u>Free Swelling Index</u>		
HGI		FSI		I.D.
At Moisture %	3.25			Soft.
	0.00			Hemi.
				Fluid

Sulfur Form

Pyritic Sulfur
 Sulfate
 Organic
 Sulfur, Total

Major Ash Elem.

as det.

SiO2	1.18
Al2O3	0.05
TiO2	0.00
Fe2O3	0.05
CaO	40.23
MgO	0.33
Na2O	0.28
K2O	0.04
P2O5	0.01
SO3	51.01

Misc.

<u>Analysis</u>	<u>Value</u>
% SOLIDS	9.4
DENSITY	1.090

Hg 0.616 ppm
 Fluorine

Undetermined 6.82

As Determined Moisture 3.25 %

These values have been reviewed and are approved for transmission.

Distribution: S. TSENG
 J. LOCKE
 J. WITHUM

Approved: 

FGD SLURRY FILTRATE 13:05

Sample No.: U1T1 FGDS-1A
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050792
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations	
pH					Ion Sum	50967.72
Acidity, CaCO ₃					Cation Sum	805.05
Alkalinity, CaCO ₃					Anion Sum	1004.25
Hydroxide, CaCO ₃					Ion Balance	12.71
Carbonate, CaCO ₃					% Ion Imbalance	-11.01
Bicarbonate, CaCO ₃						
Total Suspended Solids						
Total Dissolved Solids						
Specific Conductivity						
Hardness						
Turbidity						
Osmotic Pressure						
Dissolved Oxygen						
Ammonia, N	<10					
Total Elements						
Aluminum					Hg	4.0 <i>ng/ml</i>
Calcium	3910.37					
Iron	1.42					
Magnesium	4525.65					
Manganese						
Potassium	753.97					
Phosphorous						
Silicon						
Sodium	5021.37					
Chromium						
Anions:						
Sulfate	4059.71					
Chloride	32500					
Nitrate, N	44.08					
Nitrite, N						
Bromide						
Fluoride						

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 13:05

Sample No.: U1T1 FGDS-1B
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050793
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result

(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 38216.08
Acidity, CaCO ₃					Cation Sum 554.62
Alkalinity, CaCO ₃					Anion Sum 765.94
Hydroxide, CaCO ₃					Ion Balance 17.64
Carbonate, CaCO ₃					% Ion Imbalance -16.00
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					Hg 4.5 <i>mg/ml</i>
Calcium	2981.17				
Iron	3.99				
Magnesium	3011.70				
Manganese					
Potassium	506.33				
Phosphorous					
Silicon					
Sodium	3335.64				
Chromium					
Anions:					
Sulfate	3936.56				
Chloride	24000				
Nitrate, N	99.5				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 11:00

Sample No.: U1T2 FGDS-1A

Date Received: 02/07/2005

Date Completed: 04/05/2005

Analytical No.: 20050794

Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result

(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 50671.24
Acidity, CaCO ₃					Cation Sum 708.70
Alkalinity, CaCO ₃					Anion Sum 1049.28
Hydroxide, CaCO ₃					Ion Balance 20.80
Carbonate, CaCO ₃					% Ion Imbalance -19.37
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	10				
Total Elements					
Aluminum					Hg 4.8 <i>ng/ml</i>
Calcium	3447.08				
Iron	<1.25				
Magnesium	4002.58				
Manganese					
Potassium	659.04				
Phosphorous					
Silicon					
Sodium	4383.71				
Chromium					
Anions:					
Sulfate	3617.71				
Chloride	34500				
Nitrate, N	13.8				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 11:05

Sample No.: U1T2 FGDS-1B
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050795
Project No.: 1621 -087 -000
Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 36362.28
Acidity, CaCO ₃					Cation Sum 560.19
Alkalinity, CaCO ₃					Anion Sum 706.59
Hydroxide, CaCO ₃					Ion Balance 13.24
Carbonate, CaCO ₃					% Ion Imbalance -11.56
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	10				
Total Elements					
Aluminum					Hg 5.7 <i>ng/mL</i>
Calcium	3044.15				
Iron	4.53				
Magnesium	3017.89				
Manganese					
Potassium	505.00				
Phosphorous					
Silicon					
Sodium	3380.13				
Chromium					
Anions:					
Sulfate	4478.75				
Chloride	21500				
Nitrate, N	97.5				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 15:45

Sample No.: U1T3 FGDS-1A
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: **20050796**
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result

(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 50628.59
Acidity, CaCO ₃					Cation Sum 754.47
Alkalinity, CaCO ₃					Anion Sum 1024.59
Hydroxide, CaCO ₃					Ion Balance 16.90
Carbonate, CaCO ₃					% Ion Imbalance -15.18
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	10				
Total Elements					
Aluminum					Hg 2.7 ng/mL
Calcium	3673.01				
Iron	2.29				
Magnesium	4276.17				
Manganese					
Potassium	697.68				
Phosphorous					
Silicon					
Sodium	4634.72				
Chromium					
Anions:					
Sulfate	3795.12				
Chloride	33500				
Nitrate, N	11.2				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 15:50

Sample No.: U1T3 FGDS-1B
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: **20050797**
Project No.: 1621 -087 -000
Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 36385.99
Acidity, CaCO ₃					Cation Sum 521.81
Alkalinity, CaCO ₃					Anion Sum 728.67
Hydroxide, CaCO ₃					Ion Balance 18.14
Carbonate, CaCO ₃					% Ion Imbalance -16.54
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					Hg 3.6 <i>ng/ml</i>
Calcium	2833.62				
Iron	4.17				
Magnesium	2797.98				
Manganese					
Potassium	472.19				
Phosphorous					
Silicon					
Sodium	3174.58				
Chromium					
Anions:					
Sulfate	4230.53				
Chloride	22500				
Nitrate, N	84.2				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 11:20

Sample No.: U1T4 FGDS-1A
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: **20050798**
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result

(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 49220.75
Acidity, CaCO ₃					Cation Sum 694.62
Alkalinity, CaCO ₃					Anion Sum 1017.41
Hydroxide, CaCO ₃					Ion Balance 20.33
Carbonate, CaCO ₃					% Ion Imbalance -18.85
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					Hg 4.0 <i>ng/mL</i>
Calcium	3389.53				
Iron	2.14				
Magnesium	3937.33				
Manganese					
Potassium	639.89				
Phosphorous					
Silicon					
Sodium	4258.81				
Chromium					
Anions:					
Sulfate	3474.18				
Chloride	33500				
Nitrate, N	4.26				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 11:25
Sample No.: U1T4 FGDS-1B

Date Received: 02/07/2005

Date Completed: 04/05/2005

Analytical No.: 20050799

Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 33483.01
Acidity, CaCO ₃					Cation Sum 507.21
Alkalinity, CaCO ₃					Anion Sum 659.33
Hydroxide, CaCO ₃					Ion Balance 14.73
Carbonate, CaCO ₃					% Ion Imbalance -13.04
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	10				
Total Elements					
Aluminum					Hg 4.2 <i>ng/mL</i>
Calcium	2767.72				
Iron	3.63				
Magnesium	2738.40				
Manganese					
Potassium	454.20				
Phosphorous					
Silicon					
Sodium	3038.37				
Chromium					
Anions:					
Sulfate	3615.30				
Chloride	20500				
Nitrate, N	82.5				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 12:53

Sample No.: U2T1 FGDS-2A
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050800
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 44965.26
Acidity, CaCO ₃					Cation Sum 690.57
Alkalinity, CaCO ₃					Anion Sum 895.17
Hydroxide, CaCO ₃					Ion Balance 14.63
Carbonate, CaCO ₃					% Ion Imbalance -12.90
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	10				
Total Elements					
Aluminum					<i>Hg</i> <1.0 mg/mL
Calcium	3639.67				
Iron	1.98				
Magnesium	3627.91				
Manganese					
Potassium	668.04				
Phosphorous					
Silicon					
Sodium	4447.30				
Chromium					
Anions:					
Sulfate	2882.38				
Chloride	29500				
Nitrate, N	44.7				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 12:58

Sample No.: U2T1 FGDS-2C
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: **20050801**
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result

(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations	
pH					Ion Sum	49157.85
Acidity, CaCO ₃					Cation Sum	729.53
Alkalinity, CaCO ₃					Anion Sum	994.26
Hydroxide, CaCO ₃					Ion Balance	17.06
Carbonate, CaCO ₃					% Ion Imbalance	-15.36
Bicarbonate, CaCO ₃						
Total Suspended Solids						
Total Dissolved Solids						
Specific Conductivity						
Hardness						
Turbidity						
Osmotic Pressure						
Dissolved Oxygen						
Ammonia, N	10					
Total Elements						
Aluminum					Hg	1.9 <i>ng/mL</i>
Calcium	3795.69					
Iron	<1.25					
Magnesium	3869.88					
Manganese						
Potassium	706.67					
Phosphorous						
Silicon						
Sodium	4685.44					
Chromium						
Anions:						
Sulfate	2897.32					
Chloride	33000					
Nitrate, N	45.8					
Nitrite, N						
Bromide						
Fluoride						

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 10:11

 Sample No.: U2T2 FGDS-2A
 Date Received: 02/07/2005
 Date Completed: 04/05/2005

 Analytical No.: **20050802**
 Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
 (mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 41714.65
Acidity, CaCO ₃					Cation Sum 631.70
Alkalinity, CaCO ₃					Anion Sum 834.52
Hydroxide, CaCO ₃					Ion Balance 15.55
Carbonate, CaCO ₃					% Ion Imbalance -13.83
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					Hg 1.3 <i>ng/mL</i>
Calcium	3313.01				
Iron	1.69				
Magnesium	3313.00				
Manganese					
Potassium	610.91				
Phosphorous					
Silicon					
Sodium	4097.95				
Chromium					
Anions:					
Sulfate	2673.03				
Chloride	27500				
Nitrate, N	46.3				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 10:16

Sample No.: U2T2 FGDS-2C
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: **20050803**
Project No.: 1621 -087 -000
Submitter: S. TSENG

Water Result

(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 49936.40
Acidity, CaCO ₃					Cation Sum 859.19
Alkalinity, CaCO ₃					Anion Sum 946.89
Hydroxide, CaCO ₃					Ion Balance 5.93
Carbonate, CaCO ₃					% Ion Imbalance -4.86
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg <1.0 ng/mL</i>
Calcium	4367.31				
Iron	<1.25				
Magnesium	4548.29				
Manganese					
Potassium	836.90				
Phosphorous					
Silicon					
Sodium	5651.44				
Chromium					
Anions:					
Sulfate	3336.26				
Chloride	31000				
Nitrate, N	44.3				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 14:02

 Sample No.: U2T3 FGDS-2A
 Date Received: 02/07/2005
 Date Completed: 04/05/2005

 Analytical No.: **20050804**
 Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 38070.27
Acidity, CaCO ₃					Cation Sum 603.79
Alkalinity, CaCO ₃					Anion Sum 746.72
Hydroxide, CaCO ₃					Ion Balance 12.24
Carbonate, CaCO ₃					% Ion Imbalance -10.58
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					Hg 1.3 <i>ng/ml</i>
Calcium	3122.81				
Iron	<1.25				
Magnesium	3148.49				
Manganese					
Potassium	586.93				
Phosphorous					
Silicon					
Sodium	4000.99				
Chromium					
Anions:					
Sulfate	2565.78				
Chloride	24500				
Nitrate, N	32.8				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 14:07

Sample No.: U2T3 FGDS-2C
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050805
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result

(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 48263.39
Acidity, CaCO ₃					Cation Sum 807.07
Alkalinity, CaCO ₃					Anion Sum 928.25
Hydroxide, CaCO ₃					Ion Balance 8.36
Carbonate, CaCO ₃					% Ion Imbalance -6.98
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	10				
Total Elements					
Aluminum					Hg 1.0 <i>ng/mL</i>
Calcium	4145.00				
Iron	<1.25				
Magnesium	4277.07				
Manganese					
Potassium	784.28				
Phosphorous					
Silicon					
Sodium	5251.84				
Chromium					
Anions:					
Sulfate	3150.18				
Chloride	30500				
Nitrate, N	35.0				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 09:38

Sample No.: U2T4 FGDS-2A
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050806
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result

(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 46286.42
Acidity, CaCO ₃					Cation Sum 772.61
Alkalinity, CaCO ₃					Anion Sum 888.03
Hydroxide, CaCO ₃					Ion Balance 8.32
Carbonate, CaCO ₃					% Ion Imbalance -6.95
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					Hg 1.0 <i>ng/ml</i>
Calcium	3928.41				
Iron	1.61				
Magnesium	4067.27				
Manganese					
Potassium	752.80				
Phosphorous					
Silicon					
Sodium	5121.87				
Chromium					
Anions:					
Sulfate	3218.26				
Chloride	29000				
Nitrate, N	44.3				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD SLURRY FILTRATE 09:40

Sample No.: U2T4 FGDS-2C
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: **20050807**
Project No.: 1621 -087 -000
Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 50415.24
Acidity, CaCO ₃					Cation Sum 693.77
Alkalinity, CaCO ₃					Anion Sum 1047.82
Hydroxide, CaCO ₃					Ion Balance 21.66
Carbonate, CaCO ₃					% Ion Imbalance -20.33
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	10				
Total Elements					
Aluminum					Hg 1.3 <i>ng/mL</i>
Calcium	3541.98				
Iron	<1.25				
Magnesium	3649.58				
Manganese					
Potassium	682.19				
Phosphorous					
Silicon					
Sodium	4585.21				
Chromium					
Anions:					
Sulfate	2787.98				
Chloride	35000				
Nitrate, N	38.0				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD MAKE-UP WATER 13:00

Sample No.: FGD MAKEUP U1T1
 Date Received: 02/07/2005
 Date Completed: 04/05/2005

Analytical No.: 20050808
 Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
 (mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 9306.31
Acidity, CaCO ₃					Cation Sum 156.33
Alkalinity, CaCO ₃					Anion Sum 165.79
Hydroxide, CaCO ₃					Ion Balance 3.53
Carbonate, CaCO ₃					% Ion Imbalance -2.94
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					Hg <1.0 mg/ml
Calcium	917.31				
Iron	0.10				
Magnesium	679.16				
Manganese					
Potassium	198.57				
Phosphorous					
Silicon					
Sodium	1140.83				
Chromium					
Anions:					
Sulfate	1853.07				
Chloride	4500				
Nitrate, N	3.9				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD MAKE-UP WATER 11:00

Sample No.: FGD MAKEUP U1T2
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050809
Project No.: 1621 -087 -000
Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 8426.92
Acidity, CaCO ₃					Cation Sum 142.39
Alkalinity, CaCO ₃					Anion Sum 148.69
Hydroxide, CaCO ₃					Ion Balance 2.61
Carbonate, CaCO ₃					% Ion Imbalance -2.16
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg <1.0 ng/ml</i>
Calcium	828.85				
Iron	0.13				
Magnesium	609.90				
Manganese					
Potassium	170.14				
Phosphorous					
Silicon					
Sodium	1069.51				
Chromium					
Anions:					
Sulfate	1762.52				
Chloride	3950				
Nitrate, N	8.1				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD MAKE-UP WATER 15:40

Sample No.: FGD MAKEUP U1T3

Date Received: 02/07/2005

Date Completed: 04/05/2005

Analytical No.: 20050810

Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
 (mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 8277.87
Acidity, CaCO ₃					Cation Sum 138.97
Alkalinity, CaCO ₃					Anion Sum 146.55
Hydroxide, CaCO ₃					Ion Balance 3.19
Carbonate, CaCO ₃					% Ion Imbalance -2.65
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg</i> <1.0 <i>ng/ml</i>
Calcium	810.99				
Iron	0.07				
Magnesium	595.92				
Manganese					
Potassium	164.96				
Phosphorous					
Silicon					
Sodium	1040.89				
Chromium					
Anions:					
Sulfate	1721.64				
Chloride	3900				
Nitrate, N	9.8				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD MAKE-UP WATER 11:15

Sample No.: FGD MAKEUP U1T4
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050811
Project No.: 1621 -087 -000
Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 7294.38
Acidity, CaCO ₃					Cation Sum 123.13
Alkalinity, CaCO ₃					Anion Sum 126.74
Hydroxide, CaCO ₃					Ion Balance 1.75
Carbonate, CaCO ₃					% Ion Imbalance -1.45
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					
Calcium	694.67				
Iron	0.08				
Magnesium	496.20				
Manganese					
Potassium	153.82				
Phosphorous					
Silicon					
Sodium	1005.17				
Chromium					
Anions:					
Sulfate	1649.71				
Chloride	3250				
Nitrate, N	10.1				
Nitrite, N					
Bromide					
Fluoride					

Hg <1.0 *ng/ml*

These values have been reviewed and are approved for transmission.

FGD MAKE-UP WATER 11:45

Sample No.: FGD MAKEUP U2T1
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050812
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 31648.04
Acidity, CaCO ₃					Cation Sum 504.98
Alkalinity, CaCO ₃					Anion Sum 613.12
Hydroxide, CaCO ₃					Ion Balance 11.25
Carbonate, CaCO ₃					% Ion Imbalance -9.67
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	<10				
Total Elements					
Aluminum					<i>Hg</i> <1.0 <i>ng/ml</i>
Calcium	2798.04				
Iron	0.64				
Magnesium	2565.96				
Manganese					
Potassium	489.87				
Phosphorous					
Silicon					
Sodium	3259.80				
Chromium					
Anions:					
Sulfate	3033.73				
Chloride	19500				
Nitrate, N	<0.02				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD MAKE-UP WATER 09:17

Sample No.: FGD MAKEUP U2T2
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050813
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 34596.96
Acidity, CaCO ₃					Cation Sum 572.54
Alkalinity, CaCO ₃					Anion Sum 660.79
Hydroxide, CaCO ₃					Ion Balance 8.53
Carbonate, CaCO ₃					% Ion Imbalance -7.16
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	10				
Total Elements					
Aluminum					<i>Hg</i> <1.0 ng/mL
Calcium	3173.55				
Iron	0.94				
Magnesium	2938.35				
Manganese					
Potassium	549.83				
Phosphorous					
Silicon					
Sodium	3642.54				
Chromium					
Anions:					
Sulfate	3291.75				
Chloride	21000				
Nitrate, N	<0.02				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD MAKE-UP WATER 13:30

Sample No.: FGD MAKEUP U2T3
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050814
Project No.: 1621 -087 -000

Submitter: S. TSENG

Water Result
(mg/L unless noted otherwise)

Parameter	Value	Value	Units	Avg Value	Quality Control Calculations
pH					Ion Sum 28457.16
Acidity, CaCO ₃					Cation Sum 474.56
Alkalinity, CaCO ₃					Anion Sum 539.80
Hydroxide, CaCO ₃					Ion Balance 7.70
Carbonate, CaCO ₃					% Ion Imbalance -6.43
Bicarbonate, CaCO ₃					
Total Suspended Solids					
Total Dissolved Solids					
Specific Conductivity					
Hardness					
Turbidity					
Osmotic Pressure					
Dissolved Oxygen					
Ammonia, N	10				
Total Elements					
Aluminum					Hg <1.0 ng/mL
Calcium	2693.57				
Iron	0.97				
Magnesium	2404.54				
Manganese					
Potassium	452.63				
Phosphorous					
Silicon					
Sodium	3006.98				
Chromium					
Anions:					
Sulfate	2898.47				
Chloride	17000				
Nitrate, N	<0.02				
Nitrite, N					
Bromide					
Fluoride					

These values have been reviewed and are approved for transmission.

FGD MAKE-UP WATER 09:00

Sample No.: FGD MAKEUP U2T4
Date Received: 02/07/2005
Date Completed: 04/05/2005

Analytical No.: 20050815
Project No.: 1621 -087 -000

Submitter: S. TSENG

<u>Water Result</u>						
<u>(mg/L unless noted otherwise)</u>						
Parameter	Value	Value	Units	Avg Value	Quality Control Calculations	
pH					Ion Sum	25299.25
Acidity, CaCO ₃					Cation Sum	400.75
Alkalinity, CaCO ₃					Anion Sum	489.88
Hydroxide, CaCO ₃					Ion Balance	11.58
Carbonate, CaCO ₃					% Ion Imbalance	-10.01
Bicarbonate, CaCO ₃						
Total Suspended Solids						
Total Dissolved Solids						
Specific Conductivity						
Hardness						
Turbidity						
Osmotic Pressure						
Dissolved Oxygen						
Ammonia, N	<10					
Total Elements						
Aluminum					<i>Hkj</i> <1.0 <i>mg/lmc</i>	
Calcium	2225.20					
Iron	0.77					
Magnesium	1999.49					
Manganese						
Potassium	392.08					
Phosphorous						
Silicon						
Sodium	2649.03					
Chromium						
Anions:						
Sulfate	2532.68					
Chloride	15500					
Nitrate, N	<0.02					
Nitrite, N						
Bromide						
Fluoride						

These values have been reviewed and are approved for transmission.