

University of New Hampshire
University of New Hampshire Scholars' Repository

Division 10 – Specialties

Chapter 5 – Technical Construction and
Renovation Standards

8-11-2015

102113 - Toilet Compartments

Sandra Hickey
sandra.hickey@unh.edu

Follow this and additional works at: https://scholars.unh.edu/pdch_5_10

Recommended Citation

Hickey, Sandra, "102113 - Toilet Compartments" (2015). *Division 10 – Specialties*. 9.
https://scholars.unh.edu/pdch_5_10/9

This Article is brought to you for free and open access by the Chapter 5 – Technical Construction and Renovation Standards at University of New Hampshire Scholars' Repository. It has been accepted for inclusion in Division 10 – Specialties by an authorized administrator of University of New Hampshire Scholars' Repository. For more information, please contact nicole.hentz@unh.edu.

SECTION 10 2113 - TOILET COMPARTMENTS

PART 1 GENERAL

1.1 SUMMARY

- A. The University prefers to use regional materials within a 500 mile radius of the campus.
- B. Section Includes:
 - 1. Solid-polymer toilet compartments configured as toilet enclosures and urinal screens.

1.2 SUBMITTALS

- A. LEED Submittals:
 - 1. Product Data for Credit MR 4.1 and Credit MR 4.2: For products having recycled content, documentation indicating percentages by weight of postconsumer and preconsumer recycled content. Include statement indicating costs for each product having recycled content.

1.3 QUALITY ASSURANCE

- A. Comply with requirements in GSA's CID-A-A-60003, "Partitions, Toilets, Complete."
- B. Surface-Burning Characteristics: As determined by testing identical products according to ASTM E 84, or another standard acceptable to authorities having jurisdiction, by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - 1. Flame-Spread Index: 25 or less.
 - 2. Smoke-Developed Index: 450 or less.
- C. Regulatory Requirements: Comply with applicable provisions in the U.S. Architectural & Transportation Barriers Compliance Board's "Americans with Disabilities Act (ADA) and Architectural Barriers Act (ABA) Accessibility Guidelines for Buildings and Facilities" and ICC/ANSI A117.1 for toilet compartments designated as accessible.

PART 2 PRODUCTS

2.1 MATERIALS

- A. Aluminum Castings: ASTM B 26/B 26M.

- B. Aluminum Extrusions: ASTM B 221 (ASTM B 221M).
- C. Steel Sheet: Commercial steel sheet for exposed applications; mill phosphatized and selected for smoothness.
 - 1. Electrolytically Zinc Coated: ASTM A 879/A 879M, 01Z (03G).
 - 2. Hot-Dip Galvanized: ASTM A 653/A 653M, either hot-dip galvanized or galvanized.
- D. Stainless-Steel Sheet: ASTM A 666, Type 304, stretcher-leveled standard of flatness.
- E. Stainless-Steel Castings: ASTM A 743/A 743M.
- F. Zamac: ASTM B 86, commercial zinc-alloy die castings.

2.2 SOLID-POLYMER UNITS

- A. Manufacturers:
 - 1. Bradley Corporation; Mills Partitions.
 - 2. Comtec Industries/Capitol Partitions.
 - 3. General Partitions Mfg. Corp.
 - 4. Global Steel Products Corp.
 - 5. Santana Products, Inc.
 - 6. Sanymetal; a Crane Plumbing company.
- B. Toilet-Enclosure Style: Floor mounted.
- C. Urinal-Screen Style: Wall hung.
- D. Door, Panel, and Pilaster Construction: Solid, high-density polyethylene (HDPE) or polypropylene (PP) panel material, not less than 1 inch (25 mm) thick, seamless, with eased edges, and with homogenous color and pattern throughout thickness of material.
 - 1. Integral Hinges: Configure doors and pilasters to receive integral hinges.
 - 2. Heat-Sink Strip: Manufacturer's standard continuous, extruded-aluminum or stainless-steel strip fastened to exposed bottom edges of solid-polymer components to prevent burning.
- E. Pilaster Sleeves (Caps): Manufacturer's standard design; polymer or stainless steel.
- F. Brackets (Fittings):
 - 1. Full-Height (Continuous) Type: Manufacturer's standard design; stainless steel.

2.3 ACCESSORIES

- A. Hardware and Accessories: Manufacturer's standard design, heavy-duty operating hardware and accessories.

1. Material: Stainless steel.

PART 3 EXECUTION

3.1 FABRICATION

- A. Floor mounted Units: Provide manufacturer's standard corrosion-resistant anchoring assemblies with leveling adjustment nuts at pilasters for connection to the finished floor. Provide sleeves (caps) at bottom of pilasters to conceal anchorage.
- B. Door Size and Swings: Unless otherwise indicated, provide 24-inch- (610-mm-) wide, in-swinging doors for standard toilet compartments and 36-inch- (914-mm-) wide, out-swinging doors with a minimum 32-inch- (813-mm-) wide, clear opening for compartments designated as accessible.

3.2 INSTALLATION

- A. Floor mounted Units: Secure pilasters to floor and level, plumb, and tighten.
- B. Urinal Screens: Attach with anchoring devices to suit supporting structure. Set units level and plumb, rigid, and secured to resist lateral impact.

END OF SECTION 10 2113