

## COMPARATIVE STUDY OF FLOW CONDENSATION IN CONVENTIONAL AND SMALL DIAMETER TUBES

Dariusz Mikielwicz\*, Rafał Andrzejczyk

\*Author for correspondence

Gdansk University of Technology, Faculty of Mechanical Engineering,

Department of Energy and Industrial Apparatus,

ul. Narutowicza 11/12, 80-233 Gdansk, Poland

Email: [Dariusz.Mikielwicz@pg.gda.pl](mailto:Dariusz.Mikielwicz@pg.gda.pl)

### ABSTRACT

Flow boiling and flow condensation are often regarded as two opposite or symmetrical phenomena, however their description with a single correlation has yet to be suggested. In the case of flow boiling in minichannels there is mostly encountered the annular flow structure, where the bubble generation is not present. Similar picture holds for the case of inside tube condensation, where annular flow structure predominates. In such case the heat transfer coefficient is primarily dependent on the convective mechanism. In the paper a method developed earlier by D. Mikielwicz et al. [1] is applied to calculations of heat transfer coefficient for inside tube condensation. The method has been verified using experimental data from literature due to Cavallini et al. [4], Hoo-Kyu Oh et al. [5], Matkovic et al. [6], Park et al. [9] and compared to Cavallini et al. [2] and Thome et al. [11] correlations for calculations of heat transfer coefficient.

### INTRODUCTION

Flow boiling and flow condensation are often regarded as two opposite or symmetrical phenomena involving the change of phase. There is a temptation to describe both these phenomena with one only correlation, however no such model has yet been suggested. In both cases of phase change the annular flow structure seems to be mostly susceptible to common modeling. Such approach to modeling fail however in cases where other flow structures are present as for example the bubbly flow. In the case of flow boiling in conventional channels one can expect that bubble nucleation renders the process of heat transfer not to have its counterpart in the condensation inside tubes. Similarly in as the case of inside tube condensation, where the collapse of bubbles to form a continuous liquid is the condensation specific phenomenon. Situation seems to be a little less complex in the case of flow boiling in minichannels and microchannels. In such flows the annular flow structure is dominant for most qualities, Thome and Consolini [19]. In such case the heat transfer coefficient is primarily dependent on the convective mechanism. Most of correct modeling of heat transfer in case of condensation inside

channels relates the heat transfer coefficient to the friction coefficient, contrary to modeling in case of flow boiling.

The objective of this paper is to present the capability of the flow boiling model, developed earlier [1] to model flow boiling and flow condensation inside tubes. Therefore some calculations have been accomplished to validate that method with the selection of experimental data due to Cavallini et al. [3], Hoo-Kyu Oh et al. [4], Matkovic et al. [5], Park et al. [8]. Calculations have been also compared against some well established methods for calculation of heat transfer coefficient due to Cavallini et al. [2] and Thome et al. [10].

### NOMENCLATURE

$c_p$	J/kg K	specific heat
Con		Constraint number, $Con=(\sigma/g/(\rho_l-\rho_v))^{0.5}/d$
$d$	m	channel inner diameter
$f_l, f_{lz}$	[-]	functions
$G$	kg/m <sup>2</sup> s	mass flowrate
$J_G$	[-]	dimensionless vapour velocity
$k_L$	W/mK	liquid thermal conductivity
$l$	m	channel length
$p$	Pa	pressure
$Pr$	[-]	Prandtl number
$R_{MS}$	[-]	two-phase flow multiplier due to Müller-Steinhagen and Heck
$Re$	[-]	Reynolds number
$T$	K	temperature
$x$	[-]	quality
$X_{tt}$	[-]	Martinelli parameter
$g$	m/s <sup>2</sup>	gravity
$u, w$	m/s	velocity components
$\alpha$	W/m <sup>2</sup> K	heat transfer coefficient
$\mu$	Pa s	dynamic viscosity
$\rho$	kg/m <sup>3</sup>	density
$\delta$	m	liquid film thickness
$\sigma$	N/m	surface tension
$\tau$	Pa	shear stress
Subscripts		
$l$		liquid
LO		liquid only
TPB		two-phase boiling
TPK		two-phase condensation

## THE MODEL

The relation enabling calculation of heat transfer coefficient in flow boiling without bubble generation, which is also applicable to calculations of flow condensation yields.

$$\frac{\alpha_{TPB}}{\alpha_L} = \frac{\alpha_{TPK}}{\alpha_L} = \sqrt{R_{MS}^n} \quad (1)$$

Value of the exponent present in (1) assumes  $n=2$  for laminar flows, whereas for turbulent flows it takes a value of 0.76. The two-phase flow multiplier  $R_{MS}$  due to Müller-Steinhagen and Heck [12] is recommended for use in case of refrigerants, as confirmed in the state-of-the-art reviews by Ould Didi et al. [13] and Sun and Mishima [14].

It should be noted however that the selection of a two-phase flow multiplier to be used in the postulated model is arbitrary. In the results presented in the present paper the Muller-Steinhagen and Heck model has been selected for use as it is regarded best for refrigerants such as hydrocarbons, however, a different model could be selected such as for example the Lockhart-Martinelli model, where the two-phase flow multiplier is a direct function of the Martinelli parameter, see [15]. Another conclusion could be drawn from the presented model that in correlations of the type of equation (1) the two-phase flow multiplier could also be used for modeling instead of the Martinelli parameter. Author's up to date experience shows that the influence of the two-phase flow multiplier is very important and each fluid could have a different description of a two-phase resistance, D. Mikielewicz [15]. In the form applicable to conventional and small diameter channels the Muller-Steinhagen and Heck model yields, [15]:

$$R_{MS} = \left[ 1 + 2 \left( \frac{1}{f_1} - 1 \right) x \text{Con}^m \right] \cdot (1-x)^{1/3} + x^3 \frac{1}{f_{1z}} \quad (2)$$

where  $\text{Con} = (\sigma/g/(\rho_L - \rho_G))^{0.5}/d$  and  $m=0$  for conventional channels. Best consistency with experimental data, in case of small diameter and minichannels, is obtained for  $m=-1$ . In (2)  $f_1 = (\rho_L/\rho_G) (\mu_L/\mu_G)^{0.25}$  for turbulent flow and  $f_1 = (\rho_L/\rho_G)(\mu_L/\mu_G)$  for laminar flows. Introduction of the function  $f_{1z}$ , expressing the ratio of heat transfer coefficient for liquid only flow to the heat transfer coefficient for gas only flow, is to meet the limiting conditions, i.e. for  $x=0$  the correlation should reduce to a value of heat transfer coefficient for liquid,  $\alpha_{TPK} = \alpha_L$  whereas for  $x=1$ , approximately that for vapour, i.e.  $\alpha_{TPK} \cong \alpha_G$ . Hence:

$$f_{1z} = \frac{\alpha_{GO}}{\alpha_{LO}} \quad (3)$$

where  $f_{1z} = (\lambda_G/\lambda_L)$  for laminar flows and for turbulent flows  $f_{1z} = (\mu_G/\mu_L)(\lambda_L/\lambda_G)^{1.5}(c_{pL}/c_{pG})$ . The correlation (1) seems to be general, as the study by Chiou et al. [16] confirms

## CONDENSATION INSIDE TUBES

Condensation inside tubes has been the topic of interest of not too many investigations. Mentioned here should be studies by Cavallini et al. [2], Garimella [17] and Thome et al. [11]. Flow condensation at high heat fluxes enables removal of significant heat fluxes. In case of condensation in small diameter channels the surface phenomena together with the characteristics of the surface itself become more important, as well as interactions between the wall and fluid.

In microchannels we observe domination of forces resulting from action of surface tension and viscosity over the gravitational forces. Hence the attempt to extend the range of validity of correlations developed for conventional channels onto the channels with small diameters leads to errors in pressure drop and heat transfer description, making such approach useless. Additionally, the heat transfer coefficient and pressure drop in microchannels strongly depend upon the quality. Hence the detection of flow structures and their influence on pressure drop and heat transfer is indispensable during the condensation of the fluid.

Cavallini *et al.* [2] proposed separate correlations for the annular, annular-stratified and stratified and slug flow regimes. This method is based upon a large data bank, collected for halogenated refrigerants inside tubes with internal diameter  $d > 3\text{mm}$  at reduced pressure  $p_R < 0.75$  and density ratio  $(\rho_L/\rho_G)$ . Author use their correlations to predict heat transfer coefficient during condensation inside tubes with internal diameter  $d < 3\text{mm}$ . The applicable flow regimes were selected based on criteria similar to those proposed by Breber et al. [20], when at the dimensionless vapour velocity  $J_G < 2.5$  and  $X_{tt} < 1.6$  the flow enters the annular-stratified flow transition and stratified flow region. The heat transfer coefficient  $\alpha_{an-st}$  is calculated from linear interpolation between heat transfer coefficient at the boundary of the annular flow region  $\alpha_{an, J_G=2.5}$  and that for fully stratified flow  $\alpha_{st}$ . When  $X_{tt} > 1.6$  and  $J_G < 2.5$ , the flow enters the stratified-slug transition and slug flow pattern region, the heat transfer coefficient is calculated as linear interpolation between the coefficient computed at  $X_{tt}=1.6$  and the one for the liquid flowing with the entire flow rate. Model for annular flow is applied when the dimensionless vapour velocity is lower than 2.5. For the annular flow regime, Cavallini et al. [2] suggested the use of the heat transfer model proposed by Kosky and Staub [21] with the modified Friedel [22] correlation for shear stress:

$$J_G^* = \frac{G*x}{\sqrt{D*g*\rho_V*(\rho_L-\rho_V)}} \quad (4)$$

$$X_{tt} = \left( \frac{\mu_L}{\mu_G} \right)^{0.1} * \left( \frac{\rho_G}{\rho_L} \right)^{0.5} * \left[ \frac{(1-x)}{x} \right]^{0.9} \quad (5)$$

The dimensionless film thickness is based on the liquid-phase Reynolds number:

$$\delta^+ = \begin{cases} \left( \frac{Re_l}{2} \right)^{0.5} & \text{for } Re_l \leq 1145 \\ 0.0504 Re_l^{7/8} & \text{for } Re_l > 1145 \end{cases} \quad (6)$$

The dimensionless temperature is determined based on the dimensionless film thickness analogously to Traviss *et al.* [18].

$$T^+ = \begin{cases} \delta^+ Pr_L & \text{for } \delta^+ \leq 5 \\ 5 \left\{ Pr_L + \ln \left[ 1 + Pr_L \left( \frac{\delta^+}{5} - 1 \right) \right] \right\} & \text{for } 5 < \delta^+ \leq 30 \\ 5 \left\{ Pr_L + \ln(1 + 5 Pr_L) + 0.495 \left( \frac{\delta^+}{30} \right) \right\} & \text{for } \delta^+ > 30 \end{cases} \quad (7)$$

Finally, the heat transfer coefficient is calculated as follows:

$$\alpha_{an} = \frac{\rho_L c_{pL} \left( \frac{\tau}{\rho_L} \right)^{0.5}}{T^+} \quad \text{for } J_G > 2.5$$

$$\alpha_{TPK} = \begin{cases} \alpha_{an-st} = \left( \alpha_{an, J_G=2.5} - \alpha_{st} \right) \left( \frac{J_G}{2.5} \right) + \alpha_{st} & \text{for } 1.6 < J_G \leq 2.5 \\ \alpha_{an-lt} = \alpha_{LO} + \frac{x(\alpha_{1.6} - \alpha_{LO})}{x_{1.6}} & \end{cases} \quad (8)$$

Thome *et al.* [11] developed a multi-regime heat transfer correlation, in which the regimes identified are either as (a) fully annular forced convective, or as (b) consisting of varying combinations of upper gravity driven, and lower forced convective terms, in case of horizontal flows (2003). Thome *et al.* proposed heat transfer model for evaporation inside horizontal tubes. They founded that there is a close similarity between the convection mechanisms in annular film condensation and annular film evaporation inside tubes. Finally they proposed the new following model for the annular flow:

$$\alpha_{TPK} = c * Re_L^n * Pr_L^m * \frac{k_L}{\delta} * f_i \quad (9)$$


where  $\delta$  is the film thickness determined based on the void fraction model, where  $f_i$  is:

$$f_i = 1 + \left( \frac{u_v}{u_L} \right)^{\frac{1}{2}} * \left[ \frac{(\rho_L - \rho_v) * g * \delta^2}{\sigma} \right]^{\frac{1}{4}} \quad (10)$$


The constants  $c$ ,  $n$  and  $m$  were determined to be 0.003, 0.74 and 0.5, respectively, based on best fit to experimental data for tubes with  $d_h > 3$  mm. This correlation predicts heat transfer coefficients with an average deviation of -74%. Thome *et al.* [11] proposed also the general expression for the local condensing heat transfer coefficient, but this method is determined with complicated procedure who which required identification of the flow pattern. In such approach the intermittent flow is very complex, and therefore assume that is can be predicted approximately by annular flow equations (9).

## RESULTS OF CALCULATIONS

Presented below is a comparison of best established literature correlations for calculations of flow condensation with the model presented in the first part of the paper, namely relation (1). From available literature the correlations due to Cavallini *et al.* [2] and Thome *et al.* [11] have been selected. Bearing in mind that the proposed model (1) was thoroughly tested for the conditions of flow boiling, see for example D. Mikielewicz [15], showing satisfactory performance, the prediction of condensation inside tubes commenced. The considered methods have been verified by experimental data collected from literature [4, 5, 6, 9]. Results of calculations in the form of distributions of heat transfer coefficient with respect to quality are presented in Fig. 1-18.




**Figure 1.** Comparison of heat transfer coefficient for R134a in relation to experimental data [6] using (1),(9),(8),  $d=0,96$  mm,  $G=100$  kg/m<sup>2</sup>s,  $T_{sat}=40^\circ\text{C}$




**Figure 2.** Comparison of heat transfer coefficient for R134a in relation to experimental data [6] using (1),(9),(8),  $d=0,96$  mm,  $G=400$  kg/m<sup>2</sup>s,  $T_{sat}=40^\circ\text{C}$

It can be seen that equation (1) describes reasonably well the heat transfer coefficients during the flow condensation, see fig.1 to 18. The results of comparisons, which are presented in these figures are very promising. The biggest advantage

offered by equation (1) is the fact that it has a general character and does not require any specific fluid-related constants. Relation (1) does not require prior knowledge of flow maps which are indispensable in case of more accurate methods for calculation of heat transfer coefficients. Calculation show that the method described by (1) can predict heat transfer coefficient in conventional channels and minichannels.




**Figure 3.** Comparison of heat transfer coefficient for R134a in relation to experimental data [6] using (1),(9),(8),  $d=0,96$  mm,  $G=1200\text{kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$




**Figure 4.** Comparison of heat transfer coefficient for R134a in relation to experimental data [5] using (1),(9),(8),  $d=1,77$  mm,  $G=650\text{kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$

It results from examination of presented above results that heat transfer coefficient in flow condensation is a function of the two-phase multiplier. Careful examinations of presented above results show two distinct trends. In case of data for higher diameter tubes (conventional size tubes) the results clearly show that the method described by equation (1) outperforms other models for smaller mass velocities in case of R134a and R32. On the other hand in case of simulations for smaller tube diameters the picture of calculations looks different. The model (1) performs poorly for smaller mass


velocities ( $G < 200\text{kg/m}^2\text{s}$ ), whereas it by for the best model for the case of higher mass velocities. The qualitative trends are very well revealed and the qualitative consistency is very satisfactory. It is difficult to judge why the models due to Cavallini et al. [3] and Thome et al. [11] exhibit the presented in the paper accuracy. In case of the model described by equation (1) the situation is different, as the model predicts depend on the two-phase multiplier. In the present work the halogenated refrigerants were examined in which case the two-phase multiplier due to Muller-Steinhagen and Heck [12] is recommended. That model is also developed on the adjustment to experimental data. In some calculations, in order to increase the accuracy of predictions, the more appropriate two-phase flow multiplier could be used, specifically developed for a particular fluid.




**Figure 5.** Comparison of heat transfer coefficient for R134a in relation to experimental data [5] using (1),(9),(9),  $d=1.77$  mm,  $G=850\text{kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$




**Figure 6.** Comparison of heat transfer coefficient for R410aa in relation to experimental data [5] using (1),(9),(8),  $d=1.77$  mm,  $G=850\text{kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$




**Figure 7.** Comparison of heat transfer coefficient for R410a in relation to experimental data [5] using (9),(16),(17),  $d=1.77$  mm,  $G=850$  kg/m<sup>2</sup>s,  $T_{sat}=40^{\circ}\text{C}$




**Figure 10.** Comparison of heat transfer coefficient for R134a in relation to experimental data [4] using (1),(9),(8),  $d=8$  mm,  $G=750$  kg/m<sup>2</sup>s,  $T_{sat}=40^{\circ}\text{C}$




**Figure 8.** Comparison of heat transfer coefficient for R134a in relation to experimental data [4] using (1),(9),(8),  $d=8$  mm,  $G=100$  kg/m<sup>2</sup>s,  $T_{sat}=40^{\circ}\text{C}$




**Figure 11.** Comparison of heat transfer coefficient for R32 in relation to experimental data [6] using (1),(9),(8),  $d=0.96$  mm,  $G=200$  kg/m<sup>2</sup>s,  $T_{sat}=40^{\circ}\text{C}$




**Figure 9.** Comparison of heat transfer coefficient for R134a in relation to experimental data [4] using (1),(8),(9),  $d=8$  mm,  $G=300$  kg/m<sup>2</sup>s,  $T_{sat}=40^{\circ}\text{C}$




**Figure 12.** Comparison of heat transfer coefficient for R32 in relation to experimental data [6] using (1),(9),(8),  $d=0.96$  mm,  $G=600$  kg/m<sup>2</sup>s,  $T_{sat}=40^{\circ}\text{C}$




**Figure 13.** Comparison of heat transfer coefficient for R32 in relation to experimental data [6] using (1),(9),(8),  $d=0,96 \text{ mm}$ ,  $G=1000 \text{ kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$




**Figure 16.** Comparison of heat transfer coefficient for R32 in relation to experimental data [4] using (1),(9),(8),  $d=8 \text{ mm}$ ,  $G=600\text{kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$




**Figure 14.** Comparison of heat transfer coefficient for R32 in relation to experimental data [4] using (1),(9),(8),  $d=8 \text{ mm}$ ,  $G=100 \text{ kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$



**Figure 17.** Comparison of heat transfer coefficient for R236fa in relation to experimental data [9] using (1),(9),(8),  $d_h=1.45 \text{ mm}$ ,  $G=150\text{kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$



**Figure 15** Comparison of heat transfer coefficient for R32 in relation to experimental data [4] using (1),(9),(8),  $d=8 \text{ mm}$ ,  $G=400\text{kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$



**Figure 18.** Comparison of heat transfer coefficient for R1234ze in relation to experimental data [9] using (1),(9),(8),  $d_h=1.45 \text{ mm}$ ,  $G=150\text{kg/m}^2\text{s}$ ,  $T_{\text{sat}}=40^\circ\text{C}$



In case of flow condensation and flow boiling, if the two-phase flow multiplier developed for adiabatic conditions is used then the non-isothermal effects on the interface of annular flow are neglected. In some case these can lead to significant modifications of heat transfer coefficient. In flow boiling the liquid film layer is thickening, whereas in case of flow condensation it is thinning. Some way to solve this problem has been presented in [7] where the so called boiling parameter was introduced to model that effect. The presented in that paper date will be reconsidered in that light. The poor performance of (1) in case of small mass velocity may be attributed to the fact that the bubbly flow is encountered. In such case the annular flow approach is not valid, however the authors would like to stress that still the formulae dependent on the two-phase flow multiplier is applicable. In such case authors plan to incorporate into the two-phase flow multiplier the term responsible for the presence of heat flux. Works on that topic are underway.

## CONCLUSIONS

In the paper presented is a comparison of predictions of condensation inside conventional tubes for two tube diameters, namely  $d=8\text{mm}$  and minichannels ( $d<3\text{mm}$ ) with the correlation originally developed for flow boiling. In the paper that method has been applied to predictions of heat transfer coefficient in flow condensation. The method has been verified by experimental data due to Cavallini et al. [3], Hoo-Kyu Oh et al. [4], Matkovic et al. [5], Park et. al. [9] and also compared to Cavallini's correlation [2] and Thome's correlation [11]. The comparison is satisfactory. The calculation shows that equation (1) outperforms other models, is universal and can be used to predict heat transfer due to condensation for different halogeneous refrigerants and other fluids. Ways to improve the performance of correlation (1) have been presented. There are based on selection of more appropriate two-phase flow multiplier or to introduce non-isothermal or heat flow dependent terms into the two-phase flow multiplier.

## ACKNOWLEDGMENTS

The work presented in the paper was funded from the Polish Ministry for Science and Education research project No. N512 459036 in years 2009-2012

## REFERENCES

- [1] Mikielewicz D., Mikielewicz J., Tesmar J., Improved semi-empirical method for determination of heat transfer coefficient in flow boiling in conventional and small diameter tubes, *Int. J. of Heat and Mass Transfer*, 50, 3949-3956, 2007.
- [2] Cavallini, A., Censi G., Del Col D., Doretto L., Longo G.A., Rossetto L., Condensation of Halogenated Refrigerants inside Smooth Tubes, *HVAC and Research*, vol. 8, 429-451, 2002.
- [3] Cavallini A., Censi G., Del Col D., Doretto L., Longo G.A., Rossetto L., Zilio C, Condensation inside and outside smooth and enhanced tubes — a review of recent research, *International Journal of Heat and Mass Transfer*, vol 26, pp. 373-392, 2002.
- [4] Cavallini, A., Censi G., Del Col D., Doretto L., Longo G. A., Rossetto L., Experimental investigation on condensation heat transfer and pressure drop of new HFC refrigerants (R134a, R125, R32, R410A, R236ea) in a horizontal smooth tube, *Int. Journal of Heat and Mass Transfer*, vol. 24, pp.73-87, 2000.
- [5] Oh H.-K., Son C.-H., Condensation heat transfer characteristics of R-22, R-134a and R-410A in a single circular microtube, *Exp. Therm. Fluid Sci.* (2011), doi:10.1016/j.expthermflusci.2011.01.005.
- [6] Matkovic M., Cavallini A., Del Col D., Rossetto L., Experimental study on condensation heat transfer inside a single circular minichannel, *Int. Journal of Heat and Mass Transfer*, vol.52, pp.2311-2323, 2009.
- [7] Mikielewicz D., Mikielewicz J., A common method for calculation of flow boiling and flow condensation heat transfer coefficients in minichannels with account of non-adiabatic effects, *accepted for publication in Heat Transfer Engng*, 2010.
- [8] Mikielewicz D., Mikielewicz J., Non-isothermal effects in condensation inside tubes, *Proceedings XIV Conference of Heat and Mass Transfer*, Międzyzdroje, 2010.
- [9] Park J.E. Vakili-Farahani F., Consolini A., Thome J.T., Experimental study on condensation heat transfer in vertical minichannels for new refrigerant R1234ze(E) versus R134a and R236fa, *Exp. Therm. Fluid Sci.* (2010), doi:10.1016/j.expthermflusci.2010.11.006.
- [10] Thome J.R., El Hajal J., Cavallini A., Condensation in horizontal tubes, part 1: two-phase flow pattern map, *International Journal of Heat and Mass Transfer*, vol.46, pp.3349-3363, 2003.
- [11] Thome J.R., El Hajal J., Cavallini A., Condensation in horizontal tubes, part 2: new heat transfer model based on flow, *Int. Journal of Heat and Mass Transfer*, 24, pp.3365-3387, 2003.
- [12] Müller-Steinhagen R., Heck K., A simple friction pressure drop correlation for two-phase flow in pipes, *Chem. Eng. Progress*, 20, 1986.
- [13] Ould Didi M.B., Kattan N., Thome J.R., Prediction of two-phase pressure gradients of refrigerants in horizontal tubes, *Int. J. of Refrigeration*, vol. 25, pp. 935-947, 2002.
- [14] Sun L. and Mishima K., Evaluation analysis of prediction methods for two-phase flow pressure drop in mini-channels, *Int. J. of Multiphase Flows*, vol. 35, pp. 47-54, 2009.
- [15] Mikielewicz D., A new method for determination of flow boiling heat transfer coefficient in conventional diameter channels and minichannels, *Heat Transfer Eng.*, Vol. 31 (4), 276-284, 2009.
- [16] Chiou C.B., Lu D.C., Liao C.Y., Su Y.Y., Experimental study of forced convective boiling for non-azeotropic refrigerant mixtures R-22/R-124 in horizontal smooth tube, *Applied Thermal Engineering*, vol. 29, pp. 1864–1871, 2009.
- [17] Garimella, S., Condensation Flow Mechanisms in Microchannels: Basis for Pressure Drop and Heat Transfer Models, *Heat Transfer Engineering*, vol. 25(3), pp. 104-116, 2004.
- [18] Traviss, D. P., Rohsenow W. M., Flow Regimes in Horizontal Two-Phase Flow with Condensation, *ASHRAE Transactions*, Vol. 79 (Part 2), pp. 31-39, 1973.
- [19] Thome J. R., Consolini L., Mechanisms of Boiling in Micro-Channels: Critical Assessment, Proc. 5th Int. Conference on Transport Phenomena in Multiphase Systems, June 30-July 3, Bialystok, 2008.
- [20] Breber, G., J. W. Palen and J. Taborek, Prediction of Horizontal Tubeside Condensation of Pure Components Using Flow Regime Criteria, *Journal of Heat Transfer, Transactions ASME*, 102(3), 471-476, 1980.
- [21] Kosky, P.G. and F. W. Staub, Local Condensing Heat Transfer Coefficients in the Annular Flow Regime, *AIChE Journal*, Vol. 17(5) pp. 1037-1043, 1971.
- [22] Friedel L., Improved friction pressure drop correlations for horizontal and vertical two-phase pipe flow, *European Two-Phase Flow Group Meeting*, Paper E2, Ispra, Italy, 1979.