



The University of
Nottingham

UNITED KINGDOM · CHINA · MALAYSIA

Lu, B. and Ou, H. and Shi, S.Q. and Long, H. and Chen, J. (2016) Titanium based cranial reconstruction using incremental sheet forming. *International Journal of Material Forming*, 9 (3). pp. 361-370. ISSN 1960-6214

Access from the University of Nottingham repository:

http://eprints.nottingham.ac.uk/42963/1/ISF%20for%20cranioplasty_IJMF_2016%20%28Ou4%29.pdf

Copyright and reuse:

The Nottingham ePrints service makes this work by researchers of the University of Nottingham available open access under the following conditions.

This article is made available under the Creative Commons Attribution licence and may be reused according to the conditions of the licence. For more details see: <http://creativecommons.org/licenses/by/2.5/>

A note on versions:

The version presented here may differ from the published version or from the version of record. If you wish to cite this item you are advised to consult the publisher's version. Please see the repository url above for details on accessing the published version and note that access may require a subscription.

For more information, please contact eprints@nottingham.ac.uk

Titanium based cranial reconstruction using incremental sheet forming

B. Lu · H. Ou · S. Q. Shi · H. Long · J. Chen

Received: 21 August 2014 / Accepted: 1 December 2014 / Published online: 11 December 2014
© The Author(s) 2014. This article is published with open access at Springerlink.com

Abstract In this paper, we report recent work in cranial plate manufacturing using incremental sheet forming (ISF) process. With a typical cranial shape, the ISF process was used to manufacture the titanium cranial shape by using different ISF tooling solutions with and without backing plates. Detailed evaluation of the ISF process including material deformation and thinning, geometric accuracy and surface finish was conducted by using a combination of experimental testing and Finite Element (FE) simulation. The results show that satisfactory cranial shape can be achieved with sufficient accuracy and surface finish by using a feature based tool path generation method and new ISF tooling design. The results also demonstrate that the ISF based cranial reconstruction has the potential to achieve considerable lead time reduction as compared to conventional methods for cranial plate manufacturing. This outcome indicates that there is a potential for the ISF process to achieve technological advances and economic benefits as well as improvement to quality of life.

Keywords Incremental sheet forming · Cranial plate reconstruction · Finite element

Introduction

Cranioplasty is a surgical procedure for the repair of deformity of a human skull due to brain tumour, stroke or traumatic injuries. Cranioplasty surgery does not only offer cosmetic and sometimes lifesaving benefits but also give relief to psychological drawbacks and improve the quality of life of patients [1]. Cranioplasty surgical procedures may be conducted by using autografting (implant taken from patient own body) and allografting (implant taken from a donor body) or alloplastic (non-biologic such as polymeric and metallic) materials. Non-metallic materials such as Polymethylmethacrylate (PMMA), Polyetheretherketone (PEEK) and Hydroxyapatite, and metallic substitutes such as stainless steel and titanium, alloplastic materials are commonly used in cranioplasty surgeries. The selection of cranioplasty materials is normally based on the requirements of such as biocompatibility, material properties and surgeon's experience and preference. Technical readiness for clinical application, short lead time, low cost and ease of manufacture for alloplastic cranioplasty are also important considerations [2].

Among all alloplastic materials including PMMA and PEEK, titanium continues to be the main stream material used in cranioplasty surgeries because of its excellent biocompatibility, resistance to infection, excellent material property, strength and lightweight. However, in spite of the common use and increasing need for titanium based cranial reconstruction, there is a wide variety of methods including casting [3], manual shaping [4, 5] and rubber press forming [6–8] commonly used in the manufacture of cranial reconstruction. Even with the assistance of advanced CAD/CAM (computer-aided design and manufacture), computed tomographic (CT) and magnetic resonance imaging (MRI) technologies [2, 3, 6–8], the processes needed to manufacture customised casting moulds, templates and forming dies in conventional methods of cranial manufacturing is not only costly but also time

B. Lu · J. Chen
Department of Plasticity Technology, Shanghai Jiao Tong University,
1954 Huashan Road, Shanghai 200030, People's Republic of China

H. Ou (✉) · S. Q. Shi
Department of Mechanical, Materials and Manufacturing
Engineering, University of Nottingham, Nottingham NG7 2RD, UK
e-mail: h.ou@nottingham.ac.uk

B. Lu · H. Long
Department of Mechanical Engineering, University of Sheffield,
Sheffield S1 3JD, UK

consuming often normally requiring a few days up to 2 weeks to completion depending on considerations of such as technical planning and whether there is a case of surgical urgency [2, 6, 7]. In recent years, 3D printing or additive manufacturing based technologies have made rapid advances and it is possible to complete the 3D printing of a cranial or a maxillofacial prosthetic part within several hours [9, 10]. However, there are still a number of impediments including insufficient material properties and high cost issues to be overcome before its wide adoption for clinical applications [11].

The ISF process is centred on material plastic deformation of symmetric and asymmetric shapes of sheet metals by tracing a rotational tool along a sequence of contour lines generated directly from part CAD model [12]. Its excellent adaptability to CNC (Computer Numerical Control) systems through direct control of CAD data, with the minimum use of complex tooling, dies and forming press, makes the process cost-effective and easy to automate and adapt for various applications. The localised plastic deformation taking place incrementally ensures improved material formability and this makes it suitable for a wide range of sheet metal materials including titanium. Therefore, it is particularly attractive for manufacturing high value-added, small batch and customised sheet parts. In the past decade, significant progress has been made in the research of ISF technology. In the ISF process development, conventional single point incremental forming (SPIF) [13], two-point incremental forming (TPIF) [14], hybrid forming by combining stretch forming and incremental sheet forming [15] and double side incremental forming (DSIF) [16] have been developed in recent years. Concerning the deformation and fracture mechanisms, different theories including bending under tension (BUT) [17], through-thickness shear effect [18, 19] and the “noodle theory” [20] has been proposed. The forming accuracy and the surface finish of the final part have also been investigated [21, 22]. Thanks to these efforts, the application of ISF technology in the real-world becomes possible.

In the application of the ISF technology, the advances of ISF make it specially suitable for manufacture small-batch or customised components, such as those in automobile [23], aerospace [24] and medical application [25]. In a recent paper, effort was made to use ISF to manufacture cranial reconstruction [26]. Whilst the study demonstrated the soundness of ISF based approach for cranial manufacturing, unintended failures in forming high wall angle cranial shape and insufficient accuracy of the formed cranial plate were encountered. From the skull geometry of a patient to a manufactured cranial plate, a few challenges still exist including the formability of material, the geometric construction with ISF toolpath generation, the geometric accuracy and the final surface finish of the cranial plate. Although these topics may have been individually

examined in the past of ISF research, these challenges need to be further investigated for the potential practical application in cranial reconstruction.

This paper aims to study the feasibility of manufacturing customized titanium cranial plates by using the ISF approach. In this paper, the material properties of Grade 1 pure (TA1) titanium sheets were firstly investigated. To evaluate the friction effect between the tool and sheet, both conventional ball-head rigid tool and a roller ball tool were employed in the forming process and the surface finish after ISF process was examined. By taking a typical cranial shape, the cranial geometric shape for ISF processing was constructed and the tool path was generated. With the support of FE simulation, a series of ISF experiments were carried out to examine the feasibility of incremental sheet forming for manufacturing cranial plates. By investigating the forming load, material deformation with consideration of thickness distribution and surface finish, a detailed assessment of the ISF based cranial reconstruction is conducted. This is followed by concluding remarks for future work.

Material and methods

Material properties of (TA1) titanium sheets

TA1 titanium material contains 99.67 % of titanium, 0.08 % of carbon and 0.03 % of iron and 0.22 % of other compositions such as oxygen and hydrogen. Table 1 shows the material properties of TA1 pure titanium. Concerning the ISF processing of TA1 material, from the manufacturing point of view, the flow stress and material ductility are the two key factors that affect the ISF process: the flow stress including the initial yielding and strain hardening which determine the forming load and corresponding contact pressure between tool-sheet interfaces. Although it is proven that ISF enables enhanced formability, the ductility of material is still a key factor that would affect the potential ISF formability, which is important for the successful implementation of incremental forming. In this work, the material properties of TA1 titanium material are examined by using tensile tests on an Instron tensile testing machine, as shown in Fig. 1.

Table 1 Material properties of TA1 pure titanium

Young's modulus E (MPa)	Yield strength σ_S (MPa)	Elongation δ (%)	Tensile stress σ_b (Mpa)	Poisson's ratio
105,000	205	36	370	0.37

Fig. 1 Tensile test of TA1 titanium sheet




Figure 2 shows the flow stress of TA1 titanium. As can be seen from the figure, the initial yield stress is about 200 MPa while the stress at fracture is about 350 MPa due to strain hardening. Concerning the material ductility, TA1 titanium shows good elongation property in the tensile test. Although the measured elongation is different, the minimum value can be over 35 %, which indicates good material formability in incremental sheet forming process. Based on this elongation, the maximum achievable ISF forming angle may be up to 40° by calculation from Sine law. With the consideration of increased formability in ISF process comparing to tensile test, the maximum achievable forming angle is even higher in a single pass ISF process. The tensile test results suggested a good potential of this material to be used in ISF process.

Evaluation of friction between tool and sheet

The severe contact condition between the tool and sheet could cause rough surface finish of the cranial plate after ISF process. In order to solve this problem, instead of using the conventional ball head rigid tool, a roller ball tool could be a better option to the conventional tool for the material such as pure titanium that is easy to be




Fig. 2 Flow stress of TA1 titanium

scratched. In this way, the conventional sliding friction condition in the ISF process can be replaced by the rolling friction condition, which proves to be effective preventing the potential scratch of the sheet surface in ISF processing [19]. Figures 3 and 4 show the two types of tools used in incremental forming of the cranial plates.

Geometric definition and ISF tool path generation

Generation of the ISF toolpath is a key step for ISF based cranial reconstruction. In the conventional ISF technology, toolpaths may be generated directly through CAD-based freeform surface or discrete surface represented by STereoLithography (STL). In practical application for cranioplasty, the geometric data of a skull shape to be reconstructed are typically from the point cloud from CT scan for subsequent model repair [27]. Concerning the technical approach based on the scanned points cloud, the toolpath generation via STL model seems to





Fig. 3 ISF tools for cranial plate forming: **a** conventional ball-head rigid tool; **b** roller-ball tool

Fig. 4 Geometric construction for cranial plate model. **a** Skull model **b** Cranial model taken for ISF construction



be more convenient than the approach of free form surface generation as the reverse engineering technique can be avoided in reconstructing the CAD surface through point cloud. In this work, a cranial shape from a human skull of point cloud was employed. Although model repair may be required due to traumatic tissue loss in some cases, no model repair is implemented in this work and the surface model is directly taken from the top of the cranium as a demonstration of the ISF based cranial reconstruction technique.

Based on the geometrical shape of the cranial plate, an offset model with consideration of tool radius was established. Spiral tool paths with scallop height of 0.005 mm are generated based on the z-level slicing approach described in authors' previous work [22]. In the z-level slicing approach, the toolpaths are generated by interpolation to the contour lines of the model in the vertical direction. Figure 5 shows the toolpath generated for ISF processing of the cranial plate. By considering the total length of the toolpath and a feed rate of 2000 mm/min, the whole ISF process for the cranial plate manufacturing requires 12 min to complete, which is generally much more efficient than many conventional forming based techniques for cranial reconstruction where additional dies and moulds are necessary.




Fig. 5 ISF tool path generated for cranial plate manufacture

FE modelling

As an effective method for analysing material deformation and other concerned issues such as accuracy and material thinning and strain distribution of the work-piece, FE method was used to investigate the sheet deformation in ISF processing for the cranial plate. In this work, ABAQUS Explicit software package was employed. Using the flow stress results obtained from the tensile test and the toolpath generated based on the cranial geometry, an FE model was built as shown in Fig. 6. As shown in the figure, a roller-ball tool with diameter of 10 mm other than the conventional rigid tool was employed in the ISF simulation. The 10 mm wide purple region to the edge of the blank was constrained to represent the clamping of the workpiece onto the fixture. The friction coefficient was set to be 0.05 for the contacts between the tool and sheet [28]. A backing plate is placed underneath the sheet to support the part. The mesh size is 1 mm with approximately 50,000 elements. The original feed rate of the tool was set to be 2000 mm/min. However, in order to improve the simulation efficiency, the virtual forming speed was scaled up by 100 times according to the best practice





Fig. 6 - FE model for forming of cranial plate

Fig. 7 ISF experiments of cranial plate forming **a** ISF experiment **b** Finished part



[28], in which the ratio of kinematic energy to total energy can be controlled within a limited value. By using this model, the ISF process for cranial plate construction can be analysed and the simulation results compared with experiment.

Experimental setup

To facilitate the incremental forming for the cranial plate, ISF experiments were conducted by using a 3-axis milling machine. Figure 7 shows the setup of the ISF process and one of the formed cranial plates with the roller ball tool. TA1 titanium sheet with a thickness of 0.5 mm was used for ISF based forming of the cranial plate. Both conventional ball-head rigid tool and the roller ball tool, as shown in Fig. 3 were used for comparison. Rocol RTD compound was employed as the lubricant during the forming process. The tool path generated in Section 2.3 was converted to NC code and the forming tool moved along this pre-defined path during the ISF process. The feed rate of the tool was

set to be 2000 mm/min during forming. During the ISF experiment, a multi-axis JR3 load cell was employed to measure the forming forces during the ISF process.

Results and discussion

Forming forces

The forming forces from both FE simulation and experiment were obtained as shown in Fig. 8. As can be seen from the figure, similar trend of forming load variations can be observed. The forming loads increase rapidly to its maximum value at the initial forming stage and gradually drop down in the forming process. This variation is depended upon the forming shape and the step down value of the forming path. By examining the maximum forming load, in vertical direction, the value reaches 500 N, while in the horizontal direction, the maximum forming load is 300 N. This result suggests that comparing to other methods such as stamping, the

Fig. 8 Comparison of forming load





Fig. 9 Distribution of equivalent strain



forming load is relatively small by using the ISF process for cranial plate manufacturing. In addition, the similarity of forming load from both FE and ISF experimental results suggests that the FE model can be used to provide an accurate prediction of the ISF process for cranial plate manufacturing.

Sheet deformation

Using the FE model, the strain and thickness distributions of the finished cranial part are obtained. As shown in Figs. 9 and 10,

the maximum deformation occurs at the edge of the cranial plate model, where it has the largest wall angle. With the forming process continues, the slope of the wall angle becomes more gradual so the material deformation is less severe.

Sheet thickness

By examining the thickness distribution obtained from FE simulation, it tends to have the similar variation trend to the material deformation as shown in Fig. 10. With an initial

Fig. 10 Distribution of final sheet thickness





Fig. 11 Thickness distribution along section *I-I*



thickness of 0.5 mm, the minimum wall thickness is about 0.37 mm resulting in a 26 % reduction. The maximum thickness reduction occurs at the edge of the cranial plate whilst in the bottom region, the sheet becomes less deformed. To validate the calculated thickness distribution, the formed cranial parts processed by both the roller-ball and rigid tools were measured by a Mitutoyo CMM Euro-C-*A121210* coordinate measurement machine (CMM) and the thickness along section *I-I* was obtained and compared with the FE results as shown in Fig. 11. As can be seen from the figure, both the rigid and roller-ball tool types produce almost identical thickness distributions. In addition, similar results between FE and experimental results can also be observed. The minimum measured thickness is 0.368 mm, which is very close to the FE thickness result of 0.373 mm. This comparison also suggests the accuracy of FE prediction.

Geometric accuracy

Both the finished parts before and after trimming of the blank from experimental approach were measured by using a

Dantec Q-400 digital image correlation (DIC) system, as shown in Fig. 12, and the scanned point clouds were then reconstructed to STL model so the geometric accuracy of the ISF formed cranial plates can be evaluated by comparing to the nominal shape. Figure 13 shows the geometrical deviation from the nominal shape of parts from both FE and experimental testing. By comparing Fig. 13a and b, it can be found some notable geometric difference between FE and experimental results. The maximum difference is in the region of the bottom of the part reaching 0.5 mm. This discrepancy may be due to the inaccurate prediction of material springback in FE explicit simulation. Concerning the deviation of the actual cranial plate geometry from the nominal shape, it can be found that the maximum deviation is from the edge of the part with a magnitude of 0.5 mm. By measuring the deviation of the trimmed part as shown in Fig. 13c, obvious springback can be observed after removing the blank. The maximum deviation occurs along the trimmed edge with the value of about 3 mm. This springback may be due to the reduced stiffness around the edge after trimming and re-distribution of residual stress. This result suggested





Fig. 12 Measurement and evaluation of finished cranial plate. **a** Shape measurement using DIC system **b** Comparison of the formed part with nominal shape

Fig. 13 Geometrical deviation of finished part. **a** FE simulation **b** Untrimmed cranial plate **c** Trimmed cranial plate




that geometric inaccuracy of the cranial plate after the ISF processing and trimming needs to be compensated for to a smaller amount. Further optimisation on ISF toolpath strategies and ISF specific compensation methods may be used to minimise the springback due to such as residual stress redistribution. Alternatively it is possible to manually correct the shape deviation to an acceptable level for cranial reconstruction before more robust optimisation and compensation approaches may be developed [4, 5].

Surface finish

The surface finish of the ISF processed cranial plates can be examined as shown in Fig. 14. Obvious galling can be observed

on the part surface processed by the rigid tool. This is due to the adherence of the titanium sheet onto the tool surface and these adhesions further scratch the part surface. Concerning the part processed by the roller ball tool, although tool marks may still be visible, the surface finish is much improved and no adhesion on the part surface can be observed. The detailed surface profiles were examined by using a surface roughness measurement machine as shown in Fig. 15. Obvious difference of profiles can be observed. The R_z value of the part processed by the rigid tool is $25.7 \mu\text{m}$ as compared to that of $5.7 \mu\text{m}$ processed by the roller ball tool. As given in same the figure, similar proportion of difference of the R_a value is obtained. This result further proves that substantial surface roughness improvement may be made by using the roller-ball tool.

Fig. 14 Surface examination of roller-ball tool and rigid tool **a** Rigid tool **b** Roller ball tool






Fig. 15 Comparison of surface profiles of parts processed by roller-ball tool and rigid tool

General assessment of ISF based methods for reconstruction of cranial plates

By evaluating the feasibility and challenges for ISF based cranial reconstruction, this study confirms that the titanium sheet can be produced for cranioplasty applications by using the ISF approach. Comparing to the conventional approaches such as stamping, ISF does not require the preparation of shape specified forming tools, which not only reduces the cost but also the forming time. The localized deformation of the workpiece ensures the enhanced deformation stability and sheet formability as compared to conventional forming methods. By employing the roller ball tool, the surface finish of the formed part can be significantly improved to meet the requirement for surgical operations. Concerning the geometric accuracy, a maximum 3 mm springback of the trimmed part can be observed at the edge of cranial plate after removal of the blank. As the cranial plate is a thin-wall part with thickness of about 0.5 mm or less, the stiffness may not be large enough to maintain its original shape during the re-distribution of residual stress in the blank trimming. For clinical implementation of the ISF process in cranial plate manufacturing, three specific aspects need to be considered:

- 1) **Processing technology:** In ISF processing of the cranial plate a pre-prepared backing plate was employed in the forming process. A customized backing plate needs to be made to ensure the ISF geometric accuracy. Thus this is still not an entirely “flexible” process. In the future development, a more advanced DSIF (double side incremental forming) technology with a forming tool and a counter tool may be employed to replace the current technology framework of forming tool i.e. the use of a backing plate. Such a solution would further increase the process flexibility and automation.
- 2) **Lubrication:** It was found that pure titanium is easy to adhere to the forming tool so roller-ball type tools with lubricants were employed in the experiments. Although surface cleaning process is employed in clinical

application, development of new roller ball tool with self-lubricant coating or non-metallic tools to avoid ISF tool and workpiece adhesion would be beneficial for less demand in cranial plate sterilisation.

- 3) **Geometric accuracy:** The springback during the trimming of the blank is considerably large. This kind of springback may not be easily avoided as the cranial plate is a thin sheet and the tensile strength of titanium is relatively high. Therefore, for full clinical application of ISF based cranial reconstruction, it is important to develop more robust toolpath strategies to achieve uniform residual stress distribution and to establish more rigorous optimisation and compensation methods for accurate quantification and efficient minimisation of part springback with a given size and shape of cranial plate.

Conclusions

In this work, by evaluating the material properties of Grade 1 pure titanium sheets, FE simulation and ISF experimental testing for cranial plates, the feasibility of manufacturing customized titanium cranial plates by using the ISF approach is studied and the particular issues and possible solutions were discussed. The conclusions of this work may be summarized as follows:

- 1) ISF based construction of cranial plate by using Grade 1 pure titanium sheets is a feasible solution and it shows clearly the potential for real medical application.
- 2) The surface finish and thickness distribution are satisfactory for the application of cranioplasty.
- 3) Further development is still needed to overcome few specific issues including the current use of backing plate and lubricant, the requirement for new tools as well as the minimisation of springback.

Acknowledgment The authors are grateful for the support provided by the Engineering and Physical Science Research Council of UK (EP/L02084X/1) and the Marie Curie International Incoming Fellowship (628,055 & 913,055) and International Research Staff Exchange Scheme (IRSES, MatProFuture project, 318,968) within the 7th EC Framework Programme (FP7). The authors wish to thank Dr Mingjun Liu of Cranioplasty Unit, The University College London Hospitals NHS Foundation Trust for reviewing the manuscript and for providing valuable suggestions in cranioplasty, Mr Tom Edgar of Queen’s University Belfast for providing the geometric model of the skull for cranial reconstruction; Mr Tom Buss, Jason Young and Mark Daine of University of Nottingham for their support in material testing and cranial plate measurements.

Open Access This article is distributed under the terms of the Creative Commons Attribution License which permits any use, distribution, and reproduction in any medium, provided the original author(s) and the source are credited.

References

- Aydin S et al (2011) Cranioplasty: Review of materials and techniques. *J Neurosci Rural Pract* 2(2):162–167
- Spetzger U, Vougioukas V, Schipper J (2010) Materials and techniques for osseous skull reconstruction. *Minim Invasive Ther Allied Technol* 19:110–121
- Heissler E et al (1998) Custom-made cast titanium implants produced with CAD/CAM for the reconstruction of cranium defects. *Int J Oral Maxillofac Surg* 27(5):334–338
- Bartlett P, Carter LM, Russell JL (2009) The Leeds method for titanium cranioplasty construction. *Br J Oral Maxillofac Surg* 47(3):238–240
- Bhargava D et al (2010) Construction of titanium cranioplasty plate using craniectomy bone flap as template. *Acta Neurochir* 152(1):173–176
- Joffe J et al (1999) A prospective study of computer-aided design and manufacture of titanium plate for cranioplasty and its clinical outcome. *Br J Neurosurg* 13(6):576–580
- Day RE et al (2012) The Royal Perth Hospital method for the design and manufacture of titanium cranioplasty plates. *Br J Oral Maxillofac Surg* 50:376–377
- Lieger O et al (2010) Computer-assisted design and manufacture of implants in the late reconstruction of extensive orbital fractures. *Arch Facial Plast Surg* 12(3):186–191
- Rotaru H, et al. *Cranioplasty With Custom-Made Implants: Analyzing the Cases of 10 Patients*. *Journal of Oral and Maxillofacial Surgery*. 70(2): p. e169-e176
- Klein GT, Lu Y, Wang MY (2013) 3D Printing and Neurosurgery—Ready for Prime Time? *World Neurosurg* 80(3):233–235
- Elahinia MH et al (2012) Manufacturing and processing of NiTi implants: A review. *Prog Mater Sci* 57(5):911–946
- Jeswiet J (2005) Asymmetric Incremental Sheet Forming. *Adv Mater Res* 6–8:35–58
- Iseki H, Kato K, and Sakamoto S (1389) *Flexible and incremental sheet metal forming using a spherical roller*. In: Proc. 40th JJCTP: p. 41–44 (in Japanese).
- Matsubara S (1994) Incremental Backward Bulge Forming of a Sheet Metal with a Hemispherical Head Tool. *J JSTP* 35(406):1311–1316
- Araghi BT et al (2009) Investigation into a new hybrid forming process: Incremental sheet forming combined with stretch forming. *CIRP Ann Manuf Technol* 58(1):225–228
- Malhotra R et al (2010) Improvement of Geometric Accuracy in Incremental Forming by Using a Squeezing Toolpath Strategy with Two Forming Tools. *J Manuf Sci Eng* 133(6):603–611
- Emmens WC, Boogaard AH (2008) Tensile tests with bending: a mechanism for incremental forming. *Int J Mater Form* 1(1):1155–1158
- Allwood JM, Shouler DR (2009) Generalised forming limit diagrams showing increased forming limits with non-planar stress states. *Int J Plast* 25(7):1207–1230
- Lu B et al (2014) Mechanism investigation of friction-related effects in single point incremental forming using a developed oblique roller-ball tool. *Int J Mach Tools Manuf* 85:14–29
- Malhotra R et al (2012) Mechanics of fracture in single point incremental forming. *J Mater Process Technol* 212(7):1573–1590
- Micari F, Ambrogio G, Filice L (2007) Shape and dimensional accuracy in Single Point Incremental Forming: State of the art and future trends. *J Mater Process Technol* 191(1–3):390–395
- Lu B et al (2013) Feature-based tool path generation approach for incremental sheet forming process. *J Mater Process Technol* 213(7):1221–1233
- Lievers WB, Pilkey AK, Lloyd DJ (2004) Using incremental forming to calibrate a void nucleation model for automotive aluminum sheet alloys. *Acta Mater* 52(10):3001–3007
- Hussain G et al (2012) Guidelines for Tool-Size Selection for Single-Point Incremental Forming of an Aerospace Alloy. *Mater Manuf Process* 28(3):324–329
- Ambrogio G et al (2005) Application of Incremental Forming process for high customised medical product manufacturing. *J Mater Process Technol* 162–163:156–162
- Duflou JR et al (2013) Manufacture of Accurate Titanium Cranio-Facial Implants with High Forming Angle Using Single Point Incremental Forming. *Key Eng Mater* 549:223–230
- Scholz M et al (2007) Reconstruction of the temporal contour for traumatic tissue loss using a CAD/CAM-prefabricated titanium implant-case report. *J Cranio-Maxillofac Surg* 35(8):388–392
- Fang Y et al (2014) Analytical and experimental investigations on deformation mechanism and fracture behavior in single point incremental forming. *J Mater Process Technol* 214(8):1503–1515