

Service Orchestration with OPC UA in a Graphical Control Language

Theorin, Alfred; Hagsund, Johan; Johnsson, Charlotta

Published in: [Host publication title missing]

DOI:

10.1109/ETFA.2014.7005351

2014

Link to publication

Citation for published version (APA):

Theorin, A., Hagsund, J., & Johnsson, C. (2014). Service Orchestration with OPC UA in a Graphical Control Language. In [Host publication title missing] IEEE - Institute of Electrical and Electronics Engineers Inc.. https://doi.org/10.1109/ETFA.2014.7005351

Total number of authors:

General rights

Unless other specific re-use rights are stated the following general rights apply:

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.

 • You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

Read more about Creative commons licenses: https://creativecommons.org/licenses/

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Service Orchestration with OPC UA in a Graphical Control Language

Alfred Theorin, Johan Hagsund, and Charlotta Johnsson Department of Automatic Control, Lund University, Lund, Sweden

Automatic Control Lund Lund Www.control.lth.se

Background

Increasing market demands require highly flexible automation systems. A successful approach to compose flexible software is Service Oriented Architecture (SOA). In this work a convenient way to do SOA service orchestration with OPC Unified Architecture (OPC UA) is presented.

Me




Alfred Theorin
Ph.D. student
alfred.theorin@control.lth.se

OPC Unified Architecture

OPC UA offers robust and secure communication for distributed systems. It is backward compatible feature-wise with the classic OPC standards and is platform and language independent. It also offers SOA features and more powerful modeling capabilities with types and instances.


Java	C++	C#		Application lawer
OPC UA API				- Application layer
UA Binary		UA XML		} Data encoding layer
UA-SecureConversation		WS-SecureConversation		Security protocol layer
OPC UA TCP		SOAP		
TCP/IP		HTTP / HTTPS TCP/IP		Transport protocol layer
	UA B UA-SecureC OPC U	OPC U UA Binary UA-SecureConversation OPC UA TCP	OPC UA API UA Binary UA-SecureConversation OPC UA TCP SO HTTP /	OPC UA API UA Binary UA-SecureConversation OPC UA TCP SOAP HTTP / HTTPS

The Grafchart Language




Grafchart is a graphical programming language based on the PLC standard language SFC. The basic building blocks are steps (application states) with actions (what to do when) and transitions (how and when to change application state).

OPC UA Integration in JGrafchart




An *OPC UA Object* is bound to a node in an OPC UA server. The OPC UA variables and methods are then used like native variables and methods.


Use Case



The OPC UA support was tried out on a physical device in an Industry 4.0 setting. The device consists of a punching machine (1) and a conveyor belt (2). A microcontroller (3) was used to expose the device as variables in an OPC UA server.



The task to process incoming goods (4) was straightforward to implement in JGrafchart with the new OPC UA support.



OPC

Conclusions

The new integrated OPC UA support in JGrafchart is a convenient way to do SOA service orchestration in the automation domain. Both DPWS and OPC UA are required to cope with industrial requirements on device level and now JGrafchart supports both. With an OPC classic adapter, JGrafchart can now also interact with most industrial automation systems.

Download: http://www.control.lth.se/Research/tools/grafchart.html

Acknowledgments

Financial support from the VINNOVA-FFI project LISA is gratefully acknowledged. The authors are members of the LCCC Linnaeus Center and the eLLIIT Excellence Center at Lund University.





