

Accepted Manuscript

Measurement of the inter-tablet coating uniformity of a pharmaceutical pan coating process with combined terahertz and optical coherence tomography in-line sensing

Hungyen Lin, Yue Dong, Daniel Markl, Bryan M. Williams, Yalin Zheng, Yaochun Shen, J. Axel Zeitler

PII: S0022-3549(16)41905-2

DOI: [10.1016/j.xphs.2016.12.012](https://doi.org/10.1016/j.xphs.2016.12.012)

Reference: XPHS 589

To appear in: *Journal of Pharmaceutical Sciences*

Received Date: 25 August 2016

Revised Date: 29 November 2016

Accepted Date: 2 December 2016

Please cite this article as: Lin H, Dong Y, Markl D, Williams BM, Zheng Y, Shen Y, Zeitler JA, Measurement of the inter-tablet coating uniformity of a pharmaceutical pan coating process with combined terahertz and optical coherence tomography in-line sensing, *Journal of Pharmaceutical Sciences* (2017), doi: 10.1016/j.xphs.2016.12.012.

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.



Measurement of the inter-tablet coating uniformity of a pharmaceutical pan coating process with combined terahertz and optical coherence tomography in-line sensing

Hungyen Lin¹, Yue Dong², Daniel Markl³, Bryan M. Williams⁴, Yalin Zheng⁴, Yaochun Shen², and J. Axel Zeitler³

¹ Department of Engineering, Lancaster University, Lancaster LA1 4YW, UK

² Department of Electrical Engineering and Electronics, University of Liverpool, Liverpool L69 3GJ, UK

³ Department of Chemical Engineering and Biotechnology, University of Cambridge, Cambridge CB2 0AS, UK

⁴ Department of Eye and Vision Science, University of Liverpool, Liverpool LT7 8TX, UK

*Corresponding author: h.lin2@lancaster.ac.uk and jaz22@cam.ac.uk

Abstract

We present in-line coating thickness measurements acquired simultaneously using two independent sensing modalities: terahertz pulsed imaging (TPI) and optical coherence tomography (OCT). Both techniques are sufficiently fast to resolve the coating thickness of individual pharmaceutical tablets in-situ during the film coating operation and both techniques are direct structural imaging techniques that do not require multivariate calibration. The TPI sensor is suitable to measure coatings greater than 50 μm and can penetrate through thick coatings even in the presence of pigments over a wide range of excipients. Due to the long wavelength, terahertz radiation is not affected by scattering from dust within the coater. In contrast, OCT can resolve coating layers as thin as 20 μm and is capable of measuring the intra-tablet coating uniformity as well as the inter-tablet coating thickness distribution within the coating pan. However, the OCT technique is less robust when it comes to the compatibility with excipients, dust and potentially the maximum coating thickness that can be resolved. Using a custom built laboratory scale coating unit, the coating thickness measurements were acquired independently by the TPI and OCT sensors throughout a film coating operation. Results of the in-line TPI and OCT measurements were compared against one another and validated with off-line TPI and weight gain measurements. Compared to other process analytical technology (PAT) sensors, such as near-infrared and Raman spectroscopy, the TPI/OCT sensors can resolve the inter-tablet thickness distribution based on sampling a significant fraction of the tablet populations in the process. By combining two complementary sensing modalities it was possible to seamlessly monitor the coating process over the range of film thickness from 20 μm to greater than 250 μm .

Keywords: terahertz sensing; optical coherence tomography; pharmaceutical film coating; coating thickness; coating uniformity; terahertz pulsed imaging.

1. Introduction

The process of coating one or more layers of polymer onto tablets is almost ubiquitous in pharmaceutical manufacturing¹ in order to achieve dosage forms that exhibit uniformity in colour from an aesthetic point of view or to achieve light protection, taste masking and, more recently, in advanced coatings for active and modified release. Pharmaceutical tablet film coating is typically performed in large batches in perforated pan coaters. The quality of the resulting product is determined by the intricacies of the tablet mixing dynamics as well as the spray gun configuration during the coating process. Hence the quality is driven by the complex interplay between tablet properties (e.g. size and shape), process parameters (e.g. pan speed, pan loading, spray rate) and device specific parameters (e.g. size, geometry and baffles, spray angle). In an effort to better understand this process various in-line techniques have been devised and demonstrated for characterising pharmaceutical film coating, including optical sensing at near-infrared frequencies² and Raman spectroscopy.³⁻⁵ Comprehensive reviews on the topic have been presented elsewhere.⁶⁻⁷ Typically, these optical sensing techniques monitor the spectral attenuation of chemical constituents within the tablet or the coating and the average coating thickness can be inferred using previously calibrated multivariate models (e.g. partial least squares regression). Although such techniques are suitable, and indeed used in the field, to determine process endpoints, the calibration models are time-consuming to construct, require ongoing maintenance support and provide prediction performances that are specific to the formulation and instrument. Even in cases of the same vendor and model of the sensor and the process equipment, the transferability of the models is not always seamless and often must be reconstructed at significant financial and time expense. Furthermore, the sensor readings typically represent a time averaged measurement over a large number of sampled dosage forms and information pertaining to the individual dosage form, such as inter-tablet coating uniformity, is therefore unavailable. Other techniques such as optical imaging⁸ can sample individual tablets and therefore provide information on inter-tablet coating uniformity. Further, it can provide tremendous throughput with the use of modern visual imaging systems that also reduce the equipment cost barrier. However, optical imaging techniques are currently limited in application to monitoring small spherical dosage forms, such as pellets, largely because of the simplicity involved in determining the coating thickness and the smaller relative error in determining the change in dimension due to coating in small pellets.⁸ Tablets with complex shapes may therefore pose a challenge to thickness calculation.

In-line sensing with terahertz radiation was previously demonstrated for film coating using a production scale coater.⁹ The study exploited the fact that moving tablets have a tendency to align themselves facing towards the metallic mesh of the coating drum and therefore by focusing the terahertz pulses from outside the drum into the coater where the tablets exhibit a preferred orientation towards the sensor, the time of flight between successive reflections from coating interfaces could be measured directly to determine the coating thickness of individual tablets. The terahertz sensor was externally mounted in such a way that its focus plane was just behind the inner surface of the metal mesh of the rotating coating pan. Tablets passing through this terahertz focus point would lead to good terahertz reflections with a distinct arrival time (peak position) that can be used as one of the criteria for differentiating “good’

measurements (e.g., tablets are at the focus position) from “bad” ones (e.g., tablets are away from the terahertz focus plane). The effect of tablet orientation on the measured terahertz reflection has also been studied previously where terahertz reflections could be acquired through the steel mesh on top of an aluminium tablet holder that held tablets at slightly different angles relative to the mesh. The acquired in-line measurements from the coating experiments were automatically processed using a specifically developed algorithm that selected waveforms representative of reflections from the coated tablets that were at the focus of the terahertz beam and aligned at normal angle to the terahertz optics for thickness calculation. As the coating thickness at a given point on a tablet surface is directly proportional to the time delay Δt between adjacent reflection peaks in the measured terahertz waveform, the coating thickness d is determined as $2d = \Delta t c/n$, where n is the coating refractive index at terahertz frequencies and is readily attainable with terahertz time-domain spectroscopy, and c is the speed of light in vacuum. No further assumptions are required for the thickness measurement. The combination of the terahertz probe design and the selection algorithms therefore allows terahertz measurements to be reliably performed on fast-moving tables inside a rotating coater. Compared with the aforementioned measurement techniques, terahertz pulsed imaging (TPI) technology is unique in that it can measure the tablet coating thickness directly with sufficiently fast acquisition rate (up to 120 Hz⁹), obtained only from a single spot of the moving tablets, so that the inter-tablet coating uniformity of the tablet population within the coating unit can be directly measured. It was also established that the technique could resolve film coating thicknesses greater than 30 to 40 μm ^{9,14}. Exploiting a similar measurement principle and configuration is the more recently demonstrated spectral-domain optical coherence tomography where coating thickness of individual dosage forms in the coating thickness range of 15 to 80 μm could be reliably measured with high spatial resolution, both laterally and axially owing to a comparatively shorter wavelength of the radiation used^{10,11} thus making it an ideal alternative sensing modality for thin coatings. The technique can further operate with a high data acquisition rate (MHz has been shown¹⁰), enabling the determination of several thickness measurements per tablet. Such data thus yields both inter- and intra-tablet coating uniformity information and it further allows the evaluation of the tablet orientation and velocity^{10,11}. OCT measurement were successfully acquired through a perforated coating drum¹¹, which was also tested and evaluated at different tablet orientations and velocities under well-defined conditions prior¹⁰. Coating thickness can be determined in a similar manner to terahertz measurement while taking into account the coating refractive index at optical frequencies that could be measured with spectroscopic ellipsometry. It should be noted that OCT measures the scattered radiation from the tablets, as opposed to the specular reflection in terahertz measurement and therefore the tablet orientation is not be an issue.

2. Materials and Methods

2.1 Lab-scale tablet coating unit

In order to perform film coating thickness measurements of each of the individual tablets during the coating operations with in-line TPI and OCT sensing, a bespoke lab-scale coating unit was designed and commissioned. A TPI Imaga 2000 (TeraView Ltd., Cambridge, UK) was used as

the TPI measurement platform and a coating unit was designed to fit inside the commercial TPI unit (Fig. 1). The height of the coater was adapted to the height of the terahertz sensor such that surfaces of tablets on the mesh would lie in perpendicular orientation to the propagation direction of the incident terahertz beam to ensure an accurate thickness measurement. The terahertz sensor location therefore lies perpendicular to the centre of the coating pan as opposed to radially from the exhaust location⁹. To allow for the precise positioning of the perforated coating pan relative to the fixed terahertz sensor, the coating unit was mounted on a manually adjustable linear translational stage. The rotational movement was driven by an A-max 32 permanent magnet DC motor (Maxon Motor AG, Switzerland) supplied with 24 V. A PWM servo controller (ESCON Module 50/5) was used to maintain closed loop speed control by comparing and dynamically adjusting the speed measured by a 3 channel 100 kHz encoder HEDL 5540 (Maxon Motor AG, Switzerland), against the speed set-point configured on the ESCON Studio via USB 2.0 interface. The coating unit had a CNC machined perforated coating pan of 3 mm wall thickness and an overall diameter of 150 mm while each circular perforation had a diameter of 4.2 mm. The patterning of the perforations resulted in a 45% opening on the external surface of the pan. The 1.2 L coating pan was additionally fitted with three drive bars or baffles spaced out at 120° apart to facilitate the mixing of the tablet bed. Each baffle has a length of 70 mm corresponding to the longitudinal axis of the coating pan, a thickness of 6.2 mm and a length of 6 mm towards the centre of the coating pan. The baffles were dimensioned to account for the spatial limitations inside the coating pan such that they do not interfere with the spray nozzle. The coating pan was housed inside an air tight cylindrical poly(methyl methacrylate) enclosure with relevant cut-outs for inlet and outlet airflow, as well as a window for terahertz propagation. Examples of high terahertz transparency window materials include high density polyethylene¹², quartz and high resistance silicon. VisiJet M3 Crystal based manifolds were designed, 3D printed at 25 µm resolution and installed on the enclosure to guide the airflow at the inlet and outlet. Additionally, the manifolds were fitted with orifices for temperature, humidity and pressure sensor insertions. In a manner similar to previous in-line measurements,^{9,11} the OCT sensor was positioned outside the coating pan at the exhaust of the coater and orientated such that tablet surfaces were perpendicular to the incident beam. The OCT sensor was covered by a micron thick polyethylene based plastic cling film to protect it from direct exposure to dust. In order to validate the integration of in-line TPI and OCT sensing, in-line measurement was initially performed on a batch of previously coated bi-convex tablets in the absence of spray. The film coating thickness of three randomly selected tablets was measured with off-line TPI and OCT for comparison against in-line measurements¹³. The assembled coating unit was bolted to the TPI base plate. It weighed approximately 10 kg and demonstrated good resistance to external vibrations or movement that could distort terahertz measurements.

2.2 Tablet coating process

Film coating was performed using a Schlick Nano ABC spray nozzle (Düsen-Schlick GmbH, Coburg, Germany) at a spray rate of 1.4 g/min operating at an atomising air pressure of 1 bar. The coating dispersion was pumped by a Watson Marlow 120S peristaltic pump (Spirax-Sarco Engineering, Cheltenham, UK) at 2 rpm. The coating drum rotated at 15 rpm (0.11 ms⁻¹). The

inlet air flow was supplied by the laboratory compressed air and regulated by a Mass Stream mass flow controller (Bronkhorst High-Tech B.V., Ruurlo, Netherlands) that interfaced directly to the PC via RS-232. The inlet airflow was set at 20 m³/h and was kept constant throughout the coating process. The inlet temperature was heated by passing the lab compressed air through a 800 W heating element where the electric current to the heating element was regulated by a piccolo P160 PID controller (Eurotherm, Worthing, UK). The inlet temperature was set at 55°C in order to ensure outlet/exhaust temperature was maintained at 38-43°C. A sustained release coating formulation consisting of Kollicoat SR30D and Kollicoat IR (BASF, Ludwigshafen, Germany), detailed in Table 1, was applied to each batch of tablets. The batch size of uncoated tablet cores was 300 g. The tablet cores (Ludipress LCE, BASF, Ludwigshafen, Germany) were of bi-convex geometry of 8 mm diameter and were embossed ($m = 360$ mg). The coating formulation was chosen such that it could be measured with both OCT and TPI simultaneously. Due to scattering at NIR frequencies, this is not always the case¹¹.

2.3 In-line TPI sensing

To ensure that the generated terahertz pulses were focused onto the surface of tablets inside the coating pan, the sensor was kept at a fixed distance that matched to the 7 mm focal length of the terahertz sensor optics from the inner wall of the coating pan. Taking into account the distance of travel on the mesh and the tablet tangential speed, reflected time-domain waveforms were recorded at a rate of 30 Hz (acquisition time of a single waveform 33.3 ms) with no signal averaging in order to ensure that the likelihood of multiple measurements on a single tablet is minimised. The measurements were saved and processed off-line (Matlab R2015b, The MathWorks Inc., Natick, Massachusetts) using the previously presented analysis algorithm^{9,14}. As the strength of the reflections from the coating core interfaces was weaker than the reflections obtained from previously published coating trials, due to a more porous coating as a result of a sub-optimally controlled process, additional selection criteria were included into the analysis algorithm to take advantage of ancillary waveform features present in the coating formulation used in this study. Furthermore, a sliding window with fixed window size was used to define the thickness search range as a function of coating time so as to more accurately discriminate the reflections from the coated tablets. Like previously, the settings for the selection criteria were determined based on the off-line analysis of the coated tablets.

2.4 Spectral-domain optical coherence tomography

An in-house fibre based SD-OCT sensor was developed for in-line measurement. As shown in Fig. 2, a super-luminescent diode (EXALOS AG, Schlieren, Switzerland), centred at a wavelength of 840 nm and with a full width at half maximum (FWHM) bandwidth of 55 nm, was used as the light source. The light beam was firstly coupled into the input port of a 2 x 2 wideband single mode fibre coupler (TW850R5F2, Thorlabs Inc., Newton, New Jersey). The fibre coupler splits the light (50:50) into a reference and a probe port. The light of the reference port was collimated by an adjustable collimator (CFC-2X-B, Thorlabs Inc.) and the light reflected from a reference mirror was coupled back to the reference port by the same collimator (C1).

The light of the probe port was focused onto the sample by using another identical collimator (C2). The back-scattered light from the sample was collected and coupled back into the probe port by the same collimator. The light from the output port of the fibre coupler, which contains the interference patterns of the reflected/backscattered light from the reference/sample, is delivered to a high-resolution spectrometer (Wasatch Photonics Inc., Logan, Utah) with a 2048 line CCD array.

This fibre based OCT configuration is highly suitable for in-line monitoring applications since the fibre sample port can be easily integrated into the coater unit through an orifice at the outlet manifold of the coating unit. A photograph of the entire experimental setup is shown in Fig. 3. It should be noted that because of the physical space constraint, the OCT sensor described here is only a collimator as opposed to a more integrated design described previously¹¹. The focus position of the sample beam was set to the inner surface of the coating pan by using the adjustable aspheric fibre collimator. This gave rise to an approximate distance of 7 mm (NA of 0.27) between the collimator and the focal point, providing a depth of field of 734 μm . The achieved axial and lateral resolution is approximately 7.5 μm and 20 μm respectively. In all OCT measurements, the exposure time and the idle time of the spectrometer were set to 65 μs and 5 μs respectively, providing a data acquisition rate of 14,285 Hz. The on-board memory allows 1000 successive spectral interferograms to be captured and stored at a time before they are transferred to a computer for processing. The signal processing includes (1) subtraction of the reference spectrum that is estimated by averaging all the 1000 acquired spectra (2) interpolation to convert the spectral interferograms from wavelength domain to wavenumber domain (3) fast Fourier transform to convert frequency-domain spectra to time-domain depth profiles. Finally a B-scan, e.g., a cross-sectional image consisting of 1000 successive A-scans, is obtained.

As the OCT sensor developed in this work is much more compact, thus vastly different to the previous design¹¹, a different data processing solution specific to our OCT system is proposed. In order to automatically extract the coating thickness from the measured OCT B-scan, further signal and image processing algorithms were used, as shown in Fig. 4. In general, A-scans were processed for denoising purposes while B-scans were used for tablet identification and thickness quantification. Wavelet denoising was used as the first step to remove the background speckle noise followed by determining the mean intensity profiles. The rationale for this step was because the distance covered in a single B-scan was 7.7 mm and that corresponded to approximately twice the perforation diameter. The B-scan therefore included more than one tablet hit, as well as additional features from the metallic mesh and the baffle. Even though reflections from metallic mesh and baffles generally have magnitudes greater than those of the tablets, the number of peaks/scatterings from tablets on an A-scan was understandably greater due to a mix of particle and air inclusions in the coating. Consequently, the average intensity of an A-scan of a tablet is greater than that of either the metallic mesh or baffles. By exploiting this fact, A-scans with tablets can be easily identified by thresholding the mean intensity profile that is generated by averaging the intensities of all A-scan pixels. The thresholding value is set in this instance to be greater than the maximum intensities from the mesh/baffle and generally does not change for the same process settings. To qualify as a tablet hit, the number of successive A-scans with intensities greater than the mean intensity profile must be greater than

80 on a single B-scan. This value was determined on the basis of the segmentation algorithm used for accurate thickness measurement.

Like in previous work¹¹, a graph-based segmentation algorithm was also used to detect the position of the interfaces for automatic thickness calculation²⁰. Specifically, the image is represented in the algorithm as a graph, where each pixel of the image is regarded as a node that is connected to neighbouring pixels by weighted edges. The algorithm then attempts to find the path from the source (on the left side of the image) to the sink (right side of the image), which is regarded as the shortest or the path of least energy cost. In order to accomplish this, an energy function is defined as the linear combination of the gradient information in the lateral and depth directions of the image, with the associated coefficients determined by the emerging curvature. This energy is then used to determine the edge weighting cost or cost from moving from one node to the next. Consequently, the precise path can be determined locally leading to efficient detection of the path for fast segmentation of the edges. The coating thickness is then calculated by the distance between the detected interfaces at each transversal pixel scaled by refractive index. It is recognised that further improvements can be made to the processing algorithm. In particular, thickness calculations should take account of interface curvatures for precise measurement. This was not performed in this study due to the embossings on the tablet cores used. Furthermore, the algorithm can be further extended to check if more tablet hits on a same B-scan did actually come from a single tablet.

2.5 Off-line measurement

Owing to the spatial constraint inside the TPI and the likelihood of causing misalignment to the in-line TPI measurements during the coating operation, tablets were not removed throughout the process as was performed in previous studies for validation purposes^{9,11}. In contrast, only the film coating thickness and the average weight gain of coated tablets obtained at the process endpoint were measured. Specifically, average weight gain for 18 tablets was measured and off-line thickness determined using the off-line TPI where the top, bottom and centre band were imaged at a 200 μm lateral resolution. To determine the coating material refractive index at terahertz and optical frequencies, the film coating thickness for a scratched side of a randomly selected coated tablet was measured independently with off-line TPI, OCT¹⁵ and X-ray computed microtomography (X μ CT)¹⁶ where the ratio of the thickness represents the ratio between the refractive indices. The terahertz refractive index was also independently determined based on the primary reflection intensity from all of the off-line TPI measurements of the coated tablets¹⁷. The X μ CT measurement was performed on a Skyscan 1172 (Bruker, Kontich, Belgium, control software: Skyscan1172 XuCT Control Program v1.5). Reconstruction was performed using the program NRecon (Bruker, v1.6.9.8) on a single PC using GPU accelerated reconstruction (Windows 7 64-bit workstation, 2 Intel Xeon X5647 with 4 cores each, 48 GB RAM, NVIDIA Quadro 4000 with 256 cores) yielding 3D data with an isotropic voxel size of 2.97 μm . The data acquisition time was 1.5 hours and the image reconstruction took 0.5 h size for 356 slices of 1148 x 1148 pixels. The data was downsampled to a voxel size of 9.9 x 9.9 x 9.9 μm^3 in the interest of data processing and visualisation. The 3D data (X μ CT, OCT and TPI) was visualised using Avizo Fire (FEI Company, Hillsboro, Oregon, USA, v8.1.1.). The voxel size (image dimensions) was 9.9 x 9.9 x 9.9 μm^3 (801 x 801 x 312 pixels), 50 x 10 x

4.2 μm^3 (170 x 1000 x 509 pixels), 199.1 x 200.4 x 4.4 μm^3 (48 x 48 x 571 pixels) for X μ CT, OCT and TPI, respectively.

3. Results and Discussions

In order to compare the absolute coating thickness, the coating material refractive index is determined to be 1.42 and 1.61 for terahertz and optical frequencies, respectively. The coated tablet has an average coating thickness of 280 μm as measured with X μ CT (Fig. 5). Interestingly, by examining the primary reflection intensity from all of the off-line TPI measurements of the faces of the coated tablets removing contributions from embossings and tablet edges, a refractive index value of 1.46 was revealed in close agreement with the X μ CT measurements. The maps indicated that the polymer layer is generally uniformly distributed over the surface of the individual tablet faces. By comparing this value with the refractive index of the same coating material coated inside a commercial coater, it showed a reduction by 16% thus implying the possibility of forming a rather porous coating leading to a reduced effective refractive index (i.e. density) as a result of a sub-optimally controlled process¹⁹. It is also interesting to note that this particular coating formulation at such high coating thicknesses compared to the ones previously studied¹⁵ was still fairly transparent at optical frequencies for OCT to successfully resolve the interfaces in an off-line thickness measurement.

The absolute coating thickness was independently obtained by processing the acquired in-line TPI and OCT measurements automatically by the respective algorithms and taking into account the refractive index at terahertz and optical frequencies. Fig. 6 shows the average coating thickness over 30 seconds as a function of process time. As expected, there is a steady increase in coating thickness observed with both of the sensing modalities. OCT measurements, owing to a shorter wavelength used and a lower coherence length, is able to resolve thin coatings and this starts as early as 6 minutes into the process with the detection of 20 μm thick coatings. In contrast, in-line TPI operating with picosecond pulses is sensitive for coatings greater than 50 μm . This is slightly greater than the previously reported resolution of 30 to 40 μm ⁹ because of the additional stringent selection criteria used for waveform extraction. This step was necessary so as to filter out the weaker reflection that is buried in noise. Despite this, the in-line TPI measurements, though obtained only from a single measurement of a moving tablet in the coating pans, show a good overlap after 50 minutes of coating and a general good agreement with film thickness growth rate when compared against the OCT measurements. It should also be noted that in OCT measurements, owing to the two orders of magnitude higher data acquisition rate, multiple measurements were taken at a moving tablet and the median of which is used to represent the tablet hit. Alternatively, the average value could be used provided the edge effects are accounted for.

To further compare the measurements, the thickness distributions obtained from the respective sensors are shown in Fig. 7 at 20 minutes time interval. As expected, process measurements start with OCT where the distribution takes the shape of a log-normal distribution in the first 40 minutes in a similar manner to the production scale process with in-line TPI sensing¹⁴. The coating thickness detected with TPI is however, below the minimum resolution thus

incomparable with OCT measurement. The distribution then converges closer to a Gaussian distribution in the following 60 minutes from which the number of hits have deteriorated to provide any insightful interpretation. This is evident in Fig. 7 where the tablet hits measured with OCT decreases monotonically with process time. In contrast, in-line TPI measurements start after the first 40 minutes of the process with the detection of coatings greater than 50 μm and generally overlap well with the OCT measurements. The number of hits, however, does not increase until after 60 minutes largely because of the stringent waveform amplitude settings used in the selection criteria. The thickness distribution at this time interval nevertheless centres about 85 μm coinciding well with the OCT distribution. In the 80 to 100 minutes time interval, the shape of the distributions resembles closely despite the thickness distribution of the coating process no longer following a clear Gaussian like distribution as observed in a commercial coater¹⁴. This could be in part due to the process being sub-optimally controlled, the use of tubular mixing baffles that did not promote axial mixing or the settings for the selection criteria used. This matter could be independently verified when more tablet hits could be obtained with OCT measurements. Interestingly however, is the similarity of the distributions during the time intervals of significant thickness overlap i.e. 60 to 100 minutes that implies the possibility of a tablet being measured firstly by OCT then by terahertz. However, considering that the measurements were not synchronised, such hypothesis is unlikely despite of the relative axial positions of the sensors on the coating unit. Opportunities however loom on the prospect of using such sensing arrangement positioned precisely to study mixing dynamics without spray coating or identify the optimal sensing locations when coupled with simulations. Following this time period, the terahertz thickness distribution still loosely resembles a Gaussian distribution where some overlaps with the limited OCT measurements are still present and thereby reinforcing the terahertz measurement. The in-line TPI measurements in the final time interval can be validated against the off-line TPI measurements where the in-line measurements lie within the error bars of the off-line TPI measurements of the coated tablets. Specifically, the measurement of 134 tablets by in-line TPI in this time period has a coefficient of variation or relative standard deviation (RSD) of 11% comparable to a RSD of 9% from the off-line TPI measurements with 18 tablets. It is interesting to note that this value of RSD is approximately twice than what could be achieved with a commercial coating process of a similar scale operating at half the process time¹¹, thereby showing that the existing process has not been optimally controlled.

Further exploiting the comparative higher data acquisition rate in OCT, the acquired B-scans for the tablet hits shown in Fig. 8 allow for a visual assessment to determine if the measurements did actually represent physical tablets. As an example, the RSD of OCT measurements in Fig. 9 appears to increase with process time exceeding to 20% at 120 minutes. By inspecting the B-scans after 100 minutes, there were indeed B-scans of coated tablets with thicknesses in the order of 80 to 120 μm at coating times of 125, 130 and 149 minutes. Such low thicknesses were however, not detected with terahertz because of the sliding window used in the algorithm designed to capture the weak reflections. Noticeably, the number of tablet hits from OCT measurements reduces after 120 minutes of coating. This is because of a deterioration in signal-to-noise ratio (SNR) of the acquired B-scans after 120 minutes of coating leading to an increased probability of interface misdetection with the applied segmentation algorithm. The

SNR reduction can be attributed to the increased amount of dust accumulated on the OCT sensor head as opposed to the increased scattering encountered with thicker coating¹⁵. The dust issue culminates with no tablet detections in OCT measurement after 180 minutes of coating. To remedy the dust issue, we are now exploring the use of a low pressure compressed air purge alongside the OCT sensor head for in-process sensor clean. The dust issue coupled with increasing coating thickness leads to a reduced contrast from the coating core interface and eventually lowers the number of successfully measured tablets. Consequently the effects of outliers are greater on the 30 s average values towards the end of the coating process than at the beginning, where at least 200 more tablets were measured. Furthermore, the increasing deviation of the coating thickness measured by OCT from the average coating thickness can be explained by the systematic error introduced by the curvature of the tablet. This error grows with increasing coating thickness and can be as high as 15 μm for a 150 μm thick coating layer²². Future work will seek to correct this error by considering the angle of incidence of the optical beam and applying Snell's law²³. Additional acquired B-scans can be found in the supporting information.

The reliability of the OCT measurements can be further assessed by inspecting the RSD-hits plot (Fig 9). It should be noted that values of the RSD should only be interpreted alongside the tablet hits recorded as too little hits, or effectively sampling only a very small fraction of tablet population, is likely to lead to a meaningless result. As can be seen, following the 80 to 100 minutes interval, OCT measurements become unreliable because the measured RSD has increased as opposed to an expected decrease²¹ that is observed with the terahertz measurement. During the same time periods, the number of tablets measured with OCT decrease monotonically for reasons described above while the hits remain relatively constant for terahertz. It is worthwhile to note that no OCT measurements were recorded during 180 to 200 minutes interval hence no RSD value. Considering the total number of hits of OCT (1128) and terahertz (1284) for a tablet population of approximately 840 tablets, it is likely that some tablets were measured more than once during this process.

4. Conclusion

In this investigation, we have custom built a laboratory scale coating unit within the spatial confines of the TPI in order to facilitate the measurement of the film thickness of each of the individual tablets during the coating process by combined in-line TPI and OCT sensing. By combining two similar yet complementary in-line sensing modalities, it allows for a validation of coating thickness measurements without regular tablet withdrawals for off-line characterisation. Furthermore, coating thicknesses starting as low as 20 μm and up to 300 μm and above could be measured potentially also with different coating formulations. The availability of film coating thickness measurements from individual tablets as opposed to the average coating thickness of a large number of tablets can provide substantially more information about the inter-tablet coating uniformity. The film coating process, however, has not been optimally controlled and therefore the finished coatings as evaluated by $X\mu\text{CT}$ and off-line TPI show a reduced effective refractive index compared to what would be expected with a commercial process. In turn, the

reduced refractive index implies a reduced coating density or an increased porosity in the coating. Further, the measured coating thickness distribution does not yet follow an optimally controlled process^{14,21}. To better understand the present coating process as well as explain the observed coating distributions measured at different locations of the coating unit, numerical simulation with discrete element method is currently underway. This work nevertheless has resulted in the development of a unique platform exploiting a multiple-sensing arrangement to generate time-resolved and spatially resolved in-process measurements for studying the pharmaceutical film coating process comprehensively for consolidation with numerical modelling.

Acknowledgements

The authors would like to acknowledge the financial support from UK EPSRC Research Grant EP/L019787/1 and EP/L019922/1. The authors acknowledge BASF for providing the materials used in this study, Colorcon Ltd. (Dartford, UK) for coating process recommendations, Hüttlin GmbH (Bosch Packaging Technology, Schopfheim, Germany) for advice on the coating unit design and the staff of the electronics and mechanical workshops in Department of Chemical Engineering and Biotechnology at University of Cambridge. HL also acknowledges travel support from Joy Welch Educational Charitable Trust.

References

1. McGinity JW, Felton LA. 2008. Aqueous polymeric coatings for pharmaceutical dosage forms. 3rd ed., London: Informa Healthcare.
2. Kirsch JD, Drennen JK 1996. Near-infrared spectroscopic monitoring of the film coating process. *Pharm Res* 13(2):234-237.
3. Romero-Torres S, Pérez-Ramos JD, Morris KR, Grant ER 2005. Raman spectroscopic measurement of tablet-to-tablet coating variability. *J Pharm Biomed Anal* 38(2):270-274.
4. El Hagrasy A, Chang S-Y, Desai D, Kiang S 2006. Raman spectroscopy for the determination of coating uniformity of tablets: assessment of product quality and coating pan mixing efficiency during scale-up. *J Pharm Innov* 1(1):37-42.
5. Muller J, Brock D, Knop K, Zeitler JA, Kleinebudde P 2012. Prediction of dissolution time and coating thickness of sustained release formulations using Raman spectroscopy and terahertz pulsed imaging. *Eur J Pharm Biopharm* 80(3):690-697.
6. De Beer T, Burggraeve A, Fonteyne M, Saerens L, Remon JP, Vervaet C 2011. Near infrared and Raman spectroscopy for the in-process monitoring of pharmaceutical production processes. *Int J Pharm* 417(1-2):32-47.
7. Knop K, Kleinebudde P 2013. PAT-tools for process control in pharmaceutical film coating applications. *Int J Pharm* 457(2):527-536.
8. Oman Kadunc N, Sibanc R, Dreu R, Likar B, Tomazevic D 2014. In-line monitoring of pellet coating thickness growth by means of visual imaging. *Int J Pharm* 470(1-2):8-14.

9. May RK, Evans MJ, Zhong S, Warr I, Gladden LF, Shen Y, Zeitler JA 2011. Terahertz in-line sensor for direct coating thickness measurement of individual tablets during film coating in real-time. *J Pharm Sci* 100(4):1535-1544.
10. Markl D, Hanneschläger G, Sacher S, Leitner M, Khinast JG 2014. Optical coherence tomography as a novel tool for in-line monitoring of a pharmaceutical film-coating process. *Eur J Pharm Sci* 55(0):58-67.
11. Markl D, Hanneschläger G., Sacher S, Leitner M, Buchsbaum A, Pescod R, Baele T and Khinast JG 2015, In-Line Monitoring of a Pharmaceutical Pan Coating Process by Optical Coherence Tomography. *J Pharm Sci* 104(8): 2531–2540.
12. Piesiewicz R, Jansen C, Wietzke S, Mittleman D, Koch M, Kürner T 2007. Properties of building and plastic materials in the THz range, *Int J Infrared Millimeter Waves* 28(5):363–371.
13. Lin H, Dong Y, Pei C, Elliot JA, Shen YC, Zeitler JA 2015. Investigation of pharmaceutical film coating process with terahertz sensing, optical coherence tomography and numerical modelling, 40th International Conference on Infrared Millimeter and Terahertz Waves, Hong Kong.
14. Lin H, May RK, Evans MJ, Zhong S, Gladden LF, Shen YC, Zeitler JA 2015. Impact of Processing Conditions on Inter-tablet Coating Thickness Variations Measured by Terahertz In-Line Sensing. *J Pharm Sci* 104(8): 2513–2522.
15. Lin H, Dong Y, Shen YC, Zeitler JA 2015. Quantifying Pharmaceutical Film Coating with Optical Coherence Tomography and Terahertz Pulsed Imaging: An Evaluation. *J Pharm Sci* 104(10): 3377–3385.
16. Russe I-S, Brock D, Knop K, Kleinebudde P, Zeitler JA 2012. Validation of Terahertz Coating Thickness Measurements Using X-ray Microtomography. *Mol Pharm* 9(12):3551-3559.
17. Shen YC, Taday PF 2008. Development and Application of Terahertz Pulsed Imaging for Nondestructive Inspection of Pharmaceutical Tablet. *IEEE J Sel Top Quantum Electron* 14(2):407-415.
18. Yassin S, Su K, Lin H, Gladden LF, Zeitler JA 2015. Diffusion and Swelling Measurements in Pharmaceutical Powder Compacts Using Terahertz Pulsed Imaging. *J Pharm Sci* 104(5): 1658–1667.
19. Chakraborty M, Bawuah P, Tan NY, Ervasti T, Pääkkönen P, Zeitler JA, Ketolainen J, Peiponen KE 2016. On the correlation of effective terahertz refractive index and average surface roughness of pharmaceutical tablets, *Int J Infrared Millimeter Waves* 37(8):776-785.
20. Williams D, Zheng Y, Davey PG, Bao F, Shen M, and Elsheikh A 2016, Reconstruction of 3D surface maps from anterior segment optical coherence tomography images using graph theory and genetic algorithms. *Biomed Signal Process Control* 25: 91–98.
21. Kalbag A, Wassgren C. 2009. Inter-tablet coating variability: Tablet residence time variability. *Chem Eng Sci* 64(11):2705–2717.

22. Markl D, Hanneschläger G, Sacher S, Leitner M, Khinast JG, Buchsbaum A. 2014. Automated pharmaceutical tablet coating layer evaluation of optical coherence tomography images. *Meas Sci Technol* 26(3):035701.
23. Podoleanu A, Charalambous I, Plesea L, Dogariu A, Rosen R. 2004. Correction of distortions in optical coherence tomography imaging of the eye. *Phys Med Biol* 49(7):1277-1294.

Figure Captions

Figure 1. (a) Schematic diagram of the lab-scale pan coater coupled to the TPI and OCT sensor for in-line coating thickness measurement and (b) a technical drawing of the pan coater in perspective view.

Figure 2 - Schematic of an in-house SD-OCT system with a tablet placed in the perforated coating pan. SLD - superluminescent diode, RM – reference mirror, C1 and C2 – adjustable collimators.

Figure 3 - Data processing algorithm implemented in Matlab for automatically quantifying film coating thickness based on acquired OCT B-scans.

Figure 4 - Photos of the experimental setup showing a) the sensing setup comprising an external OCT system for driving the OCT sensor head integrated into the custom built coating unit inside the TPI for performing combined in-line TPI and OCT sensing of a coating process that is managed at b) the control desk where the pneumatics, motor speed, heating temperature and mass transfer are monitored.

Figure 5 - 3D renderings of film coating measurements for a coated tablet at the end of the process run with a coating thickness of 280 μm independently obtained with three techniques (b) X μ CT, (c) OCT and (d) off-line TPI. The 3D data sets from the three techniques were superimposed in (a). The contrast is due to electron density differences in case of the X μ CT (orange) measurements and due to refractive index changes for OCT (grey) and TPI (blue).

Figure 6 – Film coating thickness measured by combined in-line TPI (open circles) and OCT sensing (crosses) as a function of the process time. Each datum corresponds to the average coating thickness over 30 s period. The black dashed line represents the linear fit over both the in-line terahertz and OCT measurements. The black and magenta open circles indicate the coating mass and the film coating thickness of 18 tablets at the process endpoint, respectively. The film coating thickness is measured by off-line TPI for both surfaces.

Figure 7 - Comparison of the film coating thickness distribution measured using combined in-line TPI and OCT sensing at 20 minutes time intervals throughout the entire film coating process. It should be noted that 20 minutes coating time corresponds to an approximate thickness change of 28 μm .

Figure 8 – Examples of B-scans captured with OCT throughout the coating process showing tablet hits with coating interfaces highlighted with the applied segmentation algorithm for automated thickness quantification. The title of each OCT image indicates the mean \pm standard deviation calculated from the detected coating layer interfaces. The x-axis represents the width of the tablet measured and depends on the tablet movement speed.


Figure 9 - Comparison of the RSD of coating thickness (open circle) and tablet hits (star) at 20 minutes time intervals as measured with in-line TPI (blue) and OCT (red) sensing. Lines are


drawn to guide the eye.

ACCEPTED MANUSCRIPT


Table 1 – Sustained release coating formulation

Function	Ingredient	Quantity (%)
Polymer	Kollicoat SR 30D	13.5
Binder	Kollicoat IR	5.8
Plasticizer	Propylene glycol	0.675
Diluent	Water	80.25








a



b







ACCEPTED M

