Northumbria Research Link

Citation: Valinejad, Jaber, Marzband, Mousa, Akorede, Mudathir, Barforoshi, Taghi and Jovanovic, Milutin (2017) Generation expansion planning in electricity market considering uncertainty in load demand and presence of strategic GENCOs. Electric Power Systems Research, 152. pp. 92-104. ISSN 0378-7796

Published by: Elsevier

URL: https://doi.org/10.1016/j.epsr.2017.07.004 < https://doi.org/10.1016/j.epsr.2017.07.004 >

This version was downloaded from Northumbria Research Link: http://nrl.northumbria.ac.uk/31431/

Northumbria University has developed Northumbria Research Link (NRL) to enable users to access the University's research output. Copyright © and moral rights for items on NRL are retained by the individual author(s) and/or other copyright owners. Single copies of full items can be reproduced, displayed or performed, and given to third parties in any format or medium for personal research or study, educational, or not-for-profit purposes without prior permission or charge, provided the authors, title and full bibliographic details are given, as well as a hyperlink and/or URL to the original metadata page. The content must not be changed in any way. Full items must not be sold commercially in any format or medium without formal permission of the copyright holder. The full policy is available online: http://nrl.northumbria.ac.uk/policies.html

This document may differ from the final, published version of the research and has been made available online in accordance with publisher policies. To read and/or cite from the published version of the research, please visit the publisher's website (a subscription may be required.)

www.northumbria.ac.uk/nrl



Generation Expansion Planning in Electricity Market Considering Uncertainty in Load Demand and Presence of Strategic GENCOs

Jaber Valinejad^a, Mousa Marzband^{b,c}, Mudathir Funsho Akorede^d, Taghi Barforoshi^a, Milutin Jovanović^b

^aFaculty of Electrical and Computer Engineering, Babol Noshirvani University of Technology, Babol, Iran

^bFaculty of Engineering and Environment, Department of Physics and Electrical Engineering, Northumbria University Newcastle, Newcastle upon Tyne NE1 8ST,

IJΚ

^cDept. of Electrical Engineering, Lahijan branch, Islamic Azad University, Lahijan, Iran

^dDept. of Electrical & Electronics Engineering, Faculty of Engineering and Technology, University of Ilorin, P.M.B. 1515, Ilorin, Nigeria.

Abstract

This paper presents a new framework to study the generation capacity expansion in a multi-stage horizon in the presence of strategic generation companies (GENCOs). The proposed three-level model is a pool-based network-constrained electricity market that is presented under uncertainty in the predicted load demand modeled by the discrete Markov model. The first level includes decisions related to investment aimed to maximize the total profit of all GENCOs in the planning horizon, while the second level entails decisions related to investment aimed at maximizing the total profit of each GENCO. The third level consists of maximizing social welfare where the power market is cleared. The three-level optimization problem is converted to a one-level problem through an auxiliary mixed integer linear programming (MILP) using primal-dual transformation and Karush-Kuhn-Tucker (KKT) conditions. The efficiency of the proposed framework is examined on MAZANDARAN regional electric company (MREC) transmission network- a part of the Iranian interconnected power system. Simulation results confirm that the proposed framework could be a useful tool for analyzing the behaviour of investment in electricity markets in the presence of strategic GENCOs.

Keywords: Generation expansion planning, mathematical programming of equilibrium constraints problem, dynamic planning, strategic GENCO, uncertainty, three-level model.

		EC	
Nomencla	ature	$\overline{P}_{\mathrm{yk}}^{\mathrm{ES}}$	capacity of existing generation unit k of
	Indices	5	strategic GENCO y (MW)
w/w'	index for scenario	\overline{P}_{td}^{D}	maximum load of demand d in block t
r/r′	index for year		(MW)
t	index for demand blocks	C_i^S/C_k^{ES}	marginal cost of new/existing unit of
у	index for GENCOs		strategic GENCO (€/MWh)
i/k	index for new/existing generation unit of	U_{rtd}^{D}	price bid of demand d in demand block t
	strategic GENCO		and year r (€ /MWh)
d	index for demand	B _{mn}	musceptance of line n-m (p.u.)
h	index for size of investment option	F _{nm}	transmission capacity of line n-m (MW)
n/m	index for bus	f	discount rate
Parameters			Decision variables
σ_{rt}	weight of demand block t in year r	X_{yri}	capacity investment of new unit i of the
W_w	weight of scenario w and year r		strategic GENCO y in year r (MW)
Q_{wr}	demand growth of scenario w in year r	$\mathfrak{u}_{\mathrm{yrih}}$	binary variable that is equal to 1 if the
K _{yri}	annual investment cost of new generat-		h th investment option of technology i is
	ing unit i of strategic GENCO y in year r		selected in year r, otherwise it is equal to
	(€ /MW)		0
Κ _y	available investment budget of strategic	$P_{yrtkw}^{Es}/P_{yrtiw}^{S}$	power produced by existing/new unit k/i
	GENCO y (M€)		of strategic GENCO y in year r, demand
X _{ih}	option h for investment capacity of new		block t and scenario w (MW)
	unit i (MW)	$X_{yrr'i}/P_{yrr'tiw}^{Sr}$	available Capacity/ Power produced of
			new unit i of strategic GENCO y in year
Email ac	dress: mousa marzhand@manchester ac uk		r', in years after the installation in year r
Correspon	ding author (Mousa Marzband)		(MW)
		P_{rtdw}^D	demand d, in year r, demand block t and
Preprint submitted to Electrical Power System Research			scenario w (MW) August 1, 2017

Preprint submitted to Electrical Power System Research

$O_{vrtkw}^{ES}/O_{vrtiv}^{S}$	vprice offered by existing/new unit k/i of
5	the of strategic GENCO y in year r, de-
	mand block t and scenario w (\in /MWh)
O ^{Sr} vrr'tiw	price offered by new unit i of strategic
J	GENCO y, in year r' , in the years after the
	installation in year r, demand block t and
	scenario w (€/MWh)
λ_{rtnw}	location marginal price or market clear-
	ing price (€/MWh)
C ^r _{vrr'i}	marginal cost of new unit of GENCO i, in
,	year r', in the years after the installation
	in year r (€ /MWh)
θ_{rtnw}	voltage angle of bus n, in year r, demand
	block t and scenario w

1. Introduction

Security and quality of supply, which implies the physical availability of electric power in sufficient quantities at all times and prices that are affordable for consumers, have remained top priorities since the electricity market liberalization [1-5]. These two vital features of the electric power supply must be ensured on the short and long-term basis [6]. To achieve this goal, it is important to have a positive correlation between generation expansion and the demand growth to maintain balance between production and consumption. However, generation expansion planning has become a complex issue in the power generation industry in the competitive space [7-9]. In a limited competitive space, it is necessary that the independent system operator is equipped with the capabilities of models and computational tools to enable it to study the behaviour of the expansion of the generation sector in power systems under uncertainty [5, 7, 10–27].

Generation investment market involves competition of a set of strategic companies of which each can exact power with its decisions in the market. Given this scenario, challenges and significant difficulties will be created in strategic companies, decisions include short-term decisions which include strategic offers in the instantaneous market and longterm decisions invested in a new power plant. Also in this model, the market price is considered reliably effected by the decisions of the strategic companies. In this case, both the market price and the companies productions are variable, while investor in on-level models such as [1–3, 8, 9, 11–18] must have a prediction pattern of market price. in these models, Investment capacity for optimizing profit is affected this prediction pattern of price.

A number of models have been developed to address the generation expansion problem both before and after restructuring of the electricity market. However, many of these models are deficient in one way or another. For example, in many bi-level models such as [7, 10, 28-34] presented, the market price prediction model was used but the existence of a strategic company for the production development planning was not considered.

The market in [30, 31] was modeled using the conjecture price approach in the lower level of the problem while ref [29] used Cournot modeling approach their work. Although, the market price was considered a variable in the bi-level models presented for the production expansion planning problem in [9] and [13] strategic companies were not taken into account in the studies. In some other bi-level models such as [35–37] the supply function model was used to consider the strategic companies. However, these models include competition of only one strategic company with a set of non-strategic companies. Meanwhile, there is no competition among the strategic companies in the approach used in [35, 36], due to the static nature of planning. Its worth mentioning that one of the other important advantages of multi-level models is that the objectives that are in conflict with each other are observed in them. In [38], a three level model for generation expansion planning without considering the strategic companies is presented. Similarly, though competition among a set of strategic companies was considered for the generation expansion planning in [39, 40], certain important features such as dynamism, consideration for uncertainty and capacities of true investment are missing in these references.

Furthermore, the models proposed in [29, 36, 39, 41–48] did not take into account the dynamic nature of investment decisions. Similarly, uncertainty in the demand growth were not included in the models proposed in [36, 37, 44, 49] just as the investors in the models in [36, 39, 44, 50] have no choice of different technologies.

Interestingly, the present work tries to address most of the deficiencies highlighted above, to present a very accurate model. In this respect, it considers the dynamics of the investment decisions, just as it puts into account strategic GEN-COs. It also considers the problem as a three-level model consisting of the transmission network constraints. The uncertainty regarding demand growth is equally accounted for in this study. In addition, the model takes into account peak and base technologies in different capacities from which the user could select. In the proposed model, small and large private GENCOs compete with one another. Fig. 1 shows the effectiveness of investment and planning.

By way of summary, the contributions of this paper are listed below:

- The proposed model for the strategic GENCOs is dynamic in nature. To the best of the authors' knowledge, none of the equilibrium programming with equilibrium constraint (EPEC) models presented in the literature considered the dynamic nature of investment decisions. Thus, the multi-period stochastic three-level model consisting of transmission network constraints is presented here.
- Inclusion of uncertainty in the load demand in the dynamic competition of strategic GENCOS: Scenarios are used to describe the uncertainty pertaining to the demand growth modelled by the discrete Markov model because no anticipativity constraints are inherent in all multi stage stochastic optimisation problems;
- Consideration of investment decision variable as discrete variables in the three-level stochastic dynamic



Figure 1: Effectiveness of investment and planning

model for competition among the strategic GENCOS: Two scenarios (base and peak) in which each has different option for investment capacity are considered for each candidate.

• In this model, small and large strategic GENCOs compete with one another.

2. The proposed algorithm

The generation planning problem in this study is solved using the algorithm presented in Algorithm 1. It is desired to have the objective function established at the scheduled time. The following procedure is repeated for each scenario. At first, for each company participating in this competition, the investment is done with the aim of maximizing profits in the market. Non-anticipativity is considered at the output of the optimization offers in the market as well as investment for each company. New peak and base units added to the existing unit in the power network is considered as the existing units in the following year. At the lowest level, the social welfare is maximized for all time blocks in the horizon year.

For simplicity, time blocks and GENCOs count blocks are not shown in the pseudo code illustrated in Algorithm 1. r_n , w_n , t_n , and y_n are number of stages, scenarios, time block, and GENCOs respectively.

The variables in the first level represent the invested capacity of the strategic GENCOs and their associated operation costs (X_{yri} , $X_{yrr'i}^r$, u_{yrih} , $C_{yrr'i}^r$). Therefore, their values are known in the second and third levels and they modeled as known parameters. Again, only the variables related to the second level offers of the strategic GENCOs (O_{yrtiw}^S , $O_{yrr'tw'}^S$, O_{yrrtkw}^E) in the market for the sale of electricity produced by their existing and new units are characterized with the aim

Algorithm 1 THE ALGORITHM FOR SOLVING THE PRO-POSED IDEA

Requ	ire: growth demand uncertainty, network and GENCOs info
1:	while $r \leq rn do$
2:	max aim of first level
3:	if peak unit is invested then
4:	It added to the existing unit in network;
5:	$k \leftarrow k + 1$
6:	end if
7:	if base unit is invested then
8:	It added to existing unit in network;
9:	$k \leftarrow k + 1$
10:	end if
11:	enforcing dynamic decency for invested capacity
12:	Output: investment by GENCOs
13:	y←1
14:	while $S \leq y_n$ do
15:	max profit of company S in second level
16:	Output: offers by GENCOs;
17:	non-anticipativity checking of primary level variables;
18:	while $t \leq t_n$ do
19:	$W \leftarrow 1$
20:	while $w \leq w_n$ do
21:	max social welfare in third level
22:	Market clearing with DC power flow
23:	Output: generation, consumption and price
24:	non-anticipativity checking of tertiary level variables;
25:	$W \leftarrow w + 1$
26:	end while
27:	y←y+1
28:	end while
29:	$\mathbf{r} \leftarrow \mathbf{r} + 1$
30:	end while
31:	end while
32:	return production, consumption and market clearing price

of maximizing the profit of both strategic GENCOs as a constraint in the first level problem. Similarly, only the variables related to the second level problem are considered as the first level variables. The invested capacity by the GENCOs and their operation cost and offers of strategic GENCOs have a certain amount in the third level which are parameterized. Only the third-level variables are included in the variables of production, consumption, buses angles, and market clearing prices (P_{yrtiw}^{S} , P_{yrtkw}^{E} , P_{rtdw}^{d} , P_{yrrtiw}^{Sr} , θ_{rtnw} , λ_{rtnw}) which are determined with the aim of maximizing the social welfare as a constraint in the second level problem. Finally, only the variables related to the third level are accounted for as first and second level variables.

3. Uncertainty and non-anticipativity constraints in the dynamic problem

It should be noted that non-anticipativity constraints are inherent in all multi-stage stochastic optimisation problems [40]. If the realizations of stochastic processes are identical up to stage n, then the values of all decision variables for these scenarios need to be identical up to stage n. However, without the non-anticipativity constraints, values of decision variables for the scenarios may not be identical up to stage n [51]. Therefore, the provisions of non-anticipitivity used as scenarios are not independent of each other similar to the case of a 5-stage planning.

Figure 2 shows different states of a stochastic problem as used in this study. One way to solve the problem is to include the results of each year in the studies of the following year. This could be in form of quasi-dynamic planning [51]. It is apparent that the dynamic planning solution could be more optimal in comparison with the quasi-dynamic planning solution. If the scenarios considered in the model are independent and different from one another at all stages (nodevariable formulation), the provisions should not be applied to the programming (mode 1, Figure 2).

The multistage problem as scenario-variable formulation including dependent uncertainties has two modes when the uncertainties in the scenarios considered are similar in the process of multi-stage models. The constraints related to non-anticipativity should be applied to the model (mode 3, Figure 2). If the multistage stochastic problem is solved by an optimization algorithm such as heuristic algorithm, each iteration results in different optimal solutions. It should be noted that applying the non-anticipativity constraints to the program is optional, especially if it uses GAMS solvers like MILP, LP, NLP and EXT.

Because of the structure of the optimization problem, solutions obtained for each scenario is essentially the same in mode 2 of Figure 2. Therefore, applying the nonanticipativity conditions to the program increases the complexity of the model and calculations volume which does not necessarily lead to the optimal solution. For this reason, application of the non-anticipativity constraints is considered optional in this study since the uncertainties in the defined scenarios are similar in the process of multi-stage models since they use MILP GAMS solvers. Interestingly, the dynamic stochastic approach [52] is similar to case 1 of Figure 2 while the formulated model in [53] is similar to mode 3 of Figure 2 of the work presented in this paper.

After the simulation, this subject must be checked to ensure the accuracy of the obtained optimal results. In this model, the second and third level variables must be checked to ensure the accuracy of non-anticipativity constraints. The variables of the first level which correspond to the installed generation capacity of the investing agent will not be stochastic in nature. The reason for this is that a generation company can only make one investment decision at a time as it is impossible to know which scenario is going to occur in reality. Thus, the non-anticipativity subject is not considered in the first level variables.

In this paper, the uncertainty in load demand is modelled by using the Markov chains with the demand growth is assumed to be 10% and 8% with the probabilities of 60% and 40%, respectively, in any scenario for each year. Figurer. 2 shows the Markov chain for the uncertainty in the demand growth. The generation expansion planning includes 16 scenarios for five years according to the scenarios taken into account for each year. Therefore, the subject of nonanticipativity conditions must be checked in these assumed scenarios as follows. The variables introduced are the same in all the scenarios for the first year. In the second year, however, only variables in scenarios 1 to 8 and that of 9 to 16 remains the same. In the third year the variables for scenarios 1 to 4, 5 to 8, 9 to 12 and 13 to 16 are similar while in the fourth year the variables are the same for scenario 1 with 2, 3



Figure 2: Different states considering non-anticipativity in the multi-stage stochastic problem



First stage Second stage Third stage Fourth stage Fifth stage

Figure 3: Scenario and non-anticipativity in the proposed model

with 4, 5 with 6, 7 with 8, 9 with 10, 11 with 12, 13 with 14 and 15 with 16. However, these variables are not the same in the last year.

4. Mathematical formulation

The proposed idea presented in form of a three-level model comprises a first level, i.e. Eqs. (15)-(22), a second level, i.e. Eqs. (23)-(26), and a collection of third level problems, i.e. Eqs. (1)-(14). The first level is related to the competitive environment in which the GENCOs participate in, while the second and third levels are related to the model of each strategic company in the power market.

Third level problem: The third-level problem represents the market clearing. The clearing of the market for any given operating condition is represented as an optimization problem that identifies the operating decisions that maximize social welfare. The market clearing problem is constrained by DC power flow equations, transmission network limitations, upper and lower bound for production and consumption as well as non-anticipativity constraint related to the lowest level variables. The outputs of the lower level problem is nodal prices (dual variables associated to the power balance constraints), which are fed back to the medium level.

Third-level objective function:

$$\min \sum_{y} \sum_{i} O_{yrtiw}^{S} P_{yrtiw}^{S} + \sum_{y} \sum_{k} O_{yrtiw}^{E} P_{yrtkw}^{E} + \sum_{r'} \sum_{y} \sum_{i} O_{yrr'tiw}^{S} P_{yrtiw}^{F}$$
(1)

The market clearing problems are represented by the negative social welfare (i.e. Eq. (1)) and Eqs.(2)-(14). Note that dual variables associated with the third-problems are indicated at their corresponding constraints following a colon.

Third-level constraints constraints fond thing a coroling $\sum_{d}^{D} P_{rtdw}^{D} + \sum_{m \in \phi \phi_{n}} B_{nm}(\theta_{rtnw} - \theta_{rtmw}) - \sum_{y} \sum_{i} P_{yrtiw}^{S} - \sum_{y} \sum_{r'} -\sum_{y} \sum_{k} P_{yrtkw}^{E} = 0 : \lambda_{rtnw} \quad \forall n, \forall t, \forall r, \forall w$ (2)

Eq. (2) represents the energy balance at each bus, being the associated dual variables, LMPs (λ_{rtw}) or nodal prices.

 $0 \leqslant \mathsf{P}_{yrtiw}^{S} \leqslant X_{yri} : \overline{\mu}_{yrtiw}^{S}, \underline{\mu}_{yrtiw}^{S} \; \forall y, \forall i, \forall t, \forall r, \forall w \quad (3)$

$$0 \leqslant \mathsf{P}_{yrritw}^{Sr} \leqslant X_{yrri}^{r} : \overline{\mu}_{yrtiw}^{Sr}, \underline{\mu}_{yrtiw}^{Sr} \quad \forall y, \forall r, \forall r' \subset \{X_{rs} > 0, r > (4)$$

$$0 \leqslant \mathsf{P}_{\text{yrtkw}}^{\mathsf{E}} \leqslant \overline{\mathsf{P}}_{yk}^{\mathsf{E}} : \overline{\mu}_{\text{yrtkw}}^{\mathsf{E}}, \underline{\mu}_{\text{yrtkw}}^{\mathsf{E}} \; \forall y, \forall k, \forall t, \forall r, \forall w \quad (5)$$

$$0 \leqslant P_{\text{rtdw}}^{D} \leqslant Q_{wr}\overline{P}_{td}^{D} : \overline{\mu}_{rtdw}^{D}, \underline{\mu}_{rtdw}^{D} \quad \forall d, \forall t, \forall r, \forall w \quad (6)$$

$$\pi \leqslant \theta_{\text{rtnw}} \leqslant \pi : \underline{\zeta}_{\text{rtnw}}, \overline{\zeta}_{\text{rtnw}} \quad \forall n, \forall t, \forall r, \forall w$$
(8)

The third-level variable bounds are given for unit generation, demand consumption, power flow and angle bounds in Eqs. (4)-(9). Eqs. (3)-(5) are associated with limits for the generated power of new units in installed year, the power produced by new unit in the next years after installed year, and the generated power of existing units for strategic producers, respectively. In this work, demands are considered to be elastic. Eq. (6) is relevant to elastic demands. The power flow through transmission lines using a lossless DC mode limits for power and buses' voltage angles are represented in Eqs. (7)-(8), respectively.

$$\theta_{\rm rtnw} = 0: \zeta_{\rm t}^1 \ n = 1, \forall t, \forall r, \forall w$$
(9)

Eq. (9) fixes the voltage angle at the reference bus.

$$P_{\text{yrtiw}}^{S} = P_{\text{yrtiw}}^{S} : \mu_{\text{yrtiw}}^{S} \quad \forall y, \forall r, \forall w, \forall w' \in \{Q_{\text{wr}} = Q_{w'r}\}, \forall t, \forall i$$
(10)

$$P_{yrtkw}^{E} = P_{yrtkw}^{E} : \mu_{yrtkw}^{E} \quad \forall y, \forall r, \forall w, \forall w' \subset \{Q_{wr} = Q_{w'r}\}, \forall t, \forall k$$
(11)

$$P_{yrr'tiw}^{Sr} = P_{yrr'tiw'}^{Sr} : \mu_{yrr'tiw'}^{Sr}, \forall y, \forall r, \forall w, \forall w' \in \{Q_{wr} = Q_{w'r}\}, \forall t,$$
(12)

$$P_{\text{rtdw}}^{\text{D}} = P_{\text{rtdw'}}^{\text{D}} : \mu_{\text{rtdw}}^{\text{D}} \quad \forall r, \forall w, \forall w' \in \{Q_{\text{wr}} = Q_{w'r}\}, \forall t, \forall d$$
(13)

$$\theta_{\text{rtnw}} = P_{\text{rtnw'}} : \zeta_{\text{rtnw'}} \ \forall \mathbf{r}, \forall w, \forall w' \in \{Q_{wr} = Q_{w'r}\}, \forall t, \forall n$$
(14)

The non-anticipativity equation related to the third-level variables are represented in Eqs. (10)-(14).

Second-level problem: The problem solved by each strategic GENCO to determine its best offering decisions is formulated as a bi-level model that is organized as a third and second levels in the proposed three-level model. The

^{S Second} Hatel Represents the vinvestment problem of a dominant GENCO S who is seeking to maximize the present value of the total investment profit.

The dynamic dependency constraints exist in the second level as a result of the dynamic nature of the planning of the problem. The second-level constraints include investment budget limit and non-anticipativity related to the company's offer which must be positive.

$$\sum_{i} \frac{\text{Specond-level objective function}}{\min \sum_{i} (\frac{1}{1+f})^{r} \sum_{i} K_{yri} X_{yri} - \sum_{w} \sum_{r} W_{wr} (\frac{1}{1+f})^{r} \sum_{t} \sigma_{rt} [\sum_{i} P_{yrtiw}^{S} (\lambda_{rtn} (\sum_{i \in n} w - C_{yrr'i}^{r}) + \sum_{k} P_{yrtkw}^{E} (\lambda_{rtn(k \in n)w} - C_{k}^{E})]$$

$$(15)$$

Eq. (15) is the negative profit (investment cost minus expected profit) in the planning horizon, which comprises two terms. The first term of Eq. (15) is associated to the investment cost of new thermal units including peak and base technologies, whereas the second term is the expected profit obtained by selling energy in the spot market.

Second-level constraints:

$$\sum_{r} (\frac{1}{1+f})^{r} \sum_{i} K_{yri} X_{yri} \leqslant \overline{K}_{y} : \Delta_{y} \quad \forall y$$
 (16)

✓w The available budget limitation is represented by Eq. (16) for investment in the new base or peak unit which reflects the limited financial resources available to the market for each GENCO.

$$O_{\text{vrtiw}}^{S} \ge 0: \underline{\zeta}_{\text{rvtiw}}^{s} \quad \forall y, \forall r, \forall t, \forall i, \forall w$$
(17)

$$O_{\text{yrtkw}}^{\text{E}} \ge 0 : \underline{\zeta}_{\text{rvtkw}}^{\text{E}} \quad \forall y, \forall r, \forall t, \forall k, \forall w$$
(18)

$$O_{\rm yrr'tiw} \ge 0 : \underline{\mu}_{\rm rr'ytiw}^{\rm Sr}$$
 (19)

Eqs. (17)-(19) mean that the GENCO's offer is positive so that Eq. (19) is related to the strategic offer of the new units in the following years.

$$\begin{split} O_{yrtiw}^{S} &= O_{yrtiw'}^{S} : \mu_{rytiw}^{S} \quad \forall y, \forall r, \forall w, \forall w' \in \{Q_{wr} = Q_{w'r}\}, \forall t, \forall i \\ & (20) \\ O_{yrtkw}^{E} &= O_{yrtkw'}^{E} : \mu_{rytiw}^{E} \quad \forall y, \forall r, \forall w, \forall w' \in \{Q_{wr} = Q_{w'r}\}, \forall t, \forall k \\ & (21) \\ O_{yrr'tiw}^{Sr} &= O_{yrr'tiw'}^{Sr} : \mu_{yrr'tiw}^{Sr} \quad \forall y, \forall r, \forall w, \forall w' \in \{Q_{wr} = Q_{w'r}\}, \forall r', \forall t, \forall (22) \\ \end{split}$$

The non-anticipativity equations related to GENCO offer are represented in Eq. (20)-(22).

First-level problem: The objective function in the first level is minimization of the present value minus the expected ∀iprofit (investment cost minus expected profit) of all strategic GENCOs in the planning horizon. The first level constraints include bounds on investment, dynamic dependency constraints related to the company investment and dynamic dependency constraints related to the marginal cost of newly added units.

First-level objective function:

$$\min \sum_{y} \sum_{r} (\frac{1}{1+f})^{r} \sum_{i} K_{yri} X_{yri} - \sum_{w} \sum_{r} W_{wr} (\frac{1}{1+f})^{r} \sum_{t} \sigma_{rt} [\sum_{i} P_{yrt}^{S} + \sum_{i} \sum_{r'} P_{yrr'tiw}^{Sr} (\lambda_{rtn(i \in n)w} - C_{yrr'i}^{r}) + \sum_{k} P_{yrtkw}^{E} (\lambda_{rtn(k \in n)w} - C_{k}^{E})]$$

$$(23)$$



Figure 4: Converting the three-level problem into a one-level problem considering uncertainty

Eq. (23) is the present value of the expected profit of all GENCOs in the planning horizon. The profit of all producers is the summation of profit for all producers.

It has to be noted that $i \in n$ means the new power plant i is installed at bus n.

First-level constraints:

$$X_{yri} = \sum_{h} u_{yrih} \cdot X_{ih} \quad \forall i, \forall r, \forall y \quad \sum_{h} u_{yrih} = 1, u_{yrih} \in \{0, 1\}, \forall i, \forall i \in \{0, 1\}, \forall i, \forall i, \forall j \in \{0, 1\}, \forall i, \forall j \in \{0, 1\}, \forall i, \forall j \in \{0, 1\}, \forall j \in \{0, 1\}, \forall j \in \{1, 2\}, \forall j \in \{1, 2\}$$

It states that investment options for new thermal units are only available in discrete blocks.

$$X^{r}_{yrr'i} = X_{yri} \ \forall r, r' \subset \{X_{r'i} > 0, r > r'\}, \ \forall i, \forall y \qquad (25)$$

The dynamic dependency constraints on the base and peak investment decision variables are represented in Eq. (25). The new units are operated in the coming years as existing units in the network.

$$C^{r}_{yrri} = C_{i} \quad \forall r, r' \subset \{X_{ri} > 0, r > r'\}, \quad \forall i, \forall y$$
 (26)

Similarly, the dynamic dependency constraints on decision variables of the marginal cost of new units are presented in Eq. (26).

5. Converting the three-level to one-level problem

The market and the proposed algorithm are expressed using a multi-level model to implement the proposed idea in this article. GAMS solvers are used to solve the model proposed in the paper. For this purpose, the multi-level model is converted to a one-level problem and then the optimal solution is obtained using the available solvers as shown in Figure 4.

The constraints of the first level of this three-level model include the candidate capacities for investment and the model for the presence of each strategic company in the market. Each strategic company is considered as a bi-level model including second and third level whose aims at second and third levels are to maximize the company's profit as well as maximize social welfare. At first, the bi-level model of each company is converted to a one-level model to solve. Then, the bi-level model created in the next step (the objective function of the three-level model with candidate capacities constraints as a part of the first level constraint and the model of one level of each strategic company) must be converted to a one level model. In the next step, the mathematical model becomes one MILP problem after linearisation. This final problem can be solved by with the available solver.

To convert the bi-level model of each company to a onelevel model, both the KKT conditions and the Primal-dual transformation could be used. The bi-level model of each strategic company becomes a one level model mixed-integer LP due to the complementary nature of the constraints. When KKT conditions are used, lower level problem of the achieved bi-level model is non-convex because generating of the binary variables from enforcing the KKT conditions on the third level. Therefore the final bi-level model cannot be converted to a one-level. Thus, in this stage, the Primal-dual transformation is used to convert the bi-level model of each strategic company i.e. second and third levels to one levelmodel from which blocks 8, 3 and 4 are obtained (refer to part 1 in the appendix).

In the next step, we are again faced with the problem of bilevel that must be converted to the one-level problem using one of two mentioned methods such that in this stage, block ^T, ^T is considered as first level constraint and blocks 4, 3, 8 and 5 considered the second-level constraints (refer to part 2 in the appendix). In this study, the KKT condition is enforced, so the second-level problem includes blocks 8, 3 and 4 as the second-level problem constraints obtained. The reason for this is that the converted problem comes in the form of MILP resulting in blocks 6, 7 and 9 (refer to part 3 in the appendix). Block 9 itself includes blocks 3, 4, 5 and 8. Note that the strong duality equality of the primal-dual transformation is a non-linear expression.

The obtained one-level model has non-linear phrases. These non-linear phrases must be linearised and replaced with equivalent linear relationship. Therefore, in the last step, the strong duality equality of Primal-dual transformation achieved in the previous steps is replaced with its equivalent KKT condition resulting in the transformation of block 10 to 2 (refer to part 4 in the appendix). These equivalent KKT conditions are in form of MILP.

Note that in the previous section, the candidate capacities for investment was modelled as a continuous variable in each strategic company. On the other hand, investors select various generation technologies with a certain capacity. Therefore, it is logical that these variables are considered discrete. It should also be noted that the one-level model of each company must be convex to be used in the next step. The one level model of each company is not convex if the model has the integer variables.

Therefore, the variables of company investment cannot be assumed as a discrete variable in the model of each strategic company. Thus, in this paper, the variables are considered to be continuous in the model of each strategic company. Therefore, the capacity limitation is applied in higher level constraints. This means that the selected investment capacity should be from among the specified candidates. Finally, the problem with the first level objective function and the equivalent constraints of three level problem is transformed to one level, which includes blocks 1 to 8. Explaining in detail about this subject is addressed in [37].

6. CASE STUDY: MREC NETWORK

In this section, the efficiency of the proposed framework is examined through a case study. To validate the proposed model, it is implemented on a 2-bus network from [39]. In this case, planning included in the competition of three strategic GENCOS with one another at stage one (static planning) without uncertainty. The network data of the case study system is extracted from [37]. The data of the existing generation units for all strategic GENCOs are considered in Table 1. The second column provides the capacity of each unit, which comprises two generation blocks (columns 3-4), with their corresponding production costs (columns 5-6).

In a three-level competition, it is assumed that the strategic GENCOS 1,2 and 3 participate in the market. Table 1 shows the results of generation expansion planning for the three-level competition for both static and stochastic dynamic as well as for 5-level competition for different cases. The second column of Table 3 is related to the planning stage while the third column illustrates the total installed capacity having the base technology in the parenthesis. Note that both nodes N1 and N2 are candidates to locate new units. The next two columns provide the Total profit (M \in) and Social welfare (M \in) during the planning period. The CPU time for each case is shown in the last column.

The case study is the MAZANDARAN regional electric company (MREC) transmission network- a part of the IRAN interconnected power system. The single-line diagram of MREC transmission network is shown in Figure 5 while the load demand information could be found in [37]. The annual growth of the demand for the first year is assumed 6.2% while subsequent years are treated based on the explanation related to Figure 3. The price bids of the demands are 35.75, 28.721, and $27.357 (\in /MWh)$ for peak, shoulder, and offpeak blocks, respectively.

To ease computational burden, those transmission lines that operate at 230kV with respect to their capacities are not explicitly modeled. Thus, the 230kV network is considered as a bus. In this case study, two strategic GENCOs (i.e., Producers 1 and 2) are considered, meaning that, the competition between the players is duopoly. It should be noted that the generation units NEKA and ALIABAD are owned by two different Producers, 1 and 2, respectively. The candidate buses for construction of available investment budget is assumed $75M \in$ over the planning period for each GENCO.

The total capacity of the existing units is 3155MW, of which 69.57% of it (i.e., 2195MW) belongs to Producer 1, connected to buses NEKA4 and NEKA2, as indicated in Figure 5, and the remaining capacity to Producer 2. The operation

Table 3: Information relating to the candidate units for investment

Candidate	Annualized capital (K_{yri})	X _{ih} (MW)	C_i^S / C_k^{ES} Productio
unit	cost (€/MW)		cost (€/MWh)
Base technology	30000	0-500-750-1000	10
Peak technology	6000	0-200-300-400-500	14
		600-700-800-900-1000	

costs of the existing units are presented in Figure 5. Types and data for investment options are given in Table 3. Here, only one generation block is assumed for the new units. The results of the simulations are illustrated in Figure 6.

Shown in the figure are the results of generation expansion planning for the duopoly competition. It can be seen that the investment share of GENCO 1 is 300MW, which takes five years to build up at NEKA. On the other hand, GENCO 2's investment share totals 1800MW, which means there is a build-up of 1100MW on the 230kV network while the rest power is contributed by ALIABAD. The price for all years is the same and equal to $33.55 \in /MWh$. The social welfare is $2157M \in$ and it is planned to increase on yearly basis above the previous year. While the profit made by strategic GENCO 1 decreases over time, the one of strategic GENCO 2 increases. The share of the two GENCOs in the total profit is 44.04% and 55.98% for strategic GENCO 1 and 2, respectively from a total profit of $2054M \in .$

Existing	Capacity	Capacity	Capacity	Production	Production	
unit	(MW)	of block 1	of block 2	cost of	cost of	
		(MW)	(MW)	block 1	block 2	
				(€/MWh)	(€/MWh)	
GENCO 1	60	30	30	12	14	
GENCO 2	60	30	30	12	14	
GENCO 3	120	60	60	13	15	
GENCO 4	50	25	25	18.6	20.03	
GENCO 5	76	30	46	11.46	11.96	

Table 1: Units data for the two-bus test network

Table 2: The results of generation expansion planning for a three-level competition

Case	Stage	Total capacity added (base) MW-Location [by]	Total profit (M€)	Social welfare (M€)	CPU time (S)
Static: Tri-level competition [34]	Horizon stage	200(180)-N1 [GENCO 1:180- GENCO 3:20)	12.34	19.61	33.821
	1	300(0)- N1[GENCO 1]	9.43	22.22	
Stochastic dynamic	2	0	10.64	28.29	451.051
: Tri-level competition	3	0	10.71	28.8	1
	4	0	10.69	29.1	1
	5 (horizon stage)	200(0)- N2[GENCO 2]	10.68	29.4	
	1	300(0)- N1[GENCO 3]	17.93	16.85	
Stochastic dynamic	2	0	19.54	39.98	634.128
: 5-level competition	3	500(500)- N1[GENCO 5]	15.45	27.64	
	4	0	30.24	54.8	1
	5 (horizon stage)	0	30.22	54.6]







Figure 6: Generation expansion planning in a duopoly competition



Figure 7: Energy production of the strategic GENCOs in the planning period

Figure 7 shows the production of strategic GENCOs 1 and 2 in the planning period. It can be seen that the production share of strategic GENCO 1 is 59.39% of the total energy while the production share of the strategic GENCO 2 is 40.61%.

7. CONCLUSION

A new three-level dynamic framework programming has been presented to study the generation capacity expansion in a restructured power system under uncertainty. This paper provided a methodology to characterize the interactions among strategic GENCOs and to find generation investment equilibria in a network-constrained electricity pool.

To numerically validate the proposed methodology, the MAZANDARAN regional electric company's (MREC) transmission network- a subset of the IRAN interconnected power system is adopted. The results obtained showed that while strategic GENCO 1 had its profit decreasing, strategic GENCO 2 experienced an increase in profit over time. However, the impact of investment incentives could be included in the proposed model as future work. This could be expanded to consider the impacts of transmission expansion plans, availability of gas transmission network and tax policy.

8. Acknowledgements

The authors acknowledge the useful discussion on this matter with Prof. Jovica Milanovic. This work was partly founded by European Union's Horizon 2020 research and innovation programme (NobelGrid project) under the grant agreement N: 646184.

Appendix:

9. Part 1: Enforcing primal-dual transformation to third level

TransactiveAs stated so far the model of each strategic company includes Eqs. (1) to (22). The third level problem (Eqs. (1)-(14)) is convex because of linearity. As a result of transforming the third optimization problem to equivalent constraints we can use both primal-dual transformation and KKT conditions. Because the complimentary constraints obtained from KKT conditions are mixed integer, the obtained constraints, in this stage primal-dual transformation is used. The constraints equivalent to the third level optimization level problem includes primal constraints, dual constraints and the strong duality equality.

9.1. TransactiveDual constraints (block 3 in Figure 4)

 $\mbox{TransactiveL}_{y}$ is the Lagrangian function of third level problem.

TransactiveSome of the equations in using KKT method are obtained from the derivative of Lagrange expression relative to decision variables of which the equations are equivalent to the set of dual constraints of primal-dual transformation.

$$\frac{\partial l_{y}}{\partial P_{yritw}^{S}} = O_{yritw}^{S} - \lambda_{yritw} + \overline{\mu}_{yritw}^{S} - \underline{\mu}_{yritw}^{S} - \mu_{yritw}^{Sr} + \sum_{w'(w,w' \in \{Q_{wr} = Q_{w'r}\})} \mu_{yritw}^{S}$$
$$\frac{\partial l_{y}}{\partial p_{ritw}^{E}} = O_{rtiw}^{E} - \lambda_{rtnw} + \overline{\mu}_{vrtkw}^{E} - \mu_{vrtkw}^{E} - \mu_{vrtkw}^{E} + \sum_{w'(w,w' \in \{Q_{wr} = Q_{w'r}\})} \mu_{yrtkw}^{S}$$

$$\frac{\partial P_{yrtkw}^{E}}{\partial P_{yrtkw}^{E}} = O_{rtiw}^{E} - \lambda_{rtnw} + \mu_{yrtkw}^{E} - \mu_{yrtkw}^{E} - \mu_{yrtkw}^{E} + \sum_{w'(w,w' \in \{Q_{wr} = Q_{w'r}\})} (28)$$

$$\frac{\partial l_{y}}{\partial \mathsf{P}_{rtdw}^{\mathrm{D}}} = -\mathsf{U}_{td}^{\mathrm{D}} + \lambda_{rtnw} + \overline{\mu}_{rtdw}^{\mathrm{D}} - \underline{\mu}_{rtdw}^{\mathrm{D}} - \mu_{rtdw}^{\mathrm{D}} + \sum_{w'(w,w' \subset \{Q_{w\tau} = Q_{w'\tau}\})} \mu_{yr}^{\mathrm{D}}$$
(29)

$$\begin{aligned} \frac{\partial \iota_{y}}{\partial P_{yrritw}^{Sr}} &= O_{yrritw}^{Sr} - \lambda_{rtnw} + \overline{\mu}_{yrtiw}^{Sr} - \underline{\mu}_{yrritw}^{Sr} - \mu_{yrritw}^{Sr} \\ + \sum_{w'(w,w' \subset \{Q_{wr} = Q_{w'r}\})} \mu_{yrritw}^{Sr} = 0 : \rho_{yrritw}^{Sr} \quad \forall y, \forall r, \forall r' \subset \{X_{r's} > 0, \forall r' \in \{X_{r's} > 0\} \end{aligned}$$

$$(30)$$

$$\begin{split} \frac{\partial l_{y}}{\partial \theta_{rtnw}} &= \sum_{m} B_{nm} (\lambda_{rtnw} - \lambda_{rtmw}) + \sum_{m} B_{nm} (\overline{V}_{rtnmw} - \overline{V}_{rtnmw}) \\ &+ \sum_{m} B_{nm} (\underline{V}_{rtnmw} - \underline{V}_{rtnmw}) + \overline{\zeta}_{rtnw} - \underline{\zeta}_{rtnw} - \zeta_{rtnw} \\ &\sum_{w'(w,w' \subset \{Q_{wr} = Q_{w'r}\})} \zeta_{rtnw'} + (\zeta_{rtw}^{1})|_{n=1} = 0 : \rho_{rtnw}^{\theta} \quad \forall r, \forall t, \forall n, \forall w \end{split}$$

$$(31)$$

9.2. TransactiveThe strong duality equality (block 8 in Figure 4)

TransactiveStrong dual theory relation is as follows:

~ 1

$$\begin{split} &\sum_{y} \sum_{i} O_{ytriw}^{s} P_{yrtiw}^{s} + \sum_{y} \sum_{k} O_{ytriw}^{E} P_{yrtkw}^{E} + \sum_{r'} \sum_{y} \sum_{i} O_{yrr'tiw}^{S} P_{yrr'ti}^{S} \\ &+ \sum_{y} \sum_{i} X_{yri} \overline{\mu}_{yrtiw}^{S} + \sum_{y} \sum_{i} \sum_{r'} X_{yrr'i}^{r} \overline{\mu}_{yrtiw}^{Sr} + \sum_{y} \sum_{k} \overline{P}_{yk}^{E} \overline{\mu}_{yrtkw}^{E} + \sum_{y} \sum_{n} \overline{P}_{nm}^{E} \overline{P}_{nm} (\underline{V}_{rtnmw} + \overline{V}_{rtnmw}) + \sum_{n} \pi(\underline{\zeta}_{rtnw} + \overline{\zeta}_{rtnw}) = 0 : \varphi_{rtw}^{SD} \end{split}$$

$$(32)$$

9.3. Primal constraints (block 4 in Figure 4)

TransactivePrimal constraints use primal-dual transformation including Eqs. (33) to (45). These equations are the same as third level constraints equations with new duals variable for using in the next stage (where KKT conditions are again applied to these constraints). The dual constraints of each constraint has been written in front of it.

$$\sum_{d} P_{\text{rtdw}}^{D} + \sum_{m \in \psi \Phi_{n}} B_{nm}(\theta_{\text{rtnw}} - \theta_{\text{rtmw}}) - \sum_{y} \sum_{i} P_{y\text{rtiw}}^{3} - \sum_{i} P_{y\text{rtiw}}$$

$$0 \leqslant \mathsf{P}_{\text{yrtiw}}^{S} \leqslant X_{\text{yri}} : \underline{\mu}_{\text{yrtiw}}^{\prime S}, \overline{\mu}_{\text{yrtiw}}^{\prime S}, \forall y, \forall i, \forall t, \forall r, \forall w$$
(34)

$$0 \leqslant \mathsf{P}_{\text{yrr'tiw}}^{Sr} \leqslant X_{\text{yrr'i}}^{r} : \underline{\mu}_{\text{yrtiw}}^{\prime Sr}, \overline{\mu}_{\text{yrtiw}}^{\prime Sr}, \forall y, \forall r, \forall r' \subset \{X_{r's} > 0, r > r'\}, \forall t, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r' \in \{X_{$$

$$0 \leqslant \mathsf{P}_{\text{yrtkw}}^{\mathsf{E}} \leqslant \overline{\mathsf{P}}_{yk}^{\mathsf{E}} : \underline{\mu}_{\text{yrtkw}}^{\prime\mathsf{E}}, \overline{\mu}_{\text{yrtkw}}^{\prime\mathsf{E}} \; \forall y, \forall k, \forall t, \forall r, \forall w \quad (36)$$

$$0 \leqslant \mathsf{P}_{\mathrm{rtdw}}^{\mathrm{D}} \leqslant \mathsf{Q}_{\mathrm{wr}} \overline{\mathsf{P}}_{\mathrm{td}}^{\mathrm{D}} : \underline{\mu}_{\mathrm{rtdw}}^{\prime \mathrm{D}}, \overline{\mu}_{\mathrm{rtdw}}^{\prime \mathrm{D}} \; \forall \mathrm{d}, \forall \mathrm{t}, \forall \mathrm{r}, \forall w \qquad (37)$$

$$-\pi \leqslant \theta_{\text{rtnw}} \leqslant \pi : \underline{\zeta}_{\text{rtnw}}', \overline{\zeta}_{\text{rtnw}}', \forall n, \forall t, \forall r, \forall w$$
(39)

$$\Theta_{\text{rtnw}} = 0: \zeta'_{\text{t}} \quad n = 1, \forall t, \forall r, \forall w$$
(40)

 $\mathsf{P}^{\mathsf{S}}_{\mathsf{vrtiw}} = \mathsf{P}^{\mathsf{S}}_{\mathsf{vrtiw}} : \mu_{\mathsf{vrtiw}}'^{\mathsf{S}} \; \forall \mathsf{y}, \forall \mathsf{r}, \forall \mathsf{w}, \forall \mathsf{w}' \subset \{\mathsf{Q}_{\mathsf{wr}} = \mathsf{Q}_{\mathsf{w}'\mathsf{r}}\}, \forall \mathsf{t}, \forall \mathsf{t}, \forall \mathsf{t}, \forall \mathsf{w}' \in \{\mathsf{Q}_{\mathsf{wr}} = \mathsf{Q}_{\mathsf{w}'\mathsf{r}}\}, \forall \mathsf{w}, \forall \mathsf{w}' \in \{\mathsf{Q}_{\mathsf{wr}} = \mathsf{Q}_{\mathsf{w}'\mathsf{r}}\}, \forall \mathsf{w}, \forall \mathsf{w}' \in \{\mathsf{Q}_{\mathsf{wr}} = \mathsf{Q}_{\mathsf{w}'\mathsf{r}}\}, \forall \mathsf{w}, \forall \mathsf{w}' \in \{\mathsf{w}, \mathsf{w}, \mathsf{w}' \in \mathsf{w}, \mathsf{w}, \mathsf{w}' \in \mathsf{w}, \mathsf{w}, \mathsf{w}' \in \mathsf{w}, \mathsf{w}, \mathsf{w}' \in \mathsf{w}, \mathsf{w}' \in \mathsf{w}, \mathsf{w}' \in \mathsf{w}, \mathsf{w}' \in \mathsf{w}$ (41)

$$\mathsf{P}_{\text{yrtkw}}^{\mathsf{E}} = \mathsf{P}_{\text{yrtkw}}^{\mathsf{E}} : \boldsymbol{\mu}_{\text{yrtkw}}^{\prime \mathsf{E}} \; \forall \boldsymbol{y}, \forall \boldsymbol{r}, \forall \boldsymbol{w}, \forall \boldsymbol{w}^{\prime} \subset \{\boldsymbol{Q}_{\boldsymbol{w}\boldsymbol{r}} = \boldsymbol{Q}_{\boldsymbol{w}^{\prime}\boldsymbol{r}}\}, \forall \boldsymbol{t},$$
(42)

$$P_{yrr'tkw}^{Sr} = P_{yrr'tkw} : \mu_{yrr'tiw}^{\prime Sr} \quad \forall y, \forall r, w, w' \in \{Q_{wr} = Q_{wr}\}, \forall t, \forall i$$
(43)
$$P_{yrr'tkw}^{D} = P_{yrr'tkw} : \langle P_{wr}, \psi \rangle = \langle Q_{wr}, \psi \rangle =$$

$$\begin{aligned} \mathsf{P}_{\mathsf{rtdw}}^{\mathsf{r}} &= \mathsf{P}_{\mathsf{rtdw}}^{\mathsf{r}} : \mu_{\mathsf{rtdw}}^{\mathsf{r}} \; \forall \mathsf{r}, \forall w, w' \subset \{\mathsf{Q}_{\mathsf{wr}} = \mathsf{Q}_{\mathsf{w'r}}\}, \forall \mathsf{t}, \forall \mathsf{d} \\ \end{aligned}$$

$$\begin{aligned} \theta_{\mathsf{rtnw}} &= \theta_{\mathsf{rtnw}}^{\mathsf{r}} : \zeta_{\mathsf{rtnw}}' \; \forall \mathsf{r}, \forall w, w' \subset \{\mathsf{Q}_{\mathsf{wr}} = \mathsf{Q}_{\mathsf{w'r}}\}, \forall \mathsf{t}, \forall \mathsf{n} \end{aligned}$$

$$\theta_{\text{rtnw}} = \theta_{\text{rtnw}} : \zeta_{\text{rtnw}} \quad \forall r, \forall w, w \in \{Q_{wr} = Q_{wr}\}, \forall t, \forall n$$
(45)

Meanwhile, it must be noted that at this stage that the dual variables of inequality constraints have positive values:

$$\underline{\mu}_{yrtiw}^{S} \ge 0 : \overline{\mu}_{yrtiw}^{S} \ge 0 : \underline{\eta}_{rytiw}^{S}, \overline{\eta}_{rytiw}^{S} \quad \forall y, \forall i, \forall t, \forall r, \forall w$$
(46)

$$\underline{\mu}_{yrr'tiw}^{Sr} \ge 0 : \overline{\mu}_{yrr'tiw}^{Sr} \ge 0 : \underline{\eta}_{rr'ytiw}^{Sr}, \overline{\eta}_{rr'ytiw}^{Sr} \quad \forall y, \forall i, \forall t, \forall r, r' \subset \{X_{r's} > (47) \\ \underline{\mu}_{yrtkw}^{E} \ge 0; \overline{\mu}_{yrtkw}^{E} \ge 0 : \underline{\eta}_{rytkw}^{E}, \overline{\eta}_{rytkw}^{E} \quad \forall y, \forall k, \forall t, \forall r, \forall w$$

$$(48)$$

$$\underline{\mu}_{rtdw}^{D} \ge 0; \overline{\mu}_{rtdw}^{D} \ge 0: \underline{\eta}_{rtdw}^{D}, \overline{\eta}_{rtdw}^{D}, \forall d, \forall t, \forall r, \forall w$$
(49)

$$\underline{V}_{rtnmw} \ge 0; \overline{V}_{rtnmw} \ge 0: \underline{\eta}_{rtnmw}^{V}, \overline{\eta}_{rtnmw}^{V} \quad \forall r, \forall t, \forall n, \forall m, \forall w$$
(50)

$$\underline{\eta}_{rtnw} \ge 0; \overline{\eta}_{rtnw} \ge 0: \underline{\mu}_{rytnw}^{\eta}, \overline{\mu}_{rytnw}^{\eta} \quad \forall r, \forall t, \forall n, \forall w$$
(51)

10. Dant 2: Romverting third and second level to Equivalent MPEC

 $Q_{wr}\overline{P}_{rd}^{D}\overline{\mu}_{rdw}^{D}$ At this stage, a two-level problem exists such that the first level objective function includes Eq. (23) while first level constraints include Eqs. (24) to (26). Now the third level and second level problem have been merged with a problem as second level problem and have formed MPEC. Second level problem objective function includes Eq. (15) and second level problem constraints include Eqs. (16)-(22) and Eqs. (27)-(52) which include blocks 3, 4, 5 and 8 in Figure 4.

Second-level objective function:

Second-level new constraints

$$P_{\text{First}}^{\text{Sr.}} - \sum_{y \in \mathcal{E}} \frac{Eqs.}{27} (27) - (52), Eqs. (16) - (22)$$
(53)
First level objective function:

$$F_{q_{1}}(23)$$
 (54)

First-level constraints:

Eqs.
$$(24) - (26)$$
 (55)

′r,∀w Part 3: Enforcing Karush-Kuhn-Tucker (KKT) conditions to MPEC (equivalent problem of second and third levels)

Due to the non-linearity of MPEC at this stage, we cannot use primal-dual transformation but to use two level problem r, KKT conditions to transform Eqs. (52)-(55). Such that KKT conditions are applied to Eqs. (52)-(53). KKT conditions include three groups of primal equality constraints, equality constraints obtained from differentiating the corresponding Langrangian and complimentary constraints obtained from inequality constraints.

∀k 11.1. Primal equality Constraints (blocks 3,4,5,8 in Figure 4)

These constraints include the equality constraints of Eq. (53) which is as follows:

Eqs. (20) - (22), Eqs. (27) - (33), Eqs. (41) - (45) (56)

11.2. Equality constraints obtained from differentiating the corresponding Lagrangian (block 6 in Figure 4)

 l_u is the Langarangian function of the new second-level problem.

$$\begin{split} & \frac{\partial l_{y}}{\partial P_{yrtiw}^{S}} = -W_{wr}(\frac{1}{1+f})^{r} \delta_{rt}(\lambda_{rtn(i\in n)w} - C_{i}^{S}) - \lambda'_{rtn(i\in n)w} + \overline{\mu}_{yrtiw}^{\prime S} \\ & + \sum_{s \mid 0_{w} \mathfrak{p}_{(\widetilde{w}, \mathfrak{p}') \in \widetilde{W}_{wr} = Q_{w'r})} \mu_{yrtiw'}^{\prime S} - O_{ytriw}^{S} \varphi_{rtw}^{SD} = 0 \quad \forall y, \forall r, \forall t, \forall i, \forall w \end{split}$$

$$\frac{\partial l_{y}}{\partial P_{yrtkw}^{E}} = -W_{wr}(\frac{1}{1+f})^{r} \delta_{rt}(\lambda_{rtn(k\in n)w} - C_{k}^{E}) - \lambda'_{rtn(k\in n)w} + \overline{\mu}_{yrtkw}^{/E} + \sum_{w'(w,w' \in \{Q_{wr} = Q_{w'r}\})} \mu_{yrtkw'}^{/E} - O_{ytrkw}^{E} \phi_{rtw}^{SD} = 0 \quad \forall y, \forall r, \forall t, \forall k, \forall w$$
(58)

(57)

$$\frac{\partial l_{y}}{\partial P_{rtdw}^{D}} = \lambda'_{rtnw} + \overline{\mu}'^{D}_{rtdw} - \underline{\mu}'^{D}_{rtdw} - \mu'^{D}_{yrtdw} + \sum_{w'(w,w' \subset \{Q_{wr} = Q_{w'r}\})} \mu^{D}_{yrtdw'} + \phi$$
(59)

$$\begin{aligned} \frac{m_{introv}^{1}}{m_{introv}^{0}} &= W_{int} \left(\frac{1}{i_{i}} l^{2} \delta_{intro}^{0} (\lambda_{intro} - \zeta_{intro}) - \zeta_{intro}^{1} (\zeta_{intro}) + \frac{\mu_{introv}^{2} \delta_{intro}^{0} (\lambda_{intro}^{0} - \zeta_{intro}) + \zeta_{introv}^{1} (\zeta_{intro}) - \zeta_{intro}^{1} (\zeta_{intro})$$

$$0 \leqslant (Q_{wr}\overline{P}_{td}^{D}) \perp \overline{\mu}_{rtdw}^{D'} \geqslant 0 \ \forall d, \forall t, \forall r, \forall w$$
 (95)

 $0 \leq B_{nm}(\theta_{rtnw} - \theta_{rtmw}) + \overline{F}_{nm} \perp \underline{V}_{rtnmw} \geq 0 \quad \forall n, \forall m, \forall t, \forall r, \forall w$ (96) $0 \leq \overline{F}_{nm} - B_{nm}(\theta_{rtnw} - \theta_{rtmw}) \perp \overline{V}'_{rtnmw} \geq 0 \quad \forall n, \forall m, \forall t, \forall r, \forall w$

$$0 < (\theta_{\perp} + \pi) + \zeta' > 0 \quad \forall n \quad \forall t \quad \forall r \quad \forall w$$
(97)
(97)

$$0 \leq (\theta_{\rm rtnw} + \pi) \perp \underline{\zeta}_{\rm rtnw} \geq 0 \quad \forall n, \forall t, \forall r, \forall w$$
(98)

$$0 \leqslant (\pi - \theta_{\text{rtnw}}) \perp \overline{\zeta}'_{\text{rtnw}} \geqslant 0 \quad \forall n, \forall t, \forall r, \forall w$$
(99)

TransactiveDual variables complementary constraints created after applying primal-dual transformation to third level problem (Eqs. (46)-(51)).

$$0 \leq \underline{\mu}_{\text{yrtiw}}^{S} \perp \underline{\eta}_{\text{rytiw}}^{S} \geq 0, \quad 0 \leq \overline{\mu}_{\text{yrtiw}}^{S} \perp \overline{\eta}_{\text{rytiw}}^{S} \geq 0, \quad \forall y, \forall i, \forall t, \forall r, \forall v$$

$$(100)$$

$$0 \leq \underline{\mu}_{\text{yrr'tiw}}^{\text{sr}} \perp \underline{\eta}_{\text{rr'ytiw}}^{\text{sr}} \geq 0, \quad 0 \leq \overline{\mu}_{\text{yrr'tiw}}^{\text{sr}} \perp \overline{\eta}_{\text{rr'ytiw}}^{\text{sr}} \geq 0 \quad \forall y, \forall r, \forall r' \in \{\underline{X}_{b}$$

$$(101) \quad \text{point}$$

$$\begin{split} 0 &\leq \underline{\mu}_{\text{yrtkw}}^{\text{E}} \perp \underline{\eta}_{\text{rytkw}}^{\text{E}} \geqslant 0, \ 0 \leq \overline{\mu}_{\text{yrtkw}}^{\text{E}} \perp \overline{\eta}_{\text{rytkw}}^{\text{E}} \geqslant 0, \ \forall y, \forall k, \forall t, \forall r \\ (102) \\ 0 &\leq \mu^{\text{D}} \perp n^{\text{D}} \geqslant 0, \ 0 \leq \overline{\mu}_{\text{otr}}^{\text{D}} \perp \overline{\eta}_{\text{otr}}^{\text{D}} \geqslant 0, \ \forall d, \forall t, \forall r, \forall w \end{split}$$

 $0 \leq \underline{V}_{\text{rtnmw}} \perp \underline{\eta}_{\text{rtnmw}}^{V} \geq 0, \quad 0 \leq \overline{V}_{\text{rtnmw}} \perp \overline{\eta}_{\text{rtnmw}}^{V} \geq 0, \quad \forall r, \forall t, \forall n,$ (104)

 $0 \leq \underline{\zeta}_{\text{rtnw}} \perp \underline{\eta}_{\text{rytnw}}^{\zeta} \geq 0, \ 0 \leq \overline{\zeta}_{\text{rtnw}} \perp \overline{\eta}_{\text{rytnw}}^{\zeta} \geq 0, \ \forall r, \forall t, \forall n, \forall (105)$

11.4. Part 4: Equivalent MINLP problem of thri-level model and Linearization

TransactiveAfter applying primal-dual transformation consecutively and KKT conditions to three-level problem now a single level problem has been created. The total problem's objective function is Eq. (23) which is non-linear. The constraints of this problem are as Eq. (106).

$$Eqs. (24) - (26), Eqs. (55) - (105)$$
 (106)

The above problem is non-linear and is as MINLP. The problem objective function that is Eq. (23) is non-linear because of the multiplication of the variables by the expression $\sum_{i} P_{yrtiw}^{S} \lambda_{rtn(i \in n)w} + \sum_{i} \sum_{r'} P_{yrrtiw}^{Sr} \lambda_{rtn(i \in n)w} + \sum_{k} P_{yrtkw}^{E} \lambda_{rtn(k \in n)w}$ which for making it linear the dual theory obtained from primal-dual transformation that is Eq. (32) is

used. As a result Eq. (23) becomes equivalent with Eq. (107).

$$TP = \sum_{w} \sum_{r} W_{wr} (\frac{1}{1+f})^{r} \sum_{t} \sigma_{rt} [\sum_{d} U_{td}^{D} P_{rtdw}^{D}$$

$$-\sum_{d} \overline{\mu}_{rtdw}^{D} Q_{wr} \overline{P}_{td} - \sum_{n} \sum_{m} (\underline{V}_{rtnmw} + \overline{V}_{rtnmw}) \overline{F}_{tnm} - \sum_{n} (\underline{\zeta}_{rtnw}$$

$$-\sum_{r} (\frac{1}{1+f})^{r} \sum_{i \in \psi^{S}} K_{yri} X_{yri}$$
(107)

Three groups of Eq. 106 constraints are non-linear.

The complementary constraints of Eqs. (84)-(105). Each complementary constraint in the form of b≥0 ⊥ a≥0 is equivalent to b≥0, a≥0, a≤Mψ and b≤M(1-ψ). It's worth mentioning that ψ and M are respectively binary variable and a constant number big enough.

• Eq. 31 dual theory constraint: the equality constraint obtained from the dual theory because of its non-linear nature including the multiplication of continues variable is not simply linearized. As was explained in part 5 of the paper (Converting the three-level to one-level problem) the equation obtained from dual theory has been obtained using primal-dual transform method equivalent to the set of commentary constraints using KKT conditions. Because of this linearization, dual theory constraints Eq. (32) are replaced with its equivalent complementary constraints in 107-118 (block 8 in Figure 4 is replaced with block 2). It's worth mentioning that the complementary constraints are linearized using the explanations of linearization of previous section.

 $\forall \mathbf{r}, \forall \mathbf{r}' \subset \{X_{\text{Constraints including}} \phi_{\text{rtw}}^{\mathsf{t}} \text{ from the mathematical view 101)} point, we can linearize the non-linear expressions including <math>\forall k, \forall t, \forall r, \forall r \notin W$ variable by giving a specific value to $\phi_{\text{rtw}}^{\text{Sd}}$.

$$0 \leqslant P_{\text{yrtiw}}^{S} \perp \underline{\mu}_{\text{yrtiw}}^{S} \geqslant 0, \quad \forall y, \forall i, \forall t, \forall r, \forall w$$
(108)

$$0 \leq (X_{yri} - P_{yrtiw}^{S}) \perp \overline{\mu}_{yrtiw}^{S} \geq 0, \quad \forall y, \forall i, \forall t, \forall r, \forall w \quad (109)$$

$$0 \leq \mathsf{P}_{\mathsf{yrr'tiw}}^{\mathsf{Sr}} \perp \underline{\mu}_{\mathsf{yrtiw}}^{\mathsf{Sr}} \geq 0, \quad \forall \mathsf{y}, \forall \mathsf{r}, \forall \mathsf{r}' \subset \{\mathsf{X}_{\mathsf{r's}} > 0, \mathsf{r} > \mathsf{r'}\}, \forall \mathsf{t}, \forall \mathsf{i}, \forall \mathsf{w}$$

$$(110)$$

$$0 \leqslant (X_{yrr'i}^{r} - P_{yrr'itw}^{Sr}) \perp \overline{\mu}_{yrtiw}^{Sr} \geqslant 0, \quad \forall y, \forall r, \forall r' \subset \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r > r'\}, \forall t, \forall r' \in \{X_{r's} > 0, r' \in \{X_{r's}$$

$$0 \leqslant \mathsf{P}_{\mathrm{yrtkw}}^{\mathsf{E}} \perp \underline{\mu}_{\mathrm{yrtkw}}^{\mathsf{E}} \geqslant 0, \quad \forall y, \forall k, \forall t, \forall r, \forall w$$
(112)

$$0 \leq (\overline{P}_{yk}^{E} - P_{yrtkw}^{E}) \perp \overline{\mu}_{yrtkw}^{E} \geq 0, \quad \forall y, \forall k, \forall t, \forall r, \forall w \quad (113)$$

$$0 \leq \mathsf{P}_{\mathrm{rtdw}}^{\mathrm{D}} \perp \underline{\mu}_{\mathrm{rtdw}}^{\mathrm{D}} \geq 0, \ \forall d, \forall t, \forall r, \forall w$$
(114)

$$0 \leqslant (Q_{wr}\overline{P}_{td}^{D}) \perp \overline{\mu}_{rtdw}^{D} \ge 0, \quad \forall d, \forall t, \forall r, \forall w$$
(115)

$$0 \leq B_{nm}(\theta_{rtnw} - \theta_{rtmw}) + \overline{F}_{nm} \perp \underline{V}_{rtnmw} \geq 0, \quad \forall n, \forall m, \forall t, \forall r, \forall w$$
(116)

$$0 \leqslant \overline{\mathsf{F}}_{nm} - \mathsf{B}_{nm}(\theta_{rtnw} - \theta_{rtmw}) \perp \overline{\mathsf{V}}_{rtnmw} \geqslant 0, \quad \forall n, \forall m, \forall t, \forall r, \forall w$$
(117)

$$0 \leqslant \theta_{rtnw} + \pi \perp \underline{\zeta}_{rtnw} \geqslant 0, \ \forall n, \forall t, \forall r, \forall w$$
 (118)

$$0 \leqslant \pi - \theta_{rtnw} \perp \overline{\zeta}_{rtnw} \geqslant 0, \ \forall n, \forall t, \forall r, \forall w$$
 (119)

References

- Z. Lu, J. Qi, B. Wen, X. Li, A dynamic model for generation expansion planning based on conditional value-at-risk theory under low-carbon economy Effectic Power Systems Research. 141 (2016) 363–71.
- conomy, Epstric Power Systems Research, 141 (2016) 363–71.
 [2] S. Li, D. W. Colt, Felder, Stochastic optimization for electric power generation expansion planning with discrete climate change scenarios, Electric Power Systems Research, 140 (2016) 401–12.
- [3] M. Marzband, H. Alavi, S. S. Ghazimirsaeid, H. Uppal, T. Fernando, Optimal energy management system based on stochastic approach for a home microgrid with integrated responsive load demand and energy storage, Sustainable Cities and Society, 28 (2017) 256–64.
- [4] M. Marzband, R. R. Ardeshiri, M. Moafi, H. Uppal, Distributed generation for economic benefit maximization through coalition formation based game theory concept, International Transactions on Electrical Energy Systems, (2017) 1–16.
- [5] M. Marzband, M. M. Moghaddam, M. F. Akorede, G. Khomeyrani, Adaptive load shedding scheme for frequency stability enhancement in microgrids, Electric Power Systems Research, (2016) 1–11.

- [6] A. Flores-Quiroz, R. Palma-Behnke, G. Zakeri, R. Moreno, A column generation approach for solving generation expansion planning problems with high renewable energy penetration, Electric Power Systems Research, 136 (2016) 232–41.
- [7] V. Hinojosa, J. Velásquez, Improving the mathematical formulation of security-constrained generation capacity expansion planning using power transmission distribution factors and line outage distribution factors, Electric Power Systems Research, 140 (2016) 391–00.
- [8] S. Pineda, J. Morales, Y. Ding, J. Ostergaard, Impact of equipment failures and wind correlation on generation expansion planning, Electric Power Systems Research, 116 (2014) 451–58.
- [9] A. J. Pereira, J. T. Saraiva, A long term generation expansion planning model using system dynamics a case study using data from the portuguese/spanish generation system, Electric Power Systems Research, 97 (2013) 41–50.
- [10] M. Manickavasagam, M. F. Anjos, W. D. Rosehart, Sensitivity-based chance-constrained generation expansion planning, Electric Power Systems Research, 127 (2015) 32–40.
- [11] S. Rebennack, Generation expansion planning under uncertainty with emissions quotas, Electric Power Systems Research, 114 (2014) 78– 85.
- [12] Y. Tohidi, F. Aminifar, M. Fotuhi-Firuzabad, Generation expansion and retirement planning based on the stochastic programming, Electric Power Systems Research, 104 (2013) 138–45.
- [13] J. Aghaei, M. A. Akbari, A. Roosta, A. Baharvandi, Multiobjective generation expansion planning considering power system adequacy, Electric Power Systems Research, 102 (2013) 8–19.
- M. Pantos, Stochastic generation-expansion planning and diversification of energy transmission paths, Electric Power Systems Research, 98 (2013) 1–10.
- [15] G. A. Bakirtzis, P. N. Biskas, V. Chatziathanasiou, Generation expansion planning by MILP considering mid-term scheduling decisions, Electric Power Systems Research, 86 (2012) 98–12.
- [16] H. Tekiner, D. W. Coit, F. A. Felder, Multi-period multi-objective electricity generation expansion planning problem with monte-carlo simulation, Electric Power Systems Research, 80 (12) (2010) 1394–405.
- [17] A. J. Pereira, J. T. Saraiva, A decision support system for generation expansion planning in competitive electricity markets, Electric Power Systems Research, 80 (7) (2010) 778–87.
- [18] P. Murugan, S. Kannan, S. Baskar, NSGA-II algorithm for multiobjective generation expansion planning problem, Electric Power Systems Research, 79 (4) (2009) 622–28.
- [19] S.-L. Chen, T.-S. Zhan, M.-T. Tsay, Generation expansion planning of the utility with refined immune algorithm, Electric Power Systems Research, 76 (4) (2006) 251–58.
- [20] L. Manso, A. L. da Silva, Probabilistic criteria for power system expansion planning, Electric Power Systems Research, 69 (1) (2004) 51–58.
- [21] C.-H. Wang, K. J. Min, Generation planning with quantified outage costs, Electric Power Systems Research, 54 (1) (2000) 37–46.
- [22] M. Marzband, F. Azarinejadian, M. Savaghebi, J. M. Guerrero, An optimal energy management system for islanded microgrids based on multiperiod artificial bee colony combined with markov chain, IEEE systems journal, PP (99) (2015) 1–11.
- [23] M. Marzband, M. Ghadimi, A. Sumper, J. L. Domínguez-García, Experimental validation of a real-time energy management system using multi-period gravitational search algorithm for microgrids in islanded mode, Applied Energy, 128 (0) (2014) 164–74.
- [24] M. Marzband, Experimental validation of optimal real-time energy management system for microgrids, Phd thesis, Departament d'Enginyeria Elèctrica, EU d'Enginyeria Tècnica Industrial de Barcelona, Universitat Politècnica de Catalunya (2013).
- [25] M. Marzband, S. S. Ghazimirsaeid, H. Uppal, T. Fernando, A real-time evaluation of energy management systems for smart hybrid home microgrids, Electric Power Systems Research, 143 (2017) 624–33.
- [26] M. Marzband, M. Javadi, J. L. Domínguez-García, M. M. Moghaddam, Non-cooperative game theory based energy management systems for energy district in the retail market considering DER uncertainties, IET Generation, Transmission & Distribution, 10 (2016) 2999–3009.
- [27] M. Marzband, N. Parhizi, J. Adabi, Optimal energy management for stand-alone microgrids based on multi-period imperialist competition algorithm considering uncertainties: experimental validation, Interna-

tional Transactions on Electrical Energy Systems, 30 (1) (2015) 122– 31.

- [28] T. Barforoushi, M. P. Moghaddam, M. H. Javidi, M. K. Sheikh-El-Eslami, Evaluation of regulatory impacts on dynamic behavior of investments in electricity markets: A new hybrid DP/GAME framework, IEEE Transactions on Power Systems, 25 (4) (2010) 1978–86.
- [29] F. H. Murphy, Y. Smeers, Generation capacity expansion in imperfectly competitive restructured electricity markets, Operation reaserch 53 (4) (2005) 646–61.
- [30] S. Wogrin, J. Barquín, E. Centeno, Capacity expansion equilibria in liberalized electricity markets: An EPEC approach, IEEE Transactions on Power Systems, 28 (2) (2013) 1531–39.
- [31] S. Wogrin, E. Centeno, J. Barquín, Generation capacity expansion analysis: Open loop approximation of closed loop equilibria, IEEE Transactions on Power Systems, 28 (3) (2013) 3362–71.
- [32] M. Marzband, N. Parhizi, M. Savaghebi, J. Guerrero, Distributed smart decision-making for a multimicrogrid system based on a hierarchical interactive architecture, IEEE Transactions on Energy Conversion, 31 (2) (2016) 637–48.
- [33] M. Marzband, A. Sumper, Implementation of an optimal energy management within islanded microgrid, International Conference on Renewable Energies and Power Quality (ICREPQ), Cordoba, Spain, 2014.
- [34] M. Marzband, A. Sumper, M. Chindriş, B. Tomoiagă, Energy management system of hybrid microgrid with energy storage, *The International Word Energy System Conference (WESC)*, Suceava, Romania, 2012.
- [35] S. J. Kazempour, A. J. Conejo, C. Ruiz, Strategic generation investment using a complementarity approach, IEEE Transactions on Power Systems, 26 (2) (2010) 940–48.
- [36] S. J. Kazempour, A. J. Conejo, Strategic generation investment under uncertainty via benders decomposition, IEEE Transactions on Power Systems, 27 (1) (2012) 424–32.
- [37] J. Valinejad, T. Barforoushi, Generation expansion planning in electricity markets: A novel framework based on dynamic stochastic MPEC, International Journal of Electrical Power & Energy Systems, 70 (2015) 108–17.
- [38] S. Jin, S. M. Ryan, A tri-level model of centralized transmission and decentralized generation expansion planning for an electricity marketpart I, IEEE Transactions on Power Systems, 29 (1) (2014) 132–41.
- [39] S. J. Kazempour, A. J. Conejo, C. Ruiz, Generation investment equilibria with strategic producers-part I: Formulation, IEEE Transactions on Power Systems, 28 (3) (2013) 2613–22.
- [40] J. R. Birge, F. Louveaux, Introduction to stochastic programming, Springer.
- [41] A. Ford, Cycles in competitive electricity markets: a simulation study of the western united states, Energy Policy, 27 (11) (1999) 637–58.
- [42] P. Kaymaz, J. Valenzuela, C. S. Park, Transmission congestion and competition on power generation expansion, IEEE Transactions on Power Systems, 22 (1) (2007) 156–63.
- [43] M. Marzband, A. Sumper, J. L. Domínguez-García, R. Gumara-Ferret, Experimental validation of a real time energy management system for microgrids in islanded mode using a local day-ahead electricity market and MINLP, Energy Conversion and Management 76 (0) (2013) 314– 22.
- [44] C. Ruiz, A. J. Conejo, Pool strategy of a producer with endogenous formation of locational marginal prices, IEEE Transactions on Power Systems, 24 (4) (2009) 1855–66.
- [45] M. Marzband, E. Yousefnejad, A. Sumper, J. L. Domínguez-García, Real time experimental implementation of optimum energy management system in standalone microgrid by using multi-layer ant colony optimization, International Journal of Electrical Power & Energy Systems, 75 (2016) 265–74.
- [46] M. Moafi, M. Marzband, M. Savaghebi, J. M. Guerrero, Energy management system based on fuzzy fractional order PID controller for transient stability improvement in microgrids with energy storage, International Transactions on Electrical Energy Systems (2016) 1–20.
- [47] M. Marzband, A. Sumper, A. Ruiz-Álvarez, J. L. Domínguez-García, B. Tomoiagă, Experimental evaluation of a real time energy management system for stand-alone microgrids in day-ahead markets, Applied Energy 106 (0) (2013) 365–76.
- [48] M. Marzband, A. Sumper, O. Gomis-Bellmunt, P. Pezzini, M. Chindris,

Frequency control of isolated wind and diesel hybrid microgrid power system by using fuzzy logic controllers and PID controllers, in: Electrical Power Quality and Utilisation (EPQU), 2011 11th International Conference on, 2011, pp. 1–6.

- [49] A. Botterud, M. D. Ilic, I. Wangensteen, Optimal investments in power generation under centralized and decentralized decision making, IEEE Transactions on Power Systems, 20 (1) (2005) 254–63.
- [50] I. Dyner, E. R. Larsen, From planning to strategy in the electricity industry, Energy Policy, 29 (13) (2001) 1145–54.
- [51] A. J. Conejo, M. Carrión, J. M. Morales, Decision making under uncertainty in electricity markets, Springer, 2010.
- [52] S. Wogrin, E. Centeno, J. Barquin, Generation capacity expansion in liberalized electricity markets: A stochastic MPEC approach, IEEE Transactions on Power Systems, 26 (4) (2011) 2526–32.
- [53] S. Gabriel, A. Conejo, J. Fuller, B. Hobbs, C. Ruiz, Complementarity Modeling in Energy Markets, Springer, 2013.