

Technical University of Denmark



Fate prediction and mass balances verification of pharmaceuticals compounds in Roldán-Balsicas WWTP (Murcia, Spain)

González-García, Mariano; Polesel, Fabio; Trapp, Stefan; Fernández-López (, Carmen

Publication date:
2017

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):

González-García, M., Polesel, F., Trapp, S., & Fernández-López (, C. (2017). Fate prediction and mass balances verification of pharmaceuticals compounds in Roldán-Balsicas WWTP (Murcia, Spain). Poster session presented at Summer School on Advanced Treatment Technologies and Contaminants of Emerging Concern, Porto, Portugal.

DTU Library

Technical Information Center of Denmark

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Fate prediction and mass balances verification of pharmaceuticals compounds in Roldán-Balsicas WWTP (Murcia, Spain).

Mariano González-García⁽¹⁾ *, Fabio Polese⁽²⁾, Stefan Trapp⁽²⁾, Carmen Fernández-López⁽¹⁾, *mgonzalez9@alu.ucam.edu

(1) Catholic University of Murcia (UCAM), Murcia, Spain.

(2) Technical University of Denmark, Kongens Lyngby, Denmark.



Introduction

The available water resources are limited and the growing water consumption has increased pressure on natural resources. Therefore, wastewater represents an alternative option for use in urban areas, industry and, especially, agriculture. The current study was carried out in the wastewater treatment plant (WWTP) located in Roldán-Balsicas (Murcia, Spain), employing primary physicochemical treatment followed by biological treatment. Recent research has shown that some pharmaceuticals compounds are not completely removed in the WWTP, and may eventually be released to agricultural system with the reuse of wastewater-based resources (sludge and effluent). In this study, we used a simulation tool to predict the fate of three pharmaceuticals compounds (Diclofenac, ibuprofen and ketoprofen) in a municipal WWTP. Model predictions were verified with measurements from a monitoring campaign in the WWTP.

Objectives

The aims of this study were:

- Evaluate the biological degradation of the target compounds diclofenac (DCF), ibuprofen (IBP) and ketoprofen (KTF) in the secondary treatment of a conventional activated sludge WWTPs and estimate their sorption onto the sludge.
- Apply a simulation system to predict the fate of three pharmaceuticals compounds (DCF, IBP and KTF) in a municipal WWTP.

Experimental layout

The current study was carried out in the wastewater treatment plant (WWTP) located in Roldán-Balsicas (Murcia, Spain) (UTM X: 679615.7525, Y:4185244.9214) (Fig. 1).

This WWTP manages 8910 population equivalents (PE) and is equipped for the elimination of carbon and nutrients. The primary treatment consists of a screen, an aerated bean extraction tank and a primary clarifier. The biologically treated wastewater from the conventional activated sludge is filtered through a layer of a continuously operating sand filter prior to being disinfected by ultraviolet radiation. Effluents are used for irrigation in agriculture.



Fig. 1. Roldán-Balsicas WWTP

Methodology

The sampling campaign was carried out in February 2016, and the samples were taken in the raw urban wastewater, anaerobic effluent, anoxic effluent, aerobic effluent and tertiary effluent [1].

The WWTP model Activity SimpleTreat [2] describes the fate (biodegradation, sorption) of ionizable pharmaceuticals based on the activity concept [3].

The physico-chemical input properties necessary in this model are the biodegradation rate, the molecular weight, the octanol-water partition coefficient, vapor pressure, solubility, the type of ionization, the acid dissociation constant of acids and bases (pKa,a and pKa,b) and the Henry constant of the neutral compound.

The model allows to predict the fraction of influent DCF, IBP and KTF biotransformed, sorbed to sewage sludge and discharged with wastewater effluent [4].

Measurements from a sampling campaign (raw WWTP influent and effluent from the activated sludge reactor) were used to verify model predictions. Measurements in the final effluent were not considered, since tertiary treatment removal is not described for in the model.

Acknowledgements

The authors wish to thank the staff from Roldán, Lo Ferro-Balsicas WWTP and Entity for Water Cleaning and Sanitation of Murcia (ESAMUR). Also, we would like to thanks to IAMA for the support on sample collection, as well as the technical assistance in analysis.

Finally, we would like to thanks to NEREUS COST Action and University of Porto for organizing the 2nd Summer School.

Results and conclusions

The results suggested a high measured removal efficiency of DCF, IBP and KTF concentrations in the WWTP Roldán-balsicas (Table 1).

	Diclofenac	Ibuprofen	Ketoprofen
Measured removal efficiency (%)	76,52	98,68	55,55
Kbiol (1 h ⁻¹)	0,03	0,85	0,01
Kd (L kg _{dwt} ⁻¹)	110,00	30,00	40,00

Table 1. Measured removal efficiency, constant biodegradation rates (Kbiol) and sorption equilibrium in the sludge (Kd) calculated in WWTP.

The model prediction confirm the same conclusion explained above.

Fig. 2. show the three treatment steps: primary settling, activated sludge reactor and secondary settling. Each treatment step is divided in a number of boxes (Air, water, suspended solids and settled sludge).




Fig. 2. Diagram with the predicted removal efficiency

The results of this study indicated that the concentration of pharmaceuticals in the effluent showed a trend in the order: DCF > KTF > IBP.

References

- [1] Martínez-Alcalá, I, Guillén-Navarro, J.M., Fernández-López, C., (2107). Pharmaceutical biological degradation, sorption and mass balance determination in a conventional activated-sludge wastewater treatment plant from Murcia, Spain. Chemical Engineering Journal, 95, 811–816.
- [2] Franco, A., Song, L., Trapp, S. (2011). Activity SimpleTreat User Instructions. Available at: <http://homepage.env.dtu.dk/stt/Homepage%20anf/Website.htm>.
- [3] Trapp, S., Franco, A., Mackay, D. (2010). Activity-based concept for transport and partitioning of ionizing organics. Environmental Science and Technology, 44(16), 6123-6129.
- [4] Polese, F., Plosz, B. G., Trapp, S. (2015). From consumption to harvest: Environmental fate prediction of excreted ionizable trace organic chemicals. Water Research, 84, 85-98.