

Air Flow Regulation in Fuel Cells: An Efficient Design of Hybrid Fuzzy-PID Control

Zakaria BAROUD¹, Attalah BENALIA¹, Carlos OCAMPO-MARTINEZ²

¹LACoSERE laboratory, Amar Telidji University, 03000 Laghouat, Algeria

²Automatic Control Department, Universitat Politècnica de Catalunya, Institut de Robòtica i Informàtica Industrial (CSIC-UPC), 08028 Barcelona, Spain

Abstract

This paper presents a hybrid fuzzy-PID controller for air flow supply on a Proton Exchange Membrane fuel cell (PEMFC) system. The control objective is to adjust the oxygen excess ratio at a given setpoint in order to prevent oxygen starvation and damage of the fuel-cell stack. The proposed control scheme combines a fuzzy logic controller (FLC) and classical PID controller with a view to benefit the advantages of both controllers. The results show that the proposed technique performs significantly better than the classical PID controller and the FLC in terms of several key performances indices such as the Integral Squared Error (ISE), the Integral Absolute Error (IAE) and the Integral Time-weighted Absolute Error (ITAE) for the closed-loop control system.

Keywords: PEM fuel cell system, Fuzzy Logic, Classical PID, Hybrid controller.

1. Introduction

The serious environmental pollution and energy crisis around the world are driving innovation on new clean energy sources such as solar, wind, geothermal or hydrogen. Among these sources, the hydrogen appears as a energy vector to be used as a combustible for fuel cells to produce electricity, water and heat [1].

Among all types of fuel cells, the proton exchange membrane fuel cells (PEMFC), also called solid polymer fuel cells (SPFC), are particularly suitable for use in wide range applications, with advantages of high efficiency, low weight, low pollution and low operation temperature (50°C to 100°C), facts that allow fast starting times. However, short lifetime and high expenses have hindered their vast applicability in real systems so far [2]. As a result, in order to improve the performance, enhance the lifetime and reduce the production costs, effective control systems are required.

Many control strategies for PEMFC systems in the literature have been proposed considering dynamic feedforward and linear quadratic regulator [3, 4], unfalsified control [5], sliding mode control [6], model predictive control [7] and Fuzzy logic control [8, 9, 10]. These control methods are applied to the manipulation of the oxygen excess ratio in PEMFC with certain limitations on the tracking

performance.

In order to enhance effectively the tracking accuracy of the oxygen excess ratio, a hybrid fuzzy-PID controller is proposed in this paper.

The proposed controller combines a fuzzy logic controller and a classical PID controller, allowing the overall scheme to switch between both strategies by using a simple switching system. The dynamic model used in this paper to validate the proposed controller is a reduced version of the ninth-order state-space model proposed by Pukrushpan et al. [3].

The remainder of the paper is organized in the following way: the mathematical model of the PEMFC air supply system and the control objective are explained in Section 2. In Section 3, the hybrid fuzzy-PID controller design is explained. The designed control strategy is applied to the model of PEMFC system and its simulation results are shown in Section 4. Finally main conclusions are presented in Section 5.

2. PEMFC System Model

Nonlinear Model

The PEMFC model considered in this paper is based on a 75 kW PEMFC power system. The PEMFC system includes five main subsystems: the air flow (breathing), the hydrogen flow, the humidifier, the stack electrochemistry and the stack

temperature. In [11], it is assumed that the temperature and humidity of input reactant flows are well regulated by dedicated controllers. In addition, it is considered that sufficient compressed hydrogen is available, and therefore the main attention is focused on the air management. Under these assumptions, we present a fourth-order state space model that is a reduced version of the ninth-order model presented in [3]. The model equations and the constants are summarized in Tables A.1 and A.2 in Appendix A, respectively. The details of the model used in this study and the numerical values can be found in [11] and [12].

The nonlinear state equations in Table A.1 in Appendix A have the form

$$\dot{x} = f(x, u, w), \quad (1)$$

where the vector of states $x \in \mathbb{R}^4$ is associated to the partial pressure of oxygen and nitrogen in the cathode channel, the rotational speed of the motor shaft in the compressor and the air pressure in the supply manifold, respectively.

The control input $u \in \mathbb{R}$, as shown in Figure 1, is the compressor motor voltage v_{cm} , which allows the manipulation of the air feed and, as a consequence, the oxygen supply to the fuel-cell stack. The measurable disturbance input $w \in \mathbb{R}$ is the stack current I_{st} . The system output $h_y \in \mathbb{R}^3$, as illustrated also in Figure 1, is the stack voltage $h_{y1} = v_{st}$, the supply manifold pressure $h_{y2} = x_4$ and the air flow rate through the compressor $h_{y3} = W_{cp}$, respectively. For further details about the functions h_{y1} and h_{y3} , see [12, 13]. The performance variables $z \in \mathbb{R}^2$, with z_1 as the net power and z_2 as the oxygen excess ratio, are also outlined in Table A.1 in Appendix A.




Figure 1. Fuel Cell System showing control inputs and outputs

Control Objective

The main control objective for the PEMFC system is to regulate the oxygen excess ratio z_2 , which is defined by the amount of oxygen provided $W_{O_2,in}$ and the amount of oxygen reacted $W_{O_2,rc}$, which is described as

$$z_2 = \frac{W_{O_2,in}}{W_{O_2,rc}} \quad (2)$$

If the value of z_2 is quite low, even though higher than 1, it is likely to cause *Oxygen starvation*. This phenomenon can cause a short circuit and hot spot on the surface of membrane cell. On the other hand, a higher values of z_2 will drive the auxiliary system to consume more power. Therefore, the system efficiency then decreases. Consequently, it is necessary to use efficient control methods to regulate the oxygen excess ratio around an optimum value.

The oxygen excess ratio was analyzed for different stack current and temperature in [14]. The results show that the optimal value of z_2 depends strongly on the stack current. Hence, we choose $z_{2,opt} = 2.05$, which corresponds to maximum PEMFC net power z_1 for the nominal stack current [2].

3. Control Design

This section presents the design of the hybrid fuzzy-PID controller based on simple switching system to regulate the oxygen excess ratio at its optimal value. Firstly, we design the PID controller and the fuzzy logic controller, and then we combine them to obtain the hybrid controller. The switching method depends on the state of the system response.

PID Controller

The PID-controller-based scheme, shown in Figure 2, is widely used in industrial process control due to its simple structure and robust performance for both linear and nonlinear systems. The mathematical expression of this controller is given by

$$u_{PID}(t) = k_p e(t) + k_i \int e(t) dt + k_d \frac{de(t)}{dt} \quad (3)$$

where e is the feedback error defined in the case of this paper as the difference between the current value of z_2 and its setpoint value, i.e.,

$$e(t) = z_2(t) - z_{2,opt} \quad (4)$$

Besides, the parameters k_p, k_i and k_d are known as proportional gain, integral gain and derivative gain, respectively.




Figure 2. Structure of PID-controller-based scheme

Gains k_p, k_i and k_d may be computed by using optimization methods [15], among other traditional strategies.

Fuzzy Logic Controller (FLC)

Fuzzy logic is one of the most versatile control techniques due to its simplicity, efficiency and robustness against the system dynamics variation. The FLC has several advantages such as it does not require the precise information about the process dynamics [16]. There are three main parts in the FLC as shown in Figure 3:

- Fuzzification interface: Converts a crisp input to a fuzzy value by using fuzzy sets,
- Rule base and inference system: Generates a result for each suitable rule, then combines the results of the rules,

- Defuzzification interface: Converts the combined result back into a specific control output value.




Figure 3. Structure of the FLC

In Figure 3, the variables $e, \Delta e; E$ and ΔE indicate error, derivative of error, normalized error and normalized derivative of error, respectively, while the parameters k_1, k_2 and k_3 are input and output scaling factors. In Table 1, the fuzzy linguistic variables NB, N, Z, P and PB represent negative big, negative, zero, positive and positive big, respectively.

The membership functions of the FLC inputs and output are respectively shown in Figures 4 and 5.




Figure 4. Membership functions of inputs ($e, \Delta e$)




Figure 5. Membership functions of output (Δu)

Table 1: Linear rule base for FLC.

ΔU		E				
		NB	N	Z	P	PB
ΔE	NB	NB	NB	N	N	Z
	N	NB	N	N	Z	P
	Z	N	N	Z	P	P
	P	N	Z	P	P	PB
	PB	Z	P	P	PB	PB

Hybrid Fuzzy-PID Controller

While the fundamental difficulty with PID control is that it is sensitive to variations of the system parameters, FLC does not need precise information about the system variables in order to be effective. However, PID control is more able to reduce the steady-state error of the system [17]. Therefore, a hybrid system, as shown in Figure 6, is required in order to regulate the dynamic and steady-state performance of the oxygen excess ratio.




Figure 6. Structure of the hybrid Fuzzy-PID controller

Figure 6 shows the switching mechanism between the FLC and the PID controller, where the position of the switch depends on the error between the actual value of oxygen excess ratio and its optimal value. If the output value is far away from the setpoint, the FLC has the greatest effect on the control system. Similarly, when the output value is near the setpoint value, the PID controller has the greatest effect over the system rather than the FLC. The output of the hybrid fuzzy-PID controller can be expressed as

$$u(t) = \begin{cases} u_{fuzzy}(t) & \text{if } |e| > |e_0| \\ u_{PID}(t) & \text{if } |e| \leq |e_0| \end{cases} \quad (5)$$

where e_0 is the threshold value.

4. Simulation results

The hybrid fuzzy-PID control scheme is applied to the PEMFC system model in (1). The control input is computed such as it is defined a compressor motor input voltage v_{cm} in order to maintain the oxygen excess ratio at 2.05 and thus, minimizing the parasitic power consumption. For this purpose, rapid variations of stack current are applied, as shown in Figure 7, in order to illustrate the air supply regulation in a wide range of operation points.

It can be seen from Figure 8 that all the applied control strategies adjust z_2 at the setpoint with a satisfactory tracking performance.

Figures 9 and 10 present the zoomed plot of z_2 when the stack current is increased from 200 A to 300 A (at $t=20$ s) and when the stack current is decreased from 250 A to 200 A (at $t=40$ s), respectively. In the former case, the oxygen excess ratio decreases, as shown in Figure 9, due to the depletion of the oxygen at the cathode side. This fact caused an important drop of the stack voltage, as shown in Figure 11. An inverse case is shown in Figure 10 at $t=40$ s. According to the zoomed plot of z_2 (Figures 9 and 10), the HFPIID controller exhibits a faster time response compared to the remainder control strategies. As seen in Figure 11 and Table 2, the HFPIID controller reduces the rise time and the settling time of z_2 during the transient step changes of w with respect to the PID and FLC controllers separately.

Table 2 show the obtained results in terms of several performance indices including the Integral Squared Error (ISE), the Integral Absolute Error (IAE) and the Integral Time-weighted Absolute Error (ITAE). Those indices allow to show that the proposed control strategy performs much better than the PID and FLC control strategies in separate fashion.




Figure 7. Stack current variation




Figure 11. Stack voltage variation




Figure 8. Response of oxygen excess ratio for different control strategies




Figure 9. The magnified plot of oxygen excess ratio variation at $t=20$ s




Figure 10. The magnified plot of oxygen excess ratio variation at $t=40$ s

Table 2: Performance index comparison and time domain specifications

Controller	ISE	IAE	ITAE	Rise Time	Settling Time
PID	0.1094	0.3763	7.5115	0.19	0.11
FLC	0.6736	1.3346	23.6383	0.38	0.77
HFPID	0.0606	0.2041	4.1203	0.075	0.061

5. Conclusions

In this study, a reduced PEMFC system model is explained, which presents cathode mass flow transients. Based on this model, a hybrid fuzzy-PID controller is designed to regulate the oxygen excess ratio in order to avoid oxygen starvation when the stack current suddenly changes. The proposed controller combines a FLC and classical PID controller, which can be switched between them by using a simple switching system. The simulation results show that the hybrid fuzzy-PID control has the better control effect than the classical PID and the FLC. However, for better results, it is advisable to use a variable optimal oxygen excess ratio expression as a function of the PEMFC stack current.

6. References

- [1] Larminie J, Dicks A, *Fuel Cell Systems Explained*, New York: J. Wiley & Sons, 2000.
- [2] Kunusch C, Puelston P.F, Mayosky M.A, *Sliding-mode control of PEM fuel cells*, London: Springer-Verlag London, 2012.
- [3] Pukrushpan J.T, Stefanopoulou A.G, Peng H, "Control of fuel cell breathing", in *IEEE, Control Systems*, 2004; vol. 24 (no. 2): p. 30-46.

- [4] Niknezhadi A, Allué-Fantova M, Kunusch C, Ocampo-Martinez C, “Design and implementation of LQR/LQG strategies for oxygen stoichiometry“, in *Journal of Power Sources*, 2011; vol. 196 (no. 9): p. 4277 - 4282.
- [5] Bianchi F, Kunusch C, Ocampo-Martinez C, Sánchez Peña R, “Fault tolerant unfalsified control for PEM fuel cell systems“, in *IEEE Transactions on, Energy Conversion*, 2015; vol. 30 (no. 1): p. 307-315.
- [6] Baroud Z, Benmiloud M, Benalia A. “Sliding mode controller for breathing subsystem on a PEM fuel cell system“, in *Proc. 3rd IEEE conf. on Control engineering & information technology; 2014 May 25-27*; Tlemcen, Algeria; p. 1-6.
- [7] Bordons C, Arce A, Delreal A.J, “Constrained predictive control strategies for PEM fuel cells“, in *Proc. American Control Conf.; 2006*; Minneapolis, USA.
- [8] Hao X, Zhang H, An A, Liu X, Chen L, “Fuzzy double model control for air supply on a PEM fuel cell system“, in *Springer Berlin Heidelberg, 2013*; vol. 355: p. 392-400.
- [9] Baroud Z, Benmiloud M, Benalia A. “Fuzzy Self-Tuning PID Controller for Air Supply on a PEM Fuel Cell system“, in *Proc. 4th Int. Conf. on Electrical Engineering; 2015 Dec. 13-15*; Boumerdès, Algeria; p. 1-6.
- [10] Ou K, Wang Y, Li Z, Shen Y.D, “Feedforward fuzzy -PID control for air flow regulation of PEM fuel cell system“, in *International journal of Hydrogen Energy*, 2015; vol. 40 (no. 35): p. 11686 - 11695.
- [11] Suh KW, “*Modeling, analysis and control of fuel cell hybrid power systems*“, Ph.D. thesis, 2006; University of Michigan, USA.
- [12] Gruber J, Bordons C, Dorado F, “Nonlinear control of the air feed of a fuel cell“, in *Proc. American Control Conf.; 2008 June 11-13*; Seattle WA, USA; p. 1121-1126.
- [13] J. Pukrushpan, A. Stefanopoulou, H. Peng, “*Fuel Cell System Model: Fuel Cell Stack*“, in: *Control of Fuel Cell Power Systems*, London: Springer London, 2004.
- [14] Guo A, Chen W, Li Q, Liu Z. Que H, “Air flow control based on optimal oxygen excess ratio in fuel cells for vehicles“, in *Journal of Modern Transportation*, 2013, vol. 21; (no. 2): p. 79-85.
- [15] O’Dwyer A, *Handbook of PI and PID controller tuning rules*, World Scientific, 2009.
- [16] Fereidouni A. Masoun M.A.S, Moghbel M, “A new adaptive configuration of PID type fuzzy logic controller“, in *International journal of ISA Transactions*, 2015; vol. 56 p. 222-240.

- [17] Sinthipsomboon K, Hunsacharoonroj I, Khedari J, PO-nagen W, Pratumsumwan P, “A hybrid of fuzzy and fuzzy self-tuning PID controller for Servo Electro-Hydraulic System“, *International journal of advanced robotic systems*, (2012).

Appendix A

Equations, Constants of the PEMFC system

Table A.1: Fourth-order state-space model of the PEMFC system.

$\dot{x}_1 = c_1(x_4 - \chi) - \frac{c_3 x_1 \alpha(x_1, x_2)}{c_4 x_1 + c_5 x_2 + c_6} - c_7 w$
$\dot{x}_2 = c_8(x_4 - \chi) - \frac{c_3 x_2 \alpha(x_1, x_2)}{c_4 x_1 + c_5 x_2 + c_6}$
$\dot{x}_3 = -c_9 x_3 - \frac{c_{10}}{x_3} \left(\left(\frac{x_4}{c_{11}} \right)^{c_{12}} - 1 \right) \cdot h_{y3}(x_3, x_4) + c_{13} u$
$\dot{x}_4 = c_{14} \left(1 + c_{15} \left(\left(\frac{x_4}{c_{11}} \right)^{c_{12}} - 1 \right) \right) \cdot (h_{y3}(x_3, x_4) - c_{16}(x_4 - \chi))$
$\chi = x_1 + x_2 + c_2$
$\alpha = \begin{cases} c_{17} \chi \left(\frac{c_{11}}{\chi} \right)^{c_{18}} \sqrt{1 - \left(\frac{c_{11}}{\chi} \right)^{c_{12}}}, & \text{if } \frac{c_{11}}{\chi} > c_{19} \\ c_{20} \chi, & \text{if } \frac{c_{11}}{\chi} \leq c_{19} \end{cases}$
$z_1 = h_{y1}(x_1, x_2) w - c_{21} u (u - c_{22} x_3)$
$z_2 = \frac{c_{23}(x_4 - \chi)}{c_{24} w}$

Table A.2: Constants of the PEMFC system model.

$c_1 = \frac{RT_{st} k_{ca,in}}{M_{O_2} V_{ca}} \left(\frac{x_{O_2,atm}}{1 + \omega_{atm}} \right)$	$c_{15} = \frac{1}{\eta_{cp}}$
$c_2 = p_{sat}$	$c_{16} = k_{ca,in}$
$c_3 = \frac{RT_{st}}{V_{ca}}$	$c_{17} = \frac{C_D A_T}{\sqrt{RT_{st}}} \sqrt{\frac{2\gamma}{\gamma-1}}$
$c_4 = M_{O_2}$	$c_{18} = \frac{1}{\gamma}$
$c_5 = M_{N_2}$	$c_{19} = \left(\frac{2}{\gamma+1} \right)^{\frac{\gamma}{\gamma-1}}$
$c_6 = M_v p_{sat}$	
$c_7 = \frac{RT_{st} n}{4 F V_{ca}}$	

$$c_8 = \frac{RT_{st}k_{ca,in}}{M_{N_2}V_{ca}} \left(\frac{1-x_{O_2,atm}}{1+\omega_{atm}} \right)$$

$$c_9 = \frac{\eta_{cm}k_t k_v}{J_{cp}R_{cm}}$$

$$c_{10} = \frac{C_p T_{atm}}{J_{cp}\eta_{cp}}$$

$$c_{11} = p_{atm}$$

$$c_{12} = \frac{\gamma - 1}{\gamma}$$

$$c_{13} = \frac{\eta_{cm}k_t}{J_{cp}R_{cm}}$$

$$c_{14} = \frac{RT_{atm}\gamma}{M_{a,atm}V_{sm}}$$

$$c_{20} = \frac{C_D A_T}{\sqrt{RT_{st}}} \gamma^{1/2} \left(\frac{2}{\gamma+1} \right)^{\frac{\gamma+1}{2\gamma-2}}$$

$$c_{21} = \frac{1}{R_{cm}}$$

$$c_{22} = k_v$$

$$c_{23} = k_{ca,in} \frac{x_{O_2,atm}}{1+\omega_{atm}}$$

$$c_{24} = \frac{nM_{O_2}}{4F}$$

$$x_{O_2,atm} = \frac{y_{O_2,atm}M_{O_2}}{M_{a,atm}}$$

$$\omega_{atm} = \frac{M_v}{M_{a,atm}} \frac{\phi_{atm}P_{sat}}{P_{atm} - \phi_{atm}P_{sat}}$$

8. Biographies



Zakaria BAROUD was born on 21 April 1990 in Laghouat/Algeria. He earned his License degree in Electro-technology (2010) and his Master degree in Automatic (2012) from the university of Amar Telidji.

He also got the first rank (Highest Marks) in his group in License and Master. He is currently a PhD Student in the Electrical Engineering Department. His general research interests are in the areas of Automatic control systems and his current research focuses on the PEM Fuel Cell Systems modeling and control.

Correspondence address: Oasis-Nord, Lots n° 500, Laghouat, Algeria.

e-mail: z.baroud@lagh-univ.dz



Atallah BENALIA was born in 1972 in Algiers/Algeria. He received the diploma of state engineer from Ecole Polytechnique of Algiers in 1996, and the DEA

and PhD degrees in Automatic control from the University of Paris-Sud (France), in 1998 and 2004, respectively.

He joined the faculty of the Technology at the University of Amar Telidji, Laghouat (Algeria), in 2008 where he is currently a professor. His research interests deal mainly with analysis and control of nonlinear systems.

Correspondence address: Oasis-Nord, Lots n° 720, Laghouat, Algeria.

e-mail: a.benalia@lagh-univ.dz



Carlos OCAMPO-MARTINEZ received his electronics engineering degree and MSc. degree in industrial automation from National University of Colombia (Manizales), in 2001 and 2003, respectively. In 2007,

he received his Ph.D. degree in Control Engineering from Technical University of Catalonia (UPC). In 2007-2008, he held a postdoctoral position at University of Newcastle (Australia) and, afterwards (2008-2011) at the Spanish Research Council (CSIC), Institut de Robòtica i Informàtica Industrial (IRI), CSIC-UPC. Currently, he is Associate Professor at UPC, Automatic Control Department. Since 2014, he is also Deputy Director of IRI. His research interests include constrained predictive control, large-scale systems and industrial applications (mainly in water and energy).

Correspondence address: Universitat Politècnica de Catalunya, Llorens i Artigas, 4-6, 08028 Barcelona, Spain. e-mail: cocampo@iri.upc.edu