

Strathprints Institutional Repository

Grimble, M.J. (2006) *Design of generalized minimum variance controllers for nonlinear multivariable systems.* International Journal of Control, Automation and Systems, 4 (3). pp. 281-292. ISSN 1598-6446

Strathprints is designed to allow users to access the research output of the University of Strathclyde. Copyright © and Moral Rights for the papers on this site are retained by the individual authors and/or other copyright owners. You may not engage in further distribution of the material for any profitmaking activities or any commercial gain. You may freely distribute both the url (http:// strathprints.strath.ac.uk/) and the content of this paper for research or study, educational, or not-for-profit purposes without prior permission or charge.

Any correspondence concerning this service should be sent to Strathprints administrator: mailto:strathprints@strath.ac.uk



Grimble, M.J. (2006) Design of generalized minimum variance controllers for nonlinear multivariable systems. International Journal of Control, Automation and Systems, 4 (3). pp. 281-292. ISSN 1598-6446

http://strathprints.strath.ac.uk/7132/

This is an author-produced version of a paper published in International Journal of Control, Automation and Systems, 4 (3). pp. 281-292. ISSN 1598-6446. This version has been peer-reviewed, but does not include the final publisher proof corrections, published layout, or pagination.

Strathprints is designed to allow users to access the research output of the University of Strathclyde. Copyright © and Moral Rights for the papers on this site are retained by the individual authors and/or other copyright owners. You may not engage in further distribution of the material for any profitmaking activities or any commercial gain. You may freely distribute both the url (http://eprints.cdlr.strath.ac.uk) and the content of this paper for research or study, educational, or not-for-profit purposes without prior permission or charge. You may freely distribute the url (http://eprints.cdlr.strath.ac.uk) of the Strathprints website.

Any correspondence concerning this service should be sent to The Strathprints Administrator: eprints@cis.strath.ac.uk

Design of Generalized Minimum Variance Controllers for Nonlinear Systems

Michael J. Grimble

Abstract: The design and implementation of *Generalized Minimum Variance control laws for nonlinear multivariable systems that can include severe nonlinearities* is considered. The quadratic cost index minimised involves dynamically weighted error and nonlinear control signal costing terms. The aim here is to show the controller obtained is simple to design and implement. The features of the control law are explored. The controller obtained includes an internal model of the process and in one form is a nonlinear version of the Smith Predictor.

Keywords: Cost-function, delays, minimum variance, nonlinear, optimal control.

1. INTRODUCTION

The proposed control law is for nonlinear multivariable systems is based on a rich heritage. Åström introduced the Minimum Variance (MV) controller assuming the linear plant was minimum phase and later derived the MV controller for processes that could be non-minimum phase (Åström 1979 [1]). The latter was guaranteed to be stable on non-minimum phase processes, whereas the former was unstable. Hastings-James and later Clarke and Hastings-James (1971, [2]), modified the first of these control laws by adding a control costing term. This was termed a Generalized Minimum Variance (GMV) control law and enabled non-minimum phase processes to be stabilized, although when the control weighting tended to zero the control law reverted to the initial algorithm of *Åström*, which was unstable (Grimble 1981 [3], 1988 [4]). However, the control law had similar characteristics to Linear Quadratic Gaussian (LQG) design and in some cases and was much simpler to implement. This simplicity was exploited in the GMV self-tuner (1975, [5]). All of these results were applicable to linear discrete-time processes.

The aim in the following is to first introduce the

GMV controller for *Nonlinear* (*NL*) multivariable processes using dynamic cost-function weightings in the same spirit as the above results. The structure of the system is defined so that a simple controller and solution are obtained. When the system is linear the results then revert to those for the *GMV* controller (*Grimble* 2001 [8]).

There is some loss of generality in assuming the reference and disturbance models are represented by linear subsystems. However, the plant model can be in a very general nonlinear operator form, which might involve state-space, transfer operators or even nonlinear function look up tables. That is, the input sub-system to the plant might include valves or a servo-system that has no traditional equation based model. The input nonlinear subsystem can be a black box. No state-space or model based operator structure is needed. The optimal solution reveals all that is needed is a method of computing the output from such subsystem, given a control input. If on the an equation based model is available it may be used directly. For this reason the nonlinear part of the plant is represented in operator (unstructured form) for most of the analysis.

The nonlinear (*NL*) dynamic terms, in the plant, only need to be open loop stable and can include hard static nonlinearities or complex dynamic equations. The ability to introduce very general plant structures, without formal models, is an advantage of the method. This feature is similar to the properties of some controllers generated by feedback linearization methods (*Goodwin, Rojas and Takata,* 2001 [6]). However the plant model does not need to be affine in the control and feedback linearization methods do not of course provide a general solution that gives optimal disturbance rejection and tracking.

For linear systems stability is ensured when the combination of a control weighting function and an

Manuscript received October 29, 2005; accepted February 20, 2006. Recommended by Editorial Board member Jae Weon Choi under the direction of past Eitor-in-Chief Myung Jin Chung. This work was supported by the Engineering and Physical Science Research Council (EPSRC), grant No: EP/C526422/1. We would like to acknowledge the discussions and work by Pawel Majecki on the development of a comprehensive toolbox for implementing the algorithms and the example.

Michael J. Grimble is with the Industrial Control Centre, University of Strathclyde, Graham Hills Building, 50 George Street, Glasgow, G1 1QE, UK (e-mail: m.grimble@eee.strath. ac.uk).

error weighted plant model is strictly minimum phase. For nonlinear systems a related operator equation must have a stable inverse. It is shown that if there exists say a *PID* controller that will stabilize the nonlinear system, without transport delay elements, then a set of cost weightings can be defined to guarantee the existence of this inverse and thereby ensure the stability of the closed loop.

The results presented here concentrate on the feedback control problem and design/implementation issues. It only includes an abbreviated solution since the full solution of the Feedforward and Tracking Nonlinear Generalized Minimum Variance (NGMV) control problem was given in Grimble (2005 [11]). This required the solution of three bilateral Diophantine equations in [11]. The structure of the polynomial equations derived below, is rather different to those in [11] and for the feedback control here only one unilateral Diophantine equation is involved. The result is a truly nonlinear controller that is sufficiently straightforward to be used on real applications. In the following the properties of the control law are explored and the focus is on implementation and design issues.

2. SYSTEM DESCRIPTION

The system description is of restricted generality and is carefully chosen so that simple results are obtained. The plant itself is nonlinear and may have quite a general form. However, the reference and disturbance signals are assumed to have linear timeinvariant model representations. This is often valid, since in many applications the only models available for the disturbance and reference signals are LTI approximations. The system is shown in Fig. 1 and includes the nonlinear plant model and the linear reference/disturbance models. There is no loss of generality in assuming that the zero mean white noise sources $\{\omega(t)\}\$ and $\{\xi(t)\}\$ have identity covariance matrices. There is no requirement to specify the distribution of the noise sources, since the special structure of the system leads to a prediction equation, which is dependent upon the linear disturbance and reference models.

The polynomial matrix system models, for the multivariable system, shown in Fig. 1, may now be introduced. Part of the system is represented by linear models. The linear disturbance, reference and plant *output* subsystem models have the left-coprime polynomial matrix representation:

$$[W_d(z^{-1}), W_r(z^{-1}), W_{0k}(z^{-1})] = A^{-1}(z^{-1})[C_d(z^{-1}), E_r(z^{-1}), B_{0k}(z^{-1})].$$
(1)

The polynomial matrix system models follow:

Disturbance model:
$$W_d(z^{-1}) = A^{-1}(z^{-1})C_d(z^{-1})$$

Reference model:
$$W_r(z^{-1}) = A^{-1}(z^{-1})E_r(z^{-1}).(2)$$

The subsystem associated with the plant inputs is assumed to be unstructured and of the form:

Nonlinear plant model: $(Wu)(t) = D_k(W_ku)(t)$,(3)

where $D_k = \text{diag} \{z^{-k_1}, z^{-k_2}, ..., z^{-k_r}\}$ denotes the common delay elements in the respective output signal paths.

One of the main strengths of the method is that no model is required for the nonlinear subsystem: $(\mathcal{W}_k u)(t)$. It is necessary to have some means of computing the output from this block but a traditional equation based model is not essential. That is, *look-up tables* may be employed, *old Fortran code* may be available that enables the output to be computed for a given input, or as in current research, a *fuzzy-neural model*, may be fitted to plant data. These methods do not involve a conventional model.

Most of the results do not need a more detailed breakdown of the plant model structure. However, if the plant model is separated into an input subsystem W_{1k} and a linear subsystem W_{0k} then only the input nonlinear subsystem needs to be assumed stable (finite gain stable for example). In the later sections, to show the system can be stabilised, it will be assumed that any unstable modes of the linear plant subsystem are included in a stable/unstable linear time-invariant block of polynomial matrix form: $W_{0k} = A^{-1}B_{0k}$. The delay free plant model: $(W_k u)(t)$ $= W_{0k} (W_{1k}u)(t) = A^{-1}B_{0k} (W_{1k}u)(t)$ and the total plant model:

$$(\mathcal{W}u)(t) = D_k W_{0k} \left(\mathcal{W}_{1k}u \right)(t) , \qquad (4)$$

where it is assumed that this nonlinear model \mathcal{W}_{1k} is *finite gain stable*. Note the solution does not require the plant model be affine in the control. The signals shown in the system model of Fig. 1 may be listed:

Error signal: e(t) = r(t) - y(t), (5)

Plant output: $y(t) = d(t) + (\mathcal{W}u)(t)$, (6)

Reference: $r(t) = W_r \omega(t)$, (7)

Disturbance signal:
$$d(t) = W_d \xi(t)$$
, (8)

Combined signal:
$$f(t) = r(t) - d(t)$$
. (9)

The *power spectrum* for the combined reference – disturbance:

$$\Phi_{ff} = \Phi_{rr} + \Phi_{dd} = W_r W_r^* + W_d W_d^*$$
(10)

and the *spectral-factor* Y_f satisfies:

$$Y_f Y_f^* = \Phi_{ff} , \qquad (11)$$

where the system models ensure Y_f is strictly minimum phase. A measurement noise model has not been included to simplify the equations. This is appropriate so long as the control cost-function weighting, ensures controller roll-off at *HF*.

3. NONLINEAR GMV CONTROL PROBLEM

The optimal *NGMV* control problem involves the minimisation of the variance of the signal $\{\phi_0(t)\}$ in Fig. 1. This has a $(r \times m)$ dynamic cost-function weighting matrix: $P_c(z^{-1})$ on the error signal, represented by linear polynomial matrices as: $P_c = P_{cd}^{-1}P_{cn}$. The signal also includes an *m*-square, nonlinear dynamic control signal costing operator term: $(\mathcal{F}_c u)(t)$. Typically P_c is low-pass and \mathcal{F}_c is a high-pass transfer. The signal:

$$\phi_0(t) = P_c e(t) + (\mathcal{F}_c u)(t) \tag{12}$$

is to be minimized in a variance sense, so the cost:

$$J = E\left\{\phi_0^T(t)\phi_0(t)\right\} = E\left\{trace\left\{\phi_0(t)\phi_0^T(t)\right\}\right\}, \quad (13)$$

where $E\{\cdot\}$ denotes the unconditional expectation operator. If the smallest of the delays in each output channel of the plant are of magnitudes: $\{k_1, k_2, ..., k_r\}$, respectively, this implies the control signal at time *t* affects the *j*th output at least k_j steps later. For this reason the control signal costing can be defined as:

$$\left(\mathcal{F}_{\mathbf{c}}u\right)(t) = D_k\left(\mathcal{F}_{\mathbf{c}k}u\right)(t). \tag{14}$$

Typically this will be a linear operator but it may be nonlinear to cancel the plant input nonlinearities in appropriate cases. The control weighting operator \mathcal{F}_{ck} is assumed full rank and invertible.

Theorem 3.1: NGMV Optimal Controller

The *NGMV* optimal controller to minimize the variance of the weighted error and control signals may be computed from the following equations. The assumptions are made that the input subsystem W_{lk} is finite gain stable and the nonlinear operator $(P_c \mathcal{M}_k - \mathcal{F}_{ck})$ has a finite gain stable causal inverse, due to the choice of weighting operators P_c and \mathcal{F}_c .

The smallest degree solution: (G_0, F_0) , with respect to F_0 , must be computed from the polynomial matrix unilateral Diophantine equation:

$$A_p P_{cd} F_0 + D_k G_0 = P_{cf} D_f , \qquad (15)$$

where the left coprime polynomial matrices satisfy:



Fig. 1. Single degree of freedom feedback.

$$A_p^{-1} P_{cf} = P_{cn} A^{-1} \tag{16}$$

and the spectral factor: $Y_f = A^{-1}D_f$.

Optimal control signal: The optimal NGMV control action can be computed as:

$$u(t) = \left(F_0 Y_f^{-1} \mathcal{M}_k - \mathcal{F}_{ck}\right)^{-1} \left(\left(A_{pf} P_{cd}\right)^{-1} G_0 Y_f^{-1} e\right)(t). (17)$$

Proof: Involves collecting results in next section. \Box

The solution is simplified if D_k and weighting P_c and Y_f commute. This assumption is valid if the delay elements are the same in each channel $D_k = z^{-k}I$ or if P_c , Y_f are diagonal. The class of problems considered are those for which a solution to the *Diophantine equation* can be found where the row degrees of $F_0(z^{-1})$ are less than the delay path magnitudes $\{k_1, k_2, ..., k_r\}$ and this is ensured under the conditions listed in the previous remark.

4. NGMV NONLINEAR OPTIMAL CONTROL

A simple optimisation argument is used in the following. The signal to be minimised is shown to consist of both linear and nonlinear terms. However, the stochastic part of the problem involves linear models so that a prediction equation may easily be derived. This enables the signal to be written in terms of *future* and *past* white noise related terms. The optimal *causal* solution is therefore that which sets the past terms to zero. This will include some of the nonlinear terms and the optimal control follows.

Consider the minimisation of $\phi_0(t)$ that represents the weighted sum of error and control signals and is the same dimension as the input signal. This fictitious or inferred output is defined as: $\phi_0(t) = P_c e(t) + (\mathcal{F}_c u)(t)$, where P_c is assumed to be a linear and \mathcal{F}_c can be a linear or nonlinear operator. Now from the equations in §2: e = r - y = r - d - Wu and hence, Michael J. Grimble

$$\phi_0(t) = P_c(r-d) - \left(P_c \mathcal{W} - \mathcal{F}_c\right)u.$$
(18)

Assumption: An important assumption will now be recalled that does not affect stability properties. That is, the model for signal f = r - d is assumed linear.

Spectral factor: Recall the innovations model for the signal: $f = Y_f \varepsilon$, where Y_f is a linear transfer and $\varepsilon(t)$ denotes a zero mean white noise signal of identity covariance matrix. This follows from a spectral-factor computation, given the disturbance W_d and the reference W_r signal models. The $Y_f = A^{-1}D_f$ where from the system description D_f is *strictly Schur*. Thence, from the first term in (18): $P_c(r-d) = P_c f$ $= P_{cd}^{-1}P_{cn}A^{-1}D_f\varepsilon$. Introduce the left coprime matrices A_p and P_{cf} where $P_{cn}A^{-1} = A_p^{-1}P_{cf}$ then $P_cf = (A_pP_{cd})^{-1}$

 $P_{cf}D_f\varepsilon$ and from (15) the weighted error and control signals:

$$\phi_0 = \left(A_p P_{cd}\right)^{-1} P_{cf} D_f \varepsilon - \left(P_c \mathcal{W} - \mathcal{F}_c\right) u .$$
(19)

Introduce the Diophantine equation, to expand the *combined disturbance and reference model* into two groups of terms:

$$A_p P_{cd} F_0 + D_k G_0 = P_{cf} D_f , \qquad (20)$$

where the solution for (F_0, G_0) satisfies the row j degree of $F_0 < k_j$. Hence,

$$P_{c}Y_{f} = \left(A_{p}P_{cd}\right)^{-1}P_{cf}D_{f} = F_{0} + \left(A_{p}P_{cd}\right)^{-1}D_{k}G_{0}.(21)$$

The first polynomial matrix includes delay elements in the jth channel, up to and including z^{-k_j+1} and the last term involves delay elements greater than or equal to k_j in each channel. Substituting into (19):

$$\phi_0 = F_0 \varepsilon + \left(A_p P_{cd}\right)^{-1} D_k G_0 \varepsilon - \left(P_c \mathcal{W} - \mathcal{F}_c\right) u \quad (22)$$

but $\varepsilon = Y_f^{-1}f = Y_f^{-1}(r-d)$ and substituting in (22):

$$\phi_{0} = F_{0}\varepsilon + (A_{p}P_{cd})^{-1}D_{k}G_{0}Y_{f}^{-1}e$$

$$+ ((A_{p}P_{cd})^{-1}(D_{k}G_{0} - A_{p}P_{cd}P_{c}Y_{f})Y_{f}^{-1}W + \mathcal{F}_{c})u$$
(23)

but $A_p P_{cd} P_c Y_f = A_p P_{cn} A^{-1} D_f = P_{cf} D_f$ and hence (20) gives: $D_k G_0 - P_{cf} D_f = -A_p P_{cd} F_0$.

These last two equations then give the desired weighted error and control signal as:

$$\phi_0 = F_0 \varepsilon + \left(A_p P_{cd}\right)^{-1} D_k G_0 Y_f^{-1} e + \left(\mathcal{F}_c - F_0 Y_f^{-1} \mathcal{W}\right) u.(24)$$

The control signal at time *t* affects the jth system output at time $t+k_j$ and hence the control signal costing term \mathcal{F}_c should include a delay of k_j steps, so that $\mathcal{F}_c = D_k \mathcal{F}_{ck}$. Moreover, since in general the control signal costing is required on each signal channel, the \mathcal{F}_{ck} weighting may be defined to be of full rank and invertible. (24) may be simplified further if $A_p P_{cd}$ and D_k and $F_0 Y_f^{-1}$ and D_k commute, which is certainly the case under the assumptions on P_c and Y_f discussed after the Theorem at the end of the last section. From (24) the inferred or fictitious output may be written as:

$$\phi_0(t) = F_0 \varepsilon(t) + D_k [(\mathcal{F}_{ck} u)(t) - F_0 Y_f^{-1} (\mathcal{W}_k u)(t) + (A_p P_{cd})^{-1} G_0 Y_f^{-1} e(t)].$$
(25)

To compute the optimal control signal inspect the form of the weighted error and control signals in equation (25). Since the row degrees of F_0 are required to be less than k_j (the magnitude of the delay in the jth channel) the jth row of the first term is dependent upon the values of the white noise signal components: $\varepsilon(t)$,..., $\varepsilon(t-k_j+1)$. The remaining terms in the expression for the jth row are all delayed by at least k_j steps and therefore depend upon the earlier values: $\varepsilon(t-k_j)$, $\varepsilon(t-k_j-1)$, and it follows the first and remaining terms are statistically independent. The first term on the right of (25) is independent of the control action and the smallest variance is achieved when the remaining terms are zero. The optimal control signal must satisfy:

$$u(t) = \mathcal{F}_{ck}^{-1} \bigg(F_0 Y_f^{-1} (\mathcal{W}_k u)(t) - \big(A_p P_{cd} \big)^{-1} G_0 Y_f^{-1} e(t) \bigg) (26)$$

and this may be represented by the Fig. 2. Note the signal $\phi_0 = P_c e + \mathcal{F}_c u = P_c (r - y) + \mathcal{F}_c u$ involves a weighting \mathcal{F}_c that normally has a negative zero frequency gain. The forward path gain of the controller block is therefore usually positive.



Fig. 2. NGMV control generation and controller.

An alternative expression for the control signal, in terms of the exogenous signals may be found that is useful for stability analysis. From (26), recalling $F_0Y_f^{-1}$ and D_k , commute, the optimal control:

$$u(t) = \mathcal{F}_{ck}^{-1} [F_0 Y_f^{-1} (\mathcal{W}_k u)(t) - (A_p P_{cd})^{-1} G_0 Y_f^{-1} (r(t) - d(t) - (\mathcal{W} u)(t))]$$

but $F_0Y_f^{-1} + (A_p P_{cd})^{-1} D_k G_0 Y_f^{-1} = P_{cd}^{-1} P_{cn}$. Thence, $u(t) = \mathcal{F}_{ck}^{-1} (P_c (\mathcal{W}_k^* u)(t) - (A_p P_{cd})^{-1} G_0 Y_f^{-1} (r-d)(t))$.

Alternatively, rewriting:

$$u(t) = \left(P_{c}\mathcal{W}_{k} - \mathcal{F}_{ck}\right)^{-1} \left(A_{p}P_{cd}\right)^{-1} G_{0}Y_{f}^{-1}(r(t) - d(t)), (27)$$

where the existence of a *finite gain stable* causal inverse of the nonlinear operator $(P_c \mathcal{W}_k - \mathcal{F}_{ck})$ ensures the control action represents a stable system.

The system output follows as: m(t) = (Wu)(t) and

since the cascade controller sub-system $(A_p P_{cd})^{-1}$ $G_0 Y_f^{-1}$ must be implemented in its minimal form, it follows the output does not involve cancellation of any unstable modes present in $W_{0k}(z^{-1})$ and internal stability is preserved.

5. IMPLEMENTATION OF CONTROLLER

The implementation of the controller shown in Fig. 2 reveals that the computational complexity increases with the model order and number of inputs and outputs since the plant model is included. A way to reduce part of this burden is described later (the *RS* version).

To consider the implementation of the control law recall from (17) that the optimal control signal is given as: $u(t) = (F_0 Y_f^{-1} \mathcal{W}_k - \mathcal{F}_{ck})^{-1} p(t)$ where $p(t) = (A_p P_{cd})^{-1} G_0 Y_f^{-1} e(t)$ as shown in Fig. 2. Introducing non-singular constant scaling matrix: Y_0 the control

$$u(t) = (Y_0^{-1}F_0D_f^{-1}B_{0k} \mathcal{W}_{1k} - Y_0^{-1}\mathcal{F}_{ck})^{-1}(Y_0^{-1}(A_pP_{cd})^{-1}G_0Y_f^{-1}e)(t)$$

and

signal may be written, using (4) as:

$$(Y_0^{-1}F_0D_f^{-1}B_{0k}\mathcal{W}_{1k} - \mathcal{F}_{cy})u(t) = (A_pP_{cd}Y_0)^{-1}G_0Y_f^{-1}e(t), (28)$$

where $\mathcal{F}_{ck} = Y_0 \mathcal{F}_{cy}$ and $(Y_0^{-1} F_0 D_f^{-1} B_{0k} \mathcal{W}_{1k} - \mathcal{F}_{cy})^{-1}$ may then be computed, assuming the existence of the inverse \mathcal{F}_{cy}^{-1} Redefine the scaled signal p(t) as:

$$p(t) = (A_p P_{cd} Y_0)^{-1} G_0 Y_f^{-1} e(t)$$

= $Y_0^{-1} F_0 D_f^{-1} B_{0k} (\mathcal{W}_{1k} u)(t) - (\mathcal{F}_{cy} u)(t).$ (29)

Then the control signal:

$$u(t) = \mathcal{F}_{cy}^{-1} \Big(Y_0^{-1} F_0 D_f^{-1} B_{0k} \big(\mathcal{W}_{1k} u \big)(t) - p(t) \Big).$$

Unfortunately this solution requires iteration, since the right-hand side includes: u(t). This represents an algebraic loop and to avoid this problem the operator $(Y_0^{-1}F_0D_f^{-1}B_{0k}\mathcal{M}'_{1k} - \mathcal{F}_{cy})$ may be split into two parts involving a through term, without a delay \mathcal{N}_0 and a term that depends upon past values of the control action, denoted $z^{-1}\mathcal{N}_1$. That is, $p(t) = (Y_0^{-1}F_0D_f^{-1}B_{0k}\mathcal{M}'_{1k} - \mathcal{F}_{cy})u = (\mathcal{N}_0u)(t) + (z^{-1}\mathcal{N}_1u)(t)$ so that the control:

$$u(t) = \mathcal{N}_0^{-1} \left(p(t) - (z^{-1} \mathcal{N}_1 u)(t) \right).$$
(30)

These results suggest the method of implementing the inverse operator in Fig. 3. To obtain a more explicit description of \mathcal{N}_0 and \mathcal{N}_1 let the nonlinear plant model subsystem: $\mathcal{M}_{1k} = \mathcal{G}_0 + z^{-1}\mathcal{G}_1$ and let the linear terms: $Y_0^{-1}F_0D_f^{-1}B_{0k} = L_0 + z^{-1}L_1$ where these nonlinear and linear terms \mathcal{G}_0 and L_0 include no delay terms. Also let \mathcal{F}_{cy} be split into a non-dynamic through term: \mathcal{F}_{c0} and a term: $z^{-1}\mathcal{F}_{c1}$. That is, $\mathcal{F}_{cy} =$ $\mathcal{F}_{c0} + z^{-1}\mathcal{F}_{c1}$ and

$$\mathcal{N}u = (Y_0^{-1}F_0D_f^{-1}B_{0k}\mathcal{M}_{1k} - \mathcal{F}_{cy})u = (L_0\mathcal{G}_0 - \mathcal{F}_{cy} + z^{-1}(\mathcal{G}_1 + L_1\mathcal{M}_{1k}))u$$
(31)
= $(\mathcal{N}_0u)(t) + (z^{-1}\mathcal{N}_1u)(t)$.

Hence identify: $(\mathcal{N}_0 u)(t) = (L_0 \mathcal{G}_0 - \mathcal{F}_{c0}) u(t)$ and $(\mathcal{N}_1 u)(t) = (\mathcal{G}_1 + L_1 \mathcal{W}_{1k} - \mathcal{F}_{c1}) u(t)$. (32)

It is clear the algebraic loop is removed in the implementation of the inverse operator in Fig. 3. Note



Fig. 3. NL operator and inverse.

that this term L_0 is not diagonal naturally and complicates the computation of \mathcal{N}_0^{-1} which involves the inverse of the operator: $(L_0\mathcal{G}_0 - \mathcal{F}_{c0})$.

This can be simplified if an appropriate scaling is used as described below. Let Y_0 denote the constant full rank matrix: $Y_0 = F_0(0)D_f(0)^{-1}B_{0k}(0)$, then this may be used to normalise and diagonalise the fist z^0 term in the denominator of the expression for the optimal control in (28). It is interesting that the scaling matrix Y_0 may be related to the weighted plant model, by noting from (15) and (16):

$$F_0 D_f^{-1} + P_{cd}^{-1} A_p^{-1} D_k G_0 D_f^{-1} = P_c A^{-1}$$

and this gives:

$$Y_0 = F_0(0)D_f(0)^{-1}B_{0k}(0) = P_c(0)W_{0k}(0) .$$
 (33)

Recall that in the previous section the term Y_0^{-1} $F_0 D_f^{-1} B_{0k}$ was expanded into a constant matrix and terms that are delayed by at least one step:

$$Y_0^{-1}F_0D_f^{-1}B_{0k} = L_0 + z^{-1}L_1$$
(34)

but when the scaling (33) is applied the constant matrix: $L_0 = I$. Clearly \mathcal{F}_{c0} can also be taken as a diagonal matrix function so that in the majority of problems the operator term:

$$(\mathcal{N}_0 u)(t) = \left(L_0 \mathcal{G}_0 - \mathcal{F}_{c0}\right) u(t) = \left(\mathcal{G}_0 - \mathcal{F}_{c0}\right) u(t)$$

in (32) is easy to invert, even noting that both of these terms may involve a nonlinear and multivariable process. The scaling suggested above ensures the direct control related terms have corresponding diagonal structures for most problems.

If it is complicated to compute the inverse of the non-dynamic function: \mathcal{N}_0 a modified strategy can be applied. Assuming the existence of the inverse of \mathcal{G}_0 and L_0 (30) can be written, noting (31) as:

$$u(t) = \mathcal{N}_0^{-1} \left(p(t) - (z^{-1} \mathcal{N}_1 u)(t) \right)$$
(35)

$$= (\mathcal{G}_0)^{-1} L_0^{-1} \Big(p(t) - (z^{-1} \mathcal{N}_1 u)(t) + \mathcal{F}_{c0} u(t) \Big). (36)$$

The term \mathcal{F}_{c0} is often small so that although this expression involves an algebraic loop the result can considerably reduce the computation time. If the nonlinearity is represented by a black box the above method of avoiding the algebraic loop does not hold. In this case the function \mathcal{N}_0 can be found by experiment, inputting a unit pulse at different operating points and fitting a smooth function. The operator \mathcal{N}_1 can again be defined as: $z^{-1}\mathcal{N}_1$ $= \mathcal{N} - \mathcal{N}_0$ but since errors are inevitable there remains the possibility of a small through term that will prolong an iterative solution of the inverse operator equations. To avoid this component a possible strategy, is to define the model with zeroed initial states/conditions as: $\mathcal{F}_0 = \mathcal{N} - \mathcal{N}_0$ and compute the signal: $(\mathcal{F}_0 u)(t)$ just for u at time t. This can then be subtracted from the output of the block: $((\mathcal{N} u)(t) - (\mathcal{N}_0 u)(t))$ to ensure the error at the operating point is zero. Note that this complication is only introduced when black box models are used for the nonlinear subsystem and it may not be necessary.

The result (27) indicates a necessary condition for optimality is that the operator $(P_c \mathcal{W}_k - \mathcal{F}_{ck})$ must have a stable inverse. This reveals that one of the restrictions on the choice of cost weightings is that this stability condition be fulfilled. An important question is whether sensible choices of the weightings will lead to this condition. Consider the case where \mathcal{F}_{ck} is linear and $\mathcal{F}_{ck} = -F_k$. Then,

$$\left(P_{c}\mathcal{W}_{k}+F_{k}\right)u=F_{k}\left(F_{k}^{-1}P_{c}\mathcal{W}_{k}+I\right)u$$
(37)

and note that the term $(I + F_k^{-1}P_c\mathcal{W}_k)$ represents the return-difference for a system with controller:

$$K_c = F_k^{-1} P_c \,. \tag{38}$$

This is important since it provides a starting point for cost weighting selection. That is, consider the delay free plant \mathcal{W}_k and assume a *PID* controller exists *Kc* to stabilize the closed loop system. Then a weighting choice, that will ensure $(P_c\mathcal{W}_k + F_k)$ is stably invertible, is $F_k^{-1}P_c = K_c$. The controller expression may also be expressed in a slightly different form, using the inverse of the NL operator (from (26)) as:

$$u(t) = (F_0 D_f^{-1} B_{0k} \mathcal{W}_{1k} - \mathcal{F}_{ck})^{-1} \Big((A_p P_{cd})^{-1} G_0 Y_f^{-1} e \Big)(t).$$
(39)

The controller then has the structure shown in Fig. 4, showing the nonlinear compensator block.

Minimum Cost: This may be found from (25):

$$\phi_0(t) = F_0 \varepsilon(t) + D_k \left\{ \left(\left(\mathcal{F}_{ck} - F_0 Y_f^{-1} \mathcal{W}_k \right) u \right) (t) + \left(A_p P_{cd} \right)^{-1} G_0 Y_f^{-1} e(t) \right\}$$

$$(40)$$

and if at the optimum the term within the braces is null then $\phi_{0\min}(t) = F_0\varepsilon(t)$ and the *minimum cost*:

$$J_{\min} = E\left\{ \left(F_0 \varepsilon(t) \right)^T \left(F_0 \varepsilon(t) \right) \right\}$$



Fig. 4. Equivalent single DOF NL system.

$$= \frac{1}{2\pi j} \oint_{|z|=1} trace \left\{ F_0 \left(z^{-1} \right) F_0 \left(z^{-1} \right)^* \right\} \frac{dz}{z} .$$
(41)

This expression for the minimum cost can provide a benchmark cost for nonlinear controller design and depends only on the reference and disturbance signal models that are linear, time invariant (*LTI*). This arises because the control action effectively removes the nonlinear plant model from the prediction of $\{\phi(t)\}$, whose variance is being minimised.

6. NONLINEAR SMITH PREDICTOR AND RESTRICTED STRUCTURE CONTROLLER

The optimal controller can be expressed in a similar form to that of a *Smith Predictor*. This provides a new nonlinear version of the Smith Predictor. Moreover, it provides an optimal method of tuning and provides optimal stochastic disturbance rejection and tracking properties. However, the introduction of this structure also limits the application of the solution on openloop unstable systems. Although the structure illustrates a useful link between the new solution and the Smith time delay compensator, it also has the same disadvantage, that it may only be used on open-loop stable systems. The Nonlinear Smith Predictor will now be derived. Observe that the system in Fig. 2 may be redrawn as in Fig. 5. The changes are made to the linear subsystems by adding and subtracting equivalent terms. Now combine the two linear inner loop blocks, by first defining the signal:

$$m_k(t) = (\mathcal{M}_k u)(t) \tag{42}$$

as follows:

$$\left(F_0 Y_f^{-1} + \left(A_p P_{cd}\right)^{-1} G_0 Y_f^{-1} D_k\right) m_k$$

= $\left(A_p P_{cd}\right)^{-1} \left(A_p P_{cd} F_0 + D_k G_0\right) Y_f^{-1} m_k$ (43)

but from (20), assuming D_k and G_0 commute:

$$(F_0 Y_f^{-1} + (A_p P_{cd})^{-1} G_0 Y_f^{-1} D_k) m_k = P_c m_k.$$
(44)

The system may therefore be redrawn as shown in Fig. 6 where the control action clearly satisfies equation: (27). Now observe that the compensator may be rearranged, as shown in Fig. 7. This latter



Fig. 5. Modification to the controller structure.



Fig. 6. Nonlinear smith predictor compensator.



Fig. 7. NL Smith predictor compensator and internal model ($\psi_0 = P_{cd}\psi$).

structure is essential if P_c includes an integrator, which introduces integral action. That is, P_{cd}^{-1} must be placed in the *inner error* channel, rather than in individual blocks as in Fig. 6.

6.1. Restricted structure low order implementation

The NGMV controller structure is already simple to understand and implement but in some industries the experience gained at using a PID parameterisation of a controller is so important it suggests replacing the cascade linear block by a low order parameterised model. This involves a parallel of the so-called *Restrictive Structure (RS)* control design method for linear systems introduced by Grimble (2000 [7]). The cascade linear subsystem in Fig. 1 can then be simplified to a given lower order controller structure where the cascade block is parameterised and the unknown coefficients optimised directly. This is possible since the minimum cost expression, when the inner *nonlinear* block is unchanged, only depends upon the cascade term in the above figure. This may be shown since, from (27), the optimal control:

$$u(t) = \left(P_{c}\mathcal{W}_{k} - \mathcal{F}_{ck}\right)^{-1} \left(A_{p}P_{cd}\right)^{-1} G_{0}Y_{f}^{-1}(r(t) - d(t))$$

Denote the linear cascade block in Fig. 2 or Fig. 6 as: $G_c = (A_p P_{cd})^{-1} G_0 Y_f^{-1}$. If this block is to be simplified by using a restricted structure then the parameterised cascade transfer (say a PID block) might be denoted as: \tilde{G}_c and the sub-optimal control:

$$\tilde{u}(t) = (P_c \mathcal{W}_k - \mathcal{F}_{ck})^{-1} \tilde{G}_c(r(t) - d(t)).$$
(45)

Substituting into (19), recalling $P_{cn}A^{-1} = A_p^{-1}P_{cf}$,

$$\tilde{\phi}_{0} = \left(A_{p}P_{cd}\right)^{-1} P_{cf}D_{f} \varepsilon - \left(P_{c}\mathcal{W} - \mathcal{F}_{c}\right)\tilde{u}$$

$$= \left(A_{p}P_{cd}\right)^{-1} P_{cf}D_{f} \varepsilon(t) - D_{k}\tilde{G}_{c}\left(r\left(t\right) - d\left(t\right)\right) (46)$$

$$= \left(P_{c} - D_{k}\tilde{G}_{c}\right)Y_{f}\varepsilon.$$
(47)

The cascade block \tilde{G}_c is linear and the output when this block is used is given by the linear system in equation: (47). It follows that the very same algorithms that has been used by *Grimble* (2002 [9]) for linear systems which directly optimises the cost index may be applied. Note that assuming that D_k commutes (44) reveals that as expected (47) simplifies to $F_0\varepsilon(t)$ in the optimal ($G_c = \tilde{G}_c$) case.

If greater simplification is demanded the inner nonlinear loop in Fig. 1 has to be simplified but in this case the nonlinear operator does not cancel when forming: (46). The problem is then no longer linear and the simple RS method does not apply. However, a so-called *multiple model RS* approach (Grimble 2002 [9]) has also been suggested for nonlinear systems. This technique may be applied to simplify the inner loop where the first step is to linearize the delay free plant model at a number of operating points. The single linear inner feedback loop block can then be calculated that minimises the cost function that is averaged over the different models. Note that the NL model for the plant is still included in the inner loop. Thus the controller remains nonlinear but with a simpler inner-loop linear sub-system. The resulting RS strategy should simplify the controller sub-systems simplify implementation.

7. NONLINEAR GMV CONTROL PROBLEM

The computation of a *NGMV* controller is illustrated below in the design of a scalar nonlinear discrete-time dynamic system, given in the following

very nonlinear state-space form:

$$x_{1}(t+1) = \frac{x_{1}(t) \cdot x_{2}(t)}{1 + x_{1}^{2}(t)} + u(t),$$

$$x_{2}(t+1) = e^{-x_{1}^{2}(t)x_{2}^{2}(t)} + u(t),$$

$$y(t) = x_{1}(t-4).$$
(48)

Let the initial state x(0) = 0. Observe that the output y(t) includes an explicit transport delay of k = 5 samples. The open-loop system response to a series of steps is shown in Fig. 8, and the nonlinearity present in the system is clearly evident from the range of responses. The polynomial system models for the disturbance and reference models have the form: $A = 1-1.79z^{-1} + 0.792z^{-2}$, $C_d = 0.05-0.0495z^{-1}$, $E_r = 0.05 - 0.04z^{-1}$ and Ap = A.

For the *nonlinear GMV* controller design, the linear reference model has been defined as: $W_r = 0.05 (1-0.99z^{-1})$, and is the stochastic analogue of a near step reference changes. The model of the additive linear disturbance acting on the system output was chosen as: $W_d = 0.05/(1-0.8z^{-1})$.

Assume the plant is controlled by the nominal stabilizing PID controller, denoted: $C_1(z^{-1})$, with filtered derivative term:

$$C_1(z^{-1}) = K \left(1 + \frac{1}{T_i(1 - z^{-1})} + \frac{T_d(1 - z^{-1})}{(1 - \tau_d z^{-1})} \right)$$
 and with the

tuning parameters: K=0.1, $T_i=4s$, $T_d=1s$ and $\tau_d=0.5$. As explained in Section 5.2, the initial choice of dynamic weightings for the *NGMV* design may be defined in terms of this controller as: $P_c(z^{-1}) = C_1(z^{-1})$, $F_c(z^{-1}) = -z^{-4}$. The Bode plots of these weightings are shown in Fig. 9. The reference tracking of a sequence of steps for the two nominal controllers is shown in Fig. 10, and the corresponding output and control signal variances are collected in Table 1.



Fig. 8. Open-loop plant responses.



Fig. 9. Frequency responses of the dynamic weightings (nominal design).

Note that the nominal *PID* tuning parameters have only been found to stabilize the delay-free plant and are not *optimized* in any sense. However, this controller is useful in that it can provide initial design parameters for the *NGMV* controller that will stabilize the plant, ie. make the nonlinear operator stable and invertible.

Computation of NGMV control law: The cost weightings implied by the *PID controller become:*

1

and the polynomials in Fig. 2 have the solutions:

$$F_0 = 0.0162 + 0.0133 \text{ z}^{-1} + 0.0125 \text{ z}^{-2} + 0.0127 \text{ z}^{-3},$$

$$G_0 = 0.0134 - 0.0298 \text{ z}^{-1} + 0.0215 \text{ z}^{-2} - 0.0050 \text{ z}^{-3},$$

and $D_f = 0.0721 \cdot 0.0621 z^{-1}$. The optimal control may then be calculated from (26) or as in Fig. 2:

$$u(t) = \mathcal{F}_{ck}^{-1} \bigg(F_0 Y_f^{-1} \big(\mathcal{W}_k u \big) \big(t \big) - \big(A_p P_{cd} \big)^{-1} G_0 Y_f^{-1} e \big(t \big) \bigg).$$
(49)

As can be seen from Fig. 10 and Table 1, the performance of the initial nonlinear controller design is close to that of the original *PID*, although it is normally more robust to the changes of the operating point (this can be seen for the set-point equal to zero). The stochastic performance of the nonlinear controller is also slightly better. The importance of this result is not the controller produced but that it provides a painless way to obtain an initial choice of cost weightings.

The nominal design may be modified by changing the control weighting. Parameterize the weighting as: $F_{ck} = -\rho(1 - \gamma z^{-1})$, where ρ is a positive scalar



Fig. 10. Time responses nominal PID and NGMV controllers.

Table 1. Stochastic performance: Nominal PID and NGMV controllers.

Op. point	Controller	Var[e]	Var[u]	Var[phi]
3	PID	0.01662	0.00117	0.00082
	NGMV	0.01672	0.00104	0.00082
0	PID	0.01568	0.00046	0.00054
	NGMV	0.01180	0.00025	0.00038
-1	PID	0.01122	0.00168	0.00051
	NGMV	0.01117	0.00166	0.00052
-3	PID	0.00729	0.00115	0.00035
	NGMV	0.00726	0.00115	0.00033



Fig. 11. Frequency response of the weightings (P_c solid, F_c ($\gamma = 0$) dashed, F_c with $\rho = 1$ dotted).

and γ is a value from 0 to 1, to introduce a lead term. This is useful to reduce the high frequency gain of the controller. For the nominal design: $\rho = 1$ and $\gamma = 0$. The Bode plots are shown in Fig. 11. The parameterization of the weightings involves two tuning parameters and is meant to simplify the design. Decreasing the value of ρ (reducing the control



Fig. 12. Time responses for weighting parameters: $\rho = 0.5, 0.7, 1, 2; (\gamma = 0).$

Table 2. Stochastic performance for weighting parameters: $\rho = 0.5, 0.7, 1, 2; \gamma = 0$.

Op. point	rho	Var[e]	Var[u]	Var[phi]
3	0.5	0.01528	0.00334	0.00263
	0.7	0.01515	0.00199	0.00162
	1	0.01512	0.00120	0.00131
	2	0.01518	0.00049	0.00169
0	0.5	0.01330	0.00095	0.00233
	0.7	0.01324	0.00059	0.00126
	1	0.01322	0.00035	0.00077
	2	0.01312	0.00013	0.00055
-1	0.5	0.01042	0.00345	0.00352
	0.7	0.01017	0.00201	0.00171
	1	0.01015	0.00117	0.00127
	2	0.01023	0.00063	0.00214
-3	0.5	0.00604	0.00182	0.00258
	0.7	0.00593	0.00129	0.00140
	1	0.00595	0.00089	0.00104
	2	0.00617	0.00042	0.00141

weighting) leads to a faster response and a more violent control action. This can be seen from the stochastic performance results (with added disturbance noise). Interestingly, there is little change in the error variance. Decreasing ρ to a value of 0.35 leads to some undesirable oscillations. Adding a lead term resolves this problem. Fig. 12 and Table 2 present the simulation results for different values of ρ ($\gamma = 0$). Increasing ρ results in a slower response providing a simple tuning mechanism.

For comparison, the nominal *PID* controller has been retuned and compared with that of the *NGMV* controller with $\rho = 0.5$ and $\gamma = 0.3$. The results are presented in Fig. 13 and Table 3. After many attempts, a set of *PID* parameters were obtained close to the NGMV design in terms of speed of response, but the



Fig. 13. Responses for retuned PID and NGMV.

Table 3. Performance for retuned PID – NGMV.

Op. point	Control	Var[e]	Var[u]	Var[phi]
3	PID	0.03724	0.03473	0.00184
	NGMV	0.03485	0.03800	0.00124
0	PID	0.03170	0.01567	0.00135
	NGMV	0.02768	0.01677	0.00087
-1	PID	0.03164	0.12969	0.00373
	NGMV	0.02856	0.15558	0.00092
-3	PID	0.02519	0.06335	0.00198
	NGMV	0.02336	0.06492	0.00076

NL plant still caused some oscillatory behaviour in the PID control design responses.

Fig. 14 and Table 4 present the simulation step response results for different values of γ ($\rho = 0.35$, rescaled for constant DC gain).

In the last experiment, the plant time delay was increased from 4 to 10 samples. For the controller design, the same weightings were used as before but the *NGMV* controller obtained was of course different, reflecting the change in the time-delay. Then the Nonlinear Control Design Blockset of Matlab was used to find the optimal *PID* parameters, given the desired response. The boundary constraints were relaxed until a feasible set of parameters was found. However, it was not possible to tune the PID controller for satisfactory responses, across the whole operating range.

Fig. 15 shows the response of the *NGMV* design and 2 of the *PID* controllers obtained. The dynamic response of the *NGMV* controller is very close to that in Fig. 14, despite the significant increase in the time delay. It was not possible to obtain, for the *PID* controllers, both fast transient responses at the operating point = 3 and no oscillatory behaviour at the operating point = 0.

The *PID* controller did not have time delay compensation, so it might be argued that it is not a fair



Fig. 14. Responses for $\rho = 0.35$, $\gamma = 0, 0.3, 0.6, 0.9$.

Op. point	Gamma	Var[e]	Var[u]	Var[phi]
3	0	0.01857	0.00917	1.01559
	0.3	0.01826	0.00578	0.31276
	0.6	0.01813	0.00358	0.11540
	0.9	0.01771	0.00215	0.01998
0	0	0.02495	0.00257	0.87553
	0.3	0.02592	0.00190	0.35453
	0.6	0.02847	0.00154	0.13790
	0.9	0.05257	0.00198	0.02958
-1	0	0.04224	0.02324	20.15882
	0.3	0.01305	0.00703	0.33807
	0.6	0.01261	0.00575	0.12317
	0.9	0.01218	0.00414	0.02745
-3	0	0.01158	0.00458	1.00197
	0.3	0.01112	0.00406	0.31726
	0.6	0.01098	0.00382	0.12312
	0.9	0.01031	0.00323	0.02547

Table 4. Performance: $\rho = 0.35$, $\gamma = 0, 0.3, 0.6, 0.9$.



Fig. 15. Responses delay increased from 4 to 10.

comparison, nevertheless it demonstrates a potential of the *NGMV* controller to control highly nonlinear plants with significant time delays. Moreover, although the link to a Smith Predictor time delay compensator was made, the approach has the significant advantage over the Smith Predictor, that it provides a stochastic control design procedure, whereas the Smith Predictor only provides a structure (there is no guidance how to design the controller for say disturbance rejection).

In general, it seems relatively easy to obtain an *NGMV* design very close (and normally better) than the existing *PID* performance, and then use the proposed parameterization (which is only one of a number of possible choices) to achieve further improvement.

The approach is not in competition with *PID* of course. There is every reason to use the simplest possible controller that will do the job. The *NGMV* has the advantage that if the plant is high order, a stabilising *PID* control law may not even exist.

As the controller includes the *NL* model of the plant, it should be robust against any changes of the operating point, whereas any linear controller may have problems regulating across the whole operating range. The above results do, of course, correspond to no (or little) plant/model mismatch. The choice of cost weightings to optimise robustness will be a subject of future research. A slight generalization is to define a completely nonlinear objective function, so that the error weighting is nonlinear \mathcal{P}_c . Constraints on input actuators, like mechanical bending limits, can be allowed for using *barrier* functions, which may be absorbed into the plant model as a further nonlinearity.

8. CONCLUDING REMARKS

The *NGMV* design provides a relatively simple controller for *NL* multivariable systems. The assumptions made in the definition of the system and the specification of the cost, were all to obtain a simple controller. However, the plant description can be very general. An advantage of the *NGMV* solution is that the nonlinear plant model is not required, only the ability to compute an output for a given control input. The controller is simple to compute and implement.

The closed loop stability of the system was shown to depend upon the existence of a stable inverse for a particular loop operator. This operator depended upon the cost weighting definitions. A possible starting point for weighting selection was through the relationship to a *PID controller*. If a *PID* controller exists, to stabilize the delay free plant model this guaranteed the existence of at least one set of control weightings to ensure closed-loop stability.

Leaving aside issues of optimality the controller is

such that the input nonlinear subsystem can also be time-varying without complicating implementation. This suggests a simple adaptive or learning control solution may be possible. Future work will be concerned with applications on automotive power train control, ship roll stabilisation and loopers for hot strip rolling mills. A state-space version (*Grimble and Majecki*, 2004 [10]) may also lead to a simple *NL* predictive controller. This will use the receding horizon philosophy (*Kwon and Pearson*, 1975 [12]).

REFERENCES

- [1] K. J. Åström, *Introduction to Stochastic Control Theory*, Academic Press, London, 1979.
- [2] D. W. Clarke and R. Hastings-James, "Design of digital controllers for randomly disturbed systems," *Proc. of IEE*, vol. 118, no. 10, pp. 1502-1506, 1971.
- [3] M. J. Grimble, "A control weighted minimumvariance controller for non-minimum phase systems," *International Journal of Control*, vol. 33, no. 4, pp. 751-762, 1981.
- [4] M. J. Grimble, "Generalized minimum-variance control law revisited," *Optimal Control Applications and Methods*, vol. 9, pp. 63-77, 1988.
- [5] D. W. Clarke and P. J. Gawthrop, "Self-tuning controllers," *Proc. of IEE*, vol. 122, no. 9, pp. 929-934, 1975.
- [6] G. Goodwin, O. Rojas, and H. Takata, "Nonlinear control via generalized feedback linearization using neural networks," *Asian Journal of Control*, vol. 3, no. 2, pp. 79-88, 2001.
- [7] M. J. Gimble, "Restricted structure LQG optimal control for continuous time systems," *IEE Proceedings of Control Theory Applications*, vol. 147, no. 2, pp. 185-195, 2000.
- [8] M. J. Grimble, *Industrial Control Systems Design*, John Wiley, Chichester, 2001.

- [9] M. J. Grimble, "Restricted structure controller tuning and performance assessment," *Proc. of IEE, Control Theory and Applications*, vol. 149, no. 1, pp. 8-16, 2002.
- [10] M. J. Grimble and P. Majecki, NGMV Control of Multivariable Systems with Common Delays and State-Space Disturbance Model, Research Report 212, January 2004.
- [11] M. J. Grimble, "Non-linear generalised minimum variance feedback, feedforward and tracking control," *Automatica*, vol. 41, pp. 957-969, 2005.
- [12] W. H. Kwon and A. E. Pearson, "On the stabilization of a discrete constant linear systems," *IEEE Trans. on Automatic Control*, vol. AC-20, no. 6, pp. 838-842, 1975.



Michael J. Grimble is a Professor in the Industrial Control Centre, University of Strathclyde, UK. The University of Strathclyde, appointed him to the Professorship of Industrial Systems in 1981 and he developed the *Industrial Control Centre*. He established a university consultancy company *Industrial Systems and*

Control Ltd. and also the Applied Control Technology Consortium, which is a technology transfer and training organisation. The IEE presented him the Heaviside Premium in 1978. In 1979, he was awarded the Coopers Hill War Memorial Prize and Medal by the Institutions of Electrical, Mechanical and Civil Engineering. The Institute of Measurement and Control awarded him the 1991 Honeywell International Medal. He was awarded an IEEE Fellowship in 1992 and was recognised at the 1993 Edinburgh International Science Festival as one of Scotland's four most cited Scientists. He was appointed a Fellow of the Royal Society of Edinburgh in 1999 and was jointly awarded the Asian Journal of Control best paper award for 2002/2003.