

**EUR 4497 e**

**COMMISSION OF THE EUROPEAN COMMUNITIES**

**C O S T A X - B O I L**

**A COMPUTER PROGRAMME OF THE COSTANZA SERIES FOR  
THE AXIAL DYNAMICS OF BWR AND PWR NUCLEAR REACTORS**

by

**G. FORTI**

**1970**



Joint Nuclear Research Center  
Ispra Establishment - Italy  
Reactor Physics Department  
Reactor Theory and Analysis

## LEGAL NOTICE

This document was prepared under the sponsorship of the Commission of the European Communities.

Neither the Commission of the European Communities, its contractors nor any person acting on their behalf :

make any warranty or representation, express or implied, with respect to the accuracy, completeness or usefulness of the information contained in this document, or that the use of any information, apparatus, method or process disclosed in this document may not infringe privately owned rights; or

assume any liability with respect to the use of, or for damages resulting from the use of any information, apparatus, method or process disclosed in this document.

This report is on sale at the addresses listed on cover page 4

at the price of FF 9.45

FB 85.—

DM 6.20

Lit. 1,060

Fl. 6.20

**When ordering, please quote the EUR number and the title, which are indicated on the cover of each report.**

Printed by SMEETS, Brussels  
Luxembourg, June 1970

This document was reproduced on the basis of the best available copy.

**EUR 4497 e**

COSTAX-BOIL - A COMPUTER PROGRAMME OF THE COSTANZA SERIES FOR THE AXIAL DYNAMICS OF BWR AND PWR NUCLEAR REACTORS, by G. FORTI

Commission of the European Communities  
Joint Nuclear Research Center - Ispra Establishment (Italy)  
Reactor Physics Department - Reactor Theory and Analysis  
Luxembourg, June 1970 - 58 Pages - FB 85

Costax-Boil is a FORTRAN programme for transient analysis of BWR in the time domain. It couples the two velocity groups neutron diffusion kinetic calculations (up to 10 delayed neutron groups) in one dimension (axial) with the heat conduction equations in the fuel rods and a two phase flow dynamics calculation for the typical coolant channel.

**EUR 4497 e**

COSTAX-BOIL - A COMPUTER PROGRAMME OF THE COSTANZA SERIES FOR THE AXIAL DYNAMICS OF BWR AND PWR NUCLEAR REACTORS, by G. FORTI

Commission of the European Communities  
Joint Nuclear Research Center - Ispra Establishment (Italy)  
Reactor Physics Department - Reactor Theory and Analysis  
Luxembourg, June 1970 - 58 Pages - FB 85

Costax-Boil is a FORTRAN programme for transient analysis of BWR in the time domain. It couples the two velocity groups neutron diffusion kinetic calculations (up to 10 delayed neutron groups) in one dimension (axial) with the heat conduction equations in the fuel rods and a two phase flow dynamics calculation for the typical coolant channel.

---

Doppler and void reactivity feedback are accounted for pointwise. A flexible input allows representation of reactivity transients, flow recirculation or inlet enthalpy transients, or an arbitrary mixture of them, including control rod bank movement. No pressure variation is possible in the present version. The programme is intended for the analysis of intermediate accidents or severe operational transients in which a detailed spatial representation is essential.

Doppler and void reactivity feedback are accounted for pointwise. A flexible input allows representation of reactivity transients, flow recirculation or inlet enthalpy transients, or an arbitrary mixture of them, including control rod bank movement. No pressure variation is possible in the present version. The programme is intended for the analysis of intermediate accidents or severe operational transients in which a detailed spatial representation is essential.

**EUR 4497 e**

**COMMISSION OF THE EUROPEAN COMMUNITIES**

**C O S T A X - B O I L**

**A COMPUTER PROGRAMME OF THE COSTANZA SERIES FOR  
THE AXIAL DYNAMICS OF BWR AND PWR NUCLEAR REACTORS**

by

**G. FORTI**

**1970**



**Joint Nuclear Research Center  
Ispra Establishment - Italy  
Reactor Physics Department  
Reactor Theory and Analysis**

## **ABSTRACT**

Costax-Boil is a FORTRAN programme for transient analysis of BWR in the time domain. It couples the two velocity groups neutron diffusion kinetic calculations (up to 10 delayed neutron groups) in one dimension (axial) with the heat conduction equations in the fuel rods and a two phase flow dynamics calculation for the typical coolant channel. Doppler and void reactivity feedback are accounted for pointwise. A flexible input allows representation of reactivity transients, flow recirculation or inlet enthalpy transients, or an arbitrary mixture of them, including control rod bank movement. No pressure variation is possible in the present version. The programme is intended for the analysis of intermediate accidents or severe operational transients in which a detailed spatial representation is essential.

## **KEYWORDS**

FORTRAN  
ANALYSIS  
BWR  
NEUTRON  
DIFFUSION  
DOPPLER EFFECT  
TRANSIENTS  
COOLANT LOOPS

## Contents

	page
Purpose	5
Structure of the programme	6
Physical and numerical models and available options of the programme	8
Directions and suggestions for the user of the code	10
Output	14
Input form	15
Computer specifications and programme's performance	16
References	
Appendix "A" - COSTAX-BOIL, INPUT KEY"	18
Appendix "B" - Data and output listing for the sample problem	37





1 - Purpose \*)

The Costax-Boil programme has been developed for the analysis of those transients of thermal nuclear power reactors for which the spatial effects in the axial direction are of essential importance, either because of neutronic behaviour in itself (high reactivity accidents) or because of localized reactivity feedbacks such as void feedback for BWR or PWR in accident situations. It is built by coupling the neutronic spatial kinetics in plane geometry and two energy groups to the thermal conduction equations in the fuel elements and the two phase flow thermohydrodynamics of the typical coolant channel by means of Doppler, void, and liquid coolant temperature feedback evaluated pointwise.

Any kind of transient problem may be analyzed by the code, except those that imply a relevant variation of the general pressure level of the reactor core, as the thermohydraulic model is limited to constant physical properties of the coolant in the present version. The input allows scheduled time variations of general or local reactivity, or control rod insertion, freely combined with scheduled coolant flow rate and inlet temperature variations. The assumption that coolant physical properties are independent of space and time limits the applicability of the programme to those reactors in which the pressure drop across the core is not relevant compared to the general pressurization level. This condition is generally fairly met by PWR and BWR power plants.

## 2 - Structure of the programme

Each transient problem treated is started from an initial condition of equilibrium in which the reactor is critical in some configuration, keeping into account all the power feedbacks in the stationary state. Then time dependent perturbations are introduced in any of the available input parameters and the dynamic calculation is started and goes on up to a specified final time.

Therefore at the beginning of each problem the programme enters a starting up procedure that is articulated as follows:

- a) After the reading out of the data and some preliminary calculations, assuming a flat power distribution, a stationary calculation of the average coolant channel is performed, and the map of the results is printed; the fuel temperatures, coolant temperatures and void distribution are used to calculate pointwise the feedback for neutron equations.
- b) A fixed number of time steps in neutron diffusion kinetics (without delayed neutrons) are taken, starting from flat fluxes and using the neutronic constants given in input modified by the feedbacks obtained in a). The fluxes are normalized to give the prescribed initial power. This allows a first rough shaping of the fluxes. This first map of fluxes is printed.
- c) The criticality search is made, varying a chosen parameter (see options). Each iteration consists of a kinetic time step corresponding to the same time increment  $\Delta t$  used in b), after which a new channel stationary calculation is performed with the new power distribution, and the new feedback is evaluated. A number of time steps (up to 10) are then taken in the new condition to obtain a stable period in the new configuration; the reciprocal of the period is the objective value that has to be reduced to

zero during the search by varying the parameter. The search is started with the parameter equal to zero, and the second iteration with a guess value given in input. In the following iterations the parameter is varied on the basis of the last two values obtained of the reciprocal of the period by linear interpolation or extrapolation, until the reciprocal of the period is smaller than a given criterium in absolute value.

The converged fluxes are then utilized to calculate the delayed neutron precursors concentrations at equilibrium condition and the complete stationary conditions for the cooling channels, including pressure drops in the channel and the riser. A final complete print of stationary results is made and this concludes the static part of the problem which may be utilized also in itself.

Then the dynamic calculation begins. Time step after time step in the neutronic calculation the current value of the nuclear perturbation parameters are interpolated in the input tables, and the same applies, whenever a thermohydraulic step is called for after a fixed number of neutronic steps, to the inlet velocity and subcooling variables when it is the case. The last current distribution of fluxes is the source for the power generation in the fuel rods at each thermal step, and the last values of the temperature and void distribution give the feedback for all the neutronic steps between two successive thermal steps. A flexible printing pattern is available for synthetic or detailed output of the results along the time.

### 3 - Physical and numerical models and available options of the programme

The physical model for the neutronic part is fundamentally unchanged from the last published code of the Costanza series, (EUR 3633 e) not considering minor improvements. The heat conduction and hydrodynamic model is illustrated in EUR 4052 e and the corresponding computer programme is EUR 4241 e.

The feedback is represented locally pointwise as a reactivity factor that multiplies the neutron production cross section (fast and thermal) in the form  $\nu \Sigma_f = (1 + \delta k) \nu \Sigma_f^{\text{nominal}}$

$\delta k$  is given as the sum of three contributions

$$\delta k = \delta k_D + \delta k_\alpha + \delta k_{T_l}$$

$\delta k_D$  is the Doppler feedback and is given as function of the average fuel temperature (three functional forms are possible, see input key) and of the void fraction

$$\delta k_D = f(T_f, T_{ref}) e^{\alpha \alpha}$$

( $\alpha$  is defined as the volume fraction of the coolant channel occupied by vapour)

$\delta k_\alpha$  is given as a quadratic function of the void fraction

$$\delta k_\alpha = a\alpha + b\alpha^2 \text{ or may be given as a tabulated}$$

function of  $\alpha$

$\delta k_{T_l}$  is a quadratic function of the liquid coolant temperature  $\delta k_{T_l} = a(T_l - T_{l,ref}) + b(T_l - T_{l,ref})^2$

A multiple option is available for the criticality search. The search parameter may be a factor for all the  $\nu \Sigma_f$  cross section, giving a conventional  $k_{\text{eff}}$  search (the  $k_{\text{eff}}$  found at convergence will be printed in the output in this case). Alternatively the search parameter may be chosen

as a poison absorption cross section to be added in any region of the reactor or in any combination of regions; a fixed ratio between thermal and epithermal poison cross section is to be given in input, so that the search is performed, as it must, on a single parameter. As a third alternative, the search parameter may be the depth of insertion of a control rod bank. In this case the bank is represented by a specified thermal and epithermal cross sections and the direction of the rod insertion (parallel or antiparallel to the coolant flow) is specified at will. In the steady state channel calculation, different options are available on fuel geometry, and on other matters. We omit here the details, as they are easily understood from the analytical input description in appendix; they reproduce essentially the features of the FRANCESCA code (EUR 4241 e) except that no coolant inlet velocity search is admitted, so that coolant flow rate must be given either directly or indirectly by specifying the output quality in the steady state condition.

The nuclear perturbation during transient is given as a time table. A double alternative of options is available. As for the nature of the perturbation, this is either a poison absorption cross sections insertion or a  $\delta k$  insertion, by the latter meaning that a factor  $(1 + \delta k)$  effects the  $\nu \sum f$  cross sections. The modality of the perturbation may be a diffused insertion in any zone or combination of zones (obtained by zone weighting of the perturbation) or a bank rod movement represented as a shifting boundary.

In the latter case the direction of insertion for the rod bank is specified at will.

In the dynamic channel calculation, the same features are present that in the already mentioned FRANCESCA code.

The main option concerns the inlet flow rate of coolant, that may be either given as a time schedule, or calculated by the programme as it follows from the dynamic conditions taking into account the specifications for the driving pressure.

For the details here also the reader is referred to the analytic description of the input (and to the quoted report EUR 4241 e).

#### 4- Directions and suggestions for the user of the code

The whole programme, aiming to provide a practical tool for calculations is, as it happens in such cases, a rather intricate machinery, and the author is unable to give a complete description of its working that, to be useful, should be more readable than the FORTRAN listing itself. A real know how of its functioning and possibilities can best be gained by using it in practical cases. The input key given in appendix should be the essential guide to the use of the code; as however the author is well aware that many items may not be clear to the user, care was taken in framing the input, so that whenever a puzzled user omits an indicator, or even a parameter whose definition looks obscure, the code automatically selects what in the author's opinion is best or more convenient in the majority of cases. Of course no sensible answer can be expected if essential logical or numerical information is missing.

A specific direction is given now about the use of DATA (1700). In a problem implying a rod drop, a scram or anyway the movement

of a bank of rods, it may be important to represent the rod starting from a specified position, inside the core. On the other hand, the programme is so conceived that it must start from an equilibrium condition; therefore the time zero insertion value has in the programme a double effect: a rod specified as the negative counterpart of the rod to be moved is positioned permanently at the position specified, while the actual rod is set in the same position to be subsequently moved. The net effect at time zero is nil, as it should be, and a net effect will appear only when the rod is moved. If the user wants to represent the sudden appearance, of a rod in a given position at the time zero, he should give DATA (1700) as zero and give the wanted position as DATA (1701) corresponding to a successive time smaller than the calculation time step, as this will produce the desired effect.

Some observations on the general use of the programme follow. When in a problem one tries to represent an actual transient in a real reactor, one will find always some difficulty in adapting the one dimensional model to the real case. In our opinion the best way of proceeding should be the following. First the best guess at the reactor starting configuration should be worked out, and the problem run as a stationary one with  $\delta k$  search. Observing the results will permit to adjust, if it is required, the poison cross sections or the boundaries of the regions to have a better matching with the real situation. A stationary problem will generally take less than one minute of machine time on a IBM 360/65. When satisfactory results are obtained for the stationary situation the time dependent perturbation should be introduced, and the complete transient calculated.

Sometimes it may even be useful to run a short transient without any perturbation, to check the equilibrium condition. In normal situations, everything should stay constant, or change irrelevantly. A fluctuation however will not necessarily indicate that something in the calculation is wrong; it may happen that the system is physically in an unstable situation, and in this case the numerical errors are sufficient to start an oscillation. The reader must be aware the convergence of the iteration process that leads to the equilibrium condition is not theoretically proved; all that can be safely said is that we always found it to converge when the physical problem was a sound one. Starting from an initial configuration which is very far from critical, it may happen that the iteration process produces negative fluxes. When this happens, no recovery of the iteration process is possible and the programme will be stopped by some diagnostic (typical is the square root of a negative number, occurring in the feedback calculation because of negative fuel temperature). In such cases, the first thing to do is a careful scrutiny of the input, to detect unphysical conditions (negative absorption cross sections, wrong order of magnitude of nuclear data, inconsistent geometry, and so on). If everything is all right, but the reactor is too far from criticality, altering beforehand the  $\nu\Sigma_f$  data by a common factor, so that the problem becomes more manageable is a good move, and the following one is to decrease the time increment  $\Delta t$  for initialization (DATA 11). A better second guess for criticality parameter is also helpful. In our experience a physically well posed problem has always converged satisfactorily, sometimes after some trials. The convergence is easier for  $\delta k$  search, it may be more difficult when control rod insertion



is the search parameter. This is easy to understand, if it is considered that in BWR problems it may very well happen that two rod positions are critical at the same time, because of the interaction between flux shape and voids, through void coefficients. In this case the iteration process may succeed in finding one of the two equilibrium positions or it may oscillate among the two, or even diverge. In such cases the rod position should be fixed in input (utilizing region constants definition) and the search made on  $\delta k$ .

Generally, when a problem is well posed, the number of iterations for criticality search should be below 50, very often below 20. When a small  $\Delta t$  has been used, it may happen that the maximum number of iterations is exceeded. The solution often is nevertheless good, but in this case the trial of an unperturbed dynamic run is advisable. Should the results be unsatisfactory, the static problem may be repeated altering the  $\sum f$  cross sections and with a wider time step for initialization.

A warning is also given against the temptation to use always the full capacity of the programme (100 mesh points). This is most of the time a pure waste of machine time, and may make things more difficult. In our experience, 50 mesh points in most cases is all what is needed, and very often 30 give a more than adequate representation. The reader should bear in mind that, also when the static problem is used for its own sake, the goal is to reach a fair representation of flux shape and heat fluxes, and by no means the exact determination of  $k_{eff}$ , for which a one dimensional tool is clearly insufficient. Very often a mesh size of the order of 10 cm has been found quite adequate for power reactors.

## 5 - Output

The output of the programme is largely selfexplanatory. The input data are first printed. Then the delayed neutron groups composition is shown.

A summary of the coolant channel characteristics follows with the results of the thermal calculation corresponding to a flat distribution of power; the pressure drop appears as zero, as the calculation is not yet performed at this stage.

Then the first map of fluxes is printed, which corresponds to the first initialization step, performed with the feedback corresponding to the flat thermal calculation. The power column is normalized to the average value of the power and the average is given in watt per cm of height of one single average channel. The averages appearing in the DK columns are weighted on the square of power, for best comparison with point models.

Then the criticality search results are printed; a complete map of the neutronic and thermal results for the equilibrium state is given. Then the output of the dynamic calculation follows: the printing pattern is freely chosen by the user among three possibilities: complete maps of values, average on regions and global values. In the print of region values FLM1 indicates average fast flux in the region, FLM2 average thermal flux and AVPO average power in regions relative to mean power. By PINT is indicated the total integrated power in Joule. The map of channel results gives for each axial mesh the following items: Power/cm POW, Heat flux FI, vapour quality Q, void fraction VF, temperature of the cladding surface TSUR, inner temperature of the cladding TICL, average temperature of the fuel AVTF, maximum (central point) temperature of the fuel TMAXF and liquid coolant temperature TL. If a riser is present, the void fraction is given, while the quality is printed as zero, because it is not memorized.

The Sample problem output in appendix is an illustrative case of a reactor which is not boiling in the nominal condition. There is no perturbation, and the dynamic calculation shows practical equilibrium, up to 0.5 seconds, then a pump trip is simulated, followed by a scram.

## 6 - Input form

Many problems may be executed in one run. For every problem the first input card is a title card, in which any alphanumerical information may appear in columns from 7 to 70 included. This title will appear in the output - a 1 in column 6 means that the problem is the last of the run.

A vector of 3500 memory positions DATA (1) to DATA (3500) contains all the data in floating point form (Internal conversion is performed by the code when needed). Since entire groups of memory positions are zero, it is possible to read different sets of significant data; each set must be preceded by a card containing the integers  $Ki_1$ ,  $Ki_2$  defining the first and last datum of the set.  $Ki_1$  and  $Ki_2$  are given in integer form adjusted to the right at columns 12 and 24. The last set of a problem is indicated by -1 in columns 1 and 2. The data of each set are all in floating form (FORTRAN FORMAT E 12.8). Any number of problems may be run in sequence and only the data changing from the preceding problem need to be given. A title card must be present for each problem. The key to the input is given in appendix A.

## 7 - Computer specifications and programme's performance

The programme has been assembled at the CETIS computing center at Ispra on IBM 360/65 in FORTRAN H 360 optimization level 2, except the routine FUELS, for which the optimization level 0 has been employed, as it was found that level 2 gave unexplained execution errors due to bad compilation. The programme will be available at the CETIS nuclear code group - Ispra. The running time is somewhat difficult to assess, as it depends on many items. An average problem of 50 mesh points will require of the order of the minute on 360/65 for every 1000 neutronic time steps and about 2 minutes for every 1000 thermal steps. The stationary calculation will generally require less than 1 minute in the whole. A typical problem may require in total around 5 minutes.

The programme has been extensively tested and used by the author in many different ways, and no logical mistake has ever been detected. As the combination of available options is unusually large, no absolute statement can be made that the code will work correctly in all the possible consistent uses, but the author is pretty confident it should.

Physically, the inner consistency has been carefully checked; the neutronic part of the calculation have been tested in straight-forward cases where the analytical solution may be calculated with nearly perfect agreement. The channel calculations had also been checked at it was mentioned in the FRANCESCA code report (EUR 4241 e). The code has been used for the calculation of an experimental pump trip case for the Lingen BWR power plant built by AEG for which the data were available, with surprisingly good agreement.

We want here to thank Dr. Wolff of the AEG and the methods group of AEG headed by Dr. Schmidt for the helpful suggestions and criticism and the opportunity of access to real plant data and problems in the frame of a fruitful collaboration.

## References

- EUR 3633 e "The codes COSTANZA for the dynamics of liquid-cooled nuclear reactors"  
G.FORTI and E.VINCENTI, 1967.
- EUR 4052 e "A dynamic model for the cooling channels of a boiling nuclear reactor with forced circulation and high pressure level"  
G.FORTI, 1968.
- EUR 4241 e "FRANCESCA, A dynamic program for boiling cooling channels"  
G.FORTI, 1969.

APPENDIX A

C O S T A X - B O I L

INPUT KEY

Title card (bbbbbb any title) a 1 in column 6 means that the problem is the last of the run.

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
1	DELT	$\Delta t$ for transient calculation	sec	1/15 of minimum expected period generally gives good results.
2	DZ	$\Delta Z$ mesh width	cm	
3	IMAX	Number of mesh points	-	up to 100
4	NREG	Number of regions	-	up to 12
5	NRIT	Number of delayed neutron groups		up to 10
6	IDST	Number of steps for initialization	-	30 is suggested
7	ITCR	Put always 1	-	
8	IDIR	Search indicator - 1 Search for $\delta K_{eff}$ 0 Poison search 1 Control rods inserted from top (entry of the coolant) 2 Control rods inserted from bottom	-	
9	SI	Area of the core cross section	cm <sup>2</sup>	This value is employed to normalize the neutronic fluxes to the given total power for the whole reactor.
10	BU	Transversal Buckling	cm <sup>-2</sup>	
11	DELT	$\Delta t$ for initialization	sec	10 <sup>-4</sup> is suggested (reactor.
12	POWER	Steady state power of the reactor	watt	
13	ICAN	Number of channels in the core The power given to the average channel will be POWER/ICAN	-	Put 0 if no channel calculation is wanted
14	KPC	Thermal calculation will be made every KPC neutronic time steps	-	Omit if no channel is represented

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
15	IDOP	Doppler feedback indicator $0 \quad \delta K_D = b(e^{a(\sqrt{T}-\sqrt{T_0})-1})^{(DATA(19))}$ $-1 \quad \delta K_D = a(T-T_0) + b(T-T_0)^2$ $+1 \quad \delta K_D = a(\sqrt{T}-\sqrt{T_0})$	-	
16	TDOPP	Reference temperature $T_0$ of the fuel for Doppler feedback	Kelvin	°C may also be employed if IDOP = -1
17	TREF	Reference temperature for liquid coolant temperature feedback	Kelvin	All temperature should be given in the same unit, so °C may be used if the square root formulae are not employed for Doppler feedback
19		Coefficient in void dependent Doppler feedback (see DATA (15))		
31-40	BETA	$\beta_i$ Delayed neutrons precursors yield per fission	-	
41-50	DLI	$\lambda_i$ Delayed neutron precursors decay constants	sec <sup>-1</sup>	
61-73	I1, I2	Region boundary mesh numbers	-	The first value must be 1 and the last IMAX



REGIONS CONSTANTS

First region

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
81	D1	$D_f$ Fast group diffusion coefficient	cm	
82	SR	$\Sigma_r = \Sigma_{sd} + \Sigma_{af}$ Total removal cross section from fast group	$\text{cm}^{-1}$	
83	SSD	$\Sigma_{sd}$ Slowing down cross section from fast to thermal	$\text{cm}^{-1}$	
84	SF1	$\nu \Sigma_{f1}$ Fast neutron production cross section	$\text{cm}^{-1}$	
85	W	Fast group neutron velocity	cm/sec	
86	PFAC1	$E_1 \Sigma_{f1}$ Fission energy production cross section for group 1	joule/cm	
87	D2	$D_{th}$ Thermal group diffusion coefficient	cm	
88	SA	$\Sigma_{a2}$ Thermal group absorption cross section	$\text{cm}^{-1}$	
89	SF	$\nu \Sigma_{f2}$ Thermal neutron production cross section	$\text{cm}^{-1}$	
90	V	Thermal group neutron velocity	cm/sec	
91	PFAC <sub>2</sub>	$E_2 \Sigma_{f2}$ Fission energy production cross section - group 2	joule/cm	
92	-	Not used		
93-104		Same constants for second region etc...		

Feed-back coefficients

Only for ICAN>0  
Omit if no coolant channel is present-Neutronic calculation will be executed without feedback.

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
300	ICI	If 0 the feedback coefficients are equal in all the regions. If 1 they are given regionwise		
301	ALDOP	a in Doppler feedback formula		see Data (15)
302	BEDOP	b in Doppler feedback formula		Units depend on formula-Temperature in Kelvin or °C
303	AVOID	a in void feedback formula $\delta k_v = a\alpha + b\alpha^2$		May be omitted, if the void feedback is given as a table (see DATA (1000))
304	BVOID	b in void feedback formula		
305	ACOCO	a in liquid coolant temperature feedback $\delta k_T = a(T-TREF) + b(T-TREF)^2$	°C <sup>-1</sup>	
306	BCOCO	b in coolant feedback formula	°C <sup>-2</sup>	
307-312		Same for 2nd region etc..		Only if DATA (300)>0
450	ICORE	Mesh number of the beginning of the core	-	First node of the active channel, if channel is present If omitted, the code will take 1
451	NCORE	Mesh number of the end of the core		If omitted, the code will take IMAX

Integer channel data

Only if ICAN &gt; 0

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
452	NF	Number of radial meshes in the fuel for thermal conduction		up to 10
453	IP1	Full print of thermal data every IP1 restricted prints		
454	ISTD	If 1. Standard formulae for water are selected		
455	ITIPO	0. Cylindrical fuel element 1. Slab element -1. General geometry		
456	IVAR	0. Thermal parameters in fuel are constant 1. Variable parameters (functions of temperature)		
457	JPØW	0. → Constant power density along the thickness of the fuel element 1. → Power in radial zones given in input -1. → Power is the same in all radial zones		
458	IOR	0. → No operation 1. → Orificing at the inlet of the channel is calculated to match a given pressure drop in the steady state		
459	IVIN	0. Inlet velocity of the channel is calculated by the code during the transient 1. Inlet velocity is tabulated as a function of time		

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
460	IEX	<p>0. Driving pressure is a function of the inlet velocity <math>\Delta p = \Delta p_0 + a(v - v_0) + b(v - v_0)^2</math></p> <p>1. Driving pressure is tabulated as function of time</p>		Only if IVIN = 0
461	IFRIC	<p>Two phase friction multiplier selector</p> <p>0. <math>TPM = 1 + ax + bx^2</math> (x=vapour quality)</p> <p>1. <math>TPM = 1 + a\alpha + b\alpha^2</math> (<math>\alpha</math>=void fraction)</p> <p>+1. <math>TPM = 1 + a\chi + b\chi^2</math> (<math>\chi = TMART \frac{x}{1-x}</math>)</p> <p>+2. <math>TPM = 1 + a\chi^{-1} + b\chi^{-2}</math></p>		
462	IRIS	Number of meshes in the riser (put zero if no riser)		up to 10
463-465	KRIS	Index of the riser meshes where local friction loss is present		
466		leave blank		
467	IDF	<p>Geometry indicator</p> <p>0. Radial zones in fuel have constant area</p> <p>1. Uniform radial mesh</p> <p>+1. Radii of fuel zones given in input</p>		
468	ITET	<p>0. <math>\theta</math> calculated by the code</p> <p>1. <math>\theta</math> given in input</p>		
469-478	KKC(I)	Indexes of the active meshes where local friction losses are present		
479-500	-	Dummy - leave blank		

Floating channel data

Only if ICAN = 1

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
501	A	Coolant cross section area	cm <sup>2</sup>	
502	DIAF	Fuel diameter (or thickness)	cm	
503	GAPTH	Gap thickness	cm	
504	CLTH	Cladding thickness	cm	
505	ROF	Fuel density	g/cm <sup>3</sup>	
506	CPF	Fuel specific heat	$\frac{\text{joule}}{\text{gr}^\circ\text{C}}$	
507	AKF	Thermal conductivity of the fuel	$\frac{\text{watt}}{\text{cm}^2^\circ\text{C}}$	
508	RGAP	Gap thermal resistance	$\frac{\text{watt}}{\text{cm}^2^\circ\text{C}}$	
509	ROCL	Cladding density	g/cm <sup>3</sup>	
510	CPCL	Cladding specific heat	$\frac{\text{joule}}{\text{gr}^\circ\text{C}}$	
511	AKCL	Thermal conductivity of the cladding	watt/cm <sup>2</sup> °C	
512	SWID	Fuel element width	cm	Only for slab geometry
513	TINER	Total inertia of the channel	cm	The inertia is expressed as the equivalent length of a channel of constant cross section A with the same inertia of the actual channel. May be omitted if IVIN = 0
514	RGFAC	Factor for gravity pressure drop in the riser (if omitted, the code will take 1. Give h/l otherwise)		
515	FRDF	Ratio of the power directly added to the liquid coolant (γ-rays and neutron moderation) the total power produced.		

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
516	PS	Printing time interval (restricted print) for thermal output		
517-518		Dummv		
519	HINLET	Inlet temperature of the coolant for steady state	Kelvin (or °C)	
520	VINLET	Inlet velocity of the coolant for the steady state	cm/sec	May be omitted if the exit quality is given
521	FFK	Friction coefficient in the active channel $\Delta p = FFK \cdot \Delta z \cdot \frac{1}{2} \rho (G/\rho)^2$	cm <sup>-1</sup>	
522	FFRK	Friction coefficient in the riser Same formula	cm <sup>-1</sup>	
523	XOUT	Imposed exit quality for steady state	-	If omitted it will be calculated by the code
524	DPEQ	Imposed pressure drop for the steady state	bar	If omitted it will be calculated by the code
525	TSAT	Saturation temperature	Kelvin (or °C)	
526	RO	Liquid coolant density	gr/cm <sup>3</sup>	
527	ROVAP	Vapour density	gr/cm <sup>3</sup>	
528	CP	Coolant specific heat	$\frac{\text{joule}}{\text{gr}^\circ\text{C}}$	
529	HLAT	Latent heat of vaporization	$\frac{\text{joule}}{\text{gr}}$	

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
530	HC	Convective heat transfer coefficient	$\frac{\text{watt}}{\text{cm}^2\text{C}}$	Omit if standard formula for water is selected (ISTD=1)
531	HB	Boiling heat transfer constant ( $q = HB \Delta T^n$ )	$\frac{\text{watt}}{\text{cm}^2\text{C}^n}$	Omit if standard
532	AN	Exponent in the boiling heat transfer correlation $q = HB T^n$		Omit if standard
533	TAU	Boiling ratio of heat transmitted through vapour bubbles to total heat transmitted by boiling mechanism	-	Omit if standard
534	AK	Bankoff's slip constant	-	Omit if standard
535	ZE	Relaxation parameter for void profile in diabatic two phase flow	cm	Omit lacking better information
536	R1	Recondensation time constant for subcooled boiling	$(\text{sec}^{\circ}\text{C})^{-1}$	Omit lacking information
537	R2	Vaporization time constant for superheated liquid (put zero if no overheating is wanted)	$(\text{sec}^{\circ}\text{C})^{-1}$	Omit lacking information
538	AFRIC	} Coefficients for two phase flow friction multiplier	-	See DATA (461)
539	BFRIC			
540	ALOC	} Coefficient for two phase flow friction multiplier for local losses		
541	BLOC			
542	TMART	Coefficient in Lockhart-Martinelli parameter $\chi = \text{TMART} \frac{x}{1-x}$	-	Needed only if IFRIC = 1,2 May be omitted also if standard formula is used (see DATA (604))

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
543	COEF 1	Coefficient for momentum flow of liquid at outlet	-	} Omit lacking better information. They will be taken as 1.
544	COEF 2	Same for vapour	-	
545	COEF 3	Same for inlet liquid	-	
546	ZIN	Inlet pipe height	cm	
547	CFFI	Inlet friction coefficient $\Delta p = CFFI \frac{\rho V^2}{2}$	-	
548	ZR	Riser length	cm	
549	ARIS	Riser flow area	cm <sup>2</sup>	
550	GRAV	Gravity direction cosinus (+1. for upwards flow)	-	
551		Dummy		
552				
553	APEX	{ Coefficient for external driving pressure $DPEX = \Delta p_o (1. + APEX \cdot \Delta v + BPEX \cdot \Delta v^2)$	sec/cm	Needed only of IVIN = 0 and IEX = 0
554	BPEX		(sec/cm) <sup>2</sup>	
555	TKF	To } a } in formula $K = k_o + a(T - T_o) + b(T - T_o)^2$ for fuel variable heat conductivity b }	Kelvin (°C)	Only if IVAR = 1. if TKF is omitted the parameter will be kept constant
556	AKF1			
557	AKF2			



DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
558	TCPF	To		
559	CPF1	a		
560	CPF2	b		
		} in the same formula for fuel specific heat		
561	TKCL	To		
562	CPCL1	a		
563	CPCL2	b		
		} same for cladding thermal conductivity		
564	TCCL	To		
565	CPCL1	a		
566	CPCL2	b		
		} same for cladding specific heat		
567				
to	CFRF (I)	Values for local pressure drop coefficients in riser		
569		$\Delta p_i = CFRZ (I) \cdot \frac{1}{2} \rho (g/\rho)^2$		
570				
to	CKFF(I)	Same for active channel		
579		(same formula)		
580				
to	RFØ(I)	Radii of successive regions in the fuel pellet	cm	Only if IDF = -1
589				
590				
to	PFAC(I)	Corresponding power factors (relative values normalization performed by the code)	-	Only if JPØW = 1
599				
600	TINPUT	Ø value	°C	Only if ITET = 1

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
601	PRESS	Average pressure	bar	Needed only when ISTD = 1 (Standard formulae for water)
602	VISC	Viscosity of liquid coolant	poise	Only if ISTD=1 and/or if IFRIC=1,2 and TMART=0
603	WCON	Water conductivity	$\frac{\text{watt}}{\text{cm}^\circ\text{C}}$	Only if ISTD=1
604	VISCV	Viscosity of vapour (it is needed to evaluate Martinelli parameter TMART if not given in input. Formula employed is $\chi = \frac{x}{1-x} \left( \frac{\mu_w}{\mu_{\text{vap}}} \right)^{0.143} \left( \frac{\rho_{\text{vap}}}{\rho_{\text{water}}} \right)^{0.571}$ )		Only if IFRIC = 1,2
605	DIAH	Hydraulic diameter of the channel (appears in Colburn formula for $h_c = 0.023 \frac{k_w}{D_n} \text{Re}^{0.8} \text{Pr}^{0.4}$ )	cm	Only if ISTD = 1
606	-	Not employed		
607	ELSUR	Area of the heating surface per cm of height	cm	Only for general geometry (ITIPO = -1)
608	CLCAP	Thermal capacity of the cladding per cm of height	$\frac{\text{joule}}{\text{cm}^\circ\text{C}}$	Same
609	ACONCL	Thermal conductance of the cladding per cm of height	watt/cm°C	Same
610 to 619	FMASS(1)	Mass/cm in every zone in the fuel element	gr/cm	Same
620 to 629	CAP(I)	Thermal capacities in the fuel element zones per unit height	$\frac{\text{joule}}{\text{cm}^\circ\text{C}}$	Same

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
630 to 639	CONF(I)	Thermal conductivities from one zone to the following in the outer direction (per unit height)	$\frac{\text{watt}}{\text{cm}^\circ\text{C}}$	same

Tabulations for the channel

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
640 to 648	TIMEV(I)	Times for the inlet velocity tabulation	sec	Only when the corresponding options are checked
650 to 658	VVAL(I)	Values for inlet velocity	cm/sec	First time in each table is always zero. If the first value is zero, the steady state is kept
660 to 668	TIMEH(I)	Times for inlet temperature tabulation	sec	After the last value of time the values are kept constant to the last value of the Table
670 to 678	HVAL(I)	Values for inlet temperature	Kelvin (or°C)	Therefore if no DATA are entered in a table, the values are kept constant to the steady state value if the tabulation option is checked.
680 to 688	TIMEPR(I)	Times for external driving pressure tabulation	sec	
690 to	PRE(I)	Values of driving pressure	bar	

Void feedback tabulations

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
1000	-	If greater than zero, void feed back is tabulated (10 values)		Omit if DATA (1000) is zero the quadratic formula will be employed
1001 to 1012	-	Give ten values of $\delta k$ corresponding to $x = 0.1, 0.2 \dots 1.0$		
1013 to 1024 etc	-	Same for 2 <sup>nd</sup> region, if DATA (300) > 0		

Criticality search parameters

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
1600	LF	Maximum number of trials for search		50 is suggested
1601	DAPF	Convergence criterium for search (10 <sup>-3</sup> ) Reciprocal of period will be less than DAPF		
1602	SPRG	Second guess of control parameter for search ( $\Sigma a_2$ , cm of rod insertion, or $\delta k$ )		First guess is zero
1603	SPB	$\Sigma p_2$ corresponding to control rods	cm <sup>-1</sup>	Only if banked rods (IDIR=1,2)
1604	RFAST	Ratio $\Sigma_{p1} / \Sigma_{p2}$ for poison		Not used if IDIR = -1 (K <sub>eff</sub> search)
1605 to 1616	KV(I)	I if poison is present in region I 0 if it is not		Only when diluted poisons search is done (IDIR = 0)

Nuclear perturbation parameters

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
1617	IDKF	0 perturbation is given as absorption cross sections -1 perturbation given as $\delta k$		
1618	IDIR	0 perturbation is diffused 1 banked rod perturbation from top 2 banked rod perturbation from bottom		
1619	RFAST	Ratio $\Sigma_{P1}/\Sigma_{P2}$ for absorption perturbation		Only if IDKF = 0
1620	SPB	Control rod $\Sigma_{P2}$ (or $\delta k$ if IDKF=-1) for perturbation	$\text{cm}^{-1}$ or $\delta k$	Only if IDIR = 1,2
1621 to 1699	TBAR	Successive times for perturbation insertion	sec	
1700	VBAR	Time zero insertion for perturbation parameter		The parameter may represent depth of insertion (cm) of rods, or $\Sigma_{P2}$ , or $\delta k$ , according to the options checked. See directions and suggestions page of the text.
1701 to 1779	VBAR	Insertion values for successive times		
1781 to 1792		Factors which multiply the value VBAR(t) in each region I		Considered only if IDIR = 0

Criticality search parameters

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
1600	LF	Maximum number of trials for search		50 is suggested
1601	DAPF	Convergence criterium for search (10 <sup>-3</sup> ) Reciprocal of period will be less than DAPF		
1602	SPRG	Second guess of control parameter for search ( $\bar{\lambda}a_2$ , cm of rod insertion, or $\delta k$ )		First guess is zero
1603	SPB	$\sum p_2$ corresponding to control rods	cm <sup>-1</sup>	Only if banked rods (IDIR=1,2)
1604	RFAST	Ratio $\sum_{P1} / \sum_{P2}$ for poison		Not used if IDIR = -1 (K <sub>eff</sub> search)
1605 to 1616	KV(I)	I if poison is present in region I 0 if it is not		Only when diluted poisons search is done (IDIR = 0)



Nuclear perturbation parameters

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
1617	IDKF	0 perturbation is given as absorption cross sections -1 perturbation given as $\delta k$		
1618	IDIR	0 perturbation is diffused 1 banked rod perturbation from top 2 banked rod perturbation from bottom		
1619	RFAST	Ratio $\sum_{p1} / \sum_{p2}$ for absorption perturbation		Only if IDKF = 0
1620	SPB	Control rod $\sum_{p2}$ (or $\delta k$ if IDKF=-1) for perturbation	$\text{cm}^{-1}$ or $\delta k$	Only if IDIR = 1,2
1621 to 1699	TBAR	Successive times for perturbation insertion	sec	
1700	VBAR	Time zero insertion for perturbation parameter		The parameter may represent depth of insertion (cm) of rods, or $\sum_{p2}$ , or $\delta k$ , according to the options checked. See directions and suggestions page of the text.
1701 to 1779	VBAR	Insertion values for successive times		
1781 to 1792		Factors which multiply the value VBAR(t) in each region I		Considered only if IDIR = 0

Printing specifications

DATA N°	NAME	DESCRIPTION	UNIT	REMARKS
1851+6n	KTP	Number of time step for the n <sup>th</sup> printing pattern		n = 0, 1, etc.. As many cards as wanted may be given, allowing successive printing patterns.
1852+6n	I1P	Number of time steps for the more frequent type of print		
1853+6n	I1S	Type of more frequent output 1. only power, average fluxes and period 2. complete map of fluxes and delayed neutron precursors concentration 3. same as 1 plus region averages 4.5 no print		After the last is completed the calculation stops and a final print is done. Then the control is transferred to the beginning of the programme to start a new problem, unless the title card contains a positive integer in column 1-6, in which case the run is stopped
1854+6n	I2P	Number of time steps for the less frequent type of print (must be multiple of I1P and divisor of KTP)		
1855+6n	I2S	Same as I1S for less frequent output		
1856+6n	-	Not used		
<u>END of DATA</u>				

Appendix B

Data and output listing for the sample problem.

INPUT LIST

1	12	24	36	48	60	72
		SAMPLE PROBLEM	COSTAX BOIL			
0.01	18.39	25.	3.	6.	30.	
1.	1.	77500.	0.00016	0.001	2.	+08
4477.	5.	-1.	640.	262.5		
30.	-0583.	-05269.	-05131.	-05145.	-0521.	-05
3.	1.13	0.301	0.111	0.0305	0.0124	
1.	3.	23.	25.			
1.319	0.008655	0.0077627	0.	5.	+06	
0.939	0.00392	0.004788	270000.	6.19	-14	
1.319	0.008655	0.0077627	0.	5.	+06	
0.939	0.00392	0.004788	270000.	6.19	-14	
1.319	0.008655	0.0077627	0.	5.	+06	
0.939	0.00392	0.004788	270000.	6.19	-14	
-1.3	0.	0.0066	0.	-0.6	-05	
3.	23.					
3.	2.	1.	0.	0.	0.	
1.	1.	1.	0.	0.		
0.92	1.08	0.005	0.04	10.35	0.335	
0.0334	2.	6.55	0.335	0.159	0.	
367.8	0.	0.	0.5			
251.5	398.	0.0171			2.5	
297.	0.865	0.05	5.18	1275.		
50.	-65.					
30.			1.			
86.8	1.15	-035.22	-03	0.313		
0.	0.499	0.5				
2.5	2.5	1.				
50.	0.001	0.001				
-1.	2.	0.	-0.0785			
2.	2.5					
-1	400.					
300.	50.	3.	100.	2.		

COSTAX AXIAL-BOILING CHANNEL  
T.C.R. EURATOM ISPRA

SAMPLE PROBLEM COSTAX BOIL

1	0.100000E-01	2	0.133700E 02	3	0.250000E 02	4	0.300000E 01	5	0.600000E 01	6	0.300000E 02
7	0.100000E 01	8	-0.100000E 01	9	0.776000E 05	10	0.160000E-03	11	0.100000E-02	12	0.200000E 09
13	0.447700E 04	14	J.500000E 01	15	-0.100000E 01	16	J.640000E 03	17	0.262500E 03		
31	0.300000E-03	32	J.300000E-03	33	0.260000E-02	34	0.131000E-02	35	0.145000E-02	36	0.210000E-03
41	0.300000E 01	42	J.113000E 01	43	0.301000E 00	44	0.111000E 00	45	0.305000E-01	46	0.124000E-01
61	0.100000E 01	62	J.300000E 01	63	0.230000E 02	64	0.250000E 02				
81	0.131900E 01	82	J.365500E-02	83	0.776270E-02	84	0.0	85	0.500000E 07	86	0.0
87	0.939000E 00	88	J.392000E-02	89	0.473800E-02	90	0.270000E 06	91	0.619000E-13	92	0.0
93	J.131900E 01	94	J.335500E-02	95	0.776270E-02	96	0.0	97	0.500000E 07	98	0.0
99	0.939000E 00	100	J.392000E-02	101	0.473800E-02	102	0.270000E 06	103	0.619000E-13	104	0.0
105	0.131900E 01	106	J.365500E-02	107	0.776270E-02	108	0.0	109	0.500000E 07	110	0.0
111	0.939000E 00	112	J.392000E-02	113	0.473800E-02	114	0.270000E 06	115	0.619000E-13	116	0.0
301	-0.130000E-04	302	J.0	303	0.660000E-02	304	0.0	305	-0.600000E-05	306	0.0
450	J.300000E 01	451	J.230000E 02								
452	J.300000E 01	453	J.200000E 01	454	J.100000E 01	455	0.0	456	0.0	457	0.0
458	J.100000E 01	459	J.0	460	0.100000E 01	461	0.0	462	0.0		
501	0.900000E 00	502	J.108000E 01	503	0.500000E-02	504	0.400000E-01	505	0.103500E 02	506	0.335000E 00
507	0.334000E-01	508	J.200000E 01	509	0.655000E 01	510	0.335000E 00	511	0.159000E 00	512	0.0
513	0.367800E 03	514	J.0	515	0.0	516	0.500000E 00	517	0.0	518	0.0
519	0.251500E 03	520	J.338000E 03	521	0.171000E-01	522	0.0	523	0.0	524	0.250000E 01
525	0.207000E 03	526	J.365000E 00	527	0.500000E-01	528	0.518000E 01	529	0.127500E 04	530	0.0
533	0.500000E 02	534	-J.650000E 02								
547	J.300000E 02	548	J.0	549	J.0	550	0.100000E 01				
601	0.838000E 02	602	J.115000E-02	603	0.522000E-02	604	0.0	605	0.813000E 00		
680	0.0	681	J.499000E 00	682	J.500000E 00						
690	J.250000E 01	691	0.250000E 01	692	0.100000E 01						
1600	J.500000E 02	1601	J.100000E-02	1602	0.100000E-02						
1617	-0.100000E 01	1618	J.200000E 01	1619	0.0	1620	-0.785000E-01				
1621	0.200000E 01	1622	0.250000E 01								
1701	0.0	1702	J.400000E 03								
1851	J.300000E 03	1852	J.500000E 02	1853	J.300000E 01	1854	0.100000E 03	1855	0.200000E 01	1856	0.0

BETA	LAMBDA
0.30000E-03	0.30000E 01
0.83000E-03	0.11300E 01
0.26900E-02	0.30100E 00
0.13100E-02	0.11100E 00
0.14500E-02	0.39000E-01
0.21000E-03	0.12700E-01

FUEL DATA

FUEL RADIUS	DENSITY	MASS/CM	CLAD RADIUS	EXT. RADIUS
0.54000E 00	0.10350E 02	0.04815E 01	0.54500E 00	0.58500E 00

3 REGIONS IN FUEL

RAJII	RELATIVE POWER
0.31177	0.44091 0.54000
0.33333	0.33333 0.33333

TEMPERATURE INDEPENDENT CONSTANTS

CPF	KF	CPCL	KCL
0.33500E 00	0.33400E-01	0.33500E 00	0.15900E 00

STATIC CALCULATION

CHANNEL DATA

HEIGHT 307.8 CM SECTION 0.920 CM COOLANT DENSITY 0.86500 G/CM3 GRAVITY= 990.000 CM/SEC\*\*2  
 INLET PIPE HEIGHT 0.0  
 NO RISER  
 TOTAL CHANNEL POWER IN FUEL 0.44673E 05WATT  
 TOTAL CHANNEL POWER IN COOLANT 0.0 WATT

OPTICS

IMPOSED PRESSURE DROP 2.50000 BAR  
 SEARCH FOR INLET ORIFICE FOR= 0.0

INLET VELOCITY /VINLET/= 393.000 CM/SEC  
 EXIT QUALITY /XOUT/= -0.07423  
 AVERAGE VOID FRACTION /AVE/= 0.0  
 POWER FLUX TO COOLANT /T.M.F/= 0.44673E 05WATT  
 POWER OUTPUT 0.44673E 05

PRESSURE DROP 2.50000 BAR  
 INLET 0.0 CHANNEL 0.74267 RISER 0.0  
 FRICTION 0.40038 GRAVITY 0.31178 SPACE ACCEL. 0.0

HEAT TRANSFER CONSTANTS

HC 0.31713E 01 HD 0.33273E-01 AM 4.000 TAU 0.43500  
 TETA 2.26 TETA 3.91 K 0.873 ZE 0.0 41

I	PJH	FI	J	VF	TSJR	TICL	AVTF	TMAXE	TL						
1	0.12146E	03	0.33044E	02	0.0	0.26323E	03	0.27189E	03	0.51119E	03	0.63542E	03	0.25286E	03
2	0.12146E	03	0.33044E	02	0.0	0.26464E	03	0.27325E	03	0.51255E	03	0.63679E	03	0.25422E	03
3	0.12146E	03	0.33044E	02	0.0	0.26500E	03	0.27461E	03	0.51391E	03	0.63814E	03	0.25558E	03
4	0.12146E	03	0.33044E	02	0.0	0.26736E	03	0.27597E	03	0.51527E	03	0.63951E	03	0.25695E	03
5	0.12146E	03	0.33044E	02	0.0	0.26873E	03	0.27733E	03	0.51663E	03	0.64087E	03	0.25831E	03
6	0.12146E	03	0.33044E	02	0.0	0.27009E	03	0.27869E	03	0.51799E	03	0.64223E	03	0.25967E	03
7	0.12146E	03	0.33044E	02	0.0	0.27145E	03	0.28006E	03	0.51936E	03	0.64359E	03	0.26103E	03
8	0.12146E	03	0.33044E	02	0.0	0.27281E	03	0.28142E	03	0.52072E	03	0.64495E	03	0.26239E	03
9	0.12146E	03	0.33044E	02	0.0	0.27417E	03	0.28278E	03	0.52208E	03	0.64631E	03	0.26375E	03
10	0.12146E	03	0.33044E	02	0.0	0.27553E	03	0.28414E	03	0.52344E	03	0.64767E	03	0.26511E	03
11	0.12146E	03	0.33044E	02	0.0	0.27689E	03	0.28550E	03	0.52480E	03	0.64904E	03	0.26648E	03
12	0.12146E	03	0.33044E	02	0.0	0.27826E	03	0.28686E	03	0.52616E	03	0.65040E	03	0.26784E	03
13	0.12146E	03	0.33044E	02	0.0	0.27962E	03	0.28822E	03	0.52752E	03	0.65176E	03	0.26920E	03
14	0.12146E	03	0.33044E	02	0.0	0.28098E	03	0.28958E	03	0.52889E	03	0.65312E	03	0.27056E	03
15	0.12146E	03	0.33044E	02	0.0	0.28234E	03	0.29095E	03	0.53025E	03	0.65448E	03	0.27192E	03
16	0.12146E	03	0.33044E	02	0.0	0.28370E	03	0.29231E	03	0.53161E	03	0.65584E	03	0.27328E	03
17	0.12146E	03	0.33044E	02	0.0	0.28506E	03	0.29367E	03	0.53297E	03	0.65720E	03	0.27464E	03
18	0.12146E	03	0.33044E	02	0.0	0.28642E	03	0.29503E	03	0.53433E	03	0.65857E	03	0.27601E	03
19	0.12146E	03	0.33044E	02	0.0	0.28779E	03	0.29639E	03	0.53569E	03	0.65993E	03	0.27737E	03
20	0.12146E	03	0.33044E	02	0.0	0.28915E	03	0.29775E	03	0.53705E	03	0.66129E	03	0.27873E	03

FUEL TEMPERATURE MAP

1	635.42	477.00	339.14
2	636.73	500.50	+10.50
3	638.14	502.75	+11.86
4	639.51	503.90	+13.22
5	640.87	504.45	+14.59
6	642.23	505.00	+15.95
7	643.59	507.17	+17.31
8	644.95	508.50	+18.67
9	646.31	509.90	+10.03
10	647.67	511.20	+11.39
11	649.04	512.50	+12.75
12	650.40	513.90	+14.12
13	651.77	515.34	+15.48
14	653.12	516.70	+16.84
15	654.48	518.00	+18.20
16	655.84	519.50	+19.56
17	657.20	520.70	+20.92
18	658.57	522.20	+22.28
19	659.93	523.50	+23.64
20	661.29	524.87	+25.00



TIME 0.0 IT 0 POWER 0.20000E 09

	FLUX1	FLUX2	POWER	RJD VALUE	DKFBACK	DKVOID
1	0.0	0.0	0.0	0.0	0.0	0.0
2	0.10330D 14	0.20270D 14	0.0	0.0	0.0	0.0
3	0.21331D 14	0.40190D 14	0.3931E 00	0.0	0.17324E-02	0.0
4	0.51633D 14	0.59337D 14	0.50453E 00	0.0	0.17065E-02	0.0
5	0.41370D 14	0.77000D 14	0.75825E 00	0.0	0.16807E-02	0.0
6	0.50333D 14	0.94180D 14	0.39813E 00	0.0	0.16548E-02	0.0
7	0.58534D 14	0.10913D 15	0.10221E 01	0.0	0.16289E-02	0.0
8	0.65377D 14	0.12210D 15	0.11280E 01	0.0	0.16031E-02	0.0
9	0.71436D 14	0.13316D 15	0.12145E 01	0.0	0.15772E-02	0.0
10	0.75133D 14	0.14130D 15	0.12801E 01	0.0	0.15513E-02	0.0
11	0.79433D 14	0.14303D 15	0.13241E 01	0.0	0.15255E-02	0.0
12	0.81432D 14	0.15170D 15	0.13460E 01	0.0	0.14996E-02	0.0
13	0.82110D 14	0.15293D 15	0.13454E 01	0.0	0.14737E-02	0.0
14	0.81371D 14	0.15100D 15	0.13225E 01	0.0	0.14479E-02	0.0
15	0.79515D 14	0.14778D 15	0.12775E 01	0.0	0.14220E-02	0.0
16	0.75911D 14	0.14100D 15	0.12110E 01	0.0	0.13961E-02	0.0
17	0.71220D 14	0.13270D 15	0.11240E 01	0.0	0.13703E-02	0.0
18	0.65327D 14	0.12170D 15	0.10177E 01	0.0	0.13444E-02	0.0
19	0.58333D 14	0.10337D 15	0.39381E 00	0.0	0.13185E-02	0.0
20	0.50233D 14	0.93300D 14	0.75410E 00	0.0	0.12927E-02	0.0
21	0.41320D 14	0.77000D 14	0.50103E 00	0.0	0.12668E-02	0.0
22	0.31650D 14	0.59035D 14	0.37171E 00	0.0	0.12409E-02	0.0
23	0.21410D 14	0.39070D 14	0.0	0.0	0.0	0.0
24	0.10700D 14	0.20109D 14	0.0	0.0	0.0	0.0
25	0.0	0.0	0.0	0.0	0.0	0.0
AVER.	0.52421D 14	0.97692D 14	0.12175E 03		0.14870E-02	0.0

TIME 0.0 POWER RATIO 0.10000E 01  
 POWER 0.20000E 09 MAT7 PHE 0.52421D 14 PHE 0.97692D 14 PER 0.77782E-01 PINT 0.0  
 FLUX1 0.1032E 14 0.3075E 14 0.1070E 14  
 FLUX2 0.2013E 14 0.1132E 15 0.2005E 14  
 A/PD 0.0 0.1000E 01 0.0

SPRS = 0.10000E-02    JAPF = 0.10000E-02    LF = 50    ITCR = 1

ITERATIONS                    PM2                    REP                    SPCR  
 0                    0.976980 14            -0.47050E-03            -0.11325E-01  
 KEFF 1.011454

TIME 0.0    IT    0    POWER 0.20000E 09

	FLUX1	FLUX2	POWER	RJD VALUE	DKFBACK	DKVOID
1	0.0	J.0	0.0	0.0	0.0	0.0
2	0.10782D 14	J.20329D 14	J.0	J.0	0.0	0.0
3	0.21403D 14	J.40313D 14	0.44119E 00	0.0	0.36235E-02	0.0
4	0.31641D 14	J.59574D 14	0.60631E 00	0.0	0.30533E-02	0.0
5	0.41260D 14	J.77701D 14	0.76002E 00	0.0	0.25174E-02	0.0
6	0.50101D 14	J.94373D 14	0.89970E 00	0.0	0.20251E-02	0.0
7	0.58022D 14	0.10933D 15	0.10232E 01	0.0	0.15840E-02	0.0
8	0.64993D 14	J.12233D 15	0.11285E 01	0.0	0.12009E-02	0.0
9	0.70653D 14	0.13319D 15	0.12144E 01	0.0	0.88125E-03	0.0
10	J.75133D 14	0.14173D 15	J.12795E 01	0.0	0.62945E-03	0.0
11	0.78451D 14	0.14793D 15	0.13231E 01	J.0	0.44882E-03	0.0
12	J.83403D 14	J.15113D 15	J.13446E 01	J.0	0.34171E-03	0.0
13	0.81027D 14	J.15281D 15	0.13439E 01	0.0	0.30947E-03	0.0
14	0.83312D 14	J.15143D 15	0.13209E 01	0.0	0.35251E-03	0.0
15	0.78271D 14	J.14730D 15	J.12760E 01	J.0	0.47027E-03	0.0
16	0.74932D 14	J.14130D 15	0.12098E 01	0.0	0.56126E-03	0.0
17	J.70540D 14	J.13282D 15	0.11232E 01	0.0	0.92298E-03	0.0
18	0.64553D 14	J.12133D 15	J.10174E 01	0.0	0.12519E-02	0.0
19	J.57633D 14	J.10387D 15	J.89399E 00	0.0	0.16433E-02	0.0
20	0.49751D 14	0.93713D 14	J.75471E 00	0.0	0.20916E-02	0.0
21	0.40943D 14	0.77134D 14	J.50173E 00	J.0	0.25896E-02	0.0
22	0.31333D 14	J.59116D 14	0.43770E 00	0.0	0.31290E-02	0.0
23	0.21227D 14	J.59399D 14	J.0	0.0	0.0	0.0
24	0.10093D 14	J.20133D 14	0.0	0.0	0.0	0.0
25	0.0	0.0	0.0	0.0	0.0	0.0
AVER.	0.51330D 14	0.97693D 14	0.12146E 03		0.97478E-03	0.0

	C1	C2	C3	C4	C5	C6
1	0.0	J.0	0.0	0.0	0.0	0.0
2	0.97337D 07	0.71493D 03	J.36988D 09	0.11487D 10	0.46275D 10	0.16494D 10
3	0.19303D 08	J.14173D 09	0.17251D 10	0.22781D 10	0.91769D 10	0.32691D 10

4	J.28524J	03	J.20951J	03	J.25491J	10	0.33563D	10	0.13561D	11	0.49307D	10
5	J.37203D	03	J.27326J	03	0.33248D	10	0.43906D	10	0.17687D	11	0.63005D	10
6	J.45187J	03	J.35190J	03	0.40383J	10	0.53329D	10	0.21482D	11	0.76526D	10
7	J.5234J	03	J.33749J	03	0.45781J	10	0.61778D	10	0.24886D	11	0.88650D	10
8	J.58570J	03	J.43021J	03	J.52343J	10	0.69123D	10	0.27845D	11	0.99191D	10
9	J.65770J	03	J.4637J	03	0.56991D	10	0.75260D	10	0.30317D	11	0.10900D	11
10	J.67374J	03	J.49355J	03	0.60659J	10	0.80104D	10	0.32268D	11	0.11405D	11
11	J.70330J	03	J.52025J	03	J.63300J	10	0.83592D	10	0.33573D	11	0.11995D	11
12	J.72000J	03	J.55525J	03	0.64882D	10	0.85581D	10	0.34515D	11	0.12295D	11
13	J.75265D	03	J.5772J	03	J.65387D	10	0.86548D	10	0.34783D	11	0.12391D	11
14	J.72529J	03	J.55255J	03	0.64309J	10	0.85585D	10	0.34476D	11	0.12291D	11
15	J.70573J	03	J.51910J	03	0.63159J	10	0.83407D	10	0.33599D	11	0.11960D	11
16	J.67552J	03	J.49531J	03	0.60460J	10	0.79342J	10	0.32162D	11	0.11457D	11
17	J.65497J	03	J.46070J	03	0.55747D	10	0.74938D	10	0.30187D	11	0.10754D	11
18	J.62055J	03	J.42727J	03	0.52071J	10	0.68764D	10	0.27700D	11	0.09676D	10
19	J.58051J	03	J.38217J	03	J.48499J	10	0.61406D	10	0.24736D	11	0.09117D	10
20	J.44333J	03	J.35567J	03	J.40111D	10	0.52970D	10	0.21338D	11	0.76012D	10
21	J.55952J	03	J.47127J	03	J.53005J	10	0.43586J	10	0.17558D	11	0.62546D	10
22	J.26503J	03	J.25700J	03	J.25296J	10	J.33705D	10	0.13456D	11	0.47935D	10
23	J.19251J	03	J.24057D	03	J.17115J	10	0.22502D	10	0.91047D	10	0.32434D	10
24	J.95567J	07	J.70930J	03	J.35301D	09	0.11397D	10	0.45909D	10	0.15354D	10
25	J.J		J.0		0.0		0.0		0.0		0.0	

TIME 0.0 POWER RATIO 0.10000E 01

POWER 0.20000E 00 MATF PH1 0.52550D 14 PH2 0.97593D 14 PER-0.21254E 04 PINT 0.0

FL1 J.20712 14 0.0000E 14 0.1000E 14

FL2 J.20272 14 0.0132E 15 0.2000E 14

A/P J.J 0.1000E 01 0.0

STATIC CALCULATION

CHANNEL DATA

HEIGHT 307.8 CM SECTION 0.020 C.M COOLANT DENSITY 0.86500 G/CM3 GRAVITY= 990.000 CM/SEC\*\*2  
 INLET PIPE HEIGHT 0.0  
 NO RISER  
 TOTAL CHANNEL POWER IN FUEL 0.44573E 05.WATT  
 TOTAL CHANNEL POWER IN COOLANT 0.0 WATT

OPTIONS

IMPOSED PRESSURE DROP 2.50000 BAR  
 SEARCH FOR INLET ORIFICE FDR= -4.34909

INLET VELOCITY /VINLET/= 393.000 CM/SEC  
 EXIT QUALITY /XOUT/= -0.07423  
 AVERAGE VOID FRACTION /AVE/= 0.0  
 POWER FLOW TO COOLANT /T.MF/= 0.44573E 05.WATT  
 POWER OUTPUT 0.44573E 05

PRESSURE DROP 2.50000 BAR  
 INLET 2.05319 CHARGE 0.74267 RISER -0.00000  
 FRICTION 2.43517 GRAVITY 0.31178 SPACE ACCEL. 0.0

HEAT TRANSFER CONSTANTS  
 HC 0.01715E 01 IS 0.03273E-01 AI 4.000 TAU 0.43500  
 TEF 2.25 TEFAP 3.01 K 0.873 ZE 0.0 40

I	PJJ	FI	VF	TJJK	TICL	AVTF	TMAXE	TL
1	0.35586E	0.14577E	0.0	0.25670E	0.26749E	0.36607E	0.42089E	0.25210E
2	0.75541E	0.20055E	0.0	0.25924E	0.26446E	0.40955E	0.48487E	0.25293E
3	0.92311E	0.23211E	0.0	0.26133E	0.26342E	0.45029E	0.54471E	0.25396E
4	0.10943E	0.27750E	0.0	0.26456E	0.27230E	0.48760E	0.59938E	0.25519E
5	0.12417E	0.3309E	0.0	0.26724E	0.27604E	0.52089E	0.64800E	0.25653E
6	0.13707E	0.37202E	0.0	0.26937E	0.27959E	0.54965E	0.68985E	0.25911E
7	0.14750E	0.40123E	0.0	0.27242E	0.28287E	0.57347E	0.72434E	0.25977E
8	0.15541E	0.42280E	0.0	0.27484E	0.28585E	0.59204E	0.75090E	0.26151E
9	0.16070E	0.43721E	0.0	0.27740E	0.28848E	0.60510E	0.76947E	0.26331E
10	0.16332E	0.4451E	0.0	0.27915E	0.29072E	0.61249E	0.77954E	0.26514E
11	0.16323E	0.44707E	0.0	0.28097E	0.29254E	0.61413E	0.78100E	0.26697E
12	0.16143E	0.44343E	0.0	0.28253E	0.29390E	0.60999E	0.77400E	0.26877E
13	0.15498E	0.42164E	0.0	0.28380E	0.29478E	0.60013E	0.75955E	0.27051E
14	0.14501E	0.3977E	0.0	0.28476E	0.29517E	0.58468E	0.73499E	0.27215E
15	0.13545E	0.37115E	0.0	0.28539E	0.29505E	0.56384E	0.70339E	0.27368E
16	0.12353E	0.3352E	0.0	0.28567E	0.29443E	0.53790E	0.65430E	0.27507E
17	0.10858E	0.2941E	0.0	0.28560E	0.29329E	0.50723E	0.61920E	0.27629E
18	0.09157E	0.2493E	0.0	0.28513E	0.29167E	0.47227E	0.56503E	0.27731E
19	0.75092E	0.13385E	0.0	0.28440E	0.28958E	0.43359E	0.50935E	0.27813E
20	0.53171E	0.14465E	0.0	0.28329E	0.28706E	0.39181E	0.44620E	0.27873E

FUEL TEMPERATURE MAP

1	420.33	500.70	316.64
2	437.57	492.20	341.51
3	444.71	481.00	355.13
4	493.53	470.54	330.79
5	448.00	503.42	416.24
6	489.65	535.90	423.20
7	724.34	533.53	437.40
8	750.99	570.45	449.67
9	769.17	533.98	455.35
10	779.54	505.21	451.85
11	774.69	507.75	453.55
12	774.69	593.70	451.70
13	738.65	534.58	457.15
14	734.93	509.94	449.12
15	795.53	550.20	437.90
16	554.50	525.50	423.90
17	518.29	495.34	407.05
18	558.03	423.08	337.71
19	508.55	425.20	356.10
20	440.20	336.43	342.70

DYNAMIC CALCULATION

OPTIO 15

VIJLET CALCULATED  
PRESSURE DROP GIVEN IN INPUT

TIME 0.0 0.50 0.50  
P. DRDP 0.250E 07 0.250E 07 0.100E 07

TIME STEP FOR THERMAL CALCULATION 0.05000

DKIME PERTURBATION  
BANKED RODS PERTURBATION  
INSERTION FROM OUTLET

PERTURBATION TIME TABLE

TIME	1.000	2.000
0.0	0.0	0.40000E 05

TO = 0.010

VBAR = 0.0

TIME 0.500 SEC  
 POWER 0.44565E 05 TIME 0.44673E 05 AVF 0.0 XOUT -0.07423  
 VI.ILET 393.000 PDRDP 1.000  
 AVERAGE FUEL TEMPERATURE 524.132  
 MAX.FUEL TEMP. 731.079 IN NODE 11  
 MAX.CEND TEMP. 205.172 IN NODE 14  
 MAX.HEAT FLUX 44.752 IN NODE 10  
 FIRST BOILING NODE 21  
 EXIT LIQUID SUPERHEAT -13.271

TIME 0.5000 POWER RATIO 0.09934E 00  
 POWER 0.10907E 09 WATT PH1 0.51322D 14 PH2 0.97683D 14 PER-0.15515E 05 PINT 0.22334E 05  
 FL11 0.1077E 14 0.5005E 14 0.1005E 14  
 FL12 0.2024E 14 0.1132E 15 0.2003E 14  
 AVPJ 0.0 0.1000E 01 0.0

TIME 1.000 SEC  
 POWER 0.47435E 05 TIME 0.41373E 05 AVF 0.0 XOUT -0.05807  
 VI.ILET 223.211 PDRDP 1.000  
 AVERAGE FUEL TEMPERATURE 524.357  
 MAX.FUEL TEMP. 731.051 IN NODE 11  
 MAX.CEND TEMP. 205.370 IN NODE 14  
 MAX.HEAT FLUX 41.255 IN NODE 10  
 FIRST BOILING NODE 21  
 EXIT LIQUID SUPERHEAT -14.294

I	PUJ	FI	VF	TSJR	TICL	AVTF	TMAXE	TL
1	0.55580E 02	0.14701E 02	0.0	0.25954E 03	0.26319E 03	0.36633E 03	0.42097E 03	0.25252E 03
2	0.75555E 02	0.17067E 02	0.0	0.26348E 03	0.26849E 03	0.40993E 03	0.48496E 03	0.25388E 03
3	0.90949E 02	0.25013E 02	0.0	0.26752E 03	0.27377E 03	0.45078E 03	0.54459E 03	0.25554E 03
4	0.10884E 03	0.23084E 02	0.0	0.27155E 03	0.27392E 03	0.48820E 03	0.59935E 03	0.25744E 03
5	0.12577E 03	0.31921E 02	0.0	0.27549E 03	0.28385E 03	0.52158E 03	0.64797E 03	0.25951E 03

6	U.13551E	03	U.55374E	JL	U.0	U.0	U.27027E	03	U.29346E	03	U.55043E	03	U.69982E	03	U.26170E	03
7	U.14839E	03	U.57511E	JL	U.0	U.0	U.23280E	03	U.29267E	03	U.57433E	03	U.72431E	03	U.26396E	03
8	U.15470E	03	U.59499E	JL	U.0	U.0	U.23609E	03	U.29541E	03	U.59295E	03	U.75095E	03	U.26625E	03
9	U.15903E	03	U.61721E	JL	U.0	U.0	U.23891E	03	U.29362E	03	U.60606E	03	U.76844E	03	U.26852E	03
10	U.16262E	03	U.64283E	JL	U.0	U.0	U.29140E	03	U.30226E	03	U.61348E	03	U.77951E	03	U.27073E	03
11	U.16253E	03	U.66112E	JL	U.0	U.0	U.29344E	03	U.30427E	03	U.61512E	03	U.78105E	03	U.27285E	03
12	U.15974E	03	U.68290E	JL	U.0	U.0	U.29502E	03	U.30564E	03	U.61097E	03	U.77405E	03	U.27483E	03
13	U.15431E	03	U.70309E	JL	U.0	U.0	U.29609E	03	U.30633E	03	U.60109E	03	U.75962E	03	U.27666E	03
14	U.14630E	03	U.72721E	JL	U.0	U.0	U.29655E	03	U.30634E	03	U.58560E	03	U.73494E	03	U.27829E	03
15	U.13583E	03	U.75013E	JL	U.0	U.0	U.29663E	03	U.30565E	03	U.56470E	03	U.70335E	03	U.27969E	03
16	U.12504E	03	U.76581E	JL	U.0	U.0	U.29617E	03	U.30427E	03	U.53869E	03	U.65427E	03	U.28086E	03
17	U.10311E	03	U.78713E	JL	U.0	U.0	U.29513E	03	U.30222E	03	U.50794E	03	U.61826E	03	U.28176E	03
18	U.91268E	02	U.82371E	JL	U.0	U.0	U.29557E	03	U.29953E	03	U.47289E	03	U.55691E	03	U.28237E	03
19	U.72775E	02	U.17523E	JL	U.0	U.0	U.29151E	03	U.29522E	03	U.43410E	03	U.50833E	03	U.28269E	03
20	U.52940E	02	U.12547E	JL	U.0	U.0	U.23399E	03	U.29237E	03	U.39221E	03	U.44619E	03	U.28271E	03

TIME 1.0000 POWER RATIO 0.00584E 00

POWER 0.19913E 00 HATT P11 0.51504D 14 PH2 0.97275D 14 PER-0.67568E 02 PINT 0.44631E 05  
 FL11 J.1070E 14 0.5979E 14 0.1001E 14  
 FL12 J.2015E 14 0.1127E 15 0.1099E 14  
 AVPU J.0 0.1000E 01 0.0

TIME 1.00001 IT 100 POWER 0.19913E 00

	FLUX1	FLUX2	POWER	RJD VALUE	DKFBACK	DKVOID
1	0.0	0.0	0.0	0.0	0.0	0.0
2	U.10740D 14	J.20219D 14	U.0	U.0	U.0	U.0
3	U.21315D 14	J.40136D 14	U.44136E 00	U.0	U.36176E-02	U.0
4	U.31515D 14	J.59356D 14	U.50652E 00	U.0	U.30426E-02	U.0
5	U.41094D 14	J.77337D 14	U.76025E 00	U.0	U.25015E-02	U.0
6	U.49895D 14	J.95991D 14	U.99993E 00	U.0	U.20038E-02	U.0
7	U.57782D 14	J.10333D 15	U.10234E 01	U.0	U.15573E-02	U.0
8	U.64834D 14	J.12132D 15	U.11237E 01	U.0	U.11692E-02	U.0
9	U.70533D 14	J.15262D 15	U.12145E 01	U.0	U.84495E-03	U.0
10	U.74864D 14	J.14115D 15	U.12709E 01	U.0	U.58913E-03	U.0
11	U.78110D 14	J.14729D 15	U.13231E 01	U.0	U.40515E-03	U.0
12	U.80052D 14	J.15007D 15	U.13445E 01	U.0	U.29542E-03	U.0
13	U.80857D 14	J.15215D 15	U.13433E 01	U.0	U.26135E-03	U.0
14	U.79953D 14	J.15070D 15	U.13297E 01	U.0	U.30335E-03	U.0
15	U.77910D 14	J.14507D 15	U.12758E 01	U.0	U.42092E-03	U.0
16	U.74594D 14	J.14066D 15	U.12095E 01	U.0	U.61253E-03	U.0
17	U.70021D 14	J.13201D 15	U.11230E 01	U.0	U.37568E-03	U.0
18	U.64233D 14	J.12117D 15	U.10173E 01	U.0	U.12068E-02	U.0
19	U.57590D 14	J.10513D 15	U.99585E 00	U.0	U.16013E-02	U.0
20	U.49525D 14	J.95513D 14	U.75460E 00	U.0	U.20532E-02	U.0
21	U.40764D 14	J.76730D 14	U.50170E 00	U.0	U.25556E-02	U.0
22	U.31243D 14	J.56350D 14	U.3771E 00	U.0	U.11001E-02	U.0



23	0.21132D 14	0.39320D 14	J.0	0.0	0.0	0.0
24	0.10043D 14	0.20070D 14	J.0	0.0	0.0	0.0
25	0.0	J.0	0.0	-0.37250E-01	0.0	0.0
AVER.	0.51504D 14	0.97273D 14	J.12093E 03		0.93437E-03	0.0

TIME 1.500 SEC  
 POWER 0.44207E 05 TRF 0.41402E 05 AVF 0.0 XOUT -0.03414

VILET 223.205 PWRP 1.000

AVERAGE FUEL TEMPERATURE 325.326  
 MAX.FUEL TEMP. 730.075 IN NODE 11  
 MAX.CLAD TEMP. 311.295 IN NODE 14  
 MAX.HEAT FLUX 11.545 IN NODE 10

FIRST BOILING NODE 21  
 EXIT LIQUID SUPERHEAT -3.402

TIME 1.5000 POWER RATIO 0.33945E 00

POWER 0.19739E 00 WATT P1 0.51233D 14 P12 0.96669D 14 PER-0.79294E 02 PINT 0.65795E 05  
 FLM1 0.1004E 14 0.5942E 14 0.1057E 14  
 FLM2 0.2005E 14 0.1120E 13 0.1935E 14  
 AVP1 0.0 0.1000E 01 0.0

TIME 2.000 SEC  
 POWER 0.45193E 05 TRF 0.42412E 05 AVF 0.05106 XOUT -0.01111

VILET 219.311 PWRP 1.000

AVERAGE FUEL TEMPERATURE 326.068  
 MAX.FUEL TEMP. 731.250 IN NODE 11  
 MAX.CLAD TEMP. 312.439 IN NODE 13  
 MAX.HEAT FLUX 12.200 IN NODE 10

FIRST BOILING NODE 13  
 EXIT LIQUID SUPERHEAT -7.132

I	P01	FI		VF	TSJR	TICL	AVTF	TMAXC	TL
1	0.54001E 01	0.21129E 01	J.0	0.0	0.25914E 03	0.26354E 03	0.36675E 03	0.42097E 03	0.25257E 03
2	0.74121E 02	0.19585E 02	J.0	0.0	0.26309E 03	0.26707E 03	0.41058E 03	0.48487E 03	0.25404E 03
3	0.05053E 02	0.21173E 02	J.0	0.0	0.26331E 03	0.27465E 03	0.45169E 03	0.54472E 03	0.25587E 03
4	0.21018E 03	0.23394E 03	J.0	0.0	0.27170E 03	0.28019E 03	0.48936E 03	0.59740E 03	0.25803E 03
5	0.12553E 03	0.32765E 03	J.0	0.0	0.27710E 03	0.28560E 03	0.52301E 03	0.64903E 03	0.26046E 03
6	0.13329E 03	0.35023E 03	J.0	0.0	0.28147E 03	0.29077E 03	0.55211E 03	0.68990E 03	0.26313E 03

7	0.14333E	03	0.03342E	02	0.0	0.0	0.23550E	03	0.29562E	03	0.57626E	03	0.72440E	03	0.25597E	03
8	0.15095E	03	0.40572E	02	0.0	0.0	0.28955E	03	0.30007E	03	0.59511E	03	0.75109E	03	0.26894E	03
9	0.16241E	03	0.11792E	02	0.0	0.0	0.29320E	03	0.30405E	03	0.60843E	03	0.76959E	03	0.27198E	03
10	0.16520E	03	0.41291E	02	0.0	0.0	0.29650E	03	0.30743E	03	0.61604E	03	0.77967E	03	0.27502E	03
11	0.16923E	03	0.42301E	02	0.0	0.0	0.29933E	03	0.31030E	03	0.61784E	03	0.78123E	03	0.27801E	03
12	0.16257E	03	0.41181E	02	0.0	0.0	0.30173E	03	0.31246E	03	0.61382E	03	0.77426E	03	0.28090E	03
13	0.15740E	03	0.41265E	02	-0.04841E-01	0.032251E-01	0.30195E	03	0.31247E	03	0.60398E	03	0.75894E	03	0.28293E	03
14	0.14352E	03	0.37355E	02	-0.04443E-01	0.015330E-01	0.30135E	03	0.31163E	03	0.58837E	03	0.73519E	03	0.28432E	03
15	0.13909E	03	0.34983E	02	-0.03573E-01	0.015261E-01	0.30175E	03	0.31087E	03	0.56740E	03	0.70360E	03	0.28957E	03
16	0.12522E	03	0.3324E	02	-0.02709E-01	0.014407E-01	0.30154E	03	0.30985E	03	0.54133E	03	0.66453E	03	0.28695E	03
17	0.11109E	03	0.27407E	02	-0.02051E-01	0.013722E-01	0.30143E	03	0.30862E	03	0.51053E	03	0.61952E	03	0.28798E	03
18	0.93903E	02	0.22395E	02	-0.01553E-01	0.011184E-01	0.30127E	03	0.30713E	03	0.47544E	03	0.56625E	03	0.28883E	03
19	0.74047E	02	0.17467E	02	-0.01154E-01	0.010759E-01	0.30100E	03	0.30555E	03	0.43662E	03	0.50955E	03	0.28946E	03
20	0.54549E	02	0.11015E	02	-0.01113E-01	0.010427E-01	0.30055E	03	0.30371E	03	0.39470E	03	0.44539E	03	0.28987E	03

TJ = 2.000      VBAR = 0.0

TIME 2.0000 POWER RATIO 0.101+3E 01  
 POWER 0.20200E 03 HATT P11 0.32599D 14 PH2 0.99157D 14 PER 0.12135E 02 PINT 0.99103E 05  
 FL11 0.1003E 14 0.3003E 14 0.1003E 14  
 FL12 0.2041E 14 0.1140E 13 0.2003E 14  
 AVPJ 0.0 0.1000E 01 0.0

TIME 2.0000 IT LOC POWER 0.20296E 09

	FL1X1	FL1X2	POWER	RJD VALUE	OKFBACK	OKVOID
1	0.0	0.0	0.0	0.0	0.0	0.0
2	0.10870D 14	0.10490D 14	0.0	0.0	0.0	0.0
3	0.21570D 14	0.40840D 14	0.4383E 00	0.0	0.36118E-02	0.0
4	0.31900D 14	0.60070D 14	0.50249E 00	0.0	0.50332E-02	0.0
5	0.41600D 14	0.78361D 14	0.75535E 00	0.0	0.24878E-02	0.0
6	0.50534D 14	0.95100D 14	0.89433E 00	0.0	0.19851E-02	0.0
7	0.53533D 14	0.11030D 15	0.10174E 01	0.0	0.15332E-02	0.0
8	0.65504D 14	0.12300D 15	0.11225E 01	0.0	0.11388E-02	0.0
9	0.71534D 14	0.13400D 15	0.12035E 01	0.0	0.80787E-03	0.0
10	0.75951D 14	0.14320D 15	0.12741E 01	0.0	0.54489E-03	0.0
11	0.79300D 14	0.14950D 15	0.13185E 01	0.0	0.35354E-03	0.0
12	0.81342D 14	0.15340D 15	0.13421E 01	0.0	0.23634E-03	0.0
13	0.82050D 14	0.15470D 15	0.13420E 01	0.0	0.19493E-03	0.0
14	0.81435D 14	0.15500D 15	0.13210E 01	0.0	0.22993E-03	0.0
15	0.77470D 14	0.14900D 15	0.12782E 01	0.0	0.55855E-03	0.21296E-03
16	0.75250D 14	0.14370D 15	0.12143E 01	0.0	0.11430E-02	0.50278E-03
17	0.71742D 14	0.13520D 15	0.11295E 01	0.0	0.16798E-02	0.87524E-03
18	0.55932D 14	0.11430D 15	0.10251E 01	0.0	0.22189E-02	0.10829E-02

19	0.590430	14	0.111220	15	1.00225E 00	0.0	0.27658E-02	0.12356E-02
20	0.510230	14	0.950850	14	0.76260E 00	0.0	0.33124E-02	0.13322E-02
21	0.420310	14	0.791550	14	0.50874E 00	0.0	0.38523E-02	0.13701E-02
22	0.322530	14	0.507120	14	0.14305E 00	0.0	0.43728E-02	0.13492E-02
23	0.220150	14	0.410000	14	0.0	0.0	0.0	0.0
24	0.109330	14	0.207130	14	0.0	0.0	0.0	0.0
25	0.0		0.0		0.0	-0.39265E-01	0.0	0.0
AVER.	0.525090	14	0.991570	14	0.12326E 00		0.11576E-02	0.27744E-03

TIME 2.500 SEC  
 POWER 0.54275E 04      FIF 0.40515E 05      AVE 0.05935      XOUT 0.00036  
 VILET 224.336      PDRJP 1.000  
 AVERAGE FUEL TEMPERATURE 513.513  
 MAX.FUEL TEMP. 758.200 14 NODE 11  
 MAX.CEAD TEMP. 322.372 14 NODE 23  
 MAX.HEAT FLUX 70.757 14 NODE 19  
 FIRST BOILING NODE 14  
 EXIT LIQUID SUPERHEAT -0.513

TS = 2.500      TMAX = 0.40000E 05

TIME 2.5000 POWER RATIO 0.75505E-01  
 POWER 0.15101E 03 WATF P11 0.592540 13      P12 0.739890 13      PER-0.59414E 00      PINT 0.10010E 06  
 FL1 0.1003E 13      0.1500E 13      0.7810E 12  
 FL2 0.1336E 13      0.3543E 13      0.1474E 13  
 A/PJ 0.0      0.1000E 01      0.0

TIME 3.000 SEC  
 POWER 0.29275E 04      FIF 0.55944E 05      AVE 0.03874      XOUT -0.00453  
 VILET 223.623      PDRJP 1.000  
 AVERAGE FUEL TEMPERATURE 503.730  
 MAX.FUEL TEMP. 714.970 14 NODE 11  
 MAX.CEAD TEMP. 319.100 14 NODE 17  
 MAX.HEAT FLUX 57.497 14 NODE 19  
 FIRST BOILING NODE 17  
 EXIT LIQUID SUPERHEAT -0.517

I	PJJ	FI	J	VF	TSJK	TICL	AVTF	TMAXE	TL						
1	0.59470E	01	0.12520E	JL	0.0	0.25372E	03	0.26196E	03	0.35664E	03	0.40965E	03	0.25244E	03
2	0.52155E	01	0.17190E	JL	0.0	0.26255E	03	0.26581E	03	0.39667E	03	0.45940E	03	0.25374E	03
3	0.65704E	01	0.21525E	JL	0.0	0.25517E	03	0.27174E	03	0.43421E	03	0.52524E	03	0.25539E	03
4	0.75605E	01	0.25440E	JL	0.0	0.27010E	03	0.27663E	03	0.46862E	03	0.57624E	03	0.25735E	03
5	0.82659E	01	0.33730E	JL	0.0	0.27405E	03	0.28154E	03	0.49935E	03	0.62156E	03	0.25961E	03
6	0.93404E	01	0.51780E	JL	0.0	0.27304E	03	0.28525E	03	0.52594E	03	0.66054E	03	0.26211E	03
7	0.95711E	01	0.51110E	JL	0.0	0.28102E	03	0.29073E	03	0.54801E	03	0.69262E	03	0.26482E	03
8	0.10144E	02	0.55340E	JL	0.0	0.28500E	03	0.29491E	03	0.56524E	03	0.71735E	03	0.26769E	03
9	0.10454E	02	0.55340E	JL	0.0	0.28919E	03	0.29873E	03	0.57743E	03	0.73445E	03	0.27068E	03
10	0.10596E	02	0.57100E	JL	0.0	0.29247E	03	0.30212E	03	0.58441E	03	0.74360E	03	0.27373E	03
11	0.10557E	02	0.57220E	JL	0.0	0.29547E	03	0.30504E	03	0.58612E	03	0.74499E	03	0.27678E	03
12	0.10557E	02	0.57400E	JL	0.0	0.29304E	03	0.30743E	03	0.58254E	03	0.73933E	03	0.27979E	03
13	0.10300E	02	0.57900E	JL	0.0	0.30129E	03	0.30719E	03	0.57357E	03	0.72391E	03	0.28270E	03
14	0.04710E	01	0.52590E	JL	0.0	0.30179E	03	0.31018E	03	0.55927E	03	0.70162E	03	0.28539E	03
15	0.37355E	01	0.20450E	JL	0.0	0.30225E	03	0.30993E	03	0.54013E	03	0.67215E	03	0.28749E	03
16	0.73551E	01	0.25240E	JL	0.0	0.30178E	03	0.30365E	03	0.51652E	03	0.63590E	03	0.28861E	03
17	0.59398E	01	0.25290E	JL	-0.21432E-02	0.30150E	03	0.30736E	03	0.48878E	03	0.59310E	03	0.28869E	03
18	0.59100E	01	0.19350E	JL	-0.17555E-01	0.31400E	00	0.30110E	03	0.30614E	03	0.45732E	03	0.54471E	03
19	0.47037E	01	0.15000E	JL	-0.33517E-02	0.21000E	00	0.30035E	03	0.30476E	03	0.42262E	03	0.49139E	03
20	0.54205E	01	0.10320E	JL	-0.45525E-02	0.23274E	00	0.30051E	03	0.30320E	03	0.38524E	03	0.43400E	03

TIME 0.0000 POWER RATIO 0.55333E-01

POWER 0.13077E 03 HATT P11 0.54000E 13 P12 0.54043D 13 PER-0.43122E 01 PINT 0.10155E 06  
 FL11 0.3430E 12 0.5927E 13 0.5323E 12  
 FL12 0.1547E 13 0.7402E 13 0.1233E 13  
 AVPJ 0.0 0.1000E 01 0.0

TIME 0.0000 IT 300 POWER 0.13077E 03

	FLJ11	FLJ12	POWER	RJD VALJE	OKFBACK	OKVOID
1	0.0	0.0	0.0	0.0	0.0	0.0
2	0.66575D 12	0.25750D 13	0.0	0.0	0.0	0.0
3	0.15551D 13	0.50373D 13	0.49591E 00	-0.93502E-02	0.37441E-02	0.0
4	0.25173D 13	0.45055D 13	0.65530E 00	-0.73500E-01	0.32159E-02	0.0
5	0.28055D 13	0.55375D 13	0.79654E 00	-0.73500E-01	0.27180E-02	0.0
6	0.35533D 13	0.53057D 13	0.92435E 00	-0.73500E-01	0.22588E-02	0.0
7	0.33651D 13	0.71949D 13	0.16380E 01	-0.73500E-01	0.13458E-02	0.0
8	0.42317D 13	0.30707D 13	0.11559E 01	-0.73500E-01	0.14851E-02	0.0
9	0.45207D 13	0.37355D 13	0.12150E 01	-0.73500E-01	0.11820E-02	0.0
10	0.40050D 13	0.01509D 13	0.12745E 01	-0.73500E-01	0.24066E-03	0.0
11	0.50970D 13	0.55170D 13	0.15135E 01	-0.73500E-01	0.75436E-03	0.0
12	0.51057D 13	0.55270D 13	0.13313E 01	-0.73500E-01	0.55527E-03	0.0
13	0.52555D 13	0.53305D 13	0.15276E 01	-0.73500E-01	0.61475E-03	0.0
14	0.51700D 13	0.37750D 13	0.13025E 01	-0.73500E-01	0.54523E-03	0.0

15	J.533330	13	J.333333	13	J.12584E	01	-J.7350E-01	0.74240E-03	0.0
16	J.432300	13	J.333333	13	J.11897E	01	-J.73500E-01	0.91211E-03	0.0
17	0.432770	13	J.3322+J	13	J.11033E	01	-J.73500E-01	0.11483E-02	0.0
18	J.424320	13	J.731130	13	J.09920E	00	-J.73500E-01	0.14486E-02	0.0
19	J.370330	13	J.67737J	13	J.37733E	00	-J.73500E-01	0.28034E-02	0.99470E-03
20	0.319330	13	J.30133J	13	J.74103E	00	-J.73500E-01	0.34093E-02	0.11972E-02
21	0.202330	13	J.49317J	13	J.59080E	00	-J.73500E-01	0.40454E-02	0.13950E-02
22	J.201420	13	J.37712J	13	J.42964E	00	-J.73500E-01	0.46788E-02	0.15351E-02
23	J.130130	13	J.23333J	13	0.0		-J.73500E-01	0.0	0.0
24	J.633130	12	J.12332J	13	0.0		-J.73500E-01	0.0	0.0
25	0.0		J.0		0.0		-J.73500E-01	0.0	0.0
AVER.	0.34000J	13	J.34013J	13	0.79414E	01		0.13581E-02	0.10119E-03

TIME 0.0001 IT 333 POWER 0.1307E 03

	FLUJ1		FLUJ2		POWER		RJD VALJE		DKFBACK		DKVOID
1	J.0		J.0		0.0		0.0		0.0		0.0
2	J.305730	13	J.13733J	13	0.0		J.0		0.0		0.0
3	J.100310	13	J.30373J	13	J.49591E	00	-J.93502E-02		0.37441E-02		0.0
4	J.231730	13	J.43333J	13	J.65530E	00	-J.73500E-01		0.32159E-02		0.0
5	J.230330	13	J.33937J	13	0.70634E	00	-J.73500E-01		0.27180E-02		0.0
6	J.303330	13	J.33937J	13	J.22483E	00	-J.73500E-01		0.22588E-02		0.0
7	J.300320	13	J.72070J	13	J.10380E	01	-J.73500E-01		0.18456E-02		0.0
8	J.420170	13	J.33717J	13	J.11530E	01	-J.73500E-01		0.14851E-02		0.0
9	0.402770	13	J.37333J	13	J.12150E	01	-J.73500E-01		0.11820E-02		0.0
10	J.400330	13	J.32333J	13	J.12743E	01	-J.73500E-01		0.94866E-03		0.0
11	J.309730	13	J.30170J	13	J.13135E	01	-J.73500E-01		0.76436E-03		0.0
12	J.520370	13	J.33179J	13	0.13313E	01	-J.73500E-01		0.35527E-03		0.0
13	J.323330	13	J.33333J	13	0.13273E	01	-J.73500E-01		0.61475E-03		0.0
14	0.27799J	13	J.77344J	13	J.13025E	01	-J.73500E-01		0.64323E-03		0.0
15	J.303730	13	J.23330J	13	J.12534E	01	-J.73500E-01		0.74240E-03		0.0
16	J.401330	13	J.03333J	13	J.11897E	01	-J.73500E-01		0.91211E-03		0.0
17	J.432770	13	J.3322+J	13	J.11033E	01	-J.73500E-01		0.11483E-02		0.0
18	J.424320	13	J.731130	13	J.09920E	00	-J.73500E-01		0.14486E-02		0.0
19	J.370330	13	J.67737J	13	J.37733E	00	-J.73500E-01		0.28034E-02		0.99470E-03
20	0.319330	13	J.30133J	13	J.74103E	00	-J.73500E-01		0.34093E-02		0.11972E-02
21	0.202330	13	J.49317J	13	J.59080E	00	-J.73500E-01		0.40454E-02		0.13950E-02
22	J.201420	13	J.37712J	13	J.42964E	00	-J.73500E-01		0.46788E-02		0.15351E-02
23	J.130130	13	J.23333J	13	0.0		-J.73500E-01		0.0		0.0
24	J.633130	12	J.12332J	13	0.0		-J.73500E-01		0.0		0.0
25	J.0		J.0		0.0		-J.73500E-01		0.0		0.0
AVER.	0.34000J	13	J.34013J	13	0.79414E	01		0.13581E-02		0.10119E-03	

01 02 03 04 05 06

2 J.0 0.10773J 07 J.049922J 03 0.71282J 09 0.0 0.10667J 10 0.0 0.43338J 10 0.0 0.15349J 10

4	J.354000	07	J.101750	00	J.203520	10	0.312390	10	0.132840	11	0.479930	10
5	J.355070	07	J.102050	00	0.271640	10	0.407250	10	0.173240	11	0.624750	10
6	J.321150	07	J.109500	00	0.329540	10	0.494450	10	0.210390	11	0.759900	10
7	J.930140	07	J.103000	00	0.531230	10	0.572520	10	0.245690	11	0.879970	10
8	J.103650	03	J.104300	00	0.426040	10	0.640280	10	0.272630	11	0.993430	10
9	J.111740	03	J.121330	00	0.463190	10	0.696750	10	0.296790	11	0.107070	11
10	J.117470	03	J.104750	00	0.492220	10	0.741150	10	0.315840	11	0.113050	11
11	J.121040	03	J.105470	00	0.522780	10	0.772950	10	0.329540	11	0.118900	11
12	J.122450	03	J.107340	00	0.524650	10	0.791750	10	0.337710	11	0.121870	11
13	J.121740	03	J.108160	00	0.527720	10	0.797320	10	0.340270	11	0.122810	11
14	0.110020	03	J.104220	00	0.522020	10	0.789700	10	0.337200	11	0.121710	11
15	J.114330	03	J.106270	00	0.507650	10	0.769010	10	0.328550	11	0.118600	11
16	0.107930	03	J.104900	00	0.434970	10	0.735570	10	0.314430	11	0.113520	11
17	0.099090	07	0.091400	00	0.454220	10	0.689850	10	0.295060	11	0.106540	11
18	J.905130	07	J.100130	00	0.415910	10	0.632510	10	0.270690	11	0.077550	10
19	J.797850	07	J.105330	00	0.370610	10	0.564330	10	0.241670	11	0.097850	10
20	0.679820	07	J.104500	00	0.310030	10	0.485470	10	0.208430	11	0.075290	10
21	0.555110	07	J.105170	00	0.251990	10	0.399990	10	0.171470	11	0.061940	10
22	0.419720	07	0.900220	00	0.200440	10	0.305550	10	0.131390	11	0.047420	10
23	J.281030	07	0.605340	00	0.135420	10	0.207160	10	0.088860	10	0.032110	10
24	J.141240	07	J.304530	00	0.032100	00	0.104420	10	0.0448140	10	0.0161940	10
25	J.0		J.0		0.0		0.0		0.0		0.0	

TIME 3.000 SEC  
 POWER 0.29203E 04 TIF 0.3694E 05 AVF 0.03874 XOUT -0.00453  
 VI. LET 223.025 PDRUP 1.000  
 AVERAGE FUEL TEMPERATURE 505.000  
 MAX.FUEL TEMP. 714.070 11 NODE 11  
 MAX.CLAD TEMP. 310.130 11 NODE 17  
 MAX.HEAT FLUX 57.407 11 NODE 10  
 FIRST BOILING NODE 17  
 EXIT LIQUID SUPERHEAT -0.317

I	PJJ	FI	J	VF	TSUR	TICL	AVTF	TMAXE	TL
1	0.09532E 01	0.12527E 02	0.0	0.0	0.25871E 03	0.26196E 03	0.35664E 03	0.40965E 03	0.25244E 03
2	0.052039E 01	0.17195E 02	0.0	0.0	0.26235E 03	0.26681E 03	0.39667E 03	0.46940E 03	0.25374E 03
3	0.032064E 01	0.21325E 02	0.0	0.0	0.26617E 03	0.27174E 03	0.43421E 03	0.52524E 03	0.25539E 03
4	0.073744E 01	0.25140E 02	0.0	0.0	0.27010E 03	0.27668E 03	0.46862E 03	0.57524E 03	0.25735E 03
5	0.032478E 01	0.23378E 02	0.0	0.0	0.27400E 03	0.28154E 03	0.49935E 03	0.62155E 03	0.25961E 03
6	0.090207E 01	0.31784E 02	0.0	0.0	0.27304E 03	0.28625E 03	0.52594E 03	0.66954E 03	0.26211E 03
7	0.06490E 01	0.34117E 02	0.0	0.0	0.28102E 03	0.29073E 03	0.54801E 03	0.69262E 03	0.26482E 03
8	0.10122E 02	0.35345E 02	0.0	0.0	0.28566E 03	0.29491E 03	0.56524E 03	0.71735E 03	0.26769E 03
9	0.10451E 02	0.35345E 02	0.0	0.0	0.28919E 03	0.29873E 03	0.57743E 03	0.73445E 03	0.27068E 03
10	0.10573E 02	0.37407E 02	0.0	0.0	0.29247E 03	0.30212E 03	0.58441E 03	0.74350E 03	0.27373E 03
11	0.10543E 02	0.37226E 02	0.0	0.0	0.29544E 03	0.30504E 03	0.58612E 03	0.74498E 03	0.27678E 03
12	0.10544E 02	0.35703E 02	0.0	0.0	0.29304E 03	0.30743E 03	0.58254E 03	0.73933E 03	0.27979E 03
13	0.09771E 01	0.31902E 02	0.0	0.0	0.30019E 03	0.30919E 03	0.57357E 03	0.72391E 03	0.28270E 03
14	0.04731E 01	0.22547E 02	0.0	0.0	0.30175E 03	0.31013E 03	0.55927E 03	0.70152E 03	0.28539E 03
15	0.03757E 01	0.20457E 02	0.0	0.0	0.30225E 03	0.30993E 03	0.54013E 03	0.67215E 03	0.28749E 03
16	0.07950E 01	0.25142E 02	0.0	0.0	0.30175E 03	0.30356E 03	0.51652E 03	0.63590E 03	0.28861E 03
17	0.09711E 01	0.25297E 02	-0.21732E-01	0.15071E 00	0.30130E 03	0.30736E 03	0.48878E 03	0.59310E 02	0.28859E 03
18	0.03343E 01	0.10350E 02	-0.14355E-01	0.18140E 00	0.30110E 03	0.30614E 03	0.45732E 03	0.54471E 03	0.28963E 03


## NOTICE TO THE READER

All Euratom reports are announced, as and when they are issued, in the monthly periodical "**euro abstracts**", edited by the Centre for Information and Documentation (CID). For subscription (1 year : £ 6.17, US\$ 16.40) or free specimen copies please write to :

**Handelsblatt GmbH**  
**"euro abstracts"**  
**Postfach 1102**  
**D 4 Düsseldorf 1 (Germany)**

or

**Office de vente des publications officielles  
des Communautés européennes**  
**37, rue Glesener**  
**Luxembourg**



To disseminate knowledge is to disseminate prosperity — I mean general prosperity and not individual riches — and with prosperity disappears the greater part of the evil which is our heritage from darker times.

Alfred Nobel

## SALES OFFICES

All reports published by the Commission of the European Communities are on sale at the offices listed below, at the prices given on the back of the front cover. When ordering, specify clearly the EUR number and the title of the report which are shown on the front cover.

### SALES OFFICE FOR OFFICIAL PUBLICATIONS OF THE EUROPEAN COMMUNITIES

37, rue Glesener, Luxembourg (Compte chèque postal N° 191-90)

#### BELGIQUE - BELGIË

MONITEUR BELGE  
Rue de Louvain 40-42 - 1000 Bruxelles  
BELGISCH STAATSBLAD  
Leuvenseweg 40-42 - 1000 Brussel

#### DEUTSCHLAND

BUNDESANZEIGER  
Postfach - 5000 Köln 1

#### FRANCE

SERVICE DE VENTE EN FRANCE  
DES PUBLICATIONS DES  
COMMUNAUTES EUROPEENNES  
26, rue Desaix - 75 Paris 15°

#### ITALIA

LIBRERIA DELLO STATO  
Piazza G. Verdi, 10 - 00198 Roma

#### LUXEMBOURG

OFFICE DE VENTE  
DES PUBLICATIONS OFFICIELLES  
DES COMMUNAUTES EUROPEENNES  
37, rue Glesener - Luxembourg

#### NEDERLAND

STAATSDRUKKERIJ  
Christoffel Plantijnstraat - Den Haag

#### UNITED KINGDOM

H. M. STATIONERY OFFICE  
P.O. Box 569 - London S.E.1

Commission of the  
European Communities  
D.G. XIII - C.I.D.  
29, rue Aldringer  
Luxembourg

CDNA04497ENC