

September 1969

Brief 69-10516

NASA TECH BRIEF



NASA Tech Briefs are issued to summarize specific innovations derived from the U.S. space program, to encourage their commercial application. Copies are available to the public at 15 cents each from the Clearinghouse for Federal Scientific and Technical Information, Springfield, Virginia 22151.

Rate of Heat Extraction Controller for Environmental Control

The problem:

To regulate the temperature automatically within a watercooled environmental control suit.

The solution:

An automatic control device measures a physiological parameter related to heat production and conditions it to control the heat removal capacity of the suit.

How it's done:

A metabolic rate monitor uses a polarographic cell to measure the partial pressure of oxygen in exhaled gas, and generates a signal proportional to the amount of oxygen consumed.

The oxygen consumption rate is directly related to the heat production rate of the worker enclosed in the suit. Hence, this signal is used to control the efficiency of a thermoelectric cooling system. Changes in the temperature of the water input to the suit cool-

ing coil produce changes in its heat removal capability and maintain a constant temperature within the suit.

This device should find application in the areas of thermal control and life support systems.

Note:

Documentation is available from:

Clearinghouse for Federal Scientific
and Technical Information
Springfield, Virginia 22151

Reference: TSP-69-10516

Source: Paul Webb, James F. Annis,
and Samuel J. Troutman of
Webb Associates
Yellow Springs, Ohio
under contract to
NASA Headquarters
(HQN-10318)

Category 01