

THEORETICAL ANALYSIS ON THE WIND POWER AND PUMPED HYDROPOWER STORAGE INTEGRATED FLOOD MITIGATION SYSTEM

SITI AISHAH BINTI SAFI

Master of Science

UNIVERSITI MALAYSIA PAHANG



SUPERVISOR'S DECLARATION

We hereby declare that we have checked this thesis and in our opinion, this thesis is adequate in terms of scope and quality for the award of the degree of Master of Science.

(Supervisor's Signature)

Full Name : DR MOHAMMAD FIRDAUS BIN BASRAWI

Position : SENIOR LECTURER

Date :

(Co-supervisor's Signature)

Full Name : DR DAING MOHAMAD NAFIZ BIN DAING IDRIS

Position : SENIOR LECTURER

Date :



STUDENT'S DECLARATION

I hereby declare that the work in this thesis is based on my original work except for quotations and citation which have been duly acknowledged. I also declare that it has not been previously or concurrently submitted for any other degree at Universiti Malaysia Pahang or any other institutions.

(Student's Signature)

Full Name : SITI AISHAH BINTI SAFI

ID Number : MMM14016

Date :

THEORETICAL ANALYSIS ON THE WIND POWER AND PUMPED
HYDROPOWER STORAGE INTEGRATED FLOOD MITIGATION SYSTEM

SITI AISHAH BINTI SAFI

Thesis submitted in fulfillment of the requirements
for the award of the degree of
Master of Science

Faculty of Mechanical Engineering
UNIVERSITI MALAYSIA PAHANG

MARCH 2019

ACKNOWLEDGEMENTS

Firstly, all the praise and gratitude to Allah S.W.T for giving good health and strength to me to complete my project successfully. Many people helped me throughout my project journey, there are no words to describe their contribution and time spent to help me to complete my project. Sincerely, I would like to thank each one of them and apologise for any of my mistake or behaviour.

I am grateful and like to express my sincere gratitude to my supervisors Prof. Dr. Hj. Shahrani bin Hj. Anuar and Dr. Mohamad Firdaus bin Basrawi for their germinal ideas, invaluable guidance, continuous encouragement and constant support who have been my biggest inspiration throughout this project till my research study was completed successfully. They were always willing to help me whenever I face a problem with my research. Also, they were constantly guiding me with their immense knowledge and experience, from the beginning till to the end, and also in the course of writing this thesis.

Additionally, I would like to thank my co-supervisor, Dr. Daing Nafiz and also Dr. Ahmmad Shukrie for their guidance, suggestion, comment and co-operation in this project. Besides that, I sincerely would like to thank staff of Mechanical Engineering Department, UMP, who were always available to assist me throughout my research work.

Above all, I acknowledge my sincere indebtedness and gratitude to my parents and my family members for their love and sacrifice throughout my life by supporting me morally and financially. I also wish to acknowledge my appreciation and convey sincere thanks to my fellow friends who encouraged me motivationally and provided moral support for me throughout the project until its successful completion.

ABSTRAK

Kesan serta-merta banjir menyebabkan kehilangan nyawa manusia dan kerosakan kepada harta benda. Langkah semasa untuk pencegahan banjir adalah lebih kepada keperluan segera untuk menyediakan bantuan segera ketika banjir. Oleh itu, mengintegrasikan takungan banjir dengan hidroelektrik simpanan-pam seolah-olah penyelesaian yang meyakinkan untuk masalah banjir. Hidroelektrik simpanan-pam pada dasarnya dikenali sebagai satu alat penyimpanan yang boleh meningkatkan kebolehpercayaan sumber tenaga tidak tetap. Namun, terdapat isu dengan kos kuasa angin hidroelektrik simpanan-pam (KAHSP) yang mana adalah mahal untuk dibina. Oleh itu, KAHSP memerlukan nilai tambah supaya pembinaan kemudahan simpanan tenaga ini berbaloi untuk dibina. Takungan KAHSP boleh menyimpan air dalam jumlah yang banyak dan jika dibina dengan mekanisma yang sama dengan takungan banjir, ianya berkemungkinan mampu untuk mengatasi banjir ketika keadaan hidrologi yang ekstrem dan memberikan pelbagai faedah, terutamanya dari segi ekonomi. Oleh kerana keupayaan takungan KAHSP dalam mengatasi banjir dan kos yang tinggi bagi projek tersebut, adalah berguna untuk mengkaji impaknya dari segi ekonomi dan alam sekitar. Oleh itu, kajian ini bertujuan untuk menilai prestasi kuasa angin hidroelektrik simpanan-pam berintegrasi sistem penebatan banjir dari segi ekonomi dan alam sekitar. Perisian Optimization Hybrid Model Electric Diperbaharui (HOMER) digunakan untuk mensimulasi dan membandingkan sistem penjanaan kuasa yang mempunyai takungan banjir dan juga tanpa takungan banjir. Kemudian, aspek ekonomi untuk setiap sistem ditentukan berdasarkan kos bersih projek dan juga kos seunit tenaga. Manakala, impak alam sekitar dinilai berdasarkan jumlah pelepasan bahan pencemar ke udara. Didapati bahawa jumlah takungan air untuk mengatasi banjir adalah sebanyak 8,396,256 m³ dan loji kuasa yang dicadangkan dianggarkan mampu menampung 69% daripada keperluan tenaga di salah satu daripada kawasan banjir dengan nilai kuasa pengeluaran sebanyak 0.7 MW dan kuasa input sebanyak 1.2 MW. Berdasarkan simulasi oleh HOMER, sistem grid (B-I) yang mana tanpa takungan air banjir adalah sistem yang terbaik dengan kos bersih projek hanya RM 0.38 juta dan kos bagi seunit tenaga adalah sebanyak RM 0.246/kWh. Namun, apabila kos kerugian banjir disertakan dalam kos bersih projek, sistem diesel/turbin angin/takungan air (A-III) dan sistem grid/turbin angin/ takungan air (B-III) mempunyai kos bersih lebih murah berbanding sistem lain yang tidak mempunyai takungan untuk mengatasi banjir. Kos bersih bagi sistem A-III adalah RM 1.52 juta dan bagi sistem B-III adalah RM 1.37 juta, manakala bagi sistem B-I adalah sebanyak RM 10.4 juta apabila kos kerugian banjir disertakan sekali dalam jumlah keseluruhan kos bersih projek. Antara sistem yang menyertakan sekali takungan dalam rekabentuknya, jumlah pelepasan bahan pencemar daripada sistem A-III adalah sebanyak 408 kg gas karbon dioksida dalam setahun yang mana lebih rendah daripada sistem B-III iaitu sebanyak 29,662 kg gas karbon dioksida dilepaskan dalam jangka waktu yang sama. Oleh yang demikian, boleh dikatakan A-III adalah sistem penjanaan kuasa yang terbaik kerana menawarkan manfaat dari segi aspek ekonomi dan alam sekitar. Tetapi, saiz takungan A-III yang dicadangkan hanya boleh mengumpul 20.8 % daripada keseluruhan lebihan air yang dijana dari keseluruhan basin Pahang. Adalah hampir mustahil untuk hanya satu takungan air untuk mengumpul lebihan air yang dijana dari basin yang besar. Oleh demikian, beberapa takungan air boleh dibina untuk mengumpul lebihan air sebagai langkah pencegahan banjir. Kesimpulannya, sistem penebatan banjir bersepadu tenaga angin hidroelektrik simpanan-pam kelihatannya memberi manfaat dalam aspek ekonomi dan persekitaran.

ABSTRACT

The immediate consequences of flood causes loss of human life and damage to property. The current flood mitigation was more on the urgent need to provide immediate flood relief works. Thus, integrating flood reservoir with pumped hydropower storage seems a promising solutions for flood problems. Pumped hydropower storage is basically known as a storage device that can improve the reliability of the intermittent source of wind energy. But, there is an issue with the cost of a wind power pumped hydropower storage (WPHS) as it can be expensive to construct. Thus, WPHS requires an additional value so that it is worth to construct this storage facility. The reservoir of WPHS can store huge amount of water and if it is designed with similar mechanism of flood reservoir, it may be capable to mitigate flood during extreme hydrological events and render significant benefits, especially in the terms of economic aspects. Due to the feasibility of WPHS reservoir in flood mitigation and the high cost of the projects, it is beneficial to study economic and environmental aspects of WPHS. Thus, this research aims to evaluate economic and environmental performances of wind-power pumped hydropower storage integrated flood mitigation system. The Hybrid Optimization Model for Electric Renewable (HOMER) software was used to simulate and compare power generation system with and without the flood reservoir. Then, the economic aspects of each system were evaluated based on the Net Present Cost (NPC) and Levelized Cost of Energy (LCOE). Meanwhile, environmental impacts were evaluated based on the amount of air pollutants released to the environment. It was found that the estimated volume of the reservoir to attenuate flood event was 8,396,256 m³ and the proposed power system was estimated to support 69% of energy demand in one of the flood-prone areas with a mean value of power output being 0.7 MW and power input 1.2 MW. Based on the simulation in HOMER, the grid standalone system (B-I) which is without flood reservoir is the optimum system with the NPC only RM 0.38 million and the LCOE RM 0.246/kWh. But, when the cost of flood losses are internalised in the total NPC, the wind-diesel with reservoir storage system (A-III) and the wind-grid with the pumped hydro storage system (B-III) will have much lower NPC than other systems that do not include reservoir for flood mitigation. The NPC for system A-III is RM 1.52 million and for system B-I is RM 1.37 million; meanwhile, the NPC for system B-I is RM 10.4 million when the cost of flood losses are included in the total NPC. Between both energy systems which included the reservoir in their design, the amount of pollutants emitted by the A-III system is 408 kg of carbon dioxide per year which is much less than the B-III system which is 29,662 kg of carbon dioxide during similar period. Therefore, it can be said that the A-III system is the most optimum power generation system as it offers benefits in both economic and environmental aspects. But, the suggested size of reservoir for A-III only can capture 20.8 % of excess runoff generated from the whole Pahang basin. It is almost impossible to expect only a reservoir to capture all excess runoff generated from a large basin. A few reservoir can be built at each sub basin to capture the excess runoff as a flood prevention. In conclusion, the WPHS integrated with flood mitigation system seems beneficial in the term of economic and environment.

TABLE OF CONTENT

DECLARATION

TITLE PAGE

ACKNOWLEDGEMENT **ii**

ABSTRAK **iii**

ABSTRACT **iv**

CHAPTER 1 INTRODUCTION **1**

1.1 Background 1

1.2 Problem statement 2

1.3 Objectives of the study 3

1.4 Scope of the study 3

1.5 Thesis outline 4

CHAPTER 2 LITERATURE REVIEW **6**

2.1 Introduction 6

2.1.1 Floods in Malaysia 7

2.1.2 Floods mitigation and management in Malaysia 10

2.2 Flood reservoir and potential of hydropower generation 13

2.3 Classification of hydropower plants 14

2.3.1 Run-off-river hydropower 15

2.3.2 Conventional hydropower plant 15

2.3.2 Pumped hydro storage hydropower plant 16

2.4 Potential of hydropower generation and flood mitigation using pumped hydro storage plant 18

2.5 Concepts and design of wind pumped hydropower storage system 19

2.5.1	Overview of wind power	19
2.5.2	Overview of pumped hydro storage	20
2.5.3	Design considerations	23
2.5.4	Pumped hydropower storage as energy storage	29
2.6	Economic and environmental evaluation of wind-powered pumped storage system	35
2.7	Summary	38
CHAPTER 3 METHODOLOGY		40
3.1	Introduction	40
3.2	Description of the study area	40
3.3	Data Acquisition	43
3.4	Hydrologic Modelling System (HEC-HMS)	43
3.5	Rainfall and run-off simulation in HEC-HMS	44
3.5.1	Rainfall analysis	44
3.5.2	Division of catchment area into various sub-basins	44
3.5.3	The concept of Soil Conservation Service (SCS) curve number method for runoff estimation	45
3.5.4	Estimation of volume of flood attenuated	50
3.6	Estimation on designation and power generation capacity of pumped hydro storage	52
3.6.1	Flow and power capacity	52
3.6.2	Velocity in penstock	53
3.6.3	Penstock design	53
3.6.4	Head loss	54
3.6.5	Pump-motor set	54
3.6.6	Turbine-generator set	55

3.6.7	Upper reservoir	55
3.6.8	Model of flood water discharge	56
3.7	Modelling pumped hydro storage in Hybrid Optimization Model for Electric Renewables (HOMER)	58
3.7.1	System description and specification	58
3.7.2	Modeling pumped hydropower reservoir as battery in HOMER	65
3.8	Economic and environmental analysis	68
3.8.1	Net present cost	68
3.8.2	Levelised cost of energy	69
3.8.3	Production of emission	70
CHAPTER 4 RESULTS & DISCUSSION		71
4.1	Introduction	71
4.2	Analysis of rainfall in Pekan basin	71
4.2.1	Analysis of rainfall and runoff simulation in Hydrologic Modelling System (HEC – HMS)	74
4.2.2	Validation of hydrograph simulated by HEC-HMS	76
4.2.3	Hydrograph for Pekan basin during monsoon period	77
4.3	Estimated volume of reservoir for flood attenuation	78
4.4	Designation of proposed pumped-hydropower storage	83
4.4.1	Turbine efficiencies	84
4.4.2	Generating and pumping power of proposed pumped hydropower plant	85
4.5	Simulation of wind-diesel pumped hydro storage system in HOMER	86
4.5.1	Diesel standalone system (A-I)	88
4.5.2	Wind-diesel without reservoir system (A-II)	89
4.5.3	Wind-diesel with reservoir storage system (A-III)	91

4.6	Simulation of wind-grid with pumped-hydro storage system in HOMER	101
4.6.1	Grid standalone system (B-I)	101
4.6.2	Wind-grid without reservoir storage system (B-II)	103
4.6.3	Wind-grid with pumped hydro storage system (B-III)	106
4.7	Comparison of energy system	111
CHAPTER 5 CONCLUSION AND RECOMMENDATIONS		119
5.1	Overall Conclusion	119
5.2	Recommendations	120
REFERENCES		123
APPENDIX A		133
APPENDIX B		135

LIST OF TABLES

Table 2.1	List of hydropower plants	14
Table 2.2	Summary of PHS installed capacities of the world	21
Table 2.3	Classifications of turbine	27
Table 2.4	Summary on pumped hydropower storage studies	32
Table 2.5	Review of storage mechanisms	36
Table 3.1	Data of selected system components	63
Table 3.2	Economic cost of selected system components	64
Table 3.3	Input of economic parameters	70
Table 3.4	Emission factors (kg/kWh) used for estimating the amount of emissions produced	70
Table 4.1	Values of parameter in HEC-HMS modelling	74
Table 4.2	Runoff volume for each sub basin	74
Table 4.3	Computed results of Kuala Pahang sub-basin	75
Table 4.4	Computed results of sub-basin outlet	76
Table 4.5	The RME and RMSE values	77
Table 4.6	Parameters in PSD calculation	79
Table 4.7	Parameter of estimation of flood storage volume	79
Table 4.8	Plant basic parameters	83
Table 4.9	Summary of turbine efficiencies	84
Table 4.10	Summary of basic parameters	85
Table 4.11	Potential energy of proposed pumped-hydropower storage	86
Table 4.12	Net present cost of diesel standalone system in RM	89
Table 4.13	Net present cost of wind-diesel system without storage configuration in RM	91
Table 4.14	Net present cost of wind-diesel with reservoir storage system in RM	96
Table 4.15	Different scenarios of wind-diesel with reservoir storage system	97
Table 4.16	Net present cost of grid standalone system in RM	103
Table 4.17	Net present cost of wind-grid without reservoir storage system	105
Table 4.18	Detailed energy description of wind-grid without reservoir storage system	105
Table 4.19	Detailed energy description of wind-grid with pumped-hydro storage system	107
Table 4.20	Net present cost of wind-grid with pumped-hydro storage system in RM	110

LIST OF FIGURES

Figure 2.1	Flood prone areas in Peninsular Malaysia	8
Figure 2.2	Flood prone areas in Sabah and Sarawak	9
Figure 2.3	The bird's eye view during 2014 flood event in Termeloh, Pahang	10
Figure 2.4	Flood victim looks at her destroyed house caused by flood	10
Figure 2.5	Structural measures in Malaysia	12
Figure 2.6	Non-structural measures in Malaysia	12
Figure 2.7	Run-of-river hydropower plant	15
Figure 2.8	Conventional hydropower plant with reservoir	16
Figure 2.9	Layout of pumped hydro storage power plant	17
Figure 2.10	Kaplan turbine	25
Figure 2.11	Francis turbine	26
Figure 2.12	Pelton turbine	26
Figure 2.13	Turbine selection range chart	28
Figure 2.14	Schematic diagram of wind pumped hydropower storage	31
Figure 3.1	Part one of research methodology	41
Figure 3.2	Part two of research methodology	42
Figure 3.3	Map of Pekan, Pahang	43
Figure 3.4	The meteorological stations in catchment areas	45
Figure 3.5	The three main watersheds of the Pahang River and locations of gauging stations.	48
Figure 3.6	Tributary rivers at the downstream of Lubuk Paku station	49
Figure 3.7	Proposed location of PHS	50
Figure 3.8	Standard triangular shape for preliminary of detention volume	51
Figure 3.9	Model of flood water discharge	56
Figure 3.10	Cross section of Pahang River at Pekan	58
Figure 3.11	Daily load profile in Kuala Pahang	59
Figure 3.12	Seasonal load profile in Kuala Pahang	59
Figure 3.13	Reference diesel standalone system as A-I	60
Figure 3.14	Reference wind-diesel without reservoir storage as A-II	60
Figure 3.15	Wind-diesel with pumped hydropower storage as A-III	61
Figure 3.16	Reference grid standalone system as B-I	61
Figure 3.17	Reference wind-grid without reservoir storage system as B-II	62
Figure 3.18	Wind-grid with pumped-hydro storage system as B-III	62

Figure 3.19	Power curve of Fuhrländer 30 wind turbine	65
Figure 4.1	Annual rainfall in Pekan, Pahang	72
Figure 4.2	Boxplot of rainfall from year 2011 to 2015	73
Figure 4.3	Outflow of discharge of Kuala Pahang sub-basin	75
Figure 4.4	Outflow of discharge from sub-basin outlet	76
Figure 4.5	Monsoonal hydrograph of Pekan basin for December 2014	78
Figure 4.6	Standard triangular shape of inflow and outflow hydrograph	79
Figure 4.7	Proposed flood discharge model	81
Figure 4.8	Water flow of flood discharge model	82
Figure 4.9	Schematic diagram of the wind-diesel pumped hydropower with generator system	87
Figure 4.10	Optimization results of wind/diesel pumped hydro storage system	88
Figure 4.11	Monthly electrical energy production of standalone diesel generator configuration	88
Figure 4.12	Monthly electrical energy production of wind-diesel without storage configuration.	90
Figure 4.13	The cash flow of wind-diesel system without storage configuration	91
Figure 4.14	Monthly electrical energy production of wind-diesel system with storage configuration	92
Figure 4.15	Average monthly wind turbine output power of wind-diesel with reservoir system	93
Figure 4.16	Inverter power output of wind-diesel with reservoir system	93
Figure 4.17	Rectifier power output of wind-diesel with reservoir system	94
Figure 4.18	SOC of water reservoir for wind-diesel with reservoir storage system	94
Figure 4.19	PHS monthly reservoir SOC statistics for wind-diesel with reservoir storage system	95
Figure 4.20	Cash flow summary of wind-diesel with reservoir storage system	95
Figure 4.21	The cash flow of wind-diesel with reservoir storage system	97
Figure 4.22	Sensitivity analysis of system in terms of wind speed and diesel price	98
Figure 4.23	Optimal system plot of levelized cost of energy	99
Figure 4.24	Surface plots for the total NPC superimposed with levelised COE	99
Figure 4.25	Sensitivity graph superimposed with breakeven grid extension	100
Figure 4.26	The breakeven grid extension distance for the optimised system	101
Figure 4.27	The optimisation results of grid-connected wind-pumped hydro storage system	102
Figure 4.28	Monthly average electrical production of grid standalone system	103

Figure 4.29	Monthly electricity production of wind-grid without reservoir storage system	104
Figure 4.30	Cash flow summary of wind-grid without reservoir storage system	104
Figure 4.31	Monthly electricity production of wind-grid with pumped-hydro storage system	106
Figure 4.32	Average monthly of wind turbine output from the wind-grid with pumped-hydro storage system	108
Figure 4.33	SOC of water reservoir for wind-grid with pumped-hydro storage system	109
Figure 4.34	Monthly SOC statistics for wind-grid with pumped-hydro storage system	109
Figure 4.35	Cash flow summary of wind-grid with pumped-hydro storage system	110
Figure 4.36	Cash flow of wind-grid with pumped-hydro storage system	111
Figure 4.37	Comparison electricity production for different configuration systems	112
Figure 4.38	Comparison between electricity production and consumption of different configuration systems	113
Figure 4.39	Amount of carbon dioxide produced by different configurations (kg/year)	114
Figure 4.40	Amount of pollutants produced by different configurations (kg/year)	115
Figure 4.41	Amount of pollutants emitted for different configuration systems	116
Figure 4.42	Comparison NPC of different configuration systems with (a) and without flood losses included (b)	117

LIST OF SYMBOLS

$C_{ann,tot}$	Total annualized cost, USD/year
C_B	Capacity, A. h
CO	Carbon monoxide
CO_2	Carbon dioxide
e_g	Generator efficiency
E_{M-P}	Charging power, W
E_{G-T}	Energy generated from the turbine-generator, kWh
E_R	Storage capacity of the reservoir, kWh
E_S	Energy stored, kWh
f	Friction factor
g	Acceleration due to gravity, m/s^2
h	Head height, m
h_f	Head loss due to friction, m
i	Interest rate, %
I_a	Initial abstraction, mm
l	Length, m
L	Lag, hr
L_g	Length of grid, m
L_w	Length of penstock for water, m
n	Friction factor manning's
NO_x	Nitrogen oxides
P	Rainfall, mm
P_{bat}	Power produced by the battery, W
P_C	Power capacity, W
Q	Volumetric flow rate, m^3/s
Q_a	Peak post-development, m^3/s
Q_i	Peak inflow, m^3/s
Q_o	Peak outflow, m^3/s
Q_p	Peak pre-development flow, m^3/s
r	Radius, m
R	Runoff, mm
S	Potential maximum retention after runoff/ slope, mm
SO_2	Sulphur dioxide
T_i	Duration of basin inflow, sec

t_c	Time of concentration, hr
V	Velocity, m/s
V_s	Volume of reservoir, m ³
ρ	Density of water, kg/m ³
η	Efficiency
η_p	Pump efficiency

LIST OF ABBREVIATIONS

CN	Curve Number
COE	Cost of Energy
DID	Drainage and Irrigation Department
EPRI	Electric Power Research Institute
HEC-HMS	Hydrology Modelling System
HOMER	Hybrid Optimisation Model for Electric Renewable
ICOLD	International Commission on Large Dams
MSMA	Manual Saliran Mesra Alam
NRSC	National Resources Conservation Service
NHA	National Hydropower Association
NPC	Net Present Cost
O&M	Operating and Maintaining
PHS	Pumped Hydropower Storage
PDTP	Pejabat Daerah dan Tanah Pekan
PSD	Permissible Site Discharge
RME	Relative Mean Error
RMSE	Root of Mean Square Error
SCS	Soil Conservation Service
TNB	Tenaga Nasional Berhad
VBA	Visual Basic for Applications

REFERENCES

- Abbas, M. Y., Elias, Z., Hamin, Z., & Othman, M. B. (2013). Sustainable management of flood risks in Malaysia: some lessons from the legislation in England and Wales. *Procedia - Social and Behavioral Sciences*, 105, 491-497.
- Abbas, M. Y., Mohit, M. A., & Sellu, G. M. (2013). Mitigation of climate change effects through non-structural flood disaster management in Pekan town, Malaysia. *Procedia - Social and Behavioral Sciences*, 85, 564-573.
- Abdullah, Z. (2015). Potential analysis of grid connected wind turbine system in Peninsular Malaysia. *International Journal of Scientific & Engineering Research*, 5(2), 929-933.
- Ahmadi, H., & Shamsai, A. (2009). Preliminary site selection of pumped storage hydropower plants - A GIS-based approach *International Journal of Modeling, Identification, Simulation And Control*, 41(2), 25-32.
- Ajao, K. R., & Sule, B. F. (2011). Reduction of carbon dioxide (CO₂) in the atmosphere, hydropower as a viable renewable energy resource. *Journal of Basic and Applied Scientific Research*, 1(11), 2125-2130.
- Akakah, Z. A., & Doraisamy, S. V. (2015). 2014 Malaysia flood: Impacts & factors contributing towards the restoration of damages. *Journal of Scientific Research and Development*, 2(10), 53-59.
- Alam, M. M., Rehman, S., Al-Hadhrani, L. M., & Meyer, J. P. (2014). Extraction of the inherent nature of wind speed using wavelets and FFT. *Energy for Sustainable Development*, 22, 34-47.
- Alley, R. B. (2016, 15/11/2016). Conventional hydroelectric dams. Retrieved from <https://www.e-education.psu.edu/earth104/node/1067>
- Almén, J., & Falk, J. (2013). *Subsea pumped hydro storage: a technology assessment*. (Master Thesis), Chalmers University of Technology, Göteborg, Sweden. Retrieved from <http://publications.lib.chalmers.se/records/fulltext/179756/179756.pdf> (T2013-387)
- Anagnostopoulos, J. S., & Papantonis, D. E. (2007). Pumping station design for a pumped-storage wind-hydro power plant. *Energy Conversion and Management*, 48(11), 3009-3017.
- Baily, T., & Bass, R. (2009). *Hydroelectric feasibility study*. Retrieved from Oregon, United States: <http://www.oit.edu/docs/default-source/strategic-partnerships-and-government-relations/applied-research/oc-hydro-study-report-r1.pdf?sfvrsn=4>
- Barbour, E., Wilson, I. A. G., Radcliffe, J., Ding, Y., & Li, Y. (2016). A review of pumped hydro energy storage development in significant international electricity markets. *Renewable and Sustainable Energy Reviews*, 61, 421-432.
- Barsoum, N., & Pearl, D. P. (2015). Cost optimization of hybrid solar, micro-hydro and hydrogen fuel cell using homer software. *Energy and Power Engineering*, 7, 337-347.
- Beisler, M. (2013). Hybrid energy production, financial feasibility of a combined solar/wind – a combined solar/wind – pumped storage hydropower system. *The IMRE Journal*, 7(1), 1-20.

- BNM, B. N. M. (2017). Inflation Rate. Retrieved from <http://www.bnm.gov.my/index.php>
- BoR. (2011). *Hydropower resource assessment at existing reclamation facilities*. Retrieved from Denver, Colorado: <https://www.usbr.gov/power/AssessmentReport/USBRHydroAssessmentFinalReportMarch2011.pdf>
- Boustani, F. (2009). An assessment of the small hydropower potential of Sisakht region of Yasuj. *International Journal of Electrical, Computer, Energetic, Electronic and Communication Engineering*, 3(9), 1711 - 1715.
- Boxwell, M. (2018). Wind Turbines vs Solar Panels. *Solar Electricity Handbook*. Retrieved from <http://solarelectricityhandbook.com/Solar-Articles/wind-turbines.html>
- Ćalović, M., Mandić, D., & Mesarović, M. (2016). Market challenges for pumped storage hydropower plants. *International journal of computational engineering research*, 6(3), 51-61.
- Campbell, R. J. (2010). *Small hydro and low-head hydro power technologies and prospects*. Retrieved from United States:
- Canales, F. A., & Beluco, A. (2014). Modeling pumped hydro storage with the micropower optimization model (HOMER). *Journal of Renewable and Sustainable Energy*, 6(4), 043131.
- Canales, F. A., Beluco, A., & Mendes, C. A. B. (2015). A comparative study of a wind hydro hybrid system with water storage capacity: Conventional reservoir or pumped storage plant? *Journal of Energy Storage*, 4, 96-105.
- Carmen, L., Ana, P., Yolanda, L., & Christian, O. (2008). *Wind energy – the facts Part V Environmental Issue*. Retrieved from Spain: <https://wind-energy-the-facts.org/images/chapter5.pdf>
- Chan, N. W. (1997). Increasing flood risk in Malaysia: causes and solutions. *Disaster Prevention and Management: An International Journal*, 6(2), 72-86.
- Chan, N. W. (2011). Addressing flood hazards via environmental humanities in Malaysia. *Malaysian Journal of Environmental Management*, 12(2), 11-22.
- Chan, N. W. (2012). *Impacts of disasters and disaster risk management in Malaysia: The case of floods* (Vol. 8). Jakarta: ERIA.
- Chan, N. W. (2015). Impacts of disasters and disaster risk management in Malaysia: The case of floods. In P. D. Aldrich, S. Oum, & Y. Sawada (Eds.), *Resilience and Recovery in Asian Disasters: Community Ties, Market Mechanisms, and Governance* (pp. 239-265). Tokyo: Springer Japan.
- Chen, H., Cong, T. N., Yang, W., Tan, C., Li, Y., & Ding, Y. (2009). Progress in electrical energy storage system: A critical review. *Progress in Natural Science*, 19(3), 291-312.
- Chukwunke, J. L., Achebe, C. H., Nwosu, M. C., & Sinebe, J. E. (2014). Analysis and simulation on effect of head and bucket splitter angle on the power output of a pelton turbine. *International Journal of Engineering and Applied Sciences*, 5(3), 1 - 8.

- Cronshey, R. (1986). *Urban hydrology for small watersheds, TR-55. technical release 55*. Retrieved from Springfield, VA: http://www.nrcs.usda.gov/Internet/FSE_DOCUMENTS/stelprdb1044171.pdf
- Davis, A. (2016). Types of Turbines. Retrieved from <http://greenbugenergy.com/get-educated-knowledge/types-of-turbines#prettyPhoto>
- DID. (2016a, 02/06/2016). Flood management - programme and activities. Retrieved from <http://www.water.gov.my/our-services-mainmenu-252/flood-mitigation-mainmenu-323/programme-aamp-activities-mainmenu-199#>
- DID. (2016b, 02/06/2016). Flood management - programme and activities. Retrieved from <http://www.water.gov.my/our-services-mainmenu-252/flood-mitigation-mainmenu-323/programme-aamp-activities-mainmenu-199?lang=en>
- DID. (2016c, 2/6/2016). Flood management - programme and activities. Retrieved from <http://www.water.gov.my/our-services-mainmenu-252/flood-mitigation-mainmenu-323/programme-aamp-activities-mainmenu-199?lang=en&start=1>
- DID. (2016d, 2/6/2016). Flood Management - Programme and Activities - Flood Management in Malaysia. Retrieved from <http://www.water.gov.my/our-services-mainmenu-252/flood-mitigation-mainmenu-323/programme-aamp-activities-mainmenu-199?lang=en&start=1>
- DID. (2016e, 2/6/2016). Flood management - programme and activities - non structural measures. Retrieved from <http://www.water.gov.my/our-services-mainmenu-252/flood-mitigation-mainmenu-323/programme-aamp-activities-mainmenu-199?lang=en&start=2>
- Dinglin, L., Yingjie, C., Kun, Z., & Ming, Z. (2012). Economic evaluation of wind-powered pumped storage system. *Systems Engineering Procedia*, 4, 107-115.
- Dongwoo, K. (2015). *Mitigation effects on urban flood by installing an underground storage box*. (Doctoral Degree in Civil and Earth Resources Engineering P.h.D Thesis), Kyoto University, Japan. Retrieved from <http://repository.kulib.kyoto-u.ac.jp/dspace/bitstream/2433/202684/2/dkogk04078.pdf>
- Douglas, T., Brommhall, P., & Orr, C. (2007). *Run-of-river hydropower in BC*. Retrieved from Coquitlam, British Columbia: <https://www.watershed-watch.org/publications/files/RoR-CitizensGuide.pdf>
- Dunn, B., Kamath, H., & Tarascon, J. M. (2011). Electrical energy storage for the grid: a battery of choices. *Science*, 334(6058), 928-935.
- Energy Storage Association, E. (2018). Executive Summary of Pumped Hydroelectric Storage. *Energy Storage*. Retrieved from <http://energystorage.org/energy-storage/technologies/pumped-hydroelectric-storage>
- ESA. (2014). Energy Storage Association (ESA). Retrieved from <http://energystorage.org/energy-storage/technologies/pumped-hydroelectric-storage>
- Gayer, M., & Connolly, M. A. (2005). Communicable disease control after disasters *Public Health Consequences of Disasters*: Oxford University Press.

- Ghani, A. A., Chang, C. K., Leow, C. S., & Zakaria, N. A. (2012). Sungai Pahang digital flood mapping: 2007 flood. *International Journal of River Basin Management*, 10(2), 139-148. doi:10.1080/15715124.2012.680022
- Ging, Y. T. (2015, 08/12/2015). Energy ministry: No change to 2016 power tariffs, but peninsular users to get smaller rebate. *The Malay Mail Online*. Retrieved from <http://www.themalaymailonline.com/malaysia/article/energy-ministry-no-change-to-2016-power-tariffs-but-peninsula-users-to-get>
- GoogleMaps (Cartographer). (2016). Pekan, Pahang. Retrieved from https://www.google.com/maps/d/viewer?mid=1YV_5S0ZnKiHP6c0mOCy5ZsT57FI&hl=en_US&ll=3.4898830000000074%2C103.39008100000001&z=17
- Guzović, Z., & Matijašević, B. (2010). *Report on the feasibility analysis for most technically acceptable locations*. Retrieved from Milano, Italy:
- Hadjipaschalis, I., Poullikkas, A., & Efthimiou, V. (2009). Overview of current and future energy storage technologies for electric power applications. *Renewable and Sustainable Energy Reviews*, 13(6–7), 1513-1522.
- Harmancioğlu, N. B. (1994). Flood control by reservoirs. In G. Rossi, N. Harmancioğlu, & V. Yevjevich (Eds.), *Coping with Floods* (pp. 637-652). Dordrecht: Springer Netherlands.
- HEC. (2008). *Hydrologic Modeling System (HEC-HMS) Applications Guide: Version 3.1.0*. Retrieved from California: http://www.hec.usace.army.mil/software/hec-hms/documentation/HEC-HMS_QuickStart_Guide_3.1.0.pdf
- Hino, T., & Lejeune, A. (2012). Pumped storage hydropower developments *Comprehensive Renewable Energy* (Vol. 6, pp. 405-434).
- HOMER. (2016). Grid emissions factors. Retrieved 3/4/2016 https://www.homerenergy.com/support/docs/3.10/us_grid_emissions_factors.html
- HQ. (2016, 26/08/2016). Turbines. Retrieved from <http://www.hydroquebec.com/learning/hydroelectricite/types-turbines.html>
- Hussaini, H. A. (2007). *Flood and drought management in Malaysia*. Ministry of Natural Resources and Environment. Kuala Lumpur, Malaysia.
- Hyodo, M. (2015). *Integrated flood management tools series: Reservoir operations and managed flows*. Retrieved from Geneva, Switzerland: http://www.apfm.info/publications/tools/APFM_Tool_05.pdf
- Ibrahim, G. A., C.H.C., H., & Azhari, C. H. (2010). Traditional water wheels as a renewable rural energy. *The Online Journal on Power and Energy Engineering (OJPEE)*, 1(2), 62-66.
- ICOLD. (2016a). Role of dams. Retrieved from http://www.icold-cigb.org/GB/Dams/role_of_dams.asp
- ICOLD. (2016b, 13/07/2016). Role of dams. Retrieved from http://www.icold-cigb.org/GB/Dams/role_of_dams.asp
- Islam, R., Kamaruddin, R., Ahmad, S. A., Jan, S. J., & Anuar, A. R. (2016). A review on mechanism of flood disaster management in Asia. *International Review of Management and Marketing*, 6(1), 29-52.

- Jalal, T. S., & Bodger, P. (2009, 7-8/12/2009). *National energy policies and electricity sector in Malaysia*. Paper presented at the 3rd International Conference on Energy and Environment (ICEE 2009), Selangor, Malaysia.
- Jamii, J., Abbes, D., & Mimouni, M. F. (2016, 19-21 Dec. 2016). *Scheduling optimization of wind power generation with pumped storage hydro plant*. Paper presented at the 2016 17th International Conference on Sciences and Techniques of Automatic Control and Computer Engineering (STA).
- Kapsali, M., & Kaldellis, J. K. (2010). Combining hydro and variable wind power generation by means of pumped-storage under economically viable terms. *Applied Energy*(87), 3475–3485.
- Karim, F. N., Sayuthi, S., Abdullah, N. I., & Zakaria, R. (2014). Pekan folk bracing for the worst. *New Straits Times*. Retrieved from <http://www.nst.com.my/news/2015/09/pekan-folk-bracing-worst>
- Kaunda, C. S., Kimambo, C. Z., & Nielsen, T. K. (2012). Hydropower in the context of sustainable energy supply: a review of technologies and challenges. *ISRN Renewable Energy*, 2012, 15.
- Kear, G., & Chapman, R. (2013). 'Reserving judgement': Perceptions of pumped hydro and utility-scale batteries for electricity storage and reserve generation in New Zealand. *Renewable Energy*, 57, 249-261.
- Khalid, M. S., & Shafiai, S. (2015). Flood disaster management in Malaysia: An evaluation of the effectiveness flood delivery system. *International Journal of Social Science and Humanity*, 5(4), 398-402.
- Khan, M., & Zaidi, A. Z. (2015). Run-of-river hydropower potential of Kunhar river, Pakistan *Pakistan Journal of Meteorology*, 12(23), 25-32.
- Kibrit, B. (2013). *Pumped hydropower storage in the Netherlands*. (Master Thesis), Delft University of Technology, Delft, Netherlands. (1354027)
- Koutnik, J., & Lutzmann, S. (2011). *Study on capabilities of variable speed pumped hydroelectric power plants and comparison with other bulk energy storage solutions*. Paper presented at the Proceedings of the HYDRO 2011 conference, Prague.
- Kucukali, S. (2014). Finding the most suitable existing hydropower reservoirs for the development of pumped-storage schemes: An integrated approach. *Renewable and Sustainable Energy Reviews*, 37, 502-508.
- Kumar, M., Pratap, D., & Kumar, N. (2016a). Scheduling of wind-pumped storage hydro power plants. *Imperial Journal of Interdisciplinary Research*, 2(5), 35-40.
- Kumar, M., Pratap, D., & Kumar, N. (2016b). Scheduling of wind-pumped storage hydro power plants. *Imperial Journal of Interdisciplinary Research*, 2(5), 35-40.
- Kusakana, K. (2015). Feasibility analysis of river off-grid hydrokinetic systems with pumped hydro storage in rural applications. *Energy Conversion and Management*, 96, 352-362.
- Lajqi, S., Lajqi, N., & Hamidi, B. (2016). Design and construction of mini hydropower plant with propeller turbine *International Journal of Contemporary ENERGY*, 2(1), 1-13.

- Lee, J. G., Selvakumar, A., Alvi, K., Riverson, J., Zhen, J. X., Shoemaker, L., & Lai, F. (2012). A watershed-scale design optimization model for stormwater best management practices. *Environmental Modelling & Software*, 37, 6-18.
- Lemus, R. G., & Duarte, J. M. M. (2012). *Renewable energies and CO2: Cost analysis, environmental impacts and technological trends- 2012 edition* (Vol. 3). London: Springer-Verlag London.
- Leonidas, N., & Pierre, S. (2014). *Feasibility study of Gisuma micro-hydropower plant (Rwanda)*. (Master Thesis), KTH Royal Institute of Technology, Stockholm, Sweden. (SE10044STOCKHOLM)
- Leskens, J. G., Brugnach, M., Hoekstra, A. Y., & Schuurmans, W. (2014). Why are decisions in flood disaster management so poorly supported by information from flood models? *Environmental Modelling & Software*, 53, 53-61.
- Li, T. (2015). *Dams failure in Europe*. (Master Thesis), Polytechnic University of Milan, Milan, Italy.
- Loisel, R., Mercier, A., Gatzen, C., Elms, N., & Petric, H. (2010). Valuation framework for large scale electricity storage in a case with wind curtailment. *Energy Policy*, 38(11), 7323-7337.
- Luis, J., Lariyah, M. S., Mohammed, N. M. D., & Julien, P. Y. (2013). Hydropower reservoir for flood control: a case study on Ringlet reservoir, Cameron Highlands, Malaysia. *Journal of Flood Engineering*, 4(1-2), 87-102.
- Luo, X., Wang, J., Dooner, M., & Clarke, J. (2015). Overview of current development in electrical energy storage technologies and the application potential in power system operation. *Applied Energy*, 137, 511-536.
- Ma, T., Yang, H., Lu, L., & Peng, J. (2014). Technical feasibility study on a standalone hybrid solar-wind system with pumped hydro storage for a remote island in Hong Kong. *Renewable Energy*, 69, 7-15.
- Maksom, Z. (2012). *Developing Malaysian community based flood warning initiatives through activity centered design*. (Ph.D Thesis), Swinburne University of Technology, Melbourne, Australia.
- Margeta, J., & Đurin, B. (2014). Hydrological and hydro-energy indicators of the hybrid energy system using solar and pump storage hydroelectric plant. *International Journal of Sustainable Energy*, 33(4), 827-841. doi:10.1080/14786451.2013.774002
- Margeta, J., & Glasnovic, Z. (2011). Introduction of PV Energy Into an Existing HEP. *IEEE Transactions on Energy Conversion*, 26(3), 717-727. doi:10.1109/TEC.2011.2159305
- McLean, E., & Kearney, D. (2014). An evaluation of seawater pumped hydro storage for regulating the export of renewable energy to the national grid. *Energy Procedia*, 46, 152-160.
- Millsapp, R. (2017, 2017). Levelized cost of energy. Retrieved from <http://www.renewable-energy-advisors.com/learn-more-2/levelized-cost-of-electricity/>
- Mitteregger, A., & Penninger, G. (2008). Austrian pumped storage power stations supply peak demands. *World Pumps*, 2008(500), 16-21.

- Mockus, V. (2004). Estimation of direct runoff from storm rainfall. In D. o. Agriculture (Ed.), *Hydrology National Engineering Handbook* (pp. 450). Washington: Natural Resources Conservation Service.
- Mokhtar, M. M., Hassim, M. H., & Taib, R. M. (2014). Health risk assessment of emissions from a coal-fired power plant using AERMOD modelling. *Process Safety and Environmental Protection*, 92(5), 476-485. doi:<http://dx.doi.org/10.1016/j.psep.2014.05.008>
- Muhadi, N. A., & Abdullah, A. F. (2015). Flood damage assessment in agricultural area in Selangor river basin. *Jurnal Teknologi (Sciences & Engineering)*, 76(15), 111–117
- Murage, M. W., & Anderson, C. L. (2014). Contribution of pumped hydro storage to integration of wind power in Kenya: An optimal control approach. *Renewable Energy*, 63, 698-707.
- Mustaffa, C. S., Marzuki, N. A., Ariffin, M. T., Salleh, N. A., & Rahaman, N. H. (2014). Relationship between social support, impression management and well-being among flood victims in Malaysia. *Procedia - Social and Behavioral Sciences*, 155, 197-202.
- Nasir, B. A. (2014). Design considerations of micro-hydro-electric power plant. *Energy Procedia*, 50, 19-29.
- Nazari, M. E., Ardehali, M. M., & Jafari, S. (2010). Pumped-storage unit commitment with considerations for energy demand, economics, and environmental constraints. *Energy*, 35(10), 4092-4101.
- NHA, N. H. A. (2014). *Challenges and opportunities for new pumped storage development* Retrieved from Washington, DC http://www.hydro.org/wp-content/uploads/2014/01/NHA_PumpedStorage_071212b12.pdf
- Nicola, M., & Kathleen, O. (2004). *Spatial planning for wind energy: Lessons from the Danish case*. (Master of Science in Technological and Socio-Economic Planning), Roskilde Universitets center, Roskilde Denmark.
- Nikolaidis, P., & Poullikkas, A. (2017). A comparative review of electrical energy storage systems for better sustainability. *Journal of Power Technologies*, 3(87), 220-245.
- Nwosu, M. C., & Madueme, T. C. (2013). Recycled micro hydropower generation using hydraulic ram pump (hydram) *International Journal of Research in Engineering & Technology*, 1(3), 1-10.
- Olatomiwa, L., Mekhilef, S., Huda, A. S. N., & Ohunakin, O. S. (2015). Economic evaluation of hybrid energy systems for rural electrification in six geo-political zones of Nigeria. *Renewable Energy*, 83, 435-446.
- Pasalli, Y. R., & Rehiara, A. B. (2014). Design planning of micro-hydro power plant in Hink river. *Procedia Environmental Sciences*, 20, 55-63.
- Patel, S. U., & Pakale, P. N. (2015). Study on power generation by using cross flow water turbine in micro hydro power plant. *International Journal of Research in Engineering and Technology*, 4(5), 1-4.
- PDTP (Cartographer). (2016). Pekan Map. Retrieved from <https://www.google.com.my/maps/@3.4903999,103.1060773,68748m/data=!3m1!1e3?hl=en>

- Penche, C., & Minas, I. (1998). *Layman's handbook on how to develop a small hydro site*. Retrieved from Bruselas, Bélgica:
- Pereira, B. S. A., Sobrinho, P., & Silveira, J. (2015). *The use of LINGO programming language to develop a computer tool to provide a technical and economic analysis of a hydraulic potential that allows the application of Francis turbines and Kaplan turbines*.
- Peter, R. B. W., Timo, A. R., Meynell, P. J., & Ketelsen, T. (2013). *Flood control challenges for large hydroelectric reservoirs*. Retrieved from Hanoi, Vietnam: <https://wle-mekong.cgiar.org/download/mk3-optimizing-cascades/MK3-Flood-Control-Challenges1.pdf>
- Pickard, W. F., Shen, A. Q., & Hansing, N. J. (2009). Parking the power: Strategies and physical limitations for bulk energy storage in supply–demand matching on a grid whose input power is provided by intermittent sources. *Renewable and Sustainable Energy Reviews*, 13(8), 1934-1945.
- Prajapati, M. V., Patel, R. H., & Thakkar, K. H. (2015). Design, Modeling & Analysis of Pelton Wheel Turbine Blade. *International Journal for Scientific Research & Development*, 3(10), 159-163.
- Ramli, M. A. M., Hiendro, A., & Twaha, S. (2015). Economic analysis of PV/diesel hybrid system with flywheel energy storage. *Renewable Energy*, 78, 398-405.
- Ramos, H. M., Amaral, M. P., & Covas, D. I. C. (2014). Pumped-storage solution towards energy efficiency and sustainability: Portugal contribution and real case studies. *Journal of Water Resource and Protection*, 6(12), 1099-1111.
- Ramos, H. M., Teyssier, C., Samora, I., & Schleiss, A. J. (2013a). Energy recovery in SUDS towards smart water grids: A case study. *Journal of Energy Policy*, 62, 463-472.
- Ramos, H. M., Teyssier, C., Samora, I., & Schleiss, A. J. (2013b). Energy recovery in SUDS towards smart water grids: A case study. *Energy Policy*, 62, 463-472.
- Razi, M. A. M., Ariffin, J., Tahir, W., & Arish, N. A. M. (2010). Flood estimation studies using Hydrologic Modeling System (HEC-HMS) for Johor River, Malaysia. *Journal of Applied Sciences*(10), 930-939.
- Rehman, S., Al-Hadhrami, L. M., & Alam, M. M. (2015). Pumped hydro energy storage system: A technological review. *Renewable and Sustainable Energy Reviews*, 44, 586-598.
- Reiche, D., & Bechnerger, M. (2004). Policy differences in the promotion of renewable energies in the EU member states. *Energy Policy*, 32.
- Rukh, G., Khan, I., & Nawaz, U. (2014). An efficient micro-hydroelectric scheme for low heads. *International Journal of Electrical & Computer Sciences*, 14(4), 33-35.
- Sah, N. K., Uprety, M., Bhandari, S., Kharel, P., Suman, S., & Maskey, R. K. (2014). Prospects of storage and pumped-storage hydropower for enhancing integrated nepal power systems. *Journal of Water, Energy and Environment*, 15, 37-41.
- Sangal, S., Garg, A., & Kumar, D. (2013). Review of optimal selection of turbines for hydroelectric. *International Journal of Emerging Technology and Advanced Engineering*, 3(3), 424-430.

- Shamsudin, S., & Dan'azumi, S. (2014). *Impounded water bodies modelling and simulation*. United States.
- Shekarchian, M., Moghavvemi, M., Mahlia, T. M. I., & Mazandarani, A. (2011). A review on the pattern of electricity generation and emission in Malaysia from 1976 to 2008. *Renewable and Sustainable Energy Reviews*, 15(6), 2629-2642.
- Singh, P., Thakur, T., & Sahu, P. S. (2014). A comparative and analytical review of impulse and reaction turbine on the basis of type of action of the water on the blade. *International Journal of Research in Aeronautical and Mechanical Engineering*, 2(3), 1-13.
- Sinha, S., & Chandel, S. S. (2015a). Prospects of solar photovoltaic–micro-wind based hybrid power systems in western Himalayan state of Himachal Pradesh in India. *Energy Conversion and Management*, 105, 1340-1351.
- Sinha, S., & Chandel, S. S. (2015b). Review of recent trends in optimization techniques for solar photovoltaic–wind based hybrid energy systems. *Renewable and Sustainable Energy Reviews*, 50, 755-769.
- Spellman, F. R. (2013). *Water & wastewater infrastructure: Energy efficiency and sustainability*: CRC Press.
- Stackhouse, P. W. (2016, 12/04/2016). Surface meteorology and solar energy. Retrieved from <https://eosweb.larc.nasa.gov/sse/>
- Stenzel, P., & Linssen, J. (2016). Concept and potential of pumped hydro storage in federal waterways. *Applied Energy*, 162, 486-493.
- Strachan, N., & Farrell, A. (2006). Emissions from distributed vs. centralized generation: The importance of system performance. *Energy Policy*, 34(17), 2677-2689.
- Suaad, J. (2013). Environmental Impacts of Wind Energy *Journal of Clean Energy Technologies*, 1(3), 251-254.
- Suhaimi, S. (2015). Japan offers emergency assistance to flood victims. *New Straits Times*. Retrieved from <http://www.nst.com.my/news/2015/09/japan-offers-emergency-assistance-flood-victims>
- Szykitka, W. (2009). *Big book of self-reliant living: Advice and information on just about everything you need to know to live on planet earth*: Lyons Press.
- Tam, T. H., Ibrahim, A. L., Rahman, M. A., Chan, N. W., & Woodhouse, I. (2016). *Flood risk assessment for Kota Tinggi, Johor, Malaysia*.
- Tamrakar, A., Pandey, S. K., & Dubey, S. C. (2015). Hydro power opportunity in the sewage waste water. *American International Journal of Research in Science, Technology, Engineering & Mathematics*, 2(10), 179-183.
- Tekolla, A. W. (2010). *Rainfall and flood frequency analysis for Pahang river basin, Malaysia*. (Master of Science Thesis in Water Resources Engineering Master Thesis), Lund University, Lund, Sweden. Retrieved from <https://lup.lub.lu.se/luur/download?func=downloadFile&recordOID=1701272&fileOID=1701282> (TVVR 10/5012)

- Teoh, W. Y., Khu, S. Y., Tan, C. W., Hii, I. H., & Cheu, K. W. (2015). Technoeconomic and carbon emission analysis for a grid-connected photovoltaic system in Malacca. *International Scholarly Research Network ISRN Renewable Energy*.
- Than, K. (2012, January). The many faces of flooding. *City of Santa Barbara* Retrieved from <http://www.santabarbaraca.gov/gov/depts/fire/oes/newsletter/archive.asp>
- TheEconomist. (2012). Energy Storage - Packing some power. Retrieved from <http://www.economist.com/node/21548495>
- Tilahun, M. A. (2009). *Feasibility study of pumped storage system for application in Amhara region, Ethiopia*. (Master Thesis), Royal Institute of Technology, Stockholm, Sweden. Retrieved from [http://www.diva-portal.org/smash/get/diva2:511233/FULLTEXT02\(850614-A186\)](http://www.diva-portal.org/smash/get/diva2:511233/FULLTEXT02(850614-A186))
- Tingsanchali, T. (2012). Urban flood disaster management. *Procedia Engineering*, 32, 25-37.
- UCS. (2016, 18/8/2016). How hydroelectric energy works. Retrieved from http://www.ucsusa.org/clean_energy/our-energy-choices/renewable-energy/how-hydroelectric-energy.html
- Wagner, H. J., & Mathur, J. (2011). *Introduction to hydro energy systems: basics, technology and operation*: Springer Berlin Heidelberg.
- Wang, Q. (2013). Hydro development-induced environmental impact on river ecosystem. *Open Journal of Social Sciences*, 1(5), 1-4.
- Williamson, S. J., Stark, B. H., & Booker, J. D. (2011). *Low head pico hydro turbine selection using a multi-criteria analysis*. Paper presented at the World Renewable Energy Congress 2011 - Sweden, Linköping, Sweden.
- Wolsink, M. (2000). Wind power and the NIMBY-myth: Institutional capacity and the limited significance of public support. *Renewable Energy*, 21.
- WVIC. (2016, 02/05/2016). How hydropower works. Retrieved from http://www.wvic.com/content/how_hydropower_works.cfm
- Yang, C. J. (2016). Chapter 2 - Pumped hydroelectric storage *Storing Energy* (pp. 25-38). Oxford: Elsevier.
- Yang, C. J., & Jackson, R. B. (2011). Opportunities and barriers to pumped-hydro energy storage in the United States. *Renewable and Sustainable Energy Reviews*, 15(1), 839-844.
- Zohbi, G. I., Hendrick, P., Renie, C., & Bouillard, P. (2015). Wind-hydro pumped storage systems to meet lebanese electricity demand. *Revue des Energies Renouvelables*, 18(3), 375 – 397.