



INTERIM REPORT  
SMALL CENTRIFUGAL PUMPS FOR  
LOW-THRUST ROCKET ENGINES

by  
R. B. Furst

Rockwell International  
Rocketdyne Division

prepared for  
NATIONAL AERONAUTICS AND SPACE ADMINISTRATION

March 1986

NASA-Lewis Research Center  
Contract NAS3-23164  
Dean D. Scheer, Project Manager

(NASA-CR-174913) SMALL CENTRIFUGAL PUMPS  
FOR LOW-THRUST ROCKET ENGINES Interim  
Report (Rockwell International Corp.) 114 p  
CSCI 13K

N86-32741

G3/37

Unclas  
44408



1. Report No. CR 174913		2. Government Accession No.		3. Recipient's Catalog No.	
4. Title and Subtitle SMALL CENTRIFUGAL PUMPS FOR LOW-THRUST ROCKET ENGINES INTERIM REPORT				5. Report Date 21 March 1986	
				6. Performing Organization Code	
7. Author(s) R. B. Furst				8. Performing Organization Report No. RI/RD85-183	
9. Performing Organization Name and Address Rocketdyne Division Rockwell International 6633 Canoga Avenue Canoga Park, CA 91304				10. Work Unit No. YOS 1449	
				11. Contract or Grant No. NAS3-23164	
12. Sponsoring Agency Name and Address National Aeronautics and Space Administration Washington, DC 20546				13. Type of Report and Period Covered Interim	
				14. Sponsoring Agency Code	
15. Supplementary Notes Project Manager: Dean D. Scheer NASA-Lewis Research Center Cleveland, Ohio 44135					
16. Abstract <p>Six small, low specific speed centrifugal pump configurations were designed, fabricated, and tested. The configurations included shrouded, and 25 and 100% admission open face impellers with 2 inch tip diameters; 25, 50, and 100% emission vaned diffusers; and volutes with conical exits. Impeller tip widths varied from 0.030 inch to 0.052 inch. Design specific speeds (<math>N_s = \text{RPM} \cdot \text{GPM}^{0.5} / \text{FT}^{0.75}</math>) were 430 (four configurations) and 215 (two configurations).</p> <p>The six configurations were tested with water as the pumped fluid. Noncavitating performance results are presented for the design speed of 24,500 rpm over a flowrate range from 1 to 6 gpm for the <math>N_s = 430</math> configurations and test speeds up to 29,000 rpm over a flowrate range from 0.3 to 1.2 gpm for the <math>N_s = 215</math> configurations. Cavitating performance results are presented over a flowrate range from 60 to 120% of design flow. Fabrication of the small pump components is also discussed.</p>					
17. Key Words (Suggested by Author(s)) Low-thrust rocket engine pumps Low specific speed pumps Centrifugal pumps Partial emission vaned diffusers Partial admission impellers				18. Distribution Statement	
19. Security Classif. (of this report) Unclassified		20. Security Classif. (of this page) Unclassified		21. No. of Pages	22. Price*

\* For sale by the National Technical Information Service, Springfield, Virginia 22161

## CONTENTS

Introduction . . . . .	3
Pump Configurations . . . . .	5
Design . . . . .	5
Fabrication . . . . .	14
Test Program . . . . .	16
Test Results . . . . .	27
Head and Efficiency Performance Versus Flow . . . . .	27
Suction Performance . . . . .	43
Hydrodynamic Shaft Loading . . . . .	46
Analysis of Pump Losses . . . . .	55
Pump Seal Clearance Effects . . . . .	61
Conclusions . . . . .	63
<u>Appendix</u>	
Sample Data . . . . .	65

PRECEDING PAGE BLANK NOT FILMED

## ILLUSTRATIONS

1.	Shrouded Impeller Vaned Diffuser Pump . . . . .	9
2.	Shrouded Impeller Volute Pump . . . . .	10
3.	Shrouded Impeller 25% Emission Diffuser Pump . . . . .	11
4.	Open Face Impeller Volute Pump . . . . .	12
5.	Open Face 25% Admission Impeller Volute Pump . . . . .	13
6.	Shrouded Impeller 50% Emission Diffuser Pump . . . . .	15
7.	2-Inch Diameter Impeller Casting . . . . .	17
8.	2-Inch Diameter Impeller Casting . . . . .	18
9.	Water Test Facility Schematic . . . . .	19
10.	Pump/Tester Cross Section . . . . .	20
11.	Pump/Tester Assembly . . . . .	21
12.	Pump Test Facility . . . . .	22
13.	Pump/Tester Installed in Test Facility . . . . .	23
14.	Typical Pump Instrumentation . . . . .	24
15.	Tester and Turbine Instrumentation . . . . .	25
16.	Low-Thrust Water Testing Configuration 1 Test and Curve Speed - 24,500 rpm Specific Speed - 430 . . . . .	29
17.	Low-Thrust Water Testing Configuration 2 Test and Curve Speed - 24,500 rpm Specific Speed - 430 . . . . .	30
18.	Low-Thrust Water Testing Configuration 3 Test and Curve Speed - 29,000 rpm Specific Speed - 215 . . . . .	31
19.	Low-Thrust Water Testing Configuration 4 Test and Curve Speed - 24,500 rpm Specific Speed - 430 . . . . .	32
20.	Low-Thrust Water Testing Configuration 5 Test and Curve Speed - 29,000 rpm Specific Speed - 215 . . . . .	33
21.	Low-Thrust Water Testing Configuration 6 Test and Curve Speed - 24,500 rpm Specific Speed - 430 . . . . .	34
22.	Low-Thrust Water Test Efficiency . . . . .	35
23.	Low-Thrust Water Test Head . . . . .	36
24.	Pump and Impeller Static Headrise Low-Thrust Water Testing, Configuration 1 . . . . .	37
25.	Pump and Impeller Static Headrise Low-Thrust Water Testing, Configuration 2 . . . . .	38
26.	Pump and Impeller Static Headrise Low-Thrust Water Testing, Configuration 3 . . . . .	39



27.	Pump and Impeller Static Headrise Low-Thrust Water Testing, Configuration 4 . . . . .	40
28.	Pump and Impeller Static Headrise Low-Thrust Water Testing, Configuration 5 . . . . .	41
29.	Pump and Impeller Static Headrise Low-Thrust Water Testing, Configuration 6 . . . . .	42
30.	Cavitation Test, Configuration 2 . . . . .	44
31.	Suction Performance, Configuration 2 . . . . .	45
32.	Cavitation Test, Configuration 3 . . . . .	47
33.	Suction Performance, Configuration 3 . . . . .	48
34.	Cavitation Test, Configuration 4 . . . . .	49
35.	Suction Performance, Configuration 4 . . . . .	50
36.	Cavitation Test, Configuration 5 . . . . .	51
37.	Suction Performance, Configuration 5 . . . . .	52
38.	Cavitation Test, Configuration 6 . . . . .	53
39.	Suction Performance, Configuration 6 . . . . .	54
40.	Radial Loads, Test Data . . . . .	56
41.	Axial Load, Shrouded Impellers, Test Data . . . . .	57
42.	Axial Load, Open Face Impellers, Test Data . . . . .	58
43.	Low-Thrust Pump Head Coefficient Versus Flow Coefficient Configuration 6, Wear Ring Clearance Effect . . . . .	64

## TABLES

1. Design Summary of Centrifugal Pump Test Configurations . . . . .	6
2. Pump Design Geometry Specific Speed - 430 . . . . .	7
3. Pump Design Geometry Specific Speed - 215 . . . . .	8
4. Instrumentation Accuracies . . . . .	26
5. Design Point Pump Performance Summary . . . . .	28
6. Diffusion System Static Pressure Distribution . . . . .	43
7. Summary of Centrifugal Stage Design Point Suction Performance . . . . .	46
8. Predicted Losses Percent of Input Power Pumping Water Specific Speed = 430 . . . . .	59
9. Predicted Losses Percent of Input Power Pumping Liquid Hydrogen Specific Speed = 430 . . . . .	60
10. Design Point Pump Efficiency Summary . . . . .	62
11. Turbopump Geometry . . . . .	66

## SUMMARY

Six small (2-inch tip diameter) low specific speed centrifugal pump configurations were designed, fabricated, and tested pumping water. The configurations included shrouded, and 25 and 100% admission open face impellers, 25 to 100% emission vaned diffusers, and volutes with conical diffusers. Tip widths varied from 0.030 inch to 0.052 inch. Design specific speeds were 430 and 215.

Head, flow, efficiency, and cavitation tests were conducted in water at speeds up to 29,000 rpm.

Test efficiencies for the shrouded 430 specific speed configurations were 28 to 33%. The 215 specific speed configurations obtained efficiencies of only 5 to 10%.

Suction performance was largely better than predicted at 8000 to 11,000, while axial and radial loads were less than predicted.

Best performance was obtained by 430 specific speed configuration 2 with a shrouded impeller discharging into a volute with a conical diffuser.

There appeared to be no difference in the ability to cast the two different tip widths and the smallest (0.030 inch) does not appear to be a limit.



## INTRODUCTION

Pump-fed, low-thrust chemical propulsion systems are being considered for transferring acceleration-limited structures from low earth orbit to geosynchronous or other high earth orbits. Engine systems for these applications will require small, relatively low flowrate, high head rise pumps that fall outside the design range of existing rocket engine turbopumps. In order to establish a technology base for future design of these systems, a program was initiated to experimentally evaluate low specific speed centrifugal pump stages and inlet-type stages over the flowrate range of interest. Funding for the program is being provided under NASA-Lewis Research Center contract NAS3-23164 and related effort is being provided by Rocketdyne internal sources.

Contract scope consists of design fabrication and test of six single-stage centrifugal pump test articles, and a conventional inducer. The tester and drive turbine were fabricated and tested as part of a prior company-funded effort. The shear force pump will be tested following completion of the contract effort. The test program was structured to first determine performance of each of the six centrifugal stages with water as the test fluid. Two of the stages will then be tested in liquid hydrogen to determine performance change due to differences in fluid properties such as viscosity and compressibility. The inducer and shear force stage will be tested in liquid hydrogen to determine relative suction performance capability.

The water test program has been completed. This interim report discusses the design and fabrication of the centrifugal stages and presents the water test performance results.

**PRECEDING PAGE BLANK NOT FILMED**



## PUMP CONFIGURATIONS

### DESIGN

A design summary of the six centrifugal pump configurations is given in Table 1. Details of the pump geometries are given in Tables 2 and 3. Configurations 1, 2, 4, and 6 were designed for a specific speed of 430 ( $\text{rpm} * \text{gpm}^{0.5} / \text{FT}^{0.75}$ ). Configurations 3 and 5 were designed for a specific speed of 215. All of the pumps incorporated impellers with 2-inch tip diameters. Discharge tip widths ranged from 0.030 to 0.052 inch.

Design details for Configuration 1 are given in Table 2. Pump hardware is shown in Fig. 1. This pump incorporates a 100% admission shrouded impeller discharging into a 100% emission vaned diffuser that discharges into a volute. The impeller is fully shrouded with backwardly curved blades. The vaned diffuser is the vane island type with eight straight mean line diffusing passages machined into the inlet housing rear face. The volute is designed with proportionately larger cross-section area than for a large pump to reduce friction loss. The area distribution is designed to minimize radial load through equalizing static pressure circumferentially. The use of a vaned diffuser produces a nearly constant radial load over a wide flowrange since the diffuser produces a volute velocity matching the flowrate down to the diffuser stall flowrate.

Configuration 2 (Table 2 and Fig. 2) utilizes the same impeller as Configuration 1 but discharges its flow directly into a volute. Diffusion is accomplished by a volute exit conical diffuser.

Configuration 3 (Table 3 and Fig. 3) utilizes the same impeller as Configurations 1 and 2. The impeller discharges through a 25% emission diffuser that has the same diffuser passage geometry as Configuration 1. The diffuser differs in that only two opposite passages were machined as compared to eight for Configuration 1. The intent is to reduce the design flowrate to one-fourth and the specific speed to one-half of that for 100% emission diffuser.

Configuration 4 (Table 2 and Fig. 4) incorporates a 0.035-inch tip width open face impeller with 100% admission that discharges directly into a volute. The diffusion is accomplished by a conical diffuser at the volute exit. The impeller tip width was increased above that for the shrouded impeller to compensate for the open face tip clearance leakage flow.

Configuration 5 (Table 3 and Fig. 5) incorporates a 25% admission open face impeller that discharges directly into a volute-shaped passage to minimize hydrodynamic radial loads. The impeller passage geometry is the same as for Configuration 4. The impeller geometry differs in that only two opposite passages are machined as compared with eight for Configuration 4. This modification was intended to reduce the design flowrate to one-fourth and the specific speed to one-half of that for a 100% admission impeller (Fig. 5, Table 3).

TABLE 1. DESIGN SUMMARY OF CENTRIFUGAL PUMP TEST CONFIGURATIONS

CONFIGURATION	IMPELLER		TIP WIDTH, INCHES	DIFFUSER TYPE	FLUID	SPEED, rpm	FLOW, gpm	HEAD, FEET	SPECIFIC SPEED, rpm rpm*gpm <sup>0.5</sup> /ft <sup>0.75</sup>
	TYPE	DISCHARGE DIAMETER, INCHES							
1	SHROUDED 100% ADMISSION	2.00	0.030	VANED 100% EMISSION	WATER HYDROGEN	24,500 77,000	5.0 15.7	637 6,300	430 430
2	SAME AS CONFIGURATION 1	2.00	0.030	VOLUTE EXIT	WATER HYDROGEN	24,500 77,000	5.0 15.7	637 6,300	430 430
3	SAME AS CONFIGURATION 1	2.00	0.030	VANED 25% EMISSION	WATER HYDROGEN	39,200 125,000	2.0 6.38	1,630 16,600	215 215
4	OPEN FACE 100% ADMISSION	2.00	0.035	VOLUTE EXIT	WATER HYDROGEN	24,500 77,000	5.0 15.7	637 6,300	430 430
5	OPEN FACE 25% ADMISSION	2.00	0.035	VOLUTE EXIT	WATER HYDROGEN	39,200 125,000	2.0 6.78	1,711 17,400	215 215
6	SHROUDED 100% ADMISSION	2.00	0.052	VANED 50% EMISSION	WATER HYDROGEN	24,500 77,000	5.0 15.7	637 6,300	430 430




TABLE 2. PUMP DESIGN GEOMETRY SPECIFIC SPEED = 430

CONFIGURATION NO.	1	2	4	6
<b>IMPELLER</b>				
TYPE	SHROUDED	SHROUDED	OPEN FACE	SHROUDED
DISCHARGE DIAMETER, INCHES	2.0	2.0	2.0	2.0
INLET EYE DIAMETER, INCHES	0.75	0.75	0.80	0.81
INLET HUB DIAMETER, INCHES	0.50	0.50	0.50	0.50
DISCHARGE TIP WIDTH, INCHES	0.030	0.030	0.035	0.052
NUMBER OF BLADES	7	7	8	7
DISCHARGE BLADE ANGLE, DEGREES	33	33	20	33
WEAR RING DIAMETER, INCHES	1.00	1.00	1.00	1.00
FRONT WEAR RING RADIAL CLEARANCE, INCHES (MAXIMUM DESIGN)	0.002	0.002	--	0.002
IMPELLER FACE CLEARANCE, INCHES	--	--	0.004	--
REAR WEAR RING RADIAL CLEARANCE, INCHES (MAXIMUM DESIGN)	0.002	0.002	0.002	0.002
INLET EYE BLADE ANGLE, DEGREES	21.9	21.9	21.25	20
INLET FLOW COEFFICIENT (10% BLOCKAGE)	0.134	0.134	0.107	0.174
PERCENT ADMISSION	100	100	100	100
DISCHARGE FLOW COEFFICIENT	0.074	0.074	0.080	0.085
<b>DIFFUSER</b>				
INLET DIAMETER, INCHES	2.1	--	--	2.1
DISCHARGE DIAMETER, INCHES	2.7	--	--	2.7
PASSAGE WIDTH, INCHES	0.030	--	--	0.052
NUMBER OF PASSAGES	8	--	--	4
INLET ANGLE, DEGREES	6	--	--	6
AREA RATIO, OUT/IN	1.84	--	--	1.84
PERCENT EMISSION	100	--	--	50
<b>VOLUTE</b>				
MAXIMUM AREA AT 360 DEGREES, IN. <sup>2</sup>	0.0468	0.0267	0.035	0.0468
CONTINUITY AREA/ACTUAL AREA	0.60	0.60	0.83	0.60
CONICAL DIFFUSER EXIT AREA, IN. <sup>2</sup>	0.096	0.096	0.096	0.096


TABLE 3. PUMP DESIGN GEOMETRY SPECIFIC SPEED = 215

CONFIGURATION NO.	3	5
<b>IMPELLER</b>		
TYPE	SHROUDED	OPEN FACE
DISCHARGE DIAMETER, INCHES	2.0	2.0
INLET EYE DIAMETER, INCHES	0.75	0.8
INLET HUB DIAMETER, INCHES	0.5	0.5
DISCHARGE TIP WIDTH, INCHES	0.030	0.035
NUMBER OF BLADES	7	2
DISCHARGE BLADE ANGLE, DEGREES	33	20
IMPELLER FACE CLEARANCE, INCHES	--	0.004
WEAR RING DIAMETER, INCHES	1.00	1.00
FRONT WEAR RING RADIAL CLEARANCE, INCHES (MAXIMUM DESIGN)	0.002	--
REAR WEAR RING RADIAL CLEARANCE, INCHES (MAXIMUM DESIGN)	0.002	0.002
INLET EYE BLADE ANGLE, DEGREES	21.9	21.25
INLET FLOW COEFFICIENT (10% BLOCKAGE)	0.134	0.107
PERCENT ADMISSION	100	25
DISCHARGE FLOW COEFFICIENT	0.074	0.08
<b>DIFFUSER</b>		
INLET DIAMETER, INCHES	2.1	--
DISCHARGE DIAMETER, INCHES	2.7	--
PASSAGE WIDTH, INCHES	0.030	--
NUMBER OF PASSAGES	2	--
INLET ANGLE, DEGREES	6	--
AREA RATIO, OUT/IN	1.84	--
PERCENT EMISSION	25	--
<b>VOLUTE</b>		
MAXIMUM AREA AT 360 DEGREES, IN. <sup>2</sup>	0.0146	0.011
CONTINUITY AREA/ACTUAL AREA	0.50	0.833
CONICAL DIFFUSER EXIT AREA, IN. <sup>2</sup>	0.096	0.026



1XZ91-7/19/84-C1C


Figure 1. Shrouded Impeller Vaned Diffuser Pump



1XZ91-7/19/84-C1D


Figure 2. Shrouded Impeller Volute Pump





1XZ91-7/19/84-C1E


Figure 3. Shrouded Impeller 25% Emission Diffuser Pump



1XZ91-7/19/84-C1F

Figure 4. Open Face Impeller Volute Pump





1XZ91-7/19/84-C1G

Figure 5. Open Face 25% Admission Impeller Volute Pump

Configuration 6 (Table 2 and Fig. 6) incorporates a 100% admission shrouded impeller with the same blade shape as for Configurations 1, 2, and 3 with the exception that the impeller passage height is increased from inlet to exit to give a discharge tip width of 0.052 inch. The impeller discharges into a 50% emission vaned diffuser with increased passage height but otherwise the same passage shape as for Configurations 1 and 3. This configuration is intended to operate at the same design point flow and specific speed as for Configuration 1. The larger flow passages were used to simplify fabrication.

## FABRICATION

### Machined Parts

A very real problem with small diameter low specific speed pumps as investigated in this program, is the successful fabrication of very small flow passages and tip width. The process selected for manufacture of the open flow passages of the vaned diffusers, volutes, and open face impellers was machining. This method produced a smooth and repeatable surface finish required for low pressure and friction losses with minimum variation and risk. Shrouded impellers were cast due to the difficulty associated with machining the very small enclosed passages.

The machined open face impellers had the advantage of superior surface finish control but suffered an efficiency penalty due to impeller to housing clearance. The cast shrouded impellers had front wear rings with more easily controlled radial clearance.

### Impeller Casting


A casting development effort was conducted to determine the optimum casting procedures for the Inconel 718 shrouded impellers.

The ceramic core design consisted of individual ceramic cores of the impeller passages assembled on a fixture to form a one piece core assembly. Because the core assembly was fragile due to the very small impeller passage dimensions, the impeller body wax pattern was not injected around the core in one piece. Upper and lower wax impeller halves were injection molded separately and booked to the core assembly. In order to meet the close dimensional requirements for the impeller blades and flow passages and the tight ceramic-to-wax fitup desired for the booking process, trial core assemblies were dimensionally inspected before being booked to the impeller patterns. A single iteration to fine tune the core assembly techniques and minor rework of the wax pattern dies resulted in the desired results for subsequent casting of impellers.

Inconel 718 was selected for casting the impellers because of its excellent strength, and corrosion resistance and its good castability. Inconel 718 does present a known potential problem of metal reaction with a ceramic core during the casting process. The alloy strength properties are not reduced but an unacceptable rough casting surface can result. Since the very small impeller flow passages are not readily accessible for surface finish improvement effort was made to produce the smooth as cast surface required for high impeller performance.



ORIGINAL PAGE 'IS  
OF POOR QUALITY



1XZ91-7/19/84-C1

Figure 6. Shrouded Impeller 50% Emission Diffuser Pump

Experience in this program with Inconel 718 ceramic core reaction indicated the severity of the reaction was a function of the time molten metal was in contact with the core material. An iterative procedure was followed to arrive at the metal pour temperature and investment shell temperature that would result in complete mold filling, sound metallurgical quality, and smooth surface finish. After each trial pour the impeller was cut up to evaluate the flow passage surface finish. The third test temperatures resulted in acceptable impeller quality, therefore, it was adopted for the test impeller castings.

Photographs of a 0.052-inch tip width impeller are shown in Fig. 7 and 8. There was no significant difference in the ability to cast the 0.030-inch tip width impeller and the 0.052-inch tip width impeller. Consequently, the tip width of future designs can be made as small as 0.030 inch with minimum casting problems, particularly if less reactive metal can be used. Even smaller tip widths may be feasible as 0.030 inch does not appear to be a limit.

## TEST PROGRAM

### Facility Description


The water test program was conducted in Rocketdyne's Engineering Development Laboratory in a closed loop water test facility shown schematically in Fig. 9. The test facility was capable of conducting tests over a wide range of speed, flow, and inlet pressure. Inlet pressure within the test loop can be lowered by dropping water tank pressure by means of a vacuum source or increased by pressurizing the tank with gaseous nitrogen. The test pumps are installed in the pump tester and are driven by a calibrated axial flow turbine with gaseous nitrogen as the working fluid. A cross-sectional view of the pump tester is shown in Fig. 10. The pump tester assembly and the installation of the assembly in the test facility are shown in Fig. 11, 12, and 13.

### Instrumentation

Typical pump and tester instrumentation is shown in Fig. 14 and 15. Overall (flange to flange) head rise was determined by measuring the difference in pressure between a four-hole static pressure piezometer ring located 5 diameters upstream of the pump inlet and a four-hole static pressure piezometer ring located 10 diameters downstream of the pump discharge. The velocity heads calculated from the pump flowrate and respective cross-sectional areas at the measurement stations were added to the inlet and discharge static heads to obtain the total head rise. The pump flowrate was measured by means of a flowmeter located in the pump discharge line. Pump speed was measured by a tester-mounted eddy current proximity probe that sensed the rotation of two flats machined on the tester shaft.

Instrumentation accuracies are listed in Table 4. All instrumentation was calibrated by standards traceable to the Bureau of Standards prior to testing of each pump configuration. Calibrations were checked pretest and posttest.

ORIGINAL PAGE IS  
OF POOR QUALITY




1XY52-7/8/83-C1A

Figure 7. 2-Inch Diameter Impeller Casting (Inlet)



10/10/83  
10/10/83



1XY52-7/8/83-C1B

Figure 8. 2-Inch Diameter Impeller Casting (Discharge)




Figure 9. Water Test Facility Schematic





Figure 10. Pump/Tester Cross Section


ORIGINAL PAGE IS  
OF POOR QUALITY



1SM55-4/5/84-C2A

Figure 11. Pump/Tester Assembly






1XZ91-2/2/84-C1B

Figure 12. Pump Test Facility





TXZ91-2/2/84-C1C

Figure 13. Pump/Tester Installed in Test Facility




Figure 14. Typical Pump Instrumentation




Figure 15. Tester and Turbine Instrumentation

TABLE 4. INSTRUMENTATION ACCURACIES

PUMP INLET PRESSURE	± 0.5 PSI
PUMP INLET AND DISCHARGE TEMPERATURE	± 0.2 DEGREE R
PUMP DISCHARGE PRESSURE AND ALL OTHER INTERNAL PRESSURES SHOWN IN FIG. 14	± 2.5 PSI
FLOWRATE	± 0.5%
SHAFT SPEED	± 0.5%

### Test Procedures

The tests evaluated head rise versus flow at shaft speeds of 24,500, 19,600, 14,700, and 9350 rpm for Configurations 1, 2, 4, and 6 and at shaft speeds of 29,000, 23,520, and 11,760 rpm for Configurations 3 and 5. The flowrate was controlled by a valve located downstream of the flowmeter. Pump speed was controlled by varying the turbine inlet and discharge pressure to control the power input to the pump. Sufficient turbine measurements were made to permit calculation of the power input to the pump based on turbine calibration data obtained subsequent to the pump tests.

Sufficient pressure measurements were made in the pump to permit calculation of the pump axial and radial loads and internal performance at test operating conditions.

Suction performance tests were conducted by operation at a constant pump rotating speed and flowrate with the pump inlet pressure gradually lowered from a high to a low value. The higher test speeds produced consistent suction specific speed values and were, therefore, used to determine the pump suction performance. Suction performance data were not obtained for Configuration 1 due to damage to the volute wear-ring during the head versus flow test. Since the same impeller was used for Configuration 2 the suction performance capability of the impeller was evaluated by test of Configuration 2.

The pump power was determined by computing the power generated by the drive turbine based on test measurements and turbine calibration data. The turbine was calibrated after the pump test program using a water dynamometer. The power available to the pump was determined by connecting the turbine mounted on the pump tester to the dynamometer. The turbine was driven by dry gaseous nitrogen during the calibration. The turbine measurements during the calibration were the same as those obtained during the pump tests to provide a direct relationship of calibration information.

The dynamometer replaced the pump as the power absorber. Therefore, the turbine calibration includes the rotating assembly bearing and seal power losses up to the pump and the dynamometer absorbed horsepower was directly the pump input horsepower.

## TEST RESULTS

### HEAD AND EFFICIENCY PERFORMANCE VERSUS FLOW

Table 5 summarizes the pump design point head and efficiency at the design point flowrates while Fig. 16 through 21 present the head, flow, efficiency data for each of the 6 configurations. Figure 22 presents a comparison of efficiency data from all 6 configurations. Similarly, Fig. 23 presents a comparison of delivered head. The wear ring radial clearances and open face impeller axial clearances are listed in Table 2 and 3.

Pump Configurations 1, 2, 4, and 6 were designed to operate at a design point specific speed ( $N_s$ ) of 430. The highest efficiency, 32.5%, and head rise, 750 feet at 24,500 rpm, was achieved by Configuration 2, which utilized a shrouded impeller with a 0.030-inch exit tip width discharging into a volute with a conical diffuser at the exit. The lowest efficiency, 23%, and head rise 445 feet, of the four configurations was produced by Configuration 4, which was similar to Configuration 2 except for the use of an open face impeller rather than a shrouded impeller. The second highest efficiency 31% and third highest head rise, 725 feet, was achieved by Configuration 1, which used the same impeller as Configuration 2 but discharging through a vaned diffuser followed by a volute and exit diffuser. The third highest efficiency, 28.5%, and second highest head rise, 745 feet, was achieved by Configuration 6, which used a shrouded impeller with a 0.052-inch exit tip width discharging through a 50% emission vaned diffuser into a volute. The head rise and efficiency results are influenced by the wear ring clearances and the axial clearance of the open face impeller. Test Configuration 1 operated with wear ring clearances within the pretest design values while the other configurations were tested with clearances that were slightly larger than design (Tables 1, 2, and 3) to avoid rubbing. The efficiencies would have been higher if the pumps had been operated with the design clearances. This topic is discussed in more detail in a later section. Configuration 3 was designed to operate at a design point specific speed of 215. At the test speed of 29,000 rpm Configuration 3 achieved the higher efficiency of 9.6% and head of 1125 feet. This configuration incorporated the same shrouded impeller as Configurations 1 and 2 and discharged through a 25% emission diffuser and volute. Configuration 5 incorporated a 25% admission open face impeller with the same passage configuration as Configuration 4. This impeller discharged directly into a volute. It obtained a head rise of 340 feet at 29,000 rpm at an efficiency of 5.1%. The low efficiency of Configurations 3 and 5 result from the very low flowrate, one-fourth that of Configurations 1, 2, 4, and 6, at the same speed. At one-fourth the delivered flow the hydraulic power output is reduced to one-fourth. The input power, however, is only slightly reduced resulting in the low efficiency. Configuration 5 has a lower efficiency than Configuration 3 because of the high loss in the impeller to housing axial clearance space.

Figures 24 through 29 compare the impeller static pressure rise with the overall pump static pressure rise. The difference in the two indicates the conversion of the impeller exit velocity pressure into static pressure. Table 6 summarizes the design point diffusion system performance. Configuration 2 with a volute exit conical diffuser achieved the highest diffusing system performance. Configuration 2, as well as the vaned Configurations 1 and 6, were not affected by changes in flowrate. However, the 25% emission vaned diffuser affected Configuration 3 output head as its ability to recover velocity head declined as the flowrate was increased.

TABLE 5. DESIGN POINT PUMP PERFORMANCE SUMMARY  
WATER TEST

TEST CONFIGURATION						TEST RESULTS			
CONFIGURATION NO.	FRONT WEAR RING RADIAL CLEARANCE, INCHES	REAR WEAR RING RADIAL CLEARANCE, INCHES	IMPELLER FACE AXIAL CLEARANCE, INCHES	SHAFT SPEED, RPM	FLOWRATE, GPM	HEAD, FEET	EFFICIENCY, %		
1	0.0015	0.0020	-	24,500	5.0	725*	31**		
2	0.0025	0.0020	-	24,500	5.0	750	32.5		
3	0.0026	0.0020	-	29,000	1.48	1130	9.6		
4	-	0.0045	0.010	24,500	5.0	445	23.0		
5	-	0.0038	0.008	29,000	1.48	342	5.1		
6	0.0031	0.0030	-	24,500	5.0	745 <sup>+</sup>	28.5 <sup>++</sup>		

\* HEADRISE DATA - TEST 84L007  
 \*\* EFFICIENCY DATA - TEST 84L008 (SAME TURBOPUMP BUILD)  
 + HEADRISE DATA - TEST 84L005  
 ++ EFFICIENCY DATA FOR CLEARANCES SHOWN - TEST 84L015




Figure 16. Low-Thrust Water Testing  
 Configuration 1  
 Test and Curve Speed - 24,500 rpm  
 Specific Speed - 430




Figure 17. Low-Thrust Water Testing  
 Configuration 2  
 Test and Curve Speed - 24,500 rpm  
 Specific Speed - 430






Figure 18. Low-Thrust Water Testing  
 Configuration 3  
 Test and Curve Speed - 29,000 rpm  
 Specific Speed - 215




Figure 19. Low-Thrust Water Testing  
 Configuration 4  
 Test and Curve Speed - 24,500 rpm  
 Specific Speed - 430




Figure 20. Low-Thrust Water Testing  
 Configuration 5  
 Test and Curve Speed - 29,000 rpm  
 Specific Speed - 215




Figure 21. Low-Thrust Water Testing  
 Configuration 6  
 Test and Curve Speed - 24,500 rpm  
 Specific Speed - 430




Figure 22. Low-Thrust Water Test Efficiency




Figure 23. Low-Thrust Water Test Head




Figure 24. Pump and Impeller Static Headrise  
 Low-Thrust Water Testing, Configuration 1




Figure 25. Pump and Impeller Static Headrise  
 Low-Thrust Water Testing, Configuration 2






Figure 26. Pump and Impeller Static Headrise  
Low-Thrust Water Testing, Configuration 3




Figure 27. Pump and Impeller Static Headrise  
 Low-Thrust Water Testing, Configuration 4




Figure 28. Pump and Impeller Static Headrise  
 Low-Thrust Water Testing, Configuration 5




Figure 29. Pump and Impeller Static Headrise  
 Low-Thrust Water Testing, Configuration 6

TABLE 6. DIFFUSION SYSTEM STATIC PRESSURE DISTRIBUTION

CONFIGURATION	IMPELLER STATIC HEADRISE, FEET $H_{IMP}$	OVERALL PUMP STATIC HEADRISE, FEET $H_{OV}$	DIFFUSER STATIC HEADRISE, FEET $H_{D-P}$	$H_{D-P}/H_{OV}$
1	620	724	104	0.14
2	576	752	176	0.23
3*	720	805	85	0.11
4	354	440	86	0.20
5*	192	243	51	0.21
6	638	744	106	0.14

\*TEST SPEED 29,000 RPM  
RESULTS SCALED TO 24,500 RPM

$H_{D-P} = H_{OV} - H_{IMP}$

#### SUCTION PERFORMANCE

Cavitation tests were run at constant pump speed and flowrate for pump Configurations 2, 3, 4, 5, and 6. Pump Configuration 1 was not run because it contains the same impeller as Configuration 2 and, therefore, would have the same suction performance. All suction performance data are presented at 5% overall pump head loss. The design point predicted and test suction performance is compared for the six configurations in Table 7. The predicted cavitation performance at the design point is based on the procedure developed by Gongwer and presented by Wislicenus in Ref. 1. For the partial admission and emission pumps, the impeller inlet area was determined by multiplying the geometric area by emission or admission ratio. The calculated leakage flowrate for each configuration was added to the through flowrate in computing the impeller inlet flow coefficient. As shown in Table 7, Configurations 4 and 5 (open face impellers) exhibited higher suction specific speed capability than predicted. A probable explanation is that the influence of the backflow leakage is lower than originally accounted for in the predicted values. The shrouded impeller Configurations 3 and 6 (25 and 50% emission, respectively) both performed better than predicted, indicating that the partial emission influence is not as severe as predicted.

Figure 30 presents the test Configuration 2 pump total headrise versus NPSH for 80, 100, and 120% of design flowrate at a test speed of 24,500 rpm. The test results show that the head rise is constant over a wide NPSH range for each flowrate. The suction specific speed versus flow ratio is shown on Fig. 31.




Figure 30. Cavitation Test, Configuration 2

- SHROUDED IMPELLER
- .030" TIP WIDTH
- 100% VANELESS DIFFUSER EMISSION




Figure 31. Suction Performance Configuration 2

TABLE 7. SUMMARY OF CENTRIFUGAL STAGE DESIGN POINT SUCTION PERFORMANCE

TEST CONFIGURATION	TEST SPEED, RPM	DESIGN FLOW AT TEST SPEED, GPM	INLET NPSH AT 5% HEAD FALLOFF, FEET	SUCTION SPECIFIC SPEED (TEST)	SUCTION SPECIFIC SPEED (PREDICTED)	$\frac{N_{SS} \text{ (TEST)}}{N_{SS} \text{ (PRED)}}$
1	24,500	5.0	11.6	8,700	9235	0.94
2	24,500	5.0	11.6	8,700	9370	0.93
3	27,440	1.4	6.7	7,800	4345	1.80
4	24,500	5.0	8.8	10,700	7440	1.44
5	29,000	1.48	13.2	5,100	4370	1.17
6	24,500	5.0	10.8	9,200	7120	1.29

Figure 32 indicates that the head rise versus NPSH is constant for Configuration 3 over a wide NPSH range at 80 and 100% of the design flowrate. At 120% of design flowrate the head rise begins to drop as NPSH is decreased below approximately 100 feet at 27,440 test rpm. The test results presented on Fig. 26 indicate that the diffuser static pressure recovery continuously decreases as the flowrate is increased until at 120% of design flowrate the recovery is zero. This along with the 120% head versus NPSH characteristic indicates the vaned diffuser may be cavitating. This may be a function of the percent emission since the 50% emission Configuration 6 demonstrated a constant head rise over a wide flow range of 120% flow as well as a constant diffusing system static pressure rise over a wide flow range. Suction specific speed versus flowrate for Configuration 3 is shown on Fig. 33.

Configuration 4 cavitation performance shown in Fig. 34 as head versus NPSH for 80, 100, and 120% of design flowrate indicates a wide NPSH range at constant headrise. The suction specific speed versus flow ratio at 5% head loss is shown on Fig. 35.

Configuration 5 head versus NPSH is shown for flow ratios  $Q/Q_D$  of 0.8, 1.0, and 1.2 on Fig. 36. Suction specific speed versus flow ratio is shown in Fig. 37. This partial admission impeller demonstrated the lowest suction specific speed of the six test configurations.

Configuration 6 head versus NPSH is presented on Fig. 38 for the flow ratios 0.8, 1.0, and 1.2. Constant head was generated over a wide NPSH range for the three flowrates. Suction specific speed versus flow ratio is plotted on Fig. 39.

#### HYDRODYNAMIC SHAFT LOADING

Each pump was instrumented to measure pressures required to calculate axial and radial forces produced by the impeller.






Figure 32. Cavitation Test, Configuration 3

- SHROUDED IMPELLER
- .030" TIP WIDTH
- 25% VANED DIFFUSER EMISSION




Figure 33. Suction Performance Configuration 3




Figure 34. Cavitation Test, Configuration 4

- UNSHROUDED IMPELLER
- .035" TIP WIDTH
- 100% IMPELLER ADMISSION




Figure 35. Suction Performance Configuration 4




Figure 36. Cavitation Test, Configuration 5

- UNSHROUDED IMPELLER
- .035" TIP WIDTH
- 25% IMPELLER ADMISSION




Figure 37. Suction Performance Configuration 5






Figure 38. Cavitation Test, Configuration 6




Figure 39. Suction Performance Configuration 6

Radial Load. The radial loads are determined from the static pressure distribution downstream of the impeller. For the vaned diffuser pumps the static pressure taps are located in the diffuser passage inlet. The number of diffuser passages and, therefore, the number of static pressure taps depends on the configuration. For volute pumps four taps are located equally spaced in the volute. From these pressures the static pressure at the impeller tip is determined by assuming a free vortex flow from the impeller discharge diameter to the pressure tap location.

Using the pressures at the impeller tip and assuming the pressure distribution is linear between pressure taps, the incremental forces may be calculated. The resultant force is found by summing force components vectorially.

Radial loads over the test flow range are shown in Fig. 40. The two pumps showing the smallest radial loads are Configurations 1 and 6. Both of these configurations have vaned diffusers. The only other pump with a vaned diffuser, Configuration 3, showed larger radial loads than 1 and 6. However, the radial loads for Configuration 3 were calculated using the two diffuser inlet pressure taps and, therefore, are not as accurate as the other results. The test speed for Configurations 3 and 5 were 29,000 rpm, compared with 24,500 rpm for Configurations 1, 2, 4, and 6. Therefore, the Configuration 3 and 5 radial loads should be divided by 1.4 before comparison with the other configurations. The vaned diffuser configurations exhibit radial loads which do not depend strongly on flowrate. This is in contrast to the volute pumps, which show higher radial loads with a large dependence on flowrate. These characteristics agree with those predicted for the vaned diffuser and volute pumps. Vaned diffuser pumps are more desirable when wide flow range operation is required.

Axial Loads. The axial load is determined from the static pressure distribution on the front and rear impeller face and by the impeller inlet pressure. The front face has three static pressure taps located at the shroud hub, midpoint, and tip. The rear face has two static pressure taps located at the shroud hub and tip.

The axial load versus flow/design flow is plotted in Fig. 41 and 42 for the shrouded and open face impellers, respectively. The shrouded impellers show design point axial loads in the range of 2.6 to 42.5 pounds in a direction toward the turbine. The open face impellers show design point values of 8.7 and 22.2 pounds. However, the direction is away from the turbine. All axial and radial loads are well within bearing load capability in the design flow region. With vaned diffusers load margin exists over a very wide flow range.

#### ANALYSIS OF PUMP LOSSES

After completion of the water test program, Configurations 2 and 6 were selected for further tests and will be tested with liquid hydrogen as the pumped fluid. Predicted losses for these configurations when pumping water or liquid hydrogen are given in Tables 8 and 9, respectively. The losses presented are a percent of the total power input. The types of loss noted in the tables are typical of those considered in performance prediction of pumps incorporating shrouded impellers.




Figure 40. Radial Loads, Test Data




Figure 41. Axial Load, Shrouded Impellers, Test Data




Figure 42. Axial Load, Open Face Impellers, Test Data



TABLE 8. PREDICTED LOSSES PERCENT OF INPUT POWER PUMPING  
WATER SPECIFIC SPEED = 430

	PUMP CONFIGURATION	
	2	6
SPEED, RPM	24,500	24,500
FLOWRATE, GPM	5.0	5.0
WEAR RING CLEARANCE, INCHES	0.002	0.002
TOTAL WEAR RING LEAKAGE	23.9	25.2
DISK FRICTION	23.3	21.2
IMPELLER INTERNAL FRICTION	5.69	4.02
IMPELLER DIFFUSION	0.98	2.3
IMPELLER INCIDENCE	0.50	0.51
IMPELLER EXIT RECIRCULATION	0	0.34
VANELESS SPACE FRICTION	0.90	0.84
VANED DIFFUSER INCIDENCE	-	1.38
VANED DIFFUSER FRICTION	-	2.79
VANED DIFFUSER DIFFUSION	-	4.62
VOLUTE MOMENTUM	1.44	0.15
VOLUTE FRICTION	3.99	1.77
VOLUTE DIFFUSION	0.27	0.07
TOTAL	60.97	65.2
PREDICTED EFFICIENCY, PERCENT	39.03	34.8

TABLE 9. PREDICTED LOSSES PERCENT OF INPUT POWER PUMPING  
LIQUID HYDROGEN SPECIFIC SPEED = 430

	PUMP CONFIGURATION		
	2	6	
PUMP SPEED, RPM	77,000	77,000	
FLOWRATE, GPM	15.7	15.7	
WEAR RING, CLEARANCE, INCHES	0.002	0.002	0.003
TOTAL WEAR RING LEAKAGE	27	28.3	37.4
DISK FRICTION	14.4	13.0	11.7
IMPELLER INTERNAL FRICTION	5.4	3.4	3.3
IMPELLER DIFFUSION	1.36	2.5	1.82
IMPELLER INCIDENCE	0.56	0.56	0.41
IMPELLER EXIT RECIRCULATION	0	0.34	0.03
VANELESS SPACE FRICTION	0.8	0.79	0.57
VANED DIFFUSER INCIDENCE	-	1.55	1.28
VANED DIFFUSER FRICTION	-	2.40	2.06
VANED DIFFUSER DIFFUSION	-	5.08	4.52
VOLUTE MOMENTUM	1.65	0.16	0.14
VOLUTE FRICTION	3.48	1.45	1.33
VOLUTE DIFFUSION	0.3	0.08	0.07
TOTAL	55.0	59.6	64.6
PREDICTED EFFICIENCY, PERCENT	45.0	40.4	35.4

Partial emission pump performance was evaluated assuming that the flow velocity in the flowing impeller passages was equal to the impeller through flow divided by the percent emission plus wear ring leakage flow. This fluid quantity was then used to calculate impeller friction diffusion and incidence loss in the flowing passages. No unsteady flow loss was computed and, because of the low impeller flow coefficient for these low specific speed pumps, this loss is small. For higher specific speed pumps and compressors with higher impeller passage velocities, this loss would be significant.

Comparison of the results for pumping water (Table 8) with results for pumping liquid hydrogen (Table 9) shows that flow friction and, in particular, disk friction losses are significantly lower when pumping liquid hydrogen. This is due to the much lower viscosity of hydrogen and results in higher efficiency. The losses associated with leakage, diffusion, and momentum are a higher percentage of the power input as a result of the reduced input power resulting from the lower disk friction.

By far, the highest individual losses in either fluid are the disk friction loss and the impeller wear ring (seal) leakage loss. With wear ring radial clearances of only 0.002 inch, the total of these two losses account for approximately 47% of total power input when pumping water and 40% when pumping liquid hydrogen. With low specific speed pumps, the clearance must be small to reduce leakage loss. This is illustrated in Table 9 which shows the influence of a clearance change on Configuration 6 when pumping liquid hydrogen. An increase in radial clearance from 0.002 to 0.003 inch results in a decrease in predicted efficiency from 40.4 to 35.4%, which would require a 14% increase in input power.

The leakage loss for the shrouded impellers includes the front (impeller inlet) and rear wear ring flows. The rear wear ring flow is returned to the impeller inlet through passages in the component. The leakage flow through the impeller inlet wear ring, however, has a tangential velocity approximately equal to half wheel speed at the impeller inlet prior to mixing with the incoming flow. This produces prewhirl at the impeller inlet, which drops the change of angular momentum produced by the impeller and, therefore, reduces the pump head rise. As the delivered pump flow is reduced from its normal operating flowrate, the ratio of the impeller total flow to the whirling front wear ring flow is decreased. This results in increasing prewhirl as the flow is reduced. The increased prewhirl acts to reduce pump head rise at reduced delivered flow while the increased tangential velocity at the backwardly curved impeller blade exit acts to increase the pump head rise. The result at low specific speeds is a nearly constant head rise as delivered flow is reduced.

#### PUMP SEAL CLEARANCE EFFECTS

The impeller seals are smooth faced wear ring-type seals. Clearances vary from configuration to configuration due to manufacturing differences. An adjusted efficiency is determined, which reflects the expected efficiency at the designed 0.002 inch radial wear ring clearance.

The four shrouded impeller configurations (1, 2, 3, and 6) have wear rings sealing against both front and rear shroud cavity leakage. The smooth-faced seals are located at a mean diameter of 1.002 inch. The as-tested radial wear ring clearances are presented in Table 10. The clearance influence on efficiency is

TABLE 10. DESIGN POINT PUMP EFFICIENCY SUMMARY  
WATER TEST

CONFIGURATION NO.	TEST CONFIGURATION					TEST RESULTS				
	FRONT WEAR RING RADIAL CLEARANCE, INCHES	REAR WEAR RING RADIAL CLEARANCE, INCHES	IMPELLER FACE AXIAL CLEARANCE, INCHES	SHAFT SPEED, RPM	FLOWRATE, GPM	EFFICIENCY, %	ADJUSTED EFFICIENCY TO 0.002 INCH RADIAL SEAL CLEARANCE, %			
1	0.0015	0.0020	-	24,500	5.0	31*	30.1			
2	0.0025	0.0020	-	24,500	5.0	32.5	33.5			
3	0.0026	0.0020	-	29,000	1.48	9.6	11.2			
4	-	0.0045	0.010	24,500	5.0	23.0	-			
5	-	0.0038	0.008	29,000	1.48	5.1	-			
6	0.0031	0.0030	-	24,500	5.0	28.5**	32.9			

\*EFFICIENCY DATA - TEST 84L008

\*\*EFFICIENCY DATA - TEST 84L015

computed by the centrifugal pump loss isolation program. A sample output from the program is presented in Table 9 for a 0.002 to 0.003 inch change in radial wear ring clearance. The program output presents the individual component losses as a percentage of input power. By changing only the seal clearance, the input power is affected. The magnitude of the remaining component losses show a change in the percentage of the input power, their absolute magnitudes are essentially unchanged.

Using the Loss Isolation Program the four shrouded pump efficiencies are adjusted to the design radial wear ring clearance of 0.002 inch. These efficiencies are presented in Table 10. The Configuration 6 efficiency is better than the Configuration 1 efficiency, thus indicating the potential of partial emission pumps for low specific speeds.

The turbopump efficiencies for the open-faced impellers are not adjusted. The losses due to impeller blade tip leakages are not accurately known. The lower efficiencies for the open-faced impellers compared to the shrouded pumps is attributed to the face clearance being large compared to the impeller blade height.

The seal clearance will also have an effect on the delivered pump head. The leakage flowrate through the front impeller wear ring will have a large tangential component. Mixing of whirling leakage flow with the nonwhirling inlet flow will increase the inlet prewhirl. The effect on headrise is measured for two Configuration 6 pump builds (and is shown in Fig. 43). A 4% change in headrise is the result of a large change in wear ring clearance. Preliminary calculations agree with these measured results, further analysis on the effect of leakage flowrate on pump head output is suggested.

## CONCLUSIONS

Tests were successfully completed to evaluate small centrifugal pumps operating at specific speeds well below those previously reported. The tests demonstrate successful pump operation is possible in the specific speed range from 215 to 430. At the lower specific speed range a severe efficiency penalty occurs since the hydraulic output power is substantially lower than the parasitic power.

The Configuration 6 partial emission diffuser concept has demonstrated the ability to use one impeller to cover a wide flow range by merely changing diffusers. The partial admission impeller concept resulted in low efficiency with an open face impeller.

Open face impellers resulted in low efficiency due to large axial clearance to passage height ratio. The control of axial clearance to the close tolerances required by small open face impellers for good performance is very difficult for small low specific speed pumps.

The maximum efficiency occurred for a volute-type pump (Configuration 2). The simplicity resulting from the absence of a vaned diffuser makes this configuration highly desirable when the engine operation permits single-point operation. Single-point operation permits volute design for a minimum radial load. When wide flow range operation is required a vaned diffuser is desired to produce a low radial load over a wide flow range such as exhibited by Configurations 1 and 6.




Figure 43. Low-Thrust Pump Head Coefficient Versus Flow Coefficient Configuration 6, Wear Ring Clearance Effect

## APPENDIX

### SAMPLE DATA

The data presented in the Appendix includes noncavitating results for each of the six configurations tested. The test number for each corresponding configuration is as follows:

<u>SECTION</u>	<u>CONFIGURATION</u>	<u>TEST NUMBER</u>
A1	1	84L007
A2	2	84L012
A3	3	84L010
A4	4	84L009
A5	5	84L011
A6	6	84L005

Each data slice represents the average of 10 scans taken during steady state-operating conditions. Included with the data is a copy of the constant file input for each configuration. The Data Table 11 shows the turbopump Configuration Geometries. The tabulated data format changed from test to test as the data reduction program was being updated.



TABLE 11. TURBOPUMP GEOMETRY

	Configuration					
	1	2	3	4	5	6
<u>Pressure Tap Radial Location (Inches)</u>						
34 Front Wear Ring Upstream	0.580	0.540	0.580	0.4025*	0.4025*	0.570
39 Front MidShroud	0.790	0.700	0.790	0.65	0.65	0.780
38 Impeller Front Tip	1.0	1.0	1.0	1.0	1.0	0.980
40 Impeller Rear Tip	0.970	1.0	0.970	1.0	1.0	0.970
36 Rear Wear Ring Upstream	0.580	0.580	0.580	0.580	0.580	0.580
37 Rear Wear Ring Downstream	0.580	0.600	0.580	0.600	0.600	0.580
26 Diffuser Inlet	1.07	-	1.07	-	-	1.07
18 Volute 0°	1.7037	1.308	1.7037	1.308	1.1611	1.6722
19 Volute 90	1.5091	1.142	1.5091	1.142	1.0971	1.4835
20 Volute 180°	1.5889	1.209	1.5889	1.209	1.1096	1.5599
21 Volute 270°	1.6510	1.263	1.6510	1.263	1.1422	1.6205
<u>Wear Ring Dimensions (Inches)</u>						
Mean Diameter	1.002	1.002	1.002	1.002	1.002	1.002
Front Radial Clearance	0.0015	0.0025	0.0026	-	-	0.0031
Rear Radial Clearance	0.0020	0.0020	0.0020	0.0045	0.0038	0.0030
Front Face Axial Clearance (Inches)	-	-	-	0.010	0.008	-

TEST 64L007      TEST DATE 27 FEB 1984      PUMP CALIBRATION TEST FACILITY      PAGE 0  
 TEST 64L007      2-27-84 LOW THRUST PUMP HUB & CAV TESTS      PROCLSS DATE 5 NOV 1984

NO.	DESCRIPTION	CONSTANT
1	WALL DIAMETER AT INLET PRESS TAP, IN.	1.00000E+00
2	HUB DIAMETER AT INLET PRESS TAP, IN	0.0
5	IMPELLER INLET TIP DIAMETER, IN	8.05000E-01
6	IMPELLER INLET HUB DIAMETER, IN	5.00000E-01
7	IMPELLER DISH TIP DIAMETER, IN	2.00000E+00
9	INLET AREA AT PRESS TAP, SQ. IN	7.65000E-01
10	IND/IMP INLET AREA, SQ. IN.	3.12608E-01
11	DESIGN FLOW, GPM	5.00000E+00
12	AMBIENT PRESSURE, PSIA	1.43600E+01
13	DESIGN SPEED FOR DESIGN FLOW, RPM	2.45000E+04
19	PUMP DISCHARGE LINE DIAMETER, IN.	5.00000E-01
21	HEAD ELEVATION (FT) CORRECTION FOR F(7)	1.00000E+00
23	K FACTOR	0.0
24	WATER TANK ELEVATION, FT	1.34271E+01
31	CONFIGURATION NUMBER	1.00000E+00
35	FRONT WEAR RING UPSI KEAM PRESSURE, RADIAL LOCATION	5.80000E-01
36	IMPELLER FRONT MID PRESSURE, RADIAL LOCATION	7.50000E-01
37	IMPELLER FRONT TIP PRESSURE, RADIAL LOCATION	1.00000E+00
38	IMPELLER REAR TIP PRESSURE, RADIAL LOCATION	9.70000E-01
39	REAR WEAR RING UPSI KEAM PRESSURE, RADIAL LOCATION	5.80000E-01
40	IMPELLER LEADING EDGE TIP RADIUS	5.00000E-01
51	NOZZLE INLET DIAMETER, IN	1.00000E+00
92	NOZZLE THROT DIAMETER, IN	1.91000E-01
93	NOZZLE DISCH COEFF	9.85000E-01
94	SPL. HT. RATIO	1.40000E+00
95	MMT OF GAS	2.801E-01
96	TURB MEAN DIAMETER, IN	2.40000E+00
97	TURB NOZ AREA, IN <sup>2</sup>	5.54000E-01
98	TURB PIPE IN DIAMETER, IN	1.61000E+00
99	PERCENT TURBINE ADMISSION	1.00000E+02

SECTION AT



ORIGINAL PAGE '18  
OF POOR QUALITY

TEST 64L007 TEST DATA 27 FEB 1984 PUMP CALIBRATION TEST FACILITY PROCESS DATE 9 NOV 1984 PAGE 4  
TEST 64L007 2-27-84 LOW THRUST PUMP H-Q & CAV TESTS

TIME	-23 PUMP HEAD COEF	-101 NOZZLE FLOWRATE (LB/SEC)	-102 FLOW NOZZLE PR RATIO	-105 FLOW PARAM	-104 TURB AVL ENERGY BTU/LBM	-105 CSUBO ISEN VEL FT/S	-106 TURBINE MEAN VEL FT/S	-107 TURB AVL ENER PIP BTU/LBM
24.00A	.46733	.11961	.97090E-01	2.0645	2.0655	365.31	76.044	2.8815
501.50A	.48739	.12585	.93676E-01	2.1084	2.0496	364.25	76.034	2.8511
609.67A	.49306	.12509	.93937E-01	2.1029	2.6373	363.38	75.732	2.8965
962.00A	.49242	.20413	.72757E-01	2.7002	5.4344	521.65	153.57	5.8018
1097.00A	.49705	.20093	.73249E-01	2.6831	5.3859	514.31	153.64	5.7584
1203.67A	.49992	.19821	.73603E-01	2.6699	5.2929	514.81	153.62	5.6544
1309.00A	.50361	.19544	.74130E-01	2.6538	5.2239	511.45	153.56	5.6001
1427.00A	.50567	.19272	.74583E-01	2.6362	5.1882	509.69	153.35	5.5241
1523.50A	.50626	.18966	.75148E-01	2.6162	5.1540	508.01	153.45	5.4787
1613.83A	.50637	.18676	.75740E-01	2.5989	5.0464	502.68	153.51	5.4006
1734.00A	.50268	.18495	.76141E-01	2.5860	5.0138	501.05	153.36	5.3563
1842.00A	.50042	.18185	.76753E-01	2.5647	4.9017	495.42	153.35	5.2243
2086.67A	.49574	.27035	.67092E-01	2.9169	7.1803	599.61	204.31	7.6038
2196.00A	.50090	.26514	.67462E-01	2.9026	7.0980	596.17	204.44	7.5203
2325.00A	.50284	.26064	.67793E-01	2.8883	7.0165	592.74	204.46	7.4135
2442.00A	.50521	.25616	.68147E-01	2.8725	6.9339	589.23	204.81	7.3202
2595.83A	.51237	.25190	.68512E-01	2.8600	6.8400	585.23	205.17	7.2423
2710.00A	.51332	.24648	.68926E-01	2.8411	6.7551	578.13	204.90	7.0453
2812.00A	.51864	.24159	.69389E-01	2.8222	6.6433	576.75	204.77	7.0097
2916.00A	.51363	.23645	.69889E-01	2.8040	6.4606	568.76	205.03	6.8322
3006.50A	.51221	.23146	.70463E-01	2.7823	6.3743	564.96	205.31	6.7420
3105.00A	.51230	.22686	.71022E-01	2.7618	6.2841	560.94	204.99	6.6595
3558.83A	.50318	.36348	.63919E-01	3.0446	8.6337	657.50	255.84	9.0769
3682.00A	.50592	.35948	.64136E-01	3.0367	8.5076	652.69	255.96	8.9407
3799.00A	.51035	.34759	.64402E-01	3.0253	8.3677	651.16	255.79	8.6974
3893.00A	.51074	.34027	.64705E-01	3.0110	8.2366	648.41	255.82	8.6148
4048.67A	.51695	.33273	.64930E-01	3.0007	8.1269	641.44	255.42	8.6206
4164.83A	.51712	.32533	.65214E-01	2.9895	8.1264	637.90	255.31	8.5359
4271.00A	.51829	.31747	.65546E-01	2.9765	8.0219	633.78	255.42	8.4375
4391.00A	.51442	.30979	.65909E-01	2.9586	7.8950	628.75	256.05	8.2885
4508.00A	.51364	.30168	.66273E-01	2.9452	7.8265	626.01	256.30	8.2231

SECTION A1

TIME	-21 PUMP_INL HEADRISE (FI)	-115 TURBINE PRESSURE RATIO	6 PUMP_INL ET TEMP (F)	14 PUMP_OUT LET TEMP (F)	105 TURBINE INLET TE MP (F)	-22 PUMP_INL FLOW COEF	1 PUMP_INL ET PRESS (PSIG)	6 PUMP_DIS PRESS (PSIG)
44.00A	58.305	1.0767	71.120	71.805	54.787	.29552E-01	34.505	60.045
501.50A	60.604	1.0796	69.546	69.518	54.067	.24690E-01	35.045	61.291
609.67A	61.025	1.0790	69.644	69.967	54.005	.19362E-01	35.193	61.557
962.00A	250.63	1.1701	69.496	70.213	54.362	.26618E-01	34.393	142.52
1097.00A	253.64	1.1680	69.546	70.056	40.514	.26496E-01	34.508	143.80
1203.67A	254.63	1.1645	69.742	70.852	41.400	.23990E-01	34.746	144.68
1307.00A	256.30	1.1621	69.695	70.754	41.499	.21543E-01	34.813	145.51
1427.00A	256.88	1.1610	69.988	71.000	41.253	.19361E-01	34.555	145.84
1523.50A	257.28	1.1596	69.792	71.590	41.253	.16797E-01	35.310	146.49
1613.63A	257.54	1.1582	70.138	71.767	40.557	.14568E-01	35.296	146.61
1734.00A	258.20	1.1554	70.283	72.279	40.071	.12166E-01	35.191	145.51
1842.00A	254.01	1.1516	70.234	73.016	35.579	.97000E-02	35.254	145.08
2008.67A	446.65	1.2336	70.232	71.254	37.188	.26802E-01	33.756	226.42
2196.00A	451.66	1.2302	70.156	71.635	36.103	.26236E-01	34.037	229.05
2325.00A	453.76	1.2272	70.263	71.815	36.054	.23679E-01	34.187	230.09
2442.00A	457.39	1.2245	70.626	72.219	37.512	.21605E-01	34.367	231.89
2595.63A	465.51	1.2213	70.529	72.328	36.922	.19253E-01	34.498	235.59
2710.00A	465.17	1.2155	70.929	72.567	36.526	.16710E-01	34.722	235.73
2812.00A	466.55	1.2145	70.579	73.459	36.183	.14432E-01	34.533	237.01
2916.00A	466.00	1.2080	70.775	74.049	35.888	.12120E-01	35.019	236.46
3006.50A	466.01	1.2050	70.726	74.934	35.544	.95064E-02	35.248	236.72
3105.00A	464.66	1.2018	70.674	76.066	35.297	.75153E-02	35.348	236.26
3556.83A	710.84	1.2895	70.579	72.918	37.020	.28474E-01	33.102	339.75
3882.00A	715.37	1.2644	70.523	73.410	37.217	.26213E-01	33.600	342.31
3793.00A	720.69	1.2435	71.218	73.705	36.103	.23733E-01	33.668	344.96
3893.00A	721.40	1.2417	71.216	73.852	34.707	.21465E-01	34.159	345.68
4048.61A	727.93	1.2758	71.404	74.492	35.034	.19076E-01	34.540	346.97
4164.63A	727.50	1.2732	71.513	75.229	31.508	.16801E-01	35.232	349.55
4271.00A	729.60	1.2698	71.710	75.771	30.474	.14358E-01	35.735	351.11
4391.00A	727.93	1.2654	71.612	76.852	29.687	.12056E-01	36.136	350.77
4506.00A	728.23	1.2631	71.507	78.682	29.047	.95863E-02	36.346	351.15

SECTION A1

ORIGINAL PAGE IS  
OF POOR QUALITY

TEST 84L007 PUMP CALIBRATION TEST FACILITY TEST DATE 27 FEB 1984 PROCESS DATE 9 NOV 1984 PAGE 6  
TEST 84L007 2-27-84 LOW THRUST PUMP H-Q 1 CAV ILSIS

TIME	16	19	20	21	26	34	36	37
	VOLUTE P RESS GDE G(P SIG)	VOLUTE P RESS 900 EG(P SIG)	VOLUTE P RESS 1800 EG(P SIG)	VOLUTE P RESS 2700 EG(P SIG)	DIFF IN PRESS 1 (P SIG)	FRONT WR RING UP R (P SIG)	REAR WR RING UP R (P SIG)	REAR WR RING UP R (P SIG)
24.00A	59.044	60.754	59.459	61.237	58.941	53.072	53.191	34.443
501.50A	60.434	61.916	60.026	62.235	59.791	53.692	55.774	34.592
609.67A	60.957	62.293	61.004	62.489	60.151	53.986	54.130	34.725
962.00A	138.22	141.50	139.25	138.02	133.94	106.33	107.04	35.406
1097.00A	139.87	142.50	140.47	135.07	134.43	106.92	107.41	35.522
1203.67A	141.32	143.61	141.27	140.19	135.30	107.52	108.09	35.772
1309.00A	142.58	144.27	142.08	141.22	135.89	108.11	108.75	35.938
1427.00A	143.45	145.15	142.49	141.95	136.35	108.40	109.11	36.120
1523.50A	144.53	145.69	142.95	142.69	136.86	108.66	109.85	36.552
1613.63A	144.97	146.15	143.51	143.76	137.47	109.38	110.55	36.752
1734.00A	143.52	144.80	141.72	142.82	136.61	109.27	111.09	36.735
1842.00A	143.91	144.10	140.93	142.33	136.61	109.91	111.81	37.100
2086.67A	218.71	223.19	220.86	217.74	209.25	159.25	159.23	36.386
2196.00A	222.13	225.65	223.11	220.14	211.20	160.44	160.36	36.802
2325.00A	224.06	228.66	224.23	221.30	211.93	160.99	160.67	37.117
2442.00A	226.82	229.15	226.46	223.68	213.60	162.14	162.11	37.383
2595.63A	230.99	233.52	232.07	231.76	215.76	163.61	161.66	37.698
2710.00A	231.69	234.06	232.71	232.35	215.61	163.69	162.20	38.061
2812.00A	233.87	235.23	232.90	233.95	216.60	164.60	163.20	38.429
2916.00A	233.84	235.35	233.93	233.79	216.27	164.68	163.43	38.926
3006.50A	234.62	235.84	234.44	234.79	217.15	165.83	164.64	39.343
3105.00A	234.58	235.37	234.08	234.33	217.22	166.45	165.35	39.574
3558.83A	320.91	332.57	332.68	329.94	309.42	227.16	222.99	38.064
3682.00A	331.26	336.45	336.42	333.03	311.86	228.87	224.62	36.695
3799.00A	335.25	337.67	336.75	333.17	313.05	229.88	225.74	39.127
3893.00A	337.77	340.95	340.64	337.25	314.10	231.07	227.02	39.625
4048.61A	342.23	344.88	343.72	339.94	315.67	232.31	228.71	40.406
4164.83A	343.51	345.17	344.41	341.29	315.76	233.10	230.37	41.170
4271.00A	346.11	347.15	346.70	343.96	317.76	234.91	232.62	42.200
4391.00A	346.78	347.74	346.97	344.36	318.15	235.58	233.65	42.981
4508.00A	347.81	348.27	347.90	345.41	318.91	237.03	234.99	43.761

SECTION A1



TIME	SHAFT LLD	4 SF (RPM)	-21 PUMP TGT HEADRISL (FT)	3 PUMP DIS FLOW (GPM)	-16 FLOW/ UES FLOW	-30 PUMP SCA LED HEAD RISE (FT)	-31 PUMP SCA LED FLOW (GPM)	-32 PUMP HYD PWR HP																						
									27125E-01	23635E-01	18529E-01	22807	21345	19430	17558	15780	13731	11425	98747E-01	78233E-01	54415	50182	45874	41903	38072	32975	28606	25976	18831	14428
24.00A	7201.7		58.302	1.0444	1.2448	863.98	6.2228																							
501.50A	7260.7		60.804	1.5407	1.6358	692.46	5.1989																							
609.67A	7231.9		61.025	1.2035	81542	700.55	4.0771																							
962.00A	14804.		250.63	3.6005	1.2052	659.01	6.0260																							
1097.00A	14871.		253.24	3.3409	1.1156	700.24	5.5792																							
1203.67A	14809.		254.63	3.0247	1.0103	710.27	5.0517																							
1309.00A	14884.		258.20	2.7150	50728	712.52	4.5363																							
1427.00A	14644.		250.88	2.4308	81535	718.44	4.0768																							
1523.50A	14853.		257.28	2.1154	70741	719.27	3.5370																							
1613.83A	14859.		257.54	1.8394	61254	719.43	3.0677																							
1734.00A	14645.		255.20	1.5338	51319	714.20	2.5660																							
1842.00A	14644.		254.01	1.2209	40851	710.98	2.0425																							
2082.87A	19510.		448.85	4.8257	1.2150	704.33	6.0649																							
2196.00A	19523.		451.16	4.4022	1.1049	711.87	5.5246																							
2325.00A	19528.		453.78	4.0074	1.0058	714.41	5.0281																							
2442.00A	19558.		457.35	3.6317	90989	717.78	4.5494																							
2599.83A	19593.		465.51	3.2420	81081	727.95	4.0541																							
2710.00A	19567.		465.17	2.8100	70371	729.31	3.5185																							
2812.00A	19554.		467.55	2.4254	60778	734.62	3.0389																							
2916.00A	19579.		468.00	2.0396	51044	729.74	2.5522																							
3008.50A	19600.		466.01	1.6019	40055	727.72	2.0018																							
3105.00A	19575.		464.88	1.2306	30808	727.88	1.5404																							
3258.63A	24431.		710.84	5.9788	1.1592	714.91	5.9958																							
3682.00A	24442.		715.57	5.5068	1.1034	718.79	5.5197																							
3799.00A	24446.		724.99	5.3823	99548	723.09	4.9974																							
3893.00A	24429.		721.40	4.5110	90484	725.64	4.5242																							
4046.67A	24391.		721.93	3.9950	80336	734.47	4.0168																							
4164.83A	24381.		727.50	3.5205	70756	734.70	3.5378																							
4271.00A	24391.		729.80	3.0100	60489	736.37	3.0234																							
4391.00A	24451.		727.93	2.5294	50691	730.87	2.5345																							
4508.00A	24475.		728.23	2.0165	40372	729.75	2.0186																							

SECTION A1



TEST 84L012

TEST DATE 27 MAR 1984  
 TEST 84L012, 2-26-1984, LOW THRUST PUMP HQ & LAV TESTS  
 PUMP CALIBRATION TEST FACILITY  
 PROCESS DATE 9 NOV 1984  
 PAGE 0

C	DESCRIPTION	CONSTANT
1	WALL DIAMETER AT INLET PRESS TAP, IN.	1.00000E+00
2	HUB DIAMETER AT INLET PRESS TAP, IN	0.0
5	IMPELLER INLET TIP DIAMETER, IN	8.05000E-01
6	IMPELLER INLET HUB DIAMETER, IN	5.00000E-01
7	IMPELLER DISH TIP DIAMETER, IN	2.00000E+00
9	INLET AREA AT PRESS TAP, SQ. IN	7.85000E-01
10	IND/IMP INLET AREA, SQ. IN.	3.12608E-01
11	DESIGN FLOW, GPM	5.00000E+00
12	AMBIENT PRESSURE, PSIA	1.42490E+01
13	DESIGN SPEED FOR DESIGN FLOW, RPM	2.45000E+04
19	PUMP DISCHARGE LINE DIAMETER, IN.	5.00000E-01
21	HEAD ELEVATION (FT) CORRECTION FOR F(7)	0.0
23	K FACTOR	0.0
24	WATER TANK ELEVATION, FT	0.0
91	NOZZLE INLET DIAMETER, IN	1.00000E+00
92	NOZZLE THROAT DIAMETER, IN	1.91000E-01
93	NOZZLE DISCH COEFF	9.85000E-01
94	SPEC. HT. RATIO	1.40000E+00
95	MWT OF GAS	2.80160E+01
96	TURB MEAN DIAMETER, IN	2.40000E+00
97	TURB NOZ AREA, IN2	5.54000E-01
98	TURB PIPE IN DIAMETER, IN	1.61000E+00
99	PERCENT TURBINE ADMISSION	1.00000E+02

SECTION A2

TEST 8+L012      TEST 34L012, 3-26-1984 LUM, IHKUST PUMP HQ & CAV TESTS      PUMP CALIBRATION TEST FACILITY      PROCESS DATE 9 NOV 1984      PAGE 5

TIME	-17 PUMP SIA DELTA HEAD FT	-18 PUMP DIS VELOCITY (FPS)	-1 WATER SP. WGT. LBM/FT3	-2 VAPOR HEAD (FT)	-21 PUMP ICI HEADRISE (FT)	-22 PUMP INL FLOW COEF	-23 PUMP DIS HEAD COEF	-3 INLET VELOCITY (FPS)
21.50A	27.2802	12.254	62.225	1.0585	-1.3326	.36384E-01	-.97880E-03	3.0350
32.00A	62.705	2.9352	62.266	.88652	62.874	.28344E-01	.48896	.73367
43.00A	62.559	2.5044	62.266	.89396	62.682	.24240E-01	.48995	.62643
85.50A	63.328	1.9644	62.266	.89545	63.403	.19077E-01	.49953	.49134
110.50A	264.42	5.8686	62.265	.89696	265.09	.28391E-01	.51693	1.4679
122.00A	265.30	5.4021	62.263	.90448	265.87	.26198E-01	.52096	1.3512
1302.50A	266.60	4.7763	62.264	.90146	266.49	.24125E-01	.52181	1.2447
1390.50A	267.58	4.4303	62.262	.91052	267.96	.21470E-01	.52427	1.1081
1507.50A	266.61	3.9903	62.261	.91356	266.92	.19364E-01	.52369	.99808
1906.50A	265.62	3.4435	62.260	.91663	265.85	.16688E-01	.52028	.86127
1694.00A	266.39	2.9989	62.259	.91569	266.57	.14543E-01	.52226	.75011
1658.50A	265.82	2.5373	62.257	.92891	265.94	.12309E-01	.52144	.63465
192.50A	263.89	2.0616	62.236	.93206	263.97	.97099E-02	.51755	.50067
2190.00A	474.01	7.8258	52.251	.95236	475.22	.28397E-01	.52132	1.7574
2272.50A	476.71	7.2141	52.249	.96194	477.73	.26183E-01	.52432	1.8044
2366.50A	477.77	6.6132	52.245	.97474	478.84	.24000E-01	.52541	1.9541
2450.00A	477.98	5.9323	52.243	.98279	478.67	.21509E-01	.52428	1.4838
2550.50A	477.57	5.2652	52.240	.99421	478.11	.19150E-01	.52696	1.3170
2634.00A	478.58	4.5591	52.239	.99915	478.99	.16686E-01	.52533	1.1503
2729.00A	478.13	3.9844	52.236	1.0108	478.45	.14453E-01	.52448	.99661
2850.50A	475.86	3.3241	52.235	1.0174	476.02	.12049E-01	.52107	.83146
2946.50A	475.35	2.6222	52.231	1.0326	475.49	.95237E-02	.52259	.65588
3059.50A	472.60	1.9840	52.230	1.0383	472.67	.71990E-02	.51851	.49625
3419.50A	739.61	9.7512	62.212	1.1396	741.48	.28482E-01	.52705	2.4390
3555.00A	742.57	9.0226	62.203	1.1483	744.57	.26337E-01	.52742	2.2593
3634.50A	744.25	8.1525	62.201	1.1556	745.57	.23921E-01	.52963	2.0491
3745.50A	747.18	7.4167	62.193	1.1897	748.26	.21645E-01	.53104	1.8551
3847.50A	747.75	6.5794	62.186	1.2168	748.04	.19193E-01	.53083	1.6457
3952.50A	745.82	5.7479	62.181	1.2385	744.47	.16771E-01	.52803	1.4577
4037.50A	743.77	4.8568	62.174	1.2505	744.24	.14295E-01	.52047	1.2248
4116.50A	740.03	4.1232	62.177	1.2586	740.37	.12026E-01	.52476	1.0313
4221.50A	740.25	3.2721	62.174	1.2667	740.50	.95365E-02	.52406	.81845
4321.50A	736.15	2.5270	62.169	1.2512	736.27	.73762E-02	.52266	.63207
4495.00A	734.93	1.7000	62.168	1.2974	734.99	.49597E-02	.52133	.42521

SECTION A2

TEST 84L012	PUMP CALIBRATION TEST FACILITY										PAGE 7
	TEST 84L012	IPST DATE 27 MAR 1984	PROCESS DATE 5 NOV 1984	TEST 84L012	2-26-1984 LOW THRUST PUMP HQ 6 CAV TESTS	TEST 84L012	TEST 84L012	TEST 84L012	TEST 84L012	TEST 84L012	
TIME	-0	-101	-102	-103	-104	-105	-106	-107			
	AMBIENT PRESS (PSIA)	NOZZLE FLOWRATE (LB/SEC)	NOZZLE FLOW PR RATIO	FLOW PARAM	TURB AVL ENERGY, BTU/LBM	CSUBO ISEN VEL FT/S	TURBINE MEAN VEL FI/S	TURB AVL ENER PIP BTU/LBM			
21.50A	14.249	.92315E-02	.96849	.20161	- .30387E-01	52.378	251.15	-30135E-01			
532.00A	14.249	.11741	.94593E-01	2.1125	2.6837	366.47	77.164	2.9375			
743.00A	14.249	.11966	.93386E-01	2.1327	2.6807	366.32	77.033	2.9481			
889.50A	14.249	.11902	.93715E-01	2.1236	2.6510	364.25	76.772	2.9124			
1109.50A	14.249	.19450	.70029E-01	2.8222	5.8316	540.37	154.14	6.2384			
1212.00A	14.249	.19325	.70191E-01	2.8134	5.7790	537.93	153.77	6.1852			
1302.50A	14.249	.19219	.70376E-01	2.8063	5.7590	536.99	153.82	6.1733			
1399.50A	14.249	.18952	.70374E-01	2.7882	5.6432	531.57	153.88	6.0609			
1507.50A	14.249	.18838	.71070E-01	2.7771	5.5953	529.31	153.67	5.9740			
1506.50A	14.249	.18557	.71673E-01	2.7545	5.5229	525.88	153.87	5.9039			
1694.00A	14.249	.18388	.71979E-01	2.7412	5.4909	524.34	153.78	5.8423			
1356.50A	14.249	.18094	.72634E-01	2.7202	5.3646	518.28	153.72	5.7533			
1962.50A	14.249	.17956	.72953E-01	2.7107	5.3348	516.83	153.73	5.7030			
2190.00A	14.249	.24971	.63585E-01	3.0935	8.0264	633.96	205.51	8.5237			
2272.50A	14.249	.24679	.63792E-01	3.0853	8.0354	634.32	205.46	8.5133			
2366.50A	14.249	.24413	.64009E-01	3.0707	7.9415	630.60	205.48	8.4141			
2430.00A	14.249	.24078	.64359E-01	3.0560	7.8276	626.06	205.68	8.3096			
2490.50A	14.249	.23703	.64742E-01	3.0393	7.7005	620.95	205.03	8.1783			
2634.00A	14.249	.23420	.65040E-01	3.0228	7.6439	618.67	205.53	8.0838			
2729.00A	14.249	.23098	.65233E-01	3.0084	7.5098	613.22	205.58	7.9659			
2830.50A	14.249	.22746	.65862E-01	2.9875	7.4141	609.30	205.74	7.8508			
2946.50A	14.249	.22388	.66304E-01	2.9657	7.3193	605.39	205.32	7.7340			
3029.50A	14.249	.22101	.66680E-01	2.9523	7.1888	599.97	205.51	7.6202			
3419.50A	14.249	.31040	.59835E-01	3.2699	10.223	715.47	255.31	10.731			
3523.00A	14.249	.31567	.60315E-01	3.2577	10.100	711.16	255.75	10.600			
3634.50A	14.249	.31093	.60190E-01	3.2476	9.9941	707.41	255.39	10.485			
3749.50A	14.249	.30584	.60485E-01	3.2341	9.9032	704.19	255.52	10.388			
3847.50A	14.249	.30103	.60741E-01	3.2225	9.7519	698.78	255.63	10.242			
3952.00A	14.249	.29532	.61036E-01	3.2071	9.6235	694.17	255.58	10.104			
4037.50A	14.249	.29023	.61338E-01	3.1906	9.5193	690.40	255.45	9.9840			
4116.50A	14.249	.28606	.61579E-01	3.1830	9.3299	683.50	255.67	9.8220			
4221.50A	14.249	.28026	.61929E-01	3.1636	9.1951	678.54	255.87	9.6590			
4321.50A	14.249	.27467	.62375E-01	3.1448	9.0089	671.63	255.48	9.4957			
4445.00A	14.249	.26975	.62700E-01	3.1300	8.8925	667.29	255.60	9.3872			

SECTION A2

TEST 84L012, 3-26-1984 LOW THRU PUMP HQ & CAV TESTS

PUMP CALIBRATION TEST FACILITY

TEST DATE 27 MAR 1984 PROCESS DATE 9 NOV 1984

TIME	SHAFT SP LED (RPM)	-21 PUMP TOT HEADRISE (FT)	3 PUMP DIS FLOW (GPM)	-30 PUMP SCA LED HEAD RISE (FT)	-31 PUMP SCA LED FLOW (GPM)	-32 PUMP HYD PKW HP
21.50A	2378.5	-1.3326	7.4999	5.97	694.7	-.25191E-02
532.00A	7368.0	62.874	1.7952	5.10	696.1	.28495E-01
743.00A	7356.1	62.682	1.5528	4.02	709.7	.24253E-01
885.50A	7331.2	63.403	1.2023	5.98	734.5	.19229E-01
1109.50A	1471.9	265.09	3.5718	5.52	740.2	.24016
1212.00A	1438.4	265.87	3.3065	5.08	741.4	.22171
1302.50A	1408.9	266.47	3.0757	4.52	744.9	.20471
1390.50A	1439.5	267.96	2.7115	4.08	744.0	.18326
1507.50A	1467.4	266.92	2.4422	3.51	739.2	.16440
1606.50A	1469.4	265.85	2.1075	3.06	742.0	.14130
1694.00A	1400.9	266.57	1.8355	2.59	746.9	.12340
1856.50A	1407.9	265.94	1.5529	2.04	735.3	.10416
1962.50A	1468.0	265.97	1.2251	5.98	740.7	.81558E-01
2190.00A	1925.5	475.22	4.7997	5.51	744.9	.57396
2272.50A	1752.0	477.73	4.4153	5.05	746.5	.53189
2300.50A	1922.2	478.84	4.0475	4.53	744.9	.48869
2450.00A	1954.1	476.07	3.6308	4.03	748.7	.43021
2550.50A	1957.9	478.11	3.2225	3.51	746.4	.38844
2634.00A	1927.7	478.99	2.8148	3.04	745.2	.33992
2729.00A	1903.2	476.45	2.4366	2.54	740.3	.29414
2830.50A	1934.9	476.02	2.0345	2.01	742.5	.24415
2940.50A	1960.7	475.49	1.6049	1.52	736.7	.19236
3059.50A	1952.5	472.67	1.2143	6.00	748.8	.14468
3419.50A	2438.0	741.48	5.5081	5.55	749.3	1.1152
3555.00A	2442.2	744.57	5.5283	5.04	752.5	1.0371
3634.50A	2438.8	745.57	5.0140	4.56	754.5	.94189
3745.50A	2440.0	748.26	4.5393	4.04	754.2	.85567
3837.50A	2441.1	748.64	4.0268	3.53	750.2	.75938
3952.00A	2440.6	744.47	3.5179	3.01	750.8	.65968
4037.50A	2433.5	744.24	2.9970	2.53	745.5	.56180
4116.50A	2441.5	740.37	2.5236	2.01	744.6	.47057
4221.50A	2434.4	740.50	2.0027	1.55	742.6	.37350
4321.50A	2439.6	736.27	1.5406	1.04	740.7	.28676
4443.00A	2440.8	734.93	1.0404			.19257

SECTION A2

TEST 84012 PUMP CALIBRATION TEST FACILITY TEST DATE 27 MAR 1984 PROCESSED DATE 9 NOV 1984 PAGE 31  
 TEST 84012, 3-26-1984 LOW THRUST PUMP HQ & CAV IESIS

TIME	-190 TURB TESTER EFF	-191 TURB TESTER WORK	-192 TURB TESTER HP	-193 TURB TESTER TLRQUE	-194 EQUIV. WORK BTU/LB	-195 ACTUAL PUMP EFF
21.50A	.2316UE+07	-71379.	-934.75	-2456.6	-66472.	.14261E-05
52.00A	.40105	1.2367	.20502	1.7579	1.2463	.13648
74.00A	.40051	1.2345	.20914	1.7910	1.2603	.11581
65.50A	.40134	1.2226	.20604	1.7708	1.2518	.93220E-01
110.50A	.50989	3.3233	.91462	3.9162	3.4527	.20258
1212.00A	.57065	3.2979	.90184	3.8708	3.4323	.24584
1302.50A	.57147	3.2910	.89497	3.8400	3.4265	.22874
1390.50A	.57540	3.2474	.87087	3.7351	3.3801	.21043
1507.50A	.57655	3.2259	.85989	3.6931	3.3588	.19120
1606.50A	.57950	3.2005	.84053	3.6052	3.3313	.16811
1694.00A	.58039	3.1868	.82921	3.5586	3.3146	.14882
1856.50A	.58464	3.1364	.80307	3.4478	3.2589	.12969
1902.50A	.58573	3.1246	.79394	3.4084	3.2417	.10272
2190.00A	.61815	4.9014	1.7531	5.6300	5.1811	.32740
2272.50A	.61785	4.7040	1.7351	5.5734	5.1700	.30654
2366.50A	.62007	4.9243	1.7011	5.4638	5.1297	.28728
2450.00A	.62305	4.8773	1.6617	5.3322	5.0765	.26371
2550.50A	.62450	4.8124	1.6141	5.1958	5.0054	.24068
2634.00A	.62721	4.7942	1.5888	5.1017	4.9871	.21395
2729.00A	.63055	4.7352	1.5477	4.9684	4.9242	.19007
2830.50A	.63314	4.6942	1.5109	4.8468	4.8835	.16159
2940.50A	.63474	4.6458	1.4717	4.7308	4.8337	.13070
3059.50A	.63832	4.5888	1.4350	4.6085	4.7743	.10082
3419.50A	.65270	6.0725	3.0251	7.8202	7.0461	.36865
3555.00A	.65536	6.0191	2.9560	7.6300	6.9933	.35081
3634.50A	.65668	6.5028	2.8875	7.4621	6.9324	.32622
3745.50A	.65838	6.5200	2.8217	7.2884	6.8728	.30326
3847.50A	.66111	6.4409	2.7462	7.0902	6.7909	.27855
3952.00A	.66323	6.3825	2.6672	6.8076	6.7252	.24733
4037.50A	.66484	6.3288	2.5992	6.7153	6.6678	.21615
4110.50A	.66837	6.2357	2.5241	6.5158	6.5630	.18644
4221.50A	.67093	6.1693	2.4467	6.3108	6.4877	.15267
4321.50A	.67364	6.0680	2.3589	6.0935	6.3845	.12158
4495.00A	.67577	6.0092	2.2938	5.9230	6.3129	.83956E-01

7350 RPM

14700 RPM

19600 RPM

24500 RPM

SECTION A0

ORIGINAL PAGE IS  
OF POOR QUALITY

TEST 04L01Z TEST DATE 27 MAR 1984 PUMP CALIBRATION TEST FACILITY PROCESS DATE 9 NOV 1984 PAGE 9  
 TEST 04L01Z, 3-26-1984 LOW THRUST PUMP HQ & CAV TESTS

TIME	-15 IMPELLER IN FLOW COEF	-115 TURBINE PRESSURE RATIO	6 PUMP INL EI TEMP (F)	14 PUMP OUT LEI TEMP (F)	105 TURBINE INLET TE MP (F)	106 TURBINE OUTLET T EMP (F)	1 PUMP INL ET PRESS (PSIG)	8 PUMP DIS PRESS (PSIG)
21.50A	.91366E-01	.99920	76.871	77.610	78.308	75.682	35.206	33.419
532.00A	.71177E-01	1.0800	71.605	71.844	37.586	39.726	29.493	56.612
743.00A	.60870E-01	1.0810	71.051	71.942	31.188	32.197	28.429	55.483
885.50A	.47906E-01	1.0803	71.900	72.189	29.760	29.638	28.231	55.615
1109.50A	.71295E-01	1.1911	71.949	72.830	22.669	10.348	25.752	140.10
1212.00A	.65786E-01	1.1899	72.195	73.027	21.832	8.1335	25.644	140.37
1302.50A	.60581E-01	1.1889	72.097	73.421	21.635	7.5430	25.672	140.70
1390.50A	.53913E-01	1.1840	72.392	73.667	21.783	7.3954	25.845	141.55
1507.50A	.48625E-01	1.1829	72.490	73.963	21.635	7.3954	25.835	141.11
1606.50A	.41906E-01	1.1802	72.589	74.308	21.783	7.8383	25.065	140.91
1674.00A	.36519E-01	1.1789	72.687	74.702	22.128	8.1827	26.265	141.45
1856.50A	.30910E-01	1.1742	72.983	75.294	22.620	8.6256	26.420	141.35
1962.50A	.24383E-01	1.1729	73.021	75.934	23.359	9.4130	26.872	140.96
2190.00A	.71308E-01	1.2707	73.721	75.146	20.207	-4.5132	23.496	228.44
2272.50A	.65750E-01	1.2766	74.016	75.639	20.995	-4.3656	23.869	229.97
2306.50A	.60267E-01	1.2725	74.410	76.181	21.389	-3.9719	24.280	230.91
2450.00A	.54012E-01	1.2677	74.656	76.723	21.783	-3.4306	24.789	231.41
2550.50A	.48089E-01	1.2625	75.001	77.166	22.128	-2.7909	25.163	231.59
2634.00A	.41902E-01	1.2603	75.148	77.955	22.079	-2.3480	25.664	232.52
2729.00A	.36293E-01	1.2549	75.493	78.497	22.226	-1.8959	26.017	232.67
2830.50A	.30257E-01	1.2513	75.689	79.384	22.029	-1.6591	26.434	232.07
2940.50A	.23915E-01	1.2476	76.132	80.665	21.980	-1.1178	27.041	232.47
3099.50A	.18078E-01	1.2426	76.182	82.292	21.980	-.92096	28.037	232.27
3419.50A	.71522E-01	1.3743	78.298	80.370	14.890	-20.851	22.088	341.66
3525.00A	.66136E-01	1.3690	79.282	81.454	14.644	-21.195	22.348	343.32
3634.50A	.60069E-01	1.3642	79.528	82.439	14.742	-20.801	23.058	344.57
3745.50A	.54355E-01	1.3593	80.414	83.129	15.727	-19.916	23.366	346.09
3847.50A	.48197E-01	1.3524	81.103	84.312	16.071	-19.128	24.037	346.99
3952.00A	.42114E-01	1.3469	81.645	85.248	15.924	-16.390	24.622	345.83
4037.50A	.35897E-01	1.3423	81.940	86.135	15.973	-17.898	25.540	346.71
4116.50A	.30200E-01	1.3337	82.137	87.515	16.465	-17.209	26.520	346.06
4221.50A	.23947E-01	1.3276	82.383	89.043	16.859	-16.077	27.584	347.22
4321.50A	.18523E-01	1.3199	82.924	91.704	16.662	-15.684	28.838	346.66
4495.00A	.12455E-01	1.3144	83.072	96.090	17.352	-14.355	30.269	347.56

SECTION A2

TEST 84L012 TEST DATE 27 MAR 1984 PUMP CALIBRATION TEST FACILITY PROCESS DATE 9 NOV 1984 PAGE 11  
 TEST 84L014, 3-26-1984 LOW THRUST PUMP HQ & CAV TESTS

TIME	18	19	20	21	34	36	37
	VOLUME P	VOLUME P	VOLUME P	VOLUME P	FRONT WK	REAR WK	REAR WK
	RESS UDC	RESS 90C	RESS 180C	RESS 270D	R (PSIG)	R (PSIG)	R (PSIG)
	G(PSIG)	EG(PSIG)	EG(PSIG)	EG(PSIG)	R (PSIG)	R (PSIG)	R (PSIG)
21.50A	33.771	34.145	32.789	35.309	35.153	35.360	32.558
532.00A	55.255	53.353	52.385	55.828	47.708	47.753	27.710
743.00A	54.208	52.060	51.054	54.592	46.859	46.636	26.664
895.50A	54.617	52.224	51.119	54.719	47.365	46.960	26.498
1109.50A	132.28	122.62	122.98	128.87	93.441	93.394	29.404
1212.00A	133.00	122.74	123.13	129.17	94.290	93.782	29.487
1302.50A	133.90	122.72	123.18	129.30	95.171	94.106	29.520
1390.50A	135.32	123.26	123.65	130.07	96.690	95.077	29.802
1507.50A	135.47	122.82	123.29	129.68	97.180	95.222	29.835
1606.50A	136.38	122.82	123.39	130.03	98.404	95.934	30.167
1694.00A	137.43	123.36	123.77	130.58	99.776	96.856	30.549
1856.50A	137.84	123.41	124.11	130.99	100.92	97.568	30.732
1962.50A	138.18	123.34	124.16	131.06	101.96	98.442	31.296
2190.00A	213.69	195.23	197.19	205.07	138.88	139.97	34.218
2272.50A	216.11	196.18	198.34	206.56	141.82	141.38	34.683
2360.50A	218.10	196.69	198.90	207.40	143.50	142.58	35.264
2450.00A	219.74	196.97	199.54	208.12	145.67	143.76	35.995
2550.50A	221.01	196.71	199.39	208.44	147.99	144.78	36.476
2634.00A	223.56	197.93	200.59	209.80	150.72	146.69	37.190
2729.00A	224.80	198.11	200.98	210.34	152.51	147.59	37.672
2830.50A	225.51	197.80	201.03	210.75	154.81	148.92	38.203
2946.50A	227.04	198.59	202.02	211.85	157.69	150.88	39.133
3059.50A	228.06	198.87	202.46	212.80	160.04	152.69	40.312
3419.50A	317.85	287.92	293.01	302.73	197.22	198.75	40.876
3525.00A	321.32	288.67	294.31	304.22	200.32	200.24	41.225
3634.50A	324.02	289.24	294.63	305.20	203.60	202.10	42.188
3745.50A	327.22	289.73	295.40	306.04	206.67	203.49	42.985
3847.50A	330.20	290.45	296.61	307.79	210.96	205.97	44.014
3922.00A	331.31	289.49	296.09	307.29	213.61	206.83	44.662
4037.50A	334.09	290.57	297.39	309.12	217.97	209.67	45.824
4116.50A	335.49	290.55	298.01	310.50	221.17	211.78	47.036
4221.50A	338.62	292.64	299.72	312.13	225.27	214.17	48.580
4321.50A	339.48	292.60	300.12	313.14	228.43	216.84	50.124
4495.00A	341.67	294.28	301.86	315.23	232.19	219.82	52.033

SECTION A2

SI 2014 10/10/80  
 10/10/80

ORIGINAL PAGE #15  
OF POOR QUALITY

TEST 84L012 PUMP CALIBRATION TEST FACILITY TEST DATE 27 MAR 1984 PROCESS DATE 9 NOV 1984 PAGE 13  
TEST 84L012, 3-26-1984, LOW THRUST PUMP HQ & CAV TESTS

TIME	38 IMP FR T IP PR (PSIG)	35 IMP FR M ID PR (PSIG)	40 IMP REAR TIP PK (PSIG)	110 TURB IN STATIC P R (PSIG)	111 TURB NOZ IN PR (PSIG)	114 NOZ OR OUT T TIP PR (PSIG)
21.50A	34.651	34.294	35.601	10635E-01	11323E-01	15741E-01
532.00A	51.818	47.799	52.979	2.4018	2.3641	1.0986
743.00A	50.664	46.851	51.321	2.4590	2.4143	1.1301
885.50A	50.875	47.227	51.937	2.4149	2.3722	1.0734
1109.50A	115.00	97.307	116.45	6.1119	6.0414	2.6410
1212.00A	115.35	97.863	116.80	6.0286	5.9572	2.6158
1362.50A	115.55	98.451	116.95	5.9697	5.8924	2.5655
1390.50A	116.34	99.596	117.74	5.8259	5.7451	2.5088
1507.50A	116.44	99.556	117.71	5.7589	5.7014	2.4962
1606.50A	116.60	100.87	118.16	5.6314	5.5702	2.4396
1694.00A	117.44	101.85	118.90	5.5334	5.4892	2.3577
1856.50A	117.64	102.65	119.35	5.4026	5.3338	2.3074
1962.50A	117.95	103.50	119.96	5.3241	5.2674	2.2885
2190.00A	181.43	149.40	182.90	9.5720	9.4564	4.1205
2272.50A	183.03	150.25	184.20	9.3955	9.2945	4.0198
2366.50A	183.99	151.80	185.02	9.2255	9.1277	3.9568
2450.00A	184.78	153.37	186.08	9.0327	8.9269	3.8498
2590.50A	185.67	155.09	186.96	8.8038	8.7002	3.7491
2634.00A	187.02	157.29	188.75	8.6257	8.5480	3.6924
2729.00A	187.32	158.28	188.99	8.4361	8.3456	3.5917
2830.50A	187.88	159.78	190.00	8.2318	8.1529	3.4784
2940.50A	189.23	161.92	191.59	8.0259	7.9602	3.4217
3059.50A	190.12	164.10	193.20	7.8542	7.7756	3.3273
3419.50A	267.04	214.13	267.35	14.493	14.366	6.2862
3555.00A	258.80	216.02	269.07	14.163	14.042	6.0910
3634.50A	270.05	218.79	270.52	13.820	13.707	5.9148
3745.50A	270.75	220.21	271.00	13.500	13.393	5.7700
3847.50A	273.45	223.97	274.07	13.178	13.066	5.6252
3952.00A	273.50	225.25	274.30	12.777	12.672	5.4426
4037.50A	274.65	228.35	276.40	12.439	12.347	5.2600
4116.50A	275.87	230.58	278.17	12.156	12.041	5.1404
4221.50A	277.70	234.01	280.31	11.769	11.676	4.9641
4321.50A	278.91	236.41	282.24	11.419	11.306	4.8004
4495.00A	280.90	239.68	285.14	11.195	10.985	4.6305

SECTION A2



TEST 84L010 TEST DATE 15 MAR 1984 PUMP CALIBRATION TEST FACILITY PROCESS DATE 9 NOV 1984 PAGE 0  
 TEST 84L010 3-14-84 LOW THRUST PUMP H-Q & CAV TESTS

C	DESCRIPTION	CONSTANT
1	WALL DIAMETER AT INLET PRESS TAP, IN.	1.00000E+00
2	HUB DIAMETER AT INLET PRESS TAP, IN	0.0
5	IMPELLER INLET TIP DIAMETER, IN	8.05000E-01
6	IMPELLER INLET HUB DIAMETER, IN	5.00000E-01
7	IMPELLER DISH TIP DIAMETER, IN	2.00000E+00
9	INLET AREA AT PRESS TAP, SQ. IN	7.85000E-01
10	IND/IMP INLET AREA, SQ. IN.	3.12608E-01
11	DESIGN FLOW, GPM	2.00000E+00
12	AMBIENT PRESSURE, PSIA	1.43470E+01
13	DESIGN SPEED FOR DESIGN FLOW, RPM	3.92000E+04
19	PUMP DISCHARGE LINE DIAMETER, IN.	5.00000E-01
21	HEAD ELEVATION (FT) CORRECTION FCR F(7)	0.0
23	K FACTOR	0.0
24	WATER TANK ELEVATION, FT	1.34271E+01
91	NOZZLE INLET DIAMETER, IN	1.00000E+00
92	NOZZLE THROAT DIAMETER, IN	1.91000E-01
93	NOZZLE DISCH COEFF	9.85000E-01
94	SPEC. HT. RATIO	1.40000E+00
95	MWT OF GAS	2.80160E+01
96	TURE MEAN DIAMETER, IN	2.40000E+00
97	TURB NOZ AREA, IN2	5.54000E-01
98	TURB PIPE IN DIAMETER, IN	1.61000E+00

TIME	SHAFT SP EED (RPM)	-16 FLOW/ DES FLOW	3 PUMP DIS FLOW (GPM)	-21 PUMP TOT HEADRISE (FT)	-3 INLET VELOCITY (FPS)
21.58A	4.8004	-1.1253	.58795E-04	-1.0456	.24028E-04
12091.58A	11742.	1.2454	.74605	96.019	.30490
12229.58A	11688.	.87318	.52069	155.12	.21280
12337.58A	11643.	.64504	.38317	177.10	.15659
12649.58A	23391.	1.2101	1.4441	395.91	.59018
12790.58A	23388.	1.0556	1.2596	559.10	.51478
12899.58A	23392.	.88527	1.0566	641.25	.43179
12998.58A	23401.	.71702	.85606	698.80	.34985
13095.58A	23388.	.54825	.65422	746.74	.26736
13219.58A	23361.	.35799	.42668	778.23	.17437
13858.58A	28971.	1.2676	1.8736	896.16	.76571
14018.58A	28996.	1.1574	1.7122	1056.3	.69975
14153.58A	28979.	1.0256	1.5163	1110.7	.61969
14443.58A	28981.	.89488	1.3232	1190.6	.54076
14558.58A	28971.	.76415	1.1295	1253.2	.46161
14676.58A	28974.	.62161	.91891	1309.9	.37554
14846.58A	28974.	.50178	.74176	1339.5	.30314
15756.58A	28967.	1.0770	1.5916	1048.3	.65047
16291.58A	28944.	.87475	1.2918	1175.3	.52793
16623.58A	11713.	1.2090	.72253	48.833	.29528
17664.00A	11685.	1.1739	.65933	78.926	.28600
17986.00A	11704.	1.0370	.61924	131.62	.25307

SECTION A3

TEST 84L010 TEST DATE 15 MAR 1984 PUMP CALIBRATION TEST FACILITY PROCESS DATE 9 NOV 1984 PAGE 4  
 TEST 84L010 3-14-84 LOW THRUST PUMP H-Q & CAV TESTS

TIME	-17 PUMP STA DELTA HEAD FT	-18 PUMP DIS VELOCITY (FPS)	-9 IND IN VELOCITY (FPS)	-15 IMPELLER IN FLOW COEF	-21 PUMP TOT HEADRISE (FT)	-22 PUMP INL FLOW COEF	-23 PUMP DIS HEAD COEF
21.58A	-1.0456	.96065E-04	.60338E-04	-.15656E-02	-1.0456	-.66799E-02	-2.4654
12091.58A	95.990	1.2190	.76563	.18565E-01	96.019	.73929E-02	.29427
12229.58A	155.11	.85075	.53436	.13016E-01	155.12	.51834E-02	.47993
12337.58A	177.09	.62605	.39323	.96155E-02	177.10	.38291E-02	.55197
12649.58A	395.80	2.3595	1.4820	.18038E-01	395.91	.71832E-02	.30572
12790.58A	559.02	2.0581	1.2927	.15736E-01	559.10	.62663E-02	.43186
12899.58A	641.19	1.7263	1.0843	.13196E-01	641.25	.52552E-02	.49516
12998.58A	698.77	1.3987	.87853	.10688E-01	698.80	.42564E-02	.53920
13095.58A	746.71	1.0689	.67139	.81727E-02	746.74	.32546E-02	.57682
13219.58A	778.22	.69714	.43789	.53365E-02	778.23	.21251E-02	.60260
13858.58A	895.98	3.0613	1.9228	.18895E-01	896.16	.75246E-02	.45109
14018.58A	1056.1	2.7976	1.7572	.17253E-01	1056.3	.68705E-02	.53077
14153.58A	1110.5	2.4775	1.5561	.15288E-01	1110.7	.60881E-02	.55876
14443.58A	1190.5	2.1619	1.3579	.13340E-01	1190.6	.53122E-02	.59890
14558.58A	1253.1	1.8455	1.1592	.11391E-01	1253.2	.45362E-02	.63079
14676.58A	1309.8	1.5014	.94303	.92662E-02	1309.9	.36900E-02	.65919
14846.58A	1339.5	1.2120	.76123	.74798E-02	1339.5	.29787E-02	.67413
15756.58A	1048.2	2.6005	1.6334	.16054E-01	1048.3	.63931E-02	.52783
16291.58A	1175.2	2.1107	1.3257	.13040E-01	1175.3	.51927E-02	.59257
16823.58A	48.805	1.1805	.74150	.18023E-01	48.833	.71772E-02	.15033
17664.00A	78.900	1.1434	.71820	.17499E-01	78.926	.69686E-02	.24416
17986.00A	131.60	1.0118	.63550	.15458E-01	131.62	.61558E-02	.40596

SECTION A3

ORIGINAL PAGE IS  
OF POOR QUALITY

TEST 84L010	TEST 84L010	TEST 84L010	TEST DATE 15 MAR 1984	PROCESS DATE 9 NOV 1984	PAGE 5		
TEST 84L010	TEST 84L010	TEST 84L010	3-14-84 LOW THRUST PUMP H-C & CAV TESTS				
TIME	-101 NOZZLE FLOWRATE (LB/SEC)	-102 NOZZLE PR RATIO	-103 FLOW PARAM	-104 TURB AVL ENERGY, BTU/LBM	-105 CSURO ISEN VEL FT/S	-106 TURBINE MEAN VEL FT/S	-107 TURB AVL ENER PIP BTU/LBM
21.58A	.93901E-02	.58372	.20301	-.31983E-01	32.608	.50269E-01	.88081E-02
12091.58A	.16027	.77616E-01	2.5637	4.4906	474.18	122.96	4.8304
12229.58A	.15704	.78455E-01	2.5246	4.2460	463.79	122.40	4.6225
12337.58A	.15622	.78652E-01	2.5175	4.2184	459.60	121.92	4.5713
12649.58A	.27255	.62144E-01	3.1515	9.0795	674.27	244.95	9.5424
12790.58A	.26680	.62594E-01	3.1302	8.9818	670.62	244.92	9.4393
12899.58A	.26114	.63375E-01	3.1102	8.8132	664.31	244.96	9.2885
12998.58A	.25586	.63522E-01	3.0844	8.6662	658.74	245.05	9.0827
13095.58A	.25152	.63943E-01	3.0651	8.5377	653.84	244.92	8.9717
13219.58A	.24551	.64432E-01	3.0447	8.3223	645.53	244.63	8.7626
13858.58A	.39394	.58193E-01	3.3414	12.186	781.14	303.39	12.689
14018.58A	.39306	.58246E-01	3.3356	12.233	782.66	303.65	12.742
14153.58A	.37724	.58502E-01	3.3211	11.996	775.02	303.47	12.489
14443.58A	.37163	.58725E-01	3.3144	11.862	770.70	303.49	12.346
14558.58A	.36472	.58958E-01	3.3020	11.747	766.93	303.39	12.222
14676.58A	.35751	.59222E-01	3.2895	11.540	760.15	303.42	12.019
14846.58A	.35308	.59655E-01	3.2674	11.310	752.54	303.42	11.792
15756.58A	.38323	.58524E-01	3.3239	11.943	773.33	303.34	12.430
16291.58A	.36995	.58337E-01	3.3060	11.663	764.15	303.10	12.139
16823.58A	.15158	.80183E-01	2.4679	4.0910	452.50	122.66	4.3972
17664.00A	.15143	.80430E-01	2.4629	4.0587	450.71	122.36	4.3605
17986.00A	.14964	.81003E-01	2.4450	4.0173	448.37	122.57	4.3157

SECTION A3

TEST 84L010 TEST DATE 15 MAR 1984 PROCESS DATE 9 NOV 1984  
 TEST 84L010 3-14-84 LOW THRUST PUMP H-G & CAV TESTS

TIME	-6		14		105		106		1		8		-2		-3	
	AMBIENT PRESS (PSIA)	PUMP ET TEMP (F)	PUMP INLET TEMP (F)	PUMP OUTLET TEMP (F)	TURBINE INLET MP (F)	TURBINE OUTLET EMP (F)	TURBINE INLET MP (F)	TURBINE OUTLET EMP (F)	PUMP ET PRESS (PSIG)	PUMP INLET PRESS (PSIG)	PUMP DIS PRESS (PSIG)	VAPOR HEAD (FT)	VAPOR HEAD (FT)	INLET VELOCITY (FPS)	INLET VELOCITY (FPS)	
21.58A	14.347	75.734	76.765	76.384	76.364	74.308	35.123	34.671	35.123	34.671	1.0190	1.0190	30430			
12091.58A	14.347	74.552	76.421	33.651	29.068	29.068	33.329	74.822	33.329	74.822	.97935	.97935	.21290			
12229.58A	14.347	74.798	76.756	28.131	21.725	21.725	34.052	101.10	34.052	101.10	.98750	.98750	.15659			
12337.58A	14.347	74.745	77.702	26.948	19.803	19.803	34.448	110.99	34.448	110.99	.98587	.98587	.59318			
12649.58A	14.347	74.955	79.574	26.751	-4.9364	-4.9364	31.903	202.98	31.903	202.98	.99406	.99406	.51478			
12790.58A	14.347	75.291	79.968	28.180	-3.2608	-3.2608	32.382	274.00	32.382	274.00	1.0039	1.0039	.43175			
12899.58A	14.347	75.291	80.757	28.328	-2.6594	-2.6594	32.941	310.07	32.941	310.07	1.0089	1.0089	.34935			
12998.58A	14.347	75.439	81.939	28.624	-1.9795	-1.9795	33.507	335.52	33.507	335.52	1.0039	1.0039	.26736			
13095.58A	14.347	75.291	83.762	28.624	-1.4374	-1.4374	34.080	356.82	34.080	356.82	1.0023	1.0023	.17437			
13219.58A	14.347	75.242	87.655	27.983	-1.2896	-1.2896	34.785	418.47	34.785	418.47	1.0273	1.0273	.76571			
13858.58A	14.347	75.981	83.220	23.359	-24.895	-24.895	31.250	488.03	31.250	488.03	1.0341	1.0341	.65975			
14018.58A	14.347	76.178	83.959	24.237	-24.403	-24.403	31.612	512.13	31.612	512.13	1.0342	1.0342	.61969			
14153.58A	14.347	76.178	84.630	24.779	-22.727	-22.727	32.202	547.07	32.202	547.07	1.0324	1.0324	.54376			
14443.58A	14.347	76.129	85.388	25.026	-22.037	-22.037	32.584	574.66	32.584	574.66	1.0206	1.0206	.46161			
14558.58A	14.347	75.784	86.867	24.829	-21.495	-21.495	33.093	599.89	33.093	599.89	1.0290	1.0290	.37554			
14676.58A	14.347	76.030	88.936	24.237	-21.446	-21.446	33.830	613.25	33.830	613.25	1.0342	1.0342	.30314			
14846.58A	14.347	76.178	92.188	23.054	-21.495	-21.495	34.367	444.17	34.367	444.17	1.0847	1.0847	.65347			
15756.58A	14.347	77.613	85.920	20.454	-26.965	-26.965	-8.7104	508.84	-8.7104	508.84	1.0787	1.0787	.52793			
16291.58A	14.347	77.446	87.000	19.289	-26.807	-26.807	1.059R	16.924	1.059R	16.924	1.0903	1.0903	.29528			
16823.58A	14.347	77.767	79.421	27.321	16.374	16.374	-4.1640	30.043	-4.1640	30.043	1.0923	1.0923	.28600			
17664.00A	14.347	77.824	79.395	25.654	17.643	17.643	-4.0471	52.806	-4.0471	52.806	1.0917	1.0917	.25307			
17986.00A	14.347	77.805	79.529	26.221	18.283	18.283	-4.0517		-4.0517							

SECTION A 3

PUMP CALIBRATION TEST FACILITY  
 TEST DATE 15 MAR 1984 PROCESS DATE 9 NOV 1984 PAGE 7  
 TEST 84L010 3-14-84 LOW THRUST PUMP H-C & CAV TESTS

TIME	18 VOLUTE P RESS ODE G (PSIG)	19 VOLUTE P RESS 900 EG (PSIG)	20 VOLUTE P RES 1300 EG (PSIG)	21 VOLUTE P RES 2700 EG (PSIG)	26 DIFF INCL ET O DEG (PSIG)	34 FRONT MR RING UP R (PSIG)	36 REAR MR RING UP R (PSIG)	37 REAR MR RING UP R (PSIG)
21.58A	34.691	35.406	34.120	35.557	34.237	35.462	35.710	34.635
12091.58A	73.076	74.086	67.887	70.514	92.764	75.609	79.612	35.530
12229.58A	99.732	101.08	97.077	99.283	95.203	76.309	80.612	36.458
12337.58A	110.08	111.35	108.51	110.32	96.850	76.651	81.032	36.955
12649.58A	197.32	197.62	176.93	182.36	276.92	190.77	206.26	45.011
12790.58A	268.38	268.62	254.21	256.31	280.28	191.22	206.94	45.525
12899.58A	305.17	305.62	294.31	295.41	284.17	191.88	208.17	46.403
12998.58A	331.73	332.11	325.05	324.29	289.13	193.18	210.06	47.066
13095.58A	353.42	353.70	348.56	347.34	292.47	194.08	211.03	47.862
13213.58A	368.37	368.80	365.43	364.45	297.70	195.17	212.48	48.873
13858.58A	408.30	406.70	376.12	379.51	481.75	312.64	341.62	55.835
14018.58A	478.30	476.74	450.61	450.29	494.08	319.24	349.06	57.095
14153.58A	503.83	502.18	480.34	478.28	485.25	311.04	340.60	57.177
14443.58A	539.38	537.72	520.30	516.02	490.93	312.79	343.33	57.907
14558.58A	568.32	566.80	553.21	547.61	496.62	315.28	346.09	59.133
14676.58A	594.10	591.75	581.42	574.88	501.50	315.41	347.09	59.780
14846.58A	608.94	607.23	600.89	592.95	502.72	315.46	347.20	60.758
15756.58A	435.72	434.69	410.43	411.05	428.24	260.48	288.28	15.499
16291.58A	501.47	500.52	482.95	480.01	449.46	275.07	304.61	25.732
16823.58A	15.289	15.697	12.169	9.3847	55.719	37.445	41.061	3.6679
17664.00A	28.473	29.326	25.393	25.106	55.503	37.282	40.908	3.5806
17986.00A	51.423	52.705	47.002	49.505	56.280	37.500	41.279	3.2291

SECTION A3

TEST 84L010 TEST DATE 15 MAR 1984 PUMP CALIBRATION TEST FACILITY PROCESS DATE 9 NOV 1984 PAGE 8  
 TEST 84L010 3-14-84 LOW THRUST PUMP H-C & CAV TESTS

TIME	38 IMP FR T ID PR (PSIG)	40 IMP REAR TIP PR (PSIG)	110 TURB IN STATIC P R (PSIG)	114 ROTOR OU T TIP PR (PSIG)	115 ROTOR CU T HUR PR (PSIG)
21.58A	35.265	35.932	.23725E-01	.22049E-01	.25629E-01
12091.58A	94.264	92.671	4.3151	1.8677	1.9735
12229.58A	95.152	93.711	4.1172	1.7669	1.9095
12337.58A	95.448	94.190	4.0665	1.7984	1.8774
12649.58A	274.80	263.60	11.306	4.7717	5.2030
12790.58A	275.93	265.78	10.971	4.6205	5.0364
12899.58A	277.13	266.75	10.615	4.4567	4.8826
12998.58A	279.37	269.46	10.279	4.2929	4.7160
13095.58A	279.96	270.47	9.9981	4.1544	4.5494
13219.58A	281.69	272.73	9.5991	3.9843	4.3572
13858.58A	472.04	448.34	20.520	8.8851	9.7204
14018.58A	482.70	458.65	20.458	8.8788	9.6691
14153.58A	470.83	448.61	19.286	8.3182	9.0732
14443.58A	474.28	452.19	18.852	8.0851	8.8361
14558.58A	477.93	455.91	18.344	7.8331	8.5798
14676.58A	479.15	457.57	17.806	7.6316	8.3171
14846.58A	477.70	456.76	17.591	7.6693	8.2786
15756.58A	416.85	395.02	19.635	8.4414	9.2049
16291.58A	433.50	412.09	18.587	7.9568	8.6792
16823.58A	55.996	54.197	3.8604	1.6679	1.7671
17664.00A	55.689	53.319	3.8452	1.6694	1.7504
17986.00A	56.151	54.426	3.7724	1.6356	1.7321

SECTION A3

TEST 84L009      TEST DATE 10 MAR 1984      PUMP CALIBRATION TEST FACILITY      PROCESS DATE 9 NOV 1984      PAGE 0  
 TEST 84L009, 3-9-1984 LOW THRUST PUMP H-Q & CAV TESTS

C	DESCRIPTION	CONSTANT
1	HALL DIAMETER AT INLET PRESS TAP, IN.	1.00000E+00
2	HUB DIAMETER AT INLET PRESS TAP, IN	0.0
5	IMPELLER INLET TIP DIAMETER, IN	8.05000E-01
6	IMPELLER INLET HUB DIAMETER, IN	5.00000E-01
7	IMPELLER DISC TIP DIAMETER, IN	2.00000E+00
9	INLET AREA AT PRESS TAP, SQ. IN	7.85000E-01
10	IND/IMP INLET AREA, SQ. IN.	3.12608E-01
11	DESIGN FLOW, GPM	5.00000E+00
12	AMBIENT PRESSURE, PSIA	1.43960E+01
13	DESIGN SPEED FOR DESIGN FLOW, RPM	2.45000E+04
19	PUMP DISCHARGE LINE DIAMETER, IN.	5.00000E-01
21	HEAD ELEVATION (FT) CORRECTION FOR F(7)	0.0
23	K FACTOR	0.0
24	WATER TANK ELEVATION, FT	1.34271E+01
91	NOZZLE INLET DIAMETER, IN	1.00000E+00
92	NOZZLE THROAT DIAMETER, IN	1.91000E-01
93	NOZZLE DISCH COEFF	9.85000E-01
94	SPEC. HT. RATIO	1.40000E+00
95	MMT OF GAS	2.80160E+01
96	TURB MEAN DIAMETER, IN	2.40000E+00
97	TURB NOZ AREA, IN2	5.54000E-01
98	TURB PIPE IN DIAMETER, IN	1.61000E+00

SECTION A4



TEST 84L009		TEST DATE 10 MAR 1984		PUMP CALIBRATION TEST FACILITY		TEST 84L009, 3-9-1984 LOW THRUST PUMP H-U & CAV TESTS		9 NOV 1984		PAGE 1	
TIME	SHAFT SP EED (RPM)	-16 FLOW/ DES FLOW	3 PUMP DIS FLOW (CPM)	-21 PUMP TUT HEADRISE (FT)	-3 INLET VELOCITY (FPS)						
21.50A	-95927	1.5321	.29944E-03	.65010E-01	.12258E-03						
941.00A	-2.0778	.0	.0	-1.8766	.0						
1490.00A	7419.0	1.1752	1.7786	35.742	.72689						
1657.00A	7351.5	1.0391	1.5591	36.824	.63717						
1782.00A	7302.0	.81476	1.2142	38.451	.49620						
2011.00A	14716.	1.1530	3.5831	148.94	1.4643						
2090.50A	14703.	1.0594	3.2987	151.90	1.3481						
2172.50A	14681.	.99591	2.9838	155.77	1.2194						
2271.50A	14684.	.88611	2.6334	160.33	1.0852						
2343.00A	14676.	.79416	2.3818	163.73	.97340						
2427.00A	14676.	.68709	2.0579	167.79	.84101						
2540.50A	14685.	.57629	1.7271	172.40	.70581						
2624.00A	14690.	.48552	1.4586	175.10	.59610						
2715.00A	14677.	.38565	1.1551	177.77	.47205						
3202.00A	19553.	1.2144	4.7963	257.89	1.9602						
3303.00A	19338.	1.1181	4.4124	265.25	1.8033						
3429.00A	19365.	1.0195	4.0291	273.81	1.6466						
3515.00A	19338.	.91764	3.6215	280.31	1.4800						
3601.50A	19376.	.81002	3.2031	288.39	1.3090						
3913.50A	19415.	.68480	2.7133	297.05	1.1088						
4097.50A	19509.	.57541	2.2744	303.83	.92952						
4199.00A	19404.	.46892	1.8565	309.11	.75889						
4307.00A	19404.	.37417	1.4817	313.38	.60554						
4354.00A	19400.	.26993	1.1479	317.66	.46911						
4430.00A	24564.	1.1983	6.0072	420.67	2.4550						
4976.50A	24525.	1.0985	5.4991	433.15	2.2474						
5070.00A	24497.	1.0025	5.0120	443.88	2.0483						
5211.00A	24508.	.90791	4.5411	455.20	1.8558						
5350.00A	24511.	.80275	4.0141	467.22	1.6405						
5578.00A	24558.	.69086	3.4625	478.56	1.4151						
5695.00A	24527.	.58645	2.9454	489.36	1.2037						
5799.50A	24550.	.47235	2.3665	499.24	.96715						
5905.50A	24499.	.36534	1.8260	509.30	.74651						
6067.00A	24524.	.27336	1.3881	513.98	.56730						

SECTION A4

ORIGINAL PAGE 'S  
OF POOR QUALITY

TEST 84L009	TEST DATE 10 MAR 1984	PUMP CALIBRATION TEST FACILITY	PROCESS DATE 9 NOV 1984	PAGE 7				
TEST 84L009	TEST 84L009	3-9-1984 LOW THRU S1 PUMP H-W & CAV TESTS						
TIME	-17 PUMP STA DELTA	-18 PUMP DIS VELOCITY (FPS)	-1 WATER SP. WGT. LBM/FT <sup>3</sup>	-2 VAPOR HEAD (FT)	-21 PUMP TOT HEADRISE (FT)	-22 PUMP INL FLOW COEF	-23 PUMP DIS HEAD COEF	-6 AMBIENT PRESS (PSIA)
	HLAU FT							
21.50A	.65019E-01	.49007E-03	62.422	.20469	.65010E-01	.36380E-01	50929	14.396
44.00A	-1.8766	.0	62.221	1.0732	-1.8766	.0	-.60745E+06	14.396
1490.00A	35.576	2.5061	62.290	.80193	35.742	.27904E-01	.28033	14.396
1657.00A	36.697	2.5474	62.283	.82952	36.824	.24674E-01	.28784	14.396
1762.00A	38.374	1.9838	62.280	.84080	38.451	.19347E-01	.30467	14.396
2011.00A	148.26	5.8543	62.275	.85793	148.94	.28329E-01	.29055	14.396
2090.50A	151.33	5.3898	62.274	.86376	151.90	.26105E-01	.29687	14.396
2172.50A	155.30	4.8752	62.274	.86231	155.77	.23648E-01	.30535	14.396
2271.50A	159.56	4.3386	62.273	.86809	160.33	.21041E-01	.31417	14.396
2343.00A	163.43	3.8916	62.272	.86954	163.73	.18857E-01	.32031	14.396
2427.00A	167.57	3.3624	62.271	.87396	167.79	.16315E-01	.32914	14.396
2546.50A	172.24	2.8218	62.272	.87103	172.40	.13684E-01	.33781	14.396
2624.00A	174.55	2.3832	62.270	.87072	175.10	.11553E-01	.34281	14.396
2713.00A	177.70	1.8872	62.270	.87692	177.77	.91568E-02	.34868	14.396
3202.00A	256.65	7.8367	62.269	.88281	257.89	.28835E-01	.29094	14.396
3308.00A	264.23	7.2074	62.267	.89874	265.25	.26548E-01	.29970	14.396
3429.00A	272.56	6.5851	62.267	.89171	273.81	.24208E-01	.30852	14.396
3519.00A	279.63	5.9171	62.267	.89022	280.31	.21789E-01	.31670	14.396
3661.50A	287.85	5.2334	62.265	.89617	288.39	.19234E-01	.32461	14.396
3913.50A	296.67	4.4331	62.266	.89320	297.05	.16261E-01	.33299	14.396
4097.50A	303.56	3.7162	62.265	.89520	303.83	.13663E-01	.34219	14.396
4199.00A	308.93	3.0340	62.264	.90067	309.11	.11134E-01	.34686	14.396
4304.00A	313.27	2.4209	62.264	.90217	313.38	.88846E-02	.35168	14.396
4554.00A	317.55	1.8755	62.264	.90221	317.66	.68843E-02	.35661	14.396
4334.00A	418.76	9.8151	62.262	.90823	420.67	.28454E-01	.29454	14.396
4976.50A	431.57	8.9849	62.261	.91127	433.15	.26085E-01	.30417	14.396
5070.00A	442.56	8.1890	62.260	.91735	443.88	.23805E-01	.31252	14.396
5211.00A	454.12	7.4196	62.260	.91894	455.20	.21558E-01	.32017	14.396
5398.00A	466.37	6.5586	62.258	.92507	467.22	.19054E-01	.32856	14.396
5578.00A	477.93	5.6573	62.257	.92812	478.56	.16404E-01	.33525	14.396
5693.00A	488.90	4.8125	62.258	.92658	489.36	.13973E-01	.34369	14.396
5799.50A	498.95	3.8666	62.258	.92661	499.24	.11216E-01	.34998	14.396
5903.50A	509.13	2.9815	62.258	.92507	509.30	.86751E-02	.35852	14.396
6067.00A	513.88	2.2680	62.259	.92197	513.98	.65858E-02	.36105	14.396

SECTION A4

TEST 84L009 PUMP CALIBRATION TEST FACILITY TEST DATE 10 MAR 1984 PROCESS DATE 9 NOV 1984 PAGE 9  
 TEST 84L009, 3-9-1984 LOW THRU PJ PUMP H-Q & CAV TESTS

TIME	-15 IMPELLER IN FLOW COEF	-101 NOZZLE FLOWRATE (LB/SEC)	-102 FLOW NOZZLE PR RATIO	-103 FLOW PARAM	-104 TURB AVL ENERGY, BTU/LBM	-105 CSUBO ISEN VEL FT/S	-106 TURBINE MEAN VEL FT/S	-107 TURB AVL ENER PIP BTU/LBM
21.50A	.91355E-01	.97301E-02	.98812	.20096	-.83917E-01	58.510	-.10045E-01	.21391E-02
941.00A	.0	.93255E-02	.39046	.20145	-.49067E-01	53.182	-.30136E-01	.10824E-01
1490.00A	.70071E-01	.13419	.86693E-01	2.2988	3.1814	398.98	77.692	3.4083
1657.00A	.61959E-01	.11735	.95386E-01	2.0816	2.5459	357.04	76.988	2.7182
1782.00A	.48582E-01	.11932	.94135E-01	2.1060	2.5942	360.40	76.466	2.7652
2011.00A	.71138E-01	.18585	.71808E-01	2.7445	5.4537	522.57	154.11	5.7610
2090.50A	.65552E-01	.18562	.71838E-01	2.7432	5.4487	524.25	153.97	5.8062
2172.50A	.59383E-01	.18523	.71912E-01	2.7414	5.4435	522.08	153.74	5.7731
2271.50A	.52836E-01	.18469	.72008E-01	2.7364	5.4236	521.13	153.77	5.7364
2343.00A	.47353E-01	.18370	.72155E-01	2.7294	5.3835	519.20	153.90	5.6864
2427.00A	.40969E-01	.18326	.72208E-01	2.7257	5.3903	519.52	153.69	5.7003
2546.50A	.34363E-01	.18199	.72544E-01	2.7178	5.3513	517.64	153.78	5.6778
2624.00A	.29010E-01	.18241	.72424E-01	2.7206	5.3598	518.05	153.84	5.6820
2715.00A	.22994E-01	.18084	.72723E-01	2.7086	5.3116	515.72	153.70	5.6284
3202.00A	.72410E-01	.22453	.66124E-01	2.9669	7.2712	603.40	202.67	7.6205
3308.00A	.66666E-01	.22293	.66291E-01	2.9617	7.2104	600.87	202.51	7.5831
3429.00A	.60791E-01	.22167	.66447E-01	2.9540	7.1461	598.19	202.79	7.5095
3515.00A	.54716E-01	.22147	.66442E-01	2.9551	7.1726	599.29	202.51	7.5413
3601.50A	.48299E-01	.22052	.66504E-01	2.9476	7.1114	596.73	202.91	7.4687
3913.50A	.40832E-01	.21907	.66665E-01	2.9444	7.1241	597.26	203.31	7.4850
4097.50A	.34310E-01	.21918	.66815E-01	2.9392	7.1161	596.93	202.83	7.4782
4199.00A	.27960E-01	.21842	.66901E-01	2.9346	7.0663	594.83	203.20	7.4172
4304.00A	.22310E-01	.21768	.67051E-01	2.9284	7.0749	595.20	203.20	7.4220
4554.00A	.17287E-01	.21687	.67120E-01	2.9254	7.0384	593.66	203.16	7.3887
4838.00A	.71451E-01	.28149	.61664E-01	3.1671	9.3403	683.88	257.23	9.7271
4576.50A	.65503E-01	.27980	.61747E-01	3.1622	9.3085	682.72	256.86	9.6800
5070.00A	.59778E-01	.27735	.61888E-01	3.1562	9.2468	680.45	256.53	9.6292
5211.00A	.54136E-01	.27679	.61982E-01	3.1550	9.1903	678.37	256.65	9.5956
5358.00A	.47848E-01	.27522	.62067E-01	3.1460	9.1869	678.24	256.68	9.5517
5578.00A	.41194E-01	.27361	.62174E-01	3.1427	9.1539	677.02	257.17	9.5364
5695.00A	.35087E-01	.27261	.62230E-01	3.1390	9.0918	674.72	256.84	9.4646
5799.50A	.28165E-01	.27129	.62312E-01	3.1336	9.0351	672.61	257.08	9.3960
5905.50A	.21784E-01	.26910	.62495E-01	3.1282	8.9639	669.96	256.55	9.3617
6007.00A	.16538E-01	.26786	.62577E-01	3.1235	8.9324	671.02	256.81	9.3686

SECTION A4

TEST 84L009 TEST DATE 10 MAR 1984 PUMP CALIBRATION TEST FACILITY  
 TEST 84L009, 3-9-1984 LOW THRUST PUMP H-Q 4 GAY TESTS PROCESS DATE 9 NOV 1984

TIME	-3 INLET VELOCITY (FPS)	6 PUMP INL ET TEMP (F)	14 PUMP OUT LET TEMP (F)	105 TURBINE INLET TE MP (F)	106 TURBINE OUTLET T EMP (F)	1 PUMP INL ET PRESS (PSIG)	8 PUMP DIS. PRESS (PSIG)
21.50A	.12258E-03	32.084	31.828	31.975	32.025	.50598E-02	.33245E-01
941.00A	.0	77.291	78.266	79.558	76.690	35.246	34.435
1490.00A	.72689	68.673	69.155	33.353	36.161	33.634	49.027
1657.00A	.63717	69.658	69.894	28.087	29.562	33.701	49.575
1782.00A	.49020	70.052	70.387	27.152	27.445	34.057	50.656
2011.00A	1.4643	70.643	71.372	22.624	10.307	31.842	95.976
2090.50A	1.3481	70.840	71.519	22.723	9.0180	32.299	97.755
2172.50A	1.2194	70.791	71.962	22.427	9.1256	32.626	99.799
2271.50A	1.0852	70.988	72.110	22.821	9.1748	32.911	102.09
2343.00A	.97340	71.037	72.455	22.870	9.0763	33.089	103.77
2427.00A	.84101	71.184	72.652	23.067	9.2733	33.412	105.88
2546.50A	.70581	71.086	73.144	23.756	9.5195	33.670	108.16
2624.00A	.59610	71.283	73.735	23.805	9.8150	33.965	109.64
2715.00A	.47205	71.283	74.474	24.544	10.455	34.388	111.23
3202.00A	1.9602	71.480	72.750	25.331	2.1328	31.237	142.26
3308.00A	1.8033	71.677	72.947	25.676	2.6252	31.804	146.08
3429.00A	1.6466	71.776	73.144	25.626	2.5760	31.826	149.87
3515.00A	1.4800	71.720	73.508	26.365	3.2654	32.418	153.35
3661.50A	1.3090	71.923	73.883	26.315	3.2654	32.756	157.24
3913.50A	1.1088	71.825	74.375	26.463	3.6101	33.019	161.31
4097.50A	.92952	72.022	75.163	26.709	4.0533	33.402	164.66
4199.00A	.75889	72.071	75.951	26.315	3.7579	33.907	167.49
4304.00A	.60554	72.120	77.133	26.011	3.8563	34.376	169.83
4554.00A	.46911	72.120	78.561	26.463	4.0041	34.621	171.94
4838.00A	2.4550	72.317	74.228	25.725	-7.8148	30.004	211.11
4976.50A	2.2474	72.416	74.572	26.119	-7.4208	30.682	217.31
5070.00A	2.0483	72.613	74.720	26.512	-7.0269	31.157	222.53
5211.00A	1.8558	72.662	75.163	26.562	-7.0269	31.452	227.82
5358.00A	1.6405	72.859	75.410	26.168	-7.0761	31.880	233.53
5578.00A	1.4151	72.957	76.542	26.168	-6.7314	32.191	238.84
5695.00A	1.2037	72.908	76.986	25.873	-7.0761	32.736	244.12
5799.50A	.96715	72.908	78.414	25.823	-6.6299	33.582	249.31
5905.50A	.74651	72.859	80.236	25.626	-6.9284	34.234	254.36
6067.00A	.56730	72.760	82.452	26.020	-6.3867	34.570	256.75

SECTION A4

ORIGINAL PAGE IS  
OF POOR QUALITY

TEST 84LJ009 PUMP CALIBRATION TEST FACILITY TEST DATE 10 MAR 1984 PROCESS DATE 9 NOV 1984 PAGE 13  
TEST 84LJ009, 3-9-1984 LOW THRU PUMP H-Q & CAV TESTS

TIME	18	19	20	21	34	36	37	38
	VOLUME P	VOLUME P	VOLUME P	VOLUME P	FRONT WR	REAR WR	REAR WR	IMP FR I
	RESS OCL	RESS 900	RESS 180C	RESS 2700	KING UP	KING UP	RINT DP	IP PR
	(PSIG)	EG(PSIG)	EG(PSIG)	EG(PSIG)	R (PSIG)	R (PSIG)	R (PSIG)	(PSIG)
21.50A	.15901	.72633E-C1	.98223E-05	.23791E-01	.10625	.40540E-01	.14119	.10727
941.00A	34.482	35.179	33.860	35.329	35.290	35.071	34.527	34.887
1490.00A	47.924	48.108	47.099	48.947	34.544	41.513	33.929	46.760
1657.00A	48.497	48.419	47.395	45.264	34.708	41.789	34.128	47.139
1782.00A	49.772	49.270	48.118	50.247	35.132	42.582	34.593	48.096
2011.00A	90.656	88.663	88.600	91.497	35.459	60.243	35.141	84.063
2090.50A	92.831	90.087	89.988	93.066	36.079	61.052	35.756	85.563
2172.50A	95.350	91.609	91.353	94.984	36.602	62.153	36.487	87.212
2271.50A	97.770	93.050	92.718	96.791	37.124	63.545	37.168	89.125
2343.00A	100.12	94.113	94.050	98.266	37.631	64.937	37.816	90.758
2427.00A	107.50	95.554	95.513	100.07	38.121	66.523	38.513	92.572
2546.50A	105.03	97.207	97.174	102.20	38.578	68.142	39.277	94.815
2624.00A	106.55	98.303	98.523	103.04	39.035	69.567	39.709	96.431
2715.00A	108.84	99.514	99.622	105.42	39.786	70.959	40.424	98.327
3202.00A	132.65	128.24	129.29	133.30	37.255	77.531	36.802	120.66
3308.00A	130.50	131.12	131.92	136.23	38.251	79.085	37.915	123.48
3429.00A	141.45	133.60	134.54	139.40	39.002	80.720	38.978	126.26
3515.00A	145.65	135.93	136.81	142.58	39.802	83.116	40.224	129.46
3601.50A	149.95	138.48	139.45	145.90	40.619	85.787	41.321	132.96
3613.50A	154.91	141.23	142.38	149.42	41.435	88.603	42.433	136.85
4097.50A	159.01	143.51	145.24	152.82	42.138	91.274	43.546	140.73
4199.00A	162.63	145.58	147.43	155.61	43.036	93.654	44.527	143.81
4204.00A	165.90	147.55	149.62	158.33	44.015	95.856	45.523	146.78
4554.00A	168.58	149.19	151.80	160.90	44.848	97.733	46.487	149.63
4838.00A	195.07	166.52	169.23	164.80	40.243	102.04	39.676	174.80
4976.50A	202.40	190.72	193.79	199.88	41.631	104.86	41.453	179.64
5070.00A	208.95	194.06	196.91	204.31	42.742	107.69	43.148	184.23
5211.00A	215.11	197.55	200.43	208.68	43.689	110.42	44.443	188.52
5358.00A	221.70	201.03	204.35	213.84	44.685	114.16	46.088	193.69
5578.00A	228.11	204.44	208.13	218.35	45.518	117.77	47.433	198.86
5695.00A	234.76	208.32	212.67	223.43	46.824	121.72	49.277	204.33
5799.50A	241.65	212.23	216.94	228.59	48.196	125.82	50.988	210.22
5905.50A	247.72	215.80	221.10	233.45	49.943	129.51	52.766	215.64
6067.00A	251.58	217.71	223.32	236.95	51.249	132.29	54.211	219.68

SECTION A4

C-2

ORIGINAL PAGE 'S  
OF POOR QUALITY

TEST 84L009      TEST DATE 10 MAR 1984      PUMP CALIBRATION TEST FACILITY      PROCESS DATE 9 NOV 1984      PAGE 15  
TEST 64L009, 2-9-1984 LUM THRLST PUMP H-Q & GAV TESTS

TIME	39 IMP FR M ID PR	40 IMP REAK TIP PR (PSIG)	110 TURB IN STATIC P R (PSIM)	114 ROTOR QU I TIP PR (PSIG)	115 ROTOR GU I HUB PR (PSIG)	116 TURB NOZ OUT (PSIG)
21.50A	24890E-01	157.2	40096E-01	28366E-01	28829E-01	60472E-01
941.00A	33.916	35.562	33551E-01	22076E-01	22422E-01	28645E-01
1490.00A	38.478	47.667	2.9900	1.3719	1.4255	.84341
1657.00A	38.694	47.998	2.3077	1.0376	1.0860	.63428
1782.00A	39.241	48.776	2.3617	1.0818	1.1180	.67155
2011.00A	52.299	64.893	5.5570	2.4253	2.5403	1.7791
2090.50A	56.195	66.757	5.5333	2.4379	2.5595	1.7473
2172.50A	57.608	82.337	5.5227	2.3874	2.5403	1.7346
2271.50A	57.655	89.827	5.4998	2.3611	2.5659	1.7537
2343.00A	58.319	91.301	5.4352	2.3622	2.5339	1.7282
2427.00A	59.181	92.841	5.4278	2.3433	2.5339	1.7155
2546.50A	60.011	94.646	5.3705	2.3370	2.5019	1.6964
2624.00A	60.455	96.604	5.3951	2.3370	2.5403	1.7155
2715.00A	61.338	97.594	5.3247	2.3054	2.4762	1.7027
3202.00A	72.320	121.62	7.9628	3.4408	3.6551	2.6575
3308.00A	73.630	124.85	7.8689	3.3966	3.6103	2.6321
3429.00A	74.858	127.58	7.7936	3.3462	3.5590	2.6130
3519.50A	76.318	130.05	7.7954	3.3651	3.5782	2.6257
3661.50A	77.694	133.06	7.7412	3.3462	3.5654	2.6003
3913.50A	78.972	136.28	7.7052	3.3146	3.5334	2.5875
4097.50A	80.150	139.29	7.6807	3.2957	3.5206	2.5939
4199.00A	81.460	142.04	7.6218	3.2831	3.4885	2.5684
4304.00A	82.472	144.62	7.5989	3.2768	3.4949	2.5684
4554.00A	83.418	146.92	7.5384	3.2453	3.4629	2.5493
4638.00A	86.954	175.54	11.374	5.1123	5.5131	4.2998
4976.50A	99.260	180.90	11.756	5.0492	5.4426	4.2616
5070.00A	101.20	184.58	11.596	4.9546	5.3657	4.1725
5211.00A	102.88	188.21	11.575	4.9609	5.3657	4.1725
5358.00A	104.85	192.36	11.458	4.8978	5.3145	4.1534
5578.00A	106.58	196.64	11.349	4.8474	5.2376	4.0834
5695.00A	108.28	201.31	11.270	4.8032	5.1992	4.0579
5799.50A	110.41	206.01	11.180	4.7906	5.1671	4.0388
5905.50A	112.38	210.53	11.043	4.7623	5.0838	3.9561
6067.00A	113.78	213.41	10.958	4.6518	5.0454	3.9497

SECTION A4

TEST 84L011 TEST DATE 22 MAR 1984 PUMP CALIBRATION TEST FACILITY  
 TEST 84L011 3-21-84 LGW THRUST PUMP H-G & CAV TESTS PROCESS DATE 17 NOV 1984 PAGE 0

C	DESCRIPTION	CONSTANT
2	HUB DIAMETER AT INLET PRESS TAP, IN	0.0
5	IMPELLER INLET TIP DIAMETER, IN	8.05000E-01
6	IMPELLER INLET HUB DIAMETER, IN	5.00000E-01
7	IMPELLER DISH TIP DIAMETER, IN	2.00000E+00
9	INLET AREA AT PRESS TAP, SQ. IN	7.85000E-01
10	IND/IMP INLET AREA, SQ. IN.	3.12608E-01
11	DESIGN FLOW, GPM	2.00000E+00
12	AMBIENT PRESSURE, PSIA	1.42680E+01
13	DESIGN SPEED FOR DESIGN FLOW, RPM	3.92460E+04
19	PUMP DISCHARGE LINE DIAMETER, IN.	5.00000E-01
21	HEAD ELEVATION (FT) CORRECTION FOR F(7)	0.0
23	K FACTOR	0.0
24	WATER TANK ELEVATION, FT	0.0
51	NOZZLE INLET DIAMETER, IN	1.00000E+00
52	NOZZLE THROAT DIAMETER, IN	1.91000E-01
53	NOZZLE DISCH COEFF	9.85000E-01
54	SPEC. HT. RATIO	1.40000E+00
55	MNT OF GAS	2.80160E+01
96	TURB MEAN DIAMETER, IN	2.40000E+00
97	TURB NOZ AREA, IN <sup>2</sup>	5.54000E-01
98	TURB PIPE IN DIAMETER, IN	1.61000E+00

SECTION A5

TIME	SHAFT SP EED (RPM)	-16 DES FLOW	PUMP DIS FLOW (GPM)	-21 PUMP TOT HEADRISE (FT)	-3 INLET VELOCITY (FPS)	-15 IMPELLER IN FLOW COEF	TEST 84L011	TEST DATE 22 MAR 1984	PROCESS DATE 17 NOV 1984	PAGE 1
22.50A	8.1628	.31349	-.58819E-04	-.34505E-05	-.24038E-04	.0				
1598.50A	11571.	1.2357	.72685	34.608	.29776	.18399E-01				
1568.50A	11544.	.67546	.51502	46.054	.21048	.13035E-01				
1659.50A	11536.	.64410	.31873	52.041	.15476	.95901E-02				
2062.50A	23506.	1.2257	1.4682	152.27	.60004	.18250E-01				
2156.50A	23492.	1.0504	1.2575	180.23	.51391	.15640E-01				
2263.50A	23425.	.87119	1.0412	204.53	.42550	.12986E-01				
2366.50A	23415.	.72164	.86123	221.79	.35196	.10745E-01				
2454.50A	23497.	.53556	.64667	234.06	.26403	.80337E-02				
2552.50A	23466.	.35752	.42658	255.04	.17507	.53292E-02				
3067.50A	29104.	.24132	.35791	469.39	.14627	.35931E-02				
3151.50A	29100.	.35475	.52608	453.67	.21500	.52820E-02				
3233.50A	29087.	.50511	.74671	432.18	.30598	.75207E-02				
3314.50A	29062.	.62866	.53199	415.83	.38086	.93632E-02				
3401.50A	29076.	.76962	1.1404	369.48	.46607	.11459E-01				
3508.50A	29059.	.64477	1.2150	367.05	.54150	.13222E-01				
3567.50A	29051.	1.0219	1.5129	337.94	.61626	.15215E-01				
3667.50A	29042.	1.1540	1.7080	307.19	.69802	.17183E-01				
3787.50A	29025.	1.2679	1.8754	275.19	.76643	.18878E-01				
3937.50A	29030.	1.2211	1.6046	256.63	.73758	.18182E-01				
4236.50A	29136.	1.2476	1.8516	255.78	.75681	.18575E-01				
4586.50A	29342.	1.2407	1.8552	265.26	.75816	.18473E-01				
5054.00A	28945.	1.0630	1.5974	274.85	.65284	.16125E-01				
5349.00A	29112.	1.0275	1.5237	294.07	.62270	.15299E-01				
5521.00A	29380.	.88875	1.3307	348.82	.54382	.13233E-01				
5632.00A	29364.	.64253	.96126	374.82	.39285	.95668E-02				
5976.50A	29379.	1.0135	1.5174	336.49	.62011	.15090E-01				
6425.00A	23740.	1.1502	1.3906	149.57	.56833	.17125E-01				
6562.00A	23629.	.97057	1.1703	178.62	.47827	.14457E-01				
6720.50A	23627.	.84906	.96609	197.00	.40299	.12195E-01				
6842.00A	23644.	.79986	.96376	190.22	.39395	.11909E-01				
6966.00A	23695.	.66084	.79700	205.95	.32596	.98393E-02				
7125.00A	23671.	.66827	.60615	200.52	.32946	.99500E-02				
7295.00A	23696.	1.1536	1.3940	143.91	.56970	.17176E-01				

SECTION A5



TIME	PUMP CALIBRATION TEST FACILITY										
	-17	-18	-2	-3	-21	-22	-23	-6			
PUMP STA	PUMP DIS	VELOCITY (FPS)	VELOCITY (FPS)	VELOCITY (FPS)	HEADRISE (FT)	FLOW COEF	HEAD COEF	AMBIENT PRESS (PSIA)			
DELTA HEAD FT	VELOCITY (FPS)	HEAD (FT)	INLET VELOCITY (FPS)	PUMP TOT HEADRISE (FT)	PUMP INL FLOW COEF	PUMP DIS HEAD COEF	AMBIENT PRESS (PSIA)				
22.50A	-0.3450E-05	-0.9610E-04	-0.9425E+06	-0.2403E-04	-0.3450E-05	.1858E-02	-0.22747	14.268			
1396.50A	34.580	1.1905	1.0214	.29778	34.608	.7326E-02	.10926	14.268			
1568.50A	46.040	1.84148	1.0296	.21048	46.054	.5190E-02	.14606	14.268			
1659.50A	52.034	2.61881	1.0349	.19478	52.041	.38190E-02	.16522	14.268			
2062.50A	152.15	2.3989	1.0624	.60004	152.27	.72675E-02	.11646	14.268			
2156.50A	160.15	2.0946	1.0746	.51591	160.23	.62281E-02	.13800	14.268			
2265.50A	207.26	1.7011	1.0870	.42550	204.33	.51715E-02	.15735	14.268			
2356.50A	221.75	1.4071	1.0634	.35196	221.79	.42788E-02	.17088	14.268			
2454.50A	239.04	1.0556	1.1012	.26403	239.06	.31992E-02	.18295	14.268			
2552.50A	255.03	.89992	1.1139	.17507	255.04	.21222E-02	.15536	14.268			
3067.50A	469.39	.58479	1.1981	.14627	469.39	.14309E-02	.23413	14.268			
3151.50A	453.05	.65955	1.2038	.21500	453.07	.21034E-02	.22604	14.268			
3233.50A	432.15	1.22235	1.2097	.30598	432.18	.29949E-02	.21582	14.268			
3314.50A	413.79	1.5226	1.2274	.36066	413.63	.37287E-02	.20673	14.268			
3401.50A	389.41	1.8635	1.2694	.46607	389.48	.45633E-02	.19461	14.268			
3508.50A	366.96	2.1649	1.3022	.54150	367.05	.53053E-02	.18365	14.268			
3567.50A	337.82	2.4719	1.3295	.61628	337.94	.60592E-02	.16917	14.268			
3667.50A	307.04	2.7906	1.3637	.69002	307.19	.68426E-02	.15387	14.268			
3767.50A	275.00	3.0642	1.3943	.76043	275.19	.75177E-02	.13800	14.268			
3937.50A	257.85	2.5488	1.4353	.73758	256.03	.72405E-02	.12963	14.268			
4236.50A	255.60	3.0257	1.5159	.75681	255.78	.73971E-02	.12754	14.268			
4586.50A	265.08	3.0311	1.5926	.75816	265.26	.73566E-02	.13016	14.268			
5054.00A	274.72	2.6100	1.7262	.65284	274.85	.64213E-02	.13857	14.268			
5349.00A	293.94	2.4885	1.8303	.62470	294.07	.60926E-02	.14682	14.268			
5521.00A	348.73	2.1742	1.8716	.54382	348.82	.52697E-02	.17072	14.268			
5632.00A	374.77	1.5706	1.9042	.59285	374.82	.38098E-02	.18370	14.268			
5976.50A	336.37	2.4792	2.0248	.62011	336.49	.60093E-02	.16471	14.268			
6425.00A	149.47	2.2722	2.1519	.56833	149.57	.68197E-02	.11230	14.268			
6562.00A	178.54	1.9121	2.1401	.41027	178.62	.57571E-02	.13482	14.268			
6740.50A	196.95	1.6112	2.1644	.40259	197.00	.48564E-02	.14894	14.268			
6842.00A	190.17	1.5750	2.1751	.39395	190.22	.47266E-02	.14330	14.268			
6986.00A	205.92	1.5052	2.1806	.32596	205.95	.39183E-02	.15509	14.268			
7123.00A	200.49	1.3172	2.1865	.32946	200.52	.39624E-02	.15126	14.268			
7295.00A	143.81	2.2776	2.2308	.56970	143.51	.68399E-02	.10827	14.268			

SECTION A5



TIME	-16 FLOW/ DES FLOW		6 PUMP INL ET TEMP (F)		14 PUMP OUT LET TEMP (F)		105 TURBINE INLET TE MP (F)		106 TURBINE OUTLET T EMP (F)		1 PUMP INL ET PRESS (PSIG)		8 PUMP DIS PRESS (PSIG)	
	22.50A	.31349	-3766.1	75.806	77.071	67.951	50.395	46.593	41.426	88.386	28.221	34.341	43.167	32.257
1398.50A	1.2357	75.806	76.052	78.006	76.006	44.378	43.836	36.759	28.119	50.606	28.119	47.916	50.606	
1568.50A	.87546	76.052	76.200	78.092	76.092	45.805	45.805	20.509	25.790	91.539	25.790	103.89	91.539	
2062.50A	1.2257	76.987	77.332	80.517	77.332	46.859	46.859	20.654	26.293	103.89	26.293	114.55	103.89	
2156.50A	1.0504	77.332	77.678	81.502	77.678	46.740	46.740	20.457	26.511	114.55	26.511	122.33	114.55	
2263.50A	.87219	77.678	77.578	82.555	77.578	46.396	46.396	20.309	26.806	122.33	26.806	130.08	122.33	
2356.50A	.72164	77.578	78.414	84.455	78.414	46.002	46.002	20.309	27.225	130.08	27.225	137.40	130.08	
2454.50A	.53956	78.414	80.924	87.655	80.924	45.605	45.605	4.5578	27.842	137.40	27.842	230.56	137.40	
2552.50A	.35792	80.924	81.132	88.768	81.132	40.884	40.884	4.4594	26.582	230.56	26.582	222.24	230.56	
3067.50A	1.0219	83.627	83.627	88.640	83.627	41.031	41.031	4.7055	25.144	222.24	25.144	212.79	222.24	
3151.50A	.35475	80.776	82.400	85.034	82.400	41.819	41.819	4.5086	24.886	212.79	24.886	204.52	212.79	
3233.50A	.50511	80.924	83.188	88.768	83.188	42.015	42.015	3.6195	24.886	193.63	25.495	183.57	193.63	
3314.50A	.62886	81.367	83.627	88.640	83.627	42.114	42.114	4.1148	24.523	183.57	24.523	170.72	183.57	
3401.50A	.76962	82.400	84.615	88.768	84.615	42.262	42.262	4.1640	24.230	170.72	24.230	157.05	170.72	
3508.50A	.89477	83.188	85.303	89.280	85.303	41.819	41.819	3.6718	142.92	157.05	24.230	142.92	157.05	
3567.50A	1.0219	83.627	85.303	89.280	85.303	42.452	42.452	5.2347	127.62	142.92	16.352	127.62	142.92	
3667.50A	1.2476	87.679	87.679	91.763	87.679	42.141	42.141	5.0774	123.42	127.62	13.155	123.42	127.62	
3787.50A	1.2679	85.303	86.208	90.006	86.208	42.411	42.411	4.6401	122.10	123.42	7.7793	122.10	123.42	
3837.50A	1.2211	85.479	86.208	90.006	86.208	41.762	41.762	4.7661	111.65	122.10	-6.7773	111.65	122.10	
4238.50A	1.2407	85.479	86.429	93.448	85.479	40.663	40.663	4.1405	136.43	111.65	9.7576	136.43	111.65	
5054.00A	1.0830	92.074	93.514	96.544	93.514	40.509	40.509	3.9376	167.33	136.43	17.075	167.33	136.43	
5349.00A	1.0275	93.514	94.643	100.07	94.643	40.365	40.365	4.5967	167.33	167.33	17.075	167.33	167.33	
5521.00A	.88875	94.643	95.200	102.19	95.200	40.365	40.365	3.3272	173.06	167.33	17.075	173.06	167.33	
5632.00A	.64253	95.200	97.163	101.93	97.163	39.112	39.112	15.826	73.192	173.06	8.8400	73.192	173.06	
5766.50A	1.0135	98.883	98.883	101.50	98.883	40.520	40.520	17.039	86.198	173.06	8.8400	86.198	173.06	
6425.00A	1.1502	99.009	99.009	101.86	99.009	40.613	40.613	16.643	92.649	86.198	9.3309	92.649	86.198	
6562.00A	.97097	99.009	99.361	102.81	99.361	39.679	39.679	16.342	90.483	86.198	8.6200	90.483	86.198	
6720.50A	.81906	99.361	99.545	103.10	99.545	39.679	39.679	16.482	95.034	90.483	6.3918	95.034	90.483	
6842.00A	.79986	99.545	99.627	104.16	99.627	39.972	39.972	16.727	91.878	90.483	5.5759	91.878	90.483	
6986.00A	.66084	99.627	99.744	104.22	99.744	39.972	39.972	15.711	71.425	91.878	9.5264	71.425	91.878	
7123.00A	.66827	100.36	100.36	102.57	100.36	39.555	39.555			91.878		71.425	91.878	
7295.00A	1.1536	100.36	100.36	102.57	100.36	39.555	39.555			91.878		71.425	91.878	

SECTION A5

TIME	PUMP CALIBRATION TEST FACILITY												38 IMP FR T IP PR	
	18 VOLUTE P RESS GDE (PSIG)	19 VOLUTE P RESS 900 EG(PSIG)	20 VOLUTE P RESS 1800 EG(PSIG)	21 VOLUTE P RESS 2700 EG(PSIG)	34 FRONT WR RING UP R (PSIG)	36 REAR WR RING UP R (PSIG)	37 REAR WR RINT DP R (PSIG)							
22.50A	32.781	31.726	32.847	34.322	34.202	34.102	31.398	33.754						
1598.50A	40.351	41.495	43.405	45.464	28.356	33.697	25.251	42.673						
1568.50A	45.076	44.044	45.809	46.015	28.748	35.202	25.351	45.146						
1655.50A	48.117	45.866	47.609	49.533	29.025	36.416	25.617	47.042						
2062.50A	74.852	66.674	68.517	55.635	25.650	45.350	22.012	83.936						
2156.50A	85.556	92.447	55.185	99.811	27.474	46.426	22.809	89.591						
2263.50A	100.22	98.302	101.40	106.04	29.172	51.922	24.022	95.625						
2356.50A	109.00	105.53	106.67	111.55	30.332	55.337	25.484	100.87						
2454.50A	119.04	109.05	112.27	117.53	31.769	59.561	26.879	107.05						
2152.50A	129.03	114.81	117.67	123.55	33.320	63.979	28.623	113.12						
3067.50A	218.58	187.86	192.30	200.52	40.505	94.197	33.009	165.97						
3151.50A	207.67	180.65	185.31	192.47	37.974	87.642	30.202	178.38						
3233.50A	174.64	173.17	177.93	183.73	35.932	81.621	27.976	168.56						
3314.50A	163.66	167.06	172.32	177.08	34.316	77.284	26.331	162.64						
3401.50A	170.04	160.04	164.64	165.36	32.356	72.379	24.636	154.58						
3508.50A	159.62	153.74	158.55	162.67	30.577	68.301	23.224	147.82						
3587.50A	146.15	146.06	150.80	155.05	28.699	64.028	21.779	140.14						
3667.50A	133.40	138.94	143.58	147.98	26.690	60.079	20.400	133.44						
3787.50A	122.41	132.46	136.25	141.08	24.878	56.567	19.719	126.62						
3937.50A	106.71	116.11	114.68	123.75	17.625	42.919	15.738	107.03						
4238.50A	101.11	112.66	115.92	121.36	14.391	39.315	12.665	105.41						
4586.50A	99.866	111.23	114.54	119.73	8.4379	37.845	6.7583	105.30						
5054.00A	63.515	63.326	85.916	94.473	29.589	8.2444	1.1360	78.558						
5349.00A	112.10	113.46	117.83	121.86	13.305	40.092	10.516	107.31						
5521.00A	141.55	138.56	141.96	145.76	22.324	54.867	16.868	130.73						
5632.00A	144.16	124.91	151.49	154.77	13.507	44.068	9.6502	120.58						
5976.50A	147.65	144.74	152.73	157.01	31.863	66.067	24.919	142.71						
6425.00A	55.502	65.872	68.166	71.948	10.565	26.187	10.068	63.142						
6562.00A	71.405	71.698	74.808	77.945	11.441	28.939	11.085	68.340						
6720.50A	78.294	74.275	76.648	80.657	12.569	29.620	10.516	71.738						
6842.00A	75.977	72.520	75.222	78.550	13.499	28.900	11.154	69.195						
6586.00A	82.185	73.958	77.469	80.563	12.107	27.544	10.441	71.423						
7123.00A	79.111	70.990	74.443	77.383	10.036	26.769	9.5805	67.641						
7295.00A	57.977	64.027	66.516	69.915	9.3305	24.722	9.7901	60.750						

PUMP CALIBRATION TEST FACILITY												
TEST 84L011		TEST DATE 22 MAR 1984				PROCESS DATE 17 NOV 1984						PAGE 15
TEST 84L011		3-21-84 LOW THRUST PUMP H-Q & CAV TESTS										
TIME	39	40	110	114	115	116						
	IMP PK M	IMP REAK	TURB IN	T TIP PR	T HUB PR	TURB NOZ						
	(PSIG)	(PSIG)	STATIC P	(PSIG)	(PSIG)	OUT						
			R (PSIG)	(PSIG)	(PSIG)							
			.17071E-04	.25322E-01	.64035E-02							
22.50A	33.727	34.809	5.5477	1.5256	1.6553	1.0910						
1396.50A	33.743	44.047	3.5412	1.5446	1.6144	1.1291						
1568.50A	35.067	46.362	3.5444	1.5636	1.5952	1.1355						
1659.50A	36.098	48.285	7.7902	3.2347	3.4595	2.8531						
2062.50A	45.359	86.926	7.7052	3.1651	3.4403	2.7577						
2156.50A	52.450	92.110	7.6284	3.1461	3.4210	2.7704						
2263.50A	55.566	96.064	7.5659	3.1461	3.3698	2.7449						
2356.50A	56.795	103.20	7.5417	3.1144	3.3249	2.7449						
2454.50A	62.061	105.13	7.4714	3.0828	3.3506	2.6622						
2552.50A	65.450	115.12	11.340	4.7413	5.1316	4.4371						
3067.50A	98.187	187.77	11.452	4.8173	5.1764	4.5134						
3151.50A	93.723	174.56	11.575	4.8669	5.2341	4.5579						
3233.50A	89.275	171.74	11.725	4.9565	5.2789	4.6406						
3314.50A	65.923	166.25	11.651	5.0262	5.3494	4.6661						
3401.50A	61.599	158.45	11.980	5.0515	5.4006	4.7360						
3508.50A	77.976	151.15	12.031	5.0831	5.4711	4.7233						
3567.50A	73.675	144.05	12.178	5.1338	5.4967	4.8060						
3667.50A	69.440	137.57	12.216	5.1771	5.5288	4.8124						
3787.50A	65.957	131.38	11.414	4.7888	5.1011	4.4935						
3937.50A	46.842	113.59	11.551	4.8574	5.1750	4.5311						
4236.50A	45.291	109.65	11.797	4.9917	5.3418	4.6406						
4586.50A	45.156	109.29	11.479	4.8259	5.1503	4.5109						
5054.00A	45.527	81.771	11.450	4.8101	5.1544	4.5231						
5349.00A	47.519	110.66	11.417	4.7869	5.1235	4.4790						
5521.00A	62.480	133.44	10.167	4.5247	4.8267	4.2405						
5632.00A	49.442	125.04	12.015	5.2730	5.6441	4.9714						
5976.50A	75.621	146.45	7.2074	2.9578	3.2241	2.6313						
6425.00A	30.634	65.475	6.9416	2.8453	3.0766	2.5308						
6502.00A	32.917	70.459	6.9592	2.8686	3.1045	2.5467						
6720.50A	33.366	74.417	7.0434	2.9131	3.1353	2.5706						
6842.00A	32.647	71.368	6.9074	2.8510	3.0718	2.5227						
6966.00A	30.766	73.545	6.6535	2.8235	3.0573	2.5308						
7123.00A	29.705	69.726	7.1159	2.8422	3.1847	2.6167						
7295.00A	28.718	63.138										

SECTION A5

TEST 84L005 TEST DATE 15 FEB 1984 PUMP CALIBRATION TEST FACILITY PROCESS DATE 9 NOV 1984 PAGE 0  
 TEST 84L005 2-15-84 LOW THRUST PUMP HC & CAV. TESTS

C	DESCRIPTION	CONSTANT
1	WALL DIAMETER AT INLET PRESS TAP, IN.	1.00000E+00
2	HUB DIAMETER AT INLET PRESS TAP, IN	0.0
5	IMPELLER INLET TIP DIAMETER, IN	8.05000E-01
6	IMPELLER INLET HUB DIAMETER, IN	5.00000E-01
7	IMPELLER DISH TIP DIAMETER, IN	2.00000E+00
9	INLET AREA AT PRESS TAP, SQ. IN	7.85000E-01
10	IND/IMP INLET AREA, SQ. IN.	3.12608E-01
11	DESIGN FLOW, GPM	5.00000E+00
12	AMBIENT PRESSURE, PSIA	1.43810E+01
13	DESIGN SPEED FOR DESIGN FLOW, RPM	2.45000E+04
19	PUMP DISCHARGE LINE DIAMETER, IN.	5.00000E-01
21	HEAD ELEVATION (FT) CORRECTION FOR F(7)	1.00000E+00
23	K FACTOR	0.0
24	WATER TANK ELEVATION, FT	1.34271E+01
31	CONFIGURATION NUMRER	6.00000E+00
35	FRONT WEAR RING UPSTREAM PRESSURE, RADIAL LCCATION	5.70000E-01
36	IMPELLER FRONT MID PRESSURE, RADIAL LOCATION	7.80000E-01
37	IMPELLER FRONT TIP PRESSURE, RADIAL LOCATION	9.80000E-01
38	IMPELLER REAR TIP PRESSURE, RADIAL LOCATION	9.70000E-01
39	REAR WEAR RING UPSTREAM PRESSURE, RADIAL LOCATION	5.80000E-01
40	IMPELLER LEADING EDGE TIP RADIUS	5.00000E-01
91	NOZZLE INLET DIAMETER, IN	1.00000E+00
92	NOZZLE THROAT DIAMETER, IN	1.91000E-01
93	NOZZLE DISCH COEFF	9.85000E-01
94	SPEC. HT. RATIO	1.40000E+00
95	MWT OF GAS	2.80160E+01
96	TURB MEAN DIAMETER, IN	2.40000E+00
97	TURB NOZ AREA, IN2	5.54000E-01
98	TURB PIPE IN DIAMETER, IN	1.61000E+00

SECTION A6

PUMP CALIBRATION TEST FACILITY												
TEST 84L005		TEST DATE 15 FEB 1984			PROCESS DATE 9 NOV 1984			PAGE 4				
TEST 84L005		2-15-84 LOW THRUST PUMP HQ & CAV. TESTS										
TIME	-2 VAPOR HEAD (FT)	-101 NOZZLE FLOWRATE (LB/SEC)	-102 FLOW NOZZLE PR RATIO	-103 FLOW PARAM	-104 TURB AVL ENERGY, RTU/LBM	-105 CSUBO ISEN VEL FT/S	-106 TURBINE MEAN VEL FT/S	-107 TURB AVL ENER PIP BTU/LBM				
19.79A	.68831	.11946	.56195E-01	2.1245	.68694	182.48	76.993	1.6758				
528.79A	.73360	.21110	.69830E-01	2.9630	1.9920	315.30	153.85	3.9536				
723.79A	.74752	.28147	.64141E-01	3.2370	3.2736	410.96	208.18	5.7022				
1012.79A	.77088	.38308	.61176E-01	3.3436	5.2072	510.60	257.00	7.3336				
1377.79A	.78016	.37252	.61375E-01	3.3479	5.1068	505.66	257.41	7.3535				
1525.79A	.78418	.36120	.61633E-01	3.3589	4.8133	490.93	256.88	7.2663				
1803.00A	.79082	.35518	.61793E-01	3.3473	4.7657	488.44	258.37	7.1992				
2027.00A	.79621	.34461	.61974E-01	3.3409	4.6066	480.24	256.09	7.0316				
2215.79A	.79762	.33751	.62211E-01	3.3226	4.5345	476.43	256.84	6.8856				
2319.79A	.79487	.33042	.62419E-01	3.3229	4.3854	468.54	256.67	6.8202				
2501.79A	.80028	.31994	.62647E-01	3.2971	4.2687	462.28	254.72	6.5453				
2656.79A	.80299	.31833	.62848E-01	3.2925	4.2643	462.03	258.82	6.5948				
2799.79A	.79758	.30582	.63130E-01	3.2721	4.1157	453.90	254.22	6.3807				
3033.79A	.79857	.30224	.63613E-01	3.2407	4.2362	460.53	257.77	6.3985				
3474.00A	.81802	.32984	.70935E-01	3.1140	4.2408	433.12	206.57	6.0605				
3960.79A	.82490	.37289	.61055E-01	3.3874	4.5948	476.95	226.24	7.0154				
4676.58A	.91021	.13834	.40285	1.9875	.51116	149.53	-.34078E-01	1.7145				

SECTION A6

TEST 84L005 TEST DATE 15 FEB 1984 PUMP CALIBRATION TEST FACILITY PROCESS DATE 9 NOV 1984 PAGE 5  
 TEST 84L005 2-15-84 LOW THRUST PUMP HQ & CAV. TESTS

TIME	-1 WATER SP.WGT. LBM/FT3	-115 TURBINE PRESSURE RATIO	6 PUMP INL ET TEMP (F)	14 PUMP OUT LET TEMP (F)	105 TURBINE INLET TE MP (F)	106 TURBINE OUTLET T EMP (F)	1 PUMP INL ET PRESS (PSIG)	8 PUMP DIS PRESS (PSIG)
19.79A	52.320	1.0202	64.273	64.465	27.119	31.532	39.266	66.576
528.79A	62.308	1.0620	66.798	67.080	12.131	2.0484	38.437	153.32
723.79A	62.304	1.1087	66.640	68.511	8.5317	-12.693	38.164	249.66
1012.79A	62.298	1.1716	67.528	69.745	14.744	-17.032	37.188	358.35
1377.79A	62.296	1.1657	67.373	70.238	20.710	-11.263	38.389	360.88
1525.79A	62.295	1.1551	68.021	70.731	21.005	-10.524	38.936	362.29
1803.00A	62.293	1.1539	68.268	71.323	19.871	-11.263	39.274	365.99
2027.00A	62.292	1.1487	68.465	71.669	18.540	-11.904	39.667	363.00
2215.79A	62.291	1.1466	68.514	72.261	17.160	-12.693	39.835	364.12
2319.79A	62.292	1.1415	68.416	72.853	16.617	-12.743	40.168	366.90
2501.79A	62.290	1.1378	68.613	73.642	15.483	-13.137	40.304	362.45
2656.79A	62.290	1.1379	68.711	75.221	14.645	-13.975	40.545	374.13
2799.79A	62.291	1.1328	68.514	76.751	14.399	-13.482	40.649	363.42
3033.79A	62.291	1.1373	68.563	80.796	13.610	-13.975	40.819	372.85
3474.00A	62.286	1.1395	69.250	72.024	15.261	-13.519	10.223	217.21
3960.79A	62.284	1.1503	69.478	71.681	14.113	-14.210	8.6249	289.54
4676.58A	62.261	1.0151	72.380	71.990	28.045	29.175	39.999	38.784

SECTION A6



PUMP CALIBRATION TEST FACILITY														
TEST 84L0J5		TEST DATE 15 FEB 1984		PROCESS DATE 9 NOV 1984		PAGE 6								
TEST 84L005		2-15-84 LOW THRUST PUMP HQ & CAV. TESTS												
TIME	18	19	20	21	26	34	36	37						
	VOLUME P RESS ODE G (PSIG)	VOLUME P RESS 900 EG (PSIG)	VOLUME P RES 1300 EG (PSIG)	VOLUME P RES 2700 EG (PSIG)	DIFFUSER IN PRES S (PSIG)	FRONT WR RING UP R (PSIG)	REAR WR RING UP R (PSIG)	REAR WR RING UP R (PSIG)						
19.79A	65.847	67.225	64.367	65.955	64.539	59.121	60.273	38.413						
528.79A	150.43	151.60	147.74	144.31	140.15	115.82	118.99	39.492						
723.79A	244.62	245.06	239.57	229.83	223.88	177.12	182.64	41.236						
1012.79A	348.82	348.85	342.34	324.57	318.56	244.64	252.46	40.737						
1377.79A	352.38	352.11	344.93	327.45	320.96	246.47	254.62	42.846						
1525.79A	354.79	354.47	346.94	329.31	321.66	247.27	255.82	44.307						
1803.00A	359.41	358.57	351.32	333.86	325.51	250.55	259.36	45.586						
2027.00A	357.56	356.36	349.25	331.87	322.59	248.91	257.46	46.715						
2215.79A	359.36	358.02	351.50	334.36	324.41	250.94	260.23	47.861						
2319.79A	362.63	361.14	353.58	337.64	326.70	252.90	261.38	49.787						
2501.79A	358.69	357.44	352.44	335.34	324.03	251.71	260.23	50.949						
2656.79A	370.58	368.94	364.27	346.91	333.45	259.44	268.17	53.124						
2799.79A	359.97	358.59	354.33	339.61	324.49	253.62	261.71	54.220						
3033.79A	369.74	368.80	364.16	350.30	333.43	260.52	268.72	56.113						
3474.00A	206.15	204.45	206.27	204.81	215.04	158.80	155.27	11.529						
3960.79A	278.90	279.58	275.14	260.79	251.75	185.67	197.64	12.561						
4676.58A	38.821	36.609	38.178	39.947	39.612	39.924	40.219	38.631						

SECTION A6

PUMP CALIBRATION TEST FACILITY  
 TEST DATE 15 FEB 1984  
 TEST 84L005 2-15-84 LOW THRUST PUMP HQ & CAV. TESTS  
 TEST 84L005  
 PROCESS DATE 9 NOV 1984  
 PAGE 7

TIME	38	39	40	110	111	112	113	114
	IMP FR T IP PR	IMP FR M ID PR	IMP REAR TIP PR	TURR IN STATIC P R (PSIG)	TURB NCZ IN PR (PSIG)	TURB NCZ OUT TIP PR PSIG	TURB NCZ OUT HUB PR PSIG	ROTOR OU T TIP PR (PSIG)
19.79A	62.436	58.815	63.484	2.6547	2.2504	1.0948	1.0454	1.7976
528.79A	133.21	122.00	135.51	7.4534	6.3654	3.6921	3.8488	4.9530
723.79A	211.80	192.16	215.42	12.468	10.843	6.7901	7.0206	8.0446
1012.79A	300.58	270.30	304.46	20.976	19.073	12.660	12.675	13.463
1377.79A	302.67	272.22	307.14	20.273	18.313	12.124	12.224	12.972
1525.79A	303.77	273.17	308.15	19.331	17.226	11.461	11.558	12.315
1803.00A	307.65	276.68	312.21	18.832	16.770	11.123	11.226	11.933
2027.00A	304.53	274.21	309.62	17.856	15.858	10.494	10.632	11.315
2215.79A	307.51	277.18	311.88	17.255	15.355	10.086	10.216	10.894
2319.79A	309.39	278.60	313.92	16.654	14.712	9.6902	9.8003	10.492
2501.79A	307.17	277.15	311.67	15.724	13.976	9.0380	9.2657	9.9123
2656.79A	316.50	285.70	320.99	15.644	13.847	8.9797	9.2657	9.7912
2799.79A	308.01	278.70	312.66	14.578	12.900	8.2926	8.6005	9.1282
3033.79A	316.38	286.36	321.29	14.408	12.818	8.1761	8.4223	8.9816
3474.00A	193.95	157.24	208.71	17.047	15.442	10.106	10.069	10.839
3960.79A	236.02	207.37	235.44	19.892	17.759	11.650	11.730	12.794
4676.58A	39.325	38.006	39.741	4.5457	3.8898	2.0407	2.0680	3.4298

SECTION A6

TEST 84L005 TEST DATE 15 FEB 1984 PUMP CALIBRATION TEST FACILITY PROCESS DATE 9 NOV 1984 PAGE 11  
 TEST 94L005 2-15-84 LOW THRUST PUMP HQ & CAV. TESTS

TIME	SHAFT SPEED (RPM)	PUMP TOT HEAD (FT)	PUMP DIS FLOW (GPM)	DES FLOW	PUMP SCA LED RISE (FT)	PUMP SCA LED FLOW (GPM)	PUMP PWR (HP)	PUMP CIS HEAD (CCEF)
	4	-21	3	-16	-30	-31	-32	-23
19.79A	7352.3	63.446	1.4339	.99902	705.02	4.9951	.24007E-01	.49623
528.79A	14691.	265.94	2.9176	.99247	739.62	4.9624	.19973	.52058
723.79A	19880.	489.62	4.0311	.59362	743.67	4.9681	.49813	.52343
1012.79A	24542.	744.17	6.0269	1.2033	741.64	6.0166	1.1318	.52200
1377.79A	24581.	746.98	5.5574	1.1078	742.11	5.5392	1.0475	.52234
1525.79A	24531.	748.70	4.5955	.99586	746.83	4.9793	.94190	.52565
1803.00A	24673.	756.27	4.5155	.89480	745.75	4.4740	.85978	.52490
2027.00A	24455.	748.26	4.0233	.80616	751.06	4.0308	.75963	.52864
2215.79A	24527.	750.25	3.4857	.69638	748.65	3.4819	.65986	.52694
2319.79A	24511.	755.76	2.5330	.59836	755.11	2.9918	.57079	.53148
2501.79A	24324.	745.04	2.5376	.50515	755.85	2.5257	.47141	.53200
2656.79A	24716.	771.37	2.0123	.39894	757.98	1.9947	.39166	.53351
2759.79A	24276.	746.26	1.5130	.30661	760.12	1.5331	.28604	.53501
3033.79A	24615.	767.62	1.0378	.20659	760.45	1.0329	.20102	.53524
3474.00A	19726.	479.81	4.4655	-87.343	-22504E+09	-436.72	.70097	-.15839E+06
3960.79A	21604.	650.89	5.0943	-112.06	.20180E+09	-560.20	.93927	.14204E+06
4676.58A	-3.2542	-2.8090	-.1134E-03	.20257	-1.3989E+10	1.0149	.92293E-07	-.98464E+06

SECTION A6

## REFERENCES

1. Wislicenus, G. F.: "Fluid Mechanics of Turbomachinery," Dover Publications, Inc., New York, 1965.