

## N O T I C E

THIS DOCUMENT HAS BEEN REPRODUCED FROM  
MICROFICHE. ALTHOUGH IT IS RECOGNIZED THAT  
CERTAIN PORTIONS ARE ILLEGIBLE, IT IS BEING RELEASED  
IN THE INTEREST OF MAKING AVAILABLE AS MUCH  
INFORMATION AS POSSIBLE



AUTOMATED  
WATER MONITOR SYSTEM  
FIELD DEMONSTRATION  
TEST REPORT

VOLUME II

TECHNICAL SUMMARY

CONTRACT No. NAS2-9885

SEPTEMBER 30, 1981


Prepared by:

Richard L. Brooks  
Eldon L. Jeffers  
Jim Perreira  
Jerry D. Poel  
David Nibley  
Robert H. Nuss

Prepared for:

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION  
AMES RESEARCH CENTER  
MOFFETT FIELD, CA 94035

Approved by:

  
R. H. Nuss, Manager  
Urban Systems  
(5-2700)

THE BOEING COMPANY  
HOUSTON, TEXAS

## DISCLAIMER

"This report was prepared as an account of Government-sponsored work. Neither the United States, nor the Administration, nor any person acting on behalf of the Administration:

- a. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of that information contained in this report, or that the use of any information, apparatus, methods, or process disclosed in this report may not infringe privately owned rights;
- b. Assumes any liability with respect to the use of any information, apparatus, methods, or process disclosed in this report."

As used in the above, "Person acting on behalf of the Administration" includes any employee or contractor of the Administration, or employee of such contractor to the extent that such an employee or contractor of the Administration, or employee of such contractor prepared, disseminates, or provides access to any information pursuant to his employment or contract with the Administration or his employment with such contractor.



## ABSTRACT

The Santa Clara Valley Water District (SCVWD) owns and operates a water reclamation facility located in the Palo Alto Baylands area in Northern California. The purpose of the facility is to evaluate the technical and cost feasibility of producing high quality reclaimed water in Santa Clara County. The SCVWD requested NASA to move their Water Monitor System to the reclamation facility to provide the district with data to help them evaluate the individual treatment processes and the entire treatment train. The field demonstration test period at the SCVWD Water Reclamation Facility began in July 1977 and ended in February 1981. This technical summary is divided into two major parts. The first part covers the results of the data gathered by the WMS and the SCVWD from January 1978 to September 1979. The second portion of the Technical Summary covers the results of the data gathered from July 1980 through February 1981.

## TABLE OF CONTENTS

|  | <u>Page</u> |
|--|-------------|
| DISCLAIMER . . . . .   | ii          |
| ABSTRACT . . . . .   | iii         |
| FIGURES . . . . .  | vii         |
| TABLES . . . . .   | xi          |
| ACRONYMS . . . . .   | xiii        |
| 1. Introduction . . . . .  | 1           |
| SCVWD-WRF/PA (Santa Clara Valley Water District-<br>Water Reclamation Facility at Palo Alto) Background. | 1           |
| WMS (Water Monitor System) Background . . . . .  | 1           |
| Test Program . . . . .   | 1           |
| 2. Part I Field Demonstration Test Results . . . . .   | 3           |
| Test Objectives/Accomplishments . . . . .  | 3           |
| Conclusions . . . . .  | 5           |
| WMS Performance Evaluation . . . . .   | 8           |
| Sample Collection and Distribution System . . . . .  | 8           |
| Total Organic Carbon/Total Oxygen Demand . . . . .   | 9           |
| Analyzer   |             |
| Hardness Analyzer . . . . .  | 10          |
| Nitrate Analyzer . . . . .   | 10          |
| pH Analyzer . . . . .  | 10          |
| Total Residual Chlorine Analyzer . . . . .   | 11          |
| Sodium Analyzer . . . . .  | 11          |
| Temperature Analyzer . . . . .   | 12          |
| Turbidity Analyzer . . . . .   | 12          |
| Ammonia Analyzer . . . . .   | 12          |
| Chloride Analyzer . . . . .  | 13          |
| Conductivity Analyzer . . . . .  | 14          |
| Dissolved Oxygen Analyzer . . . . .  | 14          |
| Chemiluminescence Biosensor . . . . .  | 14          |
| Coliform Detector . . . . .  | 17          |
| Gas Chromatograph . . . . .  | 18          |
| Deionized Water System . . . . .   | 20          |
| Data Acquisition and Report Generation System . . . . .  | 20          |
| Data Reports . . . . .   | 33          |

## TABLE OF CONTENTS (Continued)

|  | <u>Page</u> |
|--|-------------|
| SCVWD Water Reclamation Facility Description . . . . .   | 47          |
| General . . . . .  | 47          |
| Control and Instrumentation . . . . .                    | 47          |
| Chemical Clarification . . . . .                         | 49          |
| Recarbonation . . . . .                                  | 51          |
| Mixed-Media Filtration . . . . .                         | 51          |
| Ozonation . . . . .                                      | 51          |
| Granular Activated Carbon Sorption . . . . .             | 52          |
| Plant/Process Performance Evaluation . . . . .           | 52          |
| Nominal Input/Output Characteristics . . . . .           | 52          |
| Influent Variations . . . . .                            | 65          |
| Potential WMS Applications for Process Control . . . . . | 79          |
| 3. Part II Field Demonstration Test Results . . . . .    | 84          |
| Test Objectives . . . . .                                | 84          |
| Conclusions . . . . .                                    | 85          |
| Recommendations . . . . .                                | 87          |
| WMS Performance Evaluation . . . . .                     | 89          |
| Sample Collection and Distribution System . . . . .      | 89          |
| Chemiluminescence Biosensor . . . . .                    | 90          |
| Gas Chromatograph . . . . .                              | 90          |
| Total Organic Carbon Analyzer . . . . .                  | 92          |
| Hardness Analyzer . . . . .                              | 92          |
| Nitrate Analyzer . . . . .                               | 93          |
| pH Analyzer . . . . .                                    | 93          |
| Total Residual Chlorine Analyzer . . . . .               | 93          |
| Sodium Analyzer . . . . .                                | 93          |
| Temperature Analyzer . . . . .                           | 94          |
| Turbidity Analyzer . . . . .                             | 94          |
| Coliform Detector . . . . .                              | 94          |
| Ammonia Analyzer . . . . .                               | 96          |
| Conductivity Analyzer . . . . .                          | 96          |
| Dissolved Oxygen Analyzer . . . . .                      | 96          |
| Deionized Water System . . . . .                         | 97          |
| Data Acquisition and Report Generation System . . . . .  | 97          |
| WMS Availability . . . . .                               | 97          |
| WMS Reliability . . . . .                                | 100         |
| WMS Operations and Maintenance Cost Summary . . . . .    | 100         |
| Summary . . . . .  | 103         |

TABLE OF CONTENTS (Continued)

|   | <u>Page</u> |
|---|-------------|
| Data Processing . . . . .                           | 104         |
| Characteristics of the Lognormal Distribution. .    | 104         |
| Characteristics of the Linear Regression . . . .    | 108         |
| Reclamation Plant/Process Performance Evaluation. . | 113         |
| Input/Output . . . . .                              | 115         |
| Plant/Process Availability . . . . .                | 147         |
| Plant Reliability . . . . .                         | 149         |
| Plant O&M Costs . . . . .                           | 149         |
| 4. Future Applications                              | 155         |

REFERENCES

APPENDICES

- A Process Input/Output Characteristics for Part I
- B Monthly Averages for Part I
- C Math Model of Solids and Non-Volatile Organics  
in Effluent From Activated Sludge Process
- D Statistical Analysis Coefficients for Part II
- E Stanford/WMS Data for Organic Removal by GAC
- F Plant Downtime and Maintenance Log
- G WMS Costs

## FIGURES

|    |   | <u>Page</u> |
|----|---|-------------|
| 1  | Total and Viable Bacteria Levels in Various Waste Water Effluents . . . . .                       | 15          |
| 2  | Typical Gas Chromatogram . . . . .  | 19          |
| 3  | Calibration Curve for Tetrachloroethylene . . . . .   | 23          |
| 4  | Calibration Curve for Methylene Chloride . . . . .  | 24          |
| 5  | Calibration Curve for 1,2 Dichloroethylene . . . . .  | 25          |
| 6  | Calibration Curve for Chloroform . . . . .  | 26          |
| 7  | Calibration Curve for 1,1,1 Trichloroethane . . . . .   | 27          |
| 8  | Calibration Curve for Bromodichloromethane . . . . .  | 28          |
| 9  | Calibration Curve for Trichloroethylene . . . . .   | 29          |
| 10 | Calibration Curve for Dibromochloromethane . . . . .  | 30          |
| 11 | Calibration Curve for Bromoform . . . . .   | 31          |
| 12 | Typical Instantaneous Data Report . . . . .   | 34          |
| 13 | Typical Daily Data Report . . . . .   | 35          |
| 14 | Typical Historical Data Report . . . . .  | 37          |
| 15 | Typical Coliform Data Report . . . . .  | 38          |
| 16 | Typical Gas Chromatograph Data Report . . . . .   | 40          |
| 17 | Typical Hourly Plot . . . . .   | 41          |
| 18 | Typical Monthly Plot . . . . .  | 44          |
| 19 | Typical Sample Source Trend Data Report . . . . .   | 45          |
| 20 | Typical Statistical Report . . . . .  | 46          |
| 21 | SCVWD Water Reclamation and Injection/Extraction Well Facility at Palo Alto, California . . . . . | 48          |

FIGURES (Continued)

|  | <u>Page</u> |
|--|-------------|
| 22 Reclamation Plant Nominal Steady-State % Removal Characteristics . . . . .                    | 56          |
| 23 Reclamation Plant Nominal Steady-State Input/Output Characteristics . . . . .                 | 57          |
| 24 Unit Process Steady-State Input/Output Characteristics at 1 mgd - TOC . . . . .               | 58          |
| 25 Unit Process Steady-State Input/Output Characteristics at 1 mgd - Total Halocarbons . . . . . | 59          |
| 26 Unit Process Steady-State Input/Output Characteristics at 1 mgd - Turbidity . . . . .         | 60          |
| 27 Unit Process Steady-State Input/Output Characteristics at 1 mgd - Total Biomass . . . . .     | 61          |
| 28 Unit Process Steady-State Input/Output Characteristics at 1 mgd - Viable Biomass . . . . .    | 62          |
| 29 Monthly Plot Indicating Hour of Peak Concentrations . . .                                     | 66          |
| 30 Hourly Plot Indicating Diurnal Cycle . . . . .  | 67          |
| 31 Math Model Simulation of Process Solids . . . . .   | 70          |
| 32 Math Model Simulation of Non-Volatile Organics . . . . .                                      | 71          |
| 33 Total Halocarbons in Reclamation Facility Influent . . .                                      | 74          |
| 34 Weekly Cycle of Halocarbon Concentrations . . . . .   | 75          |
| 35 Useful Life of Activated Carbon Column (1 of 4) for Chloroform Removal . . . . .              | 76          |
| 36 Chloroform Adsorption Capacity of Granular Activated Carbon (GAC) . . . . .                   | 78          |
| 37 Rate of Activated Carbon Saturation With Non-Volatile Hydrocarbons . . . . .                  | 80          |
| 38 Total and Viable Bacteria Levels in Various Wastewater Effluents . . . . .                    | 91          |

FIGURES (Continued)

|    | <u>Page</u>  |
|----|--|
| 39 | Sampling Schedule . . . . . 116  |
| 40 | Data Distribution and Process Removal Characteristics -<br>Total Biomass . . . . . 119           |
| 41 | Data Distribution and Process Removal Characteristics -<br>Viable Biomass . . . . . 120          |
| 42 | Data Distribution and Process Removal Characteristics -<br>Total Organic Carbon . . . . . 121    |
| 43 | Data Distribution and Process Removal Characteristics -<br>Turbidity . . . . . 122               |
| 44 | Data Distribution and Process Removal Characteristics -<br>Total Residual Chlorine . . . . . 123 |
| 45 | Data Distribution and Process Removal Characteristics -<br>Dissolved Oxygen . . . . . 124        |
| 46 | Data Distribution and Process Removal Characteristics -<br>Ammonia . . . . . 125                 |
| 47 | Data Distribution and Process Removal Characteristics -<br>pH . . . . . 126                      |
| 48 | Data Distribution and Process Removal Characteristics -<br>Conductivity . . . . . 127            |
| 49 | Data Distribution and Process Removal Characteristics -<br>Hardness . . . . . 128                |
| 50 | Data Distribution and Process Removal Characteristics -<br>Total Halocarbons . . . . . 129       |
| 51 | Data Distribution and Process Removal Characteristics -<br>Trihalomethanes . . . . . 130         |
| 52 | Data Distribution and Process Removal Characteristics -<br>Tetrachloroethylene . . . . . 131     |
| 53 | Data Distribution and Process Removal Characteristics -<br>Methylene Chloride . . . . . 132      |

## FIGURES (Continued)

|    |  | <u>Page</u> |
|----|--|-------------|
| 54 | Data Distribution and Process Removal Characteristics - Chloroform . . . . .   | 133         |
| 55 | Data Distribution and Process Removal Characteristics - Trichloroethane . . . . .  | 134         |
| 56 | Data Distribution and Process Removal Characteristics - Bromodichloromethane . . . . .   | 135         |
| 57 | Data Distribution and Process Removal Characteristics - Trichloroethylene . . . . .  | 136         |
| 58 | Data Distribution and Process Removal Characteristics - Dibromochloromethane . . . . .   | 137         |
| 59 | Data Distribution and Process Removal Characteristics - Bromoform . . . . .  | 138         |
| 60 | Time History of Granular Activated Carbon Performance. .   | 146         |
| 61 | Determination of Reliability . . . . .   | 150         |
| 62 | Relationship Between Cost and Reliability for Complying with COD Discharge Limit by Granular Activated Carbon Regeneration . . . . . | 154         |



## TABLES

|    |  | <u>Page</u> |
|----|--|-------------|
| 1  | Comparison of GC Analytical Columns . . . . .  | 21          |
| 2  | Reproducibility of GC Calibration Mixtures Made<br>with Various Solvents . . . . .                   | 22          |
| 3  | WMS-Stanford University Volatile Organic Analyses<br>Comparison Samples 11/20/78 - 3/12/79 . . . . . | 32          |
| 4  | Unit Process Characteristics. . . . .  | 49          |
| 5  | Plant Instrumentation . . . . .  | 51          |
| 6  | Process Configurations for Test Periods . . . . .  | 53          |
| 7  | Water Reclamation Plant Design Criteria . . . . .  | 54          |
| 8  | Reclamation Plant Discharge Water Quality Permit<br>Requirements . . . . .                           | 55          |
| 9  | Estimated Flocculation pH Based on Lime Consumption<br>and Influent Alkalinity . . . . .             | 64          |
| 10 | Diurnal Variation in Biological Quality . . . . .  | 73          |
| 11 | Plant Systems Amenable to Automatic Computer Control. . .  | 81          |
| 12 | Configurations/Costs of Controlling Effluent COD<br>≤10 mg/l at 1 mgd . . . . .                      | 82          |
| 13 | Comparison of Coliform False Positives. . . . .  | 96          |
| 14 | WMS Availability/Reliability . . . . .   | 98          |
| 15 | Operations and Maintenance Cost of Water Monitor<br>System . . . . .                                 | 101         |
| 16 | Sample Statistical Data . . . . .  | 111         |
| 17 | Sample Regression Analysis . . . . .   | 112         |
| 18 | Process Configurations for Test Periods . . . . .  | 114         |
| 19 | Plant Performance for Two Test Periods . . . . .   | 117         |

TABLES (Continued)

|    |   | <u>Page</u> |
|----|---|-------------|
| 20 | Process Performance for Two Test Periods . . . . .                              | 118         |
| 21 | Chi Squares of Process Effluents for Two Test Periods. .                        | 140         |
| 22 | Significant Changes in Normal Distribution Across<br>Processes . . . . .        | 142         |
| 23 | Availability of Palo Alto Reclamation Facility . . . . .                        | 148         |
| 24 | Reliability of Palo Alto Reclamation Facility . . . . .                         | 151         |
| 25 | Operations and Maintenance Costs of Palo Alto<br>Reclamation Facility . . . . . | 152         |
| 26 | Estimated Costs and Savings for Automated<br>Instrumentation . . . . .          | 156         |

## ACRONYMS

|   |                                     |
|---|-------------------------------------|
| A/D   | Analog to Digital Converter         |
| ADAM  | Air Data Acquisition and Monitoring |
| AER   | Aeration                            |
| ATP   | Adenosine Triphosphate              |
| b   | Constant                            |
| BOD   | Biochemical Oxygen Demand           |
| BV  | Biosensor Valve                     |
| C   | Concentration                       |
| CaCO <sub>3</sub>                             | Calcium Carbonate                   |
| C <sub>2</sub> CL <sub>4</sub>                | Tetrachloroethylene                 |
| CHLOR   | Chlorination                        |
| CLAR  | Clarification                       |
| CH <sub>2</sub> Cl <sub>2</sub>               | Methylene Chloride                  |
| C <sub>2</sub> H <sub>2</sub> Cl <sub>2</sub> | 1,2 - Dichloroethylene              |
| CHCl <sub>3</sub>                             | Chloroform                          |
| CH <sub>3</sub> CCl <sub>3</sub>              | 1,1,1, - Trichloroethane            |
| CHBrCl <sub>2</sub>                           | Bromodichloromethane                |
| C <sub>2</sub> HCl <sub>3</sub>               | Trichloroethylene                   |
| CHBr <sub>2</sub> Cl                          | Dibromochloromethane                |
| CHBr <sub>3</sub>                             | Bromoform                           |
| CLSS  | Closed-Loop Stripping System        |
| CO  | Carbon Monoxide                     |

## ACRONYMS (Continued)

|         |   |
|---------|---|
| COD     | Chemical Oxygen Demand                    |
| °C      | Degrees Celsius                           |
| CRT     | Cathode Ray Tube                          |
| CV      | Coliform Valve                            |
| DAS     | Data Acquisition System                   |
| DI      | Deionized Water                           |
| DO      | Dissolved Oxygen                          |
| DOY     | Day of Year                               |
| DSLTB   | Double Strength Lauryl Tryptose Broth     |
| ECD     | Electron Capture Detector                 |
| EDTA    | Ethylene Diamine Tetra Acetic Acid        |
| EVE     | Environmental Verification and Evaluation |
| °F      | Degrees Fahrenheit                        |
| FID     | Flame Ionization Detector                 |
| FILT    | Filtration                                |
| floc    | Flocculant                                |
| F/M     | Food to Biomass Ratio                     |
| FTU     | Formazin Turbidity Units                  |
| GAC     | Granular Activated Carbon                 |
| GC      | Gas Chromatograph                         |
| GLI     | Great Lakes Instruments                   |
| gm, gms | Grams                                     |
| gph     | Gallons Per Hour                          |

ACRONYMS (Continued)

|                                 |                                    |
|---------------------------------|------------------------------------|
| gpm                             | Gallons Per Minute                 |
| HCl                             | Hydrochloric Acid                  |
| HNO <sub>3</sub>                | Nitric Acid                        |
| H <sub>2</sub> O, HOH           | Water                              |
| H <sub>2</sub> O <sub>2</sub>   | Hydrogen Peroxide                  |
| H <sub>2</sub>                  | Hydrogen Gas                       |
| H <sup>+</sup>                  | Hydrogen Ion                       |
| I                               | Input, Influent                    |
| IR                              | Infrared                           |
| JTU                             | Jackson Turbidity Unit             |
| K                               | Constant                           |
| KH <sub>2</sub> PO <sub>4</sub> | Potassium Phosphate                |
| LB/DAY                          | Pounds Per Day                     |
| LED                             | Light Emitting Diode               |
| LIT, L, l                       | Liter                              |
| LTB                             | Lauryl Tryptose Broth              |
| M                               | Molar Concentration                |
| m                               | Constant, Meter                    |
| MCL                             | Maximum Concentration Limit        |
| m <sup>3</sup> /s               | Cubic Meters Per Second (22.8 mgd) |
| mc/ml                           | Millions of Cells per Milliliter   |
| mgal                            | Millions of Gallons                |
| mgd                             | Millions of Gallons Per Day        |

ACRONYMS (Continued)

|                 |   |
|-----------------|---|
| mg/l            | Milligrams Per Liter                          |
| ml              | Milliliters                                   |
| ml/min          | Milliliters Per Minute                        |
| MPN             | Most Probable Number                          |
| mv              | Millivolt                                     |
| N               | Normal Concentration                          |
| n               | Number of Samples                             |
| N <sub>2</sub>  | Nitrogen                                      |
| NaOH            | Sodium Hydroxide                              |
| NASA            | National Aeronautics and Space Administration |
| NEDA            | N-1 Naphthyl-Ethylenediamine Hydrochloride    |
| NH <sub>3</sub> | Ammonia                                       |
| NTU             | Nephelometric Turbidity Units                 |
| O               | Output  |
| O/I             | Effluent (Output)/Influent (Input)            |
| O&M             | Operations and Maintenance                    |
| OZON            | Ozonation                                     |
| PMT             | Photomultiplier Tube                          |
| POX             | Purgeable Organic Halogens                    |
| ppb             | Parts Per Billion                             |
| ppm             | Parts Per Million                             |
| psi             | Pounds Per Square Inch                        |
| psig            | Pounds per Square Inch Gage                   |

## ACRONYMS (Continued)

|                  |   |
|------------------|---|
| PVC              | Polyvinyl Chloride  |
| Q                | Plant Flow, mgd   |
| Q <sub>W</sub>   | Wasted Sludge, mgd  |
| Q <sub>R</sub>   | Returned Sludge, mgd  |
| r                | Correlation Coefficient   |
| RDOS             | Real-Time Disk Operating System   |
| RO               | Reverse Osmosis   |
| RPM              | Revolutions Per Minute  |
| RTD              | Resistance Thermal Detector   |
| S <sub>a</sub>   | Aerator Substrate, mg/l TOC   |
| SCVWD-WRF/PA     | Santa Clara Valley Water District-Water Reclamation Facility at Palo Alto |
| sec              | Seconds   |
| S <sub>i</sub>   | Primary Effluent Substrate, mg/l TOC                                      |
| SiO <sub>2</sub> | Silicon Dioxide   |
| sorption         | Adsorption or Absorption  |
| TC               | Total Carbon  |
| TEC              | Techtronics   |
| THC              | Total Halocarbons   |
| TOC              | Total Organic Carbon  |
| TOX              | Total Organic Halogens  |
| T <sub>s</sub>   | Total Biomass in Aerator/Clarifier, mg                                    |
| UV               | Ultraviolet   |
| V <sub>a</sub>   | Aerator Volume, mgal  |

## ACRONYMS (Continued)

|            |  |
|------------|--|
| VAC        | Volts Alternating Current                                |
| $V_c$      | Clarifier Volume, mgal                                   |
| VDC        | Volts Direct Current                                     |
| $V_e$      | Chlorine Contact Volume, mgal                            |
| WMS        | Water Monitor System                                     |
| x          | Independent Variable                                     |
| $X_a$      | Biomass In Aerator, mc/ml                                |
| $X_c$      | Biomass in Clarifier Effluent, mc/ml                     |
| $X_e$      | Biomass in Effluent From Chlorine Contact Tank, mc/ml    |
| Y          | Mass Yield of Biomass per Unit Substrate Consumed, mg/mg |
| y          | Dependent Variable                                       |
| $\mu$      | Microns, Micro   |
| #          | Number   |
| %          | Percent  |
| $\sigma$   | Standard Deviation                                       |
| $\sigma_E$ | Standard Error of Estimate                               |
| Z          | The Number of Standard Deviations from the Mean          |



## SECTION 1.0

### INTRODUCTION

#### SCVWD-WRF/PA BACKGROUND

The Santa Clara Valley Water District, in cooperation with the Cities of Palo Alto, Los Altos, and Mountain View, embarked upon a developmental program of water reclamation and injection of the reclaimed water into underground aquifers in the South San Francisco bayfront area. The purposes of this program were to demonstrate the technical and economic feasibility of certain reclamation processes, and to attempt to provide a freshwater barrier to the intrusion of saltwater into a shallow aquifer. The wastewater supply to this system is the effluent from the Palo Alto Regional Water Quality Control Plant.

The Water Reclamation Plant provides tertiary treatment to the secondary effluent from the Palo Alto city plant, and in addition to its basic function of providing a supply for groundwater recharge, the reclamation plant can produce water of lesser quality for use in golf course irrigation or as a supplemental supply for the Palo Alto city plant's Reclaimed Water System for in-plant use.

The project took advantage of unused existing facilities at the Palo Alto plant in the construction of certain process units. An old clarifier was converted to a combined flocculator/clarifier, an unused sludge digestion tank has been used for reclaimed water storage, and an old vacuator structure has been adapted to house filters.

#### WMS BACKGROUND

As an outgrowth of its involvement in water reclamation and water quality monitoring for both spacecraft and domestic applications, NASA has conducted a project to develop and test an automated WMS (Water Monitor System). The objective of this project was to develop a system whereby water quality monitoring could be performed as it would be done in a spacecraft, on-line and in real-time. The design goal was to establish the capability to determine conformance to future high effluent quality standards, and thereby increase the potential for reclamation and reuse of wastewater. The resulting system includes both commercially available and NASA-developed sensors, an automated sample collection and distribution system, and a computerized data acquisition and reporting system. The project completed assembly and checkout of the WMS under separate contract (Reference 15). The project then entered into the field demonstration test phase which ended on February 28, 1981.

#### TEST PROGRAM

This report is a summary of test data recorded during the test period, January 1978 through February 1981. Data were recorded on the operation of the

reclamation facility and its individual processes and on the operation of the WMS. These data included reliability and availability statistics, downtime and maintenance, and operations costs. The test program was divided into two major parts. The first part of the test program and of this report covers the results of the data gathered by the WMS and the SCVWD from January 1978 to September 1979. The second portion of the test period and of this report covers the results of the data gathered from July 1980 through February 1981.

## SECTION 2

### PART I FIELD DEMONSTRATION TEST RESULTS

This section will cover the results from the data collected by the WMS and the Santa Clara Valley Water District.

#### TEST OBJECTIVES/ACCOMPLISHMENTS

The primary goal of this phase of the field demonstration program was to determine the benefits and costs of continuous monitoring as a basis for maintaining high effluent quality in a wastewater treatment application. In support of this goal, key test objectives were identified. The accomplishments, thus far, in satisfying these objectives are highlighted below.

1. Characterize treatment process performance and define the key parameters for maintaining an optimum effluent quality.

Accomplishments: The performance of each of the unit processes in the reclamation facility has been measured in terms of the WMS parameters over a wide range of operating conditions. These data, along with an interpretation of their meaning, are presented later in this section.

2. Define how the WMS concept of continuous automated monitoring might be applied in the reclamation facility.

Accomplishments: Several opportunities for process control have been identified. These are discussed at the end of this section. The potential economic impact of certain unusual control concepts is also presented. Additional work will be required before these concepts are proven feasible. The task of developing process control algorithms for normal process functions is currently in progress.

3. Demonstrate the performance of the NASA-developed sensors.

#### Accomplishments:

##### A. Chemiluminescence Biosensor

The capability for measuring viable as well as total bacteria was incorporated into the sensor. The sensor proved to be the most reliable method of measuring the performance of various processes for biological solids removal. (Dependence on the

biosensor for solids removal data has steadily increased with experience. The other major source of this information, turbidity, has proven to be of questionable value due to unexplained increases across the filtering process, possibly due to sensor susceptibility to entrained gases or to particle size.) However, efforts to correlate the biosensor to coliform, the current standard for effluent biological quality, were unsuccessful. This result might be expected considering that coliform represents less than 1 percent of the total bacterial population. A more comprehensive survey to relate the biosensor to other biological measures, including virus, might be fruitful but is beyond the scope of our current efforts. It was intended to test another potential biosensor application, biological control of the activated sludge process; however, resource constraints prevented the necessary planning. The operation of the bioluminescence (ATP) sensor was terminated when it was found that chemiluminescence, with the addition of the viable bacteria capability, provided similar information. Low operating cost and simplicity strongly favor chemiluminescence.

#### B. Hydrogen Sensing Coliform Detector

An extensive test program was performed to compare sensor performance against the standard method, MPN test. A random interference was found when testing water at very low concentrations, after disinfection. The interfering bacterium was isolated and was shown to imitate, by chemical means, the hydrogen gas production of the coliform. A change in the sensor configuration eliminated the interference problem.

#### C. Trace Organics Sensor

The gas chromatograph was calibrated for nine compounds which include the trihalomethanes - chloroform, bromodichloromethane, dibromochloromethane, and bromoform. The calibration results, as well as split samples with the Ames Research Center and Stanford University, have shown good accuracy down to at least a level of 5 ppb. Procedures have been developed to resolve recent problems with excessive column bleed. As discussed later in this section, the instrument has been useful in several instances but particularly in characterizing the solvent dumping practices of local industry.

#### 4. Characterize the performance of each element within the WMS in terms of availability.

Accomplishments: This section presents an evaluation of each of the WMS elements and reflects the reliability problems encountered with many of the commercial sensors.

## CONCLUSIONS

Continuous monitoring of various biological and physical/chemical treatment processes has identified certain key parameters which influence effluent quality. Work was conducted in order to expand and apply this knowledge by developing control algorithms where the monitoring system would be utilized for direct process control and housekeeping functions. The information collected shows that an automated monitoring system could support the following plant control functions, thereby maintaining effluent quality while preventing wasteful expenditures for consumables and energy.

1. Efficient solids removal in the flocculation process by optimum control of the feed rate of lime and flocculant aids, sludge return rate, and sludge wasting rate based on influent conditions.
2. Minimum aeration conditions (0, 1, or 2 aerators) for effective trace volatile organics removal to support desirable biological growth in the granular activated carbon (GAC) and to comply with effluent discharge restrictions for dissolved oxygen.
3. Filter backwash frequency based on head loss and effluent discharge restrictions on dissolved oxygen.
4. Activated carbon maintenance scheduling to provide acceptable performance at lowest maintenance cost.
5. Effluent neutralization by recarbonation dosage control to comply with the effluent restriction on pH.
6. Disinfection (chlorination and ozonation) based on flow and dosage requirement.
7. Selection of plant flow and process stream configuration based on desired effluent quality and existing influent conditions.

Of the 24 parameters measured by the WMS, a few provided the bulk of the useful information in that they reflected change in water quality produced in the reclamation processes. These were:

Total Organic Carbon  
Total Halocarbons  
Dissolved Oxygen  
Biomass  
Turbidity  
Total Residual Chlorine  
pH  
Ammonia  
Nitrate/Nitrite

Thus, these are the available parameters which, potentially, can support process control. The other inorganic parameters were essentially unchanged

in the treatment process since ion exchange or reverse osmosis is not among the reclamation processes at this site. On the other hand, the capability for measuring phosphorus and heavy metals, which are removed in lime clarification, was not available in the WMS. Thus, the contingent of sensors on-hand was not tailored to all specific needs of this particular facility but the data provided are judged to be adequate for the purpose, even though not comprehensive.

### Sample Collection and Distribution

The system provided itself to be extremely successful in doing what it was designed for: to continuously deliver both a filtered and unfiltered sample to the sensors. The system demonstrated its ability to filter samples ranging from tap water to primary effluent with a minimum amount of maintenance. The 50 micron stainless steel filters showed that they removed the large particles from the stream without affecting the parameters measured with filtered sample. It was found that the biggest hazard for the filters was grease from the sample. This was not only a problem during operation, but also during cleanup. After extensive testing, an effective method of cleaning the grease from the filters was developed. The system demonstrated that the concept of multipoint sampling is very feasible.

### Sensors

#### Commercial Sensors

The performance of the commercial sensors varied greatly. On one extreme, the Sigris Photometer performed throughout the test period with hardly a single malfunction and a minimum of required maintenance. On the other hand, the chloride analyzer was out of service 65% of the test period, either for repair at the manufacturer's or for troubleshooting at the WMS. The remainder of the commercial sensors fell somewhere between these two extremes. The major problem cited with these sensors as a group was reliability. Mechanical and electronic failures were a continuing problem. However, in defense of these sensors it must be noted that several of the sensors were not designed for the type of continuous 24-hours a day, seven days a week usage. Additionally, all these sensors are at least 42 months old, and several are over 50 months old. It is reasonable to expect that during that period of time the various manufacturers have made significant changes and improvements to their sensors. The feasibility of computer controlled auto standardization was successfully demonstrated. In any type of sensor operation, this would result in a significant decrease in the amount of manpower required to maintain and operate the system.

#### Chemiluminescence Biosensor

The state of the art for an automated chemiluminescence biosensor has come a long way during the test period. The mechanical and electronic reliability of the sensor has been extremely good, especially for a prototype.

### Coliform Detector

The coliform detector demonstrated itself to be quite reliable, both mechanically and electronically. The only significant electronic failures were the three electrodes, three thermistors, and two temperature control boards that failed. However, all these components were at least 3 years old at the time they failed. Both the reproducibility and validity of the detector adequately demonstrated using seeded samples.

### Gas Chromatograph

The gas chromatograph has proven to be a reliable instrument for monitoring volatile halogenated organics. The instrument has operated without any major problems since its installation over 1-1/2 years ago. The method was shown to be accurate down to 5 parts per billion. It appears that this level is the sensitivity limit with this method; however, this sensitivity should be sufficient for monitoring potable water.

The chromatography for the nine monitored compounds is adequate. The chromatography for methylene chloride and 1,2-dichloroethylene could be improved and would probably yield somewhat more accurate results. In addition, several as yet unidentified compound peaks can be found in the chromatograms. Identification of these peaks will provide additional information in the characterization of the water quality.

### Deionized Water System

The system functioned quite reliably throughout the test period. The only significant mechanical failures were those involving the pump impeller. These were typically due to operator error. Bacteria contamination of the storage reservoirs was periodically a problem. The system's capability to provide a continuous supply of reagent grade deionized water made the sensor system possible.

### Other Sensors

Attempts to develop a total nitrogen sensor were unsuccessful. The following describes the test system and problems encountered. The IBC/Berkeley Nitrogen Analyzer receives the noncondensable combustion gases from the TOD analyzer and determines the concentration of nitric oxide by measurement of the potential between two electrodes. During the combustion at 850°C, nitrogen compounds in the sample are converted to nitric oxide; thus, a total nitrogen reading is provided by the instrument in the range of 10 to 10000 ppm nitrogen. Testing results showed inconsistent performance for this measurement. It was discovered

that measurement sensitivity was considerably greater for nitrogen in the form of nitrates than that in the form of ammonia (about 5 to 1). It was concluded that a large portion of the ammonia nitrogen was being reduced to nitrogen gas ( $N_2$ ) rather than to nitric oxide (NO). A sensor utilizing chemiluminescence for detection was tried with similar results. Thus, a mixture of nitrogen compounds in a sample must be converted to a single form in order for this technique to be accurate.

## WMS PERFORMANCE EVALUATION

### Sample Collection and Distribution System

Figure 21 shows the location of the six sampling points used during the test period, which included water of a quality ranging from primary to tertiary treated wastewater. The system worked very well throughout the test period. Fifty micron woven stainless steel filters were used for filtration purposes for 80% of the test period. The remaining 20% of the time, thirty micron woven stainless steel filters were used. Due to the high flow rate of sample across the filter surface and the backflushing action, the system had no difficulty removing particles and debris from the sample stream. This was true even for the primary effluent sample from the Palo Alto waste treatment plant. However, what did present a problem was the grease contained in the primary and secondary effluent sample stream. Within about 4 days, the buildup of grease would be enough to reduce the filtered sample flow below the required 2000 ml/min. flow rate to the trailer. Additionally, when the filters were removed for cleaning, the grease was extremely difficult to remove. In order to prevent a loss of sample flow, a schedule was established where the filters were changed three times a week; on Monday, Wednesday, and Friday. This schedule proved to be extremely effective in preventing any significant drop in filtered sample flow rate. Various solvents, acids, and detergents were tested for their ability to clean the filter screens so they could be reused. Finally, a procedure was developed which thoroughly cleaned the filters. As soon as the filter screens were removed from the filter housing they were rinsed with tap water. Next, the filter screens were soaked in a solution of enzyme detergent and water overnight. The filter screens were then placed in a solution of Isoterge detergent and soaked overnight. The filter screens have been reused numerous times using this cleaning procedure.

Overall, the sample collection system performed well with only a minimal number of failures. During the test period four pump boots failed. Two of these were due to loss of sample flow over a long period of time (2 days). One boot failed due to a bad universal joint in the Monyo pump. The last boot failed due to overpressurization when two sample lines in the trailer became clogged. Also during the test period each pump had to have its bearings replaced. The Red Valves which are used on the sample collection system worked quite well. Five of the valve liners had to be replaced during the test period. Each of these five developed a small leak after almost a year of operation. Six of the Red Valves had tygon tubing used as a pneumatic line. This proved to be a mistake as the tygon softened with age. This resulted in three of the lines rupturing. All the lines were replaced with 1/4" polyethylene tubing. During the test period one of the Bimba air actuators used for the



backflush system failed. Additionally, the gears on one of the backflush timers had to be replaced due to excessive wear. The only parts of the system which had repeated failures were the pressure gauges. The original gauges had a life expectancy of 4 months due to pressure surges from the backflush system. Snubbers were installed on all the gauges. However, this did not solve the problem. Finally, the gauges were replaced with liquid filled gauges manufactured by U.S. Gauge.

#### Total Organic Carbon (TOC)/Total Oxygen Demand (TOD)

The Astro Ecology TOC/TOD Analyzer was modified to allow for computer controlled automatic calibration. This system consisted of two teflon air actuated slider valves, two pilot valves and two micro switches. The slider valves were used to switch from sample to either zero or span standards. The micro switches were used to send the valves status back to the computer.

The TOC analyzer worked quite reliably. However, several problems did show up during the test period. First, due to the high temperature (850°C) of the reactor, corrosion from the acid reagent caused the reactor to eventually fail. It appears that the life expectancy of the reactor is between 18 to 24 months. Another problem area was that the sample pumps were poorly located. If a pump tube failed it could result in water filling the furnace compartment. Since the construction of the WMS TOC Analyzer, the manufacturer has corrected both these problems. Due to the fact that the infrared analyzer was located in an adjoining rack, the line from the reactor to analyzer was longer than normal. As a result, condensation took place in the line. To prevent this, a 40 micron prefilter was installed in the line. Additionally, a trap was installed at the low point of the line. This prevented small amounts of moisture from accumulating and reducing the sample gas flow to the infrared analyzer. Also, a manual three-way valve was installed in the line to the 50 cc sample pump. This allowed grab samples to be easily tested. To verify the accuracy of the analyzer, numerous split samples were run in the SCVWD lab. The results of the comparisons showed good correlation of data. Comparisons were made with both TOC and TOD standards with less than 5% error. One of the difficulties with sampling of both primary effluent and Reclamation Plant effluent is that the analyzers must be scaled to read the high primary values. As a result the analyzer is not as exact as it would be on the lower scale. This was especially a problem for the TOC analyzer. The TOC values for primary effluent were often over 100 ppm, while they were as low as 1.0 ppm for the Reclamation Plant effluent.

The TOD analyzer used the same reactor as the TOC analyzer. The sample gas was routed from the reactor to the TOC infrared analyzer, then to the TOD analyzer, and lastly to the vent. A problem with the electronics overheating was discovered with the TOD analyzer. This was due to the location of the fiberglass box, which contained the electronics, within the same rack as the reactor. An attempt was made to relocate the electronics in another rack; however, it was found that the increased resistance from the longer wires was too high. The electronics were remounted in the old location. The door to the electronics was left open to allow cool air to enter. This stabilized the temperature and the data output. The most serious problem with the TOD analyzer was that the

analyzer was designed for a range of 0-1000 ppm and the water sampled was generally in the range of 10 ppm. As a result, the accuracy of the measurements varied. This was not so much a design problem with the analyzer as it was a problem of trying to apply an instrument intended for industrial effluent to reclaimed wastewater.

### Hardness Analyzer

The analyzer provided good, reliable data with few exceptions. The only problems encountered were when samples of primary effluent or secondary effluent were being analyzed. There is an apparent interference in the primary effluent which causes the analyzer to consistently read erroneously low values (less than 50 mg/L). The problem with the secondary effluent was apparent only 5% of the time. The analyzer would, on these occasions, show an erroneously high value. The interference would cause a jump in the reading of 200 to 500 ppm. The exact nature of the interference has yet to be determined. One possibility that is being studied is that the high residual chlorine level of the secondary effluent may be affecting the data. However, as stated earlier, the sensor operated very reliably 95% of the time. The other minor problems encountered during the test period included periodic rupturing of the analyzer's pump tubing. This problem was practically eliminated by replacing all the pump tubing every 2 months. Another problem was leaking "O" rings in the electrode holder. In the beginning of the test the "O" rings had to be replaced with a thin rubber gasket. This replacement gasket solved the problem.

### Nitrate Analyzer

The analyzer was only run during the first month of the Phase I test period. During that month it was found that the levels were consistently less than 1 ppm. It was decided by NASA and SCVWD that at that level the nitrate was not a concern and that it would not be necessary to continue to run the analyzer. During that brief period of operation the following observations were made. The analyzer is fairly labor intensive due to the wet chemistry method of analysis used. Two gallons of reagent must be mixed each week. Additionally, due to the large number of pumps and drains used in the system, the analyzer needed to be frequently monitored for leaks. While on-line the analyzer did provide accurate and reliable data.

### pH Analyzer

The Great Lakes Instrument Model 70 pH Analyzer generally provided good, reliable data. The sensor required calibration on an average of once a week during the test period. There was no serious fouling of the probe as a result of sampling primary or secondary effluent. The probe was removed once a month and checked for accumulations on the electrode. The electrode tip was cleaned in a 0.1 N acid solution if a significant accumulation was found. When calibrated, a pH standard of 7 was first used, then a pH standard of 10 was used to check the slope. One problem, which hampered operation of the sensor, was that air bubbles would come out of the sample and become trapped in the flow cell. When enough air bubbles would accumulate in the flow cell, the electrode would lose the necessary contact with the sample. This would result

in the analyzer reading approximately .5 pH unit lower than the sample actual value. To resolve this problem a hole was drilled into the top of the flow cell to vent off the trapped air. This modification worked quite well. Throughout the test period the analyzer was supplied with 50 micron filtered sample. Shortly after the end of the test period the analyzer began to generate slightly erratic data. The epoxy used to build the probe began to pull away from the electrode body. At this point the probe was replaced with a new probe. With the new probe installed, the results were as stable as ever. Based on this information, the life of the pH probe is estimated to be 3 years.

### Total Residual Chlorine Analyzer

The analyzer was generally very reliable and provided good, accurate data throughout the test period. The analyzer was modified with the WMS auto standardization system. The analyzer required a minimum amount of routine maintenance during the test period. The analyzer encountered some problems with clogging due to particles clumping together in the small diameter tubing (1/32") leading in and out of the flow head. It was found that this was not a significant problem as long as the analyzer was operated continuously. However, if the analyzer was shut down for any period of time over 3 hours, the chances of clogging were greatly increased. Therefore, it is recommended that if possible, avoid prolonged shutdowns of the analyzer. If the analyzer should run out of reagent, it is recommended that the data switch be turned off and the analyzer run with deionized water in place of the reagent. On several occasions the pump tubes for the analyzer would fail within the pump. To prevent this problem it is recommended that the pump tubes be replaced every 2 weeks. Throughout the first half of the test period the analyzer's results were compared once a week with the SCVWD lab results on a split sample. The results were consistently within .1 ppm of each other. Periodically, every 2 months, the electrodes were removed from the analyzer and polished with Orion Research polishing strips. This prevented an accumulation of debris. It is recommended that the two electrodes be replaced every 6 months. The schedule for auto calibration once a day appears to be fine. Both the zero and span drift in a 24-hour period are approximately .1% full scale.

### Sodium Analyzer

The Beckman Sodium Analyzer provided good data reliably throughout the majority of the test period. The only time that it did not perform was a two month period when it was out of service while awaiting arrival of a replacement sodium electrode. The major drawback to the analyzer is the high number of manhours required for routine maintenance. The analyzer is equipped with the WMS auto standardization system, and is calibrated once each day. One reason for the high number of manhours is that both gallon containers of standard (zero and span) must be refilled each day. Another reason is that the flow system must be disassembled and cleaned once each week. This is due to the fact that the anhydrous ammonia causes the particles in the sample to clump and settle in the flow system. The anhydrous ammonia is necessary to adjust the pH level of the sample prior to introducing it to the electrode. When

cleaning the electrode and flow system, it is suggested that a dilute solution of HCL be used. Split sample comparisons with SCVWD lab were routinely made during the first part of the test period. The results showed an excellent correlation within 20 ppm. Tests were run to see if the analyzer could be operated without the anhydrous ammonia in order to reduce the amount of required maintenance. The results of the tests indicate that without the ammonia pretreatment the values are approximately 50% lower than the actual value. One problem which was encountered was the unavailability of a replacement sodium electrode from Beckman. The original electrode was broken during a routine cleaning operation. When Beckman was contacted to order a new electrode there were none available off the shelf. A shorting problem had been found in the cable from the electrode to the analyzer. It took 2 months before the problem was fully resolved and the electrode delivered.

### Temperature Analyzer

The two Action Pac Resistance Thermal Detectors worked without any problem during the test period. One of the electronic boards had to be replaced when it shorted out due to a major water spill. The two units were then relocated to prevent a recurrence of the problem. The probes were periodically checked with a thermometer to verify their readings. They showed essentially no drift during the entire test period.

### Turbidity Analyzer

The Sigrist Photometer Turbidimeter Model UP52-TJ worked extremely well throughout the test period. The analyzer provided excellent data with a bare minimum of routine or unscheduled maintenance. The only component which failed during the entire test period was the replaceable light source. The only routine maintenance required by the instrument was a once a week cleaning of the mirror in the flow cell and a calibration. The TJ25 flow cell was used throughout the test period. The 0-100 mg/l SiO<sub>2</sub> standard was compatible with primary effluent and reclamation facility effluent. Some problems were encountered with the sample line running from the trailer wall to the analyzer. On several occasions the line would become clogged with debris. To resolve this problem the line was modified to remove all elbows and increase the diameter of the tubing. Since this modification was made there have been no more stoppages. A problem was also encountered with the drain line becoming clogged, resulting in an overflow of sample. This problem was resolved by removing the elbow in the drain line and doubling the diameter of the line.

### Ammonia Analyzer

A serious problem with precipitates greatly hampered operation of the sensor during the first part of the test period. The precipitate was brownish in color and would appear in the color analysis tube for the sample. The precipitate would build up to such a point that the data generated by the analyzer were invalid only a few hours after calibration. Extensive testing was done to find a method of preventing the precipitate from forming. Finally, it was found that by deleting the sodium nitroferricyanide reagent, the problem could be resolved. The manufacturer stated that for levels above 1.0 ppm of

ammonia, the sodium nitroferricyanide was not required. The stability of the analyzer improved greatly after making this change. The analyzer was calibrated for a range of 0-40 ppm. This range was satisfactory for the primary effluent as well as the reclamation plant effluent. Another problem area was the pump seals used in the analyzer's sample pump, reagent pump, and drain pump. These seals would last an average of two months before they would have to be removed and replaced. Once they were removed they could be reused after cleaning and soaking in tap water for 48 hours. The metricone had to be removed once during the test period. This was necessary to polish out several small grooves in the teflon metricone. The gear drive train for the metricone had to be replaced once during the test period. All the plastic fittings had to be resealed during the beginning of the test period. This was due to the fact that the adhesive used by the manufacturer was dissolved by the analyzer's reagents.

The analyzer was equipped with the WMS auto standardization system and was automatically calibrated once each day. The span standard solution needed to be replenished once a week, as did each of the two reagents. Because of this, the analyzer was quite labor intensive. Samples were repeatedly split with the SCVWD lab. The analyzer's results were consistently within .5 ppm of the standard method results. It was found that the overhead lights in the WMS trailer had a noticeable effect on the readings. Because of this it was decided that the interior trailer lights would be left on at all times to provide a consistent background light level.

#### Chloride Analyzer

Operation of the analyzer proved to be difficult throughout the test period. It appeared at the beginning of the test that the sensor was working reliably; however, the sensor soon began to show signs of severe drift problems. Extensive calibration tests failed to resolve the problem. The probe and associated electronics were shipped back to the manufacturer for repair. It was determined by the manufacturer that the probe needed to be replaced; a replacement probe was received. Initial calibration tests indicated that the new probe was stable and accurate. The instrument was remounted in the trailer; however, problems quickly appeared. The WMS values were consistently lower than the SCVWD lab results for a split sample. While efforts were underway to resolve that problem, the analyzer began to exhibit a new problem. The analyzer would calibrate quite well, but when a real sample was introduced, the sensor would start to drift upward. The start of the drifting would occur after approximately 4 hours in the sample stream. The readings would continue to drift upward until going off scale high. This would normally take about 3 days of the probe being in contact with the sample. If the probe was then placed in a standard solution, the readings would accurately indicate the value of the standard after a 2 hour period. A five times normal solution of sodium nitrate was tested as an ionic strength adjuster. It had no appreciable effect on the readings. At this point the probe and electronics were returned to the manufacturer for repair. It was determined that the probe was being poisoned by some unknown interference in the sample.

### Conductivity Analyzer

The Beckman analyzer performed throughout the test period without any significant problems. The values were frequently checked with SCVWD lab results for a split sample. The results showed excellent correlation ( $r = .99$ ). Periodically the flow cell was removed from the flow system and checked for buildup on the cell walls.

### Dissolved Oxygen Analyzer


The Delta Scientific D.O. analyzer performed quite well during the first half of the test period. However, the analyzer then began generating erratic data. The cause of the problem was not locatable. The probe and associated electronics were returned to the manufacturer for repair. The manufacturer found the probe had failed and had to be replaced. During its operational phase the analyzer was calibrated once a week. This was done using a zero standard and a span standard of known concentration. One problem encountered with the analyzer was that the sample line from the trailer wall to the probe would become blocked with debris. In order to resolve this problem, the line was replumbed to remove all the elbows and increase the diameter of the tubing. This left only one problem area, the flow control valve. It was found that this valve had to be watched closely to verify the flow rate to the probe. If the samples monitored included primary effluent or secondary effluent, it was necessary to check the flow cell weekly for a buildup of particulate matter.

The Honeywell Model 551011-00-01 dissolved oxygen sensor worked reliably throughout the majority of the test period. Some electronic problems developed with the sensor toward the end of the test period. As with the Delta Scientific D.O. sensor, it was necessary to replumb the sample line from the trailer wall to the sensor. This was done to prevent the sample line from clogging with debris. The analyzer was checked with a Hach wet chemistry D.O. kit on a weekly basis. Once each month the zero value was checked using a zero standard. The sensor experienced some contamination on the bottom of the flow cell and the probe. This especially became a problem when analyzing primary or secondary effluent. As a result, it was necessary to check the flow cell once a week for debris.

### Chemiluminescence Biosensor

The chemiluminescence biosensor currently processes and measures total and viable bacteria once each 1-hour period. Typical values measured in the various wastewater effluents monitored by the WMS are illustrated in Figure 1. The sensor is routinely calibrated using a Coulter electronic particle counter and the firefly luciferase - ATP assay for total and viable bacteria, respectively.

To measure viable bacteria with an automated luminol chemiluminescence system, the laboratory single sample injection method developed at Goddard Space Flight Center had to be converted to a flowing system where reagents



**Figure 1 Total and Viable Bacteria Levels in Various Waste Water Effluents**

and samples could be processed with peristaltic pumps. The major problem concerned handling the carbon monoxide-treated sample. It was known that light reverses the binding of the carbon monoxide with the iron porphyrins of viable bacteria. The carbon monoxide pretreatment had to be performed in the dark and the sample had to be protected from light until after the subsequent analysis. This was achieved by locating the carbon monoxide bubble chamber in a dark box and by using black tubing for transferring the sample from the chamber to the reaction coil.

In addition to the carbon monoxide required for the determination of viable bacteria, air had to be bubbled through the sample for accurate determination of total bacteria. Without the air treatment, total bacteria counts were artificially high, a fact still unexplained.

The biosensor schedule originally required 2 hours for a measurement of both total and viable bacteria. The schedule was later shortened to 1 hour after tests confirmed that sample flush, air/carbon monoxide treatments, and analysis times were sufficient for accurate quantitation.

A standard calibration method had to be developed to insure the accuracy and repeatability of the sensor. Calibrations were established using the Coulter electronic particle counter and the firefly luciferase - ATP assay for total and viable bacteria, respectively. The biosensor calibrations for total bacteria illustrated in Figure 4, Volume I, were reproducible for samples of cultured coliform bacteria or effluent samples. The calibration curve established by these points was  $y = 2.15 (X - (-3.714))$  where  $y$  equals  $10^6$  cells/ml and  $X$  equals biosensor response in volts.<sup>1</sup> The correlation coefficient was equal to 0.96. The viable bacteria correlation curve illustrated in Figure 5, Volume I, shows much more scatter when cultured bacteria and effluent samples are compared. This may be due not so much to variations in biosensor response but due to variations in the ATP levels within the organisms grown in different environments and subject to various degrees of stress.

The standard curve generated from the measurement of total bacteria is used for the calibration of the sensor. The stability and repeatability of these measurements make it the method of choice. Extensive research in the laboratory supports the extension of the method to calculate viable bacteria with relative confidence.

The sensor has a lower sensitivity limit of  $10^5$  cells/ml<sub>x</sub> which is adequate for most municipal wastewater applications. The range of the biosensor is adjustable from a minimum of 2 logs ( $10^5$ - $10^7$  range) upwards to infinity. Thus, the sensor can be readily adapted to measure concentrated solutions such as activated sludge ( $10^9$  cells/ml).

<sup>1</sup> The previously established calibration curve of  $y = 1.66 (X - (-10.32))$  has been left in the computer for the sake of subsequent comparison.



Correlation of the viable bacteria results of the biosensor presents special problems. Various values for viable bacteria can be obtained depending on the type of method employed. Each method measures a particular parameter associated with viability. The ATP method and luminol - CO method are measures of metabolism while the standard plate count method is a measure of the ability of a cell to reproduce and form colonies in an artificial environment. For this reason the luminol method cannot be expected to produce the same results as the plate counts. The ATP results have shown correlation with the luminol data; however, it is known that ATP levels within bacteria can fluctuate, depending on environmental conditions and growth phase. Due to this reason, the ATP method can be used for "ball park" comparison and some deviations should be expected. Other methods for monitoring viable bacteria should be examined to further support and verify the biosensor results.

### Coliform Detector

The major accomplishments concerning the coliform sensor are as follows:

1. An improved cleanup procedure was developed to better protect against cross contamination. The major improvement involved substituting 0.1 N nitric acid for sodium hypochlorite reagent. In conjunction with this change, larger volumes and longer residence times of the bactericide were used.
2. A new sensor configuration was devised to allow auto inoculation of a grab sample. The benefits gained from this action include better reproducibility, ease of inoculation, and progressing toward the point of on-line operation. Figure 9, Volume I shows the improved valve configuration along with a series of valve steps to facilitate computer controlled inoculation.
3. A series of calibration curves were developed. The information gathered was used to compare the sensor to a NASA Ames coliform sensor, establish sensitivity and reproducibility limits, and to demonstrate the degree of agreement between the sensor values and MPN values.

In order to calibrate the sensor, seeded samples were run and the reaction times were plotted against the MPN values obtained on the sample. The samples consisted of serial dilutions of unchlorinated secondary effluent using chlorinated secondary effluent (which had been dechlorinated) as diluent. The dechlorinated water was used as diluent in order to approximate the chemical composition of real world samples. Figures 10 and 11, Volume I show the fecal and total calibration curves which were obtained in the manner mentioned above. Linear regression analyses were run and gave the slope, y intercept, and r values for each calibration. For the fecal coliform calibration, the values were -1.26, 10.45 hrs., and 0.95, respectively. For the total calibration curve the values were -0.9, 9.04 hrs., and 0.95, respectively. By using the equation  $y = mx + b$ , the unknown (the original number of coliform bacteria in the sample) may be calculated. Whereas, y equals the original coliform concentration, m equals the slope, and b equals the y intercept. The reaction time is designated as the amount of time required to register a 200 m.v. drop from the electrode output.

The comparison between the WMS sensor and the impedance sensor showed that the instruments performed similarly. The r values for the WMS and impedance sensor were 0.95 and 0.98, respectively, for the fecal coliform calibration curve. For the total calibration curve, the r values were 0.95 and 0.96, respectively.

4. In the course of operating the coliform sensor, several cultures of bacteria (coliforms and non-coliforms) were obtained. It was discovered that one strain of non-coliform bacteria mimicked the m.v. response of coliform bacteria. This was a revelation in that previous experience had shown that non-coliform bacteria were incapable of driving the electrodes to the maximum negative point (-500 m.v.). This particular culture, however, gave negative responses equal to those of coliforms.
5. After it became apparent that the m.v. readings were influenced by end products of metabolism other than hydrogen, a new cell configuration was devised which allowed only evolved gas to reach the electrode. This process involves venting gas from the growth cell to another cell containing saline and the measuring electrode. The line from the growth cell is submerged in the saline of the measuring cell so the electrode will sense the dissolved gas. Preliminary work with the above configuration indicates that coliforms may be distinguished from non-coliforms in this manner. More experimentation was needed, however, to verify this system. (This additional work was conducted in Phase II of the test period and is reported in the Phase II section).
6. It has been determined that the lower limit of detection for the coliform sensor should be 2.2 coliforms per 100 ml. In order to achieve this level of sensitivity, it was deemed necessary to increase the sample size in order to increase the amount of coliforms inoculated.

### Gas Chromatograph

The automated gas chromatograph separates and quantifies a total of nine volatile halogenated hydrocarbons from wastewater samples within 50 minutes. Figure 2 is a typical electron capture detector (ECD) chromatograph from a secondary effluent sample using the current analytical column and temperature program. The calibration factors are based on calibrations using standards prepared in glacial acetic acid and diluted in distilled water prior to use. The data have been compared with NASA Ames Research Center and Stanford University Department of Civil Engineering for verification and found to be accurate to the 5 ppb level.

Preliminary testing involved the use of a flame ionization detector (FID) and ECD. Various methods were tested to determine the optimum means for monitoring the volatile organics. The FID proved to be inadequate for measuring the low concentrations of organics due to the sensitivity limit of the detector.




Figure 2 Typical Gas Chromatogram

Table 1 contains a list of the analytical columns and detectors tested and the reasons for their unacceptability. The principal criteria for column and detector selection were good separation of all the compounds of interest with sensitivity below 10 ppb and an analysis time less than 1 hour. The SP-1000 column used with the ECD met these criteria. While the SP-1000 column will not separate carbon tetrachloride from 1,1,1-trichloroethane, Stanford University has indicated that carbon tetrachloride levels are usually very low, <1 ppb. The 50-minute analysis time is sufficient to permit both analysis and data processing within the 1-hour period at sensitivity limit of 5 ppb.

The calibration method currently used was selected from several tested and is shown in Table 2. The calibration methods were similar, with the primary difference being the solvents used for the standards. Table 2 shows the repeatability of the methods as reflected by the standard deviation. Glacial acetic acid proved to be the best solvent with a repeatability of + 5% and a shelf life of at least 14 days. Figures 3 through 11 illustrate the calibration curves generated with the nine standards.

Data have been continually compared with Stanford University and Ames Research Center for verification of accuracy of the results. The most recent comparison with Stanford University is shown in Table 3. Split samples were taken and simultaneously analyzed. The results indicate good correlation for those compounds observed at concentrations greater than 5 ppb, the sensitivity limit of the method. Previous comparisons have shown similar results.

#### Deionized Water System

The deionized water system performed very reliably throughout the test period. The system continuously provided the required quality of water. Due to poor quality of tap water fed to the system, the various filter cartridges did not last as long as originally anticipated. However, this was not the fault of the system. As expected, the average life of the Reverse Osmosis cartridge was found to be 1 year. The only significant mechanical failures were those associated with the pump impellers. On four different occasions the impeller had to be replaced. These failures were generally due to operator errors. The best pressure setting for the system was found to be 14 psig. Bacteria growth in the storage tanks was a recurring problem. Plate counts were routinely taken to verify the bacteria level in the tanks. When the level rose above 10 cells/100 ml, the tanks were sanitized with sodium hypochlorite and then flushed. A problem was encountered with carbon fibers escaping the carbon filter and clogging the ion exchange filters. This proved to be a generic problem which was corrected by the manufacturer. The conductivity of the tap water and the RO filtered water was routinely checked to verify that the RO cartridge was removing 90% of the conductivity. Also, routinely the deionized water was checked on the gas chromatograph to verify that the carbon filter was removing the halogenated hydrocarbons. This proved to be a very useful test for this purpose.

#### Data Acquisition and Report Generation System

Several types of peripheral and computer equipment have been integrated to provide the real-time data acquisition and control capabilities of the WMS.

TABLE 1 COMPARISON OF GC ANALYTICAL COLUMNS

| COLUMN  | DETECTOR | COMMENT  |
|---|----------|--|
| 10' x 1/8" 10% SP-2250 (OV-17)  | FID      | Did not separate chloroform and 1,1,1-trichloroethane. Excessive column bleed. |
| 10' x 1/8" 15% Carbowax 1540<br>80-100 WAW  | FID      | Excessive column bleed.  |
| 100' x 0.020" K-20M on Carbopak-C   | FID      | Excessive column bleed.  |
| 10' x 1/8" 10% SP-2250 (OV-17)  | ECD      | Did not separate chloroform and 1,1,1-trichloroethane.                         |
| 10' x 1/8" 20% OV-101, 1%<br>Carbowax 1500 100-120 WAW and<br>20' x 1/8" 20% FFAP on 60/80<br>chrom WAW | ECD      | Separates all compounds; however, analysis requires 75 minutes to complete     |
| 11½' x 1/8" 0.2% SP-1000<br>on 80/100 Carbopak C  | ECD      | Does not separate carbon tetrachloride from 1,1,1-trichloroethane.             |

TABLE 2 REPRODUCIBILITY OF GC CALIBRATION MIXTURES  
MADE WITH VARIOUS SOLVENTS\*

| <u>SOLVENT</u>      | <u>AVERAGE<br/>STD. DEV. (%)</u> | <u>STORAGE<br/>TIME</u> |
|---------------------|----------------------------------|-------------------------|
| WATER               | 9.8                              | 8 HRS.                  |
| METHANOL            | 24.4                             | 8 HRS.                  |
|                     | 21.5                             | 4 DAYS                  |
| GLACIAL ACETIC ACID | 7.3                              | 8 HRS.                  |
|                     | 7.5                              | 7 DAYS                  |
|                     | 7.3                              | 14 DAYS                 |

\* Reproducibility based on tetrachloroethylene, chloroform, trichloroethylene, and bromoform in silanized glassware.




Figure 3 Calibration Curve for Tetrachloroethylene - #1

$$C = e^{1.115 \ln A - 14.45}$$




Figure 4 Calibration Curve for Methylene Chloride - #2

$$C = e^{1.244 \ln A - 9.370}$$






Figure 5 Calibration Curve 1, 2 - Dichloroethylene - #4  
 $C = e^{0.9731 \ln A - 6.297}$




Figure 6 Calibration Curve for Chloroform - #5

$$C = e^{1.209 \ln A - 13.96}$$




Figure 7 Calibration Curve for 1, 1, 1 - Trichloroethane - #6

$$C = e^{1.352 \ln A - 17.22}$$




Figure 8 Calibration Curve for Bromodichloromethane - #7

$$C = e^{0.9404 \ln A - 11.08}$$




Figure 9 Calibration Curve for Trichloroethylene - #8

$$C = e^{1.136 \ln A - 13.21}$$




Figure 10 Calibration Curve for Dibromochloromethane - #9

$$C = e^{0.8558 \ln A - 9.668}$$




Figure 11 Calibration Curve for Bromoform - #10

$$C = e^{0.9885 \ln A - 9.64}$$

ORIGINAL PAGE IS  
OF POOR QUALITY

TABLE 3

WMS-STANFORD UNIVERSITY VOLATILE ORGANIC  
ANALYSES COMPARISON SAMPLES 11/20/78-3/12/79

| No. | Compound                   | Conc. Range*<br>(ppb) | n  | Correlation<br>$\sim r$ | Slope<br>m | Intercept<br>b |
|-----|----------------------------|-----------------------|----|-------------------------|------------|----------------|
| 1   | Tetrachloroethylene        | 1.8 - 150.0           | 9  | 0.9696                  | 0.9274     | -1.3950        |
| 5   | Chloroform                 | 6.0 - 19.1            | 12 | 0.8388                  | 0.3147     | 4.4189         |
| 6   | 1,1,1-Trichloro-<br>ethane | 3.0 - 105.0           | 15 | 0.9817                  | 0.9767     | -1.1797        |
| 7   | Bromodichloro-<br>methane  | 0.5 - 4.0             | 15 | 0.8401                  | 0.2294     | 0.5071         |
| 8   | Trichloroethylene          | 0.2 - 36.0            | 12 | 0.9357                  | 0.8485     | 0.4911         |
| 9   | Dibromochloro-<br>methane  | 0.1 - 2.0             | 11 | 0.8706                  | 0.1770     | 0.1254         |
| 10  | Bromoform                  | 0.2 - 2.0             | 8  | 0.2952                  | 0.2655     | 0.3005         |

\* Based on Stanford University results

(X, Y); (WMS, Stanford)



Monitor Labs, Inc. peripheral equipment and device controllers have been interfaced to the Data General Corporation NOVA minicomputers via data bus extensions to the ML 4100 device control chassis. The ADAM system was designed and installed by Monitor Labs and has performed without significant incident.

The EVA system was designed to utilize the RDOS capabilities for real-time operations and the ML devices for valve control. The original EVE system was configured with a Data General NOVA 1200 (32K) and a Diablo disk drive (2.5 megabytes). Intermittent core memory problems caused by overheating; software problems with multitasking caused by the insufficient memory; and disk space occurred with this configuration. The EVE system was upgraded to a Data General NOVA 3D (64K), Phoenix disk drive (10 megabytes), and communication system in May 1978. The EVE combination of the ML 4100 device control chassis with the Data General communication chassis and disk system resulted in an extension of the data bus that initially produced some signal noise. The problem was resolved after about 6 months of operation at Santa Clara by modifying the cabling to terminate the NOVA 3D data bus at the communication chassis instead of the ML 4100.

### Data Reports

Report formats were developed to support a variety of data applications. These formats are described below.

#### Instantaneous Data Reports

Instantaneous data, updated each minute, are displayed to the operator on the CRT. The display provides the previous 1-minute value and the previous 15-minute, 30-minute, and hourly averages, and the running average for each available channel. A typical instantaneous report is shown in Figure 12. The first data set are the values for the secondary effluent, sample source 2, and the second data set are the values for the reclamation facility effluent, sample source 6. The sampling points are indicated on the flow schematic for the Santa Clara Valley Water District (SCVWD) facility, Figure 21. The instantaneous report presents a data scan that occurred at 06:00 hours. The results show consistent data for all but channels 1, 2, 8, 38, and 39 as indicated by the averages and status columns. Channel 8 for TOT OXY DEM is varying more than the specified limit and the Chemiluminescence sensor (Channels 1, 2, 38, and 39) show data were not being recorded (only the instantaneous voltage is displayed).

#### Daily Data Reports

The instantaneous and hourly peak values are monitored for each channel and for each sample source and reported as daily data. A typical daily data report for 24 hours is shown in Figure 13. The report includes the number of data points, the daily average, the instantaneous and hourly peak values, and the time of day each occurred for each source of water sampled throughout the day. The effluent sensors are the first data set printed, followed by each multipoint source. The total number of data points is always somewhat less than 1440 because of calibration and sensor stabilization required after the multipoint source is changed.

| TIME - 227:06:00:00 |                | SAMPLING POINT: SECONDARY EFFLUENT          |        |            |                  |                  |                  |                  |
|---------------------|----------------|---|--------|------------|------------------|------------------|------------------|------------------|
| CHA NO.             | SENSOR         | UNITS                                       | STATUS | INST VALUE | *** AVERAGES *** | *** AVERAGES *** |                  |                  |
|                     |                |   |        |            | 15 MIN           | 30 MIN           | 1 HR             | RUNNING          |
| 1.                  | TOTAL BIOMASS  | MIL C/M                                     | NDTA   | -0.261     | 0.000            | 17.609           | 17.609           | 17.624           |
| 2.                  | VIABLE BIOMASS | MIL C/M                                     | NDTA   | -0.261     | 0.000            | 0.000            | 0.000            | 13.369           |
| 5.                  | RES CHLORINE   | MG/L  |        | 0.2        | 0.3              | 0.2              | 0.2              | 7.0              |
| 6.                  | TURBIDITY-SiO2 | MG/L  |        | 10.9       | 11.0             | 11.0             | 11.1             | 14.1             |
| 8.                  | TOT OXY DEM    | MG/L  | VARI   | 257.       | 230.             | 220.             | 227.             | 255.             |
| 9.                  | TOT ORG CARB   | MG/L  |        | 12.9       | 12.0             | 12.0             | 12.9             | 12.4             |
| 10.                 | AMMONIA        | MG/L  |        | 19.1       | 10.9             | 10.9             | 10.9             | 10.0             |
| 12.                 | PH             | PH  |        | 7.04       | 7.05             | 7.06             | 7.08             | 7.08             |
| 13.                 | CHLORIDE       | MG/L  |        | 350.       | 356.             | 355.             | 350.             | 375.             |
| 14.                 | CONDUCTIVITY   | MMHO/CM                                     |        | 1500.0     | 1574.7           | 1575.0           | 1503.4           | 1597.6           |
| 16.                 | HARDNESS       | MG/L  |        | 306.       | 323.             | 334.             | 334.             | 241.             |
| 17.                 | SODIUM         | MG/L  |        | 192.       | 187.             | 174.             | 170.             | 171.             |
| 19.                 | DIS OXYGEN-HW  | MG/L  |        | 3.3        | 3.3              | 3.3              | 3.3              | 3.3              |
| TIME - 227:06:00:00 |                | SAMPLING POINT: RECLAMATION FAC. A EFFLUENT |        |            |                  |                  |                  |                  |
| CHA NO.             | SENSOR         | UNITS                                       | STATUS | INST VALUE | *** AVERAGES *** | *** AVERAGES *** | *** AVERAGES *** | *** AVERAGES *** |
|                     |                |   |        |            | 15 MIN           | 30 MIN           | 1 HR             | RUNNING          |
| 3.                  | AIR COMP       | PSIA  |        | 14.7       | 14.7             | 14.7             | 14.7             | 14.7             |
| 15.                 | TEMPERATURE#1  | DEG F                                       |        | 70.4       | 70.4             | 70.4             | 70.4             | 70.7             |
| 18.                 | TURBIDITY-HW   | FTU   |        | 2.00       | 2.00             | 2.01             | 2.03             | 2.30             |
| 20.                 | TEMPERATURE#2  | DEG F                                       |        | 60.4       | 60.4             | 60.4             | 60.4             | 70.4             |
| 23.                 | EFFLUENT       | PSIA  |        | 23.7       | 22.7             | 22.1             | 22.7             | 23.3             |
| 30.                 | TOTAL BIOMASS  | MIL C/M                                     | NDTA   | -0.261     | 0.000            | 0.000            | 0.000            | 0.000            |
| 39.                 | VIABLE BIOMASS | MIL C/M                                     | NDTA   | -0.261     | 0.000            | 0.000            | 0.000            | 0.000            |

Figure 12 Typical Instantaneous Data Report

## DAILY REPORT FOR: 6-RECLAMATION FAC. A EFFLUENT

9/ 3/78 24:00:00

| CHA NO. | SENSOR        | UNITS   | DATA POINTS | DAILY AVERAGE | INSTANTANEOUS PEAK |       | HOURLY PEAK |       |
|---------|---------------|---------|-------------|---------------|--------------------|-------|-------------|-------|
|         |               |         |             |               | VALUE              | TIME  | VALUE       | TIME  |
| 3.      | AIR COMP      | PSIA    | 1440        | 14.7          | 14.7               | 14:29 | 14.7        | 14: 0 |
| 15.     | TEMPERATURE#1 | DEG F   | 1440        | 80.5          | 86.4               | 14:29 | 85.9        | 14: 0 |
| 18.     | TURBIDITY-HW  | FTU     | OUT         |               |                    |       |             |       |
| 20.     | TEMPERATURE#2 | DEG F   | 1440        | 67.4          | 69.2               | 11: 0 | 66.7        | 14: 0 |
| 23.     | EFFLUENT      | PSIA    | 1440        | 23.1          | 29.1               | 10:59 | 23.7        | 11: 0 |
| 30.     | TOTAL BIOMASS | MIL C/M | OUT         |               |                    |       |             |       |
| 39.     | VIALE BIOMASS | MIL C/M | OUT         |               |                    |       |             |       |

## DAILY REPORT FOR: 3-SECONDARY EFFLUENT

9/ 3/78 24:00:00

| CHA NO. | SENSOR         | UNITS   | DATA POINTS | DAILY AVERAGE | INSTANTANEOUS PEAK |       | HOURLY PEAK |       |
|---------|----------------|---------|-------------|---------------|--------------------|-------|-------------|-------|
|         |                |         |             |               | VALUE              | TIME  | VALUE       | TIME  |
| 1.      | TOTAL BIOMASS  | MIL C/M | 6           | 10.39         | 16.93              | 1:44  | 16.93       | 2: 0  |
| 2.      | VIALE BIOMASS  | MIL C/M | 6           | 6.52          | 10.39              | 2:59  | 10.39       | 3: 0  |
| 5.      | RES CHLORINE   | MG/L    | 563         | 10.5          | 17.7               | 10:15 | 16.7        | 11: 0 |
| 6.      | TURBIDITY-SI02 | MG/L    | 720         | 8.4           | 11.6               | 17: 3 | 10.3        | 2: 0  |
| 8.      | TOT OXY DEM    | MG/L    | 187         | 62.           | 104.               | 5:28  | 78.         | 6: 0  |
| 9.      | TOT ORG CARB   | MG/L    | 563         | 11.8          | 15.3               | 1:33  | 13.8        | 6: 0  |
| 10.     | AMMONIA        | MG/L    | 515         | 12.4          | 22.5               | 2:39  | 20.5        | 3: 0  |
| 12.     | PH             | PH      | 594         | 7.62          | 7.96               | 5: 1  | 7.77        | 2: 0  |
| 13.     | CHLORIDE       | MG/L    | 604         | 278.          | 294.               | 19: 0 | 292.        | 2: 0  |
| 14.     | CONDUCTIVITY   | MMHO/CM | 720         | 1401.9        | 1490.0             | 17:18 | 1459.2      | 18: 0 |
| 16.     | HARDNESS       | MG/L    | 563         | 180.          | 663.               | 10:45 | 629.        | 11: 0 |
| 17.     | SODIUM         | MG/L    | 720         | 167.          | 228.               | 1:12  | 176.        | 10: 0 |
| 19.     | DIS OXYGEN-HW  | MG/L    | 720         | 2.4           | 2.5                | 7: 0  | 2.4         | 7: 0  |
| 29.     | TOT HALOCARBON | PPB     | OUT         |               |                    |       |             |       |

## DAILY REPORT FOR: 6-RECLAMATION FAC. A EFFLUENT

9/ 3/78 24:00:00

| CHA NO. | SENSOR         | UNITS   | DATA POINTS | DAILY AVERAGE | INSTANTANEOUS PEAK |       | HOURLY PEAK |       |
|---------|----------------|---------|-------------|---------------|--------------------|-------|-------------|-------|
|         |                |         |             |               | VALUE              | TIME  | VALUE       | TIME  |
| 1.      | TOTAL BIOMASS  | MIL C/M | 5           | 1.76          | 3.37               | 15:44 | 3.37        | 16: 0 |
| 2.      | VIALE BIOMASS  | MIL C/M | 6           | 0.56          | 1.73               | 4:59  | 1.73        | 5: 0  |
| 5.      | RES CHLORINE   | MG/L    | 470         | 3.3           | 5.6                | 12:27 | 4.3         | 12: 0 |
| 6.      | TURBIDITY-SI02 | MG/L    | 660         | 2.1           | 4.1                | 19: 4 | 3.1         | 16: 0 |
| 8.      | TOT OXY DEM    | MG/L    | 141         | 28.           | 54.                | 0:48  | 42.         | 1: 0  |
| 9.      | TOT ORG CARB   | MG/L    | 470         | 6.2           | 8.1                | 19:27 | 7.2         | 8: 0  |
| 10.     | AMMONIA        | MG/L    | 445         | 10.0          | 12.5               | 12:39 | 12.1        | 4: 0  |
| 12.     | PH             | PH      | 534         | 7.93          | 7.98               | 0:57  | 7.97        | 9: 0  |
| 13.     | CHLORIDE       | MG/L    | 564         | 268.          | 275.               | 0:54  | 272.        | 1: 0  |
| 14.     | CONDUCTIVITY   | MMHO/CM | 660         | 1382.4        | 1430.0             | 19: 1 | 1395.5      | 13: 0 |
| 16.     | HARDNESS       | MG/L    | 467         | 169.          | 2128.              | 12: 0 | 527.        | 12: 0 |
| 17.     | SODIUM         | MG/L    | 660         | 154.          | 220.               | 7: 1  | 156.        | 17: 0 |
| 19.     | DIS OXYGEN-HW  | MG/L    | 660         | 2.4           | 2.5                | 7: 3  | 2.4         | 8: 0  |
| 29.     | TOT HALOCARBON | PPB     | OUT         |               |                    |       |             |       |

Figure 13 Typical Daily Data Report

### Historical Data Reports

The historical reports provide the hourly averages for the current day or any day within a 3-month period. The historical data file is a rotating file that is designed to contain 93 days of actual data. Only the sample source data recorded for each day are stored on the disk file. Whenever 93 days have been recorded, the next day is positioned at the beginning of the historical file, effectively rewinding the file for subsequent recording.

A typical historical report is shown in Figure 14. The hourly averages for the hour ending and sample source are shown for a complete day. The sample source shown for each hour indicates the multipoint source sampled for the hour. A blank indicates no data was recorded for the hour.

### Coliform Biosensor Data Reports

Coliform results require 3 to 14 hours for determination following cell inoculation. The results are available for individual cells after the minimum voltage and 200 millivolt time have been determined. A typical coliform report is shown in Figure 15. The first data set for 8-25-78 are actually for a current day in which no cells have completed reaction or have attained a minimum volt level, and the second data set for 2-14-78 are for a previous day. The report includes the inoculation time, the time at which the minimum voltage was attained, the value of the minimum voltage, the reaction time, and the cell count. The coliform evaluation is not terminated until the maximum reaction time has elapsed since inoculation of the last cell. The results are reported as cells/100 ml. Figure 15 shows that total coliform were evaluated on 8-25-78 and the cell count varied from a minimum value of 190,000 for cell #1 to a maximum value of 290,000 for cell #7.

### Volatile Halocarbon Concentration and Data Reports

The gas chromatograph is a modified Hewlett-Packard Model 5710/5840 that is fully automated and operates under internal program control. The processing time requires 50 minutes for a complete analysis of nine volatile halogenated hydrocarbons. An Electron Capture Detector (ECD) is used for accurate quantitating at the parts per billion (ppb) level. The gas chromatograph is normally scheduled to begin processing at the start of each hour. The GC results are printed on the calculator and transmitted to the EVE interface approximately 50 minutes after the hour. Only the number and compound area are required by EVE because a modified calibration curve is used to determine the measured concentration based on the area. The EVE calibration curve is exponential with constants for the slope and intercept ( $Y = e^{ax} + b$ ).

The halocarbon concentrations are summed and recorded as an hourly average of total halocarbon on channel 29. The calibration curves presently used have an accuracy of  $\pm 10\%$  at the parts per billion (ppb) level. The brominated compounds have a threshold limit of 3 ppb and the chlorinated compounds have a threshold limit of 1 ppb.

8/24/78 HOURLY AVERAGES FOR MULTIPOINT SENSORS

| CHA NO. | SENSOR         | UNITS   | HOUR OF DAY/SAMPLE |        |        |        | SOURCE |        |
|---------|----------------|---------|--------------------|--------|--------|--------|--------|--------|
|         |                |         | 1/6                | 2/3    | 3/3    | 4/6    | 5/6    | 6/3    |
| 1.      | TOTAL BIOMASS  | MIL C/M |                    |        |        |        |        |        |
| 2.      | VIABLE BIOMASS | MIL C/M | 0.57               | 18.16  | 18.18  | 0.58   | 0.61   | 12.61  |
| 5.      | RES CHLORINE   | MG/L    | 2.4                | 6.3    | 6.5    | 2.5    |        | 7.7    |
| 6.      | TURBIDITY-S102 | MG/L    | 2.0                | 12.2   | 10.4   | 2.0    | 2.0    | 0.6    |
| 8.      | TOT OXY DEM    | MG/L    | 55.                | 78.    | 89.    | 58.    |        | 182.   |
| 9.      | TOT ORG CARB   | MG/L    | 8.4                | 14.5   | 14.6   | 9.2    |        | 14.1   |
| 10.     | AMMONIA        | MG/L    | 13.4               | 21.6   | 22.0   | 15.1   |        | 19.5   |
| 12.     | PH             | PH      | 7.24               | 7.10   | 7.10   | 7.23   | 7.26   | 7.11   |
| 13.     | CHLORIDE       | MG/L    | 292.               | 307.   | 306.   | 279.   | 279.   | 200.   |
| 14.     | CONDUCTIVITY   | MMHO/CM | 1555.3             | 1487.7 | 1475.2 | 1543.3 | 1368.2 | 1517.5 |
| 16.     | HARDNESS       | MG/L    | 243.               | 141.   | 138.   | 239.   |        | 160.   |
| 17.     | SODIUM         | MG/L    | 200.               | 194.   | 194.   | 206.   |        |        |
| 19.     | DIS OXYGEN-HU  | MG/L    | 2.9                | 2.9    | 2.9    | 2.9    | 2.9    | 2.9    |
| 29.     | TOT HALOCARBON | PPB     | 143.               |        | 778.   |        | 78.    |        |

| CHA NO. | SENSOR         | UNITS   | HOUR OF DAY/SAMPLE |        |        |        | SOURCE |        |
|---------|----------------|---------|--------------------|--------|--------|--------|--------|--------|
|         |                |         | 7/3                | 8/3    | 9/6    | 10/3   | 11/3   | 12/6   |
| 1.      | TOTAL BIOMASS  | MIL C/M |                    |        |        |        |        |        |
| 2.      | VIABLE BIOMASS | MIL C/M | 12.62              | 0.12   | 0.14   | 13.48  | 13.51  |        |
| 5.      | RES CHLORINE   | MG/L    | 0.1                |        | 3.9    | 6.3    | 6.4    | 2.0    |
| 6.      | TURBIDITY-S102 | MG/L    | 7.6                |        | 2.0    | 9.7    | 11.4   | 2.9    |
| 8.      | TOT OXY DEM    | MG/L    | 99.                |        | 56.    | 111.   | 139.   | 120.   |
| 9.      | TOT ORG CARB   | MG/L    | 13.9               |        | 0.4    | 12.3   | 12.5   | 7.6    |
| 10.     | AMMONIA        | MG/L    | 19.0               |        | 14.1   |        | 19.5   | 16.3   |
| 12.     | PH             | PH      | 7.09               |        | 7.21   | 7.00   | 6.93   | 7.31   |
| 13.     | CHLORIDE       | MG/L    | 295.               |        | 261.   | 285.   | 293.   | 296.   |
| 14.     | CONDUCTIVITY   | MMHO/CM | 1468.3             | 1523.3 | 1554.0 | 1513.5 | 1475.3 | 1533.8 |
| 16.     | HARDNESS       | MG/L    | 175.               |        | 293.   | 160.   | 153.   | 219.   |
| 17.     | SODIUM         | MG/L    |                    |        |        |        |        | 155.   |
| 19.     | DIS OXYGEN-HU  | MG/L    | 2.9                | 2.9    | 2.9    | 2.9    | 2.9    | 2.9    |
| 29.     | TOT HALOCARBON | PPB     | 659.               |        | 82.    |        | 620.   |        |

| CHA NO. | SENSOR         | UNITS   | HOUR OF DAY/SAMPLE |        |        |        | SOURCE |        |
|---------|----------------|---------|--------------------|--------|--------|--------|--------|--------|
|         |                |         | 13/6               | 14/3   | 15/3   | 16/6   | 17/6   | 18/3   |
| 1.      | TOTAL BIOMASS  | MIL C/M |                    |        |        |        |        |        |
| 2.      | VIABLE BIOMASS | MIL C/M |                    | 12.48  | 12.36  |        | 0.02   | 11.00  |
| 5.      | RES CHLORINE   | MG/L    | 1.7                | 6.2    | 6.2    | 2.4    | 2.5    | 6.6    |
| 6.      | TURBIDITY-S102 | MG/L    | 3.6                | 13.5   | 10.6   | 2.2    | 2.2    | 10.6   |
| 8.      | TOT OXY DEM    | MG/L    | 116.               | 153.   | 165.   | 113.   | 130.   | 182.   |
| 9.      | TOT ORG CARB   | MG/L    | 7.1                | 11.6   | 12.2   | 7.9    | 7.3    | 12.7   |
| 10.     | AMMONIA        | MG/L    | 16.5               | 19.1   | 19.7   | 17.7   | 16.0   | 18.2   |
| 12.     | PH             | PH      | 7.33               | 6.90   | 6.86   | 7.24   | 7.23   | 6.90   |
| 13.     | CHLORIDE       | MG/L    | 307.               | 306.   | 310.   | 295.   | 299.   | 310.   |
| 14.     | CONDUCTIVITY   | MMHO/CM | 1539.0             | 1541.7 | 1546.0 | 1526.7 | 1538.0 | 1538.7 |
| 16.     | HARDNESS       | MG/L    | 221.               | 150.   | 147.   | 222.   | 227.   | 150.   |
| 17.     | SODIUM         | MG/L    | 151.               | 136.   | 131.   | 120.   | 123.   | 120.   |
| 19.     | DIS OXYGEN-HU  | MG/L    | 2.0                | 2.0    | 2.0    | 2.0    | 2.0    | 2.7    |
| 29.     | TOT HALOCARBON | PPB     |                    |        | 618.   |        | 196.   |        |

| CHA NO. | SENSOR         | UNITS   | HOUR OF DAY/SAMPLE |        |        |        | SOURCE |        |
|---------|----------------|---------|--------------------|--------|--------|--------|--------|--------|
|         |                |         | 19/3               | 20/6   | 21/6   | 22/3   | 23/3   | 24/6   |
| 1.      | TOTAL BIOMASS  | MIL C/M |                    |        |        |        |        |        |
| 2.      | VIABLE BIOMASS | MIL C/M | 0.97               | 0.93   |        | 20.47  | 15.13  | 1.01   |
| 5.      | RES CHLORINE   | MG/L    | 6.7                | 2.6    | 2.6    | 6.5    | 6.5    | 2.6    |
| 6.      | TURBIDITY-S102 | MG/L    | 10.1               | 1.7    | 1.0    | 11.5   | 10.0   | 1.0    |
| 8.      | TOT OXY DEM    | MG/L    | 161.               | 100.   | 76.    | 102.   | 90.    | 54.    |
| 9.      | TOT ORG CARB   | MG/L    | 13.3               | 7.7    | 7.2    | 13.7   | 14.1   | 7.8    |
| 10.     | AMMONIA        | MG/L    | 19.0               | 13.6   | 13.4   | 18.7   | 18.9   | 13.7   |
| 12.     | PH             | PH      | 6.98               | 7.26   | 7.29   | 7.10   | 7.09   | 7.27   |
| 13.     | CHLORIDE       | MG/L    | 307.               | 297.   | 297.   | 290.   | 299.   | 295.   |
| 14.     | CONDUCTIVITY   | MMHO/CM | 1514.5             | 1526.3 | 1534.5 | 1477.7 | 1460.0 | 1529.7 |
| 16.     | HARDNESS       | MG/L    | 152.               | 225.   | 235.   | 156.   | 149.   | 231.   |
| 17.     | SODIUM         | MG/L    | 120.               | 150.   | 150.   | 136.   | 122.   | 124.   |
| 19.     | DIS OXYGEN-HU  | MG/L    | 2.7                | 2.7    | 2.7    | 2.7    | 2.7    | 2.7    |
| 29.     | TOT HALOCARBON | PPB     | 702.               |        | 89.    |        | 899.   |        |

Figure 14 Typical Historical Data Report

| COLIFORM REPORT:                 |  | ***** SENSOR ***** |       |       |       |       |       |       |       | 8/25/78 |
|----------------------------------|--|--------------------|-------|-------|-------|-------|-------|-------|-------|---------|
|                                  |  | 1                  | 2     | 3     | 4     | 5     | 6     | 7     | 8     |         |
| INOCULATION TIME                 |  | 10:44              | 10:40 | 10:52 | 10:56 | 11:0  | 11:4  | 11:0  | 11:12 |         |
| MINIMUM VOLTS TIME               |  | 14:53              | 14:50 | 14:50 | 14:50 | 14:50 | 14:50 | 14:50 | 14:50 |         |
| VALUE                            |  | 36                 | 76    | -6    | 33    | 107   | -13   | 96    | 40    |         |
| 200MV TIME                       |  |                    |       |       |       |       |       |       |       |         |
| REACTION TIME                    |  |                    |       |       |       |       |       |       |       |         |
| LOG10(CELLS/ML)                  |  |                    |       |       |       |       |       |       |       |         |
| TOTAL                            |  |                    |       |       |       |       |       |       |       |         |
| FECAL                            |  |                    |       |       |       |       |       |       |       |         |
| MAXIMUM REACTION TIME = 14 HOURS |  |                    |       |       |       |       |       |       |       |         |
| COLIFORM REPORT:                 |  | ***** SENSOR ***** |       |       |       |       |       |       |       | 2/14/78 |
|                                  |  | 1                  | 2     | 3     | 4     | 5     | 6     | 7     | 8     |         |
| INOCULATION TIME                 |  | 24:10              | 24:14 | 24:10 | 24:22 | 24:26 | 24:30 | 24:34 | 24:30 |         |
| MINIMUM VOLTS TIME               |  | 25:30              | 25:35 | 25:30 | 25:30 | 25:55 | 25:34 | 25:37 | 25:39 |         |
| VALUE                            |  | 00                 | 04    | 49    | 112   | 00    | 92    | 73    | 83    |         |
| 200MV TIME                       |  | 29:14              | 29:2  | 29:12 | 29:7  | 29:27 | 29:22 | 29:17 | 29:30 |         |
| REACTION TIME                    |  | 5:4                | 4:40  | 4:54  | 4:45  | 5:1   | 4:52  | 4:43  | 4:52  |         |
| CELLS/100ML                      |  |                    |       |       |       |       |       |       |       |         |
| TOTAL                            |  | 1.9E5              | 2.6E5 | 2.3E5 | 2.8E5 | 2.0E5 | 2.4E5 | 2.9E5 | 2.4E5 |         |
| FECAL                            |  |                    |       |       |       |       |       |       |       |         |

Figure 15 Typical Coliform Data Report

Reports are normally available every hour for trace concentrations of the brominated and chlorinated halocarbon compounds for the multipoint sample source. A typical report is shown in Figure 16 and includes the calibration number, compound name, hour of day, and sample source for each halocarbon.

### Daily and Monthly Reports

Plotting capability is provided by separate programs for daily and monthly results. The NOVA 3D resources are allocated for FVE report generation in the foreground and plotting in the background memory partitions. The hourly plot program will graph the hourly averages of any three channels for the same day. The monthly plot program will graph the daily averages of any one channel for any month. The plot data are recalled from the historical data file that is shared by the EVE report generation program.

A typical hourly plot is shown in Figure 17. Three channels are plotted for the multipoint sample sources 1 and 3. The data points are annotated with the sample source number that is identified at the top of the graph. The scaling parameters are selected by the operator for each channel during the plotting process.

A typical monthly plot is shown in Figure 18. The daily average, standard deviation, hourly peak, and hourly peak time are plotted for the month. The sample source is indicated by the square plot symbol and a highlighted sample source identification at the top of the graph. The daily averages are indicated by the square symbol for each day plotted. The hourly peak values are indicated at the top of the lower plot.

### Sample Source Trend Report

Hourly average values of a parameter over a period of a month for a given point in the treatment process can be determined using the format illustrated in Figure 19. The average for each hour of the day that the process was sampled is reported for each day of the month. The data are also summarized in terms of the daily average.

### Statistical Report

The performance of a single process or group of processes in terms of percent removal can be reported as illustrated in Figure 20. Influent and effluent values are compared, including number of days sampled, monthly averages, daily and hourly variations ( $1\sigma$ ), and the average and variation ( $1\sigma$ ) in daily removal. Figure 20 shows these data for reclamation plant influent and effluent and thus reflects plant overall monthly performance.

8/24/78 HALOCARBON CONCENTRATIONS - PPB

| CAL NO. | COMPOUND              | * * * * HOUR OF DAY/SAMPLE SOURCE * * * * |     |       |     |      |     |
|---------|-----------------------|---|-----|-------|-----|------|-----|
|         |                       | 1/6                                       | 2/3 | 3/3   | 4/6 | 5/6  | 6/3 |
| 1.      | TETRACHLOROETHYLENE   | 10.4                                      |     | 100.0 |     | 14.8 |     |
| 2.      | METHYLENE CHLORIDE    | 5.9                                       |     | 19.9  |     |      |     |
| 3.      | 1,1-DICHLOROETHYLENE  | 1.6                                       |     |       |     |      |     |
| 4.      | 1,2-DICHLOROETHYLENE  | 42.2                                      |     |       |     |      |     |
| 5.      | CHLOROFORM            | 32.1                                      |     | 87.2  |     | 22.9 |     |
| 6.      | 1,1,1-TRICHLOROETHANE | 9.9                                       |     | 220.1 |     | 10.4 |     |
| 7.      | BROMODICHLOROMETHANE  | 4.9                                       |     | 5.3   |     | 3.9  |     |
| 8.      | TRICHLOROETHYLENE     | 20.2                                      |     | 300.4 |     | 19.3 |     |
| 9.      | DIBROMOCHLOROMETHANE  | 3.8                                       |     | 9.8   |     | 3.1  |     |
| 10.     | BROMOFORM             | 3.7                                       |     | 2.1   |     | 3.5  |     |

| CAL NO. | COMPOUND              | * * * * HOUR OF DAY/SAMPLE SOURCE * * * * |     |      |      |       |      |
|---------|-----------------------|---|-----|------|------|-------|------|
|         |                       | 7/3                                       | 8/3 | 9/6  | 10/3 | 11/3  | 12/6 |
| 1.      | TETRACHLOROETHYLENE   | 76.4                                      |     | 12.7 |      | 51.0  |      |
| 2.      | METHYLENE CHLORIDE    | 9.2                                       |     |      |      | 0.2   |      |
| 3.      | 1,1-DICHLOROETHYLENE  |   |     | 1.6  |      |       |      |
| 4.      | 1,2-DICHLOROETHYLENE  |   |     |      |      | 15.2  |      |
| 5.      | CHLOROFORM            | 82.5                                      |     | 27.7 |      | 62.8  |      |
| 6.      | 1,1,1-TRICHLOROETHANE | 156.4                                     |     | 10.2 |      | 126.1 |      |
| 7.      | BROMODICHLOROMETHANE  | 7.1                                       |     | 4.1  |      | 7.4   |      |
| 8.      | TRICHLOROETHYLENE     | 313.5                                     |     | 19.0 |      | 333.0 |      |
| 9.      | DIBROMOCHLOROMETHANE  | 11.3                                      |     | 3.2  |      | 12.0  |      |
| 10.     | BROMOFORM             | 2.6                                       |     | 3.2  |      | 4.5   |      |

| CAL NO. | COMPOUND              | * * * * HOUR OF DAY/SAMPLE SOURCE * * * * |      |       |      |      |      |
|---------|-----------------------|---|------|-------|------|------|------|
|         |                       | 13/6                                      | 14/3 | 15/3  | 16/6 | 17/6 | 18/3 |
| 1.      | TETRACHLOROETHYLENE   |   |      | 62.3  |      | 14.0 |      |
| 2.      | METHYLENE CHLORIDE    |   |      | 8.0   |      | 6.3  |      |
| 3.      | 1,1-DICHLOROETHYLENE  |   |      |       |      | 1.7  |      |
| 4.      | 1,2-DICHLOROETHYLENE  |   |      |       |      | 01.2 |      |
| 5.      | CHLOROFORM            |   |      | 50.1  |      | 35.6 |      |
| 6.      | 1,1,1-TRICHLOROETHANE |   |      | 102.1 |      | 9.6  |      |
| 7.      | BROMODICHLOROMETHANE  |   |      | 5.2   |      | 5.9  |      |
| 8.      | TRICHLOROETHYLENE     |   |      | 375.4 |      | 31.9 |      |
| 9.      | DIBROMOCHLOROMETHANE  |   |      | 11.7  |      | 4.3  |      |
| 10.     | BROMOFORM             |   |      | 2.6   |      | 4.5  |      |

| CAL NO. | COMPOUND              | * * * * HOUR OF DAY/SAMPLE SOURCE * * * * |      |      |      |       |      |
|---------|-----------------------|---|------|------|------|-------|------|
|         |                       | 19/3                                      | 20/6 | 21/6 | 22/3 | 23/3  | 24/6 |
| 1.      | TETRACHLOROETHYLENE   | 117.3                                     |      | 17.7 |      | 120.2 |      |
| 2.      | METHYLENE CHLORIDE    | 17.2                                      |      |      |      | 68.2  |      |
| 3.      | 1,1-DICHLOROETHYLENE  |   |      |      |      |       |      |
| 4.      | 1,2-DICHLOROETHYLENE  |   |      |      |      | 140.5 |      |
| 5.      | CHLOROFORM            | 84.0                                      |      | 21.0 |      | 106.6 |      |
| 6.      | 1,1,1-TRICHLOROETHANE | 90.6                                      |      | 9.8  |      | 95.6  |      |
| 7.      | BROMODICHLOROMETHANE  | 5.1                                       |      | 3.6  |      | 7.3   |      |
| 8.      | TRICHLOROETHYLENE     | 365.7                                     |      | 29.8 |      | 331.1 |      |
| 9.      | DIBROMOCHLOROMETHANE  | 11.2                                      |      | 3.3  |      | 11.7  |      |
| 10.     | BROMOFORM             | 2.4                                       |      | 3.8  |      | 2.3   |      |

Figure 16 Typical Gas Chromatograph Data Report



NASA/WMS - SCVWD PALO ALTO WATER RECLAMATION FACILITY

1 PRIMARY EFFLUENT

4 CLARIFIER EFFLUENT

2 RECLAMATION FAC. B EFFLUENT


5 NOT ACTIVE

3 SECONDARY EFFLUENT

6 RECLAMATION FAC. A EFFLUENT

6. TURBIDITY-SI02

3/ 8/78



9. TOT ORG CARB



5. RES CHLORINE





Figure 17 Typical Hourly Plot (1 of 3)


NASA/WMS - SCVWD PALO ALTO WATER RECLAMATION FACILITY

- 1 PRIMARY EFFLUENT
- 2 RECLAMATION FAC. B EFFLUENT
- 3 SECONDARY EFFLUENT
- 4 CLARIFIER EFFLUENT
- 5 AMMONIA STRIPPER PUMP
- 6 RECLAMATION FAC. A EFFLUENT

10. AMMONIA 2/10/79



14. CONDUCTIVITY



17. SODIUM




Figure 17 Typical Hourly Plot (2 of 3)

NASA/WMS - SCVWD PALO ALTO WATER RECLAMATION FACILITY

- 1 PRIMARY EFFLUENT
- 2 RECLAMATION FAC. B EFFLUENT
- 3 SECONDARY EFFLUENT
- 4 CLARIFIER EFFLUENT
- 5 AMMONIA STRIPPER PUMP
- 6 RECLAMATION FAC. A EFFLUENT




Figure 17 Typical Hourly Plot (3 of 3)

NASA/WMS - SCVWD PALO ALTO WATER RECLAMATION FACILITY

- 1 PRIMARY EFFLUENT
- 2 RECLAMATION FAC. B EFFLUENT
- 3 SECONDARY EFFLUENT
- 4 CLARIFIER EFFLUENT
- 5 AMMONIA STRIPPER PUMP
- 6 RECLAMATION FAC. A EFFLUENT

5. RES CHLORINE

2/79




Figure 18 Typical Monthly Plot

TURBIDITY-S102  
(MG/L)  
HOURLY AVERAGES  
FOR JUL 1979

SAMPLE SOURCE 3 - NH3 STRIPPED/RECARBONATED

|      | 1    | 2    | 3  | 4  | 5  | 6  | 7    | 8    | 9  | 10 | 11 | 12 |              |
|------|------|------|----|----|----|----|------|------|----|----|----|----|--------------|
| 1 S  |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 2 M  |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 3 T  |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 4 U  | 8.1  | 7.8  |    |    |    |    | 7.8  | 8.8  |    |    |    |    |              |
| 5 T  | 8.7  | 8.9  |    |    |    |    | 9.8  | 9.2  |    |    |    |    |              |
| 6 F  | 8.7  | 8.3  |    |    |    |    | 8.7  | 8.9  |    |    |    |    |              |
| 7 S  | 11.6 | 11.3 |    |    |    |    | 18.8 | 18.8 |    |    |    |    |              |
| 8 S  | 7.9  | 8.8  |    |    |    |    | 7.3  | 7.9  |    |    |    |    |              |
| 9 M  | 8.1  | 8.4  |    |    |    |    | 8.3  | 8.5  |    |    |    |    |              |
| 10 T | 7.7  | 7.5  |    |    |    |    | 7.3  | 7.7  |    |    |    |    |              |
| 11 U | 8.3  | 8.3  |    |    |    |    | 8.5  | 8.5  |    |    |    |    |              |
| 12 T | 9.8  | 18.4 |    |    |    |    | 9.8  | 8.5  |    |    |    |    |              |
| 13 F |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 14 S |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 15 S |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 16 M |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 17 T | 7.6  | 7.8  |    |    |    |    | 8.1  | 8.4  |    |    |    |    |              |
| 18 U |      | 9.2  |    |    |    |    |      | 9.5  |    |    |    |    |              |
| 19 T |      | 8.8  |    |    |    |    |      | 8.5  |    |    |    |    |              |
| 20 F |      | 7.1  |    |    |    |    |      | 6.9  |    |    |    |    |              |
| 21 S |      | 6.7  |    |    |    |    |      | 6.8  |    |    |    |    |              |
| 22 S |      | 6.8  |    |    |    |    |      | 7.4  |    |    |    |    |              |
| 23 M |      | 16.4 |    |    |    |    |      | 14.2 |    |    |    |    |              |
| 24 T |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 25 U |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 26 T |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 27 F |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 28 S |      | 7.2  |    |    |    |    |      | 7.8  |    |    |    |    |              |
| 29 S |      | 8.2  |    |    |    |    |      | 8.8  |    |    |    |    |              |
| 30 M |      | 8.9  |    |    |    |    |      | 8.7  |    |    |    |    |              |
| 31 T |      | 7.6  |    |    |    |    |      | 9.9  |    |    |    |    |              |
|      | 13   | 14   | 15 | 16 | 17 | 18 | 19   | 20   | 21 | 22 | 23 | 24 | DAILY<br>AVG |
| 1 S  |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 2 M  |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 3 T  | 18.2 | 18.9 |    |    |    |    | 9.2  | 8.9  |    |    |    |    | 11.8         |
| 4 U  | 7.7  | 6.9  |    |    |    |    | 8.5  | 8.7  |    |    |    |    | 7.9          |
| 5 T  | 9.8  | 18.5 |    |    |    |    | 9.3  | 9.8  |    |    |    |    | 9.3          |
| 6 F  | 11.5 | 13.9 |    |    |    |    | 17.6 | 17.2 |    |    |    |    | 11.9         |
| 7 S  | 8.1  | 8.2  |    |    |    |    | 7.8  | 8.8  |    |    |    |    | 9.4          |
| 8 S  | 8.8  | 7.7  |    |    |    |    | 7.9  | 8.8  |    |    |    |    | 7.9          |
| 9 M  | 9.1  | 9.1  |    |    |    |    | 7.2  | 7.5  |    |    |    |    | 8.3          |
| 10 T | 7.9  | 8.2  |    |    |    |    | 7.7  | 8.4  |    |    |    |    | 7.8          |
| 11 U | 8.8  | 6.8  |    |    |    |    | 8.1  | 8.9  |    |    |    |    | 8.1          |
| 12 T |      |      |    |    |    |    |      |      |    |    |    |    | 9.4          |
| 13 F |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 14 S |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 15 S |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 16 M | 6.2  | 6.7  |    |    |    |    | 8.5  | 7.5  |    |    |    |    | 7.2          |
| 17 T | 8.7  | 8.8  |    |    |    |    |      | 8.3  |    |    |    |    | 8.2          |
| 18 U |      | 7.1  |    |    |    |    |      | 6.6  |    |    |    |    | 8.1          |
| 19 T |      | 5.4  |    |    |    |    |      | 4.4  |    |    |    |    | 6.6          |
| 20 F |      | 6.5  |    |    |    |    |      | 6.4  |    |    |    |    | 6.7          |
| 21 S |      | 6.8  |    |    |    |    |      | 6.6  |    |    |    |    | 6.7          |
| 22 S |      | 11.4 |    |    |    |    |      | 16.7 |    |    |    |    | 18.5         |
| 23 M |      | 11.3 |    |    |    |    |      |      |    |    |    |    | 14.8         |
| 24 T |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 25 U |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 26 T |      |      |    |    |    |    |      |      |    |    |    |    |              |
| 27 F |      | 8.1  |    |    |    |    |      | 6.3  |    |    |    |    | 7.2          |
| 28 S |      | 6.8  |    |    |    |    |      | 6.5  |    |    |    |    | 6.8          |
| 29 S |      | 5.8  |    |    |    |    |      | 5.9  |    |    |    |    | 7.8          |
| 30 M |      | 4.5  |    |    |    |    |      | 5.8  |    |    |    |    | 6.8          |
| 31 T |      | 9.8  |    |    |    |    |      | 9.3  |    |    |    |    | 9.1          |

Figure 19 Typical Sample Source Trend Data Report

STATISTICAL DATA FOR JUN 1979

SAMPLE SOURCE 2 - PALO ALTO SECONDARY EFFLUENT

| CHA | SENSOR         | UNITS   | SAMPLING FREQUENCY | MONTHLY AVERAGE | DAILY AVG VARIATION | HOURLY AVG VARIATION |
|-----|----------------|---------|--------------------|-----------------|---------------------|----------------------|
| 1.  | TOTAL BIOMASS  | MIL CM  | 11                 | 5.381           | 1.1495              | 1.9382               |
| 2.  | VIABLE BIOMASS | MIL CM  | 12                 | 1.382           | 0.2339              | 0.6848               |
| 3.  | RES CHLORINE   | MG/L    | 11                 | 11.153          | 3.1388              | 3.3284               |
| 6.  | TURBIDITY-SIG2 | MG/L    | 15                 | 25.781          | 4.2681              | 6.8323               |
| 9.  | TOT ORG CARB   | MG/L    | 15                 | 12.243          | 2.8628              | 2.7746               |
| 10. | AMMONIA        | MG/L    | 15                 | 21.683          | 4.5388              | 5.6334               |
| 11. | NITRATE        | MG/L    | 2                  | 1.777           | 2.9863              | 2.1581               |
| 12. | PH             | PH      | 15                 | 6.945           | 0.1686              | 0.1885               |
| 14. | CONDUCTIVITY   | MMHO/CM | 15                 | 1258.139        | 68.6159             | 68.6781              |
| 15. | TEMPERATURE*1  | DEG F   | 15                 | 74.236          | 1.8811              | 2.6845               |
| 16. | HARDNESS       | MG/L    | 9                  | 166.711         | 53.7395             | 59.6983              |
| 17. | SODIUM         | MG/L    | 15                 | 132.883         | 18.8478             | 23.4195              |
| 28. | AMBIENT TEMP   | DEG F   | 15                 | 76.543          | 3.5442              | 4.5798               |
| 29. | TOT HALOCARBON | PPB     | 4                  | 954.352         | 156.2437            | 263.3189             |

SAMPLE SOURCE 6 - RECLAMATION FACILITY EFFLUENT

| CHA | SENSOR         | UNITS   | SAMPLING FREQUENCY | MONTHLY AVERAGE | DAILY AVG VARIATION | HOURLY AVG VARIATION | PERCENT REMOVAL<br>DAILY AVG STD DEV |        |
|-----|----------------|---------|--------------------|-----------------|---------------------|----------------------|--------------------------------------|--------|
| 1.  | TOTAL BIOMASS  | MIL CM  | 23                 | 0.982           | 0.2154              | 0.3511               | 89.18                                | 5.81   |
| 2.  | VIABLE BIOMASS | MIL CM  | 24                 | 0.155           | 0.1231              | 0.2432               | 88.14                                | 10.74  |
| 3.  | RES CHLORINE   | MG/L    | 25                 | 2.618           | 0.3839              | 0.8632               | 76.52                                | 11.82  |
| 6.  | TURBIDITY-SIG2 | MG/L    | 29                 | 3.696           | 0.4575              | 0.5881               | 85.67                                | 3.13   |
| 9.  | TOT ORG CARB   | MG/L    | 29                 | 1.966           | 0.8118              | 0.9555               | 83.94                                | 7.25   |
| 10. | AMMONIA        | MG/L    | 27                 | 16.951          | 2.8278              | 3.2153               | 23.38                                | 13.55  |
| 11. | NITRATE        | MG/L    | 11                 | 6.482           | 1.6143              | 2.1892               | *264.                                | 491.65 |
| 12. | PH             | PH      | 29                 | 7.535           | 0.2941              | 0.3163               | -0.49                                | 2.52   |
| 14. | CONDUCTIVITY   | MMHO/CM | 29                 | 1288.261        | 51.3698             | 59.5482              | 3.96                                 | 2.41   |
| 15. | TEMPERATURE*1  | DEG F   | 29                 | 73.829          | 1.3628              | 1.8932               | 0.95                                 | 0.52   |
| 16. | HARDNESS       | MG/L    | 28                 | 156.534         | 49.2368             | 46.6497              | 6.18                                 | 29.86  |
| 17. | SODIUM         | MG/L    | 29                 | 118.418         | 18.8745             | 28.1844              | 18.76                                | 4.67   |
| 28. | AMBIENT TEMP   | DEG F   | 29                 | 79.148          | 2.9278              | 3.5218               | 1.63                                 | 1.14   |
| 29. | TOT HALOCARBON | PPB     | 4                  | 92.576          | 88.6388             | 97.8129              | 83.38                                | 37.28  |

Figure 20 Typical Statistical Report

## SCVWD WATER RECLAMATION FACILITY DESCRIPTION

### General

The SCVWD Palo Alto Reclamation Facility is a pilot facility designed to treat  $0.09\text{-m}^3/\text{s}$  (2 mgd). Figure 21 shows the basic processes in the Reclamation Facility, which has as an influent the chlorinated, nitrified, filtered secondary effluent from the  $1.53\text{-m}^3/\text{s}$  (35 mgd) Regional Water Quality Control Plant located in Palo Alto. The reclamation plant includes the following: High-lime treatment, single-stage recarbonation, breakpoint chlorination for further nitrogen removal, mixed-media filtration, activated carbon sorption with carbon regeneration, ozonation, chlorination for disinfection, and storage. Innovative design of the plant allows flexibility in the sequence of the unit processes. For instance, the water can be filtered prior to or after activated carbon treatment, or both, depending on the need to protect the carbon beds or to eliminate carbon fines in the effluent. This flexibility was provided to permit research and testing of various alternatives prior to building a larger plant.

The facility has a direct digital computer control system that allows operators to alter control parameters. Process configurations are easily changed by the engineering staff. The computer supplies operational data to personnel on shift, while operating the plant.

The following are general descriptions of the processes. Table 4 describes capacity parameters for the processes.

### Control and Instrumentation

A Modcomp II/221 computer with 64K words of main memory, two moving head disk drives with 2.6M words of memory, one fixed head disk with 512K words of memory, one REMAC multiplexer unit, three CRT's, a card reader, and a printer are utilized for plant data acquisition and control. The software utilized is a modified version of a standard control package called FLICK.

All instruments in the plant, as listed on Table 5, are standard commercially available devices.

The need for exceptional process flexibility (i.e., arranging unit processes in any desired order) led to the selection of a DDC (digital data control) system with no conventional analog backup control. It was felt that such a hardwired backup, as found in many plants, would restrict process flexibility to an unacceptable extent. Also, because of the "pilot" nature of this plant, a backup computer system was not justifiable. Because of the lack of a backup system, outages due to the control system were much more frequent than would be experienced in a conventional plant where usual backup and redundancy measures were utilized.




Figure 21 SCVWD Water Reclamation & Injection/Extraction Well Facility at Palo Alto, California



## Chemical Clarification

Chemical treatment is effective in removing suspended solids, colloidal solids, and some dissolved constituents, such as heavy metals and phosphates. During the initial periods of operation, removal of ammonia by air stripping was implemented for the reclamation system. Therefore, since this process requires a high pH, lime was selected as the chemical of choice. A secondary benefit was achieved, since the high pH resulting from additional lime is also considered to be quite effective in pathogen destruction.

The process consists of separate rapid mix, flocculation, and sedimentation basins. Lime is added in a slurry form to the rapid mix basin. The feed rate is automatically controlled to achieve the optimum pH of approximately 11. The dose to achieve this pH was 100 to 200 mg/l as calcium oxide. The water flows from the bottom of the flash mix basin to a center column in the flocculator clarifier. The influent enters the center column of the tank at its bottom, rises up the center column, and comes out through the side openings at the column near the top. The flocculation basin contains two flocculating mixers within a circular mixing compartment. These provide complete mixing so as to develop a substantial rapid settling floc. After mixing and blending, the influent exits from the bottom of the flocculating compartment and flows radially outward in the clarification compartment. Heavier solids resulting from the process settle to the bottom of the tank. The tank's effluent passes over a weir into a shallow trough around the periphery of the tank.

TABLE 4  
SCWD-WRF/PA UNIT PROCESS CHARACTERISTICS  
AT 0.09 m<sup>3</sup>/s (2 MGD)

### Flash Mix

|                     |                                   |
|---------------------|-----------------------------------|
| Lime Feed Capacity: | 2700 kg/day (3 tons/day)          |
| Process Volume:     | 15.9 m <sup>3</sup> (560 cu. ft.) |
| Mixer Horsepower:   | 5 hp                              |
| Detention Time:     | 3 minutes                         |

### Flocculator/Clarifier

|                             |                               |
|-----------------------------|-------------------------------|
| Type:                       | Center Feed, Peripheral Weir, |
| Circular                    |                               |
| Diameter:                   | 16.8 meters (55 feet)         |
| Depth:                      | 3.4 meters (11 feet)          |
| Flocculator Detention Time: | 0.5 hr.                       |
| Clarifier Detention Time:   | 1.9 hr.                       |

TABLE 4  
SCVWD-WRF/PA UNIT PROCESS CHARACTERISTICS

(Continued)

Aeration (Ammonia Stripping) - Aeration pumps were not operated during this test period.

|                             |   |
|-----------------------------|---|
| Tank Dimensions:            | 16.8 m L x 9.1 m W x 4.3 m D (55 ft. L x 30 ft. W x 14 ft. D) |
| No. of Aerators:            | 2   |
| Combined Horsepower:        | 100 hp  |
| Circulation Fan Horsepower: | 30 hp   |
| Detention Time:             | 2.1 hr.   |

Recarbonation

|                          |  |
|--------------------------|--|
| Tank Dimensions:         | 6.4 m L x 2.1 m L x 2.1 m W x 4.2 m D (21 ft. L x 7 ft. W x 13.75 ft. D) |
| Mixer Horsepower:        | 10 hp  |
| Stack Gas Feed Capacity: | 550 SCFM   |
| Detention Time:          | 11 minutes   |

Ozonation

|                    |   |
|--------------------|---|
| Tank Dimensions:   | 6.4 m L x 2.1 m W x 4.1 m H (21 ft. L x 7 ft. W x 13.5 ft. H) |
| Ozonator Capacity: | 42.6 kg/day (94 lb/day)                                       |
| Detention Time:    | 10.5 minutes  |

Filters\*

|                      |  |
|----------------------|--|
| Number of Filters:   | 4  |
| Type:                | Mixed Media  |
| Surface Area (each): | 20.5 m <sup>2</sup> (221 sq. ft.)                        |
| Media Depth:         | 0.9 m (3 ft.)  |
| Hydraulic Loading:   | 7.1 m <sup>3</sup> /sec/m <sup>2</sup> (3.1 gpm/sq. ft.) |

Granular Activated Carbon

|                         |   |
|-------------------------|---|
| Number of Columns:      | 4   |
| Type:                   | Upflow  |
| Diameter:               | 3.0 m (10 ft.)  |
| Bed Depth:              | 6.1 m (20 ft.)  |
| Total Carbon Volume:    | 177.8 m <sup>3</sup> (6280 cu. ft.)                       |
| Carbon Type:            | Calgon <sub>3</sub> Filtrasorb 300 (8 X 30 mesh)          |
| Hydraulic Loading:      | 10.1 m <sup>3</sup> /sec/m <sup>2</sup> (4.4 gpm/sq. ft.) |
| Empty Bed Contact Time: | 34 minutes  |

\*Filters may be assigned to pre-GAC and post-GAC filtration in any combination. Hydraulic loading value given is for two filters on each service.

TABLE 5

PLANT INSTRUMENTATION

| <u>INSTRUMENT TYPE</u>     | <u>NUMBER</u> | <u>INSTRUMENT TYPE</u>   | <u>NUMBER</u> |
|----------------------------|---------------|--------------------------|---------------|
| Flow                       | 10            | Dissolved Oxygen ppm     | 1             |
| Level                      | 19            | Sludge Density %         | 1             |
| Pressure psi               | 5             | Tachometer RPM           | 1             |
| Temperature C <sup>o</sup> | 4             | Analog Output Test % Max | 1             |
| Turbidity FTU & NTU        | 6             | Valve Monitor % Open     | 18            |
| pH                         | 3             | Valve Monitor % Closed   | 2             |
| Conductivity MHO           | 1             | Pump Monitor % Max       | 5             |
| Residual Chlorine ppm      | 1             |                          |               |

The results of lime clarification at Palo Alto have shown this process to be effective in reducing turbidity, organics, suspended solids and heavy metals.

Recarbonation

Following settling, the effluent flows through an open tank, formerly used for air stripping, into the recarbonation basin for adjustment of the pH. Stack gas from the existing sludge incineration furnaces of the Palo Alto Regional Water Quality Control Plant is transferred to the recarbonation basin. The stack gas, providing the carbon dioxide source, and the liquid are thoroughly mixed by a flash mixer before leaving the chamber. A sediment trap is provided for removal of contaminants from the stack gas before it enters into the blower. The pH in the recarbonation chamber is automatically controlled by the in-plant computer and determines the amount of stack gas needed and automatically adjusts the opening at the motorized gas inlet valve to provide the proper recarbonation pH. During the test period, this pH was selected to be 7.0.

Mixed-Media Filtration

The recarbonated effluent is then pumped to two open gravity multimedia filter<sub>2</sub> basins designed for a hydraulic loading rate of 7.1 m<sup>3</sup>/sec/m<sup>2</sup> (3.1 gpm/ft<sup>2</sup>). The purpose of the mixed-media filtration is additional removal of suspended solids and floc carried over from preceding steps. Filtration is performed prior to granular activated carbon sorption since the possibility of fouling by suspended solids and colloidal matter exists. The filter media are 910 cm (36 inches) deep and consist of coarse coal, sand, and garnet supported by a layer of sand and garnet gravel.

Ozonation

Following mixed-media filtration, the flow is directed to an ozonation chamber. Ozonation was provided to evaluate its effectiveness for enhanced disinfection and trace organics removal. The ozonation system consists of an

ozonator, diffusers, and baffles. Ozone is an unstable form of oxygen, which is produced in nature when oxygen in the atmosphere is exposed to an electrical discharge, such as lightning. It is also produced artificially, as in an ozonator, by passing clean, dry air through electrodes when high-voltage electrical discharges occur. The ozonator is capable of generating 42.6 kilograms (94 pounds) of ozone at 1% minimum concentration in 24 hours.

### Granular Activated Carbon Sorption

From the ozone chamber, the water is pumped to the carbon towers and flows upward through the diffusers at the underdrain plate of the carbon column. Effluent discharges through the collection launders located near the top of the towers. Each tower is 3.0 meters (10 feet) in diameter, 9.1 meters (30 feet) in overall height, and contains a 6.1 meter (20 foot)-high column of granular activated carbon. All four carbon towers are identical. The contactors operate in parallel, each having an empty bed contact time of 34 minutes. The hydraulic loading rate for each column is  $10.1 \text{ m}^3/\text{sec}/\text{m}^2$  (4.4 gpm/sq ft). Following GAC sorption, the flow is diverted through the other two mixed-media filters. The purpose here is to remove any carbon fines that may have washed over the tower weirs. Finally, chlorine is added to provide a residual of about 1 mg/l and then the flow is directed to a storage tank for future use.

### PLANT/PROCESS PERFORMANCE EVALUATION

WMS data on the operating characteristics of the plant were collected beginning in 1978 through February 1981. During that 3-year timeframe the plant has operated in various configurations which are summarized in Table 6. The table shows that changes have occurred to plant influent processing as well as to in-plant configurations.

Figure 21 illustrates the process stream from raw wastewater to well injection. Table 7 describes the reclamation plant design criteria and a physical description of equipment. Table 8 presents the reclamation plant effluent discharge limits.

### Nominal Input/Output Characteristics

It was found that five parameters best represented the effectiveness of process contaminant removal under various operating conditions and plant configurations. These parameters are TOC, total halocarbons, turbidity, and total and viable biomass. Figure 22 summarizes percent removal performance based on daily averages of plant input/output measurements. Figure 23 illustrates the same data in terms of concentrations. It may be generally concluded from these data that (1) flocculation significantly improves effluent quality and (2) with the exception of biomass, effluent quality depends on a variable influent quality, thus constant effluent quality may not be expected.

The above data represent a summation of unit process performance illustrated in Figures 24 through 28. These figures represent the actual measurements (Appendix A) reduced to a mathematical expression relating process output to input over the observed range of inputs. For example, TOC removal in the reclamation plant for an influent value of 15 mg/lit can be computed from the data presented in Figure 24, as follows:

Table 6 Process Configurations for Test Periods







| TEST PERIOD SYMBOL | TEST PERIOD         | RECLAMATION PLANT INFLUENT PROCESSING |                      |                             |                          |                |                       |             |                       |               |             | RECLAMATION PLANT PROCESSES |                        |                     |          |                        |                     |                         |                             |         |  |
|--------------------|---------------------|---------------------------------------|----------------------|-----------------------------|--------------------------|----------------|-----------------------|-------------|-----------------------|---------------|-------------|-----------------------------|------------------------|---------------------|----------|------------------------|---------------------|-------------------------|-----------------------------|---------|--|
|                    |                     | PRIMARY SETTLING                      | FLOTTED FILM REACTOR | AERATION (ACTIVATED SLUDGE) | AERATION (NITRIFICATION) | CLASSIFICATION | DUAL MEDIA FILTRATION | COAGULATION | CHARGE CLASSIFICATION | PH ADJUSTMENT | AGGREGATION | REGENERATION                | MIXED MEDIA FILTRATION | COARSE DOSEAGE, MGA | GAC UNIT | MIXED MEDIA FILTRATION | COARSE DOSEAGE, MGA | CR. GRAINE DOSEAGE, MGA | RECLAMATION PLANT FLOW, MGD |         |  |
| A                  | 09/03/80 - 02/28/81 | x                                     | x                    | x                           | x                        | x              | x                     | x           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 1.5     |  |
| B                  | 05/07/80 - 02/28/80 | x                                     | x                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 1.5     |  |
| C                  | 02/12/80 - 05/06/80 | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 1.5     |  |
| D                  | 11/11/79 - 02/11/80 | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 1.5     |  |
| E                  | 10/09/79 - 11/10/79 | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 2.0     |  |
| F                  | 08/11/79 - 10/08/79 | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 1.0     |  |
| G                  | 05/21/79 - 07/28/79 | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 1.0     |  |
| H                  | 03/31/79 - 05/02/79 | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 1.0     |  |
| I                  | 11/28/78 - 03/19/79 | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 0.5     |  |
| J                  | 11/13/78 - 11/27/78 | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 0.4     |  |
| K                  | 6/11/78 - 9/30/78   | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 0.2-0.8 |  |
| L                  | 4/1/78 - 6/10/78    | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 0.5     |  |
| M                  | 1/1/78 - 3/30/78    | x                                     | -                    | x                           | x                        | x              | -                     | -           | x                     | x             | x           | x                           | x                      | x                   | x        | x                      | x                   | x                       | x                           | 0.5     |  |

Table 7 Water Reclamation Plant Design Criteria

| INCOMING FLOW CHARACTERISTICS                                  |                | Average | Maximum |
|--|----------------|---------|---------|
| Flow (full treatment), mgd                                     | 2              |         |         |
| Biochemical Oxygen Demand (5-day), mg/l                        | 20             |         |         |
| Chemical Oxygen Demand, mg/l                                   | 30             |         |         |
| Suspended Solids, mg/l   | 25             |         |         |
| Ammonia, mg/l  | 2              |         |         |
| MBAS, mg/l   | 30             |         |         |
| Turbidity, jtu   | Less than 1000 |         |         |
| Coliform, MPN/100 ml   |                |         |         |
| DESIGN OBJECTIVES  |                | Average | Maximum |
| Biochemical Oxygen Demand, mg/l                                |                | 1       | 2       |
| Chemical Oxygen Demand, mg/l                                   |                | 10      | 15      |
| Suspended Solids, mg/l   |                | 1       | 5       |
| Ammonia, mg/l  |                | 2       | 5       |
| MBAS, mg/l   |                | 0.1     | 0.2     |
| Turbidity, jtu   |                | 0.3     | 5       |
| Coliform, MPN (Median)/ 100 ml                                 |                | 2.2     | 23      |
|  | less than      |         |         |
| LIME CLARIFICATION SYSTEM                                      |                |         |         |
| Lime Storage Capacity, Tons                                    |                | 40      |         |
| Capacity Lime Feed System, Tons/day                            |                | 3       |         |
| Detention Time Rapid Mixing, min.                              |                | 3       |         |
| Flocculator/Clarifier Diameter, ft.                            |                | 55      |         |
| Flocculator/Clarifier Depth, ft.                               |                | 11      |         |
| Flocculator Detention Time, hrs.                               |                | 0.5     |         |
| Settling Detention Time, hrs.                                  |                | 1.9     |         |
| AMMONIA STRIPPING  |                |         |         |
| Tank Length, ft.   |                | 55      |         |
| Tank Width, ft.  |                | 30      |         |
| Tank Depth, ft.  |                | 14      |         |
| Detention Time, hrs.   |                | 2.1     |         |
| Number Aerators  |                | 2       |         |
| Combined Aerator Horsepower                                    |                | 100     |         |
| Horsepower/1000 cf   |                | 4.3     |         |
| RECARBONATION  |                |         |         |
| Tank Length, ft.   |                | 21      |         |
| Tank Width, ft.  |                | 7       |         |
| Tank Depth, ft.  |                | 13.75   |         |
| Detention Time, min.   |                | 11      |         |
| OZONATION SYSTEM   |                |         |         |
| Tank Length, ft.   |                | 21      |         |
| Tank Width, ft.  |                | 7       |         |
| Tank Depth, ft.  |                | 13.5    |         |
| Detention Time, min.   |                | 10.5    |         |
| Capacity Ozonator, lbs/day                                     |                | 90      |         |
| FILTERS (@ 2 mgd/2 filters split flow)                         |                |         |         |
| Number of Filters  |                | 4       |         |
| Surface Area Each, ft. <sup>2</sup>                            |                | 221     |         |
| Filter Media Depth (nominal), ft.                              |                | 3       |         |
| Hydraulic Loading, gpm/ft.                                     |                | 3.1     |         |
| CARBON ADSORPTION SYSTEM                                       |                |         |         |
| Number Adsorbers   |                | 4       |         |
| Length Column, ft.   |                | 20      |         |
| Diameter Column, ft.   |                | 10      |         |
| Total Carbon Volume, 100 ft. <sup>3</sup>                      |                | 62.8    |         |
| Hydraulic Loading, gpm/ft.                                     |                | 4.4     |         |
| Detention Time, min.   |                | 34      |         |
| Assumed Carbon Loading, lbs. COO/lb. Carbon                    |                | 0.3     |         |
| Number Carbon Storage Tanks                                    |                | 2       |         |
| Total Carbon Storage Capacity, 100 ft. <sup>3</sup>            |                | 39      |         |
| Carbon Regeneration Furnace Area, ft. <sup>2</sup>             |                | 25      |         |
| Carbon Regeneration Furnace Loading, lbs/ft. <sup>2</sup> /hr. |                | 4.2     |         |
| BACKWASH WASTE STORAGE   |                |         |         |
| Tank Length, ft.   |                | 30      |         |
| Tank Width, ft.  |                | 30      |         |
| Tank Depth, ft.  |                | 13      |         |
| Capacity, 1000 gals.   |                | 88      |         |
| FINAL STORAGE  |                |         |         |
| Tank Diameter, ft.   |                | 70      |         |
| Tank Operating Depth, ft.                                      |                | 20      |         |
| "A" Water Storage Capacity, 1000 gals.                         |                | 154     |         |
| "B" Water Storage Capacity, 1000 gals.                         |                | 415     |         |

Table 8 Reclamation Plant Discharge Water Quality Permit Requirements

|                           | GROUND WATER INJECTION |      |      | IRRIGATION |      |      |
|---------------------------|------------------------|------|------|------------|------|------|
|                           | 30 DAY AVG.            | MAX. | MIN. | 7 DAY AVG. | MAX. | MIN. |
| BOD <sub>5</sub> , MG/LIT | 1.0                    | 2.0  | -    | -          | 40.0 | -    |
| COD, MG/LIT               | 10.0                   | 15.0 | -    | -          | -    | -    |
| pH                        | -                      | 8.5  | 7.0  | -          | -    | -    |
| TURBIDITY, JTU            | -                      | 5.0  | -    | -          | -    | -    |
| TOTAL NITROGEN, MG/LIT    | 5.0                    | 10.0 | -    | -          | -    | -    |
| MBAS, MG/LIT              | 0.1                    | 0.2  | -    | -          | -    | -    |
| DISSOLVED SULFIDE, MG/LIT | -                      | 0.1  | -    | -          | 0.1  | -    |
| DISSOLVED OXYGEN, MG/LIT  | 2.0                    | -    | 1.0  | -          | -    | 1.0  |
| MPN, #/100 ML             | 2.2<br>(7 Day)         | -    | -    | 23         | -    | -    |



**Figure 22 Reclamation Plant Nominal Steady-State % Removal Characteristics (1  $\sigma$  Input Range Indicated)**






Figure 23 Reclamation Plant Nominal Steady-State Input/Output Characteristics (1  $\sigma$  Input Range Indicated)

1 - ACTIVATED SLUDGE/CHLORINATION (15-50 MGD) O = 0.22 I

2 - FLOCCULATION / AERATION / RECARBONATION

A - pH 11 O = 1-5.5

B - pH 9.5 O = 1-3.0

C - pH 9.5 W/O AERATION O = 1-1.5

3 - FILTRATION/OZONATION O = 0.85 I

4 - CARBON ADSORPTION \* O = 1-6

5 - FILTRATION/CHLORINATION O = 0.85 I

\* DEPENDENT ON OPERATING HISTORY




Figure 24 Unit Process Steady-State Input (I) / Output (O) Characteristics at 1 mgd

1 - ACTIVATED SLUDGE/CHLORINATION (15-50MGD) O = 0.35 I

2 - FLOCCULATION/AERATION/RECARBONATION

A - pH 11 O = 0.25 I

B - pH 9.5 O = 0.25 I

C - pH 9.5 W/O AERATION O = 0.53 I

3 - FILTRATION/OZONATION O = 0.75 I

4 - CARBON ADSORPTION \* O = 5.6 I<sup>0.5</sup>

5 - FILTRATION/CHLORINATION O = 1

\* DEPENDENT ON OPERATING HISTORY




Figure 25 Unit Process Steady-State Input (I)/Output (O) Characteristics at 1 mgd

1 - ACTIVATED SLUDGE/CHLORINATION (15-50 MGD)  $O = 0.3 I$

2 - FLOCCULATION/AERATION/RECARBONATION

A - pH 11  $O = 0.5 I$

B - pH 9.5  $O = 0.5 I$

C - pH 9.5 W/O AERATION  $O = 0.6 I$

3 - FILTRATION/OZONATION/CARBON ADSORPTION  $O = 0.25 I$

4 - CARBON ADSORPTION W/O FILT/O<sub>3</sub>  $O = 0.45 I$

5 - FILTRATION/CHLORINATION  $O = 10^{-1/15}$




Figure 26 Unit Process Steady-State Input(I)/Output (O) Characteristics at 1 mgd

2 - FLOCCULATION/AERATION/RECARBONATION

A - pH 11 O = 1.0

B - pH 9.5 O = 0.21

C - pH 9.5 W/O AERATION O = 0.21

3 - FILTRATION/OZONATION O = 0.21

4 - CARBON ADSORPTION O = 1 + 0.3

5 - FILTRATION/CHLORINATION O = 1e<sup>-1/7</sup>




Figure 27 Unit Process Steady-State Input(I)/Output (O) Characteristics at 1 mgd

|  |           |
|--|-----------|
| <b>2 - FLOCCULATION/AERATION/RECARBONATION</b> |           |
| A - pH 11                                      | ○ = 0.2   |
| B - pH 9.5                                     | ○ = 0.2   |
| C - pH 9.5 W/O AERATION                        | ○ = 0.121 |
| <b>3 - FILTRATION/OZONATION</b>                |           |
| ○ = 0.05                                       |           |
| <b>4 - CARBON ADSORPTION</b>                   |           |
| ○ = 1 + 0.1                                    |           |
| <b>5 - FILTRATION/CHLORINATION</b>             |           |
| ○ = 1  |           |




Figure 28 Unit Process Steady -State Input (I)/Output (O) Characteristics at 1 mgd

For process stream; Floc (pH 11)/aeration/filt/O<sub>3</sub>/GAC/filt/Cl<sub>2</sub>

$$\begin{aligned} \text{TOC OUT} &= \{ [( \text{TOC IN} - 5.5) 0.85] - 6 \} 0.85 \\ &= \{ [( 15 - 5.5) 0.85] - 6 \} 0.85 \\ &= 1.8 \text{ mg/lit} \end{aligned}$$

$$\begin{aligned} \% \text{ REMOVAL} &= (\text{TOC IN} - \text{TOC OUT}) 100/\text{TOC IN} \\ &= (15 - 1.8) 100/15 \\ &= 88\% \end{aligned}$$

For process stream; Filt/O<sub>3</sub>/GAC/Filt/Cl<sub>2</sub>

$$\begin{aligned} \text{TOC OUT} &= [0.85 (\text{TOC IN}) - 6] 0.85 \\ &= [0.85 (15) - 6] 0.85 \\ &= 5.7 \text{ mg/lit} \end{aligned}$$

$$\begin{aligned} \% \text{ REMOVAL} &= (\text{TOC IN} - \text{TOC OUT}) 100/\text{TOC IN} \\ &= (15 - 5.7) 100/15 \\ &= 62\% \end{aligned}$$

The unit process performance data presented in Figures 24 through 28 were determined during testing from April through July 1979. In mid-August 1979, the flocculation process pH sensor in the system for controlling lime dosage was found to be caked with sludge and had a calibration error which resulted in low values. In order to estimate the impact this may have had on previous data, a dosage test was performed and compared with plant operating records of lime consumption. Analysis of these data, Table 9, indicates that the pH was low throughout the test period and that the pH 9.5 and pH 11 performance data presented in this report probably are representative of performance within a pH range of 9-9.5 and 10-11, respectively. The sludge covering the pH probe may also have reduced sensor response time thereby contributing to the data scatter observed in Appendix A.

In addition to the removal characteristics provided by the five key parameters, ammonia, nitrate/nitrite, dissolved oxygen and biomass provided information concerning biological activity in the process stream, while dissolved oxygen, pH and total residual chlorine reflected operational status of the plant. The charts in Appendix B summarize representative WMS data and comparable lab data taken during this test program.

The reclamation processes which produced the most significant changes in the measured parameters may be described as follows:

|     |   |
|-----|---|
| TOC | Equal removal by flocculation and GAC; controllable by pH and activated carbon operating history/environment. |
|-----|---|

Table 9 Estimated Flocculation pH Based on Lime Consumption and Influent Alkalinity

|             | <u>pH Set Point</u> | <u>A</u><br>Alkalinity, MG/LIT(CaCO <sub>3</sub> )<br>Avg. ± 1σ | <u>D</u><br>Average Lime Dosage, MG/LIT | <u>Calculated* Average pH</u> |
|-------------|---------------------|---|---|-------------------------------|
| APRIL       | 9.5                 | 237 ± 17  | 114                                     | 9.4                           |
| MAY         | 11                  | 179 ± 30  | 211                                     | 10.6                          |
| JUNE        | 11                  | 192 ± 21  | 204                                     | 10.4                          |
| JULY        | 11                  | 176 ± 23  | 213                                     | 10.7                          |
| AUGUST 1-15 | 11                  | 190 ± 16  | 297                                     | 11.2                          |
| 16-31       | 11                  | 157 ± 12  | 216                                     | 11.0 (REFERENCE)              |

\* pH = 8.55 + 455 V

Where,

V = Volumetric ratio of lime slurry to plant influent - equation fits the results of dosage test for pH range 9 to 11.2 and alkalinity of 200 mg/lit with a correlation coefficient of 0.998.

and,

$$\text{pH} = 8.55 + 1.78 \left( \frac{D}{A} \right)$$

Assuming dosage/alkalinity ratio is constant for a given pH (Reference 18)



|   |  |
|---|--|
| Total Halocarbons                               | Removal by aeration (or purging including the effects of aeration and recarbonation with CO <sub>2</sub> ).  |
| Turbidity                                       | Removal by flocculation.   |
| Biomass   | Removal by flocculation; growth in GAC.  |
| Dissolved Oxygen                                | Quantity added by aeration is removed by biological growth in GAC and filters; frequent filter backwash is necessary to maintain a residual in the effluent. |
| Conductivity<br>Chloride,<br>Sodium<br>Hardness | No change.   |
| Ammonia   | Equal removal by aeration (below design requirement) and GAC (by biological conversion).   |
| Nitrate/Nitrite                                 | Increases due to biological growth in GAC.   |
| Total Residual Chlorine                         | Removal in GAC   |
| pH  | Neutralization by recarbonation.   |

As shown above, flocculation is a key process in attaining high effluent quality; however, to date, tests to determine optimum operating parameters for this process have not been performed. Testing has been planned and preparations are in progress. The data presented herein represent a fixed set of operating parameters, e.g., a sludge recirculation rate of 600 GPM and a wasting rate of 50 GPM, over an uncertain pH range (as discussed above).



### Influent Variations

A consistent source of variation in plant effluent quality results from the diurnal flow of raw wastewater into the primary and secondary processes. Organic and suspended solids removal in the activated sludge process is directly related to detention time (input flow) which normally varies by a factor of two each day. Secondary effluent quality has comparable variations. The pattern of the diurnal flow cycle results in highest effluent quality at midday and lowest quality at midnight. The consistency of this pattern is apparent in Figure 29, which shows the time of day of peak values and Figure 30 which shows the daily profile.

To confirm the relationship between flow and effluent quality, a math model (Appendix C) was developed to determine suspended solids (biomass) and organics (non-volatile TOC) in the secondary effluent as a function of influent concentration, plant operating parameters and hourly flow variations. The results illustrated in Figures 31 and 32, show that measured biomass values can be duplicated by a model representing variable performance in the secondary process clarifiers. The results show that effluent quality is high at a time where, based

NASDAQ/MS - SCYND PALO ALTO WATER RECLAMATION FACILITY

- 1 PRIMARY EFFLUENT
- 2 RECLAMATION FAC. B EFFLUENT
- 3 SECONDARY EFFLUENT
- 4 CLARIFIER EFFLUENT
- 5 ANOXIC STRIPPER PUMP
- 6 RECLAMATION FAC. A EFFLUENT



NASDAQ/MS - SCYND PALO ALTO WATER RECLAMATION FACILITY

- 1 PRIMARY EFFLUENT
- 2 RECLAMATION FAC. B EFFLUENT
- 3 SECONDARY EFFLUENT
- 4 CLARIFIER EFFLUENT
- 5 ANOXIC STRIPPER PUMP
- 6 RECLAMATION FAC. A EFFLUENT








Figure 29 Monthly Plot Indicating Hour of Peak Concentrations

MSBA/MSB - SCVAD PALO ALTO WATER RECLAMATION FACILITY  
 1 PRIMARY EFFLUENT  
 2 RECLAMATION FAC. B EFFLUENT  
 3 SECONDARY EFFLUENT  
 4 CLARIFIER EFFLUENT  
 5 AMMONIA STRIPPER PUMP  
 6 RECLAMATION FAC. A EFFLUENT



MSBA/MSB - SCVAD PALO ALTO WATER RECLAMATION FACILITY  
 1 PRIMARY EFFLUENT  
 2 RECLAMATION FAC. B EFFLUENT  
 3 SECONDARY EFFLUENT  
 4 CLARIFIER EFFLUENT  
 5 AMMONIA STRIPPER PUMP  
 6 RECLAMATION FAC. A EFFLUENT









Figure 30 Hourly Plot Indicating Diurnal Cycle (1 of 3)



NASA/MRS - SCVND PALO ALTO WATER RECLAMATION FACILITY

- 1 PRIMARY EFFLUENT
- 4 CLARIFIER EFFLUENT
- 2 RECLAMATION FAC. B EFFLUENT
- 5 AMMONIA STRIPPER PUMP
- 3 SECONDARY EFFLUENT
- 6 RECLAMATION FAC. A EFFLUENT



NASA/MRS - SCVND PALO ALTO WATER RECLAMATION FACILITY

- 1 PRIMARY EFFLUENT
- 4 CLARIFIER EFFLUENT
- 2 RECLAMATION FAC. B EFFLUENT
- 5 AMMONIA STRIPPER PUMP
- 3 SECONDARY EFFLUENT
- 6 RECLAMATION FAC. A EFFLUENT






Figure 30 Hourly Plot Indicating Diurnal Cycle (3 of 3)

# SUSPENDED SOLIDS IN EFFLUENT

## 1. CLARIFIER

- - - PLUG FLOW

— MIXED FLOW @ > 25 MGD

(4% OF AERATOR SOLIDS HAVE LOW SETTLING RATE ~ 75% PER HOUR)

## 2. FINAL EFFLUENT - OUTFLOW FROM CHLORINE CONTACT TANK.




FIGURE 31

MATH MODEL SIMULATION OF PROCESS SOLIDS  
IN ACTIVATED SLUDGE PROCESS EFFLUENT




FIGURE 32

MATH MODEL SIMULATION OF NON-VOLATILE ORGANICS

only on detention times, lower quality might be expected. It is interesting to note that the non-ideal performance (mixed flow in the clarifiers) results in a better overall quality effluent than might otherwise be predicted. This is attributable to the daily "morning break" where flow falls below 25 MGD and ideal (plug flow) settling occurs. It is expected that wet weather or a large increase in plant flow due to local growth, where high flows were sustained, would produce a significant decrease in secondary effluent quality.

The potential exists for utilizing the biosensor to improve secondary effluent quality. If the return sludge rate and wasted sludge rate (Appendix C) were controlled for optimum biological solids in the aerator, the conditions which result in the excursions in effluent quality might be reduced. However, no testing has yet been performed to prove this concept due to other priorities.

The observed diurnal cycle might have some influence on plant operational procedures. For example, the normal procedure for determining conformance of the secondary effluent to discharge permit requirements (240 coliform per 100 ml, 7 day average) is by grab sample collected at noon each day; however, based on the diurnal cycle, a higher biological population in the effluent would be expected around midnight. A small group of samples were collected and analyzed which showed that prior to disinfection the biological population was indeed higher at midnight (Table 10) as measured by coliform, biomass and turbidity, but the plant disinfection strategy (constant concentration of chlorine dosage) appeared adequate for the higher number of coliform. A control strategy that recognized not only dosage and contact time, but also quantity of biological material, while maybe desirable, was not justified in this short testing period, where coliform was the only standard of performance.

The changes in secondary effluent quality due to the diurnal cycle could have an influence on reclamation plant operations as will be discussed later in this section.

Major variations in total halocarbons follow a weekly cycle. Figure 33 shows that these variations result in high concentrations midweek and low concentrations on the weekend. Some of these compounds are commonly used solvents and the weekly cycle presumably reflects work patterns of local industry.

Typical concentrations of the nine individual compounds comprising the total halocarbons are shown in Figure 34, which also shows process removals. Significant removals occur in the purging processes, e.g., aeration (activated sludge) aeration (ammonia stripping) and recarbonation, and across the GAC.

#### Carbon Adsorption

Organics removal decreased with operating time as the adsorbent surface of the granular activated carbon (GAC) became saturated. For example, Figure 35 shows that chloroform removal suddenly decreased after processing about 20 mgal. After processing 35 mgal, the GAC was saturated at the average influent concentration of 39 ug/lit and the effluent was characterized by a great deal of data scatter as the GAC alternately adsorbed and desorbed in concert with the influent concentration. The performance of two other carbon towers, at plant configurations



Table 10 Diurnal Variation in Biological Quality

|                 | PRE-CHLORINATION          |                            |   | POST CHLORINATION         |                            |                      | TURBIDITY<br>MG/LIT | TOTAL<br>RESIDUAL<br>CHLORINE<br>MG/LIT |
|-----------------|---------------------------|----------------------------|---|---------------------------|----------------------------|----------------------|---------------------|---|
|                 | TOTAL<br>BIOMASS<br>MG/ML | VIABLE<br>BIOMASS<br>MG/ML | COLIFORM<br>#/100 ML                        | TOTAL<br>BIOMASS<br>MG/ML | VIABLE<br>BIOMASS<br>MG/ML | COLIFORM<br>#/100 ML |                     |   |
| <u>NOON</u>     |                           |                            |   |                           |                            |                      |                     |   |
| 4-30-79         | 9.8                       | 1.9                        | $1.65 \times 10^5$                          | 3.7                       | 0.4                        | -                    | 11                  | 8                                       |
| 5-1-79          | 16.4                      | 4.7                        | $2.30 \times 10^5$                          | 4.2                       | 0.3                        | 2                    | 14                  | 7                                       |
| 5-2-79          | 10.2                      | 2.4                        | $1.15 \times 10^5$                          | 4.1                       | 0.3                        | 8                    | 14                  | 7                                       |
| 5-3-79          | $\frac{8.1}{11.1}$        | $\frac{1.7}{2.7}$          | $\frac{7.0 \times 10^4}{1.32 \times 10^5}$  | $\frac{2.4}{3.9}$         | $\frac{0.4}{0.4}$          | $\frac{1}{5}$        | $\frac{17}{14}$     | $\frac{8}{8}$                           |
| <u>MIDNIGHT</u> |                           |                            |   |                           |                            |                      |                     |   |
| 5-7-79          | 28.1                      | 10.9                       | $3.30 \times 10^5$                          | 6.1                       | -                          | 8                    | 28                  | 7                                       |
| 5-8-79          | 17.6                      | 3.9                        | $3.30 \times 10^5$                          | 8.3                       | 2.7                        | 5                    | 17                  | 7                                       |
| 5-9-79          | 16.8                      | 10.0                       | $22.4 \times 10^7$                          | 7.4                       | 4.0                        | 2                    | 12                  | 6                                       |
| 5-10-79         | $\frac{39.9}{25.5}$       | $\frac{20.5}{11.3}$        | $\frac{1.40 \times 10^5}{27.8 \times 10^5}$ | $\frac{9.9}{7.9}$         | $\frac{5.5}{4.1}$          | $\frac{2}{4}$        | $\frac{15}{17}$     | $\frac{5}{6}$                           |

- 1 PRIMARY EFFLUENT
- 2 RECLAMATION FAC. B EFFLUENT
- 3 SECONDARY EFFLUENT
- 4 CLARIFIER EFFLUENT
- 5 AMMONIA STRIPPER PUMP
- 6 RECLAMATION FAC. A EFFLUENT




Figure 33 Total Halocarbons in Reclamation Facility Influent Water (Secondary Effluent from Palo Alto Wastewater Plant).

April Averages (ug/LIT) ± 1σ

| INFLUENT<br>15-50 HGD                   | PRIMARY                          | ACTIVATED<br>SLUDGE<br>CHLORINE<br>CONTACT |                    | FLOCCULATION<br>AERATION<br>STRIPPING*<br>RECALCINATION |                    | FILTRATION<br>OZONATION |                    | GRAVIMETRIC<br>ACTIVATED<br>CARBON |                   | FILTRATION<br>CHLORINATION |                    | EFFLUENT |
|---|----------------------------------|--|--------------------|---|--------------------|-------------------------|--------------------|------------------------------------|-------------------|----------------------------|--------------------|----------|
|   |                                  | Avg. %<br>Removal                          | 1 HGD              | Avg. %<br>Removal                                       | 1 HGD              | Avg. %<br>Removal       | 1 HGD              | Avg. %<br>Removal                  | 1 HGD             | Avg. %<br>Removal          | 1 HGD              |          |
| TETRACHLOROETHYLENE                     | MED.<br>296±162<br>SUN.<br>15±5  | 63   | 109 ± 55<br>12 ± 9 | 62  | 41 ± 14<br>7 ± 3   | 44                      | 23 ± 9<br>4 ± 1    | 83                                 | 4 ± 1<br>1 ± 1    | 0                          | 4 ± 2<br>1 ± 1     |          |
| METHYLENE CHLORIDE                      | MED.<br>320±128<br>SUN.<br>27±15 | 92   | 27 ± 27<br>1 ± 0   | 56  | 12 ± 10<br>31 ± 23 | 33                      | 8 ± 4<br>24 ± 24   | -213                               | 25 ± 7<br>25 ± 7  | 12                         | 22 ± 5<br>24 ± 7   |          |
| 1,2 DICHLOROETHYLENE                    | MED.<br>101±34<br>SUN.<br>67±11  | 69   | 31 ± 9<br>32 ± 15  | -3  | 32 ± 10<br>33 ± 14 | -9                      | 35 ± 17<br>38 ± 13 | 11                                 | 31 ± 9<br>20 ± 11 | 16                         | 26 ± 10<br>23 ± 10 |          |
| CHLOROFORM                              | MED.<br>44±30<br>SUN.<br>20±4    | 32   | 30 ± 15<br>20 ± 4  | 40  | 18 ± 5<br>15 ± 3   | 6                       | 17 ± 4<br>15 ± 2   | 76                                 | 4 ± 2<br>4 ± 1    | 0                          | 4 ± 1<br>4 ± 2     |          |
| 1,1,1 TRICHLOROETHYLENE                 | MED.<br>227±126<br>SUN.<br>17±0  | 66   | 78 ± 38<br>10 ± 8  | 74  | 20 ± 10<br>5 ± 3   | 45                      | 11 ± 7<br>3 ± 2    | 91                                 | 1 ± 1<br>1 ± 1    | 0                          | 1 ± 1<br>1 ± 1     |          |
| BROMODICHLOROMETHANE                    | MED.<br>3±1<br>SUN.<br>2±1       | -33  | 4 ± 2<br>4 ± 2     | 25  | 3 ± 1<br>4 ± 1     | 0                       | 3 ± 1<br>3 ± 1     | 33                                 | 2 ± 1<br>1 ± 1    | 50                         | 1 ± 1<br>1 ± 1     |          |
| TRICHLOROETHYLENE                       | MED.<br>150±62<br>SUN.<br>22±5   | 65   | 52 ± 50<br>7 ± 2   | 62  | 20 ± 8<br>4 ± 1    | 30                      | 14 ± 10<br>3 ± 1   | 86                                 | 2 ± 0<br>1 ± 0    | 50                         | 1 ± 0<br>1 ± 0     |          |
| DIBROMODICHLOROMETHANE                  | MED.<br><1<br>SUN.<br>1±1        | <-100                                      | 2 ± 0<br>2 ± 0     | 50  | 1 ± 1<br>1 ± 1     | 0                       | 1 ± 1<br>1 ± 1     | 0                                  | 1 ± 0<br>1 ± 0    | 0                          | 1 ± 0<br>1 ± 0     |          |
| BROMOFORM                               | MED.<br>6±3<br>SUN.<br>2±1       | 67   | 2 ± 1<br>2 ± 1     | 0   | 2 ± 1<br>2 ± 1     | 0                       | 2 ± 1<br>2 ± 1     | 0                                  | 2 ± 1<br>2 ± 1    | 0                          | 2 ± 1<br>2 ± 1     |          |
| TOTAL HALOCARBONS<br>(MONTHLY AVERAGES) |                                  | 68   | 313 ± 210          | 47  | 167 ± 86           | 25                      | 126 ± 54           | 46                                 | 68 ± 28           | 12                         | 59 ± 21            |          |

\* AERATORS WERE OUT OF SERVICE DURING APRIL.  
( ) TYPICAL REMOVAL WITH AERATORS IN SERVICE (PMY AVERAGES)

Figure 34 Weekly Cycle of Halocarbon Concentrations  
(Influent Concentration Varies From a Maximum  
at Mid-week to a Minimum at Weekend)

- X INFLUENT 30 - 35  $\mu\text{g/L}$
- INFLUENT 20 - 30  $\mu\text{g/L}$
- INFLUENT 10 - 20  $\mu\text{g/L}$




Figure 35 Useful Life Activated Carbon Column (1 of 4) for Chloroform Removal at 39 g/Lit Average Influent Concentration (20 Mgal at Breakthrough and 35 Mgal at Saturation)

which resulted in different influent concentrations, were similarly monitored. Figure 36 presents an analysis of these data showing GAC adsorption capacity for chloroform over a range of influent concentrations. Average carbon regeneration rates necessary to maintain active chloroform removal can be computed based on this capacity curve using the following equation:

$$R = 33,500 Q \frac{C_i - 7}{C_i^{1.77}}$$

Where R = Activated carbon average regeneration rate, lb/day  
 Q = Flow, mgd  
 C<sub>i</sub> = Average influent chloroform concentration, µg/lit


Thus, for the 3 plant configurations tested, the following regeneration rates would have been required at plant rated flow to prevent GAC saturation.

|   | <u>Plant Configuration</u> | <u>C<sub>i</sub></u> | <u>R @ 2 mgd</u> |
|---|----------------------------|----------------------|------------------|
| Δ | FILT/GAC/FILT              | 39 µg/lit            | 3274 lb/day      |
| φ | FLOC/FILT/GAC/FILT         | 28                   | 3862             |
| o | FLOC/AER/FILT/GAC/FILT     | 15                   | 4441             |

Or, if a limit were placed on the average effluent concentration, say 30 µg/lit, regeneration would be required only for the first configuration listed above.

These regeneration rates are much higher than the plant contractor's estimate of 1000 lb/day to maintain COD removal capability, and would represent a significant operating expense if used as criteria for carbon regeneration. However, trihalomethanes are not currently restricted by the plant's discharge permit. These data may be of interest in the future since the EPA is contemplating limits on trihalomethanes for drinking water supplies (Reference 2). It should be noted that chloroform was the first of the nine trace organics measured to saturate the GAC, thus a different effective carbon life will result if other measures are used as indicators.

TOC removal, for example, stabilized for a period, after 2-3 months of operation - Figure 37. Apparently, biological activity in the GAC had reached equilibrium where the quantity of non-volatile organics adsorbed equalled the quantity consumed by the bacterial population. Bacterial growth is apparent from the measured biomass elution from the column, the decrease in dissolved oxygen and the nitrification across the column (Appendix B, April-July 1979). The rate of the biological growth was undoubtedly affected when, after 55 days of operation, ozonation, which preceded GAC in the process stream, was turned off. Also, growth may have been inhibited for the first month of operation due to a low dissolved



$\frac{X}{M}$   
 ADSORPTION CAPACITY  
 mg CHLOROFORM  
 PER  
 GRAM CARBON

$C_i$   
 AVERAGE INFLUENT CONCENTRATION  
 $\mu\text{g/l}$

Note: Plant Configuration symbols are identified in Appendix A

Figure 36 Chloroform Adsorption Capacity of Granular Activated Carbon (GAC)

oxygen, due to inoperative aerators. Subsequent performance stabilization may have reflected the healthier growth environment, e.g., plenty of oxygen and no ozone. This biological cleaning may offer a less expensive alternative to the heating method of carbon regeneration. This is discussed further in Section 8.

Decay in performance began again after 5 months of operation. The cause is not known, but the decay was accompanied by a decrease in the earlier observed rate of biomass elution, suggesting reduced biological activity.

The rate of performance decay, Figure 37, during the first 2 months of operation, 1 mg/lit per month, indicates that an average carbon regeneration rate of 700-800 lb/day at 2 MGD would be required to maintain peak performance. This corresponds to the plant contractor's estimate of 600-1000 lb/day.

#### POTENTIAL WMS APPLICATIONS FOR PROCESS CONTROL

Several opportunities are available in the reclamation plant to utilize automated water quality data for process control. These are listed in Table 11. In addition, the number of available processes in the plant and the flexibility in selecting on-stream processes presents another control option, e.g., process stream configuration control. For example, listed in Table 12 is the maximum influent concentration to various process streams where discharge permit limits for COD (10 mg/lit) would not be exceeded. Also shown are the cost of consumables associated with the processes. This illustrates that the process stream could be selected based on the most economical way of treating specific influent conditions. If this example concept had been used during July 1979, flocculation and aeration would have been unnecessary for most of the month (1 $\sigma$  TOC range was 9.2 to 14.6 mg/lit) and a significant portion of the potential savings of \$4,600 could have been realized. Of course this example was simplified to demonstrate the concept and the impact on removals of other contaminants must also be considered.

Alternately, plant flow could be controlled to maintain the highest quality effluent. During periods of low demand, the configuration and flow could be adjusted for peak performance and the water delivered or stored for later mixing with the effluent during high demand periods.

This concept of storage and selective dispensement of high quality water may be a necessary alternative if discharge permit limits are not to be exceeded. As illustrated in Figure 23, for example, the TOC limit of 4 mg/lit (COD of 10 mg/lit) can be exceeded for expected influent conditions.

Biologically regenerated GAC offers another potential opportunity for significant savings by process control. If the GAC can be operated at conditions favorable to biological growth, it may be possible to reduce or eliminate the expense of carbon regeneration with minimum impact on effluent quality. For example, if the four GAC columns could be scheduled such that flow to one of the columns were terminated during periods of low influent organics, the bacteria in this column would have the opportunity to "clean house" under favorably quiescent conditions. Improved performance would be expected when this column was again placed on-line during periods of high influent organic concentrations.

C-2




Figure 37 Rate of Activited Carbon Saturation with Non-Volatile Hydrocarbons



Table 11 Reclamation Plant Systems Amenable to Automatic Computer Control

| Process                      | Control Parameters                         | Potential Criteria  |
|------------------------------|--|---|
| Flocculation                 |  |   |
| Chemical Feed Rate           | pH or Inorganic Carbon (Alkalinity)        | Constant pH   |
|                              | pH/Turbidity, Biomass or TOC               | Variable pH based on influent   |
| Sludge Return Rate           | Flow/Turbidity or Biomass in/out           | Relationship to be determined   |
| Sludge Wasting Rate          | Sludge density or turbidity                | Relationship to be determined   |
| Aeration (Ammonia stripping) | DO, Total Halocarbons, Flow                | 0, 1 or 2 pumps based on influent THC and effluents DO                                |
| Recarbonation                | pH   | Constant pH (7-8)   |
| Filtration                   | $\Delta P$ , DO                            | Backwash at limit   |
| GAC                          | TOC, Total Halocarbons                     | Carbon regeneration rate based on removal performance                                 |
| Chlorination                 | Flow<br>or<br>Total Residual Chlorine      | Constant dosage   |
| Ozonation                    | Flow                                       | Constant residual   |
| Flow                         | Turbidity, TOC, Total Halocarbons, Biomass | Constant dosage   |
|                              |  | Regulate flow to store/deliver highest quality effluent during periods of low demand. |

Table 12 Configurations/Costs of Controlling Effluent COD  
 ≤10 Mg/Lit at 1 mgd

| PROCESS STREAM                    | MAX. INFLENT TOC FOR ≤ 4 MG/LIT<br>IN THE EFFLUENT | CONSUMABLE COSTS, \$/DAY |     |                             |
|-----------------------------------|--|--------------------------|-----|-----------------------------|
|                                   |  | LIME                     | GAC | ELECTRICITY<br>FOR AERATION |
| FLOC(pH 11)/AER(2)/FILT/GAC/FILT  | 18.1   | 70                       | 150 | 80                          |
| FLOC(pH 9.5)/AER(2)/FILT/GAC/FILT | 15.6   | 28                       | 150 | 80                          |
| FLOC(pH 9.5)/AEC(1)/FILT/GAC/FILT | 14.9   | 28                       | 150 | 40                          |
| FLOC(pH 9.5)/FILT/GAC/FILT        | 14.1   | 28                       | 150 | 0                           |
| FILT/GAC/FILT                     | 12.6   | 0                        | 150 | 0                           |
| FLOC(pH 11)/AER(2)/FILT           | 4.7  | 70                       | 0   | 80                          |
| FLOC(pH 9.5)/FILT                 | 4.7  | 28                       | 0   | 0                           |
| FILT                              | 4.7  | 0                        | 0   | 0                           |
| TOTAL                             |  |                          |     |                             |

82

BASIS

1. COD/TOC RATIO OF 2.5
2. CARBON REGENERATION AT 500 LB/MGAL, \$0.3/LB. (ESTIMATE BASED ON 100% ESCALATION OF 1973 OPERATION AND MAINTENANCE COSTS QUOTED IN REFERENCE 19)
3. LIME DOSAGE AT 280 MG/LIT FOR PH 11, 112 MG/LIT FOR PH 9.5 - \$60/TON
4. ELECTRICAL ENERGY AT \$0.04/KWH
5. NOMINAL STEADY-STATE TOC REMOVAL PERFORMANCE (FIGURE 7-4)

Opportunities to utilize these off-periods are available daily, due to the diurnal cycle, on weekends, and during certain seasons. However, wet weather, seasonal variations and random upsets in the secondary process suggest that the off-periods should be dictated by the influent quality considerations rather than by time period scheduling in order to assure product water quality.

During the column off-periods excess flow might be routed to the other three columns, resulting in some performance penalty, but proper selection of influent criteria would prevent exceeding effluent discharge limits.

A disadvantage may be the reduced capability for removal of trace hydrocarbons, e.g., chloroform. Testing may be necessary to demonstrate the total impact of biological regeneration, but the potential savings, \$300/day @ 2 mgd, warrants due consideration.

## SECTION 3

### PART II FIELD DEMONSTRATION TEST RESULTS

This portion of the Technical Summary covers the test data recorded during the test period July 1980 through February 1981. This portion of the test period was jointly funded by NASA, the EPA, the California State Department of Water Resources, and the Santa Clara Valley Water District. Data were recorded on WMS and subsystem downtime and on maintenance and operations cost. Similar data were recorded by the Santa Clara Valley Water District for the reclamation plant. Additional test data were recorded on the quality of the water at various points within the reclamation plant as measured by the sensors within the WMS and the City of Palo Alto Laboratory. These data were used to evaluate the performance, reliability, availability, and costs of the reclamation plant, its individual processes, and the WMS and its components. Major problems encountered in the operation of the WMS and the reclamation plant are discussed.

#### TEST OBJECTIVES

The objectives of the test program described in this report were as follows:

1. To determine the steady-state performance (ability to remove contaminants) of the water reclamation facility unit processes based on WMS data.
2. To determine unit process and plant availability. Availability is defined as the portion of the time that an item operates on demand. Availability was measured as follows:

$$A = 100T/(T + D)$$

where, A = availability, %

T = operating time, hours

D = Downtime for repair, hours

T + D = total available operating time, hours

Once established, availability can be used to estimate annual repair time; thus, for a continuously operated item:

$$D = (1-A/100) (365 \text{ days/year}) (24 \text{ hours/day})$$

3. To determine plant reliability. Reliability is defined as the percentage of the operating time that an item performs within specified limits. For the water reclamation plant, reliability was measured as the percentage of time that a water quality parameter was within specified effluent limits. The WMS data were statistically evaluated based on a lognormal data distribution model and compared to an MCL (maximum concentration limit). The MCL's are based on references 9, 10, 11, 12, and 13. The percentage of time that a measured parameter was less than the MCL represented plant reliability for that parameter.

The product of multiplying availability times reliability gives the portion of the total available operating time that an item will perform within given limits.

$$P = (A)(R)$$

where, P = performance achieved  
R = reliability, %

4. To determine plant operating and maintenance costs.
5. To determine similar parameters for the WMS; i.e., performance, availability, reliability, and operating and maintenance costs.

## CONCLUSIONS

1. The following conclusions relative to process performance are based on the WMS data:
  - a. Chemical clarification removed over 90% of the influent suspended solids (biomass) and as much as 30% of the organic contaminants (TOC).
  - b. Flocculation (floc) carryover from the chemical clarification process results in additional loading on the mixed-media filters. This caused decreased filter run times; i.e., more frequent backwashing.
  - c. Except for some reduction in trace halocarbons and biomass, the contribution of ozone to water quality does not appear to be significant at the concentrations used in the study.
  - d. The removal of ammonia during treatment was not significant. Some biological oxidation to nitrate occurred in the GAC towers.
  - e. A reduced level of many dissolved contaminants is characteristic of water processed by activated carbon, when its useful life is not exceeded. However, the COD effluent limit of 10 mg/l is difficult to achieve without significant cost incurred by continuously regenerating carbon.
  - f. Just prior to and during the first few weeks of this test period, processing of the influent to the reclamation plant was changed from an activated sludge reactor to a fixed-film reactor with nitrification and dual-media filtration. These changes generally reduced the contaminant levels to the reclamation plant. Data from a 1-month period, which are representative of conditions before these changes, have also been included in this report.
2. The capability to collect and process data for convenient and improved analysis of water quality information has been demonstrated. Over three million water quality measurements were recorded during the test period and are summarized in this report.

3. Both the reclamation plant and the WMS were designed and constructed as experimental test beds where reliability was of secondary importance to flexibility. Neither system was intended to function as an operational system. Rather, they were intended for testing various concepts and configurations for water treatment, automated quality monitoring and process control. Consequently, the numbers quoted in this report for availability and reliability are not meaningful of the performance that should be expected from operational systems. Rather, the data reported here provide a focus on problem areas which strongly influence reliability. This experience should guide the future design of reliable operational systems.
4. Automated monitoring provides a mechanism for better effluent quality control. Where real-time monitoring is not available, plant- or influent-initiated upsets may go undetected until laboratory test results are received by the operators, which may be several hours or days later. Such a method of operation places a severe restriction on quality control, especially where direct water reuse is involved, and would be unacceptable, for example, in manned spaceflight. Automated, real-time monitoring provides the capability to immediately identify abnormal conditions when they occur, in time to do something about them.
5. Automated water quality monitoring will be an economic necessity in the future as effluent quality control restrictions are tightened. The costs of repetitive laboratory analyses will become prohibitive, thereby increasing the demand for automated sensing, analysis, and reporting.
6. Automated water monitoring offers the potential for reduced water production costs through process and plant configuration control.
7. There is a need for improved reliability of many of the available components used for automated water quality monitoring.
8. The sophistication and advanced technology of some water quality sensors often require highly skilled personnel to isolate and resolve problems. These skills are generally unavailable in many wastewater plants.
9. Interference problems which had previously plagued the NASA-developed coliform sensor have been resolved. However, the complex plumbing arrangement necessary to operate a totally automated multicell sensor is prone to random contamination which, when experienced, has been difficult to eliminate. During the current test period, approximately 1 month of operating time was lost because of contamination. A configuration with less complexity should reduce this problem. Since the potential for reducing the coliform detection time from 72 hours by the laboratory MPN test to 11 hours by the electrode test is quite significant, the system is worthy of further development.
10. Problems have occurred because of different suppliers for WMS computer equipment. In the case of the reclamation plant these problems were avoided by virtue of having single contractor responsibility.
11. The experience of both the reclamation plant and the WMS has been that a computer service contract is key to maximizing system availability.

12. The high labor cost (three-fourths of water production cost) indicates that more attention should be given to maintainability in the design of water treatment and instrumentation systems.
13. Early implementation of a preventive maintenance program for the plant machinery and instrumentation systems can significantly reduce downtime.
14. Process and instrumentation checkout and verification are essential prior to turning the plant over to the operators.
15. The value of plant process instrumentation is significantly reduced if operators are not trained to properly interpret the data.

#### RECOMMENDATIONS

1. Much of the data collected by the WMS over the 3 1/2 years of operation at SCVWD-WRF/PA, prior to that reported here, have received only cursory review. During that period the plant was operated in several configurations with influent conditions ranging from high quality secondary effluent, which is presented in this report, to low quality influent, including settled primary effluent. The capability now exists and these data should be analyzed, similar to the analysis presented in this report, to show a full range of performance of plant processes.
2. Data exist for periods with and without an operating ozonator. These data should be analyzed to clearly show the net effect of ozonation in a real-world environment and to evaluate cost effectiveness.
3. A test program should be performed to identify key control parameters for effective chemical clarification by lime treatment. The experience at SCVWD-WRF/PA has been that the cost of the process in terms of labor and downtime may offset the benefits in water quality improvement.
4. When using lime for chemical clarification, it is recommended that a filtration step be included prior to GAC sorption. This will reduce the possibility of clogging the GAC with coagulant and/or calcium carbonate precipitant.
5. The potential for reducing activated carbon regeneration costs by operating the towers in a "biologic activated carbon" mode (no regeneration) should be explored.
6. Many operational difficulties after plant startup could be avoided by design verification testing, more intense and continuous operator training, and established requirements for a preventive maintenance program before acceptance from the contractor.
7. The requirements for the installation of computer systems in wastewater plants must consider the environmental requirements of the equipment. Computers must operate in dust and vibration free conditions.
8. Maintain a daily log to be used for recording plant and process downtime, the cause of the downtime, and the number of man-hours required to correct the problem.

9. Maintain a comprehensive record of materials and consumables, including the process in which they are used.
10. The WMS as configured is not ideal. The mobility design criteria dictated its design. The following factors should be considered in designing an in-place integrated plant water quality monitoring system:
  - a. Locate electronic equipment in an area away from potential contact with process or other chemical exposure.
  - b. Use state-of-the-art computer technology to simplify the data acquisition system. New improved equipment is available almost daily.
  - c. Use a single contractor for all computer equipment.
  - d. The system should be designed for automatic fault detection. If not, the time required to diagnose electronics failures typically will far exceed the time required to correct the problem.
  - e. All sensors should be evaluated with regard to serviceability and cost of consumables prior to purchasing.
  - f. Design the sampling system to ensure continuous, adequate sample flow to all sensors.
  - g. Take into consideration extensive requirements for drains, vents, air conditioning, and electrical power.
  - h. Take into consideration storage requirements for consumables and spares.
  - i. Include some laboratory area to do periodic wet chemistry verification work.
11. The NASA-developed biosensor has demonstrated the capability to quantify biological activity at the low concentration levels present in reclamation processes. However, its potential in monitoring and controlling biological treatment processes, such as activated sludge, has not been explored. A vital need for such a capability has been previously identified (reference 14).
12. The NASA-developed coliform sensor should be reconfigured to eliminate complex plumbing thereby improving reliability. The sample size should be increased to provide a minimum sensitivity of one organism per 100 ml. The potential benefits of single analysis units for automated analysis and also for laboratory applications have been previously identified (reference 14).



## WMS PERFORMANCE EVALUATION

The true measure of performance by developmental systems, such as the WMS, is the contribution made toward producing effective operational systems. This means that problem areas are uncovered and possible solutions are tested before committing the design of operational systems.

Much experience has been accumulated from WMS operations. Solutions to some identified problems are yet unresolved due to practical constraints (time and money). Available resources to date have been allocated primarily to functional considerations including the understanding of sensor characteristics (standardization requirements, interferences, data collection and validation), and software development to support a variety of potential data applications (sensor and system control, treatment process characterization, and plant process control). Reconfiguring the system to totally eliminate data errors and minimize downtime has received lower priority attention.

Predicting performance of some future operational system in terms of availability, reliability and O&M costs of an existing preprototype setup is approximate, at best, and is subject to misinterpretation. Nonetheless, such data are presented in the following paragraphs. The reader should recognize that this information contains measured performance of production hardware (commercial sensors) as well as preprototype systems (biological analyzers, GC analyzer, and computer software) whose production configurations have not yet been established and tested.

Hardware age contributed to the failure frequency. The biological sensors, for example, contain some NASA surplus hardware, primarily valves, which are approximately 10 years of age. The age of most of the commercial sensors is about 4-5 years or less.

### Sample Collection and Distribution System

The sample collection and distribution system was used to collect and distribute samples from six locations which included water of a quality ranging from City of Palo Alto final effluent to tertiary treated wastewater. The system worked very well throughout the test period. Fifty micron-woven stainless steel filters were used for filtration purposes for the test period. The filters are .08 cm thick and .10 cm in diameter. Two filters are located in the filter housing and are both used concurrently. Because of the high flow rate of sample across the filter surface and the backflushing action, the system had no difficulty removing particles and debris from the sample stream. What did present a problem was grease contained in the City of Palo Alto effluent during the last part of July and the first part of August. Also during the same time period, the high amount of lime present in effluent from the flocculator/clarifier also clogged the filters. During July, a malfunction in the reclamation facility resulted in the filters becoming clogged with carbon fines. In order to prevent a loss of sample flow during this problem period, the normal procedure of cleaning the filters on Monday, Wednesday, and Friday was modified to clean the filters five times a week. Figure 3 in Volume I shows the flow schematic for the system.

The only persistent problem that occurred during the test period was the buildup of debris in the pump recirculation valve which resulted in increased sample flow and the introduction of air bubbles to the sample. One backflush cylinder and control relay failed during the test period. Four sample valves failed also during the test period. Additionally, the main sample pump had to be rebuilt because of a bearing failure.

### Chemiluminescence Biosensor

The chemiluminescence biosensor currently processes and measures total and viable bacteria once during each 1-hour period. Typical values measured in the various wastewater effluents monitored by the WMS are illustrated in Figure 38. The sensor is routinely calibrated using a Coulter electronic particle counter and the firefly luciferase - ATP assay for total and viable bacteria, respectively.

The biosensor mechanically and electronically operated satisfactorily during the test period. There were, however, several minor problems encountered during this time. The flow cell became clogged with precipitant from the reagents. This problem was solved by disassembling and flushing the flow cell. The drain line became clogged with calcium carbonate and had to be replaced. Several pilot valves and the diaphragm in the compressed air pressure regulator failed and had to be replaced.

Correlation of the viable bacteria results of the biosensor presents special problems. Various values for viable bacteria can be obtained depending on the type of method employed. Each method measures a particular parameter associated with viability. The ATP method and luminol - CO method are measures of metabolism while the standard plate count method is a measure of the ability of a cell to reproduce and form colonies in an artificial environment. For this reason the luminol method cannot be expected to produce the same results as the plate counts. The ATP results have shown correlation with the luminol data; however, it is known that ATP levels within bacteria can fluctuate depending on environmental conditions and growth phase. For this reason, the ATP method can be used for "ball park" comparison and some deviations should be expected, the most consistent correlation occurs with the Coulter electronic particle counter.

### Gas Chromatograph

The GC operated quite well during the first part (July through September) of the test period. However, early in October, the preparatory columns lost carrier gas flow for several hours because of a malfunction of the shutoff valve on the carrier gas cylinder. As a result, the two preparatory columns began exhibiting an excessive amount of column bleed, which totally masked the compounds being monitored. Efforts to reduce the column bleed by baking out the columns at above normal operating temperatures were unsuccessful. Two new preparatory columns were ordered to allow the analyzer to be put back on line as soon as possible. However, when the new preparatory columns arrived and

ORIGINAL PAGE IS  
OF POOR QUALITY




Figure 38 Total and Viable Bacteria Levels in Various Waste-Water Effluents

were installed, they showed a high baseline signal. Procedures to reduce the baseline signal were immediately started. The procedures called for raising the operating temperature of the preparatory GC to increasingly higher temperatures (from 105°C to 150°C) and injecting ultrapure water into the preparatory columns to reduce the baseline to a usable level. This procedure was extremely time consuming. The baseline was determined to be at a usable level just prior to shutting the WMS down for the Christmas holidays. The Bendix automatic injector was found to be leaking air into the sampling chamber during the column bakeout period. Replacement parts were ordered and the injector rebuilt. The preparatory column oven and the analytical oven were shut down for the Christmas holidays, and both carrier gases were allowed to continue flowing. It was believed that this would prevent the columns from becoming contaminated; however, when the GC ovens were brought back up to operating temperature the columns showed extreme column bleed. Once again, the lengthy process of baking out the columns was begun. This process was still underway at the end of the test period. As a result, the GC only collected data for the months of July, August, and September. This fact is reflected in a very low availability.

### Total Organic Carbon Analyzer

The new low temperature ultraviolet light TOC analyzer was operational for the test period. Overall the analyzer worked quite well. Stability and response time were greatly improved over the old high temperature unit. Overall maintenance time was reduced considerably. The analyzer was modified to allow for computer-controlled automatic calibration. This system consisted of two Teflon air-actuated slider valves, two pilot valves, and two microswitches.

Several problems did occur during the test period. The first problem encountered was that the sparging system was not removing all of the inorganic carbon from the sample. This problem was corrected by adding 9.1 m of 0.5 cm inside diameter tubing to increase the contact time for conversion of inorganic carbon to CO<sub>2</sub>. Additionally, a change was made in the TOC calibration curve in the ADAM minicomputer. Two separate pump tubing failures occurred. The first of these was in the sample pump and resulted in some erroneous data. The second failure took place in the pump leading to the ultraviolet light reaction chamber. This was much more serious as it allowed the ultraviolet lamp to overheat and subsequently two of the three lamps failed. The water separator and sparger assembly developed a significant crack and had to be replaced.

### Hardness Analyzer

The operation of the analyzer was hampered by one persistent problem. The analyzer was found to be very susceptible to interferences from residual chlorine levels above 0.5 mg/l. The interference effect would cause the analyzer to show excessively high (400-1,000 mg/l) values. Additionally, the high amount of lime being added in the reclamation chemical clarification process flash mixer in July and August resulted in lime accumulation in the electrode chamber. The reagent tubing in the reagent container periodically clogged with debris suspended in the reagent container. With these exceptions, the analyzer's overall performance was good during the test period. The hardness analyzer is extremely expensive to operate in terms of labor and materials costs.

## Nitrate Analyzer

The nitrate analyzer's operation during the test period was limited. The main cause of the problem was the extremely high level of nitrate in the City of Palo Alto effluent. In July it was found that the analyzer was reading 9 mg/l on a sample having a lab verified value of 19 mg/l. The apparent cause was that above 9 mg/l the colorimetric system was unable to differentiate darker shades of blue. A decision was made to order a new autodiluter system to return the color of the sample to a usable level. The new diluter took over 6 weeks to arrive from the manufacturer since it is a nonstock item. Once the new metricone was installed, an effort was made to immediately calibrate the analyzer and put it back on line. However, at that point a problem was discovered with the transmission of the sensor status and data signal to the ADAM minicomputer. This problem was finally resolved after several weeks of troubleshooting. Once again, an attempt was made to put the analyzer back on line. However, it was found that the sensor would not stay in calibration for more than a few hours of operation. The manufacturer was contacted in an effort to resolve this problem. It is believed that the high levels of nitrate in the samples were causing the cadmium in the reduction chamber to become spent very quickly. The test period ended before a lasting fix was found for this problem.

## pH Analyzer

The Great Lakes Instrument Model 70 pH Analyzer provided good, reliable data. The sensor required calibration on an average of once a month during the test period. There wasn't any serious fouling of the probe as a result of sampling secondary effluent or the high lime content in the clarifier effluent. When the probe was removed for calibration, the electrode was checked for any accumulations of foreign material. The electrode tip was cleaned in a 0.1 N acid solution if a significant accumulation was found. For calibration, a pH standard of 7 was first used; followed by a pH standard of 10 to check the slope.

## Total Residual Chlorine Analyzer

Overall the analyzer operated very well and provided reliable data throughout the test period with a minimum of problems. The only lengthy downtime the analyzer encountered was due to the unavailability of the needed reagent from the manufacturer. The manufacturer has apparently worked out a new production schedule to resolve this problem. The analyzer is fairly expensive to operate in terms of routine maintenance and consumables.

## Sodium Analyzer

The Beckman Sodium Analyzer provided good data throughout the test period. However, the analyzer's flow system repeatedly clogged during the test period. This and the need to refill the zero and span standard containers on a daily basis require a high number of man-hours of effort each week. It has been found that it is necessary to disassemble and clean the flow system once a week

with dilute hydrochloric acid. This is because the anhydrous ammonia used in the analyzer causes the particles in the sample to clump and settle in the flow system. The anhydrous ammonia is necessary to adjust the pH level of the sample prior to introducing it to the electrode chamber. A problem was encountered with the gravity flow system that feeds electrolyte to the analyzer's reference electrode. A pressurized system was installed and the problem resolved, except for one occasion when the reference electrode tip clogged. This was resolved by placing the tip in boiling deionized water.

### Temperature Analyzer

The analyzer provided good reliable data throughout the test period except during the last week of operation when the Action-Pac amplifier failed. Additionally, the socket to which the amplifier is attached was replaced at the beginning of the test period. The probes' output was checked once each month against that from a glass thermometer inserted into the sample stream.

### Turbidity Analyzer

The Sigrist Photometer Turbidimeter worked extremely well throughout the entire test period. The analyzer provided excellent data with a minimum of routine or unscheduled maintenance. The only component which failed during the test period was the replaceable light source. The only routine maintenance required by the instrument was a once-a-week cleaning of the mirror in the flow cell and a check of the calibration. The TJ25 flow cell was used throughout the test period.

### Coliform Detector

Prior to the beginning of the test period, the coliform detector was reworked to the four-broth, four-buffer cell configuration as previously described. This change significantly enhanced the capability of the detector to eliminate false positive reactions caused by noncoliform bacteria. These changes were necessitated when it was discovered that several noncoliform bacteria strains found in the Reclamation Plant effluent were capable of imitating the electrode response generated by coliform bacteria.

The majority of the effort expended on the coliform detector was divided between testing the new sensor configuration and solving an internal contamination problem which will be discussed in this section.

Specially selected samples of coliform and noncoliform bacteria and mixtures of the two were tested in an extensive effort to prove the validity of the buffer cell principle. When evaluating each experiment, a 200 mv change in the buffer cell electrode was accepted as evidence of coliform growth in the nutrient cell. The buffer cells repeatedly showed negative reactions for the noncoliform bacteria strains that were producing positive reactions in the broth cells. Based on these results, it was determined that the proper operating procedure is to use the millivolt output of the buffer cells to determine the presence of coliform bacteria and to use the broth cells millivolt output results to determine the initial coliform concentrations. As an example, if the broth and buffer cells showed positive results, the time required for the broth cells to show a 200 mv change would be plotted on the calibration curve

to determine the initial coliform concentration. In all instances, this additional criterion was sufficient to allow for differentiation between coliform and noncoliform samples. Consequently, the reconfiguration of the coliform sensor has been deemed a success in dealing with the problem of false positives.

One major problem that surfaced during testing of the coliform sensor was that of internal bacterial contamination. The contamination problem was evidenced by the fact that on numerous occasions a sample which was known to be sterile showed growth in the nutrient cells. It was concluded that a significant population of bacteria was surviving the sensor's normal sterilization process and resided internally within the sensor at various times. Repeated washing and flushing of the sensor with various bacteriocides reduced but did not permanently eliminate the problem.

Presently, it is believed that the contaminating bacteria have been residing either within the sensor's pneumatic valve parts or inside the Teflon lines leading to the cells. As the sliding parts of the valves began to wear and their tolerance increased, small pools of nutrient and previous samples were discovered within the valves. In many instances, the leaks were not visible from the outside of the valves until the problem was well advanced. It is also thought that a bacterial and protein matrix may have been built up inside the sensor's tubing. In either case, the proposed solution for the contamination problem is a routine schedule of replacement for the coliform sensor's internal parts. It is believed that this action, along with close monitoring of internal valve tolerances, would alleviate the contamination problem.

In conjunction with the samples mentioned thus far, more than 20 samples of reclaimed effluent were tested for coliform concentrations. No positive reactions were observed in any of the reclaimed water samples. Correlating MPN tests substantiated the coliform results. It should be noted that the permissible number of coliforms in finished reclaimed effluent is 2.2/100 ml while the lower confidence limit for the coliform sensor is approximately 10/100 ml.

Mechanically, the coliform sensor operated very well during the test period. The few instances of component failure can be attributed to the sensor's age as it had seen more than 4 years of continuous service prior to the test period. It is believed that the parts that failed did so because they had reached the end of their useful lives. The following component failures were encountered during the test period:

1. Several PVC fittings on the hot water tank failed and were replaced with stainless steel.
2. Two temperature control boards failed during the test period. In each instance a single capacitor failed and was replaced.
3. Two electrodes began to give erratic readings and were replaced.
4. Several of the pneumatic valves began to leak fluids. In each instance new bushings were installed and the valve fittings were readjusted.

Table 13 shows the number of false positives which occurred during the test period. The data show that out of 48 broth cell tests made with Reclamation Plant effluent there were 8 false positive reactions. For the same samples there were zero false positive from the buffer cells. The results are even more impressive for the City of Palo Alto secondary effluent samples. Based on these data, the broth/buffer cell configuration appears to have successfully resolved the problem of false positive reactions caused by noncoliform bacteria.

TABLE 13

COMPARISON OF COLIFORM FALSE POSITIVES

|              | Reclamation<br>No. of False<br>Positives | Effluent<br>Reliability | Secondary<br>No. of False<br>Positives | Effluent<br>Reliability |
|--------------|--|-------------------------|--|-------------------------|
| Broth Cells  | 8/48                                     | 83.3%                   | 19/40                                  | 53.3%                   |
| Buffer Cells | 0/48                                     | 100.0%                  | 0/40                                   | 100.0%                  |

Ammonia Analyzer

The analyzer provided reliable data during the majority of the test period; however, several problems did occur which hampered operation. One problem which occurred repeatedly was air bubbles blocking sample flow in the gravity feed system. This was determined to be a flaw in the design of the analyzer. The metricone motor failed in July 1980, as did the signal amplifier unit. A problem with the colorimetric system was found in February 1981. The proper color change was not taking place in the flow system. The problem was traced to the pH value of the sodium hypochlorite reagent which was below the acceptable range of 7-8. The pH was adjusted upwards and the analyzer calibrated. The procedure for preparation of the reagent was modified to verify the pH of the sodium hypochlorite before preparing the reagent.

The analyzer is equipped with the WMS autostandardization system and was automatically calibrated once each day. Because of the frequency of reagent preparation, the analyzer was quite labor intensive.

Conductivity Analyzer

The Beckman analyzer performed throughout the test period without any significant problems. Periodically the flow cell was removed from the flow system and checked for buildup on the cell walls. The values were routinely compared with the two conductivity analyzers in the laboratory at the reclamation facility.

Dissolved Oxygen Analyzer

The Delta Scientific analyzer performed reliably throughout the test period without any major problems. One Teflon electrode membrane failure occurred. The calibration of the analyzer was routinely checked using a Hach wet chemistry dissolved oxygen kit.



## Deionized Water System

The system reliably provided high quality deionized water to the various parts of the WMS. The one problem which periodically occurred was bacteria contamination in the reverse osmosis storage tanks. As a result of this contamination it was necessary to sanitize the entire system once every 30 days. The R060 reverse osmosis cartridge was found to have a useful life of 6 months with the available tap water. This is approximately one-half the expected useful life. The recommended procedure for storing the reverse osmosis cartridge during an extended shutdown period calls for shutting off the tap water flow to the cartridge and placing it in a formaldehyde solution. This procedure did not seem to work satisfactorily for the 2 week shutdown at Christmas. It was found that the best procedure was to leave the tap water flowing and run the effluent from the cartridge to the drain.

## Data Acquisition and Report Generation System

Numerous hardware failures occurred for both computer systems during the test period. Some were hard failures and could easily be traced to printed circuit boards for the peripheral device control interfaces such as A/D, terminals and the magnetic tape unit. In addition, one computer memory board failure occurred on the average of every 3 months. Other failures were intermittent and could not be isolated to either software or hardware when one of the computers would halt. On the average, one failure occurred every week that resulted in approximately 16 hours downtime, although normally 8 hours per week can be expected.

Except for one software error in the NOVA 3D operating system that produced intermittent computer halts throughout the test period and was corrected in February 1981, all the failures could be traced to the hardware. A substantial number of failures were directly the result of poor electrical contacts. This problem may have been aggravated by the instances of chlorine gas entering within the WMS trailer when the WRF/PA had an equipment failure. The computer equipment is approaching the limit of its useful lifetime and can be expected to fail more frequently.

Some downtime was associated with software development activities during August 1980 and cannot be realistically charged to equipment availability. Also, the failures in January 1981 were the direct result of the equipment being turned off during the last 2 weeks of 1980. If these times are not considered, the average downtime is reduced to 5.5 hours per week.

## WMS Availability

WMS availability (percent of time the subsystems/sensors operated on demand) was monitored during the test period. The operating time and downtime periods for each of these are summarized in Table 14. The downtime recorded for each of the sensors/subsystems includes actual repair times and downtime attributed to waiting for necessary reagents or parts.

TABLE 14

## WMS AVAILABILITY/RELIABILITY

| WMS OPERATING ELEMENTS | DOWN TIME (HRS)/ OPERATING TIME (HRS)/ | (%) AVAILABILITY | ERRONEOUS DATA (HRS)/ TOTAL DATA (HRS) | (%) RELIABILITY | SIGNIFICANT PROBLEM(S)                    |
|------------------------|--|------------------|--|-----------------|---|
| Sampling System        | 11/3931                                | 99.7             | 246/3916                               | 94.5            | Periodic Plant Process Upsets             |
| Computer System        | 551/4454                               | 87.6             | 371/3903                               | 90.5            | Printed Circuit Board Failures            |
| Biosensor              | 171/3633                               | 95.3             | 110/3418                               | 96.8            | None                                      |
| Coliform Detector      | 17 <sup>1</sup> /97 <sup>1</sup>       | 82.5             | 0/88                                   | ----            | Contamination and Hardware Failures       |
| TOC                    | 355/3553                               | 90.0             | 148/3111                               | 95.2            | Failure of UV Lamps                       |
| Residual Chlorine      | 870/3672                               | 76.3             | 15/2994                                | 99.5            | Temporary Unavailability of Reagent       |
| Turbidity              | 1/3739                                 | 99.9             | 4/3737                                 | 99.9            | None                                      |
| D.O.                   | 2/3729                                 | 99.9             | 20/3724                                | 99.5            | None                                      |
| Ammonia                | 267/3324                               | 92.0             | 448/3055                               | 85.3            | Pump and Valve Failures, Reagent Problems |
| Nitrate/ Nitrite       | 3366/3587                              | 6.2              | 39/221                                 | 82.4            | Cadmium Reduction System Malfunction      |
| pH                     | 3/3764                                 | 99.9             | 48/3744                                | 98.7            | None                                      |
| Conductivity           | 0/3770                                 | 100.0            | 3/3753                                 | 99.9            | None                                      |
| Temperature            | 38/3762                                | 99.0             | 11/3719                                | 99.7            | Corrosion of Contacts in Socket           |
| Hardness               | 84/3504                                | 97.6             | 1249/3420                              | 63.5            | Interference of Residual Chlorine         |

TABLE 14 (Continued)

|                          |           |      |          |      |                                       |
|--------------------------|-----------|------|----------|------|---------------------------------------|
| Sodium                   | 100/3689  | 97.3 | 259/3591 | 92.8 | Buildup of Debris in Electrode Holder |
| G.C.                     | 2613/3635 | 28.1 | 100/1022 | 90.2 | Column Bleed in Preparatory G.C.      |
| D.I. Water               | 271/5447  | 95.0 | 0/5282   | ---- | None                                  |
| A.C. System <sup>2</sup> | 3/5832    | 99.9 | 0/5756   | ---- | None                                  |

NOTE:

<sup>1</sup>Coliform Detector Operations and Downtime Reported in Days.

<sup>2</sup>A. C. System is a dual unit, each independent of the other.

## WMS Reliability

Sensor/subsystem reliability (percent of operating time the data generated were valid) is summarized in Table 14. These values are calculated based on the number of hourly averages determined to be erroneous divided by the total number of hourly averages recorded. This calculation was made for each individual sensor/subsystem.

## WMS Operations and Maintenance Cost Summary

This section deals with the operations and maintenance costs for each of the sensors/subsystems. This is intended to cover all consumables, hardware and labor required for 8 months of continuous operation. This cost estimate is based on actual expenses incurred during the test period and as such may vary depending on the age of the hardware. An additional goal of the program was to determine, when possible, the life expectancy of the various subsystems. These data where available are reported in Appendix G.

The O&M costs for the sensors/subsystems of the WMS are summarized in Table 15. Extrapolation of these data gives a projected annual O&M cost of \$94,125.

The distribution of costs may be summarized as follows:

|             | <u>Labor</u> | <u>Materials</u> | <u>Total</u> |
|-------------|--------------|------------------|--------------|
| Operations  | 18.0%        | 4.9%             | 22.9%        |
| Maintenance | <u>57.6%</u> | <u>19.5%</u>     | <u>77.1%</u> |
| Total       | 75.6%        | 24.4%            | 100.0%       |

These calculations are based on the detailed data contained in Appendix G. Appendix G additionally contains a list of the recommended spares for each sensor/subsystem.

TABLE 15

OPERATIONS AND MAINTENANCE COST OF  
WATER MONITOR SYSTEM

JULY 1, 1980 THROUGH FEBRUARY 23, 1981

|                            | <u>1/</u> | <u>Operations</u> | <u>Maintenance</u> | <u>Totals</u> |
|----------------------------|-----------|-------------------|--------------------|---------------|
| Sampling System            |           |                   |                    |               |
| Materials and Supplies     | \$        | 340               | \$ 220             | 560           |
| Labor                      |           | 300               | 190                | 490           |
| Computer System            |           |                   |                    |               |
| Materials and Supplies     |           | 1070              | 2230               | 3300          |
| Labor                      |           | 4140              | 13600              | 17740         |
| Biosensor                  |           |                   |                    |               |
| Materials and Supplies     |           | 180               | 240                | 420           |
| Labor                      |           | 450               | 2080               | 2530          |
| Coliform Detector          |           |                   |                    |               |
| Materials and Supplies     |           | 300               | 470                | 770           |
| Labor                      |           | 2900              | 3070               | 5970          |
| Gas Chromatograph          |           |                   |                    |               |
| Materials and Supplies     |           | 200               | 670                | 870           |
| Labor                      |           | 1380              | 4500               | 5880          |
| TOC Analyzer               |           |                   |                    |               |
| Materials and Supplies     |           | 790               | 940                | 1730          |
| Labor                      |           | 340               | 860                | 1200          |
| Residual Chlorine Analyzer |           |                   |                    |               |
| Materials and Supplies     |           |                   | 1480               | 1480          |
| Labor                      |           | 70                | 1370               | 1440          |
| Turbidity Analyzer         |           |                   |                    |               |
| Materials and Supplies     |           |                   | 60                 | 60            |
| Labor                      |           | 60                | 110                | 170           |
| Dissolved Oxygen Analyzer  |           |                   |                    |               |
| Materials and Supplies     |           |                   | 100                | 100           |
| Labor                      |           | 30                | 110                | 140           |
| Ammonia Analyzer           |           |                   |                    |               |
| Materials and Supplies     |           |                   | 790                | 790           |
| Labor                      |           | 570               | 4320               | 4890          |
| Nitrate/Nitrite Analyzer   |           |                   |                    |               |
| Materials and Supplies     |           |                   | 960                | 960           |
| Labor                      |           | 220               | 1500               | 1720          |
| pH Analyzer                |           |                   |                    |               |
| Materials and Supplies     |           |                   | 50                 | 50            |
| Labor                      |           | 60                | 220                | 280           |
| Conductivity Analyzer      |           |                   |                    |               |
| Materials and Supplies     |           |                   |                    |               |
| Labor                      |           |                   | 110                | 110           |
| Temperature Analyzer       |           |                   |                    |               |
| Materials and Supplies     |           |                   | 130                | 130           |
| Labor                      |           | 20                | 110                | 130           |

TABLE 15 (Continued)

|                         |          |          |          |
|-------------------------|----------|----------|----------|
| Hardness Analyzer       |          |          |          |
| Materials and Supplies  |          | 1950     | 1950     |
| Labor                   | 140      | 1830     | 1970     |
| Sodium Analyzer         |          |          |          |
| Materials and Supplies  | 200      | 150      | 350      |
| Labor                   | 400      | 1890     | 2290     |
| Defionized Water System |          |          |          |
| Materials and Supplies  |          | 1370     | 1370     |
| Labor                   | 240      | 270      | 510      |
| General Lab Supplies    |          | 400      | 400      |
|                         |          | <hr/>    | <hr/>    |
| TOTALS                  | \$14,400 | \$48,350 | \$62,750 |

Projected Yearly O&M Cost = \$94,125

1/ NOTE:

Labor costs of \$37/hr. for engineering; \$27/hr. for all others.

2/ NOTE:

Includes operator time for implementing new software.

## Summary

As previously mentioned, the purpose for developmental systems is to identify problems before committing to the design of an operational system. The experience with the WMS has shown that the following will be key considerations when building reliable and inexpensive operational systems:

1. The ideal sensor: is an electrode; can be located in the sample; requires no reagents; is not subject to interference from other constituents in the sample; is fail-safe; i.e., it fails in a readily identifiable manner; is easily maintained; is rugged; has proven reliability in a variety of applications; resists fouling by solids or grease; is stable for long periods without calibration; does not require sample preconditioning, i.e., filtering, concentration, fixed flow rate, etc.; does not require complex electronics for control or signal conditioning; provides a direct continuous readout of a controllable parameter. Most water quality sensors do not meet all these specifications. Some conductivity cells and dissolved oxygen electrodes which are available on the market meet many of these requirements. Most other sensors introduce complexities which must be managed.
2. Colorimetric procedures and gravity flow through small tubing should be avoided in unattended automated sensor applications.
3. Operators should be trained to understand the significance of each measurement and the failure modes of the sensors. Competent vendors will provide such detailed information on the characteristics of their sensors. The comprehensiveness of the vendor's operating manual is often a good indicator of the quality of the product.
4. Sensors utilizing proprietary reagents should be avoided unless a contracted delivery schedule is prearranged.
5. The system design should provide fault detection, alarm, and alternate operating modes for significant failure modes:
  - a. Loss of sample.
  - b. Air in sample (where it interferes with the analyses).
  - c. Loss of sensor sensitivity, i.e., reagent, sample, etc.
  - d. Filter plugging.
  - e. Erroneous data.
6. Automatic standardization is a necessary requirement for unattended operation of most chemical sensors.

7. Computer systems hardware and software should be provided with error detection and correction capability. The ability to detect and correct single bit errors in the computer main memory can substantially increase reliability.
8. Direct memory access or high speed I/O channel programs should be provided when communicating with other computer systems. This will allow data to be transferred directly into main memory rather than a less reliable transfer by an applications program via a low speed device, i.e., RS232.
9. Dial-up/auto-answer communications provide the capability for remote failure diagnosis. Troubleshooting thereby can be accomplished without specialists being retained on-site.

## DATA PROCESSING

In addition to the real-time data display and trend plotting, the EVE report generation system has data processing capability for a lognormal distribution analysis and a linear regression analysis. A lognormal distribution was chosen to interpret the data obtained from monitoring based on the study performed by McCarty, et al, at Stanford University (reference 3). The Stanford study evaluated parameters for several probability models using various sets of organic and inorganic concentration data from Water Factory 21 in Orange County, California. Models for normal and lognormal probability distributions were selected for analysis because they produced reasonable data fits and provided ease of statistical interpretation. It was concluded that the lognormal distribution adequately represented the results at least 92% of the time and thus provided an adequate description of the probability for organic and inorganic materials at Water Factory 21. (The lognormal distribution was rejected for only ammonia and conductivity.)

Verification of the validity of the lognormal distribution is provided in the Stanford study, and no attempt was made to consider other probability models for this study. The lognormal distribution has a strong theoretical justification based on the assumption that fluctuations are proportional rather than additive. The chi square statistic was determined for each parameter as a method to evaluate the validity of the lognormal distribution and determine if the data were normally distributed. The results indicate a high correlation exists for most parameters.

A linear regression analysis was performed on all monitored data to evaluate the relationship between parameters across the reclamation plant and among processes. The least-square line obtained by the linear regression allows a determination of the standard error of estimate and the coefficient of correlation and thus provides a means of evaluating the direct dependence of the variables.

### Characteristics of the Lognormal Distribution

Normally distributed data will plot as a straight line on probability paper if the ordinate scale is arithmetic, while lognormally distributed data




will plot as a straight line if the ordinate scale is logarithmic. Normal distribution is one of the most important examples of continuous probability distribution and is defined by the following equation (reference 6):

$$y = \frac{1}{\sigma\sqrt{2\pi}} e^{-(X-\mu)^2/2\sigma^2}$$

Where  $\mu$  = mean,  $\sigma$  = standard deviation, and  $X$  is expressed in standard units with  $Z = (X-\mu)/\sigma$

In such cases,  $Z$  is normally distributed with mean zero and variance 1. A graph of the standardized normal curve is shown below with the areas included between  $Z = -1$  and  $+1$ ,  $Z = -2$  and  $+2$ , and  $Z = -3$  and  $+3$  as equal to 68.27%, 95.45%, and 99.73% of the total area under the curve which is one.



In order to analyze a set of data, the average and standard deviation of the logs are determined by common statistical procedures. The average so obtained represents the intercept, and the standard deviation represents the slope of the regression line for the lognormal distribution.

Computer plots of these results were generated for each parameter and for each period of interest. A representation of a typical result is shown in the following figure. The ordinate presents the log over the data range and the abscissa presents the percentage of time the total population was less than the measured value. The Percent of Time Less Than corresponds to the probability of occurrence for a measured value. The data range represents the daily average obtained from the hourly average which was determined from sample rates of 1 minute for all measurements with the exception of the G.C. and biomass measurements, which were recorded once each hour.



The Z-score is also shown on the abscissa for comparison. The 50% or zero value for Z represents the geometric mean. This plot is a good example of the waterfall decrease in the dependent variable across each process and readily shows the range of data for the report period.

The normal distribution function  $Q(x)$  is defined by Hasting's best approximate equation (reference 7),


$$Z(x) = \frac{e^{-x^2/2}}{\sqrt{2\pi}}$$

$$Q(x) = Z(x)[b_1 t + b_2 t^2 + b_3 t^3 + b_4 t^4 + b_5 t^5]$$

$$t = \frac{1}{1 + px}$$

|                  |                  |
|------------------|------------------|
| $p = .231642$    | $b_3 = 1.78148$  |
| $b_1 = .319382$  | $b_4 = -1.82126$ |
| $b_2 = -.356564$ | $b_5 = 1.33027$  |

where  $Q(x)$  = area under the standardized normal curve from 0 to +Z



The test for normality or goodness of fit is based on the  $\chi^2$  (chi square) distribution at the 95% confidence level for 2 degrees of freedom,

$$\chi_{.95}^2 = 5.99 \text{ (based on } Z \text{ being a function of } \mu \text{ and } \sigma \text{)}$$

$$\text{where } \chi^2 = \sum \frac{(f_o - f_e)^2}{f_e}$$

$f_o$  = observed or actual frequency


$f_e$  = estimated frequency based on a normal distribution

The chi square statistic has been calculated for each parameter at each sample point to evaluate the goodness of fit to the postulated lognormal distribution. There is only one chance in twenty of chi square exceeding 5.99 if the data are normally distributed. Thus, the lognormal distribution model may be rejected with 95% confidence when the value exceeds 5.99. Much of the data presented in this report is adequately described by a lognormal distribution, however, there are exceptions, as shown in Appendix D.

#### Characteristics of the Linear Regression

In a linear regression analysis, values of the dependent variable are predicted from a linear function of the form

Where  $Y'$  is the estimated value of the dependent variable  $Y$ ; the constant  $a$  (referred to as the  $Y$  intercept) is the point at which the regression line crosses the  $Y$  axis and represents the predicted value of  $Y$  when  $X = 0$ ; and the constant  $b$  (usually referred to as the regression coefficient) is the slope of the regression line and indicates the expected change in  $Y$  with a one-unit change in  $X$  (reference 7).



The regression method involves the evaluation of  $a$  and  $a_1$  in such a way that the sum of the squared residual is smaller than any possible alternative values, i.e.;

$(Y - Y')^2 = \text{minimum}$   
 where  $Y - Y' = \text{residual or difference between the actual and estimated value of } Y \text{ for each case}$

The optimum values of  $a$  and  $a_1$  are obtained from

$$a_1 = \frac{\Sigma(X - \bar{X})(Y - \bar{Y})}{\Sigma(X - \bar{X})^2} = \frac{N\Sigma XY - (\Sigma X)(\Sigma Y)}{N\Sigma X^2 - (\Sigma X)^2}$$

$$a_0 = \bar{Y} - a_1\bar{X} = \frac{(\Sigma Y)(\Sigma X^2) - (\Sigma X)(\Sigma XY)}{N\Sigma X^2 - (\Sigma X)^2}$$

The Standard Error of Estimate is a measure of the accuracy of the prediction equation. It is the standard deviation of actual  $Y$  values from the predicted  $Y'$  values or

$$\sigma_E = \text{Standard Error} = \sqrt{\frac{\Sigma(Y - Y')^2}{N - 2}}$$

The Standard Error is interpreted as the "average residual."

The linear correlation coefficient is the ratio of the explained variation to the total variation or

$$r = \sqrt{\frac{\text{explained variation}}{\text{total variation}}} = \sqrt{\frac{\Sigma(Y_{\text{est}} - \bar{Y})^2}{\Sigma(Y - \bar{Y})^2}}$$

where  $Y_{\text{est}} = \text{estimated value obtained from linear regression}$

$\bar{Y} = \text{average of dependent variable}$

$Y = \text{dependent variable}$

and is determined by

$$r = \frac{m\sigma_x}{\sigma_y}$$

where  $m = \text{slope of regression line}$

$\sigma_x = \text{standard deviation of independent variable}$

$\sigma_y = \text{standard deviation of dependent variable}$

Results of the regression analysis for the report periods are presented in Appendix A. Linear ( $Y = a + a X$ ), parabolic ( $Y = a + a X + a X^2$ ), and logarithmic ( $\text{Log}Y = a + a \text{Log}X$ ) regressions were performed for each parameter across each process and across the reclamation plant. Results indicate that linear and logarithmic regressions generally provide a good prediction for the downstream parameter. In some cases, particularly for the halocarbons and total organic carbon, the logarithmic regression produced a superior improvement in the correlation coefficient compared to the linear and parabolic regressions.

A typical example of a statistical summary and regression analysis is shown in Tables 16 and 17. The monthly average is determined from the hourly averages. The daily average variation is the standard deviation of the daily averages. The hourly average variation is the standard deviation of the hourly averages. The percent removal is determined from

$$\% \text{ removal} = \frac{I - O}{I} \times 100\%$$

where I = influent value

O = effluent value

for sample source 1 to 6 across the plant. The percent removal across each process is determined from

$$\% \text{ removal} = \frac{(I - O)_{\text{process}}}{(I - O)_{\text{plant}}} \times 100\%$$

where  $(I - O)_{\text{plant}}$  = measured concentration removal across the plant

$(I - O)_{\text{process}}$  = measured concentration removal across the process

In this manner, the removal efficiency of each process can be compared for the plant.

TABLE 16 SAMPLE STATISTICAL DATA

STATISTICAL DATA FOR SEP. 3, 1980 TO FEB. 20, 1981

SAMPLE SOURCE 1 - PALO ALTO SECONDARY EFFLUENT

| CNA | SENSOR            | UNITS   | SAMPLING FREQUENCY | MONTHLY AVERAGE | DAILY AVG VARIATION | HOURLY AVG VARIATION |
|-----|-------------------|---------|--------------------|-----------------|---------------------|----------------------|
| 1.  | TOTAL BIOMASS     | ML C/ML | 97                 | 2.016           | 1.1199              | 1.7454               |
| 2.  | VARIABLE BIOMASS  | ML C/ML | 99                 | 0.559           | 0.3026              | 0.5906               |
| 3.  | RES CHLORINE      | MG/L    | 91                 | 4.038           | 1.9410              | 2.0903               |
| 4.  | TURBIDITY-BIOMASS | MG/L    | 114                | 13.450          | 5.1520              | 5.9096               |
| 7.  | DIS OXYGEN        | MG/L    | 116                | 6.167           | 1.8201              | 1.9810               |
| 10. | AMMONIA           | MG/L    | 88                 | 5.181           | 10.1695             | 13.4274              |
| 11. | NITRATE           | MG/L    | 1                  | 229.007         | 0.0000              | 0.0000               |
| 12. | PH                | PH      | 115                | 5.601           | 0.4526              | 0.5157               |
| 13. | TOT OGC CARBON    | MG/L    | 96                 | 0.742           | 2.4224              | 2.8073               |
| 14. | CONDUCTIVITY      | MMHO/CM | 115                | 1230.413        | 62.6263             | 110.6200             |
| 15. | TEMPERATURE       | DEG F   | 114                | 71.576          | 2.4593              | 3.8632               |
| 16. | MARONESS          | MG/L    | 80                 | 327.246         | 330.3390            | 390.5041             |
| 17. | SODIUM            | MG/L    | 100                | 150.729         | 12.6491             | 16.5090              |
| 20. | AMBIENT TEMP      | DEG F   | 123                | 73.003          | 1.7700              | 3.0392               |
| 24. | TOT HALOCARBON    | PPH     | 29                 | 92.881          | 117.0067            | 157.5066             |

SAMPLE SOURCE 6 - RECLAMATION FACILITY EFFLUENT

| CNA | SENSOR            | UNITS   | SAMPLING FREQUENCY | MONTHLY AVERAGE | DAILY AVG VARIATION | HOURLY AVG VARIATION | PERCENT REMOVAL DAILY AVG STD DEV |
|-----|-------------------|---------|--------------------|-----------------|---------------------|----------------------|-----------------------------------|
| 1.  | TOTAL BIOMASS     | ML C/ML | 113                | 0.295           | 0.4231              | 0.9160               | 85.30 26.93                       |
| 2.  | VARIABLE BIOMASS  | ML C/ML | 116                | 0.141           | 0.3907              | 0.6425               | 74.80 120.17                      |
| 3.  | RES CHLORINE      | MG/L    | 104                | 2.022           | 1.1813              | 2.1562               | 89.80 47.73                       |
| 4.  | TURBIDITY-BIOMASS | MG/L    | 130                | 4.402           | 1.7975              | 3.0664               | 64.22 18.61                       |
| 7.  | DIS OXYGEN        | MG/L    | 130                | 6.191           | 1.6235              | 1.6905               | -0.39 34.39                       |
| 10. | AMMONIA           | MG/L    | 97                 | 0.215           | 12.7591             | 0.1426               | 18.01 79.83                       |
| 11. | NITRATE           | MG/L    | 3                  | 16.479          | 9.0534              | 0.0534               | 0.00 0.00                         |
| 12. | PH                | PH      | 130                | 6.000           | 0.5120              | 0.4809               | -0.55 0.07                        |
| 13. | TOT OGC CARBON    | MG/L    | 106                | 3.750           | 1.3520              | 1.2533               | 61.51 15.05                       |
| 14. | CONDUCTIVITY      | MMHO/CM | 130                | 1317.281        | 65.5074             | 75.7599              | -66.39 5.09                       |
| 15. | TEMPERATURE       | DEG F   | 137                | 71.301          | 1.7635              | 1.9501               | 0.00 0.00                         |
| 16. | MARONESS          | MG/L    | 89                 | 390.219         | 306.4944            | 332.9050             | -19.24 83.13                      |
| 17. | SODIUM            | MG/L    | 130                | 153.705         | 13.1527             | 15.5043              | 0.00 0.00                         |
| 20. | AMBIENT TEMP      | DEG F   | 147                | 77.149          | 2.2023              | 2.6781               | 0.00 0.00                         |
| 24. | TOT HALOCARBON    | PPH     | 28                 | 100.872         | 103.9368            | 160.8026             | -15.06 52.13                      |

EDF 11

TABLE 17 SAMPLE REGRESSION ANALYSIS

REGRESSION ANALYSIS FOR SEP 3, 1960 TO FEB 28, 1961

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 6

LINEAR CURVE FIT RESULTS (Y=AO + A1\*X)

| CNA NO. | SENSOR           | UNITS    | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|------------------|----------|----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS    | MIL C/ML | 0.2141   | 0.0400  | 0.4055         | 0.1124       | 92          |
| 2.      | VARIABLE BIOMASS | MIL C/ML | 0.1577   | -0.0360 | 0.3941         | 0.0291       | 93          |
| 3.      | RES CHLORINE     | MG/L     | 1.7591   | 0.0312  | 1.0366         | 0.1402       | 97          |
| 6.      | TURBIDITY-S102   | MG/L     | 4.4161   | 0.0015  | 1.4065         | 0.1627       | 109         |
| 7.      | DIS OXYGEN       | MG/L     | 2.6872   | 0.5447  | 1.1041         | 0.6437       | 109         |
| 10.     | AMMONIA          | MG/L     | -1.0724  | 1.0150  | 0.6096         | 0.0960       | 75          |
| 11.     | NITRATE          | MG/L     | 0.0000   | 0.0000  | 0.0000         | 0.0000       | 0           |
| 12.     | PH               | PH       | 4.0657   | 0.3535  | 0.4493         | 0.3327       | 110         |
| 13.     | TOT ORG CARBON   | MG/L     | 1.5039   | 0.2310  | 1.3211         | 0.3777       | 87          |
| 14.     | CONDUCTIVITY     | MMHMO/CM | 551.0430 | 0.6210  | 50.2376        | 0.5751       | 110         |
| 15.     | TEMPERATURE      | DEG F    | 30.3030  | 0.5749  | 1.1896         | 0.7604       | 109         |
| 16.     | HARDNESS         | MG/L     | 175.3407 | 0.6246  | 230.5027       | 0.7105       | 56          |
| 17.     | SODIUM           | MG/L     | 49.4441  | 0.6430  | 0.4651         | 0.6913       | 104         |
| 20.     | AMBIENT TEMP     | DEG F    | 70.7091  | 0.7101  | 1.0060         | 0.7813       | 119         |
| 29.     | TOT HALOCARBON   | PPB      | 15.0007  | 0.9306  | 20.5553        | 0.9720       | 22          |

PARABOLIC CURVE FIT RESULTS (Y=AO + A1\*X + A2\*X\*\*2)

| CNA NO. | SENSOR           | UNITS    | A0         | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|------------------|----------|------------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS    | MIL C/ML | 0.1043     | 0.1523  | -0.0216 | 0.4032         | 0.1547       |
| 2.      | VARIABLE BIOMASS | MIL C/ML | 0.1501     | -0.0222 | -0.0113 | 0.3941         | 0.0290       |
| 3.      | RES CHLORINE     | MG/L     | 1.2779     | 0.2698  | -0.0242 | 1.0250         | 0.2019       |
| 6.      | TURBIDITY-S102   | MG/L     | 2.1270     | 0.3504  | -0.0117 | 1.4407         | 0.2923       |
| 7.      | DIS OXYGEN       | MG/L     | 4.2449     | -0.0540 | 0.0517  | 1.0877         | 0.6749       |
| 10.     | AMMONIA          | MG/L     | -0.2070    | 0.6493  | 0.0000  | 4.5410         | 0.4993       |
| 11.     | NITRATE          | MG/L     | 0.0000     | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 12.     | PH               | PH       | -0.6006    | 4.4506  | -0.3235 | 0.4264         | 0.5144       |
| 13.     | TOT ORG CARBON   | MG/L     | 7.3310     | -0.0341 | 0.0456  | 1.2102         | 0.5297       |
| 14.     | CONDUCTIVITY     | MMHMO/CM | -3142.5410 | 6.6745  | -0.0025 | 93.1054        | 0.6314       |
| 15.     | TEMPERATURE      | DEG F    | -120.0141  | 4.9116  | -0.0290 | 1.0343         | 0.0310       |
| 16.     | HARDNESS         | MG/L     | -37.9160   | 1.5090  | -0.0004 | 200.1962       | 0.7941       |
| 17.     | SODIUM           | MG/L     | -279.7527  | 4.7522  | -0.0126 | 0.0106         | 0.7297       |
| 20.     | AMBIENT TEMP     | DEG F    | 151.2025   | -2.0750 | 0.0247  | 1.0012         | 0.7937       |
| 29.     | TOT HALOCARBON   | PPB      | 19.3210    | 0.6472  | 0.0002  | 20.4795        | 0.9722       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=AO + A1\*LOG(X))

| CNA NO. | SENSOR           | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|------------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS    | MIL C/ML | -0.6996 | 0.2628 | 0.2500         | 0.4833       |
| 2.      | VARIABLE BIOMASS | MIL C/ML | -1.0000 | 0.1996 | 0.3497         | 0.6575       |
| 3.      | RES CHLORINE     | MG/L     | 0.0670  | 0.2346 | 0.2816         | 0.3904       |
| 6.      | TURBIDITY-S102   | MG/L     | 0.0960  | 0.1155 | 0.1310         | 0.3407       |
| 7.      | DIS OXYGEN       | MG/L     | 0.4100  | 0.4641 | 0.0940         | 0.6431       |
| 10.     | AMMONIA          | MG/L     | -0.1634 | 0.0007 | 0.3558         | 0.0603       |
| 11.     | NITRATE          | MG/L     | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 12.     | PH               | PH       | 0.4067  | 0.3927 | 0.0384         | 0.3930       |
| 13.     | TOT ORG CARBON   | MG/L     | 0.2524  | 0.3075 | 0.1325         | 0.2500       |
| 14.     | CONDUCTIVITY     | MMHMO/CM | 1.3100  | 0.5410 | 0.0100         | 0.5650       |
| 15.     | TEMPERATURE      | DEG F    | 0.7571  | 0.5917 | 0.3071         | 0.7642       |
| 16.     | HARDNESS         | MG/L     | 0.9152  | 0.6520 | 0.1050         | 0.6922       |
| 17.     | SODIUM           | MG/L     | 0.4391  | 0.7043 | 0.0734         | 0.7836       |
| 20.     | AMBIENT TEMP     | DEG F    | 0.5009  | 0.6994 | 0.0060         | 0.7610       |
| 29.     | TOT HALOCARBON   | PPB      | 0.0760  | 1.0003 | 0.1927         | 0.9806       |



## RECLAMATION PLANT/PROCESS PERFORMANCE EVALUATION

This portion of the report was originally intended to describe the steady-state performance of the plant beginning in July 1980 through the end of February 1981. As shown in Table 18, the reclamation plant influent, effluent from the secondary treatment process, changed during this period from that for which the reclamation plant was originally designed; i.e., activated sludge to fixed-film reactor (deep trickling or roughing filter)/nitrification/dual-media filtration. These changes were in the process of stabilization for much of the summer of 1980. Also, once stabilized, these changes had a substantial effect on concentration levels of certain water quality parameters in the reclamation plant influent.

Thus, in order to provide the desired steady-state performance data which are representative of plant capability, the results of two different periods, A and H, are presented. Plant and influent processing during these two test periods is shown in Table 18. In some respects, period H, even though only a 1-month period, may be more representative than period A of conditions normally present in tertiary treatment. The configuration differences of these two periods are summarized below:

| <u>Influent Processing</u>                                     | <u>Period<br/>A</u> | <u>Period<br/>H</u> |
|--|---------------------|---------------------|
| Activated Sludge   |                     | X                   |
| Fixed-Film Reactor/<br>Nitrification/<br>Dual-Media Filtration | X                   |                     |
| <u>Granular Activated Carbon</u>                               |                     |                     |
| New  |                     | X                   |
| Exhausted  | X                   |                     |
| <u>Chemical Clarification</u>                                  |                     |                     |
| pH 9.5   |                     | X                   |
| pH 11  | X                   |                     |

Presented below are plant and process input/output data for periods A and H, plant and process availability and O&M costs as measured for the 8-month period beginning July 1, 1980, through February 28, 1981, and plant reliability for the two test periods.



## Input/Output

Figure 39 shows the location of sampling points in the process stream and the sampling schedule. Plant influent and effluent concentrations for the two test periods are summarized in Table 19. It should be noted that for period A, the pH of the influent was significantly lower because of nitrification at the city plant.


The percentage change in concentration across each of the processes is shown in Table 20. The change in a parameter as the water flows through each process can be followed horizontally, from left to right, for both test periods. Large negative values indicate that the process caused a significant reduction of this constituent. The overall effectiveness of each of the processes can be judged by examining the numbers vertically. It is readily apparent from this table that the chemical clarification and activated carbon sorption processes had the greatest influence on changes in water quality.

The results of a statistical analysis of process performance are presented for each WMS parameter in Figures 40 through 59. The upper graph compares plant input to output for the two test periods based on a lognormal distribution model and a  $\pm 3\sigma$  data range (99.7% of the data). The plot also shows results of measurements made on primary effluent during the H test period, thus providing a graphic illustration of total treatment results beginning with settled raw wastewater through secondary treatment and, finally, through tertiary treatment. Additionally, comparison of the reclamation plant influent data for the two test periods shows the differences in performance of the secondary processes in each of the test periods.

The data displayed in the bottom graphs show process performance and were developed by a linear least-squares fit of each process output as a function of plant influent concentration based on a log-log model; i.e.,  $\log O = m \log I + b$ . The results of this analysis are plotted in terms of percent removal and output/input for the influent concentration range indicated by the above lognormal distribution. The resulting curves allow the reader to follow a parameter through the plant (sampling points are consecutively numbered) and determine the cumulative contaminant removal as water progressed from process to process.

Figure 40, for example, shows in the upper graph the statistical distribution of the measured total biomass in the plant influent and effluent for test periods A and H. Total biomass in the primary effluent is also shown. The plotted curve illustrates how often the measured data were less than a particular value. Ideally there were an equal number of data points above and below the 50% point which is thus the mean of the data population. The variation of the data is reflected by the slope of the curve, where a horizontal line indicates that there was no variation. As a further illustration of the interpretation of these plots, the lower graphs in Figure 40 show the contribution of individual processes to contaminant removal. The period A results showed, for example, that most all the biomass in the influent was removed in chemical clarification, whereas the subsequent process, mixed media filtration, introduced additional biomass into the water stream, indicating that bacteria are growing and being continually eluted from the filter media.

**SAMPLING POINTS**



**SAMPLING TIME ~ HOUR OF DAY**

|    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|
| 3  | 2  | 4  | 4  | 5  | 6  | 1  |
| 9  | 8  | 10 | 10 | 11 | 12 | 7  |
| 15 | 14 | 16 | 16 | 17 | 18 | 13 |
| 21 | 20 | 22 | 22 | 23 | 24 | 19 |


- SAMPLING POINT 3a WAS ACTIVE BEFORE JULY 11, 1980 (INCLUDING TEST PERIOD H).
- SAMPLING POINT 3b WAS ACTIVE BEGINNING JULY 11, 1980 (INCLUDING TEST PERIOD A).

**Figure 39 Sampling Schedule**

**TABLE 19 PLANT PERFORMANCE FOR TWO TEST PERIODS  
(GEOMETRIC MEAN)**


|                         |         | PERIOD A           |          |          | PERIOD H |          |          |
|-------------------------|---------|--------------------|----------|----------|----------|----------|----------|
|                         |         | INFLUENT           | EFFLUENT | % CHANGE | INFLUENT | EFFLUENT | % CHANGE |
| TOTAL BIOMASS           | mc/ml   | 1.7                | 0.2      | -87.2    | 13.8     | 2.4      | -82.4    |
| VIABLE BIOMASS          | mc/ml   | 0.4                | 0.1      | -84.0    | 3.1      | 0.2      | -92.9    |
| TOTAL RESIDUAL CHLORINE | mg/L    | 3.5                | 1.7      | -53.0    | 9.5      | 1.9      | -79.9    |
| TURBIDITY               | mg/L    | 12.9               | 4.4      | -65.8    | 18.8     | 2.9      | -84.4    |
| DISSOLVED OXYGEN        | mg/L    | 5.8                | 6.0      | 2.4      | -        | -        | -        |
| TOTAL ORGANIC CARBON    | mg/l    | 9.4                | 3.6      | -62.2    | 13.8     | 3.3      | -76.4    |
| AMMONIA                 | mg/l    | 2.4                | 1.3      | -43.5    | 18.7     | 16.4     | -12.7    |
| NITRATE / NITRITE       | mg/l    | SENSOR NOT ON LINE |          |          |          |          |          |
| pH                      | pH      | 5.6                | 6.1      | 8.5      | 7.0      | 7.2      | 2.7      |
| CONDUCTIVITY            | µmho/cm | 1233.              | 1312.    | 6.4      | 1466.    | 1560.    | 6.4      |
| HARDNESS                | mg/l    | 269.               | 327.     | 21.3     | 367.     | 296.     | -19.5    |
| SODIUM                  | mg/l    | 158.               | 153.     | -3.2     | -        | -        | -        |
| TETRACHLOROETHYLENE     | µg/l    | 3.1                | 2.9      | -6.7     | 51.6     | 3.6      | -93.0    |
| METHYLENE CHLORIDE      | µg/l    | 16.7               | 10.0     | -40.4    | 10.5     | 20.8     | 98.6     |
| 1,2-DICHLOROETHYLENE    | µg/l    | 0.0                | 0.0      | 0.0      | 0.0      | 0.0      | 0.0      |
| CHLOROFORM              | µg/l    | 11.5               | 23.1     | 100.4    | 24.5     | 4.9      | -79.8    |
| 1,1,1-TRICHLOROETHANE   | µg/l    | 1.5                | 3.4      | 125.1    | 21.8     | 1.3      | -94.2    |
| BROMODICHLOROMETHANE    | µg/l    | 13.7               | 18.2     | 32.7     | 3.7      | 1.2      | -67.0    |
| TRICHLOROETHYLENE       | µg/l    | 1.5                | 1.8      | 19.9     | 20.8     | 1.5      | -92.7    |
| DIBROMDICHLOROMETHANE   | µg/l    | 7.4                | 12.9     | 73.9     | 1.5      | 1.1      | -29.0    |
| BROMOFORM               | µg/l    | 0.0                | 0.0      | 0.0      | 1.7      | 1.3      | -21.6    |
| TRIHALOMETHANES         | µg/l    | 33.4               | 57.0     | 70.6     | 31.7     | 8.3      | -73.8    |
| TOTAL HALOCARBONS       | µg/l    | 62.1               | 77.4     | 24.7     | 191.0    | 38.4     | -79.9    |

**TABLE 20 PROCESS PERFORMANCE FOR TWO TEST PERIODS  
(GEOMETRIC MEAN)**





**NOTE:**  
1. A CIRCLE WITHIN A NUMBER INDICATES THAT THE CHARGE IS NOT SIGNIFICANT, I.E., USUALLY LESS THAN 1%.

ORIGINAL PAGE IS  
OF POOR QUALITY.



**Figure 40 Data Distribution & Process Removal Characteristics**

ORIGINAL PAGE IS  
OF POOR QUALITY




- 1 - RECLAMATION PLANT INFLUENT
- 2 - CHEMICAL CLARIFICATION EFFLUENT
- 3 - RECARBONATION EFFLUENT
- 4 - FILTRATION EFFLUENT
- 5 - OZONATION EFFLUENT
- 6 - GRANULAR ACTIVATED CARBON EFFLUENT
- 3b - FILTRATION/CHLORINATION EFFLUENT

**RECLAMATION PLANT  
INFLUENT CONCENTRATION**


ORIGINAL PAGE IS  
OF POOR QUALITY

**Figure 41 Data Distribution & Process Removal Characteristics**









**Figure 42 Data Distribution & Process Removal Characteristics**



**Figure 43 Data Distribution & Process Removal Characteristics**





**Figure 44 Data Distribution & Process Removal Characteristics**





**Figure 45 Data Distribution & Process Removal Characteristics**

THIS PAGE IS  
OF POOR QUALITY



- 1-RECLAMATION PLANT INFLUENT
- 2-CHEMICAL CLARIFICATION EFFLUENT
- 3-RECLAMATION EFFLUENT
- 4-FILTRATION EFFLUENT
- 5-Oxidation EFFLUENT
- 5-GRANULAR ACTIVATED CARBON EFFLUENT
- 6-FILTRATION/CHLORINATION EFFLUENT

Figure 46 Data Distribution & Process Removal Characteristics



- 1-RECLAMATION PLANT INFLUENT
- 2-CHEMICAL CLASSIFICATION EFFLUENT
- 3-RECLAMATION EFFLUENT
- 4-FILTRATION EFFLUENT
- 5-SEDIMENTATION EFFLUENT
- 6-GRANULAR ACTIVATED CARBON EFFLUENT
- 7-FILTRATION/CLORINATION EFFLUENT

RECLAMATION PLANT  
INFLUENT CONCENTRATION

Figure 47 Data Distribution & Process Removal Characteristics




Figure 48 Data Distribution & Process Removal Characteristics





Figure 49 Data Distribution & Process Removal Characteristics








Figure 50 Data Distribution & Process Removal Characteristics

ORIGINAL PAGE IS  
OF POOR QUALITY



**Figure 51 Data Distribution & Process Removal Characteristics**







Figure 52 Data Distribution & Process Removal Characteristics





**Figure 53 Data Distribution & Process Removal Characteristics**


ORIGINAL PAGE IS  
OF POOR QUALITY



**Figure 54 Data Distribution & Process Removal Characteristics**



**Figure 55 Data Distribution & Process Removal Characteristics**



**Figure 56 Data Distribution & Process Removal Characteristics**






Figure 57 Data Distribution & Process Removal Characteristics





**Figure 58 Data Distribution & Process Removal Characteristics**

ORIGINAL PAGE IS  
OF POOR QUALITY



**Figure 59 Data Distribution & Process Removal Characteristics**

The computerized data analysis from which figures 40 through 59 were constructed is included in Appendix D.

Table 21 shows the results of a test to determine whether process performance can be reliably described, as above, by simple statistical procedures; i.e., by the mean and the standard deviation. Values of chi square are shown for the lognormal data distribution model. If the data for a test period fit the assumed model, a value of 6 or less will be obtained in 19 of 20 trials (test periods), thus, the model may be rejected for values greater than 6 with at least 95% confidence.

Table 21 shows that these values ranged from near zero, indicating a near perfect fit of the data to the model, to 66, indicating an extremely poor fit. Over half (57 percent) of the measurements had chi square values of 6 or less. The parameters which most consistently showed normality were: methylene chloride, total halocarbons, viable biomass, conductivity, hardness, trihalomethanes, chloroform and pH. Total biomass, ammonia and TOC showed a pronounced change in normality between the two test periods.

It is proposed that the chi square value may reflect process stability; i.e., a high value preceded by a low value in the water treatment process train indicates that this process is susceptible to random and unexplained upsets. On the other hand, a low value preceded by a high value shows that the process is tolerant to influent upsets. Table 22 shows the number of parameters which had a significant change between the influent and effluent of processes. Chemical clarification followed closely by ozonation generally reflected a greater stabilizing effect while GAC seemed to have the greatest tendency for unexplained upsets.

A consistently high chi square value may indicate that this particular water constituent or its sensor is inherently unstable. Only one measurement, trichloroethane, failed to show any lognormal distribution characteristics. On the other hand, if the chi square values were always low, say less than 1, the data may be "too good" and the responsiveness of the sensor might be suspect. Such consistently low values did not occur.

The following summarizes significant plant characteristics reflected by the data:

1. Influent Processing: The change in secondary treatment from activated sludge to fixed-film reactor/nitrification/dual-media filtration resulted in a significant reduction in reclamation plant loading for many contaminants.
2. Chemical Clarification:
  - a. When operating at pH 11, essentially all the biomass is removed in the sludge and/or by cell lysis (disintegration at high pH). Biomass removal was less effective at the lower pH of 9.5 in period H where about 60% was removed.

TABLE 21  
 CHT SQUARES  
 OF PROCESS EFFLUENTS  
 FOR TWO TEST PERIODS

| PROCESS                 | Period A |           |           |                  |             |           |      |     |            |    | Period H |           |           |                  |             |           |      |     |            |    |   |
|-------------------------|----------|-----------|-----------|------------------|-------------|-----------|------|-----|------------|----|----------|-----------|-----------|------------------|-------------|-----------|------|-----|------------|----|---|
|                         | PRIMARY  | SECONDARY | CHEM CLAR | CHEM CLAR/RECARB | RECARB/FILT | FILT/OZON | OZON | GAC | FILT/CHLOR |    | PRIMARY  | SECONDARY | CHEM CLAR | CHEM CLAR/RECARB | RECARB/FILT | FILT/OZON | OZON | GAC | FILT/CHLOR |    |   |
| TOTAL BIOMASS           | 23       | 12        | 2         | 1                | 4           | 24        | 1    | 6   | 6          | 24 | 9        | 33        | 4         | 5                | 6           | 3         | 3    | 1   | 1          | 9  | 6 |
| VIABLE BIOMASS          | 9        | 6         | 10        | 1                | 7           | 2         | 2    | 81  | 12         | 17 | 6        | 6         | 3         | 3                | 7           | 4         | 8    | 22  | 9          | 6  | 3 |
| TOTAL RESIDUAL CHLORINE | 60       | 6         | 2         | 9                | 20          | 20        | 8    | 22  | 6          | 3  | 38       | 6         | 8         | 8                | 8           | 4         | 4    | 11  | 19         | 6  | 3 |
| TURBIDITY               | 12       | 11        | 6         | 13               | 14          | 2         | 15   | 1   | 9          | 1  | 12       | 12        | 7         | 9                | 9           | 8         | 16   | 19  | 24         | 4  | 1 |
| DISSOLVED OXYGEN        | 3        | 3         | 7         | 9                | 4           | 8         | 4    | 10  | 4          | 4  | 3        | 12        | 7         | 9                | 4           | 8         | 10   | 10  | 24         | 4  | 4 |
| TOTAL ORGANIC CARBON    | 6        | 14        | 5         | 0                | 19          | 7         | 6    | 7   | 6          | 4  | 6        | 2         | 5         | 4                | 4           | 7         | 6    | 7   | 6          | 6  | 4 |
| AMMONIA                 | 2        | 2         | 6         | 12               | 3           | 4         | 4    | 6   | 6          | 6  | 2        | 2         | 6         | 12               | 3           | 4         | 4    | 6   | 11         | 3  | 6 |
| NITRATE / NITRITE       | 1        | 12        | 3         | 1                | 5           | 3         | 3    | 4   | 4          | 7  | 1        | 12        | 3         | 1                | 0           | 3         | 3    | 4   | 2          | 12 | 7 |
| pH                      | 6        | 6         | 5         | 4                | 4           | 7         | 6    | 5   | 6          | 4  | 6        | 6         | 4         | 4                | 0           | 3         | 3    | 4   | 2          | 12 | 7 |
| CONDUCTIVITY            | 2        | 2         | 6         | 12               | 3           | 4         | 4    | 6   | 6          | 6  | 2        | 2         | 6         | 12               | 3           | 4         | 4    | 6   | 11         | 3  | 6 |
| HARDNESS                | 1        | 12        | 3         | 1                | 5           | 3         | 3    | 4   | 4          | 7  | 1        | 12        | 3         | 1                | 0           | 3         | 3    | 4   | 2          | 12 | 7 |
| SODIUM                  | 3        | 3         | 4         | 4                | 4           | 4         | 7    | 1   | 8          | 8  | 3        | 3         | 4         | 4                | 4           | 4         | 7    | 1   | 8          | 8  | 8 |

TABLE 21 (Continued)

CHI SQUARES  
OF PROCESS EFFLUENTS  
FOR TWO TEST PERIODS

—— Period A      - - - - - Period B

| PROCESS                 | PRIMARY | SECONDARY | CHEM CLAR | CHEM CLAR/RECAMB | RECAMB/FILT | FILT/OZON | OZON | GAC | FILT/CHLOR |
|-------------------------|---------|-----------|-----------|------------------|-------------|-----------|------|-----|------------|
| TETRACHLOROETHYLENE     | 9       | 8         | 27        | 13               | 9           | 2         | 10   | 5   | 6          |
| METHYLENE CHLORIDE      | 2       | 1         | 3         | 3                | 3           | 4         | 5    | 1   | 1          |
| 1,2 - DICHLOROETHYLENE  |         |           |           |                  |             |           |      |     |            |
| CHLOROFORM              | 3       | 8         | 1         | 7                | 4           | 6         | 8    | 7   | 3          |
| 1,1,1 - TRICHLOROETHANE | 7       | 25        | 8         | 12               | 8           | 24        | 56   | 15  | 16         |
| BROMOCHLOROETHANE       | 5       | 9         | 6         | 13               | 5           | 1         | 4    | 3   | 17         |
| TRICHLOROETHYLENE       | 7       | 6         | 3         | 4                | 2           | 4         | 39   | 2   | 2          |
| DIBROMOCHLOROETHANE     | 21      | 7         | 1         | 7                | 6           | 1         | 0    | 5   | 4          |
| BROMOFORM               | 2       | 2         | 2         | 2                | 30          | 4         | 3    | 3   | 4          |
| TRIHALOMETHANES         | 2       | 9         | 8         | 4                | 6           | 1         | 0    | 5   | 3          |
| TOTAL HALOCARBONS       | 3       | 3         | 1         | 7                | 4           | 2         | 2    | 0   | 2          |

TABLE 22  
SIGNIFICANT CHANGES IN  
NORMAL DISTRIBUTION ACROSS PROCESSES  
NUMBER OF PARAMETERS

|                                | <u>MORE<br/>NORMALLY<br/>DISTRIBUTED</u>                  |           | <u>LESS<br/>NORMALLY<br/>DISTRIBUTED</u>                  |           |
|--------------------------------|---|-----------|---|-----------|
|                                | <u>PHYSICAL/<br/>CHEMICAL/<br/>BIOLOGICAL<br/>SENSORS</u> | <u>GC</u> | <u>PHYSICAL/<br/>CHEMICAL/<br/>BIOLOGICAL<br/>SENSORS</u> | <u>GC</u> |
| SECONDARY<br>(PERIOD H)        | 4   | 1         | 1   | 3         |
| CHEM CLAR/RECARB<br>(PERIOD A) | 5   | 2         | 1   | 0         |
| CHEM CLAR/RECARB<br>(PERIOD H) | 1   | 4         | 3   | 1         |
| RECARB/FILT<br>(PERIOD A)      | 1   | 3         | 2   | 0         |
| FILT/OZON<br>(PERIOD H)        | 2   | 5         | 3   | 1         |
| OZON                           | 3   | 0         | 1   | 2         |
| GAC<br>(PERIOD A)              | 2   | 3         | 2   | 2         |
| (PERIOD H)                     | 0   | 2         | 2   | 3         |
| FILT/CHLOR<br>(PERIOD A)       | 2   | 1         | 5   | 1         |
| (PERIOD H)                     | 3   | 0         | 1   | 1         |

- b. The turbidity measurement indicates that only about 25% of the suspended solids removed in the plant are removed by chemical clarification. In light of the biomass data, which indicate that a much larger portion of the suspended solids is removed in the clarifier, this small decrease in turbidity is attributed to floc carryover. Experience with fouling of downstream equipment by calcium carbonate deposits supports this interpretation.
- c. More TOC was removed; i.e., 3 versus 1.5 mg/l, when operating at the higher pH of period A (with aeration at pH 11, TOC removal increased to 5.5 mg/l during period G. The aerators were not operational during periods A and H).
- d. The concentration of the trihalomethanes is increased. This is probably due to the additional time that the chlorine is in contact with organics in the clarifier. This allows more chlorinated organic formation time.
- e. Ionic activity associated with lime treatment increases the conductivity. This suggests the possibility of controlling lime dosage using a conductivity sensor rather than pH sensor for operational reliability reasons; however, the durability of the conductivity probe in this environment has not been tested. The pH control currently used has been a consistent problem because of pH probe fouling in the high solids environment.
- f. An apparent pH anomaly was noted during period A. While the pH was controlled at 11 in the flash mixer, the measured value in the aerator sump tank just ahead of recarbonation was approximately 7. In previous test periods these two pH values have been nearly the same. The noted difference remains unexplained.

### 3. Ozonation:

- a. Ozonation results in a reduction in few of the measured parameters. (Presented here are the complete data collected during the test period. There were times during this period when the ozonator was not operating because of equipment failure. These periods are known, and an analysis could be performed to quantify the effect of ozonation by comparing ozonator operating data with ozonator nonoperating data. Because of time constraints, that analysis has not been done.)
- b. The increase in turbidity after ozonation appears to be an anomaly. This increase may result from entrained gases in the effluent sample. If so, they are very fine particles since they are not visible to the naked eye.

It may be assumed that turbidity is not a reliable measure of the presence of suspended solids wherever entrained gases are introduced into the process stream. Sample points 2, 3b, 5, and 6 may thus be the only reliable points for measuring suspended solids by turbidity since gases may essentially be removed in the preceding process; i.e., clarification or filtration.

If the ozonation effluent data are ignored, Figure 43 shows that much of the work of removing particulate matter, at least that which reflects light at 25 degrees, is done in the first filtration and not in the GAC as the data may seem to indicate. The plant's experience with persistent flocculant carryover from the clarifier with the accompanying calcium carbonate deposits on downstream equipment may support this interpretation of the data; e.g., there is no significant decrease in turbidity (suspended solids) before the initial filtration and the decrease in organic material (TOC and Biomass) in the chemical clarification is offset by an increase in calcium carbonate precipitant.

#### 4. Mixed Media Filtration:

- a. Biological growth in the first filtration step results in an increase in biomass in downstream processes.
- b. The first filtration step provides the largest portion of the plant's turbidity removal. As discussed previously, this removal is largely floc carryover from chemical clarification.
- c. The addition of dual-media filtration in the secondary plant (period A) reduced the amount of solids in the reclamation influent and thus substantially increased the time periods between backwashes in the reclamation plant filters.

#### 5. Granular Activated Carbon:

- a. A reduced level of many contaminants is characteristic of water processed by GAC, when its useful life is not exceeded. The virgin carbon used during period H resulted in a pronounced reduction in most organic materials. The exhausted carbon in the system during period A was saturated resulting in an increased rather than a decreased concentration for many of the measured trace organics.
- b. All halocarbons are reduced in new GAC except methylene chloride, which is produced. In contrast, methylene chloride was removed by exhausted carbon during period A.
- c. Most halocarbon concentrations were increased by GAC processing in period A because the carbon had been previously saturated at levels higher than the period A influent levels.
- d. It is common to find biomass elution from GAC especially under favorable growth conditions; i.e., high dissolved oxygen, pH < 11, no ozone. Some growth was apparent during period H. Promoting biological growth in the GAC may extend its useful life (reference 4).
- e. Most of the plant's ammonia removal occurs in the GAC probably by biological activity; i.e., by nitrification.



- f. Mean TOC removal varied from 7.7 mg/l (O/I of 0.29) for new carbon in period H to 2.6 mg/l (O/I of 0.60) for exhausted carbon in period A. The TOC removal in period A is attributed to biological activity. In the adsorption operating mode, new GAC may be more accurately characterized as a constant TOC quantity removal process rather than as a percentage removal process (note the negative slope in Figure 42, period H, sample source 5). A different performance characteristic is obtained in the biological mode of period A.
- g. Stanford University's Civil Engineering Department has conducted a test program to characterize activated carbon performance with operating age (reference 5). Composite samples were continuously collected for a period of 7 months (test period C) with the SCVWD-WRF/PA operating with three parallel carbon columns: The first containing virgin carbon, the second containing regenerated carbon, and the third containing exhausted carbon. Composite samples of the influent and the effluent of each column were periodically analyzed (usually once a week) for various organic compounds to determine the change in carbon removal performance with time. These data are presented in Appendix E.

Included with the Stanford data in Appendix E are comparable WMS measurements made during the same time period. However, the WMS data were taken at a point after mixing of the effluent of the three columns. Thus, an average of the Stanford effluent data was computed to provide a data comparison which should be valid assuming equal flow through each of the three columns and good mixing ahead of the sampling point.

A least-squares fit of the Stanford data for two of the measurements, TOC and chloroform, is shown in Figure 60, where performance is plotted as a function of age.

The data for chloroform indicate an effective operating life of 77 days with an adsorption capacity of 0.066 mg/gm carbon at 13.8 g/l. This value is consistent with previous test results with virgin carbon (reference 4). As indicated by the data in Appendix E, the GAC performance for chloroform is typical of the other volatile organics.

The Stanford data for TOC indicate an effective operating life approaching 179 days indicating an adsorption capacity of 63.2 mg TOC/gm carbon at 8.5 mg/l. However, at about 130 days, a discontinuity in the data indicates that action of biological growth on the carbon reached an equilibrium for the remainder of the test period with a TOC removal of about 5600 gms/day (0.28 mg TOC/gm carbon/day).

LEAST SQUARES FIT (DATA FROM APPENDIX B)

TOC

$$\left. \begin{aligned} O/I &= 0.123 + \frac{BV}{8700} \\ &= 0.123 + \frac{D}{204} \end{aligned} \right\} r = 0.96, T = 8.5 \text{ MG/L}$$

CHLOROFORM

$$\left. \begin{aligned} O/I &= \log^{-1} [1.87 \log (BV) - 6.58] \\ &= \log^{-1} [1.87 \log D - 3.53] \end{aligned} \right\} r = 0.92, T = 13.8 \text{ } \mu\text{G/L}$$




Figure 60 Time History of Granular Activated Carbon Performance

Better TOC removal by biological activity has been measured during previous test periods. During test periods F and G where the aerators were operating and the ozonator was not operating, over 50% better TOC removal performance in the GAC was indicated (reference 4). These results suggest that conditioning the influent to the GAC can have a significant influence on TOC removal performance and, thus, on carbon regeneration costs. These costs are discussed in a later paragraph.

### Plant/Process Availability

Plant and process availability (percent of time the plant/process operates on demand) was monitored during the test period. The objective of operating the plant continuously for the 8-month (5832-hour) test period was met except for 69 hours when plant influent was unavailable, and when plant equipment failed. The operating time and downtime-for-repair periods for each of the processes are summarized in Table 23. Equipment failures experienced during the 8-month test period resulted in an estimated 20 days annually when the plant would be unable to deliver product; i.e., reclaimed water.

Included in this analysis is consideration of product storage capacity. Plant shutdowns of less than 8 hours were not recorded as plant downtime since reclaimed water could be delivered at the operating flow of 0.066 m<sup>3</sup>/sec. for up to 8 hours from the 1893 m<sup>3</sup> effluent storage tank.

The individual processes did not have the capability to continue process operations when equipment failed because there was negligible intermediate storage. Therefore, the downtimes recorded for each of the processes are actual repair times. However, in many cases equipment failures did not result in plant shutdown because the capability to bypass nonoperating processes was afforded by plant design flexibility.

The problems necessitating process equipment repair are outlined in Appendix C. There were three predominant problems:

1. Calcium carbonate encrustations on equipment causing pump malfunctions and scale buildup on the inside walls of piping, thereby reducing flow capacity.
2. Plumbing failures within the ozonator.
3. Carbon furnace equipment component failures. Carbon was regenerated from the unused tower during the test period. The operator efforts required to do this were quite intensive. After complete regeneration of this tower, it was decided to cease any further regeneration. This decision was based on labor requirements and the fact that Stanford University's research involved long-term sorption characteristics of activated carbon without regeneration.

The increased labor was due primarily to carbon furnace failures which included jamming of 1) the dewatering screw, 2) the horizontal feed screw, 3) the carbon drop chute, 4) the outlet at the base of the

TABLE 23  
 AVAILABILITY OF  
 PALO ALTO RECLAMATION FACILITY  
 JULY 1, 1980 THROUGH FEBRUARY 28, 1981

|                                  | <u>OPERATING<br/>TIME, HR.</u> | <u>DOWNTIME,<br/>HR.</u> | <u>AVAILABILITY,<br/>%</u> | <u>ESTIMATED<br/>YEARLY DOWNTIME,<br/>DAYS</u> |
|----------------------------------|--------------------------------|--------------------------|----------------------------|--|
| CHEMICAL<br>CLARIFICATION        | 4,993                          | 654                      | 88.4                       | 43   |
| RECARBONATION                    | 4,825                          | 91                       | 98.1                       | 7  |
| OZONATION                        | 4,160                          | 1,217                    | 77.4                       | 83   |
| MULTIMEDIA<br>FILTRATION         | 5,324                          | 0                        | 100.0                      | 0  |
| CARBON<br>SORPTION <sup>1/</sup> | 5,324                          | 0                        | 100.0                      | 0  |
| CHLORINATION                     | 5,324                          | 0                        | 100.0                      | 0  |
| COMPUTER                         | 5,324                          | 81                       | 98.5                       | 6  |
| PLANT<br>(PRODUCT DELIVERY)      | 5,455                          | 308                      | 94.7                       | 20   |

NOTE:

1. CARBON REGENERATION FURNACE WAS NOT OPERATED DURING THE TEST PERIOD.

carbon furnace as it enters the quench tank, and 5) the bottom of the spent carbon storage tank during carbon transfer. Also, the burner temperature control sensors malfunctioned quite frequently which resulted in improper temperatures within each hearth of the multiple hearth furnace. The operators spent considerable time unjamming the previously mentioned problem areas, and the operation required close attention during the regeneration process. Miscellaneous breakdowns included boiler breakdown, I.D. fan failures, and clogging at the outlet of the quench tank which added to the problems. This necessitated the discontinuance of further attempts to regenerate carbon.

### Plant Reliability

Figure 61 illustrates the method of determining plant reliability. The data distribution curve, Figures 40 to 59, at the MCL establishes the probability (reliability) that plant effluent will not exceed the MCL.

Plant reliability (percent of operating time that the plant effluent was within given limits) is summarized in Table 24. Some of these limits are illustrative only in that they are not discharge limits on this particular plant but are potential limits should the plant effluent be used for potable or irrigation purposes.


### Plant O&M Costs

The O&M costs of the plant during the 8-month test period are presented in Table 25. Extrapolation of these data gives a projected annual plant production cost of \$311,400. Water production costs were \$0.16 per 1000 liters.

The distribution of costs as determined from the totals shown in Table 18, including all categories, may be summarized as follows:

|             | <u>Labor</u> | <u>Materials</u> | <u>Total</u> |
|-------------|--------------|------------------|--------------|
| Operations  | 49.4%        | 25.5%            | 74.9%        |
| Maintenance | <u>22.5%</u> | <u>2.6%</u>      | <u>25.1%</u> |
| Total       | 71.9%        | 28.1%            | 100.0%       |

The labor costs shown under the subheading General Plant Operations include preventative maintenance on all equipment contained within the reclamation facility. It also includes maintenance that require less than 4 hours of effort. Operator process monitoring, filter backwashing, plant rounds keeping, and miscellaneous water quality testing are included in this category. Plant operators', electricians', and mechanics' labor constitutes the majority of the cost in this category. This subheading is to cover those undefinable labor costs that could not be allocated specifically to a unit process.



**Figure 61 Determination of Reliability (Example)**

TABLE 24  
RELIABILITY OF PALO ALTO RECLAMATION FACILITY

|                         | MAXIMUM<br>CONCENTRATION<br>LIMIT<br>MCL | MINIMUM<br>CONCENTRATION<br>LIMIT<br>MCL (MIN) | REFERENCE | RELIABILITY                            |          |
|-------------------------|--|--|-----------|--|----------|
|                         |  |  |           | PERIOD A                               | PERIOD H |
| CHEMICAL OXYGEN DEMAND  | 10 mg/l                                  | -  | 9         | 65.0% $\angle$ 1                       | 57.8%    |
| TRIMALOMETHANES         | 100 mg/l                                 | -  | 10        | >99.9%                                 | >99.9%   |
| TOTAL NITROGEN          | 5 mg/l                                   | -  | 9         | 86.1% $\angle$ 2<br>(NH <sub>3</sub> ) | <0.0%    |
| pH                      | 8.5                                      | 6.5  | 9         | 18.7%                                  | 99.9%    |
| DISSOLVED OXYGEN        | -  | 1 MG/L   | 9         | >99.9%                                 | -        |
| HARDNESS                | 500 mg/l                                 | -  | 11        | 78.6%                                  | 97.3%    |
| SODIUM                  | 250 mg/l                                 | -  | 12        | >99.9%                                 | -        |
| TOTAL RESIDUAL CHLORINE | -  | 1 MG/L   | 9         | 76.2%                                  | 77.5%    |
| CONDUCTIVITY            | 1600 umho/cm                             | -  | 13        | >99.9%                                 | 70.9%    |
| TURBIDITY               | 5 NTU                                    | -  | 9         | -                                      | -        |

NOTES:

1. ASSUMES COD/TOC RATIO OF 2.5.
2. BASED ON AMMONIA OR NITRATE CONCENTRATION.

TABLE 25  
 OPERATIONS & MAINTENANCE COSTS OF  
 PALO ALTO RECLAMATION FACILITY  
 JULY 1, 1980 THROUGH FEBRUARY 28, 1981

1/

|                             | <u>OPERATIONS</u> | <u>MAINTENANCE</u> | <u>LAB</u>      | <u>ADMINISTRATION<br/>&amp; ENGINEERING</u> | <u>TOTALS</u>    |
|-----------------------------|-------------------|--------------------|-----------------|---|------------------|
| CHEMICAL CLARIFICATION      |                   |                    |                 |   |                  |
| LIME                        | \$19,290          | -                  | -               | -   | \$32,890         |
| LABOR                       | -                 | \$13,600           | -               | -   |                  |
| RECARBONATION               |                   |                    |                 |   |                  |
| LABOR                       | -                 | 650                | -               | -   | 650              |
| OZONATION                   |                   |                    |                 |   |                  |
| LABOR                       | -                 | 3,960              | -               | -   | 3,960            |
| MULTIMEDIA FILTERS          | -                 | -                  | -               | -   | -                |
| CARBON ADSORPTION           | -                 | -                  | -               | -   | -                |
| CHLORINATION                |                   |                    |                 |   |                  |
| CHLORINE                    | 580               | -                  | -               | -   | 580              |
| COMPUTER                    |                   |                    |                 |   |                  |
| LABOR                       | -                 | 13,770             | -               | -   | 13,770           |
| GENERAL PLANT OPERATIONS 2/ |                   |                    |                 |   |                  |
| ELECTRIC                    | 30,650            | -                  | -               | -   | 155,740          |
| GAS                         | 2,360             | -                  | -               | -   |                  |
| MATERIALS & SUPPLIES        | -                 | 5,440              | -               | -   |                  |
| LABOR                       | 64,870            | -                  | 23,110          | 29,310                                      |                  |
| <b>TOTALS</b>               | <b>\$117,750</b>  | <b>\$37,420</b>    | <b>\$23,110</b> | <b>\$29,310</b>                             | <b>\$207,590</b> |

TOTAL WATER COST = \$0.16 PER M<sup>3</sup> (\$0.60 PER 1000 GAL.)

PROJECTED YEARLY O & M COST = \$311,400

ORIGINAL PAGE IS  
 OF POOR QUALITY

NOTES

1. LABOR COST OF \$37/HR. FOR ENGINEERING; \$27/HR. FOR ALL OTHERS. ◁
2. CARBON WAS NOT REGENERATED DURING THE TEST PERIOD.
3. INCLUDES PREVENTIVE MAINTENANCE AND MINOR MAINTENANCE REQUIRING LESS THAN FOUR HOURS LABOR.

▷ THE COSTS REPORTED HERE MAY BE UNIQUE TO THE EQUIPMENT & SYSTEM DESIGN OF THIS PARTICULAR FACILITY. CARE MUST BE EXERCISED IN EXTRAPOLATING THESE COSTS TO OTHER SYSTEM DESIGNS OR DIFFERENT PLANT CAPACITIES.



These costs did not include carbon replacement/regeneration since exhausted carbon was used throughout the test period. If carbon had been regenerated, the costs could have increased significantly.

Figure 62 illustrates potential water cost based on a \$0.227 per kilogram carbon regeneration cost and a TOC effluent upper limit of 4 mg/l. The figure shows the strong cost dependence on influent conditions and performance reliability. For example, the water production cost presented above (\$0.16 per 1000 liters) would about double for plant influent conditions of test period A, if 99 percent reliability were achieved. For the lower quality influent of test period H, the production cost could have more than doubled.


It should be noted that a significant but unconfirmed assumption was made in developing Figure 62; i.e., the performance achieved by continuously regenerated carbon, based on average carbon age existing in the column, will be the same as that obtained when the column contains all carbon of the same age. This assumption allows the carbon performance of Figure 60 to be used in computing continuous regeneration rates. The linear decay in performance seems to substantiate the assumption; however, the resulting computed costs should be considered approximate until actual tests confirm the postulated performance.

The sudden tail-off of the cost curve for period A occurs at about 50% reliability below which steady-state biological growth on the carbon maintains performance without the necessity of carbon regeneration.

It is significant to note that if over 50% reliability is to be maintained, costs will be incurred which will significantly increase the cost of water production.

**BASIS**

1. COD LIMIT OF 10 mg/l. COD/TOC RATIO OF 2.5.
2. INFLUENT CONCENTRATIONS OF FIGURE 20 .
3. PERFORMANCE WITH CONTINUOUS CARBON REGENERATION IS THE SAME AS THAT SHOWN IN FIGURE 60 BASED ON AVERAGE CARBON AGE.
4. CARBON REGENERATION COST OF \$0.227 PER KILOGRAM.



**Figure 62 Relationship Between Cost & Reliability for Complying With COD Discharge Limit by Granular Activated Carbon Regeneration**

## SECTION 4

### FUTURE APPLICATIONS

A primary responsibility of the Santa Clara Valley Water District is to insure an adequate quantity and quality of water supplies for Santa Clara County, California. The existing needs are met from local and imported supplies. Local supplies are from the natural yields of the County's three interconnected subbasins and the yields of the major tributary surface drainage areas into District reservoirs. Water is imported into Santa Clara County from the South Bay Aqueduct of the California State Water Project. In addition, water is imported through the City of San Francisco's Hetch-Hetchy Aqueduct by various cities in North Santa Clara Valley. Imported water is needed in Santa Clara County even during an average rainfall year, and a new importation supply from the Bureau of Reclamation San Felipe Division of the Central Valley Project is being constructed to fill this need.

The Santa Clara Valley Water District is committed to developing alternative supplies including reclaimed water. There are, however, barriers to reuse - principally economic and assurance of safety (i.e., water quality). The Palo Alto Reclamation Plant and the NASA WMS have been crucial projects for exploring these barriers.

Early in the Palo Alto Reclamation Project, the Santa Clara Valley Water District concluded that on-line water quality analysis would be essential to the successful marketing of high quality reclaimed water, and contacted NASA for their help and expertise in this area.

It was felt that even though there are wet chemistry analyses available for determination of water quality, these tests would be unacceptable because it often takes days before the results are obtained, long after the water would have been reused.

With the WMS, the effluent quality can be monitored on a real-time basis. If for any reason the effluent quality deteriorates, then the effluent can be diverted to waste. The WMS also was helpful in evaluating reclamation unit processes by monitoring quality improvement in each unit process. This permitted evaluation of the effectiveness of each treatment process and unit process economics. Results from the experiment indicate that such monitoring of treatment plant effluents on a continuous basis can better enable treatment plant operators to achieve optimal performance from each unit process.

The long term future applications of automated water quality monitoring appears bright but its immediate future is not well defined. Several factors need clarification, such as, the legal aspects of "product liability" of reclaimed water, and current EPA and DOH monitoring requirements for potable and wastewater. Since the demand for potable water is continuing to increase and the sources of pristine water are not increasing, it appears certain that wastewater will have to be reused. If water is to be reused, it is important that its quality be assured on a continuous basis. Automation is the only economically feasible (see cost comparison in Table 26) means of meeting such a need. The use of continuous monitoring data from the WMS as control functions for the treatment plant process control computer can result in a closed loop control of the wastewater reclamation plant resulting in reduced chemical and power usage in the various treatment processes. These benefits will be optimized by the use of closed loop control. Estimated costs of a comparable number of analyses by typical laboratory techniques are shown. These estimates are based on the results of a telephone survey conducted by the Santa Clara Valley Water District.

TABLE 26

ESTIMATED COSTS AND SAVINGS  
FOR AUTOMATED INSTRUMENTATION

|   | <u>LAB</u> | <u>WMS</u> |
|---|------------|------------|
| <u>CAPITAL COSTS, \$</u>  |            |            |
| SENSORS/SUPPORT EQUIPMENT   | —          | SAME       |
| AUTOMATION<br>(COMPUTER, PUMPS, VALVES, ETC)                                | —          | \$150,000  |
| <u>O&amp;M COSTS (ANALYSIS AND REPORTING),<br/>\$/DAY</u>                   |            |            |
| 1 SAMPLE/DAY<br>(BASED ON 30 MAN-HOURS FOR<br>22 LAB ANALYSES @ \$27/M-H.)  | \$800      | \$260      |
| 6 SAMPLES/DAY<br>(BASED ON 75 MAN-HOURS FOR<br>22 LAB ANALYSES @ \$27/M-H.) | \$2,000    | \$260      |
| <u>MINIMUM CAPITAL PAYOUT TIME FOR<br/>AUTOMATION, DAYS</u>                 |            |            |
| 1 SAMPLE/DAY  | —          | 278 DAYS   |
| 6 SAMPLES/DAY   | —          | 86 DAYS    |

## REFERENCES

1. "Boeing/NASA-Water Monitor System Computer Operating Manual," Volumes I and II, D2-118621-1A, Poel, September 11, 1978.
2. "National Interim Primary Drinking Water Regulations," EPA-570/9-76-003.
3. "Advanced Treatment for Wastewater Reclamation at Water Factory 21," McCarty et al, EPA Technical Report Number 236, January 1980.
4. "Water Monitor System Technical Summary Report," Jeffers, Brooks, Thomas, Nibley, and Poel, The Boeing Company, September 26, 1979.
5. EPA Grant R804431, Stanford University From Robert S. Kerr Environmental Lab.
6. "Schaum's Outline of Theory and Problems of Statistics," Spiegel, Rensselear Polytechnic Institute, McGraw-Hill Book Company.
7. "Statistical Package for the Social Sciences," Nie, et al, McGraw-Hill Book Company, Second Edition, 1975.
8. "Operation and Maintenance Manual for the Water Reclamation Plant at Palo Alto, California," Santa Clara Valley Water District, Santa Clara County, California, December 1977. Jenks and Harrison.
9. "Wastewater Reclamation Requirements for the Santa Clara County Flood Control and Water District and the City of Palo Alto for Direct Injection of Reclaimed Wastewater into the upper aquifer of the Santa Clara Valley Groundwater Basin near Palo Alto," Order Number 73-71, and correspondence dated August 23, 1977, California Regional Water Quality Control Board, San Francisco Bay Region.
10. "National Interim Primary Drinking Water Regulations Control of Trihalomethanes in Drinking Water." Environmental Protection Agency 40CFR, Part 141, pp. 68624-68707, Federal Register Volume 44, Number 231, Thursday, November 29, 1979, Rules and Regulations.
11. "European Standards for Drinking Water," 2nd. Ed. 1970. World Health Organization.
12. "Guidelines for Interpretation of Water Quality for Agriculture," University of California Cooperative Extension, UC - Committee of Consultants, January 15, 1975.
13. "California Domestic Water Quality and Monitoring Regulations," California Health and Safety Code. Section 4026, Division 5, Part 1, Chapter 7 Water and Water Systems, California Administrative Code. Articles 1-8, pp. 1701-1719, 1977.
14. "Final Report on Water/Wastewater Management user Requirements Committee Meeting of February 14, 1974," Public Technology Incorporated for NASA Office of Applications, July 15, 1974.

15. "NASA JSC Water Monitor System - City of Houston Field Demonstration," Taylor et al, July 1979. NASA Reference Publication 1041.

**APPENDIX A**

**PROCESS INPUT/OUTPUT CHARACTERISTICS**

**FOR PART I OF THE TEST PERIOD**

**JANUARY 1978 TO SEPTEMBER 1979**

## APPENDIX A

### PROCESS INPUT/OUTPUT CHARACTERISTICS

Two points should be noted in evaluating the enclosed data, both of which probably contributed to data scatter:

1. Each point represents a daily average of 4 measurements of both the process input and output taken at regular 6 hour intervals. No compensation has been made for hydraulic lag. The lag would have negligible effect on certain processes such as the carbon towers where detention time is 34 minutes; however, data relating plant input to output can have significant error during an influent change since the average detention time is 9-10 hours and up to 24 hours is required to fully respond to a step change. No attempt was made to edit data which occurred during upsets.
2. A faulty flocculation process control sensor resulted in pH below the set-point. Subsequent analysis of plant operating records indicate that the data identified herein at pH 9.5 should be considered in the range 9 to 9.5 and data identified as pH 11 should be considered in the range of 10 to 11.




PROCESS CONFIGURATION SYMBOLS

- BIOLOGICAL SECONDARY (ACTIVATED SLUDGE)/CHLORINATION
- FLOCCULATION (pH 9.5)/AMMONIA STRIPPING/RECARBONATION/  
FILTRATION/OZONATION/CARBON ADSORPTION (UNITS 3 & 4)/  
FILTRATION/CHLORINATION - FLOW 1 MGD
- ⊕ SAME AS ○ WITHOUT AMMONIA STRIPPING (AERATION)
- SAME AS ○ WITH pH 11
- ⊖ SAME AS ● WITHOUT OZONATION
- ⊖ ⊕ SAME AS ● WITHOUT FILTRATION/OZONATION
- △ FILTRATION/OZONATION/CARBON ADSORPTION (UNIT 2)/  
FILTRATION/CHLORINATION - FLOW 0.5 MGD
- ▲ SAME AS △ WITHOUT OZONATION

ACTIVATED SLUDGE/CHLORINATION


NOMINAL REMOVAL = 65%



# FLOCCULATION/AMMONIA STRIPPING


1. 47% REMOVAL WITHOUT AMMONIA STRIPPING

2. 75% REMOVAL WITH AMMONIA STRIPPING




FILTRATION/OZONATION

NOMINAL REMOVAL = 25%




# CARBON ADSORPTION

$$\text{NOMINAL REMOVAL} = 1 - 5.6I^{0.5} \mu\text{g/LIT}$$




# FILTRATION/CHLORINATION



FILTRATION/CARBON ADSORPTION/FILTRATION

NOMINAL REMOVAL =  $1 - 5.6(0.40I)^{0.5}$   $\mu\text{g/LIT}$



FLOCCULATION/FILTRATION/CARBON ADSORPTION/FILTRATION


NOTE: PERFORMANCE CURVES SHOWN ARE SUMMATION OF NOMINAL UNIT PROCESS' PERFORMANCE

1. REMOVAL WITHOUT AMMONIA STRIPPING

$$= I - 5.6(0.4I) 0.5 \mu\text{g/LIT}$$

2. REMOVAL WITH AMMONIA STRIPPING

$$= I - 5.6(0.2I) 0.5 \mu\text{g/LIT}$$






# RECLAMATION FACILITY


NOTE: PERFORMANCE CURVES SHOWN ARE SUMMATION OF NOMINAL UNIT PROCESS' PERFORMANCE.

1. NOMINAL REMOVAL WITH FLOCCULATION & AMMONIA STRIPPING  
=  $I - 5.6(0.19I)^{0.5}$   $\mu\text{g/LIT}$
2. NOMINAL REMOVAL WITHOUT FLOCCULATION OR WITH FLOCCULATION,  
WITHOUT AMMONIA STRIPPING =  $I - 5.6(0.40I)^{0.5}$   $\mu\text{g/LIT}$




ACTIVATED SLUDGE/CHLORINATION

NOMINAL REMOVAL-78%




### FLOCCULATION/AMMONIA STRIPPING

1. 5.5 MG/LIT REMOVAL @ pH 11 WITH AMMONIA STRIPPING
2. 3.0 MG/LIT REMOVAL @ pH 9.5 WITH AMMONIA STRIPPING
3. 1.5 MG/LIT REMOVAL @ pH 9.5 WITHOUT AMMONIA STRIPPING



FILTRATION/OZONATION


NOMINAL REMOVAL = 15% MG/LIT



# CARBON ADSORPTION


NOMINAL REMOVAL = 6 MG/LIT

NOTE: ADSORPTION PERFORMANCE IS DEPENDENT ON OPERATING HISTORY.




FILTRATION/CHLORINATION

NOMINAL REMOVAL = 15%



FILTRATION/CARBON ADSORPTION/FILTRATION

$$\text{NOMINAL REMOVAL} = I - [(0.85I - 6)0.85]$$




ORIGINAL PAGE IS  
OF POOR QUALITY

# FLOCCULATION/FILTRATION/CARBON ADSORPTION/FILTRATION

NOTE: PERFORMANCE CURVES SHOWN ARE SUMMATION OF NOMINAL UNIT PROCESS' PERFORMANCE.

1. NOMINAL REMOVAL @ pH 11 WITH AMMONIA STRIPPING  
=I-(I-13.0) 0.8 MG/LIT
2. NOMINAL REMOVAL @ pH 9.5 WITH AMMONIA STRIPPING  
=I-(I-10.5) 0.8 MG/LIT
3. NOMINAL REMOVAL @ pH 9.5 WITHOUT AMMONIA STRIPPING  
=I-(I-9.0) 0.8 MG/LIT




ORIGINAL PAGE IS  
OF POOR QUALITY

C-3




ACTIVATED SLUDGE/CHLORINATION  
NOMINAL REMOVAL = 70%




# FLOCCULATION/AMMONIA STRIPPING

1. 50% REMOVAL

2. 40% REMOVAL WITHOUT AMMONIA STRIPPING




# FILTRATION/OZONATION






# CARBON ADSORPTION



FILTRATION/CHLORINATION


$$\text{REMOVAL} = I(1 - e^{-I/15}) \text{ MG/LIT}$$



FILTRATION/CARBON ADSORPTION/FILTRATION

NOMINAL REMOVAL =  $I(1 - .25e^{-I/60})$  MG/LIT


NOTE: PERFORMANCE CURVE SHOWN IS SUMMATION OF UNIT PROCESS  
PROCESS PERFORMANCE



FLOCCULATION/FILTRATION/CARBON ADSORPTION/FILTRATION

NOTE: PERFORMANCE CURVES SHOWN ARE SUMMATION OF NOMINAL  
UNIT PROCESS' PERFORMANCE.


1. NOMINAL REMOVAL =  $I(1 - .13e^{-I/20})$  MG/LIT
2. NOMINAL REMOVAL WITHOUT AMMONIA STRIPPING =  $I(1 - .15e^{-I/100})$  MG/LIT
3. NOMINAL REMOVAL WITHOUT FILTRATION/OZONATION% =  $I(1 - .23e^{-I/67})$  MG/LIT





# FLOCCULATION


1. NOMINAL REMOVAL AT PH 11 = (I-1.0) MC/ML
2. NOMINAL REMOVAL AT PH 9.5 = 80%






CARBON ADSORPTION

NOMINAL ADDITION = 0.3 MC/ML



# FILTRATION/CHLORINATION


$$\text{NOMINAL REMOVAL} = I(1 - e^{-I/T}) \text{ MC/ML}$$



FILTRATION/CARBON ADSORPTION/FILTRATION


$$\text{NOMINAL REMOVAL} = \left[ 1 - (0.2I + 0.3)e^{-\left(\frac{0.2I+0.3}{7}\right)} \right] \text{ MC/ML}$$

NOTE: PERFORMANCE CURVE SHOWN IS SUMMATION OF UNIT PROCESS' PERFORMANCE




# FLOCCULATION

1. NOMINAL REMOVAL = 88% WITHOUT AMMONIA STRIPPING
2. NOMINAL REMOVAL = (1-0.2) MC/ML WITH AMMONIA STRIPPING




# FILTRATION/OZONATION

NOMINAL REMOVAL =  $(I - 0.05)$  MC/ML



CARBON ADSORPTION


NOMINAL ADDITION = 0.1 MC/ML






FILTRATION/CHLORINATION

NOMINAL REMOVAL = 0



FILTRATION/CARBON ADSORPTION/FILTRATION

NOMINAL REMOVAL = (I-0.6) MC/ML



APPENDIX B  
MONTHLY AVERAGES FOR PART I OF THE TEST PERIOD  
JANUARY 1978 TO SEPTEMBER 1979



APRIL AVERAGES (1σ TOTAL VARIATION)

| INFLUENT<br>15-50 MGD      | PRIMARY                   | ACTIVATED<br>SLUDGE<br>CHLORINE<br>CONTACT |                | FLOCCULATION<br>AND/OR<br>STRIPPING<br>RECARBONATION |                | FILTRATION<br>OZONATION |                | GRANULAR<br>ACTIVATED<br>CARBON |               | FILTRATION<br>CHLORINATION |              | EFFLUENT   |           |
|----------------------------|---------------------------|--|----------------|--|----------------|-------------------------|----------------|---------------------------------|---------------|----------------------------|--------------|------------|-----------|
|                            |                           | MG/L                                       | % Removal      | MG/L   | % Removal      | MG/L                    | % Removal      | MG/L                            | % Removal     | MG/L                       | % Removal    | MG/L       | % Removal |
| TOTAL BIOMASS              | MC/ML<br>29.2<br>(14)     | -  | 11.8<br>(13)   | 78<br>(20)   | 2.6<br>(3.2)   | 69<br>(88)              | 0.8<br>(3.4)   | -28<br>(82)                     | 1.1<br>(3.4)  | 38<br>(40)                 | 0.8<br>(1.6) | 93<br>(14) | 97        |
| VARIABLE BIOMASS           | MC/ML<br>8.6<br>(13)      | -  | 3.5<br>(5.6)   | 78<br>(76)   | 0.8<br>(3.8)   | 24<br>(24)              | 0.4<br>(4.8)   | 32<br>(32)                      | 0.4<br>(3.5)  | 14<br>(14)                 | 0.3<br>(0.9) | 30<br>(32) | 94        |
| COLIFORM                   | #/100 ML<br>-             | -  | -              | -  | -              | -                       | -              | -                               | -             | -                          | -            | -          | -         |
| TURBIDITY                  | MG/LIT<br>55.6<br>(21)    | 66<br>(24)                                 | 19.0<br>(19)   | 32<br>(35)   | 13.0<br>(8.3)  | -14<br>(36)             | 14.8<br>(11)   | 73<br>(87)                      | 3.9<br>(4.1)  | 23<br>(42)                 | 3.1<br>(1.8) | 94<br>(15) | 96        |
| TOTAL RESIDUAL<br>CHLORINE | MG/LIT<br>0<br>(0)        | -  | 8.0<br>(4.4)   | 26<br>(7)  | 8.9<br>(1.7)   | 11<br>(9)               | 8.3<br>(1.9)   | 26<br>(3)                       | 8.3<br>(6.1)  | -                          | 2.2<br>(1.3) | -          | (2)       |
| TOTAL ORGANIC<br>CARBON    | MG/LIT<br>77.0<br>(36)    | 82<br>(15)                                 | 14.1<br>(9)    | 14<br>(24)   | 12.1<br>(6.2)  | 10<br>(20)              | 11.8<br>(7.0)  | 87<br>(87)                      | 4.7<br>(16.4) | 27<br>(27)                 | 3.4<br>(5.4) | 76<br>(40) | 94        |
| TOTAL OXYGEN<br>DEMAND     | MG/LIT<br>-               | -  | -              | -  | -              | -                       | -              | -                               | -             | -                          | -            | -          | (6)       |
| TOTAL HALO-<br>CARBONS     | MG/LIT<br>990.1<br>(1700) | 68<br>(47)                                 | 312.6<br>(400) | 47<br>(82)   | 166.7<br>(170) | 25<br>(23)              | 126.6<br>(110) | 46<br>(68)                      | 5.6<br>(56)   | 12<br>(28)                 | 56.4<br>(41) | 81<br>(38) | 91        |
| PHENOL                     | MG/LIT<br>-               | -  | -              | -  | -              | -                       | -              | -                               | -             | -                          | -            | -          | (21)      |
| AMMONIA (AS N)             | MG/LIT<br>28.5<br>(12)    | 28<br>(26)                                 | 20.6<br>(11)   | 5<br>(20)  | 19.6<br>(10)   | 6<br>(24)               | 19.5<br>(10)   | 11<br>(15)                      | 17.4<br>(10)  | -1<br>(66)                 | 17.7<br>(16) | 14<br>(30) | 39        |
| NITRATE/NITRITE<br>(AS N)  | MG/LIT<br>-               | -  | -              | -  | -              | -                       | -              | -                               | -             | -                          | -            | -          | (32)      |
| PH                         | PH<br>7.3                 | 4  | 7.0            | -8   | 7.5            | -2                      | 7.6            | 2                               | 7.5           | 2                          | 7.3          | -          | -         |
| CONDUCTIVITY               | µMO/CM<br>1480.5          | 0  | 1486.3         | -2   | 1872.7         | -1                      | 1833.1         | 0                               | 1838.8        | -2                         | 1878.6       | -6         | -6        |
| HARDNESS                   | MG/LIT<br>-               | -  | 303.2          | 2  | 297.0          | -2                      | 301.5          | 29                              | 213.8         | -60                        | 321.1        | -6         | -         |
| SODIUM                     | MG/LIT<br>91.9            | -19  | 109.0          | 18   | 89.4           | 2                       | 87.4           | 1                               | 86.3          | -10                        | 96.2         | 13         | -4        |
| CHLORIDE                   | MG/LIT<br>-               | -  | -              | -  | -              | -                       | -              | -                               | -             | -                          | -            | -          | -         |
| DISSOLVED<br>OXYGEN        | MG/LIT<br>-               | -  | -              | -  | -              | -                       | -              | -                               | -             | -                          | -            | -          | -         |

\* ANEMATOR OUT OF SERVICE

ORIGINAL PAGE IS  
OF POOR QUALITY

MAY AVERAGES

| INFLUENT<br>15-50 MSD      | PRIMARY  | ACTIVATED<br>SLUDGE<br>CHLORINE<br>CONTACT |          | ↑ 1 MSD | FLOCCULATION<br>AMMONIA<br>STRIPPING<br>RECARBONATION |          | FILTRATION<br>OZONATION |          | GRANULAR<br>ACTIVATED<br>CARBON |          | FILTRATION<br>CHLORINATION |          | EFFLUENT |          |
|----------------------------|----------|--|----------|---------|---|----------|-------------------------|----------|---------------------------------|----------|----------------------------|----------|----------|----------|
|                            |          | MG/LIT                                     | % Remove |         | MG/LIT  | % Remove | MG/LIT                  | % Remove | MG/LIT                          | % Remove | MG/LIT                     | % Remove | MG/LIT   | % Remove |
| TOTAL BIOMASS              | MC/ML    | 21.1                                       | -        | 11.8    | 91  | 1.1      | 64                      | 0.4      | -30                             | 0.5      | 24                         | 0.4      | 96       | 96       |
| VARIABLE BIOMASS           | MC/ML    | 2.3  | -        | 5.3     | 95  | 0.3      | 63                      | 0.1      | -80                             | 0.2      | 7                          | 0.2      | 97       | 93       |
| COLIFORM                   | #/100 ML | -  | -        | -       | -   | -        | -                       | -        | -                               | -        | -                          | -        | -        | -        |
| TURBIDITY                  | MG/LIT   | 66.5                                       | 67       | 21.7    | 60  | 8.7      | -25                     | 10.9     | 81                              | 2.0      | -27                        | 2.6      | 88       | 96       |
| TOTAL RESIDUAL<br>CHLORINE | MG/LIT   | 0  | -        | 8.4     | 48  | 4.4      | 26                      | 3.3      | 92                              | 0.3      | -                          | 2.5      | -        | -        |
| TOTAL ORGANIC<br>CARBON    | MG/LIT   | 77.4                                       | 79       | 16.7    | 32  | 11.3     | 1                       | 11.2     | 58                              | 4.7      | 52                         | 2.2      | 87       | 97       |
| TOTAL OXYGEN<br>DEMAND     | MG/LIT   | -  | -        | -       | -   | -        | -                       | -        | -                               | -        | -                          | -        | -        | -        |
| TOTAL HALO-<br>CARBONS     | UG/LIT   | 1250.2                                     | 64       | 455.2   | 75  | 112.8    | -                       | -        | -                               | -        | -                          | 104.2    | 77       | 92       |
| PHENOL                     | UG/LIT   | -  | -        | -       | -   | -        | -                       | -        | -                               | -        | -                          | -        | -        | -        |
| AMMONIA (AS N)             | MG/LIT   | 29.8                                       | 19       | 24.2    | 23  | 18.6     | -1                      | 18.8     | 16                              | 15.8     | 2                          | 15.5     | 36       | 48       |
| NITRATE/NITRITE<br>(AS N)  | MG/LIT   | -  | -        | -       | -   | -        | -                       | -        | -                               | -        | -                          | -        | -        | -        |
| PH                         | PH       | 7.2  | 3        | 7.0     | -14   | 7.9      | 0                       | 7.9      | 5                               | 7.5      | 0                          | 7.5      | -        | -        |
| CONDUCTIVITY               | UMHO/CM  | 1448.0                                     | 2        | 1416.5  | 3   | 1375.8   | -3                      | 1421.9   | -1                              | 1429.7   | 5                          | 1351.2   | 5        | 7        |
| HARDNESS                   | MG/LIT   | -  | -        | 213.8   | 21  | 169.6    | -11                     | 187.7    | 26                              | 136.9    | -37                        | 189.8    | -        | -        |
| SODIUM                     | MG/LIT   | 142.0                                      | 5        | 135.5   | -1  | 136.9    | -3                      | 140.5    | 0                               | 140.7    | 6                          | 131.9    | 3        | 7        |
| CHLORIDE                   | MG/LIT   | -  | -        | -       | -   | -        | -                       | -        | -                               | -        | -                          | -        | -        | -        |
| DISSOLVED<br>OXYGEN        | MG/LIT   | -  | -        | -       | -   | -        | -                       | -        | -                               | -        | -                          | -        | -        | -        |

MAY AVERAGES

| INFLUENT<br>15-50 MED      | PRIMARY  | ACTIVATED<br>SLUDGE<br>CHLORINE<br>CONTACT |          | FLOCCULATION<br>AND<br>STRIPPING<br>RECARBONATION |          | FILTRATION<br>OXIDATION |          | GRANULAR<br>ACTIVATED<br>CARBON |          | FILTRATION<br>CALCINATION |          | EFFLUENT |          |
|----------------------------|----------|--|----------|---|----------|-------------------------|----------|---------------------------------|----------|---------------------------|----------|----------|----------|
|                            |          | MG/LIT                                     | % Remove | MG/LIT  | % Remove | MG/LIT                  | % Remove | MG/LIT                          | % Remove | MG/LIT                    | % Remove | MG/LIT   | % Remove |
| TOTAL BIOMASS              | MC/ML    | 21.1                                       | -        | 11.8  | 91       | 1.1                     | 64       | 0.4                             | -30      | 0.5                       | 24       | 0.4      | 96       |
| VARIABLE BIOMASS           | MC/ML    | 2.3  | -        | 5.3   | 96       | 0.3                     | 63       | 0.1                             | -88      | 0.2                       | 7        | 0.2      | 97       |
| COLIFORM                   | #/100 ML | -  | -        | -   | -        | -                       | -        | -                               | -        | -                         | -        | -        | -        |
| TURBIDITY                  | MG/LIT   | 66.5                                       | 67       | 21.7  | 60       | 8.7                     | -25      | 10.9                            | 81       | 2.0                       | -27      | 2.6      | 88       |
| TOTAL RESIDUAL<br>CHLORINE | MG/LIT   | 0  | -        | 8.4   | 48       | 4.4                     | 26       | 3.3                             | 92       | 0.3                       | -        | 2.5      | -        |
| TOTAL ORGANIC<br>CARBON    | MG/LIT   | 77.4                                       | 79       | 16.7  | 32       | 11.3                    | 1        | 11.2                            | 58       | 4.7                       | 52       | 2.2      | 87       |
| TOTAL OXYGEN<br>DEMAND     | MG/LIT   | -  | -        | -   | -        | -                       | -        | -                               | -        | -                         | -        | -        | -        |
| TOTAL HALO-<br>CARBONS     | UG/LIT   | 1250.2                                     | 64       | 455.2   | 75       | 112.8                   | -        | -                               | -        | -                         | -        | 104.2    | 77       |
| PHENOL                     | UG/LIT   | -  | -        | -   | -        | -                       | -        | -                               | -        | -                         | -        | -        | -        |
| AMMONIA (As N)             | MG/LIT   | 29.8                                       | 19       | 24.2  | 23       | 18.6                    | -1       | 18.8                            | 16       | 15.8                      | 2        | 15.5     | 36       |
| NITRATE/NITRITE<br>(As N)  | MG/LIT   | -  | -        | -   | -        | -                       | -        | -                               | -        | -                         | -        | -        | -        |
| PH                         | PH       | 7.2  | 3        | 7.0   | -14      | 7.9                     | 0        | 7.9                             | 5        | 7.5                       | 0        | 7.5      | -        |
| CONDUCTIVITY               | UMHO/CM  | 1448.0                                     | 2        | 1416.5  | 3        | 1375.8                  | -3       | 1421.9                          | -1       | 1429.7                    | 5        | 1351.2   | 5        |
| HARDNESS                   | MG/LIT   | -  | -        | 213.8   | 21       | 169.6                   | -11      | 187.7                           | 26       | 138.9                     | -37      | 189.8    | -        |
| SODIUM                     | MG/LIT   | 142.0                                      | 5        | 135.5   | -1       | 135.9                   | -3       | 140.5                           | 0        | 140.7                     | 6        | 131.5    | 3        |
| CHLORIDE                   | MG/LIT   | -  | -        | -   | -        | -                       | -        | -                               | -        | -                         | -        | -        | -        |
| DISSOLVED<br>OXYGEN        | MG/LIT   | -  | -        | -   | -        | -                       | -        | -                               | -        | -                         | -        | -        | -        |

MAY AVERAGES (1σ TOTAL VARIATION)

| INFLUENT<br>15-30 MGD      | PRIMARY          | ACTIVATED<br>SLUDGE<br>CONTACT<br>TANK |                | FLOCCULATION<br>AND<br>STRIPPING<br>TANK |                | FILTRATION<br>AND<br>COAGULATION |               | GRAVIMETRIC<br>ACTIVATED<br>CARBON |               | FILTRATION<br>COAGULATION |                | EFFLUENT<br>1.5 MG |            |
|----------------------------|------------------|--|----------------|--|----------------|----------------------------------|---------------|------------------------------------|---------------|---------------------------|----------------|--------------------|------------|
|                            |                  | MG/LIT                                 | MG/LIT         | MG/LIT                                   | MG/LIT         | MG/LIT                           | MG/LIT        | MG/LIT                             | MG/LIT        | MG/LIT                    | MG/LIT         | MG/LIT             | MG/LIT     |
| TOTAL BIOMASS              | 21.1<br>(16)     | -                                      | 11.8<br>(9.6)  | 91<br>(17)                               | 1.1<br>(1.8)   | 64<br>(46)                       | 0.4<br>(0.9)  | -30<br>(49)                        | 0.5<br>(2.9)  | 24<br>(27)                | 0.4<br>(2.9)   | 96<br>(27)         | 90<br>(12) |
| VARIABLE BIOMASS           | 2.3<br>(4.2)     | -                                      | 5.3<br>(7.8)   | 95<br>(22)                               | 3.3<br>(6.3)   | 83<br>(200)                      | 0.1<br>(0.2)  | -88<br>(11)                        | 0.1<br>(0.2)  | -                         | -              | 93<br>(9)          | -          |
| COLIFORM                   | -                | -                                      | -              | -  | -              | -                                | -             | -                                  | -             | -                         | -              | -                  | -          |
| TURBIDITY                  | 66.5<br>(46)     | 67                                     | 21.7<br>(25)   | 60<br>(20)                               | 0.7<br>(0.2)   | 25<br>(46)                       | 10.9<br>(6.0) | 81<br>(15)                         | 2.0<br>(2.3)  | -27<br>(42)               | 2.6<br>(2.9)   | 88<br>(12)         | 96<br>(4)  |
| TOTAL RESIDUAL<br>CHLORINE | 0<br>(0)         | 0                                      | 8.4<br>(5.1)   | 48<br>(20)                               | 4.4<br>(2.2)   | 26<br>(36)                       | 3.3<br>(2.0)  | 82<br>(11)                         | 8.3<br>(0.1)  | -                         | -              | -                  | -          |
| TOTAL ORGANIC<br>CARBON    | 77.4<br>(46)     | 79                                     | 16.7<br>(9.4)  | 32<br>(30)                               | 11.3<br>(6.6)  | 1<br>(24)                        | 11.2<br>(7.9) | 80<br>(22)                         | 4.7<br>(6.0)  | 52<br>(20)                | 2.2<br>(3.2)   | 87<br>(20)         | 97<br>(4)  |
| TOTAL OXYGEN<br>DEMAND     | -                | -                                      | -              | -  | -              | -                                | -             | -                                  | -             | -                         | -              | -                  | -          |
| TOTAL NITRO-<br>GENOUS     | 1560.2<br>(1800) | 64<br>(20)                             | 455.2<br>(200) | 75<br>(20)                               | 112.5<br>(120) | 81<br>(20)                       | -             | -                                  | -             | -                         | 104.2<br>(116) | 77<br>(17)         | 92<br>(13) |
| PHENOL                     | -                | -                                      | -              | -  | -              | -                                | -             | -                                  | -             | -                         | -              | -                  | -          |
| AMMONIA (As N)             | 29.8<br>(12)     | 19<br>(23)                             | 24.2<br>(10)   | 23<br>(20)                               | 10.6<br>(6.8)  | -1<br>(16)                       | 10.8<br>(6.6) | 16<br>(14)                         | 15.0<br>(9.0) | 2<br>(26)                 | 15.5<br>(6.6)  | 35<br>(22)         | 48<br>(22) |
| NITRATE/NITRITE<br>(As N)  | -                | -                                      | -              | -  | -              | -                                | -             | -                                  | -             | -                         | -              | -                  | -          |
| pH                         | 7.2              | 3                                      | 7.0            | -14                                      | 7.9            | 0                                | 7.9           | 6                                  | 7.5           | 0                         | 7.5            | -                  | -          |
| CONDUCTIVITY               | 3400.0           | 2                                      | 1416.5         | 3  | 1375.0         | -3                               | 1421.9        | -1                                 | 1439.7        | 5                         | 1361.2         | 6                  | 7          |
| HARDNESS                   | -                | -                                      | 213.0          | 21                                       | 149.6          | -11                              | 167.7         | 25                                 | 130.9         | -37                       | 100.0          | -                  | -          |
| SODIUM                     | 142.0            | 5                                      | 130.5          | -1                                       | 136.9          | -3                               | 140.5         | 0                                  | 140.7         | 5                         | 131.9          | 3                  | 7          |
| CHLORINE                   | -                | -                                      | -              | -  | -              | -                                | -             | -                                  | -             | -                         | -              | -                  | -          |
| DISSOLVED<br>OXYGEN        | -                | -                                      | -              | -  | -              | -                                | -             | -                                  | -             | -                         | -              | -                  | -          |



JUNE AVERAGES

| INFLUENT<br>15-50 MGD      | PRIMARY  | ACTIVATED<br>SLUDGE<br>CHLORINE<br>CONTACT<br>% Removal | ↑ 1 MGD | FLOCCULATION<br>A-PORTA<br>STRIPPING<br>RECARBONATION<br>% Removal | OUT OF SERVICE<br>FILTRATION<br>OZONATION<br>% Removal | GRANULAR<br>ACTIVATED<br>CARBON<br>% Removal | FILTRATION<br>CHLORINATION<br>% Removal | EFFLUENT         |        |
|----------------------------|----------|---|---------|--|--|--|---|------------------|--------|
|                            |          |   |         |  |  |  |   | Daily<br>Removal | Total  |
| TOTAL BIOMASS              | MG/ML    | -   | 5.4     | 87   | 0.7  | 11   | 0.6                                     | 89               | -      |
| VARIABLE BIOMASS           | MG/ML    | -   | 1.3     | 82   | 0.2  | 17   | 0.2                                     | 88               | -      |
| COLIFORM                   | #/100 ML | -   | -       | -  | -  | -  | -                                       | -                | -      |
| TURBIDITY                  | MG/LIT   | -   | 25.8    | 57   | 11.1   | 46   | 6.0                                     | 86               | 3.7    |
| TOTAL RESIDUAL<br>CHLORINE | MG/LIT   | -   | 11.2    | 51   | 5.4  | 89   | 0.6                                     | 77               | 2.6    |
| TOTAL ORGANIC<br>CARBON    | MG/LIT   | -   | 12.2    | 38   | 7.6  | 71   | 2.2                                     | 84               | 2.0    |
| TOTAL OXYGEN<br>DEMAND     | MG/LIT   | -   | -       | -  | -  | -  | -                                       | -                | -      |
| TOTAL HALO-<br>CARBONS     | UG/LIT   | -   | 554.4   | 79   | 116.9  | -  | -                                       | 83               | 92.6   |
| PHE-NOL                    | UG/LIT   | -   | -       | -  | -  | -  | -                                       | -                | -      |
| AMMONIA (As N)             | MG/LIT   | -   | 21.6    | 8  | 19.9   | 7  | 18.4                                    | 23               | 16.6   |
| NITRATE/NITRITE<br>(As N)  | MG/LIT   | -   | 1.8     | -50  | 2.7  | -156   | 6.9                                     | -264             | 6.5    |
| PH                         | PH       | -   | 6.9     | -20  | 8.3  | 4  | 7.9                                     | -8               | 7.5    |
| CONDUCTIVITY               | UMHO/CM  | -   | 1258.1  | 7  | 1175.9   | 0  | 1171.5                                  | 4                | 1208.3 |
| HARDNESS                   | MG/LIT   | -   | 166.7   | 22   | 129.2  | -6   | 137.0                                   | 6                | 156.5  |
| SODIUM<br>CHLORIDE         | MG/LIT   | -   | 132.7   | 15   | 112.6  | 4  | 108.3                                   | 11               | 118.4  |
| DISSOLVED<br>OXYGEN        | MG/LIT   | -   | -       | -  | -  | -  | -                                       | -                | -      |

JULY AVERAGES

| IMPLIMENT<br>15-50 mg      | PRIMARY  | ACTIVATED<br>SLUDGE<br>CALORINE<br>CONTACT | ↑ 1 MED | FLOCCULATION<br>AZOSTA<br>STRIPPING<br>RECOMBINATION |           | FILTRATION<br>OZONATION |           | GRANULAR<br>ACTIVATED<br>CARBON |           | FILTRATION<br>CHLORINATION |       | EFFLUENT |   |
|----------------------------|----------|--|---------|--|-----------|-------------------------|-----------|---------------------------------|-----------|----------------------------|-------|----------|---|
|                            |          |  |         | S Removal  | S Removal | S Removal               | S Removal | S Removal                       | S Removal | Daily<br>Removal<br>mg/L   | Total |          |   |
| TOTAL BIOMASS              | MG/ML    | -  | 5.3     | 00   | 0.6       | -                       | 0.5       | -                               | -20       | 0.7                        | 56    | -        | - |
| VARIABLE BIOMASS           | MG/ML    | -  | 1.6     | 04   | 0.1       | -                       | 0.1       | -15                             | -79       | 0.2                        | 00    | -        | - |
| COLIFORM                   | 8/100 ML | -  | -       | -  | -         | -                       | -         | -                               | -         | -                          | -     | -        | - |
| TURBIDITY                  | MG/LIT   | -  | 20.7    | 58   | 0.6       | -                       | 4.9       | 43                              | 31        | 3.3                        | 04    | -        | - |
| TOTAL NITROGEN<br>CHLORIDE | MG/LIT   | -  | 0.3     | 31   | 5.7       | -                       | 0.7       | 00                              | -379      | 3.2                        | 61    | -        | - |
| TOTAL ORGANIC<br>CARBON    | MG/LIT   | -  | 11.9    | 44   | 6.6       | -                       | 1.6       | 72                              | 13        | 1.6                        | 07    | -        | - |
| TOTAL OXYGEN<br>DEMAND     | MG/LIT   | -  | -       | -  | -         | -                       | -         | -                               | -         | -                          | -     | -        | - |
| TOTAL HALO-<br>CARBONS     | MG/LIT   | -  | -       | -  | -         | -                       | -         | -                               | -         | -                          | -     | -        | - |
| PHENOL                     | MG/LIT   | -  | -       | -  | -         | -                       | -         | -                               | -         | -                          | -     | -        | - |
| AMMONIA (As N)             | MG/LIT   | -  | 24.0    | 25   | 10.0      | -                       | 14.7      | 10                              | 3         | 14.3                       | 40    | -        | - |
| NITRATE/NITRITE<br>(As N)  | MG/LIT   | -  | 3.2     | -22  | 3.9       | -                       | 7.3       | -00                             | -6        | 7.0                        | -143  | -        | - |
| pH                         | pH       | -  | 6.9     | -25  | 0.7       | -                       | 0.0       | 0                               | 4         | 7.7                        | -10   | -        | - |
| CONDUCTIVITY               | µMO/CM   | -  | 1159.3  | 0  | 1157.9    | -                       | 1172.0    | -1                              | -1        | 1100.5                     | -2    | -        | - |
| HARDNESS                   | MG/LIT   | -  | 170.0   | 17   | 161.3     | -                       | 104.0     | -31                             | -12       | 207.7                      | -21   | -        | - |
| SODIUM                     | MG/LIT   | -  | 322.7   | 0  | 313.4     | -                       | 111.0     | 1                               | -2        | 113.0                      | 7     | -        | - |
| CHLORIDE                   | MG/LIT   | -  | 731.4   | -10  | 204.2     | -                       | 251.7     | -3                              | 7         | 204.4                      | -6    | -        | - |
| DISSOLVED<br>OXYGEN        | MG/LIT   | -  | 3.7     | -74  | 6.6       | -                       | 4.5       | 30                              | 02        | 0.0                        | 70    | -        | - |

RECLAMATION PLANT INFLUENT CHARACTERISTICS  
AVERAGE MONTHLY VALUES

| MONTH       | BOD, MG/LIT *<br>12.3 | COD, MG/LIT *<br>23.2 | TDS, MG/LIT *<br>24.6 | SUSPENDED *<br>SOLIDS, MG/LIT<br>18.6 | TURBIDITY<br>MG/LIT<br>11.6 | TOTAL<br>BIOMASS<br>MG/ML<br>13.9 | VARIABLE<br>BIOMASS<br>MG/ML<br>21.6 | TOTAL<br>HALOCARBONS<br>MG/LIT<br>4.5 | AMPHIPHIL *<br>MG/LIT<br>27.7 | AMPHIPHIL *<br>MG/LIT<br>25.6 | AMPHIPHIL *<br>MG/LIT<br>26.6 | AMPHIPHIL *<br>MG/LIT<br>24.6 |
|-------------|-----------------------|-----------------------|-----------------------|---------------------------------------|-----------------------------|-----------------------------------|--------------------------------------|---------------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|
| JANUARY '79 | 12.3                  |                       | 24.6                  | 18.6                                  | 11.6                        | 13.9                              | 21.6                                 |                                       | 27.7                          | 25.6                          | 26.6                          | 24.6                          |
| FEBRUARY    | 10.2                  | 23.2                  | 18.6                  | 11.6                                  | 11.6                        |                                   |                                      |                                       |                               |                               |                               | 20.4                          |
| MARCH       | 25.2                  | 24.6                  | 19.3                  | 13.9                                  | 13.9                        |                                   |                                      | 1046.0                                | 26.5                          | 26.5                          | 26.5                          | 19.2                          |
| APRIL       | 9.7                   | 30.0                  | 17.3                  | 21.6                                  | 21.6                        |                                   |                                      | 528.0                                 | 27.1                          | 27.1                          | 27.1                          | 24.3                          |
| MAY         | 12.3                  |                       | 17.8                  | 17.8                                  | 27.7                        |                                   | 4.5                                  | 563.0                                 | 24.6                          | 24.6                          | 24.6                          | 23.9                          |
| JUNE        | 18.4                  |                       | 19.4                  | 19.4                                  |                             |                                   |                                      |                                       | 27.6                          | 27.6                          | 27.6                          |                               |
| JULY        | 12.5                  |                       | 19                    | 19                                    |                             |                                   |                                      |                                       | 29.2                          | 29.2                          | 29.2                          |                               |
| AUGUST      | 12                    | 12.9                  | 18                    | 18                                    | 10.6                        | 11.5                              | 11.5                                 | 452.8                                 | 25.1                          | 25.1                          | 25.1                          | 19.7                          |
| SEPTEMBER   | 12                    | 16.7                  | 16                    | 16                                    | 12.5                        | 12.2                              | 12.2                                 | 420.9                                 | 25.4                          | 25.4                          | 25.4                          | 20.0                          |
| OCTOBER     | 17                    |                       | 22                    | 22                                    | 23.9                        | 10.4                              | 10.4                                 | 301.5                                 | 31.9                          | 31.9                          | 31.9                          |                               |
| NOVEMBER    | 28                    | 25.4                  | 21                    | 21                                    | 17.9                        | 5.8                               | 5.8                                  | 868.1                                 | 33.6                          | 33.6                          | 33.6                          | 22.7                          |
| DECEMBER    | 20                    | 19.3                  | 15                    | 15                                    | 15.2                        | 5.5                               | 5.5                                  | 824.6                                 | 31.0                          | 31.0                          | 31.0                          | 21.2                          |
| JANUARY '79 | 23                    | 18.1                  | 15.1                  | 15.1                                  | 11.9                        | 6.2                               | 6.2                                  | 470.0                                 | 29.9                          | 29.9                          | 29.9                          | 20.1                          |
| FEBRUARY    | 10                    | 20.1                  | 13                    | 13                                    | 19.4                        | 8.8                               | 8.8                                  | 730.5                                 | 21.7                          | 21.7                          | 21.7                          | 21.7                          |
| MARCH       | 20                    | 21.4                  | 15                    | 15                                    | 19.0                        | 11.8                              | 11.8                                 | 312.5                                 | 25.4                          | 25.4                          | 25.4                          | 22.0                          |
| APRIL       | 17.2                  | 14.1                  | 12.6                  | 12.6                                  | 21.7                        | 5.3                               | 5.3                                  | 455.2                                 | 20.6                          | 20.6                          | 20.6                          | 20.6                          |
| MAY         | 21                    | 16.7                  | 10                    | 10                                    | 25.8                        | 5.4                               | 5.4                                  | 554.4                                 | 24.2                          | 24.2                          | 24.2                          | 24.2                          |
| JUNE        | 18                    | 12.2                  | 10                    | 10                                    | 20.7                        | 5.3                               | 5.3                                  |                                       | 21.6                          | 21.6                          | 21.6                          | 21.6                          |
| JULY        | 18                    | 11.9                  | 14                    | 14                                    |                             |                                   |                                      |                                       | 24.5                          | 24.5                          | 24.5                          | 24.0                          |

\* PALO ALTO REGIONAL WATER QUALITY CONTROL FACILITY LABORATORY MEASUREMENTS FROM 24 HOUR COMPOSITE SAMPLES.

RECLAMATION PLANT PERFORMANCE SUMMARY  
 AVERAGE MONTHLY VALUES  $\pm 1\sigma$

| MONTH       | FLOW, MGD | BOD, MG/LIT * |           | COD, MG/LIT * |           | TOC, MG/LIT |             | TOTAL HALOCARBONS<br>MG/LIT |             |
|-------------|-----------|---------------|-----------|---------------|-----------|-------------|-------------|-----------------------------|-------------|
|             |           | EFFLUENT      | % REMOVED | EFFLUENT      | % REMOVED | EFFLUENT    | % REMOVED   | EFFLUENT                    | % REMOVED   |
| JANUARY '78 |           |               |           | 7.0           | 87        | 31.4        | 55 $\pm$ 12 |                             |             |
| FEBRUARY    | 0.4       |               |           |               |           | 26.4        |             |                             |             |
| MARCH       | 0.4       | 2.8           | 89        | 10.3          | 83        |             |             | 295                         | 92          |
| APRIL       | 0.6       |               |           | 14.0          | 69        | 19.1        | 36 $\pm$ 16 | 211                         | 79          |
| MAY         | 0.6       |               |           | 15.8          | 61        |             |             | 149                         | 69          |
| JUNE        | 0.6       |               |           |               |           |             |             |                             |             |
| JULY        | 0.6       |               |           |               |           |             |             |                             |             |
| AUGUST      | 0.6       |               |           |               |           | 6.0         | 54 $\pm$ 11 | 149.3                       | 67 $\pm$ 96 |
| SEPTEMBER   | 0.2       |               |           |               |           | 6.7         | 60 $\pm$ 12 | 121.1                       | 71 $\pm$ 29 |
| OCTOBER     | 0         |               |           |               |           |             |             |                             |             |
| NOVEMBER    | 0.4       |               |           |               |           | 10.0        | 61 $\pm$ 11 |                             |             |
| DECEMBER    | 0.44      | 5.4           | 73        | 5.5           |           | 5.6         | 71 $\pm$ 5  | 40.7                        | 95 $\pm$ 9  |
| JANUARY '79 | 0.42      | 7.7           | 67        | 10.5          | 73        | 6.5         | 64 $\pm$ 7  | 94.7                        | 89 $\pm$ 9  |
| FEBRUARY    | 0.45      | 8.8           | 12        | 24            | 35        | 9.2         | 55 $\pm$ 19 | 89.2                        | 81 $\pm$ 18 |
| MARCH       | 0.68      | 4.6           | 80        | 11.4          | 74        | 7.8         | 64 $\pm$ 15 | 164.4                       | 77 $\pm$ 23 |
| APRIL       | 1.0       | 4.1           | 76        | 5.3           | 86        | 3.4         | 76 $\pm$ 20 | 59.4                        | 81 $\pm$ 19 |
| MAY         | 1.0       | 8.6           | 59        | 5.7           | 83        | 2.2         | 87 $\pm$ 10 | 105.5                       | 77 $\pm$ 17 |
| JUNE        | 1.0       | 5.6           | 69        | 3.8           | 88        | 2.0         | 84 $\pm$ 7  | 92.6                        | 83 $\pm$ 37 |
| JULY        | 1.0       | 2.6           | 86        | -             | -         | 1.6         | 87 $\pm$ 8  | -                           | -           |

\* PALO ALTO REGIONAL WATER QUALITY CONTROL FACILITY LABORATORY MEASUREMENTS FROM 24 HOUR COMPOSITE SAMPLES.

RECLAMATION PLANT PERFORMANCE SUMMARY  
AVERAGE MONTHLY VALUES  $\pm 1\sigma$

| MONTH       | FLOW, MGD | TURBIDITY, NTU* |         | TURBIDITY, MG/LIT |         | TOTAL BIOMASS, MG/L |         | VIABLE BIOMASS, MG/L |         | AMMONIA |          |
|-------------|-----------|-----------------|---------|-------------------|---------|---------------------|---------|----------------------|---------|---------|----------|
|             |           | EFFLUENT        | REMOVED | EFFLUENT          | REMOVED | EFFLUENT            | REMOVED | EFFLUENT             | REMOVED | MG/LIT  | REMOVED  |
| JANUARY '78 |           | 1.1             | 85      | 3.9               | 85 ± 55 |                     |         |                      |         | 15.6    | 24 ± 34  |
| FEBRUARY    | 0.4       |                 |         | 4.8               | 59 ± 43 |                     |         |                      |         | 14.9    | 22 ± 150 |
| MARCH       | 0.4       | 1.1             | 83      | 4.0               | 71 ± 12 |                     |         |                      |         | 21.1    | 22 ± 7   |
| APRIL       | 0.6       | 1.0             | 85      | 4.2               | 81 ± 4  | 1.3                 |         | 1.0                  |         | 20.4    | 15 ± 7   |
| MAY         | 0.6       |                 |         | 8.1               | 71 ± 18 | 1.3                 | 71 ± 19 | 1.1                  | 84 ± 27 |         |          |
| JUNE        | 0.6       |                 |         |                   |         |                     |         |                      |         |         |          |
| JULY        | 0.6       |                 |         | 2.4               | 77 ± 8  | 1.8                 | 84 ± 7  | 1.7                  | 86 ± 46 | 14.8    | 26 ± 17  |
| AUGUST      | 0.6       |                 |         | 2.7               | 78 ± 6  | 1.3                 | 90 ± 36 | 1.1                  | 85 ± 36 | 8.0     | 60 ± 17  |
| SEPTEMBER   | 0.2       |                 |         |                   |         |                     |         |                      |         |         |          |
| OCTOBER     | 0         |                 |         | 3.7               | 85 ± 32 | 1.1                 | 90 ± 7  | 0.4                  | 90 ± 9  | 18.4    | 19 ± 6   |
| NOVEMBER    | 0.4       |                 |         | 4.6               | 74 ± 8  | 1.8                 | 68 ± 13 | 1.1                  | 66 ± 39 | 19.5    | 8 ± 13   |
| DECEMBER    | 0.44      |                 |         | 3.4               | 78 ± 6  | 1.8                 | 66 ± 16 | 0.6                  | 83 ± 20 | 15.5    | 23 ± 16  |
| JANUARY '79 | 0.12      | 0.88            | 89      | 3.0               | 75 ± 18 | 1.2                 | 85 ± 15 | 1.1                  | 81 ± 17 | 23.9    | 28 ± 183 |
| FEBRUARY    | 0.45      | 0.9             | 86      | 2.5               | 87 ± 7  | 1.0                 | 89 ± 8  | 0.4                  | 89 ± 5  | 24.7    | 14 ± 15  |
| MARCH       | 0.68      | 0.74            | 92      | 3.1               | 84 ± 8  | 0.8                 | 93 ± 7  | 0.3                  | 90 ± 16 | 17.7    | 14 ± 15  |
| APRIL       | 1.0       | 0.5             | 92      | 2.6               | 88 ± 6  | 0.4                 | 96 ± 6  | 0.2                  | 97 ± 5  | 15.5    | 36 ± 11  |
| MAY         | 1.0       | 0.25            | 95      | 3.7               | 86 ± 3  | 0.6                 | 89 ± 6  | 0.2                  | 88 ± 11 | 21.0    | 23 ± 14  |
| JUNE        | 1.0       | 0.26            | 95      | 3.3               | 84 ± 11 | 0.7                 | 88 ± 15 | 0.2                  | 88 ± 52 | 14.3    | 40 ± 11  |
| JULY        | 1.3       | 0.26            | 95      |                   |         |                     |         |                      |         |         |          |

\* PALO ALTO REGIONAL WATER QUALITY CONTROL FACILITY LABORATORY MEASUREMENTS FROM 24 HOUR COMPOSITE SAMPLES.

ORIGINAL PAGE IS  
OF POOR QUALITY

APPENDIX C


MATH MODEL

OF

SOLIDS & NON-VOLATILE ORGANICS

IN EFFLUENT FROM

ACTIVATED SLUDGE PROCESS



WASTEWATER TREATMENT PROCESS SCHEMATIC

EQUATIONS FOR CALCULATING SOLIDS AND ORGANICS CONCENTRATIONS  
IN EFFLUENT FROM ACTIVATED SLUDGE PROCESS

HOURLY CHANGE IN RETURN SOLIDS

$$\bar{X}_R = \frac{T_s - \bar{X}_a V_a}{Q_R/24}$$

HOURLY CHANGE IN AERATOR SOLIDS WITH HOURLY FLOW VARIATION

$$\bar{X}_a = \bar{X}_a' + \left[ \frac{YQ(S_i - S_c) + Q_R \bar{X}_R}{Q + Q_R} - \bar{X}_a' \right] \left[ 1 - e^{-\left(\frac{Q+Q_R}{V_a}\right)} \right]$$

SOLIDS IN CLARIFIER EFFLUENT

$$X_c = \bar{X}_a K e^{-\frac{\Delta t_c}{\gamma}}$$

SOLIDS IN FINAL EFFLUENT

$$X_e = X_c K e^{-\frac{\Delta t_e}{\gamma}}$$

WHERE, DETENTION TIME,  $\Delta t_c$

FOR PLUG FLOW

$$\Delta t_c = \frac{V_c}{\int_0^{V_c} \frac{d}{dt} (Q - Q_w)}$$

FOR MIXED FLOW

$$\bar{\Delta t}_c = \bar{\Delta t}_c' + \left[ \frac{V_c}{(Q - Q_w)} - \bar{\Delta t}_c' \right] \left[ 1 - e^{-\left(\frac{Q - Q_w}{V_c}\right)} \right]$$

FOR  $\bar{\Delta t}_e$  REPLACE  $V_c$  WITH  $V_e$  IN ABOVE EQUATION

HOURLY CHANGE IN EFFLUENT TOC WITH HOURLY LOAD VARIATION

$$S_c = \bar{S}_i \left[ \frac{m}{\bar{\Delta t}_a} - b \right]$$

$$\bar{S}_i = \bar{S}_i' + \left[ S_i - \bar{S}_i' \right] \left[ 1 - e^{-\left(\frac{Q + Q_R}{V_a}\right)} \right]$$

$$\bar{\Delta t}_a = \bar{\Delta t}_a' + \left[ \frac{V_a}{Q + Q_R} - \bar{\Delta t}_a' \right] \left[ 1 - e^{-\left(\frac{Q + Q_R}{V_a}\right)} \right]$$



WHERE THE FOLLOWING VALUES APPLY TO THE PALO ALTO REGIONAL WATER QUALITY CONTROL PLANT

$$V_a = 7.2 \text{ MGAL}$$

$$V_c = 4.3 \text{ MGAL}$$

$$V_E = 0.738 \text{ MGAL}$$

$$Q_R = 15 \text{ MGD}$$

$$Q_w = 1.64 \text{ MGD}$$

$$T_s = 45,700 \times 10^6 \text{ MG}$$

$$S_i - S_c = 50 \text{ TO } 100 \text{ mg/LIT, TOC}$$

$$Q = 15 \text{ TO } 50 \text{ MGD}$$

$$Y = 0.6 \text{ MG/MG BOD (REFERENCE 17)} \approx 0.6 \text{ MG/MG TOC}$$

APPENDIX D  
STATISTICAL ANALYSIS COEFFICIENTS  
FOR TEST PART II

APPENDIX D  
STATISTICAL ANALYSIS COEFFICIENTS  
FOR TEST PART II

This section contains the results of statistical analyses on the WMS data. Included are (1) the slope, intercept, and chi square for the lognormal data distribution model, and (2) slope, intercept, and correlation coefficients for process output as a function of input for linear, parabolic, and logarithmic regression models.

|                           | <u>PAGE</u> |
|---------------------------|-------------|
| Test Period A             |             |
| GC Data . . . . .         | D-2         |
| Other Data . . . . .      | D-13        |
| Test Period H             |             |
| GC Data . . . . .         | D-24        |
| Other Data . . . . .      | D-34        |
| Test Period A             |             |
| Plant Parameters. . . . . | D-44        |

LOG-NORMAL DISTRIBUTION: SEP 3, 1980 TO SEP 30, 1980

| SAMPLE SOURCE                | MONTHLY AVERAGE | ONE SIGMA | LOG(Y)=F(Z) |           |         | CHI SQUARE | SAMPLE SIZE |    |
|------------------------------|-----------------|-----------|-------------|-----------|---------|------------|-------------|----|
|                              |                 |           | SLOPE       | INTERCEPT |         |            |             |    |
| <b>TETRACHLOROETHYLENE</b>   |                 |           |             |           |         |            |             |    |
| 1                            | 3.5             | 2.0       | 0.2879E     | 0         | 0.4924E | 0          | 27.0000     | 18 |
| 2                            | 3.2             | 2.2       | 0.3207E     | 0         | 0.4405E | 0          | 8.1429      | 14 |
| 3                            | 4.9             | 0.8       | 0.7044E     | -1        | 0.6884E | 0          | 2.3333      | 6  |
| 4                            | 3.8             | 2.0       | 0.2918E     | 0         | 0.5265E | 0          | 9.5714      | 14 |
| 5                            | 3.7             | 2.0       | 0.2847E     | 0         | 0.5082E | 0          | 5.2857      | 14 |
| 6                            | 3.3             | 2.1       | 0.2946E     | 0         | 0.4625E | 0          | 6.2353      | 17 |
| <b>METHYLENE CHLORIDE</b>    |                 |           |             |           |         |            |             |    |
| 1                            | 21.8            | 17.6      | 0.3239E     | 0         | 0.1224E | 1          | 2.5556      | 18 |
| 2                            | 10.7            | 6.3       | 0.2498E     | 0         | 0.9629E | 0          | 1.0000      | 14 |
| 3                            | 18.5            | 8.6       | 0.2639E     | 0         | 0.1211E | 1          | 4.0000      | 6  |
| 4                            | 14.7            | 6.5       | 0.2335E     | 0         | 0.1116E | 1          | 4.5714      | 14 |
| 5                            | 12.6            | 8.6       | 0.3205E     | 0         | 0.1001E | 1          | 1.0000      | 14 |
| 6                            | 11.7            | 6.3       | 0.2718E     | 0         | 0.9995E | 0          | 0.9412      | 17 |
| <b>CHLOROFORM</b>            |                 |           |             |           |         |            |             |    |
| 1                            | 12.0            | 3.6       | 0.1239E     | 0         | 0.1062E | 1          | 0.8889      | 18 |
| 2                            | 22.5            | 18.2      | 0.2626E     | 0         | 0.1263E | 1          | 8.1429      | 14 |
| 3                            | 13.3            | 4.2       | 0.1143E     | 0         | 0.1110E | 1          | 5.6667      | 6  |
| 4                            | 16.2            | 11.1      | 0.2413E     | 0         | 0.1137E | 1          | 8.1429      | 14 |
| 5                            | 21.0            | 6.6       | 0.1364E     | 0         | 0.1303E | 1          | 6.7143      | 14 |
| 6                            | 24.2            | 7.5       | 0.1345E     | 0         | 0.1364E | 1          | 2.7059      | 17 |
| <b>1,1,1-TRICHLOROETHANE</b> |                 |           |             |           |         |            |             |    |
| 1                            | 1.6             | 0.9       | 0.2030E     | 0         | 0.1774E | 0          | 8.1111      | 18 |
| 2                            | 0.8             | 0.3       | 0.5686E     | -1        | 0.2541E | -1         | 24.5714     | 14 |
| 3                            | 0.5             | 0.0       | 0.0000E     | 0         | 0.0000E | 0          | 24.0000     | 6  |
| 4                            | 0.4             | 0.1       | 0.0000E     | 0         | 0.0000E | 0          | 56.0000     | 14 |
| 5                            | 3.2             | 1.0       | 0.1684E     | 0         | 0.4833E | 0          | 15.2857     | 14 |
| 6                            | 3.5             | 0.9       | 0.1206E     | 0         | 0.5298E | 0          | 15.6471     | 17 |
| <b>BROMODICHLOROMETHANE</b>  |                 |           |             |           |         |            |             |    |
| 1                            | 15.3            | 6.8       | 0.2251E     | 0         | 0.1137E | 1          | 5.8889      | 18 |
| 2                            | 24.4            | 14.2      | 0.2335E     | 0         | 0.1328E | 1          | 8.8571      | 14 |
| 3                            | 19.4            | 6.3       | 0.1334E     | 0         | 0.1269E | 1          | 0.6667      | 6  |
| 4                            | 21.1            | 9.0       | 0.1644E     | 0         | 0.1294E | 1          | 3.8571      | 14 |
| 5                            | 20.2            | 5.3       | 0.1505E     | 0         | 0.1285E | 1          | 3.1429      | 14 |
| 6                            | 20.1            | 7.0       | 0.2367E     | 0         | 0.1260E | 1          | 17.4118     | 17 |

EOF..

LOG-NORMAL DISTRIBUTION: SEP 3, 1980 TO SEP 30, 1980

| SAMPLE SOURCE               | MONTHLY AVERAGE | ONE SIGMA | LOG(Y)=F(Z) |            | CHI SQUARE | SAMPLE SIZE |
|-----------------------------|-----------------|-----------|-------------|------------|------------|-------------|
|                             |                 |           | SLOPE       | INTERCEPT  |            |             |
| <b>TRICHLOROETHYLENE</b>    |                 |           |             |            |            |             |
| 1                           | 1.7             | 0.9       | 0.1930E 0   | 0.1A33E 0  | 3.1111     | 18          |
| 2                           | 1.0             | 0.3       | 0.7301E -1  | 0.4955E -1 | 6.0000     | 14          |
| 3                           | 0.9             | 0.3       | 0.6559E -1  | 0.3128E -1 | 4.0000     | 6           |
| 4                           | 0.7             | 0.2       | 0.1534E -1  | 0.6028E -2 | 38.8571    | 14          |
| 5                           | 1.7             | 0.3       | 0.7605E -1  | 0.2226E 0  | 2.4286     | 14          |
| 6                           | 1.8             | 0.3       | 0.6430E -1  | 0.2621E 0  | 1.5294     | 17          |
| <b>DIBROMOCHLOROMETHANE</b> |                 |           |             |            |            |             |
| 1                           | 8.9             | 5.3       | 0.2952E 0   | 0.8086E 0  | 1.4444     | 18          |
| 2                           | 13.8            | 7.6       | 0.2366E 0   | 0.1067E 1  | 6.7143     | 14          |
| 3                           | 10.3            | 5.5       | 0.2121E 0   | 0.9662E 0  | 0.6667     | 6           |
| 4                           | 13.7            | 7.3       | 0.2413E 0   | 0.1078E 1  | 0.2857     | 14          |
| 5                           | 9.3             | 2.3       | 0.1043E 0   | 0.9550E 0  | 4.5714     | 14          |
| 6                           | 13.8            | 3.9       | 0.1348E 0   | 0.1109E 1  | 4.4706     | 17          |
| <b>BRONOFORM</b>            |                 |           |             |            |            |             |
| 4                           | 0.1             | 0.3       | 0.1521E -1  | 0.4065E -2 | 46.7143    | 14          |
| <b>TRIMALOMETHANES</b>      |                 |           |             |            |            |             |
| 1                           | 36.3            | 14.9      | 0.1880E 0   | 0.1524E 1  | 8.1111     | 18          |
| 2                           | 60.4            | 37.7      | 0.2171E 0   | 0.1722E 1  | 8.8571     | 14          |
| 3                           | 43.0            | 15.7      | 0.1425E 0   | 0.1612E 1  | 0.6667     | 6           |
| 4                           | 51.1            | 25.4      | 0.1912E 0   | 0.1667E 1  | 0.2857     | 14          |
| 5                           | 50.4            | 11.1      | 0.9698E -1  | 0.1693E 1  | 4.5714     | 14          |
| 6                           | 57.8            | 9.8       | 0.7594E -1  | 0.1756E 1  | 3.2941     | 17          |
| <b>TOTAL HALOCARBONS</b>    |                 |           |             |            |            |             |
| 1                           | 64.8            | 18.9      | 0.1326E 0   | 0.1793E 1  | 1.4444     | 18          |
| 2                           | 76.1            | 34.3      | 0.1625E 0   | 0.1850E 1  | 3.1429     | 14          |
| 3                           | 67.9            | 19.1      | 0.116AE 0   | 0.1819E 1  | 2.3333     | 6           |
| 4                           | 70.7            | 23.8      | 0.1335E 0   | 0.1829E 1  | 1.7143     | 14          |
| 5                           | 71.6            | 9.7       | 0.594AE -1  | 0.1851E 1  | 0.2857     | 14          |
| 6                           | 78.2            | 11.3      | 0.6472E -1  | 0.1889E 1  | 1.5294     | 17          |

EOF..

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR SEP 3, 1988 TO SEP 30, 1988  
FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 2

LINEAR CURVE FIT RESULTS (Y=AO + A1\*X)

| CAL NO. | COMPOUND              | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|----------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | -0.0053  | 1.0276  | 0.7142         | 0.9211       | 14          |
| 2.      | METHYLENE CHLORIDE    | 7.3039   | 0.1985  | 5.9127         | 0.3482       | 16          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000   | 0.0000  | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000   | 0.0000  | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | -10.5012 | 2.5546  | 14.2211        | 0.5685       | 16          |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.9719   | 0.1755  | 0.2002         | 0.5256       | 16          |
| 7.      | BROMODICHLOROMETHANE  | 11.0713  | 0.7395  | 12.1173        | 0.4427       | 16          |
| 8.      | TRICHLOROETHYLENE     | 0.5403   | 0.3087  | 0.1931         | 0.8220       | 16          |
| 9.      | DIBROMOCHLOROMETHANE  | 0.0894   | 0.5119  | 6.4290         | 0.4864       | 16          |
| 10.     | BROMOFORM             | 0.0472   | -0.1046 | 0.0649         | 0.9733       | 6           |
| 11.     | TRIHALOMETHANES       | 24.5235  | 0.6770  | 32.3069        | 0.4482       | 16          |
| 12.     | TOTAL HALOCARBONS     | 64.1609  | 0.1626  | 31.4403        | 0.3309       | 16          |

PARABOLIC CURVE FIT RESULTS (Y=AO + A1\*X + A2\*X\*X)

| CAL NO. | COMPOUND              | A0       | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|----------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.2633  | 1.3493  | -0.0575 | 0.7026         | 0.9237       |
| 2.      | METHYLENE CHLORIDE    | 4.1567   | 0.6159  | -0.0098 | 5.3975         | 0.3970       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 35.3777  | -4.4606 | 0.2424  | 13.7551        | 0.6057       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.0004   | 0.9866  | -0.2117 | 0.2502         | 0.6503       |
| 7.      | BROMODICHLOROMETHANE  | 40.5544  | -4.0770 | 0.1379  | 11.4300        | 0.5326       |
| 8.      | TRICHLOROETHYLENE     | 0.3153   | 0.5797  | -0.0636 | 0.1077         | 0.8327       |
| 9.      | DIBROMOCHLOROMETHANE  | 23.0442  | -2.4709 | 0.1191  | 6.0244         | 0.5742       |
| 10.     | BROMOFORM             | 0.0494   | -0.2153 | 0.4531  | 0.0640         | 0.9733       |
| 11.     | TRIHALOMETHANES       | 204.9743 | -0.4732 | 0.1000  | 29.6396        | 0.5751       |
| 12.     | TOTAL HALOCARBONS     | 107.1273 | -4.3741 | 0.0303  | 30.6693        | 0.3912       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=AO + A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|--------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.1553 | 1.2270 | 0.2923         | 0.8595       |
| 2.      | METHYLENE CHLORIDE    | 0.4414  | 0.4626 | 0.2013         | 0.5637       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -0.1944 | 1.3306 | 0.1920         | 0.7549       |
| 6.      | 1,1,1-TRICHLOROETHANE | -0.1500 | 0.3001 | 0.1234         | 0.6645       |
| 7.      | BROMODICHLOROMETHANE  | 0.5590  | 0.6403 | 0.1050         | 0.6556       |
| 8.      | TRICHLOROETHYLENE     | -0.0052 | 0.5217 | 0.0759         | 0.8320       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.6165  | 0.4728 | 0.1934         | 0.6376       |
| 10.     | BROMOFORM             | -1.5453 | 0.2502 | 0.7440         | 0.0075       |
| 11.     | TRIHALOMETHANES       | 0.7312  | 0.6204 | 0.1765         | 0.6663       |
| 12.     | TOTAL HALOCARBONS     | 1.4753  | 0.2064 | 0.1403         | 0.5207       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR SEP 3, 1968 TO SEP 30, 1968  
FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 3

LINEAR CURVE FIT RESULTS (Y=A0 + A1X)

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | 1.7181  | 0.7899  | 0.3969         | 0.7844       | 8           |
| 2.      | METHYLENE CHLORIDE    | 25.6487 | -0.2844 | 11.8371        | 0.2916       | 8           |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 5.      | CHLOROFORM            | 5.8548  | 0.6638  | 3.1839         | 0.3667       | 8           |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.3173  | 0.1045  | 0.1047         | 0.6925       | 8           |
| 7.      | BROMODICHLOROMETHANE  | 0.2896  | 1.8344  | 4.1727         | 0.7544       | 7           |
| 8.      | TRICHLOROETHYLENE     | 0.3762  | 0.2651  | 0.8939         | 0.9348       | 8           |
| 9.      | DIBROMOCHLOROMETHANE  | 5.4882  | 0.6647  | 4.9273         | 0.5133       | 8           |
| 10.     | BROMOFORM             | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 11.     | TRIHALOMETHANES       | 2.7811  | 1.8181  | 8.2688         | 0.7788       | 8           |
| 12.     | TOTAL HALOCARBONS     | 63.5411 | 0.8687  | 16.4995        | 0.8656       | 8           |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1X + A2X^2)

| CAL NO. | COMPOUND              | A0      | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 2.5636  | 0.3195  | 0.0435  | 0.3968         | 0.7855       |
| 2.      | METHYLENE CHLORIDE    | 27.8611 | -0.4777 | 0.8844  | 11.8178        | 0.2978       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 59.8891 | -0.9989 | 0.4288  | 2.9451         | 0.5894       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.2854  | 0.1444  | -0.8897 | 0.1845         | 0.6936       |
| 7.      | BROMODICHLOROMETHANE  | 33.2883 | -3.2855 | 0.1279  | 3.5858         | 0.8257       |
| 8.      | TRICHLOROETHYLENE     | 0.4329  | 0.2856  | 0.8128  | 0.8934         | 0.9347       |
| 9.      | DIBROMOCHLOROMETHANE  | 17.6994 | -1.6868 | 0.8891  | 4.7274         | 0.5675       |
| 10.     | BROMOFORM             | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 11.     | TRIHALOMETHANES       | 89.4935 | -3.6854 | 0.8572  | 5.2451         | 0.9174       |
| 12.     | TOTAL HALOCARBONS     | 66.2818 | -0.8416 | 0.8889  | 16.4986        | 0.8664       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)-A0 + A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 0.2778  | 0.6314  | 0.8368         | 0.7712       |
| 2.      | METHYLENE CHLORIDE    | 1.4821  | -0.1448 | 0.2639         | 0.3258       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.6598  | 0.4123  | 0.8988         | 0.3347       |
| 6.      | 1,1,1-TRICHLOROETHANE | -0.3872 | 0.3817  | 0.8769         | 0.7634       |
| 7.      | BROMODICHLOROMETHANE  | 0.2784  | 0.7852  | 0.8961         | 0.7867       |
| 8.      | TRICHLOROETHYLENE     | -0.2846 | 0.5664  | 0.8419         | 0.9376       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.5221  | 0.5383  | 0.1876         | 0.4768       |
| 10.     | BROMOFORM             | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 11.     | TRIHALOMETHANES       | 0.9881  | 0.6995  | 0.8885         | 0.5852       |
| 12.     | TOTAL HALOCARBONS     | 1.7298  | 0.8484  | 0.1876         | 0.1368       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR SEP 3, 1968 TO SEP 30, 1968  
FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 4

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL. NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|----------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.       | TETRACHLOROETHYLENE   | 0.7240  | 0.9178  | 0.6816         | 0.9261       | 13          |
| 2.       | METHYLENE CHLORIDE    | 11.9390 | 0.1974  | 5.9706         | 0.3436       | 13          |
| 3.       | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 4.       | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 5.       | CHLOROFORM            | -7.9730 | 1.9074  | 0.2007         | 0.6259       | 13          |
| 6.       | 1,1,1-TRICHLOROETHANE | 0.3005  | 0.0203  | 0.1117         | 0.3201       | 13          |
| 7.       | BROMODICHLOROMETHANE  | 17.0459 | 0.1741  | 0.7111         | 0.1217       | 16          |
| 8.       | TRICHLOROETHYLENE     | 0.4244  | 0.1789  | 0.0959         | 0.0990       | 16          |
| 9.       | DIBROMOCHLOROMETHANE  | 11.9606 | 0.1034  | 6.9163         | 0.0725       | 16          |
| 10.      | BROMOFORM             | 0.3000  | -1.3522 | 0.3995         | 0.3650       | 6           |
| 11.      | TRIHALOMETHANES       | 37.6200 | 0.2600  | 24.5619        | 0.1416       | 16          |
| 12.      | TOTAL HALOCARBONS     | 71.9516 | -0.0000 | 25.1705        | 0.0601       | 16          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CAL. NO. | COMPOUND              | A0       | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|----------|-----------------------|----------|---------|---------|----------------|--------------|
| 1.       | TETRACHLOROETHYLENE   | 0.2490   | 1.4104  | -0.0059 | 0.5701         | 0.9339       |
| 2.       | METHYLENE CHLORIDE    | 9.6272   | 0.4925  | -0.0060 | 5.9273         | 0.3649       |
| 3.       | CARBON TETRACHLORIDE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.       | 1,2-DICHLOROETHYLENE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.       | CHLOROFORM            | 22.6449  | -2.5960 | 0.1541  | 7.0700         | 0.6630       |
| 6.       | 1,1,1-TRICHLOROETHANE | 0.3453   | 0.0700  | -0.0131 | 0.1115         | 0.3340       |
| 7.       | BROMODICHLOROMETHANE  | 52.4306  | -4.4730 | 0.1331  | 7.0054         | 0.4563       |
| 8.       | TRICHLOROETHYLENE     | 0.4064   | 0.2006  | -0.0051 | 0.0959         | 0.0600       |
| 9.       | DIBROMOCHLOROMETHANE  | 15.2009  | -0.5420 | 0.0250  | 6.0991         | 0.1000       |
| 10.      | BROMOFORM             | 0.3447   | -3.0151 | 6.9416  | 0.3906         | 0.3710       |
| 11.      | TRIHALOMETHANES       | 176.6369 | -6.9424 | 0.0032  | 22.4000        | 0.4293       |
| 12.      | TOTAL HALOCARBONS     | 214.1011 | -5.3332 | 0.0443  | 23.0599        | 0.3244       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)-A0 +A1\*LOG(X))

| CAL. NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|----------|-----------------------|---------|---------|----------------|--------------|
| 1.       | TETRACHLOROETHYLENE   | -0.1020 | 1.2365  | 0.1110         | 0.9677       |
| 2.       | METHYLENE CHLORIDE    | 0.0066  | 0.2005  | 0.2091         | 0.3603       |
| 3.       | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.       | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.       | CHLOROFORM            | -0.2637 | 1.2961  | 0.1807         | 0.6314       |
| 6.       | 1,1,1-TRICHLOROETHANE | -0.4047 | 0.1410  | 0.1071         | 0.3432       |
| 7.       | BROMODICHLOROMETHANE  | 1.1932  | 0.0992  | 0.1693         | 0.2129       |
| 8.       | TRICHLOROETHYLENE     | -0.2246 | 0.4106  | 0.0601         | 0.0337       |
| 9.       | DIBROMOCHLOROMETHANE  | 0.9629  | 0.0940  | 0.2310         | 0.2666       |
| 10.      | BROMOFORM             | -1.0066 | -0.2345 | 0.0201         | 0.5193       |
| 11.      | TRIHALOMETHANES       | 1.5922  | 0.0220  | 0.2092         | 0.2409       |
| 12.      | TOTAL HALOCARBONS     | 2.0972  | -0.1756 | 0.1006         | 0.2206       |



GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR SEP 3, 1980 TO SEP 30, 1980  
 FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 5

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|--------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | 1.2696  | 0.7442 | 0.9736         | 0.7740       | 13          |
| 2.      | METHYLENE CHLORIDE    | 7.5962  | 0.3025 | 7.3864         | 0.3847       | 16          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 6.0647  | 1.2200 | 4.9020         | 0.6575       | 15          |
| 6.      | 1,1,1-TRICHLOROETHANE | 3.1592  | 0.0713 | 0.8724         | 0.1465       | 16          |
| 7.      | BROMODICHLOROMETHANE  | 13.0779 | 0.3909 | 4.1870         | 0.5421       | 16          |
| 8.      | TRICHLOROETHYLENE     | 1.5019  | 0.1037 | 0.2700         | 0.4039       | 16          |
| 9.      | DIBROMOCHLOROMETHANE  | 0.5901  | 0.0040 | 2.0740         | 0.4345       | 16          |
| 10.     | BROMOFORM             | 0.0020  | 0.1614 | 0.0000         | 1.0000       | 2           |
| 11.     | TRIHALOMETHANES       | 29.6752 | 0.5283 | 9.1079         | 0.6843       | 16          |
| 12.     | TOTAL HALOCARBONS     | 57.6578 | 0.2163 | 0.8952         | 0.5449       | 16          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*X2)

| CAL NO. | COMPOUND              | A0      | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 1.2695  | 0.7623  | -0.0030 | 0.9736         | 0.7740       |
| 2.      | METHYLENE CHLORIDE    | 10.3133 | -0.0570 | 0.0004  | 7.3227         | 0.4033       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 10.1066 | 0.6272  | 0.0207  | 4.8910         | 0.6593       |
| 6.      | 1,1,1-TRICHLOROETHANE | 3.0727  | -0.9415 | 0.2643  | 0.8501         | 0.2310       |
| 7.      | BROMODICHLOROMETHANE  | 12.6160 | 0.5646  | -0.0047 | 4.1855         | 0.5420       |
| 8.      | TRICHLOROETHYLENE     | 1.3130  | 0.3313  | -0.0534 | 0.2673         | 0.4993       |
| 9.      | DIBROMOCHLOROMETHANE  | 11.1539 | -0.4266 | 0.0204  | 2.0300         | 0.4655       |
| 10.     | BROMOFORM             | 0.0000  | 0.0000  | 0.0000  | 0.0130         | 1.0111       |
| 11.     | TRIHALOMETHANES       | 29.7205 | 0.5255  | 0.0000  | 9.1079         | 0.6843       |
| 12.     | TOTAL HALOCARBONS     | -6.5184 | 2.5840  | -0.0200 | 0.1206         | 0.6435       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)-A0 +A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|--------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 0.1692  | 0.7616 | 0.1136         | 0.8693       |
| 2.      | METHYLENE CHLORIDE    | 0.6090  | 0.3400 | 0.2036         | 0.3900       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.5675  | 0.6867 | 0.1097         | 0.5910       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.4030  | 0.0662 | 0.1534         | 0.2539       |
| 7.      | BROMODICHLOROMETHANE  | 0.0227  | 0.3969 | 0.1212         | 0.5390       |
| 8.      | TRICHLOROETHYLENE     | 0.1917  | 0.1424 | 0.0854         | 0.4911       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.0007  | 0.0870 | 0.0972         | 0.4849       |
| 10.     | BROMOFORM             | -1.0403 | 0.6096 | 0.0000         | 1.0000       |
| 11.     | TRIHALOMETHANES       | 1.0151  | 0.4303 | 0.0843         | 0.6901       |
| 12.     | TOTAL HALOCARBONS     | 1.5057  | 0.1920 | 0.0547         | 0.5071       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR SEP 3, 1966 TO SEP 30, 1966

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 6

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1X$ )

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | -0.0076 | 0.9757  | 0.0072         | 0.0722       | 14          |
| 2.      | METHYLENE CHLORIDE    | 10.6397 | 0.0519  | 6.2019         | 0.0049       | 16          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 12.3011 | 0.7540  | 5.4056         | 0.5037       | 16          |
| 6.      | 1,1,1-TRICHLOROETHANE | 3.9730  | -0.1115 | 0.0223         | 0.1673       | 16          |
| 7.      | BROMODICHLOROMETHANE  | 19.9201 | 0.1170  | 4.0332         | 0.4466       | 16          |
| 8.      | TRICHLOROETHYLENE     | 1.9047  | -0.0501 | 0.2925         | 0.1527       | 16          |
| 9.      | DIBROMOCHLOROMETHANE  | 12.3005 | 0.0225  | 4.0001         | 0.1290       | 16          |
| 10.     | BROMOFORM             | 0.2420  | -2.6727 | 0.0619         | 0.9000       | 3           |
| 11.     | TRIHALOMETHANES       | 51.0370 | 0.1126  | 10.0929        | 0.1430       | 16          |
| 12.     | TOTAL HALOCARBONS     | 05.2053 | -0.1500 | 12.2909        | 0.2142       | 16          |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1X + A_2X^2$ )

| CAL NO. | COMPOUND              | A0       | A1       | A2       | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|----------|----------|----------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.2104  | 1.2305   | -0.0470  | 0.0011         | 0.0741       |
| 2.      | METHYLENE CHLORIDE    | 11.6005  | -0.0076  | 0.0033   | 6.2707         | 0.1036       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000   | 0.0000   | 0.0000   | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000   | 0.0000   | 0.0000   | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 21.0030  | -0.5402  | 0.0450   | 5.3639         | 0.5150       |
| 6.      | 1,1,1-TRICHLOROETHANE | 5.3970   | -2.7004  | 0.6756   | 0.7170         | 0.5100       |
| 7.      | BROMODICHLOROMETHANE  | 17.6954  | 0.4110   | -0.0004  | 4.0250         | 0.4499       |
| 8.      | TRICHLOROETHYLENE     | 1.0414   | 0.0263   | -0.0170  | 0.2923         | 0.1500       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.3565   | 0.0107   | -0.0315  | 3.9639         | 0.1954       |
| 10.     | BROMOFORM             | 0.6606   | -30.5320 | 256.1277 | 0.0000         | 1.0000       |
| 11.     | TRIHALOMETHANES       | 55.5942  | -0.0021  | 0.0022   | 10.0095        | 0.1451       |
| 12.     | TOTAL HALOCARBONS     | 139.5964 | -2.1575  | 0.0170   | 11.0995        | 0.3251       |

LOGARITHMIC CURVE FIT RESULTS ( $\text{LOG}Y=A_0 + A_1\text{LOG}X$ )

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.1527 | 1.1902  | 0.1700         | 0.9429       |
| 2.      | METHYLENE CHLORIDE    | 0.0130  | 0.1541  | 0.2640         | 0.3263       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.0760  | 0.4117  | 0.1141         | 0.5147       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.5309  | -0.1006 | 0.1135         | 0.3071       |
| 7.      | BROMODICHLOROMETHANE  | 1.2170  | 0.0972  | 0.0796         | 0.4053       |
| 8.      | TRICHLOROETHYLENE     | 0.2630  | -0.0509 | 0.0711         | 0.1712       |
| 9.      | DIBROMOCHLOROMETHANE  | 1.0242  | 0.0532  | 0.1446         | 0.2709       |
| 10.     | BROMOFORM             | -4.2520 | -1.9939 | 0.0165         | 0.9997       |
| 11.     | TRIHALOMETHANES       | 1.6090  | 0.0030  | 0.0079         | 0.1900       |
| 12.     | TOTAL HALOCARBONS     | 2.1021  | -0.1207 | 0.0723         | 0.2664       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR SEP 3, 1988 TO SEP 30, 1988  
 FROM SAMPLE SOURCE 2 TO SAMPLE SOURCE 3

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | 2.3183  | 0.5244  | 0.4747         | 0.6784       | 8           |
| 2.      | METHYLENE CHLORIDE    | 20.8605 | -0.0196 | 11.5376        | 0.0114       | 8           |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 5.      | CHLOROFORM            | 4.1122  | 0.5622  | 1.4243         | 0.9893       | 8           |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.2100  | 0.3847  | 0.8978         | 0.7386       | 8           |
| 7.      | BROMODICHLOROMETHANE  | 2.3498  | 0.7279  | 3.2584         | 0.8594       | 7           |
| 8.      | TRICHLOROETHYLENE     | 0.8126  | 0.8822  | 0.8659         | 0.9681       | 8           |
| 9.      | DIBROMOCHLOROMETHANE  | 1.5738  | 0.8488  | 2.3854         | 0.9096       | 8           |
| 10.     | BROMOFORM             | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 11.     | TRIHALOMETHANES       | 6.7533  | 0.7898  | 5.7966         | 0.8981       | 8           |
| 12.     | TOTAL HALOCARBONS     | 29.5924 | 0.5786  | 13.5811        | 0.5784       | 8           |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*X^2)

| CAL NO. | COMPOUND              | A0       | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|----------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 16.3789  | -5.2388 | 0.5741  | 0.3419         | 0.8453       |
| 2.      | METHYLENE CHLORIDE    | 34.9632  | -2.4557 | 0.0800  | 18.6766        | 0.3792       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 19.5421  | -1.1476 | 0.8411  | 1.0515         | 0.9516       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.2754   | 0.2385  | 0.0743  | 0.8976         | 0.7398       |
| 7.      | BROMODICHLOROMETHANE  | 26.8396  | -1.4385 | 0.2449  | 2.8117         | 0.8968       |
| 8.      | TRICHLOROETHYLENE     | 0.2056   | 0.4651  | 0.1361  | 0.8642         | 0.9697       |
| 9.      | DIBROMOCHLOROMETHANE  | 1.1891   | 0.9298  | -0.0028 | 2.3838         | 0.9897       |
| 10.     | BROMOFORM             | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 11.     | TRIHALOMETHANES       | 48.6986  | -0.5597 | 0.8184  | 5.2883         | 0.9189       |
| 12.     | TOTAL HALOCARBONS     | 113.4889 | -1.8883 | 0.8157  | 12.7843        | 0.6342       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|--------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 0.3684  | 0.4745 | 0.8464         | 0.5961       |
| 2.      | METHYLENE CHLORIDE    | 1.2299  | 0.8889 | 0.2686         | 0.2711       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.3395  | 0.6469 | 0.8521         | 0.8413       |
| 6.      | 1,1,1-TRICHLOROETHANE | -0.2278 | 0.6488 | 0.8888         | 0.7348       |
| 7.      | BROMODICHLOROMETHANE  | 0.1881  | 0.7979 | 0.8797         | 0.8896       |
| 8.      | TRICHLOROETHYLENE     | -0.8898 | 0.9665 | 0.8346         | 0.9578       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.1885  | 0.8185 | 0.1898         | 0.8595       |
| 10.     | BROMOFORM             | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 11.     | TRIHALOMETHANES       | 0.2981  | 0.7844 | 0.8668         | 0.8396       |
| 12.     | TOTAL HALOCARBONS     | 0.8633  | 0.5263 | 0.8941         | 0.4986       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR SEP 3, 1960 TO SEP 30, 1960

FROM SAMPLE SOURCE 3 TO SAMPLE SOURCE 4

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1X$ )

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|--------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | -1.0734 | 1.2210 | 0.1189         | 0.9959       | 0           |
| 2.      | METHYLENE CHLORIDE    | 12.1293 | 0.2895 | 4.5235         | 0.7518       | 0           |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | -0.6456 | 0.9090 | 1.2466         | 0.9597       | 0           |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.2282  | 0.3732 | 0.0473         | 0.7701       | 0           |
| 7.      | BROMODICHLOROMETHANE  | 1.0832  | 0.8527 | 0.9636         | 0.9072       | 7           |
| 8.      | TRICHLOROETHYLENE     | 0.1541  | 0.6901 | 0.1187         | 0.8455       | 0           |
| 9.      | DIBROMOCHLOROMETHANE  | -1.6390 | 1.2013 | 1.1834         | 0.9050       | 0           |
| 10.     | BROMOFORM             | 0.0000  | 0.0000 | 0.3590         | 0.4139       | 1           |
| 11.     | TRIHALOMETHANES       | 7.3510  | 0.8442 | 9.5203         | 0.0007       | 0           |
| 12.     | TOTAL HALOCARBONS     | 26.1681 | 0.5862 | 11.5445        | 0.6446       | 0           |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1X + A_2X^2$ )

| CAL NO. | COMPOUND              | A0       | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|----------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 2.8961   | -0.8950 | 0.1343  | 0.1014         | 0.9977       |
| 2.      | METHYLENE CHLORIDE    | 6.4783   | 0.9024  | -0.8125 | 4.1224         | 0.7993       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -19.0453 | 3.4731  | -0.8766 | 1.0667         | 0.9706       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.5524   | -0.8730 | 1.0926  | 0.8395         | 0.8515       |
| 7.      | BROMODICHLOROMETHANE  | 5.7154   | 0.3696  | 0.0114  | 0.8750         | 0.9095       |
| 8.      | TRICHLOROETHYLENE     | -0.3566  | 1.7005  | -0.5362 | 0.1122         | 0.8632       |
| 9.      | DIBROMOCHLOROMETHANE  | 2.8014   | 0.3076  | 0.0290  | 0.9967         | 0.9099       |
| 10.     | BROMOFORM             | 0.0000   | 0.0000  | 0.0000  | 0.3590         | 0.4139       |
| 11.     | TRIHALOMETHANES       | 20.2304  | 0.2762  | 0.0056  | 5.4000         | 0.0026       |
| 12.     | TOTAL HALOCARBONS     | 151.0005 | -3.2522 | 0.0270  | 9.0706         | 0.7560       |

LOGARITHMIC CURVE FIT RESULTS ( $\text{LOG}(Y)=A_0 + A_1\text{LOG}(X)$ )

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|--------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.1370 | 1.1991 | 0.0112         | 0.9970       |
| 2.      | METHYLENE CHLORIDE    | 0.7010  | 0.3630 | 0.1235         | 0.7167       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -0.1500 | 1.1005 | 0.0459         | 0.9536       |
| 6.      | 1,1,1-TRICHLOROETHANE | -0.2655 | 0.4075 | 0.0573         | 0.6655       |
| 7.      | BROMODICHLOROMETHANE  | 0.0092  | 0.0900 | 0.0293         | 0.9014       |
| 8.      | TRICHLOROETHYLENE     | -0.0730 | 0.0695 | 0.0612         | 0.0624       |
| 9.      | DIBROMOCHLOROMETHANE  | -0.1010 | 1.1097 | 0.0400         | 0.9010       |
| 10.     | BROMOFORM             | 0.0000  | 0.0000 | 0.4439         | 1.0321       |
| 11.     | TRIHALOMETHANES       | 0.1940  | 0.0010 | 0.0957         | 0.0170       |
| 12.     | TOTAL HALOCARBONS     | 0.0451  | 0.5297 | 0.0760         | 0.6160       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR SEP 3, 1980 TO SEP 30, 1980  
 FROM SAMPLE SOURCE 4 TO SAMPLE SOURCE 5

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | -0.1953 | 1.0054  | 0.6003         | 0.0954       | 13          |
| 2.      | METHYLENE CHLORIDE    | 2.8341  | 0.7004  | 6.6711         | 0.5665       | 15          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 15.4012 | 0.3426  | 5.2079         | 0.5053       | 14          |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.0723  | 3.2207  | 0.0170         | 0.4361       | 15          |
| 7.      | BROMODICHLOROMETHANE  | 17.0230 | 0.1293  | 4.7155         | 0.3235       | 16          |
| 8.      | TRICHLOROETHYLENE     | 1.1923  | 0.6671  | 0.2560         | 0.5541       | 16          |
| 9.      | DIBROMOCHLOROMETHANE  | 7.9301  | 0.1146  | 1.9595         | 0.5253       | 16          |
| 10.     | BROMOFORM             | -0.0935 | 14.1360 | 0.0000         | 1.0000       | 2           |
| 11.     | TRIHALOMETHANES       | 42.6913 | 0.1543  | 10.9053        | 0.4075       | 16          |
| 12.     | TOTAL HALOCARBONS     | 70.7004 | 0.0000  | 9.6317         | 0.4191       | 16          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*X)

| CAL NO. | COMPOUND              | A0      | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.0746 | 0.9240  | 0.0112  | 0.6070         | 0.0956       |
| 2.      | METHYLENE CHLORIDE    | 4.4064  | 0.3342  | 0.0122  | 6.6421         | 0.5717       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 12.9905 | 0.6359  | -0.0060 | 5.1014         | 0.5910       |
| 6.      | 1,1,1-TRICHLOROETHANE | 2.2503  | 1.4590  | 1.0094  | 0.0165         | 0.4373       |
| 7.      | BROMODICHLOROMETHANE  | 21.6702 | -0.2306 | 0.0070  | 4.6769         | 0.3453       |
| 8.      | TRICHLOROETHYLENE     | -1.3090 | 7.3799  | -4.2210 | 0.2074         | 0.7403       |
| 9.      | DIBROMOCHLOROMETHANE  | 6.3314  | 0.3005  | -0.0006 | 1.9230         | 0.5496       |
| 10.     | BROMOFORM             | 0.0000  | 0.0000  | 0.0000  | 0.0130         | 1.0111       |
| 11.     | TRIHALOMETHANES       | 47.5377 | -0.0416 | 0.0016  | 10.0551        | 0.4947       |
| 12.     | TOTAL HALOCARBONS     | 71.5061 | -0.0250 | 0.0002  | 9.6305         | 0.4194       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)-A0 + A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.1447 | 1.1044  | 0.0744         | 0.9501       |
| 2.      | METHYLENE CHLORIDE    | 0.2031  | 0.7150  | 0.2550         | 0.5537       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.9563  | 0.3046  | 0.1107         | 0.5055       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.7125  | 0.5033  | 0.1437         | 0.4701       |
| 7.      | BROMODICHLOROMETHANE  | 1.1501  | 0.1123  | 0.1365         | 0.3164       |
| 8.      | TRICHLOROETHYLENE     | 0.2025  | 0.4353  | 0.0776         | 0.6115       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.7073  | 0.1669  | 0.0906         | 0.5705       |
| 10.     | BROMOFORM             | 19.4776 | 10.0060 | 0.0000         | 1.0000       |
| 11.     | TRIHALOMETHANES       | 1.4633  | 0.1377  | 0.1004         | 0.5066       |
| 12.     | TOTAL HALOCARBONS     | 1.0592  | -0.0075 | 0.0602         | 0.4530       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR SEP 3, 1980 TO SEP 30, 1980  
FROM SAMPLE SOURCE 5 TO SAMPLE SOURCE 6

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | 0.2370  | 0.8472  | 1.1274         | 0.7763       | 15          |
| 2.      | METHYLENE CHLORIDE    | 5.4775  | 0.5076  | 4.5263         | 0.6729       | 17          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 5.4030  | 0.7470  | 3.0206         | 0.9131       | 16          |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.3072  | 6.6241  | 0.5600         | 0.7240       | 17          |
| 7.      | BROMODICHLOROMETHANE  | 23.0625 | -0.0906 | 5.3662         | 0.2114       | 17          |
| 8.      | TRICHLOROETHYLENE     | 1.6201  | 0.1004  | 0.2014         | 0.2045       | 17          |
| 9.      | DIBROMOCHLOROMETHANE  | 7.0567  | 0.5541  | 3.2026         | 0.5793       | 17          |
| 10.     | BROMOFORM             | 0.0066  | 0.0001  | 0.0000         | 1.0000       | 2           |
| 11.     | TRIHALOMETHANES       | 46.2144 | 0.1009  | 9.9447         | 0.3057       | 17          |
| 12.     | TOTAL HALOCARBONS     | 66.4100 | 0.1345  | 12.0324        | 0.2206       | 17          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CAL NO. | COMPOUND              | A0      | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.4063 | 1.4125  | -0.0029 | 1.0935         | 0.7913       |
| 2.      | METHYLENE CHLORIDE    | 4.5402  | 0.6096  | -0.0059 | 4.5100         | 0.6757       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -0.3762 | 1.2190  | -0.0003 | 2.0700         | 0.9214       |
| 6.      | 1,1,1-TRICHLOROETHANE | 2.2323  | -0.0567 | 0.1115  | 0.5516         | 0.7432       |
| 7.      | BROMODICHLOROMETHANE  | 1.0264  | 1.9546  | -0.0430 | 3.0024         | 0.7071       |
| 8.      | TRICHLOROETHYLENE     | 0.0713  | 0.0342  | -0.1553 | 0.2669         | 0.3715       |
| 9.      | DIBROMOCHLOROMETHANE  | -7.0511 | 2.0099  | -0.0740 | 2.6105         | 0.7590       |
| 10.     | BROMOFORM             | 0.0000  | 0.0000  | 0.0000  | 0.1062         | 0.4016       |
| 11.     | TRIHALOMETHANES       | 21.6770 | 0.9379  | -0.0047 | 9.2447         | 0.5142       |
| 12.     | TOTAL HALOCARBONS     | 62.3975 | 0.2240  | -0.0004 | 12.0291        | 0.2210       |

LOGARITHMIC CURVE FIT RESULTS (LOGEY)=A0 +A1\*LOGEX)

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.4479 | 1.5966  | 0.1766         | 0.9362       |
| 2.      | METHYLENE CHLORIDE    | 0.4735  | 0.5300  | 0.1902         | 0.7143       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.2420  | 0.0177  | 0.0547         | 0.9255       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.2956  | 0.4433  | 0.0916         | 0.6229       |
| 7.      | BROMODICHLOROMETHANE  | 1.4539  | -0.1171 | 0.1471         | 0.1202       |
| 8.      | TRICHLOROETHYLENE     | 0.2107  | 0.1073  | 0.0662         | 0.3277       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.4216  | 0.6696  | 0.1100         | 0.6650       |
| 10.     | BROMOFORM             | -1.3039 | 0.4490  | 0.0000         | 1.0000       |
| 11.     | TRIHALOMETHANES       | 1.2743  | 0.2743  | 0.0770         | 0.4590       |
| 12.     | TOTAL HALOCARBONS     | 1.5440  | 0.1707  | 0.0710         | 0.2546       |

LOG-NORMAL DISTRIBUTION: SEP 3, 1980 TO FEB 28, 1981

| SAMPLE SOURCE         | AVERAGE | ONE SIGMA | LOG(Y)=F(Z) |            | CHI SQUARE | SAMPLE SIZE |
|-----------------------|---------|-----------|-------------|------------|------------|-------------|
|                       |         |           | SLOPE       | INTERCEPT  |            |             |
| <b>TOTAL BIOMASS</b>  |         |           |             |            |            |             |
| 1                     | 2.0     | 1.1       | 0.3113E     | 0 0.2206E  | 0          | 11.8144 97  |
| 2                     | 0.2     | 0.1       | 0.2601E     | 0 -0.8346E | 0          | 1.1379 58   |
| 3                     | 0.7     | 0.5       | 0.3149E     | 0 -0.2938E | 0          | 3.5663 83   |
| 4                     | 0.3     | 0.3       | 0.2845E     | 0 -0.5782E | 0          | 0.5556 90   |
| 5                     | 0.3     | 0.2       | 0.2731E     | 0 -0.6544E | 0          | 6.3158 95   |
| 6                     | 0.3     | 0.4       | 0.2975E     | 0 -0.6705E | 0          | 6.0870 115  |
| <b>VIABLE BIOMASS</b> |         |           |             |            |            |             |
| 1                     | 0.6     | 0.5       | 0.4343E     | 0 -0.3701E | 0          | 32.6667 99  |
| 2                     | 0.0     | 0.0       | 0.3448E     | 0 -0.1698E | 1          | 5.2759 58   |
| 3                     | 0.2     | 0.2       | 0.4553E     | 0 -0.8758E | 0          | 6.4762 84   |
| 4                     | 0.1     | 0.1       | 0.4671E     | 0 -0.1127E | 1          | 3.4506 91   |
| 5                     | 0.1     | 0.1       | 0.4719E     | 0 -0.1238E | 1          | 1.4624 93   |
| 6                     | 0.1     | 0.4       | 0.4335E     | 0 -0.1167E | 1          | 6.0690 116  |
| <b>RES CHLORINE</b>   |         |           |             |            |            |             |
| 1                     | 4.0     | 1.9       | 0.2464E     | 0 0.5473E  | 0          | 5.5385 91   |
| 2                     | 1.5     | 1.0       | 0.3388E     | 0 0.4781E  | -1         | 0.6377 69   |
| 3                     | 1.2     | 1.1       | 0.3129E     | 0 -0.3173E | -1         | 7.1282 78   |
| 4                     | 0.9     | 0.8       | 0.3433E     | 0 -0.1495E | 0          | 1.9080 87   |
| 5                     | 0.3     | 0.5       | 0.3356E     | 0 -0.7382E | 0          | 81.3627 91  |
| 6                     | 2.0     | 1.2       | 0.3085E     | 0 0.2194E  | 0          | 11.8654 104 |
| <b>TURBIDITY-SI02</b> |         |           |             |            |            |             |
| 1                     | 13.9    | 5.2       | 0.1746E     | 0 0.1109E  | 0          | 5.9123 114  |
| 2                     | 11.4    | 10.0      | 0.2234E     | 0 0.9805E  | 0          | 9.1795 78   |
| 3                     | 6.2     | 3.9       | 0.2149E     | 0 0.7294E  | 0          | 20.0612 98  |
| 4                     | 9.3     | 3.5       | 0.1776E     | 0 0.9353E  | 0          | 7.6364 110  |
| 5                     | 5.7     | 4.0       | 0.1805E     | 0 0.7077E  | 0          | 22.1982 111 |
| 6                     | 4.7     | 1.8       | 0.1480E     | 0 0.6437E  | 0          | 6.2029 138  |
| <b>DIS OXYGEN</b>     |         |           |             |            |            |             |
| 1                     | 6.2     | 1.8       | 0.1578E     | 0 0.7657E  | 0          | 38.5439 114 |
| 2                     | 6.7     | 1.3       | 0.8404E     | -1 0.8208E | 0          | 7.7692 78   |
| 3                     | 6.6     | 1.6       | 0.1079E     | 0 0.8089E  | 0          | 8.0202 99   |
| 4                     | 6.9     | 1.6       | 0.9945E     | -1 0.8301E | 0          | 3.9091 110  |
| 5                     | 6.3     | 1.4       | 0.9677E     | -1 0.7897E | 0          | 10.7679 112 |
| 6                     | 6.2     | 1.6       | 0.1213E     | 0 0.7760E  | 0          | 18.5217 138 |

EOF..

LOG-NORMAL DISTRIBUTION: SEP 3, 1960 TO FEB 28, 1961

| SAMPLE SOURCE         | AVERAGE | ONE SIGMA | LOG(Y)=F(Z) |            | CHI SQUARE | SAMPLE SIZE |
|-----------------------|---------|-----------|-------------|------------|------------|-------------|
|                       |         |           | SLOPE       | INTERCEPT  |            |             |
| <b>AMMONIA</b>        |         |           |             |            |            |             |
| 1                     | 5.1     | 10.2      | 0.4780E     | 0 0.3761E  | 0 12.1136  | 88          |
| 2                     | 5.9     | 12.7      | 0.5348E     | 0 0.3245E  | 0 9.2281   | 57          |
| 3                     | 5.1     | 12.1      | 0.5726E     | 0 0.2350E  | 0 9.1316   | 76          |
| 4                     | 4.6     | 13.5      | 0.5400E     | 0 0.2077E  | 0 16.2222  | 81          |
| 5                     | 4.3     | 12.6      | 0.5916E     | 0 0.9275E  | -1 18.9722 | 72          |
| 6                     | 4.2     | 12.8      | 0.5163E     | 0 0.1283E  | 0 23.5670  | 97          |
| <b>PH</b>             |         |           |             |            |            |             |
| 1                     | 5.6     | 0.5       | 0.3182E     | -1 0.7471E | 0 14.0000  | 115         |
| 2                     | 7.4     | 1.0       | 0.5853E     | -1 0.8656E | 0 0.4615   | 78          |
| 3                     | 6.0     | 0.7       | 0.4688E     | -1 0.7768E | 0 18.5000  | 100         |
| 4                     | 6.3     | 0.8       | 0.4913E     | -1 0.7959E | 0 5.5455   | 110         |
| 5                     | 6.2     | 0.6       | 0.4117E     | -1 0.7936E | 0 6.9558   | 113         |
| 6                     | 6.1     | 0.5       | 0.3425E     | -1 0.7825E | 0 6.3478   | 138         |
| <b>TOT ORG CARBON</b> |         |           |             |            |            |             |
| 1                     | 9.7     | 2.4       | 0.1108E     | 0 0.9753E  | 0 10.7708  | 96          |
| 2                     | 6.8     | 2.1       | 0.1377E     | 0 0.8107E  | 0 12.8824  | 68          |
| 3                     | 7.2     | 3.0       | 0.1536E     | 0 0.8293E  | 0 13.7531  | 81          |
| 4                     | 6.8     | 2.0       | 0.1278E     | 0 0.8145E  | 0 15.2222  | 90          |
| 5                     | 4.2     | 1.6       | 0.1448E     | 0 0.5945E  | 0 1.2527   | 91          |
| 6                     | 3.7     | 1.4       | 0.1306E     | 0 0.5524E  | 0 8.8113   | 106         |
| <b>CONDUCTIVITY</b>   |         |           |             |            |            |             |
| 1                     | 1234.4  | 62.6      | 0.2145E     | -1 0.3091E | 1 2.4348   | 115         |
| 2                     | 1287.1  | 83.3      | 0.2715E     | -1 0.3109E | 1 12.3846  | 78          |
| 3                     | 1296.1  | 53.2      | 0.1837E     | -1 0.3112E | 1 2.5000   | 100         |
| 4                     | 1303.8  | 60.4      | 0.2045E     | -1 0.3115E | 1 3.9091   | 110         |
| 5                     | 1316.9  | 64.9      | 0.2156E     | -1 0.3119E | 1 5.6283   | 113         |
| 6                     | 1313.3  | 65.5      | 0.2200E     | -1 0.3118E | 1 11.3478  | 138         |
| <b>HARDNESS</b>       |         |           |             |            |            |             |
| 1                     | 327.2   | 338.3     | 0.2237E     | 0 0.2430E  | 1 11.8750  | 80          |
| 2                     | 253.5   | 102.3     | 0.1415E     | 0 0.2379E  | 1 1.2647   | 68          |
| 3                     | 280.4   | 254.1     | 0.1782E     | 0 0.2396E  | 1 5.2791   | 86          |
| 4                     | 249.8   | 70.7      | 0.1259E     | 0 0.2380E  | 1 2.5263   | 95          |
| 5                     | 236.9   | 69.2      | 0.1315E     | 0 0.2355E  | 1 3.5306   | 98          |
| 6                     | 390.2   | 306.5     | 0.2368E     | 0 0.2514E  | 1 11.9551  | 89          |
| <b>SODIUM</b>         |         |           |             |            |            |             |
| 1                     | 158.7   | 12.6      | 0.3403E     | -1 0.2199E | 1 3.4815   | 108         |
| 2                     | 154.8   | 13.9      | 0.3757E     | -1 0.2188E | 1 4.3947   | 76          |
| 3                     | 154.1   | 10.7      | 0.2968E     | -1 0.2187E | 1 4.1505   | 93          |
| 4                     | 155.8   | 12.3      | 0.3364E     | -1 0.2191E | 1 6.8544   | 103         |
| 5                     | 154.1   | 11.2      | 0.3112E     | -1 0.2187E | 1 1.0962   | 104         |
| 6                     | 153.7   | 13.8      | 0.3650E     | -1 0.2185E | 1 8.0000   | 130         |

EOF..



REGRESSION ANALYSIS FOR SEP 3, 1980 TO FEB 28, 1981

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 2

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CHA NO. | SENSOR         | UNITS   | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|---------|----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/M | 0.1723   | 0.0040  | 0.1184         | 0.0560       | 56          |
| 2.      | VIALE BIOMASS  | MIL C/M | 0.0325   | -0.0041 | 0.0363         | 0.0360       | 57          |
| 3.      | RES CHLORINE   | MG/L    | 0.8776   | 0.1345  | 0.9308         | 0.2636       | 66          |
| 6.      | TURBIDITY-SIO2 | MG/L    | -2.2082  | 1.0335  | 5.5174         | 0.6500       | 73          |
| 7.      | DIS OXYGEN     | MG/L    | 2.1952   | 0.7251  | 0.7302         | 0.8255       | 73          |
| 10.     | AMMONIA        | MG/L    | -0.0645  | 1.0049  | 3.1423         | 0.9700       | 54          |
| 11.     | NITRATE        | MG/L    | 0.0000   | 0.0000  | 0.0000         | 0.0000       | 8           |
| 12.     | PH             | PH      | 6.3576   | 0.1949  | 0.9033         | 0.1181       | 73          |
| 13.     | TOT ORG CARBON | MG/L    | 2.8903   | 0.3952  | 1.7597         | 0.5354       | 64          |
| 14.     | CONDUCTIVITY   | MMHO/CM | 356.2761 | 0.7546  | 71.3212        | 0.4821       | 73          |
| 15.     | TEMPERATURE#1  | DEG F   | 33.7940  | 0.5293  | 1.0906         | 0.7552       | 73          |
| 16.     | HARDNESS       | MG/L    | 240.1200 | 0.0502  | 117.4959       | 0.1869       | 45          |
| 17.     | SODIUM         | MG/L    | 39.5770  | 0.7301  | 10.1351        | 0.6792       | 71          |
| 20.     | AMBIENT TEMP   | DEG F   | 15.9990  | 0.7821  | 0.9301         | 0.8237       | 81          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CHA NO. | SENSOR         | UNITS   | A0        | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|---------|-----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/M | 0.0739    | 0.0079  | -0.0170 | 0.1117         | 0.3352       |
| 2.      | VIALE BIOMASS  | MIL C/M | 0.0169    | 0.0620  | -0.0521 | 0.0356         | 0.1911       |
| 3.      | RES CHLORINE   | MG/L    | 0.2534    | 0.8820  | -0.0310 | 0.9092         | 0.3350       |
| 6.      | TURBIDITY-SIO2 | MG/L    | 12.6303   | -1.4599 | 0.0919  | 4.8211         | 0.7483       |
| 7.      | DIS OXYGEN     | MG/L    | 0.6462    | -0.7201 | 0.1113  | 0.6432         | 0.8677       |
| 10.     | AMMONIA        | MG/L    | -0.4301   | 0.8452  | 0.0034  | 3.1105         | 0.9706       |
| 11.     | NITRATE        | MG/L    | 0.0000    | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 12.     | PH             | PH      | -19.0378  | 0.4544  | -0.0305 | 0.8100         | 0.4549       |
| 13.     | TOT ORG CARBON | MG/L    | 3.4184    | 0.2907  | -0.0047 | 1.7582         | 0.3365       |
| 14.     | CONDUCTIVITY   | MMHO/CM | 2399.9630 | -2.5323 | 0.0013  | 71.1629        | 0.4856       |
| 15.     | TEMPERATURE#1  | DEG F   | -262.8664 | 0.3916  | -0.0519 | 0.5652         | 0.9423       |
| 16.     | HARDNESS       | MG/L    | 235.5657  | 0.0703  | -0.0000 | 117.4664       | 0.1863       |
| 17.     | SODIUM         | MG/L    | -340.0337 | 5.4264  | -0.0144 | 9.5244         | 0.7241       |
| 20.     | AMBIENT TEMP   | DEG F   | 190.9927  | -0.1842 | 0.0340  | 0.9283         | 0.8281       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CHA NO. | SENSOR         | UNITS   | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|---------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/M | -0.8367 | 0.0797 | 0.2437         | 0.2709       |
| 2.      | VIALE BIOMASS  | MIL C/M | -1.6619 | 0.0892 | 0.3423         | 0.2661       |
| 3.      | RES CHLORINE   | MG/L    | -0.1701 | 0.3057 | 0.3172         | 0.4284       |
| 6.      | TURBIDITY-SIO2 | MG/L    | 0.1226  | 0.7926 | 0.1491         | 0.7400       |
| 7.      | DIS OXYGEN     | MG/L    | 0.3537  | 0.5961 | 0.0523         | 0.7494       |
| 10.     | AMMONIA        | MG/L    | -0.1033 | 0.9115 | 0.2969         | 0.8906       |
| 11.     | NITRATE        | MG/L    | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 12.     | PH             | PH      | 0.7282  | 0.1867 | 0.0523         | 0.1305       |
| 13.     | TOT ORG CARBON | MG/L    | 0.1808  | 0.6448 | 0.1122         | 0.6093       |
| 14.     | CONDUCTIVITY   | MMHO/CM | 0.9678  | 0.6927 | 0.0221         | 0.4928       |
| 15.     | TEMPERATURE#1  | DEG F   | 0.7944  | 0.5714 | 0.0063         | 0.7774       |
| 16.     | HARDNESS       | MG/L    | 2.0835  | 0.1216 | 0.1540         | 0.2536       |
| 17.     | SODIUM         | MG/L    | 0.5145  | 0.7619 | 0.0262         | 0.7086       |
| 20.     | AMBIENT TEMP   | DEG F   | 0.0138  | 0.7782 | 0.0056         | 0.8227       |

ORIGINAL PAGE IS OF POOR QUALITY

REGRESSION ANALYSIS FOR SEP 3, 1980 TO FEB 28, 1981

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 3

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X$ )

| CHA NO. | SENSOR         | UNITS    | A0       | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|--------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.1074   | 0.3082 | 0.4913         | 0.5157       | 81          |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.0825   | 0.2571 | 0.2231         | 0.2947       | 82          |
| 3.      | RES CHLORINE   | MG/L     | 0.1698   | 0.1848 | 0.7693         | 0.3902       | 76          |
| 6.      | TURBIDITY-SIO2 | MG/L     | 5.7514   | 0.0331 | 3.9211         | 0.0431       | 98          |
| 7.      | DIS OXYGEN     | MG/L     | 2.3082   | 0.6901 | 1.0738         | 0.7532       | 97          |
| 10.     | AMMONIA        | MG/L     | -0.5690  | 1.0432 | 4.2268         | 0.9378       | 78          |
| 11.     | NITRATE        | MG/L     | 0.0000   | 0.0000 |                |              |             |
| 12.     | PH             | PH       | 4.1767   | 0.3283 | 0.7100         | 0.2069       | 98          |
| 13.     | TOT ORG CARBON | MG/L     | 0.4026   | 0.6978 | 2.3660         | 0.6033       | 78          |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 666.5134 | 0.5103 | 43.0356        | 0.5933       | 98          |
| 15.     | TEMPERATURE#1  | DEG F    | 27.0565  | 0.6194 | 1.1958         | 0.7961       | 97          |
| 16.     | HARDNESS       | MG/L     | 255.5196 | 0.0720 | 282.9058       | 0.0918       | 67          |
| 17.     | SODIUM         | MG/L     | 43.3488  | 0.7076 | 6.6464         | 0.7815       | 91          |
| 20.     | AMBIENT TEMP   | DEG F    | 2.9844   | 0.9613 | 0.6664         | 0.9281       | 100         |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CHA NO. | SENSOR         | UNITS    | A0        | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|-----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.1543    | 0.2442  | 0.0153  | 0.4510         | 0.5164       |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.1020    | 0.1678  | 0.0768  | 0.2229         | 0.2968       |
| 3.      | RES CHLORINE   | MG/L     | 1.0888    | -0.2138 | 0.0467  | 0.7436         | 0.4360       |
| 6.      | TURBIDITY-SIO2 | MG/L     | 1.1641    | 0.6788  | -0.0205 | 3.8867         | 0.1388       |
| 7.      | DIS OXYGEN     | MG/L     | 3.9930    | 0.0605  | 0.0532  | 1.0525         | 0.7444       |
| 10.     | AMMONIA        | MG/L     | 1.5910    | 0.1198  | 0.0195  | 3.5892         | 0.9355       |
| 11.     | NITRATE        | MG/L     | 0.0000    | 0.0000  | 0.0000  |                |              |
| 12.     | PH             | PH       | -9.6293   | 4.7598  | -0.3487 | 0.6752         | 0.3660       |
| 13.     | TOT ORG CARBON | MG/L     | 7.1888    | -0.5874 | 0.0574  | 2.2103         | 0.6641       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 2246.8800 | -2.0911 | 0.0011  | 42.3331        | 0.6108       |
| 15.     | TEMPERATURE#1  | DEG F    | -182.6000 | 6.3138  | -0.0386 | 0.8043         | 0.8941       |
| 16.     | HARDNESS       | MG/L     | 281.8149  | -0.0331 | 0.0000  | 282.6165       | 0.1022       |
| 17.     | SODIUM         | MG/L     | -119.2061 | 2.7285  | -0.0062 | 0.5421         | 0.7919       |
| 20.     | AMBIENT TEMP   | DEG F    | -119.5005 | 4.3275  | -0.0231 | 0.6600         | 0.9294       |

LOGARITHMIC CURVE FIT RESULTS ( $\text{LOG}(Y)=A_0 + A_1 \cdot \text{LOG}(X)$ )

| CHA NO. | SENSOR         | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | -0.4000 | 0.6161 | 0.2432         | 0.6550       |
| 2.      | VIABLE BIOMASS | MIL C/ML | -0.6220 | 0.5948 | 0.3591         | 0.6495       |
| 3.      | RES CHLORINE   | MG/L     | -0.3201 | 0.4808 | 0.2780         | 0.5462       |
| 6.      | TURBIDITY-SIO2 | MG/L     | 0.6655  | 0.0598 | 0.2139         | 0.2602       |
| 7.      | DIS OXYGEN     | MG/L     | 0.3620  | 0.5755 | 0.3077         | 0.7027       |
| 10.     | AMMONIA        | MG/L     | -0.0567 | 0.8090 | 0.3051         | 0.8464       |
| 11.     | NITRATE        | MG/L     | 0.0000  | 0.0000 |                |              |
| 12.     | PH             | PH       | 0.4911  | 0.3822 | 0.0454         | 0.2681       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0409  | 0.8111 | 0.1160         | 0.6418       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 1.7026  | 0.4561 | 0.0149         | 0.5573       |
| 15.     | TEMPERATURE#1  | DEG F    | 0.6382  | 0.6553 | 0.0071         | 0.8117       |
| 16.     | HARDNESS       | MG/L     | 1.8394  | 0.2224 | 0.1810         | 0.4058       |
| 17.     | SODIUM         | MG/L     | 0.5017  | 0.7318 | 0.0182         | 0.7093       |
| 20.     | AMBIENT TEMP   | DEG F    | 0.0917  | 0.9513 | 0.0039         | 0.9201       |

REGRESSION ANALYSIS FOR SEP 3, 1980 TO FEB 28, 1981

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 4

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CHA NO. | SENSOR         | UNITS    | A0       | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|--------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.2289   | 0.0955 | 0.2631         | 0.2326       | 90          |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.0613   | 0.1169 | 0.1411         | 0.2369       | 91          |
| 3.      | RES CHLORINE   | MG/L     | 0.2948   | 0.488  | 0.5000         | 0.8886       | 86          |
| 6.      | TURBIDITY-S102 | MG/L     | 1.7286   | 0.9310 | 1.9104         | 0.8173       | 107         |
| 7.      | DIS OXYGEN     | MG/L     | 2.6516   | 0.6935 | 1.0970         | 0.7501       | 107         |
| 10.     | AMMONIA        | MG/L     | -1.0612  | 1.0688 | 7.0770         | 0.8387       | 79          |
| 11.     | NITRATE        | MG/L     | 0.0000   | 0.0000 |                |              |             |
| 12.     | PH             | PH       | 2.7088   | 0.6300 | 0.7084         | 0.3870       | 108         |
| 13.     | TOT OPS CARBON | MG/L     | 1.7679   | 0.9133 | 1.5220         | 0.8404       | 89          |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 699.6009 | 0.8897 | 51.1053        | 0.5160       | 108         |
| 15.     | TEMPERATURE#1  | DEG F    | 25.5023  | 0.6406 | 1.2035         | 0.7918       | 106         |
| 16.     | HARDNESS       | MG/L     | 219.3953 | 0.0902 | 63.4912        | 0.8557       | 69          |
| 17.     | SODIUM         | MG/L     | 38.9676  | 0.7655 | 8.2940         | 0.7853       | 181         |
| 20.     | AMBIENT TEMP   | DEG F    | 14.1213  | 0.8103 | 0.8903         | 0.8466       | 116         |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CHA NO. | SENSOR         | UNITS    | A0        | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|-----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.0917    | 0.1866  | -0.0293 | 0.2581         | 0.3003       |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.0484    | 0.1052  | -0.0534 | 0.1409         | 0.2412       |
| 3.      | RES CHLORINE   | MG/L     | -0.2026   | 0.3944  | -0.0250 | 0.5589         | 0.5069       |
| 6.      | TURBIDITY-S102 | MG/L     | -0.2582   | 0.8368  | -0.0103 | 1.8039         | 0.8228       |
| 7.      | DIS OXYGEN     | MG/L     | 8.9208    | -0.1498 | 0.0718  | 1.0188         | 0.7705       |
| 10.     | AMMONIA        | MG/L     | 1.2918    | -0.7329 | 0.0383  | 3.9875         | 0.8475       |
| 11.     | NITRATE        | MG/L     | 0.0000    | 0.0000  | 0.0000  |                |              |
| 12.     | PH             | PH       | -0.2027   | 3.5043  | -0.2203 | 0.4910         | 0.3270       |
| 13.     | TOT OPS CARBON | MG/L     | 8.5195    | -0.0136 | 0.0238  | 1.4682         | 0.6608       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 1428.3480 | -0.4975 | 0.0005  | 51.0433        | 0.5194       |
| 15.     | TEMPERATURE#1  | DEG F    | -176.7576 | 6.1265  | -0.0371 | 0.9589         | 0.8734       |
| 16.     | HARDNESS       | MG/L     | 187.7379  | 0.2057  | -0.0009 | 61.9286        | 0.4962       |
| 17.     | SODIUM         | MG/L     | -138.2183 | 2.8652  | -0.0065 | 8.1327         | 0.7540       |
| 20.     | AMBIENT TEMP   | DEG F    | 18.3300   | 0.6984  | 0.0008  | 0.8903         | 0.8466       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CHA NO. | SENSOR         | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | -0.6539 | 0.3462 | 0.2011         | 0.4935       |
| 2.      | VIABLE BIOMASS | MIL C/ML | -0.9346 | 0.3328 | 0.4103         | 0.6186       |
| 3.      | RES CHLORINE   | MG/L     | -0.5263 | 0.6540 | 0.2941         | 0.5732       |
| 6.      | TURBIDITY-S102 | MG/L     | -0.0266 | 0.0589 | 0.0901         | 0.8639       |
| 7.      | DIS OXYGEN     | MG/L     | 0.4226  | 0.5289 | 0.6658         | 0.7553       |
| 10.     | AMMONIA        | MG/L     | -0.0558 | 0.7367 | 0.3800         | 0.8317       |
| 11.     | NITRATE        | MG/L     | 0.0000  | 0.0000 |                |              |
| 12.     | PH             | PH       | 0.3204  | 0.6152 | 0.0484         | 0.4272       |
| 13.     | TOT OPS CARBON | MG/L     | 0.0768  | 0.7590 | 0.0948         | 0.6781       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 1.7960  | 0.4267 | 0.0171         | 0.0007       |
| 15.     | TEMPERATURE#1  | DEG F    | 0.6126  | 0.4698 | 0.0071         | 0.7981       |
| 16.     | HARDNESS       | MG/L     | 1.7997  | 0.2305 | 0.1136         | 0.4606       |
| 17.     | SODIUM         | MG/L     | 0.8762  | 0.7804 | 0.0221         | 0.7545       |
| 20.     | AMBIENT TEMP   | DEG F    | 0.3091  | 0.7920 | 0.0053         | 0.8295       |

REGRESSION ANALYSIS FOR SEP 3, 1980 TO FEB 20, 1981

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 5

LINEAR CURVE FIT RESULTS (Y=AO + A1X)

| CHA NO. | SENSOR           | UNITS    | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|------------------|----------|----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS    | MIL C/ML | 0.1675   | 0.4533  | 0.1941         | 0.2962       | 90          |
| 2.      | VARIABLE BIOMASS | MIL C/ML | 0.0222   | 0.1532  | 0.1317         | 0.3301       | 90          |
| 3.      | RES CHLORINE     | MG/L     | 0.3041   | -0.4201 | 0.3044         | 0.1255       | 85          |
| 6.      | TURBIDITY-SIO2   | MG/L     | 3.3916   | 0.1374  | 2.3541         | 0.3244       | 107         |
| 7.      | DIS OXYGEN       | MG/L     | 3.0600   | 0.3335  | 1.0376         | 0.6044       | 107         |
| 10.     | AMMONIA          | MG/L     | -1.2794  | 0.9814  | 0.2949         | 0.6448       | 79          |
| 12.     | PH               | PH       | 2.2445   | 0.7867  | 0.4847         | 0.5545       | 107         |
| 13.     | TOT ORG CARBON   | MG/L     | 1.1331   | 0.2999  | 1.4431         | 0.4383       | 87          |
| 14.     | CONDUCTIVITY     | MMHNS/CM | 721.9695 | 0.4875  | 54.1112        | 0.4921       | 107         |
| 16.     | HARDNESS         | MG/L     | 217.8330 | 0.6665  | 65.1014        | 0.3495       | 70          |
| 17.     | SODIUM           | MG/L     | 43.7500  | 0.7005  | 7.2635         | 0.7609       | 101         |

PARABOLIC CURVE FIT RESULTS (Y=AO + A1X + A2X^2)

| CHA NO. | SENSOR           | UNITS    | A0        | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|------------------|----------|-----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS    | MIL C/ML | 0.0034    | 0.1307  | -0.0145 | 0.1912         | 0.3307       |
| 2.      | VARIABLE BIOMASS | MIL C/ML | 0.0202    | 0.1449  | 0.0069  | 0.1317         | 0.3302       |
| 3.      | RES CHLORINE     | MG/L     | 0.6911    | -0.1866 | 0.0169  | 0.3648         | 0.2904       |
| 6.      | TURBIDITY-SIO2   | MG/L     | 2.3653    | 0.2942  | -0.0093 | 2.3522         | 0.3311       |
| 7.      | DIS OXYGEN       | MG/L     | 4.4187    | 0.3274  | 0.0430  | 1.0236         | 0.6779       |
| 10.     | AMMONIA          | MG/L     | 2.7493    | -0.0475 | 0.0352  | 4.7852         | 0.9254       |
| 12.     | PH               | PH       | -5.3227   | 3.1305  | -0.1916 | 0.4716         | 0.5934       |
| 13.     | TOT ORG CARBON   | MG/L     | 0.0240    | -0.9603 | 0.0540  | 1.2990         | 0.5877       |
| 14.     | CONDUCTIVITY     | MMHNS/CM | 1841.6546 | -1.3538 | 0.0008  | 53.8423        | 0.5027       |
| 16.     | HARDNESS         | MG/L     | 200.0233  | 0.1410  | -0.0000 | 64.4771        | 0.3690       |
| 17.     | SODIUM           | MG/L     | -207.1006 | 3.8175  | -0.0096 | 0.9521         | 0.7838       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=AO + A1\*LOG(X))

| CHA NO. | SENSOR           | UNITS    | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|------------------|----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS    | MIL C/ML | -0.7105 | 0.3331  | 0.2373         | 0.4927       |
| 2.      | VARIABLE BIOMASS | MIL C/ML | -1.0431 | 0.4475  | 0.4208         | 0.6052       |
| 3.      | RES CHLORINE     | MG/L     | -0.6931 | -0.2696 | 0.2970         | 0.6134       |
| 6.      | TURBIDITY-SIO2   | MG/L     | 0.3123  | 0.3427  | 0.1426         | 0.2195       |
| 7.      | DIS OXYGEN       | MG/L     | 0.4464  | 0.4497  | 0.0727         | 0.6451       |
| 10.     | AMMONIA          | MG/L     | -0.2108 | 0.7820  | 0.4439         | 0.8295       |
| 12.     | PH               | PH       | 0.2705  | 0.6908  | 0.0310         | 0.5951       |
| 13.     | TOT ORG CARBON   | MG/L     | 0.1944  | 0.3960  | 0.1383         | 0.3149       |
| 14.     | CONDUCTIVITY     | MMHNS/CM | 1.8547  | 0.4095  | 0.0179         | 0.4521       |
| 16.     | HARDNESS         | MG/L     | 1.9335  | 0.1754  | 0.1201         | 0.3200       |
| 17.     | SODIUM           | MG/L     | 0.5796  | 0.7318  | 0.0197         | 0.7759       |

REGRESSION ANALYSIS FOR SEP 3, 1960 TO FEB 28, 1961

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 6

LINEAR CURVE FIT RESULTS ( $Y_{AB} = A_1X$ )

| CHA NO. | SENSOR         | UNITS    | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.2141   | 0.6488  | 0.4033         | 0.1124       | 92          |
| 2.      | VIALB BIOMASS  | MIL C/ML | 0.1577   | -0.0368 | 0.3941         | 0.0291       | 93          |
| 3.      | RES CHLORINE   | MG/L     | 1.7591   | 0.0312  | 1.0366         | 0.1402       | 87          |
| 6.      | TURBIDITY-SIG2 | MG/L     | 2.4161   | 0.0015  | 1.4009         | 0.1627       | 100         |
| 7.      | DIS OXYGEN     | MG/L     | 2.6872   | 0.5467  | 1.1001         | 0.6637       | 100         |
| 10.     | AMMONIA        | MG/L     | -1.0720  | 1.0150  | 0.6096         | 0.0966       | 75          |
| 11.     | NITRATE        | MG/L     | 0.0000   | 0.0000  | 0.0000         | 0.0000       | 0           |
| 12.     | PH             | PH       | 0.0057   | 0.3535  | 0.4403         | 0.3327       | 110         |
| 13.     | TOT ORG CARBON | MG/L     | 1.9030   | 0.2310  | 1.3211         | 0.3777       | 87          |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 351.0430 | 0.5216  | 50.2356        | 0.7551       | 110         |
| 15.     | TEMPERATURE#1  | DEG F    | 30.3830  | 0.5749  | 1.1896         | 0.7664       | 100         |
| 16.     | HARDNESS       | MG/L     | 175.3407 | 0.6246  | 230.5027       | 0.7105       | 56          |
| 17.     | SODIUM         | MG/L     | 89.4001  | 0.6436  | 0.4051         | 0.5913       | 104         |
| 20.     | AMBIENT TEMP   | DEG F    | 20.7091  | 0.7181  | 1.0066         | 7.7813       | 119         |

PARABOLIC CURVE FIT RESULTS ( $Y_{AB} = A_1X + A_2X^2$ )

| CHA NO. | SENSOR         | UNITS    | A0         | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|------------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.1043     | 0.1523  | -0.0216 | 0.4032         | 0.1547       |
| 2.      | VIALB BIOMASS  | MIL C/ML | 0.1501     | -0.0222 | -0.0113 | 0.3941         | 0.0294       |
| 3.      | RES CHLORINE   | MG/L     | 1.2779     | 0.2694  | -0.0262 | 1.0254         | 0.2019       |
| 6.      | TURBIDITY-SIG2 | MG/L     | 2.1270     | 0.3504  | -0.0117 | 1.4007         | 0.2923       |
| 7.      | DIS OXYGEN     | MG/L     | 0.2640     | -0.0540 | 0.0517  | 1.0877         | 0.6769       |
| 10.     | AMMONIA        | MG/L     | -0.2878    | 0.6453  | 0.0000  | 4.5438         | 0.5963       |
| 11.     | NITRATE        | MG/L     | 0.0000     | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 12.     | PH             | PH       | -0.6666    | 4.0506  | -0.3339 | 0.4266         | 0.5166       |
| 13.     | TOT ORG CARBON | MG/L     | 7.3316     | -0.8361 | 0.0056  | 1.2102         | 0.5297       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | -3142.5410 | 6.6745  | -0.0025 | 53.3050        | 0.6314       |
| 15.     | TEMPERATURE#1  | DEG F    | -129.0141  | 4.9116  | -0.0290 | 1.0343         | 0.4310       |
| 16.     | HARDNESS       | MG/L     | -37.9160   | 1.5048  | -0.0004 | 200.3962       | 0.7941       |
| 17.     | SODIUM         | MG/L     | -279.7527  | 4.7522  | -0.0126 | 0.0100         | 0.7297       |
| 20.     | AMBIENT TEMP   | DEG F    | 151.2025   | -2.0750 | 0.0247  | 1.0012         | 0.7037       |

LOGARITHMIC CURVE FIT RESULTS ( $\log(Y)_{AB} = A_1 \log(X)$ )

| CHA NO. | SENSOR         | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | -0.6096 | 0.2020 | 0.2500         | 0.4833       |
| 2.      | VIALB BIOMASS  | MIL C/ML | -1.0000 | 0.3956 | 0.3047         | 0.6575       |
| 3.      | RES CHLORINE   | MG/L     | 0.0676  | 0.2346 | 0.2036         | 0.3904       |
| 6.      | TURBIDITY-SIG2 | MG/L     | 0.4968  | 0.1155 | 0.1314         | 0.3047       |
| 7.      | DIS OXYGEN     | MG/L     | 0.4108  | 0.4061 | 0.0240         | 0.6431       |
| 10.     | AMMONIA        | MG/L     | -0.1638 | 0.0047 | 0.3558         | 0.0603       |
| 11.     | NITRATE        | MG/L     | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 12.     | PH             | PH       | 0.0067  | 0.3927 | 0.0308         | 0.3030       |
| 13.     | TOT ORG CARBON | MG/L     | 0.2524  | 0.3075 | 0.1325         | 0.2500       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 1.3140  | 0.5030 | 0.0100         | 0.3650       |
| 15.     | TEMPERATURE#1  | DEG F    | 0.7571  | 0.5917 | 0.0071         | 0.7642       |
| 16.     | HARDNESS       | MG/L     | 0.9152  | 0.0520 | 0.1424         | 0.6922       |
| 17.     | SODIUM         | MG/L     | 0.6303  | 0.7003 | 0.0234         | 0.7036       |
| 20.     | AMBIENT TEMP   | DEG F    | 0.5000  | 0.6000 | 0.0060         | 0.7610       |

REGRESSION ANALYSIS FOR SEP 3, 1980 TO FEB 28, 1981

FROM SAMPLE SOURCE 2 TO SAMPLE SOURCE 3

LINEAR CURVE FIT RESULTS (Y=A0 + A1X)

| CHA NO. | SENSOR           | UNITS    | A0        | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|------------------|----------|-----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS    | MIL C/ML | 0.0747    | 2.5795  | 0.2910         | 0.7426       | 67          |
| 2.      | VARIABLE BIOMASS | MIL C/ML | 0.1743    | -0.9792 | 0.2628         | 0.1437       | 68          |
| 3.      | RES CHLORINE     | MG/L     | 0.2978    | 0.5895  | 0.6600         | 0.6591       | 55          |
| 6.      | TURBIDITY-SI02   | MG/L     | 3.3510    | -0.1294 | 3.6318         | 0.2960       | 63          |
| 7.      | DIS OXYGEN       | MG/L     | 0.3504    | 0.9243  | 1.0272         | 0.7760       | 63          |
| 10.     | AMMONIA          | MG/L     | 0.8076    | 0.9618  | 0.6715         | 0.8950       | 67          |
| 11.     | NITRATE          | MG/L     | 0.0000    | 0.0000  | 0.0000         | 0.0000       | 8           |
| 12.     | PH               | PH       | 3.6599    | 0.2072  | 0.4502         | 0.6054       | 63          |
| 13.     | TOT ORG CARBON   | MG/L     | 2.3437    | 0.7249  | 2.9059         | 0.4638       | 55          |
| 14.     | CONDUCTIVITY     | MMHMO/CM | 215.7639  | 0.3488  | 33.4419        | 0.7859       | 63          |
| 15.     | TEMPERATURE      | DEG F    | 2.7849    | 0.9414  | 0.5330         | 0.9575       | 63          |
| 16.     | HARDNESS         | MG/L     | -280.1863 | 2.3370  | 170.3198       | 0.8351       | 55          |
| 17.     | SODIUM           | MG/L     | 15.3045   | 0.9017  | 0.3892         | 0.9150       | 61          |
| 20.     | AMBIENT TEMP     | DEG F    | 7.6624    | 0.8982  | 0.8972         | 0.8596       | 71          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1X + A2X^2)

| CHA NO. | SENSOR           | UNITS    | A0         | A1      | A2       | STANDARD ERROR | CORR. COEFF. |
|---------|------------------|----------|------------|---------|----------|----------------|--------------|
| 1.      | TOTAL BIOMASS    | MIL C/ML | 0.1139     | 2.1929  | -0.6771  | 0.2908         | 0.7429       |
| 2.      | VARIABLE BIOMASS | MIL C/ML | 0.1024     | 5.2319  | -27.1097 | 0.2502         | 0.2271       |
| 3.      | RES CHLORINE     | MG/L     | -0.3583    | 1.2781  | -0.2572  | 0.6015         | 0.7282       |
| 6.      | TURBIDITY-SI02   | MG/L     | 4.2327     | 0.2798  | -0.0029  | 3.6186         | 0.3070       |
| 7.      | DIS OXYGEN       | MG/L     | -1.5239    | 1.4663  | -0.0376  | 1.0223         | 0.7793       |
| 10.     | AMMONIA          | MG/L     | -0.7458    | 1.7595  | -0.0152  | 0.4574         | 0.9020       |
| 11.     | NITRATE          | MG/L     | 0.0000     | 0.0000  | 0.0000   | 0.0000         | 0.0000       |
| 12.     | PH               | PH       | 15.7422    | -2.9827 | 0.2186   | 0.4241         | 0.6692       |
| 13.     | TOT ORG CARBON   | MG/L     | -0.0182    | 1.4642  | -0.0265  | 2.9541         | 0.5062       |
| 14.     | CONDUCTIVITY     | MMHMO/CM | -6484.1210 | 11.3550 | -3.0041  | 29.2025        | 0.8410       |
| 15.     | TEMPERATURE      | DEG F    | -44.9141   | 2.2907  | -0.0093  | 0.5330         | 0.9576       |
| 16.     | HARDNESS         | MG/L     | 887.8701   | -1.9128 | 0.3050   | 30.0167        | 0.9625       |
| 17.     | SODIUM           | MG/L     | -93.8915   | 2.2998  | -0.0044  | 4.3402         | 0.9178       |
| 20.     | AMBIENT TEMP     | DEG F    | -429.6624  | 12.8040 | -0.0818  | 0.8435         | 0.8771       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CHA NO. | SENSOR           | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|------------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS    | MIL C/ML | 0.2982  | 0.8082 | 0.2091         | 0.7557       |
| 2.      | VARIABLE BIOMASS | MIL C/ML | 0.0501  | 0.5793 | 0.4050         | 0.6096       |
| 3.      | RES CHLORINE     | MG/L     | -0.1108 | 0.8066 | 0.1657         | 0.8629       |
| 6.      | TURBIDITY-SI02   | MG/L     | 0.5280  | 0.2491 | 0.2099         | 0.2371       |
| 7.      | DIS OXYGEN       | MG/L     | -0.0155 | 1.0028 | 0.4545         | 0.9504       |
| 10.     | AMMONIA          | MG/L     | 0.0756  | 0.9101 | 0.2357         | 0.9293       |
| 11.     | NITRATE          | MG/L     | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 12.     | PH               | PH       | 0.4704  | 0.3349 | 0.0314         | 0.6353       |
| 13.     | TOT ORG CARBON   | MG/L     | 0.2048  | 0.7414 | 0.1308         | 0.8461       |
| 14.     | CONDUCTIVITY     | MMHMO/CM | 0.0502  | 0.8975 | 0.0113         | 0.7908       |
| 15.     | TEMPERATURE      | DEG F    | 0.0755  | 0.9594 | 0.0032         | 0.9540       |
| 16.     | HARDNESS         | MG/L     | 0.1491  | 0.9613 | 0.1258         | 0.7602       |
| 17.     | SODIUM           | MG/L     | 0.2142  | 0.9028 | 0.0121         | 0.9166       |
| 20.     | AMBIENT TEMP     | DEG F    | 0.2052  | 0.8966 | 0.0057         | 0.9556       |

REGRESSION ANALYSIS FOR SEP 3, 1980 TO FEB 20, 1981

FROM SAMPLE SOURCE 3 TO SAMPLE SOURCE 4

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CHA NO. | SENSOR         | UNITS    | A0       | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|--------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.1401   | 0.2948 | 0.2301         | 0.5595       | 81          |
| 2.      | VIALE BIOMASS  | MIL C/ML | 0.0789   | 0.2250 | 0.1802         | 0.3509       | 82          |
| 5.      | RES CHLORINE   | MG/L     | 0.1965   | 0.6753 | 0.3823         | 0.8532       | 76          |
| 6.      | TURBIDITY-SIO2 | MG/L     | 9.0953   | 0.0885 | 3.2310         | 0.1500       | 97          |
| 7.      | DIS OXYGEN     | MG/L     | 1.2560   | 0.8644 | 0.8901         | 0.8447       | 98          |
| 10.     | AMMONIA        | MG/L     | -0.5591  | 1.0620 | 5.8978         | 0.9199       | 74          |
| 11.     | NITRATE        | MG/L     | 0.0000   | 0.0000 |                |              |             |
| 12.     | PH             | PH       | 0.8308   | 0.9010 | 0.3208         | 0.8981       | 98          |
| 13.     | TOT ORG CARBON | MG/L     | 3.0604   | 0.5192 | 1.3880         | 0.7449       | 78          |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 131.9837 | 0.4020 | 15.6250        | 0.9506       | 98          |
| 15.     | TEMPERATURE#1  | DEG F    | 0.1711   | 0.9957 | 0.6897         | 0.9363       | 96          |
| 16.     | HARDNESS       | MG/L     | 238.7607 | 0.0360 | 69.1733        | 0.1492       | 84          |
| 17.     | SODIUM         | MG/L     | 18.6446  | 0.8745 | 4.6400         | 0.8986       | 91          |
| 20.     | AMBIENT TEMP   | DEG F    | 5.8045   | 0.9204 | 0.5308         | 0.9548       | 107         |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CHA NO. | SENSOR         | UNITS    | A0        | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|-----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | -0.0272   | 0.7485  | -0.1887 | 0.2128         | 0.6419       |
| 2.      | VIALE BIOMASS  | MIL C/ML | 0.0396    | 0.5230  | -0.2498 | 0.1361         | 0.4161       |
| 5.      | RES CHLORINE   | MG/L     | -0.2546   | 1.4231  | -0.1941 | 0.2329         | 0.9329       |
| 6.      | TURBIDITY-SIO2 | MG/L     | 10.8727   | -0.3025 | 0.0195  | 3.2085         | 0.1899       |
| 7.      | DIS OXYGEN     | MG/L     | -3.6401   | 2.3235  | -0.1025 | 0.7762         | 0.8844       |
| 10.     | AMMONIA        | MG/L     | 2.1283    | -0.1897 | 0.0217  | 3.2457         | 0.9728       |
| 11.     | NITRATE        | MG/L     | 0.0000    | 0.0000  | 0.0000  |                |              |
| 12.     | PH             | PH       | 1.3449    | 0.7472  | 0.0112  | 0.3206         | 0.8982       |
| 13.     | TOT ORG CARBON | MG/L     | 0.6953    | 1.0383  | -0.0228 | 1.3872         | 0.7750       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 1482.9480 | -1.2193 | 0.0008  | 15.1171        | 0.9534       |
| 15.     | TEMPERATURE#1  | DEG F    | 0.0165    | 0.8315  | 0.0012  | 0.6897         | 0.9363       |
| 16.     | HARDNESS       | MG/L     | 18.6446   | 0.9675  | -0.0004 | 35.7406        | 0.8506       |
| 17.     | SODIUM         | MG/L     | 171.4216  | -1.0727 | 0.0062  | 4.6101         | 0.9019       |
| 20.     | AMBIENT TEMP   | DEG F    | -210.5481 | 0.8493  | -0.0406 | 0.5010         | 0.9683       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CHA NO. | SENSOR         | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | -0.3797 | 0.6713 | 0.1818         | 0.7768       |
| 2.      | VIALE BIOMASS  | MIL C/ML | -0.5688 | 0.6598 | 0.1627         | 0.7092       |
| 5.      | RES CHLORINE   | MG/L     | -0.0791 | 0.9990 | 0.1328         | 0.9196       |
| 6.      | TURBIDITY-SIO2 | MG/L     | 0.9073  | 0.0711 | 0.1440         | 0.1183       |
| 7.      | DIS OXYGEN     | MG/L     | 0.1361  | 0.8608 | 0.0475         | 0.8905       |
| 10.     | AMMONIA        | MG/L     | -0.0088 | 0.8716 | 0.2734         | 0.9251       |
| 11.     | NITRATE        | MG/L     | 0.0000  | 0.0000 |                |              |
| 12.     | PH             | PH       | 0.1149  | 0.4734 | 0.0215         | 0.8872       |
| 13.     | TOT ORG CARBON | MG/L     | 0.2068  | 0.7388 | 0.0715         | 0.8440       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 0.3673  | 0.8825 | 0.0058         | 0.9415       |
| 15.     | TEMPERATURE#1  | DEG F    | 0.0224  | 0.9875 | 0.0645         | 0.9248       |
| 16.     | HARDNESS       | MG/L     | 1.3800  | 0.4127 | 0.1022         | 0.5965       |
| 17.     | SODIUM         | MG/L     | 0.2721  | 0.4751 | 0.0134         | 0.8941       |
| 20.     | AMBIENT TEMP   | DEG F    | 0.1749  | 0.4063 | 0.0631         | 0.9375       |

ORIGINAL PAGE IS  
OF FOUR QUALITY

## REGRESSION ANALYSIS FOR SEP 3, 1980 TO PER 28, 1981

FROM SAMPLE SOURCE 4 TO SAMPLE SOURCE 5

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1X$ )

| CHA NO. | SENSOR         | UNITS    | A0       | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|--------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.0911   | 0.3343 | 0.1281         | 0.7498       | 89          |
| 2.      | VIALE BIOMASS  | MIL C/ML | 0.9369   | 0.5051 | 0.1087         | 0.5929       | 89          |
| 3.      | RES CHLORINE   | MG/L     | 0.2585   | 0.0041 | 0.3883         | 0.0791       | 88          |
| 6.      | TURBIDITY-S102 | MG/L     | 2.4321   | 0.3472 | 3.8024         | 0.2900       | 107         |
| 7.      | DIS OXYGEN     | MG/L     | 1.0374   | 0.7629 | 0.4953         | 0.8767       | 107         |
| 10.     | AMMONIA        | MG/L     | 0.4435   | 0.7359 | 6.8488         | 0.8358       | 72          |
| 12.     | PH             | PH       | 2.4510   | 0.1987 | 0.3718         | 0.7782       | 107         |
| 13.     | TOT ORG CARBON | MG/L     | 0.7118   | 0.4972 | 1.2986         | 0.5660       | 86          |
| 18.     | CONDUCTIVITY   | MMHO/CM  | 136.3491 | 0.9077 | 32.7114        | 0.8583       | 107         |
| 15.     | TEMPERATURE    | DEG F    | 7.1073   | 0.8805 | 1.1601         | 0.8282       | 105         |
| 16.     | HARDNESS       | MG/L     | 51.0987  | 0.7309 | 45.7176        | 0.7412       | 89          |
| 17.     | SODIUM         | MG/L     | 21.4730  | 0.8508 | 4.2222         | 0.9269       | 101         |
| 20.     | AMBIENT TEMP   | DEG F    | 2.3121   | 0.9667 | 0.4370         | 0.9691       | 118         |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1X + A_2X^2$ )

| CHA NO. | SENSOR         | UNITS    | A0        | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|-----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | -0.0308   | 1.1515  | -0.4489 | 0.1180         | 0.8229       |
| 2.      | VIALE BIOMASS  | MIL C/ML | 0.0010    | 1.0360  | -0.8410 | 0.0958         | 0.6430       |
| 3.      | RES CHLORINE   | MG/L     | 0.2660    | -0.0147 | 0.0077  | 0.3482         | 0.0796       |
| 6.      | TURBIDITY-S102 | MG/L     | 1.2510    | 0.6289  | -0.0188 | 3.7976         | 0.2904       |
| 7.      | DIS OXYGEN     | MG/L     | -1.7095   | 1.5824  | -0.0524 | 0.6255         | 0.8804       |
| 10.     | AMMONIA        | MG/L     | 0.1697    | 0.8671  | -0.0016 | 6.8307         | 0.8365       |
| 12.     | PH             | PH       | 2.9088    | 0.4548  | 0.0046  | 0.3718         | 0.7784       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0566    | 0.6602  | -0.0002 | 1.2966         | 0.5877       |
| 18.     | CONDUCTIVITY   | MMHO/CM  | 1232.6410 | -0.7736 | 0.0006  | 32.5023        | 0.8603       |
| 15.     | TEMPERATURE    | DEG F    | 108.0780  | -1.9256 | 0.0196  | 1.1579         | 0.8291       |
| 16.     | HARDNESS       | MG/L     | 109.8118  | 0.3301  | 0.0008  | 45.4899        | 0.7482       |
| 17.     | SODIUM         | MG/L     | -161.6827 | 3.1419  | -0.0071 | 3.9950         | 0.9348       |
| 20.     | AMBIENT TEMP   | DEG F    | -158.3120 | 5.2545  | -0.0245 | 0.4180         | 0.9717       |

LOGARITHMIC CURVE FIT RESULTS ( $\log(Y)=A_0 + A_1 \log(X)$ )

| CHA NO. | SENSOR         | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | -0.2106 | 0.7608 | 0.1333         | 0.8684       |
| 2.      | VIALE BIOMASS  | MIL C/ML | -0.4260 | 0.7177 | 0.3887         | 0.8082       |
| 3.      | RES CHLORINE   | MG/L     | -0.7409 | 0.0840 | 0.3033         | 0.5715       |
| 6.      | TURBIDITY-S102 | MG/L     | 0.2450  | 0.4910 | 0.1583         | 0.5502       |
| 7.      | DIS OXYGEN     | MG/L     | 0.0737  | 0.8682 | 0.0438         | 0.8900       |
| 10.     | AMMONIA        | MG/L     | -0.1882 | 0.9708 | 0.3589         | 0.8927       |
| 12.     | PH             | PH       | 0.3071  | 0.6091 | 0.0246         | 0.7764       |
| 13.     | TOT ORG CARBON | MG/L     | -0.0300 | 0.7636 | 0.1168         | 0.5953       |
| 18.     | CONDUCTIVITY   | MMHO/CM  | 0.3201  | 0.8989 | 6.0110         | 0.8587       |
| 15.     | TEMPERATURE    | DEG F    | 0.2280  | 0.8818 | 0.0849         | 0.8281       |
| 16.     | HARDNESS       | MG/L     | 0.5401  | 0.7601 | 0.0907         | 0.7226       |
| 17.     | SODIUM         | MG/L     | 0.2759  | 0.8719 | 0.0115         | 0.9291       |
| 20.     | AMBIENT TEMP   | DEG F    | 0.0720  | 0.9610 | 0.0026         | 0.9596       |



REGRESSION ANALYSIS FOR SEP 3, 1980 TO FEB 20, 1981

FROM SAMPLE SOURCE 5 TO SAMPLE SOURCE 6

LINEAR CURVE FIT RESULTS (Y=A0 + A1X)

| CHA NO. | SENSOR         | UNITS    | A0        | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|-----------|--------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.16      | 0.4320 | 0.3034         | 0.2264       | 64          |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.1074    | 0.2506 | 0.3941         | 0.0890       | 92          |
| 3.      | RES CHLORINE   | MG/L     | 1.9232    | 0.0299 | 1.0713         | 0.9277       | 89          |
| 4.      | TURBIDITY-SIG2 | MG/L     | 3.4339    | 0.1791 | 1.3404         | 0.4829       | 110         |
| 7.      | DIS OXYGEN     | MG/L     | 0.1704    | 0.9252 | 0.7030         | 0.8778       | 111         |
| 10.     | AMMONIA        | MG/L     | -0.3298   | 1.4023 | 2.4784         | 0.9740       | 67          |
| 11.     | NITRATE        | MG/L     | 0.0000    | 0.0000 | 0.0000         | 0.0000       | 0           |
| 12.     | PH             | PH       | 1.0044    | 0.7479 | 0.2750         | 0.8554       | 112         |
| 13.     | TOT ORG CARBON | MG/L     | 1.7470    | 0.9823 | 1.1044         | 0.5664       | 89          |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 143.0043  | 0.8904 | 38.1038        | 0.8204       | 112         |
| 16.     | HARDNESS       | MG/L     | -220.7514 | 2.6320 | 242.0330       | 0.5677       | 64          |
| 17.     | SODIUM         | MG/L     | 20.1280   | 0.9481 | 6.5169         | 0.8301       | 104         |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1X + A2X^2)

| CHA NO. | SENSOR         | UNITS    | A0        | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|-----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.0757    | 1.0230  | -0.5091 | 0.3020         | 0.2405       |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.0659    | 1.0403  | -1.3744 | 0.3023         | 0.1296       |
| 3.      | RES CHLORINE   | MG/L     | 2.0543    | -0.6497 | 0.3356  | 1.0694         | 0.0823       |
| 4.      | TURBIDITY-SIG2 | MG/L     | 2.4222    | 0.3713  | -0.0059 | 1.3364         | 0.5195       |
| 7.      | DIS OXYGEN     | MG/L     | 0.0000    | 0.9764  | -0.0034 | 0.7020         | 0.8778       |
| 10.     | AMMONIA        | MG/L     | -0.3175   | 1.5220  | -0.0029 | 2.4423         | 0.9743       |
| 11.     | NITRATE        | MG/L     | 0.0000    | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 12.     | PH             | PH       | 4.8220    | -0.2802 | 0.0763  | 0.2719         | 0.8554       |
| 13.     | TOT ORG CARBON | MG/L     | 1.2144    | 0.7123  | -0.0170 | 1.1793         | 0.5722       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 3303.6240 | -3.9109 | 0.0018  | 34.4031        | 0.8444       |
| 16.     | HARDNESS       | MG/L     | 78.9370   | -0.1214 | 0.0175  | 233.4413       | 0.6748       |
| 17.     | SODIUM         | MG/L     | 29.5108   | 0.7481  | 0.0004  | 6.5164         | 0.8301       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CHA NO. | SENSOR         | UNITS    | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | -0.2602 | 0.6149  | 0.2082         | 0.7095       |
| 2.      | VIABLE BIOMASS | MIL C/ML | -0.4511 | 0.5756  | 0.3203         | 0.7062       |
| 3.      | RES CHLORINE   | MG/L     | 0.1418  | -0.1023 | 0.2456         | 0.3104       |
| 4.      | TURBIDITY-SIG2 | MG/L     | 0.3059  | 0.4530  | 0.1045         | 0.6490       |
| 7.      | DIS OXYGEN     | MG/L     | -0.0124 | 0.9250  | 0.0501         | 0.8594       |
| 10.     | AMMONIA        | MG/L     | 0.0757  | 0.7944  | 0.5201         | 0.8872       |
| 11.     | NITRATE        | MG/L     | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 12.     | PH             | PH       | 0.1822  | 0.7559  | 0.0144         | 0.8532       |
| 13.     | TOT ORG CARBON | MG/L     | 0.2019  | 0.6048  | 0.1453         | 0.6440       |
| 14.     | CONDUCTIVITY   | MMHMO/CM | 0.3759  | 0.8793  | 0.0140         | 0.7946       |
| 16.     | HARDNESS       | MG/L     | 0.3415  | 0.9248  | 0.2028         | 0.5875       |
| 17.     | SODIUM         | MG/L     | 0.2030  | 0.8703  | 0.0167         | 0.8208       |

TOP..

LOG-NORMAL DISTRIBUTION: APR 1, 1979 TO APR 30, 1979

| SAMPLE SOURCE                | MONTHLY AVERAGE | ONE SIGMA | LOG(Y)=F(Z) |            | CHI SQUARE | SAMPLE SIZE |    |
|------------------------------|-----------------|-----------|-------------|------------|------------|-------------|----|
|                              |                 |           | SLOPE       | INTERCEPT  |            |             |    |
| <b>TETRACHLOROETHYLENE</b>   |                 |           |             |            |            |             |    |
| 0                            | 156.7           | 111.9     | 0.4879E     | 0 0.2010E  | 1          | 9.0000      | 20 |
| 1                            | 68.8            | 60.1      | 0.4057E     | 0 0.1713E  | 1          | 12.5000     | 20 |
| 3                            | 31.9            | 18.5      | 0.3781E     | 0 0.1389E  | 1          | 8.8000      | 25 |
| 4                            | 17.0            | 10.9      | 0.3791E     | 0 0.1108E  | 1          | 4.8182      | 22 |
| 5                            | 6.2             | 7.0       | 0.3913E     | 0 0.6049E  | 0          | 1.1429      | 21 |
| 6                            | 6.7             | 9.3       | 0.4536E     | 0 0.5601E  | 0          | 4.0000      | 26 |
| <b>METHYLENE CHLORIDE</b>    |                 |           |             |            |            |             |    |
| 0                            | 228.7           | 199.9     | 0.4197E     | 0 0.2200E  | 1          | 1.5000      | 20 |
| 1                            | 25.5            | 41.7      | 0.5803E     | 0 0.1020E  | 1          | 2.5000      | 20 |
| 3                            | 16.0            | 21.6      | 0.5787E     | 0 0.8609E  | 0          | 1.6000      | 25 |
| 4                            | 13.7            | 19.9      | 0.5703E     | 0 0.7921E  | 0          | 0.7273      | 22 |
| 5                            | 22.2            | 7.0       | 0.1608E     | 0 0.1322E  | 1          | 4.4762      | 21 |
| 6                            | 21.7            | 6.3       | 0.1344E     | 0 0.1318E  | 1          | 2.0769      | 26 |
| <b>1,2-DICHLOROETHYLENE</b>  |                 |           |             |            |            |             |    |
| 0                            | 24.2            | 78.2      | 0.7286E     | 0 0.2363E  | 0          | 62.0000     | 20 |
| 1                            | 41.6            | 186.2     | 0.6531E     | 0 0.1460E  | 0          | 70.5060     | 20 |
| 4                            | 10.1            | 47.3      | 0.5002E     | 0 0.1066E  | 0          | 78.4566     | 22 |
| 5                            | 0.1             | 0.3       | 0.1458E     | -1 0.3182E | -2         | 74.4762     | 21 |
| <b>CHLOROFORM</b>            |                 |           |             |            |            |             |    |
| 0                            | 31.6            | 14.9      | 0.2344E     | 0 0.1447E  | 1          | 2.5000      | 20 |
| 1                            | 25.1            | 5.5       | 0.9458E     | -1 0.1389E | 1          | 4.5000      | 20 |
| 3                            | 18.6            | 5.1       | 0.1174E     | 0 0.1255E  | 1          | 4.0000      | 25 |
| 4                            | 17.4            | 3.7       | 0.9395E     | -1 0.1232E | 1          | 3.4545      | 22 |
| 5                            | 5.6             | 4.8       | 0.3020E     | 0 0.6399E  | 0          | 4.9524      | 21 |
| 6                            | 5.8             | 3.8       | 0.2426E     | 0 0.6939E  | 0          | 5.5385      | 26 |
| <b>1,1,1-TRICHLOROETHANE</b> |                 |           |             |            |            |             |    |
| 0                            | 175.9           | 197.8     | 0.1056E     | 1 0.1618E  | 1          | 3.0000      | 20 |
| 1                            | 51.0            | 43.6      | 0.7834E     | 0 0.1338E  | 1          | 10.0000     | 20 |
| 3                            | 10.6            | 10.6      | 0.6103E     | 0 0.7299E  | 0          | 9.2000      | 25 |
| 4                            | 6.3             | 5.2       | 0.4555E     | 0 0.6383E  | 0          | 4.8182      | 22 |
| 5                            | 0.8             | 0.7       | 0.1049E     | 0 0.7844E  | -1         | 21.6191     | 21 |
| 6                            | 2.2             | 7.7       | 0.3138E     | 0 0.1007E  | 0          | 20.5385     | 26 |
| <b>BROMODICHLOROMETHANE</b>  |                 |           |             |            |            |             |    |
| 0                            | 2.9             | 0.9       | 0.1321E     | 0 0.4501E  | 0          | 5.0000      | 20 |
| 1                            | 4.0             | 1.2       | 0.1599E     | 0 0.5733E  | 0          | 12.5000     | 20 |
| 3                            | 3.1             | 1.2       | 0.1533E     | 0 0.4642E  | 0          | 5.2000      | 25 |
| 4                            | 2.8             | 0.6       | 0.1013E     | 0 0.4377E  | 0          | 0.7273      | 22 |
| 5                            | 0.7             | 0.6       | 0.9816E     | -1 0.3760E | -1         | 30.1905     | 21 |
| 6                            | 1.3             | 1.3       | 0.1858E     | 0 0.9150E  | -1         | 10.5385     | 26 |

EOF..

LOG-NORMAL DISTRIBUTION. APR 1, 1979 TO APR 30, 1979

| SAMPLE SOURCE               | MONTHLY AVERAGE | ONE SIGMA | LOG(Y)=F(Z) |            |    | CHI SQUARE | SAMPLE SIZE |
|-----------------------------|-----------------|-----------|-------------|------------|----|------------|-------------|
|                             |                 |           | SLOPE       | INTERCEPT  |    |            |             |
| <b>TRICHLOROETHYLENE</b>    |                 |           |             |            |    |            |             |
| 0                           | 74.6            | 40.3      | 0.2261E     | 0 0.1795E  | 1  | 6.5000     | 20          |
| 1                           | 26.5            | 20.3      | 0.3141E     | 0 0.1318E  | 1  | 4.0000     | 20          |
| 3                           | 12.4            | 8.2       | 0.3053E     | 0 0.9986E  | 0  | 2.0000     | 25          |
| 4                           | 8.2             | 5.2       | 0.2955E     | 0 0.8269E  | 0  | 11.6364    | 22          |
| 5                           | 2.2             | 2.7       | 0.3204E     | 0 0.1968E  | 0  | 14.9524    | 21          |
| 6                           | 2.3             | 3.3       | 0.3412E     | 0 0.1820E  | 0  | 29.7692    | 26          |
| <b>DIBROMOCHLOROMETHANE</b> |                 |           |             |            |    |            |             |
| 0                           | 0.2             | 0.3       | 0.8250E     | -2 0.1845E | -2 | 70.5000    | 20          |
| 1                           | 1.5             | 0.4       | 0.1091E     | 0 0.1728E  | 0  | 4.5000     | 20          |
| 3                           | 1.4             | 0.5       | 0.1107E     | 0 0.1560E  | 0  | 4.4000     | 25          |
| 4                           | 1.4             | 0.2       | 0.6690E     | -1 0.1565E | 0  | 1.6364     | 22          |
| 5                           | 0.7             | 0.2       | 0.1907E     | -1 0.5612E | -2 | 65.9048    | 21          |
| 6                           | 0.9             | 0.4       | 0.9349E     | -1 0.2422E | -1 | 33.6154    | 26          |
| <b>BROMOFORM</b>            |                 |           |             |            |    |            |             |
| 0                           | 3.4             | 2.4       | 0.2745E     | 0 0.4404E  | 0  | 1.5000     | 20          |
| 1                           | 1.7             | 0.6       | 0.1264E     | 0 0.2218E  | 0  | 2.0000     | 20          |
| 3                           | 5.0             | 15.3      | 0.3494E     | 0 0.3242E  | 0  | 29.6000    | 25          |
| 4                           | 1.9             | 0.5       | 0.1114E     | 0 0.2695E  | 0  | 3.9091     | 22          |
| 5                           | 1.1             | 0.4       | 0.7839E     | -1 0.8151E | -1 | 3.0476     | 21          |
| 6                           | 1.5             | 1.7       | 0.2061E     | 0 0.1161E  | 0  | 4.0000     | 26          |
| <b>TRIHALOMETHANES</b>      |                 |           |             |            |    |            |             |
| 0                           | 38.1            | 16.1      | 0.1801E     | 0 0.1546E  | 1  | 1.5000     | 20          |
| 1                           | 32.2            | 6.1       | 0.8311E     | -1 0.1501E | 1  | 3.5000     | 20          |
| 3                           | 28.1            | 18.3      | 0.1610E     | 0 0.1409E  | 1  | 5.2000     | 25          |
| 4                           | 23.6            | 4.1       | 0.7798E     | -1 0.1366E | 1  | 0.2727     | 22          |
| 5                           | 8.1             | 5.6       | 0.2318E     | 0 0.6410E  | 0  | 7.8095     | 21          |
| 6                           | 9.5             | 6.5       | 0.2043E     | 0 0.9188E  | 0  | 8.2308     | 26          |
| <b>TOTAL HALOCARBONS</b>    |                 |           |             |            |    |            |             |
| 0                           | 698.2           | 490.1     | 0.3872E     | 0 0.2708E  | 1  | 2.5000     | 20          |
| 1                           | 245.6           | 194.7     | 0.3256E     | 0 0.2281E  | 1  | 6.5000     | 20          |
| 3                           | 99.0            | 49.6      | 0.2332E     | 0 0.1940E  | 1  | 4.4000     | 25          |
| 4                           | 78.9            | 48.7      | 0.2329E     | 0 0.1836E  | 1  | 6.1818     | 22          |
| 5                           | 39.5            | 12.8      | 0.1279E     | 0 0.1578E  | 1  | 1.6190     | 21          |
| 6                           | 42.3            | 24.2      | 0.1741E     | 0 0.1584E  | 1  | 9.0000     | 26          |

EOF..

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR APR. 1, 1979 TO APR. 30, 1979  
FROM SAMPLE SOURCE 0 TO SAMPLE SOURCE 1

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | 13.6005 | 0.3366  | 16.1634        | 0.9293       | 20          |
| 2.      | METHYLENE CHLORIDE    | 6.5537  | 0.0666  | 27.7505        | 0.4299       | 10          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 22.7212 | 0.0301  | 5.6183         | 0.2126       | 20          |
| 6.      | 1,1,1-TRICHLOROETHANE | 24.2778 | 0.1016  | 22.0035        | 0.0676       | 16          |
| 7.      | BROMODICHLOROMETHANE  | 2.6789  | 0.4420  | 1.1396         | 0.4220       | 19          |
| 8.      | TRICHLOROETHYLENE     | -1.5500 | 0.3784  | 12.9699        | 0.7696       | 20          |
| 9.      | DIBROMOCHLOROMETHANE  | 1.6950  | 0.1010  | 0.3407         | 0.6390       | 10          |
| 10.     | BROMOFORM             | 1.6760  | -0.0001 | 0.6193         | 0.0972       | 20          |
| 11.     | TRIHALOMETHANES       | 29.0771 | 0.0470  | 6.4470         | 0.2290       | 20          |
| 12.     | TOTAL HALOCARBONS     | 76.1969 | 0.1969  | 60.6910        | 0.7930       | 20          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CAL NO. | COMPOUND              | A0      | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 13.6590 | 0.3551  | 0.0000  | 16.1634        | 0.9293       |
| 2.      | METHYLENE CHLORIDE    | 21.0051 | -0.0545 | 0.0001  | 26.5009        | 0.5021       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 29.0307 | -0.4566 | 0.0071  | 5.3093         | 0.3405       |
| 6.      | 1,1,1-TRICHLOROETHANE | 16.3032 | 0.2060  | -0.0002 | 21.1365        | 0.0796       |
| 7.      | BROMODICHLOROMETHANE  | 3.3421  | 0.0000  | 0.0645  | 1.1300         | 0.4240       |
| 8.      | TRICHLOROETHYLENE     | 11.6621 | -0.1151 | 0.0033  | 12.0919        | 0.0035       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.1379  | 6.1002  | -4.3006 | 0.2733         | 0.7074       |
| 10.     | BROMOFORM             | 1.5239  | 3.0092  | -0.0007 | 0.6164         | 0.1369       |
| 11.     | TRIHALOMETHANES       | 43.6637 | -0.7292 | 0.0009  | 6.1011         | 0.3095       |
| 12.     | TOTAL HALOCARBONS     | 37.9430 | 0.3453  | -0.0000 | 63.2045        | 0.0160       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 0.0942  | 0.0053  | 0.1531         | 0.9491       |
| 2.      | METHYLENE CHLORIDE    | -0.0254 | 0.0274  | 0.4444         | 0.7240       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 1.3009  | -0.0095 | 0.1005         | 0.0070       |
| 6.      | 1,1,1-TRICHLOROETHANE | -0.0243 | 0.7934  | 0.1024         | 0.9124       |
| 7.      | BROMODICHLOROMETHANE  | 0.3075  | 0.4167  | 0.1514         | 0.3475       |
| 8.      | TRICHLOROETHYLENE     | -0.3515 | 0.9312  | 0.1506         | 0.0703       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.2642  | 0.0050  | 0.0799         | 0.6630       |
| 10.     | BROMOFORM             | 0.1411  | 0.1120  | 0.1700         | 0.2021       |
| 11.     | TRIHALOMETHANES       | 1.4463  | 0.0220  | 0.0921         | 0.1095       |
| 12.     | TOTAL HALOCARBONS     | 0.3356  | 0.6970  | 0.1640         | 0.0560       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979  
 FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 3

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X$ )

| CAL NO. | COMPOUND              | A0      | A1       | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|----------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | 7.3943  | 0.3142   | 11.5381        | 0.7684       | 23          |
| 2.      | METHYLENE CHLORIDE    | 4.9843  | 0.4817   | 14.7889        | 0.7533       | 19          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000   | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000   | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 7.4191  | 0.4587   | 4.2844         | 0.5433       | 23          |
| 6.      | 1,1,1-TRICHLOROETHANE | 3.8890  | 0.1897   | 3.9397         | 0.8966       | 18          |
| 7.      | BROMODICHLOROMETHANE  | 0.6949  | 0.6354   | 0.9588         | 0.6817       | 22          |
| 8.      | TRICHLOROETHYLENE     | 4.8121  | 0.2957   | 3.6229         | 0.8484       | 23          |
| 9.      | DIBROMOCHLOROMETHANE  | 1.3825  | 0.1721   | 0.4386         | 0.1984       | 23          |
| 10.     | BROMOFORM             | 25.4878 | -11.5563 | 14.5494        | 0.4838       | 22          |
| 11.     | TRIHALOMETHANES       | 28.6898 | -0.8125  | 18.7822        | 0.8252       | 23          |
| 12.     | TOTAL HALOCARBONS     | 28.8748 | 0.3366   | 32.1783        | 0.7598       | 23          |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CAL NO. | COMPOUND              | A0      | A1       | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|----------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 3.1346  | 0.5888   | -0.0813 | 11.2477        | 0.7741       |
| 2.      | METHYLENE CHLORIDE    | 0.5157  | 0.0820   | 0.0823  | 14.2838        | 0.7723       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000   | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000   | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 28.1573 | -0.6449  | 0.0225  | 4.1337         | 0.5645       |
| 6.      | 1,1,1-TRICHLOROETHANE | 2.9632  | 0.2321   | -0.0883 | 3.9882         | 0.8983       |
| 7.      | BROMODICHLOROMETHANE  | -0.1787 | 1.1884   | -0.0594 | 0.9498         | 0.6187       |
| 8.      | TRICHLOROETHYLENE     | 1.3669  | 0.4881   | -0.0822 | 3.3218         | 0.8744       |
| 9.      | DIBROMOCHLOROMETHANE  | 1.6485  | -0.3114  | 0.1574  | 0.4378         | 0.2875       |
| 10.     | BROMOFORM             | 75.3384 | -71.8835 | 16.8699 | 12.3877        | 0.6271       |
| 11.     | TRIHALOMETHANES       | 27.1836 | 0.8825   | -0.0815 | 18.7828        | 0.8255       |
| 12.     | TOTAL HALOCARBONS     | 45.2872 | 0.8991   | 0.0886  | 31.6986        | 0.7674       |

LOGARITHMIC CURVE FIT RESULTS ( $\text{LOG}(Y)=A_0 + A_1 \cdot \text{LOG}(X)$ )

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.1382 | 0.8599  | 0.1884         | 0.9282       |
| 2.      | METHYLENE CHLORIDE    | -0.1847 | 0.9239  | 0.3355         | 0.8547       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.4746  | 0.5674  | 0.0968         | 0.5537       |
| 6.      | 1,1,1-TRICHLOROETHANE | -0.0263 | 0.6873  | 0.1113         | 0.9338       |
| 7.      | BROMODICHLOROMETHANE  | -0.0862 | 0.8438  | 0.0919         | 0.8134       |
| 8.      | TRICHLOROETHYLENE     | -0.0459 | 0.7898  | 0.1558         | 0.8789       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.1625  | 0.1188  | 0.0951         | 0.1558       |
| 10.     | BROMOFORM             | 0.5537  | -0.9368 | 0.3257         | 0.7428       |
| 11.     | TRIHALOMETHANES       | 0.9563  | 0.3842  | 0.1639         | 0.2765       |
| 12.     | TOTAL HALOCARBONS     | 0.5666  | 0.6129  | 0.1531         | 0.8894       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 4

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|--------|----------------|--------------|-------------|
|         | TETRACHLOROETHYLENE   | 2.1575  | 0.1896 | 4.9222         | 0.8537       | 22          |
|         | METHYLENE CHLORIDE    | 4.8291  | 0.3698 | 13.8972        | 0.7492       | 19          |
|         | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 4.3469  | 0.5223 | 2.2221         | 0.7960       | 22          |
| 6.      | 1,1,1-TRICHLOROETHANE | 3.0052  | 0.0943 | 2.1206         | 0.8776       | 18          |
| 7.      | BROMODICHLOROMETHANE  | 1.2289  | 0.4262 | 0.2858         | 0.8815       | 21          |
| 8.      | TRICHLOROETHYLENE     | 1.8771  | 0.2225 | 1.8605         | 0.9184       | 22          |
| 9.      | DIBROMOCHLOROMETHANE  | 1.2644  | 0.1581 | 0.1412         | 0.5128       | 22          |
| 10.     | BROMOFORM             | 1.3432  | 0.3886 | 0.2975         | 0.6800       | 21          |
| 11.     | TRIHALOMETHANES       | 7.6276  | 0.4993 | 2.6491         | 0.7708       | 22          |
| 12.     | TOTAL HALOCARBONS     | 40.4344 | 0.1884 | 44.4588        | 0.4824       | 22          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*X\*X2)

| CAL NO. | COMPOUND              | A0      | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 0.1493  | 0.2784  | -0.0006 | 4.7600         | 0.8640       |
| 2.      | METHYLENE CHLORIDE    | 7.4123  | 0.1411  | 0.0016  | 13.6242        | 0.7685       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -1.7281 | 1.0281  | -0.0180 | 2.2056         | 0.7994       |
| 6.      | 1,1,1-TRICHLOROETHANE | 2.0724  | 0.1270  | -0.0003 | 2.0686         | 0.8848       |
| 7.      | BROMODICHLOROMETHANE  | 1.1148  | 0.4888  | -0.0079 | 0.2853         | 0.8819       |
| 8.      | TRICHLOROETHYLENE     | 0.8982  | 0.2911  | -0.0008 | 1.7920         | 0.9245       |
| 9.      | DIBROMOCHLOROMETHANE  | 1.4691  | -0.1285 | 0.0933  | 0.1394         | 0.5381       |
| 10.     | BROMOFORM             | 1.0687  | 0.7161  | -0.0982 | 0.2945         | 0.6880       |
| 11.     | TRIHALOMETHANES       | 1.2389  | 0.9186  | -0.0066 | 2.6336         | 0.7739       |
| 12.     | TOTAL HALOCARBONS     | 7.8118  | 0.6481  | -0.0011 | 43.1337        | 0.4594       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|--------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.3489 | 0.8286 | 0.1434         | 0.9448       |
| 2.      | METHYLENE CHLORIDE    | -0.2261 | 0.9287 | 0.3523         | 0.8365       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.1779  | 0.7593 | 0.8557         | 0.8078       |
| 6.      | 1,1,1-TRICHLOROETHANE | -0.0749 | 0.5614 | 0.1050         | 0.9182       |
| 7.      | BROMODICHLOROMETHANE  | 0.1619  | 0.5123 | 0.0425         | 0.8975       |
| 8.      | TRICHLOROETHYLENE     | -0.3121 | 0.8484 | 0.1187         | 0.9315       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.1534  | 0.1324 | 0.0420         | 0.4599       |
| 10.     | BROMOFORM             | 0.2383  | 0.3125 | 0.0653         | 0.6595       |
| 11.     | TRIHALOMETHANES       | 0.3428  | 0.6841 | 0.8487         | 0.7878       |
| 12.     | TOTAL HALOCARBONS     | 0.5483  | 0.5721 | 0.1684         | 0.7441       |

ORIGINAL PAGE IS  
OF POOR QUALITY

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979  
 FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 5

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X$ )

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | 2.3298  | 0.8351  | 5.6711         | 0.3873       | 21          |
| 2.      | METHYLENE CHLORIDE    | 23.8529 | -0.8415 | 5.4897         | 0.3254       | 19          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 5.      | CHLOROFORM            | 5.2824  | -0.0343 | 2.5184         | 0.3271       | 21          |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.2286  | -0.0018 | 0.5854         | 0.4125       | 16          |
| 7.      | BROMODICHLOROMETHANE  | 0.7039  | 0.0161  | 0.3117         | 0.2827       | 14          |
| 8.      | TRICHLOROETHYLENE     | 1.2782  | 0.0146  | 1.8925         | 0.3268       | 21          |
| 9.      | DIBROMOCHLOROMETHANE  | 0.6947  | 0.0046  | 0.1518         | 0.4891       | 21          |
| 10.     | BROMOFORM             | 0.6833  | 0.3422  | 0.5850         | 0.5738       | 21          |
| 11.     | TRIHALOMETHANES       | 7.5824  | -0.0218 | 2.9221         | 0.4889       | 21          |
| 12.     | TOTAL HALOCARBONS     | 38.6494 | -0.8072 | 18.7663        | 0.2533       | 21          |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CAL NO. | COMPOUND              | A0       | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|----------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 0.8772   | 0.1365  | -0.0007 | 5.4863         | 0.3985       |
| 2.      | METHYLENE CHLORIDE    | 25.4473  | -0.1906 | 0.0011  | 5.8891         | 0.4569       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -12.2740 | 1.4175  | -0.0286 | 2.3878         | 0.4383       |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.2961   | -0.0047 | 0.0000  | 0.5845         | 0.4158       |
| 7.      | BROMODICHLOROMETHANE  | 0.4756   | 0.1456  | -0.0163 | 0.3898         | 0.3889       |
| 8.      | TRICHLOROETHYLENE     | 0.7120   | 0.0548  | -0.0004 | 1.8784         | 0.3572       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.5764   | 0.1573  | -0.0467 | 0.1515         | 0.4916       |
| 10.     | BROMOFORM             | 0.3359   | 0.6638  | -0.0872 | 0.5834         | 0.5778       |
| 11.     | TRIHALOMETHANES       | -16.5348 | 1.5343  | -0.0241 | 2.7424         | 0.5683       |
| 12.     | TOTAL HALOCARBONS     | 27.7277  | 0.1587  | -0.0004 | 18.1197        | 0.4161       |

LOGARITHMIC CURVE FIT RESULTS ( $\text{LOG}(Y)=A_0 + A_1 \cdot \text{LOG}(X)$ )

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.5488 | 0.6233  | 0.2449         | 0.8468       |
| 2.      | METHYLENE CHLORIDE    | 1.4126  | -0.0685 | 0.1243         | 0.3188       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.3187  | 0.1958  | 0.2523         | 0.4945       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.1569  | -0.1316 | 0.3678         | 0.4946       |
| 7.      | BROMODICHLOROMETHANE  | -0.1937 | 0.0652  | 0.2859         | 0.4833       |
| 8.      | TRICHLOROETHYLENE     | -0.2489 | 0.2668  | 0.2435         | 0.7374       |
| 9.      | DIBROMOCHLOROMETHANE  | -0.1753 | 0.0528  | 0.1875         | 0.4987       |
| 10.     | BROMOFORM             | -0.0825 | 0.4868  | 0.2196         | 0.6589       |
| 11.     | TRIHALOMETHANES       | 0.5562  | 0.1662  | 0.1875         | 0.5983       |
| 12.     | TOTAL HALOCARBONS     | 1.5969  | -0.0187 | 0.1183         | 0.3838       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR APR. 1, 1979 TO APR. 30, 1979

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 6

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X$ )

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | 2.4539  | 0.0120  | 3.3844         | 0.6793       | 23          |
| 2.      | METHYLENE CHLORIDE    | 22.8559 | -0.0254 | 4.2509         | 0.2716       | 20          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 8           |
| 5.      | CHLOROFORM            | 4.0694  | -0.0212 | 1.8337         | 0.5440       | 23          |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.0139  | -0.0025 | 0.5193         | 0.9137       | 17          |
| 7.      | BROMODICHLOROMETHANE  | 0.1900  | 0.1994  | 0.3613         | 0.6013       | 22          |
| 8.      | TRICHLOROETHYLENE     | 0.9077  | 0.0069  | 0.9204         | 0.7567       | 23          |
| 9.      | DIBROMOCHLOROMETHANE  | 0.7209  | 0.0903  | 0.1647         | 0.3415       | 22          |
| 10.     | BROMOFORM             | 0.2122  | 0.5190  | 0.3925         | 0.7123       | 22          |
| 11.     | TRIHALOMETHANES       | 7.1661  | 0.0012  | 2.3460         | 0.6259       | 23          |
| 12.     | TOTAL HALOCARBONS     | 35.0175 | -0.0040 | 7.8541         | 0.6634       | 23          |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CAL NO. | COMPOUND              | A0      | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 1.0169  | 0.0407  | -0.0002 | 3.3625         | 0.6844       |
| 2.      | METHYLENE CHLORIDE    | 23.6000 | -0.0964 | 0.0005  | 4.1643         | 0.3333       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.9557  | 0.3179  | -0.0069 | 1.9105         | 0.5546       |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.0630  | -0.0046 | 0.0000  | 0.5107         | 0.9139       |
| 7.      | BROMODICHLOROMETHANE  | 0.4007  | 0.0843  | 0.0145  | 0.3600         | 0.6841       |
| 8.      | TRICHLOROETHYLENE     | 0.5796  | 0.0300  | -0.0003 | 0.9027         | 0.7674       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.6700  | 0.1504  | -0.0195 | 0.1646         | 0.3425       |
| 10.     | BROMOFORM             | 0.7541  | -0.1266 | 0.1747  | 0.3036         | 0.7276       |
| 11.     | TRIHALOMETHANES       | -1.0974 | 0.6051  | -0.0096 | 2.3056         | 0.6423       |
| 12.     | TOTAL HALOCARBONS     | 20.9400 | 0.0043  | -0.0002 | 7.5746         | 0.6923       |

LOGARITHMIC CURVE FIT RESULTS ( $\text{LOG}(Y)=A_0 + A_1 \cdot \text{LOG}(X)$ )

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.2760 | 0.3906  | 0.2709         | 0.0554       |
| 2.      | METHYLENE CHLORIDE    | 1.3510  | -0.0141 | 0.0852         | 0.1000       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.6842  | -0.0622 | 0.1950         | 0.5946       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.0106  | -0.1324 | 0.3069         | 0.7970       |
| 7.      | BROMODICHLOROMETHANE  | -0.4015 | 0.6254  | 0.1513         | 0.7340       |
| 8.      | TRICHLOROETHYLENE     | -0.2363 | 0.1609  | 0.1069         | 0.0896       |
| 9.      | DIBROMOCHLOROMETHANE  | -0.0956 | 0.1320  | 0.0754         | 0.4206       |
| 10.     | BROMOFORM             | -0.1225 | 0.5909  | 0.1701         | 0.6005       |
| 11.     | TRIHALOMETHANES       | 0.2215  | 0.4091  | 0.1792         | 0.6003       |
| 12.     | TOTAL HALOCARBONS     | 1.5376  | -0.0061 | 0.0920         | 0.6900       |



GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR APR. 1, 1979 TO APR. 30, 1979  
 FROM SAMPLE SOURCE 3 TO SAMPLE SOURCE 4

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | -0.1740 | 0.5701  | 2.5754         | 0.9710       | 24          |
| 2.      | METHYLENE CHLORIDE    | 0.0235  | 0.8289  | 6.9791         | 0.9369       | 21          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 10.0151 | 0.3791  | 3.1964         | 0.5117       | 24          |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.1112  | 0.4530  | 0.8790         | 0.9000       | 10          |
| 7.      | BROMODICHLOROMETHANE  | 0.7011  | 0.6911  | 0.3150         | 0.8645       | 23          |
| 8.      | TRICHLOROETHYLENE     | 0.7034  | 0.5791  | 1.6494         | 0.9446       | 24          |
| 9.      | DIBROMOCHLOROMETHANE  | 0.7761  | 0.4009  | 0.1690         | 0.6903       | 24          |
| 10.     | BROMOFORM             | 1.9460  | -0.0047 | 0.4524         | 0.2334       | 23          |
| 11.     | TRIHALOMETHANES       | 23.1097 | -0.0009 | 4.2570         | 0.0039       | 24          |
| 12.     | TOTAL HALOCARBONS     | 40.4151 | 0.2921  | 44.4632        | 0.3176       | 24          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CAL NO. | COMPOUND              | A0       | A1     | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|----------|--------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 0.0220   | 0.4697 | 0.0016  | 2.5020         | 0.9726       |
| 2.      | METHYLENE CHLORIDE    | 1.6947   | 0.6137 | 0.0020  | 6.7243         | 0.9416       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000   | 0.0000 | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000   | 0.0000 | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -12.5998 | 2.7062 | -0.0597 | 2.5766         | 0.7214       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.2606   | 0.5940 | -0.0043 | 0.8311         | 0.9822       |
| 7.      | BROMODICHLOROMETHANE  | 0.9682   | 0.5505 | 0.0220  | 0.3151         | 0.8652       |
| 8.      | TRICHLOROETHYLENE     | 0.2296   | 0.6600 | -0.0025 | 1.6333         | 0.9457       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.0207   | 0.3636 | 0.0536  | 0.1606         | 0.6910       |
| 10.     | BROMOFORM             | 0.5046   | 0.8131 | -0.0102 | 0.3806         | 0.5752       |
| 11.     | TRIHALOMETHANES       | 4.6042   | 0.9515 | -0.0073 | 3.2003         | 0.6596       |
| 12.     | TOTAL HALOCARBONS     | 40.9006  | 0.2000 | 0.0001  | 44.4620        | 0.3176       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 +A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.1052 | 0.9555  | 0.0497         | 0.9932       |
| 2.      | METHYLENE CHLORIDE    | -0.0137 | 0.9305  | 0.1369         | 0.9747       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.6163  | 0.4020  | 0.0774         | 0.5904       |
| 6.      | 1,1,1-TRICHLOROETHANE | -0.0592 | 0.8220  | 0.0442         | 0.9060       |
| 7.      | BROMODICHLOROMETHANE  | 0.1524  | 0.6344  | 0.0505         | 0.8160       |
| 8.      | TRICHLOROETHYLENE     | -0.0799 | 0.8955  | 0.0611         | 0.9793       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.1190  | 0.2903  | 0.0592         | 0.6706       |
| 10.     | BROMOFORM             | 0.2716  | -0.0000 | 0.1109         | 0.0395       |
| 11.     | TRIHALOMETHANES       | 1.2030  | 0.1004  | 0.0002         | 0.2290       |
| 12.     | TOTAL HALOCARBONS     | 0.6542  | 0.6061  | 0.1001         | 0.6737       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979  
 FROM SAMPLE SOURCE 4 TO SAMPLE SOURCE 5

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | -1.4173 | 0.4476  | 4.7209         | 0.7079       | 23          |
| 2.      | METHYLENE CHLORIDE    | 23.0903 | -0.0917 | 6.1972         | 0.2948       | 20          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 1.6930  | 0.2243  | 4.4200         | 0.1955       | 23          |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.0962  | 0.0010  | 0.5094         | 0.3905       | 16          |
| 7.      | BROMODICHLOROMETHANE  | 1.3650  | -0.1534 | 0.4636         | 0.2442       | 16          |
| 8.      | TRICHLOROETHYLENE     | 0.2046  | 0.2401  | 2.1901         | 0.4005       | 23          |
| 9.      | DIBROMOCHLOROMETHANE  | 1.1506  | -0.2919 | 0.1606         | 0.4600       | 23          |
| 10.     | BROMOFORM             | 0.6796  | 0.2700  | 0.5941         | 0.5140       | 22          |
| 11.     | TRIHALOMETHANES       | 5.4341  | 0.1171  | 5.1635         | 0.1105       | 23          |
| 12.     | TOTAL HALOCARBONS     | 37.6770 | 0.0159  | 12.1117        | 0.1026       | 23          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*X\*2)

| CAL NO. | COMPOUND              | A0      | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 0.4830  | 0.1513  | 0.0077  | 4.3678         | 0.7300       |
| 2.      | METHYLENE CHLORIDE    | 25.0769 | -0.5131 | 0.0059  | 5.3525         | 0.5560       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 21.1113 | -2.1065 | 0.0666  | 4.3677         | 0.2535       |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.0619  | -0.2263 | 0.0134  | 0.5549         | 0.5045       |
| 7.      | BROMODICHLOROMETHANE  | 2.0666  | -0.6914 | 0.0964  | 0.4606         | 0.2682       |
| 8.      | TRICHLOROETHYLENE     | -0.1530 | 0.3343  | -0.0044 | 2.1927         | 0.4924       |
| 9.      | DIBROMOCHLOROMETHANE  | 2.9309  | -3.1170 | 1.0725  | 0.1484         | 0.6243       |
| 10.     | BROMOFORM             | 2.4070  | -1.7719 | 0.5657  | 0.5762         | 0.5556       |
| 11.     | TRIHALOMETHANES       | 14.4303 | -0.6074 | 0.0174  | 5.1530         | 0.1333       |
| 12.     | TOTAL HALOCARBONS     | 35.3212 | 0.0670  | -0.0002 | 12.0043        | 0.1225       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.30   | 0.0034  | 0.2094         | 0.0906       |
| 2.      | METHYLENE CHLORIDE    | 1.4195  | -0.1246 | 0.1359         | 0.4915       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -0.0013 | 0.5213  | 0.2974         | 0.3233       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.0017  | -0.0709 | 0.3705         | 0.4797       |
| 7.      | BROMODICHLOROMETHANE  | 0.0573  | -0.3469 | 0.2361         | 0.2242       |
| 8.      | TRICHLOROETHYLENE     | -0.5192 | 0.5910  | 0.2694         | 0.6910       |
| 9.      | DIBROMOCHLOROMETHANE  | -0.0714 | -0.4970 | 0.1090         | 0.4045       |
| 10.     | BROMOFORM             | -0.0404 | 0.2616  | 0.2294         | 0.5790       |
| 11.     | TRIHALOMETHANES       | 0.3524  | 0.3660  | -0.2157        | 0.3697       |
| 12.     | TOTAL HALOCARBONS     | 1.5146  | 0.0316  | 0.1200         | 0.2391       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979  
FROM SAMPLE SOURCE 5 TO SAMPLE SOURCE 6

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|--------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | 1.7899  | 0.5418 | 5.6570         | 0.5618       | 24          |
| 2.      | METHYLENE CHLORIDE    | 11.9355 | 0.4896 | 4.3869         | 0.6155       | 24          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 3.1761  | 0.2719 | 2.4711         | 0.5199       | 23          |
| 6.      | 1,1,1-TRICHLOROETHANE | -2.1733 | 2.7576 | 1.1714         | 0.9920       | 17          |
| 7.      | BROMODICHLOROMETHANE  | -0.0094 | 1.2046 | 0.6043         | 0.8987       | 17          |
| 8.      | TRICHLOROETHYLENE     | 0.5514  | 0.5983 | 2.6570         | 0.5026       | 24          |
| 9.      | DIBROMOCHLOROMETHANE  | -0.0150 | 1.1604 | 0.2435         | 0.8287       | 23          |
| 10.     | BROMOFORM             | -0.0690 | 0.9478 | 0.5426         | 0.9583       | 23          |
| 11.     | TRIHALOMETHANES       | 3.6805  | 0.5823 | 5.9174         | 0.4695       | 24          |
| 12.     | TOTAL HALOCARBONS     | -2.7754 | 1.0822 | 18.9517        | 0.5985       | 24          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CAL NO. | COMPOUND              | A0       | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|----------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.6687  | 1.3797  | -0.0312 | 5.4255         | 0.6087       |
| 2.      | METHYLENE CHLORIDE    | 25.1221  | -0.8766 | 0.0321  | 3.9838         | 0.6845       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000   | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -0.2619  | 1.3699  | -0.0516 | 1.9371         | 0.7427       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.8464   | 0.4996  | 0.1443  | 0.2612         | 0.9996       |
| 7.      | BROMODICHLOROMETHANE  | 1.2473   | -0.6322 | 0.3489  | 0.4140         | 0.9614       |
| 8.      | TRICHLOROETHYLENE     | -2.3631  | 3.3160  | -0.2744 | 2.1292         | 0.7211       |
| 9.      | DIBROMOCHLOROMETHANE  | 1.2867   | -1.4878 | 1.1115  | 0.1437         | 0.9439       |
| 10.     | BROMOFORM             | 0.8597   | 0.8158  | 0.0968  | 0.3884         | 0.9759       |
| 11.     | TRIHALOMETHANES       | -5.6317  | 2.5382  | -0.0724 | 5.1823         | 0.6341       |
| 12.     | TOTAL HALOCARBONS     | -36.6580 | 2.6338  | -0.0159 | 18.6339        | 0.6086       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|--------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.8248 | 0.8387 | 0.2398         | 0.8999       |
| 2.      | METHYLENE CHLORIDE    | 0.8501  | 0.3746 | 0.0821         | 0.5646       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 0.2946  | 0.4902 | 0.1641         | 0.7743       |
| 6.      | 1,1,1-TRICHLOROETHANE | -0.1230 | 1.1735 | 0.1877         | 0.9647       |
| 7.      | BROMODICHLOROMETHANE  | 0.0687  | 0.4908 | 0.2092         | 0.6863       |
| 8.      | TRICHLOROETHYLENE     | -0.0023 | 0.7722 | 0.2290         | 0.8537       |
| 9.      | DIBROMOCHLOROMETHANE  | 0.0045  | 0.5633 | 0.0981         | 0.6424       |
| 10.     | BROMOFORM             | -0.8203 | 0.7449 | 0.1513         | 0.8521       |
| 11.     | TRIHALOMETHANES       | 0.2755  | 0.6766 | 0.1885         | 0.6937       |
| 12.     | TOTAL HALOCARBONS     | 0.1189  | 0.9141 | 0.1210         | 0.7196       |

LOG-NORMAL DISTRIBUTION: APR 1, 1979 TO APR 30, 1979

| SAMPLE SOURCE         | MONTHLY AVERAGE | ONE SIGMA | LOG(Y)=F(Z) |           |          | CHI SQUARE | SAMPLE SIZE |    |
|-----------------------|-----------------|-----------|-------------|-----------|----------|------------|-------------|----|
|                       |                 |           | SLOPE       | INTERCEPT |          |            |             |    |
| <b>TOTAL BIOMASS</b>  |                 |           |             |           |          |            |             |    |
| 0                     | 30.6            | 3.8       | 0.5677E     | -1        | 0.1482E  | 1          | 23.3750     | 16 |
| 1                     | 14.3            | 3.4       | 0.1144E     | 0         | 0.1141E  | 1          | 2.0000      | 25 |
| 3                     | 5.6             | 3.1       | 0.1880E     | 0         | 0.6986E  | 0          | 7.3793      | 29 |
| 4                     | 2.4             | 0.6       | 0.9200E     | -1        | 0.3665E  | 0          | 23.6154     | 26 |
| 5                     | 2.7             | 0.9       | 0.9868E     | -1        | 0.4171E  | 0          | 8.8000      | 25 |
| 6                     | 2.5             | 0.7       | 0.9035E     | -1        | 0.3877E  | 0          | 23.9310     | 29 |
| <b>VIABLE BIOMASS</b> |                 |           |             |           |          |            |             |    |
| 0                     | 5.9             | 6.4       | 0.7849E     | 0         | 0.4564E  | 0          | 8.8333      | 12 |
| 1                     | 3.4             | 1.8       | 0.2029E     | 0         | 0.4880E  | 0          | 3.6000      | 25 |
| 3                     | 1.6             | 2.1       | 0.5040E     | 0         | -0.1115E | 0          | 3.4286      | 28 |
| 4                     | 1.5             | 4.3       | 0.8480E     | 0         | -0.8321E | 0          | 4.3636      | 22 |
| 5                     | 0.9             | 2.7       | 0.5299E     | 0         | -0.6716E | 0          | 14.3333     | 24 |
| 6                     | 0.4             | 0.8       | 0.4038E     | 0         | -0.6624E | 0          | 3.3333      | 30 |
| <b>RES CHLORINE</b>   |                 |           |             |           |          |            |             |    |
| 0                     | 0.1             | 0.0       | 0.8264E     | -3        | -0.1000E | 1          | 32.0000     | 8  |
| 1                     | 10.2            | 4.7       | 0.1544E     | 0         | 0.9793E  | 0          | 9.5714      | 14 |
| 3                     | 6.0             | 3.1       | 0.4940E     | 0         | 0.6594E  | 0          | 15.2857     | 14 |
| 4                     | 5.2             | 0.9       | 0.8556E     | -1        | 0.7045E  | 0          | 2.1667      | 12 |
| 5                     | 1.1             | 2.3       | 0.4824E     | 0         | -0.3690E | 0          | 35.0769     | 13 |
| 6                     | 2.3             | 0.8       | 0.3725E     | 0         | 0.2819E  | 0          | 16.6667     | 15 |
| <b>TURBIDITY-SI02</b> |                 |           |             |           |          |            |             |    |
| 0                     | 49.3            | 15.3      | 0.3475E     | 0         | 0.1632E  | 1          | 49.8261     | 23 |
| 1                     | 21.2            | 11.0      | 0.2263E     | 0         | 0.1274E  | 1          | 2.0769      | 26 |
| 3                     | 12.3            | 4.2       | 0.2505E     | 0         | 0.1044E  | 1          | 29.0000     | 30 |
| 4                     | 13.7            | 6.1       | 0.2960E     | 0         | 0.1065E  | 1          | 19.8519     | 27 |
| 5                     | 4.3             | 3.1       | 0.2128E     | 0         | 0.5766E  | 0          | 9.0000      | 26 |
| 6                     | 3.1             | 1.0       | 0.1423E     | 0         | 0.4670E  | 0          | 3.3333      | 30 |
| <b>TOT ORG CARBON</b> |                 |           |             |           |          |            |             |    |
| 0                     | 54.1            | 17.1      | 0.1275E     | 0         | 0.1714E  | 1          | 11.5000     | 20 |
| 1                     | 14.6            | 5.9       | 0.1394E     | 0         | 0.1140E  | 1          | 6.0000      | 24 |
| 3                     | 13.2            | 7.0       | 0.1854E     | 0         | 0.1081E  | 1          | 2.8000      | 25 |
| 4                     | 11.9            | 6.4       | 0.1689E     | 0         | 0.1038E  | 1          | 2.4348      | 23 |
| 5                     | 5.1             | 4.9       | 0.4773E     | 0         | 0.5051E  | 0          | 0.5833      | 24 |
| 6                     | 5.1             | 5.1       | 0.4514E     | 0         | 0.5136E  | 0          | 0.5385      | 24 |

EOF..

LOG-NORMAL DISTRIBUTION: APR 1, 1979 TO APR 30, 1979

| SAMPLE SOURCE       | MONTHLY AVERAGE | ONE SIGMA | LOG(Y)=F(Z) |           | CHI SQUARE | SAMPLE SIZE |
|---------------------|-----------------|-----------|-------------|-----------|------------|-------------|
|                     |                 |           | SLOPE       | INTERCEPT |            |             |
| <b>AMMONIA</b>      |                 |           |             |           |            |             |
| 0                   | 27.9            | 4.4       | 0.6925E -1  | 0.1440E 1 | 2.8696     | 23          |
| 1                   | 19.2            | 4.3       | 0.9988E -1  | 0.1273E 1 | 7.4615     | 26          |
| 3                   | 19.9            | 4.7       | 0.1104E 0   | 0.1285E 1 | 3.6667     | 30          |
| 4                   | 19.4            | 5.4       | 0.1340E 0   | 0.1269E 1 | 8.0000     | 25          |
| 5                   | 17.5            | 5.0       | 0.1346E 0   | 0.1225E 1 | 9.6000     | 25          |
| 6                   | 17.1            | 4.8       | 0.1295E 0   | 0.1214E 1 | 3.6667     | 30          |
| <b>PH</b>           |                 |           |             |           |            |             |
| 0                   | 7.2             | 0.3       | 0.1722E -1  | 0.8563E 0 | 6.3478     | 23          |
| 1                   | 7.0             | 0.3       | 0.1629E -1  | 0.8469E 0 | 4.7692     | 26          |
| 3                   | 7.3             | 0.3       | 0.1847E -1  | 0.8649E 0 | 3.6667     | 30          |
| 4                   | 7.6             | 0.2       | 0.1173E -1  | 0.8794E 0 | 6.5185     | 27          |
| 5                   | 7.4             | 0.3       | 0.1565E -1  | 0.8699E 0 | 4.7692     | 26          |
| 6                   | 7.2             | 0.2       | 0.1451E -1  | 0.8503E 0 | 4.3333     | 30          |
| <b>CONDUCTIVITY</b> |                 |           |             |           |            |             |
| 0                   | 1471.4          | 73.5      | 0.2215E -1  | 0.3167E 1 | 2.4348     | 23          |
| 1                   | 1466.0          | 69.2      | 0.2035E -1  | 0.3166E 1 | 5.9231     | 26          |
| 3                   | 1525.4          | 49.6      | 0.1445E -1  | 0.3183E 1 | 8.3333     | 30          |
| 4                   | 1537.3          | 64.8      | 0.1820E -1  | 0.3186E 1 | 3.5556     | 27          |
| 5                   | 1541.8          | 65.5      | 0.1845E -1  | 0.3188E 1 | 2.8462     | 26          |
| 6                   | 1562.5          | 73.0      | 0.2019E -1  | 0.3193E 1 | 6.3333     | 30          |
| <b>HARDNESS</b>     |                 |           |             |           |            |             |
| 0                   | 36.2            | 16.9      | 0.2186E 0   | 0.1512E 1 | 0.8750     | 16          |
| 1                   | 425.5           | 264.0     | 0.2301E 0   | 0.2565E 1 | 2.5000     | 20          |
| 3                   | 279.5           | 84.7      | 0.1231E 0   | 0.2429E 1 | 0.1667     | 24          |
| 4                   | 300.4           | 94.1      | 0.1317E 0   | 0.2458E 1 | 2.5714     | 21          |
| 5                   | 218.6           | 73.3      | 0.1251E 0   | 0.2321E 1 | 2.0000     | 20          |
| 6                   | 307.0           | 85.4      | 0.1182E 0   | 0.2471E 1 | 6.8333     | 24          |
| EOF..               |                 |           |             |           |            |             |

REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979

FROM SAMPLE SOURCE 0 TO SAMPLE SOURCE 1

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X$ )

| CHA NO. | SENSOR         | UNITS    | A0        | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|-----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 6.5642    | 0.2642  | 3.8829         | 0.2582       | 14          |
| 2.      | VIABLE BIOMASS | MIL C/ML | 4.8504    | -0.0833 | 2.1870         | 0.4379       | 10          |
| 5.      | RES CHLORINE   | MG/L     | 8.7811    | 0.0000  | 0.7818         | 0.8794       | 8           |
| 6.      | TURBIDITY-S102 | MG/L     | 9.9550    | 0.2480  | 10.9109        | 0.3429       | 21          |
| 9.      | TOT ORG CARBON | MG/L     | 10.7391   | 0.0842  | 5.9630         | 0.2527       | 20          |
| 10.     | AMMONIA        | MG/L     | 9.9887    | 0.3858  | 6.2156         | 0.3723       | 21          |
| 12.     | PH             | PH       | 3.5481    | 0.4847  | 0.2403         | 0.4982       | 21          |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000    | 0.0000  | 0.0000         | 0.0000       | 0           |
| 14.     | CONDUCTIVITY   | MMHO/CM  | 1050.6140 | 0.2880  | 47.9734        | 0.4256       | 21          |
| 16.     | HARDNESS       | MG/L     | 77.2443   | 9.2559  | 228.1157       | 0.5690       | 14          |
| 17.     | SODIUM         | MG/L     | 25.0089   | 0.7623  | 9.7510         | 0.8765       | 21          |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CHA NO. | SENSOR         | UNITS    | A0         | A1       | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|------------|----------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 130.5209   | -0.4044  | 0.1487  | 3.6378         | 0.4251       |
| 2.      | VIABLE BIOMASS | MIL C/ML | 4.2134     | 0.1228   | -0.0078 | 2.1550         | 0.4639       |
| 5.      | RES CHLORINE   | MG/L     | 8.7811     | 0.0000   | 0.0000  | 0.7818         | 0.8794       |
| 6.      | TURBIDITY-S102 | MG/L     | 8.4333     | 0.3351   | -0.0010 | 10.8997        | 0.3455       |
| 9.      | TOT ORG CARBON | MG/L     | 7.7837     | 0.1887   | -0.0008 | 5.9593         | 0.2549       |
| 10.     | AMMONIA        | MG/L     | -8.2391    | 1.6550   | -0.0227 | 4.1856         | 0.3884       |
| 12.     | PH             | PH       | -30.8204   | 10.0400  | -0.6631 | 0.2261         | 0.5780       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000     | 0.0000   | 0.0000  | 0.0000         | 0.0000       |
| 14.     | CONDUCTIVITY   | MMHO/CM  | 10767.4400 | -13.2115 | 0.0047  | 39.7095        | 0.6425       |
| 16.     | HARDNESS       | MG/L     | -62.9267   | 17.4877  | -0.0994 | 225.9348       | 0.5801       |
| 17.     | SODIUM         | MG/L     | 24.5229    | 0.7788   | -0.0001 | 9.7503         | 0.8765       |

LOGARITHMIC CURVE FIT RESULTS ( $\log(Y)=A_0 + A_1 \cdot \log(X)$ )

| CHA NO. | SENSOR         | UNITS    | A0     | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|--------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.4991 | 0.4368  | 0.1386         | 0.1627       |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.5688 | -0.0187 | 0.2187         | 0.2195       |
| 5.      | RES CHLORINE   | MG/L     |        |         |                |              |
| 6.      | TURBIDITY-S102 | MG/L     | 0.6498 | 0.3921  | 0.1924         | 0.6007       |
| 9.      | TOT ORG CARBON | MG/L     | 0.4467 | 0.3918  | 0.1338         | 0.3444       |
| 10.     | AMMONIA        | MG/L     | 0.5383 | 0.5184  | 0.0985         | 0.3331       |
| 12.     | PH             | PH       | 0.4175 | 0.5013  | 0.0186         | 0.5083       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000 | 0.0000  | 0.0000         | 0.0000       |
| 14.     | CONDUCTIVITY   | MMHO/CM  | 2.3402 | 0.2615  | 0.0141         | 0.3987       |
| 16.     | HARDNESS       | MG/L     | 1.6019 | 0.6234  | 0.1934         | 0.6405       |
| 17.     | SODIUM         | MG/L     | 0.9933 | 0.4992  | 0.0572         | 0.8911       |

REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 3

LINEAR CURVE FIT RESULTS ( $Y=a_0 + A_1 \cdot X$ )

| CHA NO. | SENSOR         | UNITS    | A0       | A1     | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|--------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 3.3430   | 0.0874 | 1.4879         | 0.5586       | 25          |
| 2.      | VIALE BIOMASS  | MIL C/ML | 0.3294   | 0.1526 | 1.4817         | 0.4579       | 23          |
| 5.      | RES CHLORINE   | MG/L     | 1.4131   | 0.8895 | 0.5868         | 0.7188       | 12          |
| 6.      | TURBIDITY-SIO2 | MG/L     | 6.6513   | 0.2639 | 3.3534         | 0.6462       | 26          |
| 9.      | TOT ORG CARBON | MG/L     | -2.7798  | 1.0950 | 2.9308         | 0.9079       | 24          |
| 10.     | AMMONIA        | MG/L     | 1.3432   | 0.9323 | 2.1068         | 0.8852       | 26          |
| 12.     | PH             | PH       | 4.0190   | 0.4827 | 0.2050         | 0.5878       | 26          |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000   | 0.0000 |                |              |             |
| 14.     | CONDUCTIVITY   | MMHO/CM  | 781.2891 | 0.5063 | 38.8259        | 0.6634       | 26          |
| 16.     | HARDNESS       | MG/L     | 186.0314 | 0.2609 | 42.1757        | 0.8545       | 20          |
| 17.     | SODIUM         | MG/L     | 5.5744   | 0.8723 | 6.5898         | 0.9544       | 26          |

PARABOLIC CURVE FIT RESULTS ( $Y=a_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CHA NO. | SENSOR         | UNITS    | A0         | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|------------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 4.5214     | -0.0994 | 0.0069  | 1.4851         | 0.5609       |
| 2.      | VIALE BIOMASS  | MIL C/ML | -1.2665    | 0.9166  | -0.0733 | 1.3779         | 0.4861       |
| 5.      | RES CHLORINE   | MG/L     | -9.5261    | 3.1930  | -0.1616 | 0.5220         | 0.7480       |
| 6.      | TURBIDITY-SIO2 | MG/L     | 0.8685     | 0.7498  | -0.0080 | 2.8465         | 0.7618       |
| 9.      | TOT ORG CARBON | MG/L     | 5.8906     | 0.1242  | 0.0223  | 2.6383         | 0.9266       |
| 10.     | AMMONIA        | MG/L     | -7.9444    | 1.9241  | -0.0251 | 2.0338         | 0.8935       |
| 12.     | PH             | PH       | 0.4816     | -1.1183 | 0.1130  | 0.2047         | 0.5896       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000     | 0.0000  | 0.0000  |                |              |
| 14.     | CONDUCTIVITY   | MMHO/CM  | -4240.3360 | 7.3229  | -0.0023 | 35.3925        | 0.7312       |
| 16.     | HARDNESS       | MG/L     | 196.4859   | 0.2132  | 0.0000  | 42.1078        | 0.8550       |
| 17.     | SODIUM         | MG/L     | 13.9686    | 0.6963  | 0.0009  | 6.4879         | 0.9558       |

LOGARITHMIC CURVE FIT RESULTS ( $\log(Y)=a_0 + A_1 \cdot \log(X)$ )

| CHA NO. | SENSOR         | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.3067  | 0.2949 | 0.1171         | 0.6788       |
| 2.      | VIALE BIOMASS  | MIL C/ML | -0.7506 | 0.9139 | 0.3430         | 0.8209       |
| 5.      | RES CHLORINE   | MG/L     | 0.0499  | 0.7642 | 0.0439         | 0.7288       |
| 6.      | TURBIDITY-SIO2 | MG/L     | -0.1160 | 0.9029 | 0.1703         | 0.7780       |
| 9.      | TOT ORG CARBON | MG/L     | -0.1568 | 1.0838 | 0.1120         | 0.8087       |
| 10.     | AMMONIA        | MG/L     | 0.0272  | 0.9779 | 0.0479         | 0.9066       |
| 12.     | PH             | PH       | 0.4770  | 0.4638 | 0.0122         | 0.5891       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000  | 0.0000 |                |              |
| 14.     | CONDUCTIVITY   | MMHO/CM  | 1.6072  | 0.4976 | 0.0109         | 0.6751       |
| 16.     | HARDNESS       | MG/L     | 1.5865  | 0.3948 | 0.0598         | 0.8316       |
| 17.     | SODIUM         | MG/L     | 0.1486  | 0.9130 | 0.0403         | 0.9446       |

REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 4

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X$ )

| CHA NO. | SENSOR         | UNITS    | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 1.8380   | 0.0265  | 0.3862         | 0.3859       | 24          |
| 2.      | VIALE BIOMASS  | MIL C/ML | 2.2026   | -0.1636 | 0.3792         | 0.0704       | 20          |
| 5.      | RES CHLORINE   | MG/L     | -0.8772  | 0.7158  | 0.5363         | 0.8032       | 12          |
| 6.      | TURBIDITY-SIO2 | MG/L     | 6.9656   | 0.3402  | 4.2803         | 0.6551       | 25          |
| 9.      | TOT ORG CARBON | MG/L     | -1.3786  | 0.8975  | 3.3424         | 0.8446       | 23          |
| 10.     | AMMONIA        | MG/L     | 1.1453   | 0.9215  | 2.7227         | 0.8338       | 23          |
| 12.     | PH             | PH       | 5.8548   | 0.2435  | 0.1913         | 0.3151       | 25          |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000   | 0.0000  | 0.0000         | 0.0000       | 0           |
| 14.     | CONDUCTIVITY   | MMHO/CM  | 553.2649 | 0.6677  | 37.6827        | 0.7443       | 25          |
| 16.     | HARDNESS       | MG/L     | 189.8890 | 0.2341  | 68.5445        | 0.6699       | 19          |
| 17.     | SODIUM         | MG/L     | 10.0335  | 0.8232  | 10.4907        | 0.8249       | 25          |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CHA NO. | SENSOR         | UNITS    | A0         | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|------------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 2.8246     | -0.1273 | 0.0058  | 0.3784         | 0.4279       |
| 2.      | VIALE BIOMASS  | MIL C/ML | 0.2988     | 0.7930  | -0.0940 | 4.3628         | 0.1113       |
| 5.      | RES CHLORINE   | MG/L     | 1.8455     | 0.2492  | 0.0279  | 0.5354         | 0.8038       |
| 6.      | TURBIDITY-SIO2 | MG/L     | -2.3901    | 1.1068  | -0.0124 | 3.2001         | 0.8153       |
| 9.      | TOT ORG CARBON | MG/L     | 13.0369    | -0.7083 | 0.0368  | 2.5456         | 0.9151       |
| 10.     | AMMONIA        | MG/L     | -10.4850   | 2.1577  | -0.0312 | 2.6279         | 0.8442       |
| 12.     | PH             | PH       | 39.1935    | -9.1771 | 0.6446  | 0.1779         | 0.4702       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000     | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 14.     | CONDUCTIVITY   | MMHO/CM  | -3137.0260 | 5.7205  | -0.0017 | 36.2035        | 0.7688       |
| 16.     | HARDNESS       | MG/L     | 169.9953   | 0.3246  | -0.0000 | 68.3870        | 0.6718       |
| 17.     | SODIUM         | MG/L     | 88.7336    | -0.1132 | 0.0058  | 9.8897         | 0.8462       |

LOGARITHMIC CURVE FIT RESULTS ( $\text{LOG}(Y)=A_0 + A_1 \cdot \text{LOG}(X)$ )

| CHA NO. | SENSOR         | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.2077  | 0.1215 | 0.0414         | 0.4716       |
| 2.      | VIALE BIOMASS  | MIL C/ML | -1.0195 | 0.2221 | 0.8317         | 0.7968       |
| 5.      | RES CHLORINE   | MG/L     | -0.3951 | 1.1925 | 0.0520         | 0.7748       |
| 6.      | TURBIDITY-SIO2 | MG/L     | -0.1939 | 1.0662 | 0.1724         | 0.7923       |
| 9.      | TOT ORG CARBON | MG/L     | 0.1177  | 0.8640 | 0.1224         | 0.6907       |
| 10.     | AMMONIA        | MG/L     | -0.0298 | 1.0127 | 0.0752         | 0.8194       |
| 12.     | PH             | PH       | 0.6929  | 0.2195 | 0.0111         | 0.3044       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000  | 0.0000 | 0.0000         | 0.0000       |
| 14.     | CONDUCTIVITY   | MMHO/CM  | 1.1618  | 0.6391 | 0.0105         | 0.7504       |
| 16.     | HARDNESS       | MG/L     | 1.8945  | 0.3695 | 0.0961         | 0.6852       |
| 17.     | SODIUM         | MG/L     | 0.1641  | 0.8995 | 0.0660         | 0.8413       |



REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 5

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X$ )

| CHA NO. | SENSOR         | UNITS    | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 2.2167   | 0.0216  | 0.2994         | 0.5217       | 23          |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.5772   | 0.0467  | 2.5703         | 0.0602       | 23          |
| 3.      | RES CHLORINE   | MG/L     | 0.3230   | -0.0134 | 0.0374         | 0.9989       | 11          |
| 6.      | TURBIDITY-S102 | MG/L     | -0.7085  | 0.2324  | 1.8161         | 0.8141       | 24          |
| 9.      | TOT ORG CARBON | MG/L     | -0.7940  | 0.3658  | 2.0260         | 0.6224       | 22          |
| 10.     | AMMONIA        | MG/L     | 2.0925   | 0.7741  | 2.7142         | 0.7877       | 23          |
| 12.     | PH             | PH       | 3.0646   | 0.6145  | 0.1909         | 0.6511       | 24          |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000   | 0.0000  | 0.0000         | 0.0000       | 0           |
| 14.     | CONDUCTIVITY   | MMMO/CM  | 509.6621 | 0.7013  | 36.8547        | 0.7733       | 24          |
| 16.     | HARDNESS       | MG/L     | 155.7979 | 0.0961  | 27.6299        | 0.7601       | 18          |
| 17.     | SODIUM         | MG/L     | 10.9695  | 0.8009  | 10.7789        | 0.8154       | 24          |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CHA NO. | SENSOR         | UNITS    | A0         | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|------------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 3.1408     | -0.1243 | 0.0054  | 0.2902         | 0.5626       |
| 2.      | VIABLE BIOMASS | MIL C/ML | -1.0417    | 0.9186  | -0.0949 | 2.5428         | 0.1574       |
| 3.      | RES CHLORINE   | MG/L     | 1.5570     | -0.2971 | 0.0170  | 0.0333         | 0.9992       |
| 6.      | TURBIDITY-S102 | MG/L     | 3.9642     | -0.1527 | 0.0062  | 1.1584         | 0.9289       |
| 9.      | TOT ORG CARBON | MG/L     | -0.3872    | 0.3294  | 0.0010  | 2.8261         | 0.6226       |
| 10.     | AMMONIA        | MG/L     | -0.8655    | 1.9308  | -0.0294 | 2.6299         | 0.8023       |
| 12.     | PH             | PH       | 6.1831     | -0.2645 | 0.0621  | 0.1908         | 0.6516       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000     | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 14.     | CONDUCTIVITY   | MMMO/CM  | -2753.1370 | 5.1679  | -0.0015 | 35.6451        | 0.7899       |
| 16.     | HARDNESS       | MG/L     | 169.0051   | 0.0369  | 0.0000  | 27.4604        | 0.7635       |
| 17.     | SODIUM         | MG/L     | 33.5060    | 0.1874  | 0.0038  | 10.5244        | 0.8248       |

LOGARITHMIC CURVE FIT RESULTS ( $\log(Y)=A_0 + A_1 \cdot \log(X)$ )

| CHA NO. | SENSOR         | UNITS    | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.2744  | 0.1095  | 0.0892         | 0.5433       |
| 2.      | VIABLE BIOMASS | MIL C/ML | -0.7399 | 0.0270  | 0.4561         | 0.8257       |
| 3.      | RES CHLORINE   | MG/L     | -0.1395 | -0.6561 | 0.0619         | 0.9967       |
| 6.      | TURBIDITY-S102 | MG/L     | -0.2507 | 0.6411  | 0.1599         | 0.7011       |
| 9.      | TOT ORG CARBON | MG/L     | -1.2575 | 1.5629  | 0.2774         | 0.7133       |
| 10.     | AMMONIA        | MG/L     | -0.0111 | 0.9623  | 0.0793         | 0.7920       |
| 12.     | PH             | PH       | 0.3715  | 0.5865  | 0.0113         | 0.6490       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 14.     | CONDUCTIVITY   | MMMO/CM  | 1.0670  | 0.6695  | 0.0102         | 0.7793       |
| 16.     | HARDNESS       | MG/L     | 1.7095  | 0.2247  | 0.0643         | 0.7425       |
| 17.     | SODIUM         | MG/L     | 0.0625  | 0.9481  | 0.0724         | 0.8353       |

REGRESSION ANALYSIS FOR APR 1, 1970 TO APR 30, 1970

FROM SAMPLE SOURCE 1 TO SAMPLE SOURCE 6

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X$ )

| CHA NO. | SENSOR         | UNITS    | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 2.4286   | 0.0057  | 0.7544         | 0.0261       | 25          |
| 2.      | VIALE BIOMASS  | MIL C/ML | 6.5551   | -0.0354 | 0.8005         | 0.0031       | 25          |
| 3.      | RES CHLORINE   | MG/L     | 1.0010   | 0.1747  | 0.5307         | 0.4555       | 12          |
| 6.      | TURBIDITY-SI02 | MG/L     | 2.1193   | 0.0499  | 0.8998         | 0.5176       | 26          |
| 9.      | TOT ORG CARBON | MG/L     | -0.7105  | 0.3246  | 2.4291         | 0.6609       | 26          |
| 10.     | AMMONIA        | MG/L     | 2.9179   | 0.7134  | 1.4269         | 0.6644       | 26          |
| 12.     | PH             | PH       | 4.4236   | 0.3916  | 0.1563         | 0.5766       | 26          |
| 13.     | TOT ORG CARRON | MG/L     | 0.0000   | 0.0000  |                |              |             |
| 14.     | CONDUCTIVITY   | MMMO/CM  | 462.6919 | 0.7392  | 37.0174        | 0.8193       | 26          |
| 16.     | HARDNESS       | MG/L     | 213.9470 | 0.1758  | 64.7749        | 0.6015       | 20          |
| 17.     | SODIUM         | MG/L     | 4.6733   | 0.8464  | 13.1874        | 0.8393       | 26          |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CHA NO. | SENSOR         | UNITS    | A0         | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|------------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 2.3784     | 0.0136  | -0.0003 | 0.7544         | 0.0266       |
| 2.      | VIALE BIOMASS  | MIL C/ML | 6.3801     | 0.0550  | -0.0002 | 0.8076         | 0.0956       |
| 3.      | RES CHLORINE   | MG/L     | 2.6574     | -0.2253 | 0.0240  | 0.5301         | 0.4572       |
| 6.      | TURBIDITY-SI02 | MG/L     | 1.8429     | 0.0731  | -0.0004 | 0.8958         | 0.5238       |
| 9.      | TOT ORG CARBON | MG/L     | -3.8259    | 0.6206  | -0.0070 | 2.3951         | 0.6803       |
| 10.     | AMMONIA        | MG/L     | -13.6726   | 2.4756  | -0.0446 | 3.2848         | 0.6995       |
| 12.     | PH             | PH       | -15.3731   | 5.9886  | -0.3950 | 0.1504         | 0.6155       |
| 13.     | TOT ORG CARRON | MG/L     | 0.0000     | 0.0000  | 0.0000  |                |              |
| 14.     | CONDUCTIVITY   | MMMO/CM  | -1345.3860 | 3.1935  | -0.0008 | 36.5685        | 0.8232       |
| 16.     | HARDNESS       | MG/L     | 235.4631   | 0.0775  | 0.0000  | 64.9876        | 0.6066       |
| 17.     | SODIUM         | MG/L     | -10.1093   | 1.1563  | -0.0015 | 13.0300        | 0.8435       |

LOGARITHMIC CURVE FIT RESULTS ( $\log(Y)=A_0 + A_1 \cdot \log(X)$ )

| CHA NO. | SENSOR         | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.3294  | 0.0291 | 0.0950         | 0.1275       |
| 2.      | VIALE BIOMASS  | MIL C/ML | -0.7432 | 0.1417 | 0.4289         | 0.5504       |
| 3.      | RES CHLORINE   | MG/L     | -0.1612 | 0.5910 | 0.1019         | 0.3660       |
| 6.      | TURBIDITY-SI02 | MG/L     | 0.0235  | 0.3571 | 0.1213         | 0.5506       |
| 9.      | TOT ORG CARBON | MG/L     | -1.7363 | 1.9194 | 0.3056         | 0.7697       |
| 10.     | AMMONIA        | MG/L     | 0.0329  | 0.9194 | 0.0898         | 0.7250       |
| 12.     | PH             | PH       | 0.5235  | 0.3925 | 0.0095         | 0.5427       |
| 13.     | TOT ORG CARRON | MG/L     | 0.0000  | 0.0000 |                |              |
| 14.     | CONDUCTIVITY   | MMMO/CM  | 0.9669  | 0.7019 | 0.0102         | 0.4232       |
| 16.     | HARDNESS       | MG/L     | 1.7220  | 0.2823 | 0.0893         | 0.6457       |
| 17.     | SODIUM         | MG/L     | -1.6722 | 1.8126 | 0.1706         | 0.8042       |

REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979

FROM SAMPLE SOURCE 3 TO SAMPLE SOURCE 4

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CHA NO. | SENSOR         | UNITS    | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 1.4825   | 0.1814  | 0.4308         | 0.8894       | 26          |
| 2.      | VIABLE BIOMASS | MIL C/ML | 2.1965   | -0.3403 | 4.3135         | 0.1642       | 28          |
| 5.      | RES CHLORINE   | MG/L     | -1.1501  | 1.0997  | 2.1923         | 0.2881       | 12          |
| 6.      | TURBIDITY-SI02 | MG/L     | -0.8113  | 1.1865  | 3.0353         | 0.4597       | 27          |
| 9.      | TOT ORG CARBON | MG/L     | 1.0620   | 0.8187  | 2.1861         | 0.9367       | 23          |
| 10.     | AMMONIA        | MG/L     | -0.2101  | 1.0979  | 2.1912         | 0.9098       | 25          |
| 12.     | PH             | PH       | 0.5456   | 0.4101  | 0.1698         | 0.5302       | 27          |
| 13.     | TOT ORG CARBON | MG/L     | 0.8888   | 0.0000  |                |              |             |
| 14.     | CONDUCTIVITY   | MMHMO/CM | -69.2825 | 1.9552  | 15.2253        | 0.8327       | 27          |
| 16.     | HARDNESS       | MG/L     | 84.1121  | 0.7481  | 47.1114        | 0.6826       | 21          |
| 17.     | SODIUM         | MG/L     | -0.2174  | 0.9954  | 6.6542         | 0.9288       | 27          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CHA NO. | SENSOR         | UNITS    | A0         | A1       | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|------------|----------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 1.9323     | 0.0279   | 0.0105  | 0.4264         | 0.6971       |
| 2.      | VIABLE BIOMASS | MIL C/ML | 3.9831     | -3.5435  | 0.4621  | 4.1490         | 0.3159       |
| 5.      | RES CHLORINE   | MG/L     | -3.5428    | 1.9964   | -0.0824 | 0.3896         | 0.9016       |
| 6.      | TURBIDITY-SI02 | MG/L     | 1.1836     | 0.6644   | 0.0260  | 2.9837         | 0.8648       |
| 9.      | TOT ORG CARBON | MG/L     | 5.6462     | 0.2713   | 0.0117  | 1.8998         | 0.9526       |
| 10.     | AMMONIA        | MG/L     | -0.2357    | 1.8897   | -0.0114 | 2.1763         | 0.9106       |
| 12.     | PH             | PH       | 96.3222    | -24.7216 | 1.7181  | 0.1040         | 0.8538       |
| 13.     | TOT ORG CARBON | MG/L     | 3.0003     | 0.0000   | 0.0000  |                |              |
| 14.     | CONDUCTIVITY   | MMHMO/CM | -3340.8910 | 5.4029   | -0.0014 | 34.7280        | 0.8378       |
| 16.     | HARDNESS       | MG/L     | 351.8313   | -0.9942  | 0.0026  | 63.0509        | 0.7271       |
| 17.     | SODIUM         | MG/L     | 6.7226     | 0.8115   | 0.0912  | 6.6173         | 0.9292       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CHA NO. | SENSOR         | UNITS    | A0      | A1     | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|--------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.1063  | 0.3920 | 0.0669         | 0.4761       |
| 2.      | VIABLE BIOMASS | MIL C/ML | -0.8075 | 0.1437 | 0.8633         | 0.7604       |
| 5.      | RES CHLORINE   | MG/L     | -0.2526 | 1.2644 | 0.0310         | 0.9264       |
| 6.      | TURBIDITY-SI02 | MG/L     | 0.0492  | 0.9904 | 0.1396         | 0.8861       |
| 9.      | TOT ORG CARBON | MG/L     | 0.2250  | 0.7542 | 0.0432         | 0.8707       |
| 10.     | AMMONIA        | MG/L     | -0.0668 | 1.0479 | 0.0545         | 0.8975       |
| 12.     | PH             | PH       | 0.5451  | 0.2048 | 0.0099         | 0.5135       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000  | 0.0000 |                |              |
| 14.     | CONDUCTIVITY   | MMHMO/CM | -0.2084 | 1.0668 | 0.0096         | 0.8542       |
| 16.     | HARDNESS       | MG/L     | 0.8481  | 0.6599 | 0.1022         | 0.6178       |
| 17.     | SODIUM         | MG/L     | -0.0941 | 1.0463 | 0.0362         | 0.9512       |

GAS CHROMATOGRAPH REGRESSION ANALYSIS FOR APR. 1, 1979 TO APR 30, 1979

FROM SAMPLE SOURCE 4 TO SAMPLE SOURCE 5

LINEAR CURVE FIT RESULTS (Y=A0 + A1\*X)

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|-----------------------|---------|---------|----------------|--------------|-------------|
| 1.      | TETRACHLOROETHYLENE   | -1.4173 | 0.4476  | 4.7209         | 0.7879       | 23          |
| 2.      | METHYLENE CHLORIDE    | 23.0903 | -0.0917 | 6.1572         | 0.2948       | 20          |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       | 0           |
| 5.      | CHLOROFORM            | 1.6930  | 0.2243  | 4.4280         | 0.1953       | 23          |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.0962  | 0.0010  | 0.5094         | 0.3905       | 16          |
| 7.      | BROMODICHLOROMETHANE  | 1.3650  | -0.1534 | 0.4636         | 0.2442       | 16          |
| 8.      | TRICHLOROETHYLENE     | 0.2046  | 0.2401  | 2.1981         | 0.4885       | 23          |
| 9.      | DIBROMOCHLOROMETHANE  | 1.1506  | -0.2919 | 0.1686         | 0.4600       | 23          |
| 10.     | BROMOFORM             | 0.6796  | 0.2700  | 0.5941         | 0.5140       | 22          |
| 11.     | TRIHALOMETHANES       | 5.4341  | 0.1171  | 5.1635         | 0.1185       | 23          |
| 12.     | TOTAL HALOCARBONS     | 37.6770 | 0.0159  | 12.1117        | 0.1026       | 23          |

PARABOLIC CURVE FIT RESULTS (Y=A0 + A1\*X + A2\*X\*\*2)

| CAL NO. | COMPOUND              | A0      | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | 0.4030  | 0.1513  | 0.0077  | 4.5678         | 0.7300       |
| 2.      | METHYLENE CHLORIDE    | 25.0769 | -0.5131 | 0.0059  | 5.3525         | 0.5568       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | 21.1113 | -2.1065 | 0.0666  | 4.3677         | 0.2535       |
| 6.      | 1,1,1-TRICHLOROETHANE | 1.0619  | -0.2263 | 0.0134  | 0.5549         | 0.5045       |
| 7.      | BROMODICHLOROMETHANE  | 2.0666  | -0.6914 | 0.0964  | 0.4606         | 0.2602       |
| 8.      | TRICHLOROETHYLENE     | -0.1530 | 0.3343  | -0.0044 | 2.1927         | 0.4924       |
| 9.      | DIBROMOCHLOROMETHANE  | 2.9309  | -3.1170 | 1.0725  | 0.1404         | 0.6243       |
| 10.     | BROMOFORM             | 2.4070  | -1.7719 | 0.5657  | 0.5762         | 0.5556       |
| 11.     | TRIHALOMETHANES       | 14.4303 | -0.6074 | 0.0174  | 5.1530         | 0.1333       |
| 12.     | TOTAL HALOCARBONS     | 35.3212 | 0.0670  | -0.0002 | 12.0043        | 0.1225       |

LOGARITHMIC CURVE FIT RESULTS (LOG(Y)=A0 + A1\*LOG(X))

| CAL NO. | COMPOUND              | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|-----------------------|---------|---------|----------------|--------------|
| 1.      | TETRACHLOROETHYLENE   | -0.3051 | 0.0034  | 0.2094         | 0.0906       |
| 2.      | METHYLENE CHLORIDE    | 1.4199  | -0.1246 | 0.1359         | 0.4915       |
| 3.      | CARBON TETRACHLORIDE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 4.      | 1,2-DICHLOROETHYLENE  | 0.0000  | 0.0000  | 0.0000         | 0.0000       |
| 5.      | CHLOROFORM            | -0.0013 | 0.5213  | 0.2974         | 0.3233       |
| 6.      | 1,1,1-TRICHLOROETHANE | 0.0017  | -0.0789 | 0.3705         | 0.4797       |
| 7.      | BROMODICHLOROMETHANE  | 0.0573  | -0.3469 | 0.2361         | 0.2242       |
| 8.      | TRICHLOROETHYLENE     | -0.3192 | 0.5910  | 0.2694         | 0.6910       |
| 9.      | DIBROMOCHLOROMETHANE  | -0.0714 | -0.4970 | 0.1090         | 0.4045       |
| 10.     | BROMOFORM             | -0.0404 | 0.2616  | 0.2294         | 0.5790       |
| 11.     | TRIHALOMETHANES       | 0.3524  | 0.3660  | -0.2157        | 0.3697       |
| 12.     | TOTAL HALOCARBONS     | 1.5146  | 0.0316  | 0.1200         | 0.2391       |

REGRESSION ANALYSIS FOR APR 1, 1979 TO APR 30, 1979

FROM SAMPLE SOURCE 5 TO SAMPLE SOURCE 6

LINEAR CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X$ )

| CHA NO. | SENSOR         | UNITS    | A0       | A1      | STANDARD ERROR | CORR. COEFF. | SAMPLE SIZE |
|---------|----------------|----------|----------|---------|----------------|--------------|-------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 2.3367   | 0.0635  | 0.7519         | 0.0734       | 25          |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.4752   | -0.0357 | 0.8203         | 0.1221       | 24          |
| 3.      | RES CHLORINE   | MG/L     | 2.6216   | -0.1379 | 0.4649         | 0.6121       | 12          |
| 6.      | TURBIDITY-S102 | MG/L     | 2.2284   | 0.2031  | 0.8870         | 0.5688       | 26          |
| 9.      | TOT ORG CARBON | MG/L     | 0.2702   | 0.8203  | 2.9208         | 0.8031       | 23          |
| 10.     | AMMONIA        | MG/L     | 2.8271   | 0.7911  | 2.6146         | 0.8298       | 25          |
| 12.     | PH             | PH       | 2.8453   | 0.5864  | 0.1193         | 0.7927       | 26          |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000   | 0.0000  |                |              |             |
| 14.     | CONDUCTIVITY   | MMHO/CM  | 18.9414  | 0.9921  | 8.3018         | 0.9920       | 26          |
| 16.     | HARDNESS       | MG/L     | 88.3779  | 0.9619  | 49.6581        | 0.8124       | 20          |
| 17.     | SODIUM         | MG/L     | -16.2452 | 1.1733  | 5.0115         | 0.9735       | 26          |

PARABOLIC CURVE FIT RESULTS ( $Y=A_0 + A_1 \cdot X + A_2 \cdot X^2$ )

| CHA NO. | SENSOR         | UNITS    | A0        | A1      | A2      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|-----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.2835    | 1.2164  | -0.1315 | 0.7384         | 0.2019       |
| 2.      | VIABLE BIOMASS | MIL C/ML | 0.4939    | -0.1099 | 0.0060  | 0.8193         | 0.1314       |
| 3.      | RES CHLORINE   | MG/L     | 3.8472    | -2.7853 | 0.5389  | 0.4349         | 0.6784       |
| 6.      | TURBIDITY-S102 | MG/L     | 0.6361    | 0.7714  | -0.0313 | 0.7854         | 0.7227       |
| 9.      | TOT ORG CARBON | MG/L     | 2.1875    | 0.0606  | 0.0416  | 2.6564         | 0.8005       |
| 10.     | AMMONIA        | MG/L     | 1.3618    | 0.9711  | -0.0051 | 2.6093         | 0.8306       |
| 12.     | PH             | PH       | -53.7068  | 15.8589 | -1.0298 | 0.0818         | 0.9885       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000    | 0.0000  | 0.0000  |                |              |
| 14.     | CONDUCTIVITY   | MMHO/CM  | -130.5771 | 1.1849  | -0.0001 | 8.2946         | 0.9920       |
| 16.     | HARDNESS       | MG/L     | -215.3994 | 3.3954  | -0.0043 | 39.5101        | 0.8859       |
| 17.     | SODIUM         | MG/L     | -28.2577  | 1.5076  | -0.0022 | 4.7545         | 0.9761       |

LOGARITHMIC CURVE FIT RESULTS ( $\log(Y)=A_0 + A_1 \cdot \log(X)$ )

| CHA NO. | SENSOR         | UNITS    | A0      | A1      | STANDARD ERROR | CORR. COEFF. |
|---------|----------------|----------|---------|---------|----------------|--------------|
| 1.      | TOTAL BIOMASS  | MIL C/ML | 0.3874  | 0.1901  | 0.0930         | 0.2305       |
| 2.      | VIABLE BIOMASS | MIL C/ML | -0.7790 | -0.1638 | 0.4275         | 0.5604       |
| 3.      | RES CHLORINE   | MG/L     | 0.3133  | -0.1627 | 0.0805         | 0.6665       |
| 6.      | TURBIDITY-S102 | MG/L     | 0.1936  | 0.4746  | 0.1119         | 0.6720       |
| 9.      | TOT ORG CARBON | MG/L     | 0.0599  | 0.7195  | 0.3391         | 0.7357       |
| 10.     | AMMONIA        | MG/L     | 0.1730  | 0.8417  | 0.0684         | 0.8587       |
| 12.     | PH             | PH       | 0.3170  | 0.6205  | 0.0071         | 0.8059       |
| 13.     | TOT ORG CARBON | MG/L     | 0.0000  | 0.0000  |                |              |
| 14.     | CONDUCTIVITY   | MMHO/CM  | 0.0072  | 0.9983  | 0.0023         | 1.0019       |
| 16.     | HARDNESS       | MG/L     | 0.5872  | 0.8064  | 0.0627         | 0.8526       |
| 17.     | SODIUM         | MG/L     | -2.1592 | 2.1096  | 0.0767         | 0.9629       |

LOG-NORMAL DISTRIBUTION: SEP 3, 1980 TO FEB 28, 1981

|                | AVERAGE | ONE<br>SIGMA | LOG(Y)=F(Z) |            | CHI<br>SQUARE | SAMPLE<br>SIZE |
|----------------|---------|--------------|-------------|------------|---------------|----------------|
|                |         |              | SLOPE       | INTERCEPT  |               |                |
| FLASH MIX PH   |         |              |             |            |               |                |
|                | 10.8    | 0.9          | 0.4223E -1  | 0.1032E 1  | 291.7720      | 149            |
| PLANT FLOW     |         |              |             |            |               |                |
|                | 1.4     | 0.3          | 0.1010E 0   | 0.1385E 0  | 189.0946      | 148            |
| SLUDGE DENSITY |         |              |             |            |               |                |
|                | 0.9     | 0.9          | 0.3121E 0   | -0.1451E 0 | 36.5369       | 149            |
| SLUDGE PUMP    |         |              |             |            |               |                |
|                | 738.4   | 139.7        | 0.2065E 0   | 0.2849E 1  | 212.8979      | 147            |
| LIME FEED VL.  |         |              |             |            |               |                |
|                | 73.1    | 237.2        | 0.5289E 0   | 0.1444E 1  | 63.7471       | 87             |
| EOF..          |         |              |             |            |               |                |

APPENDIX E

STANFORD/WMS DATA FOR ORGANIC REMOVAL BY GAC

This section contains data relative to the performance of activated carbon with age for removal of TOC and trace organics.

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF TOC**

I- Influent Concentration, mg/l; O- Effluent Concentration, mg/l; O/I- Fractional Concentration

| MEDVOLUMES | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       | AVERAGE |      | BMS DATA |     |       | PLANT |     |
|------------|------------|-------|--------------------|-------|------------------|-------|---------|------|----------|-----|-------|-------|-----|
|            | I          | O/I   | O                  | O/I   | O                | O/I   | O       | O/I  | I        | O   | O/I   | I     | O   |
|            |            |       |                    |       |                  |       |         |      |          |     |       |       |     |
| 300        | 6.44       | 0.227 | 0.92               | 0.143 | 5.56             | 0.863 | 2.65    | .411 | 10.2     | 5.9 | 0.578 |       | 6.1 |
| 600        | 7.29       | 0.200 | 1.06               | 0.145 | 5.61             | 0.770 | 2.71    | .372 | 10.6     | 5.4 | 0.509 |       | 4.9 |
| 900        | 9.74       | 0.123 | 2.78               | 0.285 | 6.68             | 0.685 | 3.55    | .365 | 9.3      | 4.7 | 0.505 |       | 4.7 |
| 1200       | 8.08       | 0.250 | 2.15               | 0.266 | 6.86             | 0.849 | 3.68    | .455 | 9.5      | 4.3 | 0.453 |       | 3.6 |
| 1500       | 10.80      | 0.306 | 2.45               | 0.227 | 6.15             | 0.569 | 3.97    | .368 | 11.2     | 4.8 | 0.429 |       | 5.0 |
| 1835       |            |       |                    |       |                  |       |         |      |          |     |       |       |     |
| 2090       | 6.52       | 0.431 | 2.50               | 0.383 | 8.98             | 1.377 | 4.76    | .731 |          |     |       |       |     |
| 2430       | 6.21       | 0.436 | 2.69               | 0.433 | 4.92             | 0.792 | 3.44    | .554 |          |     |       |       |     |
| 3235       | 9.87       | 0.574 |                    |       | 8.20             | 0.831 |         |      |          |     |       |       |     |
| 3660       | 9.25       | 0.505 | 5.12               | 0.554 | 6.52             | 0.705 | 5.44    | .588 |          |     |       |       |     |
| 4125       | 12.60      | 0.571 | 6.46               | 0.513 | 8.27             | 0.656 | 7.31    | .580 |          |     |       |       |     |
| 4465       | 11.90      | 0.595 | 6.61               | 0.555 | 10.50            | 0.882 | 8.06    | .678 |          |     |       |       |     |
| 4800       |            |       |                    |       |                  |       |         |      |          |     |       |       |     |
| 5225       | 7.92       | 0.816 | 5.32               | 0.672 | 7.33             | 0.926 | 6.37    | .804 |          |     |       |       |     |
| 5525       | 8.61       | 0.741 | 7.18               | 0.834 | 7.24             | 0.841 | 6.93    | .805 |          |     |       |       |     |
| 6000       | 8.64       | 0.666 | 5.01               | 0.580 | 7.88             | 0.912 | 6.21    | .719 | 9.3      | 6.3 | 0.677 | 15.1  | 6.0 |
| 6300       | 8.02       | 0.603 | 5.82               | 0.726 | 7.00             | 0.873 | 5.89    | .734 | 8.8      | 5.9 | 0.670 | 18.0  | 5.7 |
| 6600       |            | 4.27  | 5.02               |       |                  |       |         |      | 7.4      | 7.1 | 0.959 | 12.5  | 5.1 |
| 6900       | 6.77       | 1.056 | 5.83               | 0.861 | 6.82             | 1.007 | 6.6     | .975 | 6.6      | 5.9 | 0.894 | 11.4  | 5.4 |
| 7100       | 9.15       | 0.605 | 5.28               | 0.577 | 7.41             | 0.810 | 6.08    | .664 | 10.9     | 3.5 | 0.321 | 10.8  | 4.5 |
| 7820       | 8.93       | 0.566 | 5.44               | 0.609 | 5.59             | 0.637 | 5.39    | .604 | 9.0      | 6.1 | 0.678 | 10.5  | 4.6 |
| 8400       | 8.24       | 0.525 | 5.07               | 0.615 | 6.17             | 0.749 | 5.19    | .630 | 6.7      | 4.0 | 0.597 | 8.7   | 3.7 |
| 8820       | 6.73       | 0.611 | 4.22               | 0.627 | 4.97             | 0.738 | 4.43    | .659 | 6.7      | 3.7 | 0.552 | 8.9   | 3.3 |
| 9400       | 7.14       | 0.672 | 6.04               | 0.846 | 4.91             | 0.688 | 5.25    | .735 | 6.8      | 3.6 | 0.529 | 9.8   | 3.8 |



PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF CHLOROFORM

I - Influent Concentration, µg/l; O - Effluent Concentration, µg/l; O/I - fractional Concentration

| MED VOLUMES | NEW CARBON |       |       | REGENERATED CARBON |       |       | EXHAUSTED CARBON |       |       | AVERAGE |      |       | WMS DATA |   |       |      |  |  |
|-------------|------------|-------|-------|--------------------|-------|-------|------------------|-------|-------|---------|------|-------|----------|---|-------|------|--|--|
|             | I          | O     |       | O                  | O/I   |       | O                | O/I   |       | O       | O/I  |       | GAC      |   | PLANT |      |  |  |
|             |            | O     | O/I   |                    | O     | O/I   |                  | O     | O/I   |         | I    | O     | O/I      | I | O     |      |  |  |
| 300         | 11.24      | 0.20  | 0.018 | 0.32               | 0.026 | 12.13 | 1.079            | 4.1   | 0.375 |         |      |       |          |   |       |      |  |  |
| 600         | 12.06      | 0.82  | 0.068 | 0.26               | 0.022 | 12.88 | 1.068            | 4.7   | 0.386 | 15.8    | 9.2  | 0.582 |          |   |       |      |  |  |
| 900         | 14.58      | 0.41  | 0.028 | 1.13               | 0.078 | 15.16 | 1.041            | 5.6   | 0.382 | 19.5    | 9.6  | 0.492 |          |   |       |      |  |  |
| 1200        | 17.57      | 0.86  | 0.049 | 1.90               | 0.108 | 18.12 | 1.031            | 7.0   | 0.396 |         |      |       |          |   |       |      |  |  |
| 1500        | 22.11      | 2.79  | 0.126 | 6.42               | 0.290 | 19.79 | 0.895            | 9.7   | 0.437 | 20.7    | 11.1 | 0.536 |          |   |       |      |  |  |
| 1835        | 16.56      | 4.68  | 0.283 | 11.43              | 0.690 | 17.26 | 1.042            | 11.1  | 0.007 |         |      |       |          |   |       |      |  |  |
| 2090        | 9.21       | 4.80  | 0.521 | 5.86               | 0.636 | 11.50 | 1.249            | 7.4   | 0.802 |         |      |       |          |   |       |      |  |  |
| 2430        | 10.21      | 10.23 | 1.002 | 8.78               | 0.860 | 9.34  | 0.915            | 9.5   | 0.926 |         |      |       |          |   |       |      |  |  |
| 3235        | 11.69      | 8.13  | 0.695 |                    |       | 13.85 | 1.185            |       |       |         |      |       |          |   |       |      |  |  |
| 3660        | 12.67      | 21.17 | 1.671 | 30.75              | 2.427 | 15.59 | 1.230            | 22.5  | 1.776 | 23.2    | 28.7 | 1.237 |          |   |       | 29.1 |  |  |
| 4125        | 4.98       | 16.02 | 3.217 | 14.18              | 2.847 | 7.93  | 1.592            | 12.71 | 2.552 | 16.9    | 28.2 | 1.669 |          |   |       | 27.5 |  |  |
| 4465        | 6.24       | 12.05 | 1.931 | 9.62               | 1.542 | 5.27  | 0.845            | 9.0   | 1.439 | 16.3    | 23.1 | 1.417 |          |   |       | 19.8 |  |  |
| 4800        | 3.82       | 6.99  | 1.030 | 6.63               | 1.736 |       |                  |       |       | 16.5    | 20.8 | 1.261 |          |   |       | 20.4 |  |  |
| 5225        | 6.93       | 13.15 | 1.898 | 12.69              | 1.831 |       |                  |       |       | 16.1    | 20.7 | 1.286 |          |   |       | 24.8 |  |  |
| 5525        | 4.42       | 15.60 | 3.529 | 15.49              | 3.505 |       |                  |       |       |         |      |       |          |   |       |      |  |  |
| 5825        | 10.33      | 15.54 | 1.504 | 14.28              | 1.382 |       |                  |       |       |         |      |       |          |   |       |      |  |  |
| 6105        | 8.85       | 15.26 | 1.724 | 14.88              | 1.681 |       |                  |       |       | 12.0    | 17.6 | 1.467 |          |   |       | 16.3 |  |  |
| 6600        | 4.88       | 5.54  | 1.730 | 7.79               | 1.596 |       |                  |       |       | 21.0    | 26.4 | 1.257 |          |   |       | 22.8 |  |  |
| 6900        | 7.45       | 10.45 | 1.403 | 10.54              | 1.415 |       |                  |       |       | 18.2    | 19.9 | 1.093 |          |   |       | 20.0 |  |  |
| 7100        | 8.75       | 15.21 | 1.738 | 14.10              | 1.611 |       |                  |       |       | 16.8    | 17.3 | 1.030 |          |   |       | 20.1 |  |  |
| 7820        |            |       |       |                    |       |       |                  |       |       |         |      |       |          |   |       |      |  |  |
| 8400        |            |       |       |                    |       |       |                  |       |       |         |      |       |          |   |       |      |  |  |
| 8820        |            |       |       |                    |       |       |                  |       |       | 17.9    | 24.7 | 1.380 |          |   |       | 16.4 |  |  |
| 9400        |            |       |       |                    |       |       |                  |       |       | 10.1    | 19.3 | 1.911 |          |   |       | 26.1 |  |  |
|             |            |       |       |                    |       |       |                  |       |       |         |      |       |          |   |       | 22.0 |  |  |

PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF TRICHLOROETHANE

I - Influent Concentration, µg/l; O - Effluent Concentration, µg/l; O/I - Fractional Concentration

| BED VOLUMES | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       | AVERAGE |       | GAC   |      |      | PLANT |      |
|-------------|------------|-------|--------------------|-------|------------------|-------|---------|-------|-------|------|------|-------|------|
|             | I          | O     | O/I                | O     | O/I              | O     | O/I     | O     | I     | O    | O/I  | I     | O    |
|             |            |       |                    |       |                  |       |         |       |       |      |      |       |      |
| 300         | 10.78      | 0.04  | 0.004              | 0.04  | 0.004            | 12.27 | 1.138   | 4.12  | .382  |      |      |       |      |
| 600         | 22.02      | 0.19  | 0.009              | 0.04  | 0.002            | 19.44 | 0.883   | 6.56  | .298  | 10.9 | 2.1  | 0.193 |      |
| 900         | 24.32      | 0.00  | 0.000              | 0.07  | 0.003            | 22.73 | 0.935   |       |       | 10.6 | 2.4  | 0.226 |      |
| 1200        | 61.15      | 0.03  | 0.000              | 0.22  | 0.004            | 38.55 | 0.630   | 12.93 | .212  |      |      |       |      |
| 1500        | 64.69      | 0.20  | 0.003              | 1.94  | 0.030            | 42.21 | 0.652   | 14.78 | .229  | 26.4 | 4.2  | 0.159 |      |
| 1835        | 98.08      | 0.43  | 0.004              | 5.71  | 0.058            | 55.34 | 0.564   | 20.49 | .209  |      |      |       |      |
| 2000        | 15.79      | 0.47  | 0.030              | 1.93  | 0.122            | 21.74 | 1.377   | 8.05  | .510  |      |      |       |      |
| 2430        | 15.31      | 3.62  | 0.236              | 3.64  | 0.238            | 15.09 | 0.986   | 7.45  | .487  |      |      |       |      |
| 3235        | 37.82      | 5.35  | 0.141              |       |                  | 0.17  | 1.133   |       |       |      |      |       |      |
| 3650        | 31.32      | 21.60 | 0.690              | 36.45 | 1.164            | 37.70 | 1.204   | 31.92 | 1.019 | 63.5 | 19.9 | 0.313 | 15.9 |
| 4125        | 5.01       | 17.62 | 3.517              | 16.04 | 3.202            | 15.60 | 3.114   | 16.42 | 3.277 | 5.7  | 13.9 | 2.439 | 14.0 |
| 4465        | 9.98       | 14.28 | 1.431              | 12.76 | 1.279            | 7.54  | 0.756   | 11.53 | 1.155 | 13.6 | 13.3 | 0.978 | 12.3 |
| 4800        | 2.46       | 6.98  | 2.837              | 7.37  | 2.996            |       |         |       |       | 5.1  | 9.0  | 1.765 | 9.4  |
| 5225        | 0.23       | 15.67 | 68.130             | 15.38 | 66.870           |       |         |       |       | 1.0  | 6.1  | 6.1   | 4.5  |
| 5525        | 0.17       | 19.54 | 114.941            | 22.36 | 131.529          |       |         |       |       |      |      |       |      |
| 5825        | 1.01       | 15.68 | 15.525             | 15.06 | 14.911           |       |         |       |       |      |      |       |      |
| 6100        | 0.98       | 15.66 | 15.980             | 16.22 | 16.551           |       |         |       |       | 0.8  | 5.6  | 7.0   | 5.2  |
| 6600        | 0.42       | 8.57  | 20.405             | 8.06  | 19.190           |       |         |       |       | 0.6  | 6.6  | 11.0  | 2.1  |
| 6900        | 0.48       | 8.11  | 16.896             | 8.02  | 16.708           |       |         |       |       | 0.4  | 4.9  | 12.25 | 1.2  |
| 7100        | 5.54       | 15.59 | 2.814              | 13.85 | 2.530            |       |         |       |       | 0.6  | 3.3  | 5.5   | 2.0  |
| 7820        |            |       |                    |       |                  |       |         |       |       |      |      |       |      |
| 8400        |            |       |                    |       |                  |       |         |       |       |      |      |       |      |
| 8820        |            |       |                    |       |                  |       |         |       |       | 0.4  | 4.0  | 10.0  | 1.5  |
| 9400        |            |       |                    |       |                  |       |         |       |       | 0.4  | 2.7  | 6.75  | 1.9  |
|             |            |       |                    |       |                  |       |         |       |       |      |      |       | 3.2  |

PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF BROMODICHLOROMETHANE

I- Influent Concentration, µg/l; O- Effluent Concentration, µg/l; O/I- Fractional Concentration

| BED VOLUMES | NEW CARBON |      |       | REGENERATED CARBON |       |       | EXHAUSTED CARBON |       |     | AVERAGE |       |      | WMS DATA |       |   | PLANT |     |      |
|-------------|------------|------|-------|--------------------|-------|-------|------------------|-------|-----|---------|-------|------|----------|-------|---|-------|-----|------|
|             | I          | O    | O/I   | O                  | O/I   | O     | O/I              | O     | O/I | O       | O/I   | I    | O        | O/I   | I | O     | O/I |      |
|             | 300        | 2.57 | 0.00  | 0.000              | 0.00  | 0.000 | 1.70             | 0.637 |     |         |       |      |          |       |   |       |     |      |
| 600         | 7.14       | 0.00 | 0.000 | 0.00               | 0.000 | 2.98  | 0.720            |       |     |         |       | 7.6  | 3.5      | 0.461 |   |       |     |      |
| 900         | 2.51       | 0.00 | 0.000 | 0.01               | 0.002 | 3.93  | 0.713            |       |     |         |       | 10.3 | 4.5      | 0.437 |   |       |     |      |
| 1200        | 4.34       | 0.00 | 0.000 | 0.05               | 0.012 | 4.41  | 1.016            |       |     |         |       |      |          |       |   |       |     |      |
| 1500        | 4.46       | 0.02 | 0.004 | 0.29               | 0.065 | 4.39  | 0.984            |       |     | 1.57    | .351  | 6.1  | 4.0      | 0.656 |   |       |     |      |
| 1835        | 3.45       | 0.30 | 0.087 | 0.71               | 0.206 | 3.70  | 1.072            |       |     | 1.57    | .455  |      |          |       |   |       |     |      |
| 2090        | 1.60       | 0.07 | 0.044 | 0.31               | 0.194 | 2.07  | 1.294            |       |     | .82     | .510  |      |          |       |   |       |     |      |
| 2430        | 1.87       | 0.39 | 0.209 | 0.47               | 0.251 | 1.71  | 0.914            |       |     | .86     | .458  |      |          |       |   |       |     |      |
| 3235        | 1.59       | 0.54 | 0.340 |                    |       | 2.27  | 1.428            |       |     |         |       |      |          |       |   |       |     |      |
| 3660        | 2.34       | 2.21 | 0.944 | 3.64               | 1.556 | 2.57  | 1.098            |       |     | 2.81    | 1.199 | 8.3  | 8.0      | 0.964 |   |       |     | 8.7  |
| 4125        | 1.82       | 1.77 | 0.973 | 1.57               | 0.863 | 1.51  | 0.830            |       |     | 1.62    | .888  | 7.4  | 7.7      | 1.041 |   |       |     | 8.4  |
| 4465        | 2.06       | 1.65 | 0.801 | 1.51               | 0.733 | 1.16  | 0.563            |       |     | 1.44    | .699  | 7.5  | 7.1      | 0.947 |   |       |     | 6.8  |
| 4800        | 1.77       | 1.03 | 0.582 | 1.19               | 0.672 |       |                  |       |     | 1.11    | .627  | 8.8  | 8.3      | 0.943 |   |       |     | 8.3  |
| 5225        | 8.26       | 2.75 | 0.333 | 2.78               | 0.337 |       |                  |       |     | 2.77    | .335  | 9.4  | 8.8      | 0.936 |   |       |     | 11.2 |
| 5525        | 3.58       | 4.00 | 1.087 | 5.06               | 1.375 |       |                  |       |     | 4.53    | 1.231 |      |          |       |   |       |     |      |
| 6000        | 11.21      | 5.81 | 0.518 | 6.40               | 0.571 |       |                  |       |     | 6.11    | .545  | 7.0  | 11.1     | 1.586 |   |       |     | 8.3  |
| 6300        | 8.97       | 5.95 | 0.663 | 7.97               | 0.889 |       |                  |       |     | 6.96    | .776  | 20.4 | 12.8     | 0.627 |   |       |     | 14.2 |
| 6600        | 4.63       | 3.92 | 0.847 | 4.83               | 1.043 |       |                  |       |     | 4.38    | .945  | 15.7 | 11.0     | 0.701 |   |       |     | 21.0 |
| 6900        | 6.04       | 3.82 | 0.632 | 4.61               | 0.763 |       |                  |       |     | 4.22    | .698  | 12.0 | 9.6      | 0.800 |   |       |     | 17.9 |
| 7100        | 5.80       | 8.81 | 1.519 | 8.12               | 1.400 |       |                  |       |     | 8.46    | 1.459 |      |          |       |   |       |     | 11.6 |
| 7820        |            |      |       |                    |       |       |                  |       |     |         |       |      |          |       |   |       |     | 13.7 |
| 8400        |            |      |       |                    |       |       |                  |       |     |         |       | 23.2 | 22.6     | 0.974 |   |       |     | 20.4 |
| 8420        |            |      |       |                    |       |       |                  |       |     |         |       | 15.7 | 21.5     | 1.369 |   |       |     | 12.7 |
| 9400        |            |      |       |                    |       |       |                  |       |     |         |       |      |          |       |   |       |     | 19.5 |

ORIGINAL COPY  
OF POOR QUALITY

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF TRICHLOROETHYLENE**

I - Influent Concentration,  $\mu\text{g/l}$ ; O - Effluent Concentration,  $\mu\text{g/l}$ ; O/I - Fractional Concentration

| BED VOLUMES | NEW CARBON |      | REGENERATED CARBON |        | EXHAUSTED CARBON |       | AVERAGE |        | WMS DATA |     |       |       |
|-------------|------------|------|--------------------|--------|------------------|-------|---------|--------|----------|-----|-------|-------|
|             | I          | O    | O                  | O/I    | O                | O/I   | O       | O/I    | I        | O   | O/I   | PLANT |
| 300         | 3.14       | 0.00 | 0.00               | 0.000  | 1.64             | 0.522 |         |        |          |     |       |       |
| 600         | 23.24      | 0.04 | 0.00               | 0.000  | 4.85             | 0.209 |         |        | 18.8     | 2.1 | 0.112 |       |
| 900         | 12.55      | 0.00 | 0.00               | 0.000  | 4.94             | 0.394 |         |        | 9.0      | 2.2 | 0.244 |       |
| 1200        | 9.72       | 0.00 | 0.00               | 0.003  | 6.32             | 0.650 |         |        |          | 2.5 |       |       |
| 1500        | 19.02      | 0.29 | 0.015              | 0.039  | 7.18             | 0.377 | 2.74    | .144   | 11.9     | 2.1 | 0.176 |       |
| 1835        | 28.27      | 0.00 | 0.000              | 0.004  | 8.10             | 0.287 |         |        |          |     |       |       |
| 2090        | 8.36       | 0.00 | 0.000              | 0.000  | 4.33             | 0.518 |         |        |          |     |       |       |
| 2430        | 4.13       | 0.00 | 0.000              | 0.000  | 2.96             | 0.717 |         |        |          |     |       |       |
| 3235        | 8.00       | 0.00 | 0.000              |        | 5.60             | 0.700 |         |        |          |     |       |       |
| 3660        | 5.93       | 0.00 | 0.000              | 0.000  | 4.90             | 0.826 |         |        | 10.7     | 2.6 | 0.243 | 2.1   |
| 4125        | 1.80       | 0.30 | 0.167              | 0.306  | 3.49             | 1.339 | 1.45    | .804   | 4.6      | 2.5 | 0.543 | 2.3   |
| 4465        | 3.02       | 0.26 | 0.086              | 0.182  | 1.61             | 0.533 | .81     | .267   | 6.6      | 2.3 | 0.348 | 1.8   |
| 5000        | 0.58       | 0.23 | 0.397              | 0.49   |                  |       | .36     | .621   | 2.3      | 2.3 | 1.0   | 1.9   |
| 5225        | 0.09       | 0.67 | 7.444              | 11.444 |                  |       | .85     | 9.444  | 1.1      | 1.6 | 1.455 | 2.7   |
| 5575        | 0.10       | 1.22 | 12.200             | 24.000 |                  |       | 1.81    | 18.1   |          |     |       |       |
| 6000        | 0.00       | 1.51 |                    | 1.95   |                  |       |         |        | 1.1      | 1.6 | 1.455 | 2.3   |
| 6300        | 0.00       | 1.22 |                    | 2.35   |                  |       |         |        | 1.0      | 1.9 | 1.9   | 2.0   |
| 6600        | 0.00       | 0.73 |                    | 1.35   |                  |       |         |        | 0.9      | 1.7 | 1.889 | 1.8   |
| 6900        | 0.04       | 0.72 | 18.000             | 28.750 |                  |       | .935    | 23.375 | 1.0      | 1.5 | 1.5   | 1.8   |
| 7100        | 2.32       | 0.00 | 0.000              | 1.125  |                  |       |         |        |          |     |       | 1.4   |
| 7820        |            |      |                    |        |                  |       |         |        |          |     |       |       |
| 8400        |            |      |                    |        |                  |       |         |        | 0.7      | 1.9 | 2.714 | 1.5   |
| 8820        |            |      |                    |        |                  |       |         |        | 0.7      | 1.6 | 2.286 | 1.9   |
| 9400        |            |      |                    |        |                  |       |         |        |          |     |       | 1.6   |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF DIBROMOCHLOROMETHANE**

I - Influent Concentration, µg/l; O - Effluent Concentration, µg/l; O/I - Fractional Concentration

| BED VOLUMES | NEW CARBON |      | REGENERATED CARBON |       | EXHAUSTED CARBON |       | AVERAGE |      | WMS DATA |      |       | PLANT |      |
|-------------|------------|------|--------------------|-------|------------------|-------|---------|------|----------|------|-------|-------|------|
|             | I          | O/I  | O                  | O/I   | O                | O/I   | O       | O/I  | I        | O    | O/I   | I     | O    |
|             | 300        | 1.11 | 0.00               | 0.00  | 0.000            | 0.44  | 0.396   |      |          |      |       |       |      |
| 600         | 3.37       | 0.00 | 0.00               | 0.000 | 0.16             | 0.344 |         |      | 5.5      | 1.8  | 0.327 |       |      |
| 900         | 5.04       | 0.00 | 0.00               | 0.000 | 1.79             | 0.355 |         |      | 8.3      | 2.8  | 0.337 |       |      |
| 1200        | 2.85       | 0.00 | 0.00               | 0.000 | 2.25             | 0.789 |         |      |          |      |       |       |      |
| 1500        | 2.11       | 0.00 | 0.00               | 0.033 | 2.09             | 0.991 |         |      | 4.2      | 2.1  | 0.5   |       |      |
| 1835        | 1.46       | 0.00 | 0.00               | 0.130 | 1.85             | 1.267 |         |      |          |      |       |       |      |
| 2090        | 0.63       | 0.00 | 0.00               | 0.206 | 1.47             | 2.333 |         |      |          |      |       |       |      |
| 2430        | 0.86       | 0.08 | 0.093              | 0.19  | 0.72             | 0.837 | .33     | .384 |          |      |       |       |      |
| 3235        | 0.79       | 0.10 | 0.127              |       | 1.01             | 1.278 |         |      |          |      |       |       |      |
| 3660        | 1.28       | 0.43 | 0.336              | 0.91  | 1.09             | 0.852 | .81     | .633 | 3.3      | 2.0  | 0.606 |       | 9.8  |
| 4125        | 1.35       | 0.40 | 0.296              | 0.43  | 0.74             | 0.549 | .52     | .388 | 4.3      | 2.6  | 0.605 |       | 3.1  |
| 4465        | 1.21       | 0.42 | 0.347              | 0.48  | 0.60             | 0.496 | .50     | .413 | 4.9      | 3.5  | 0.714 |       | 1.7  |
| 4800        | 1.27       | 0.32 | 0.252              | 0.54  |                  |       | .43     | .339 | 3.8      | 3.8  | 1.0   |       | 3.0  |
| 5225        | 7.33       | 1.03 | 0.141              | 1.08  |                  |       | 1.06    | .144 | 3.6      | 2.7  | 0.75  | 4.7   | 2.2  |
| 5525        | 2.95       | 1.80 | 0.610              | 2.22  |                  |       | 2.01    | .681 |          |      |       |       |      |
| 6000        | 10.89      | 2.65 | 0.243              | 3.17  |                  |       | 2.91    | .267 |          |      |       |       |      |
| 6300        | 7.69       | 2.77 | 0.360              | 4.52  |                  |       | 3.65    | .474 | 2.4      | 5.5  | 2.292 | 3.9   | 3.3  |
| 6600        | 4.26       | 2.12 | 0.498              | 3.09  |                  |       | 2.61    | .612 | 11.7     | 3.5  | 0.299 | 7.2   | 5.1  |
| 6900        | 6.51       | 2.07 | 0.318              | 2.91  |                  |       | 2.49    | .382 | 6.3      | 2.6  | 0.382 | 9.8   | 3.7  |
| 7100        | 6.28       | 5.62 | 0.895              | 6.79  |                  |       | 6.21    | .988 | 4.3      | 2.5  | 0.581 | 8.7   | 3.4  |
| 7820        |            |      |                    |       |                  |       |         |      |          |      |       |       |      |
| 8400        |            |      |                    |       |                  |       |         |      |          |      |       |       |      |
| 8820        |            |      |                    |       |                  |       |         |      | 16.9     | 11.8 | 0.698 | 11.8  | 14.6 |
| 9400        |            |      |                    |       |                  |       |         |      | 8.1      | 8.8  | 1.086 | 5.8   | 11.4 |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF TETRACHLOROETHYLENE**

I - Influent Concentration, µg/l; O - Effluent Concentration, µg/l; O/I - Fractional Concentration

| BED VOLUMES | NEW CARBON |      | REGENERATED CARBON |      | EXHAUSTED CARBON |       | AVERAGE |      | WMS DATA |      |     | PLANT |     |
|-------------|------------|------|--------------------|------|------------------|-------|---------|------|----------|------|-----|-------|-----|
|             | I          | O    | O/I                | O    | O/I              | O     | O/I     | O    | O/I      | I    | O   |       | O/I |
| 300         | 6.03       | 0.02 | 0.003              | 0.03 | 0.005            | 1.32  | 0.219   | .46  | .076     |      |     |       |     |
| 600         | 13.79      | 0.19 | 0.014              | 0.10 | 0.007            | 2.13  | 0.154   | .81  | .068     | 15.6 | 4.8 | 0.308 |     |
| 900         | 20.19      | 0.13 | 0.006              | 0.07 | 0.003            | 2.42  | 0.120   | .87  | .043     | 17.0 | 4.5 | 0.265 |     |
| 1200        | 37.42      | 0.04 | 0.001              | 0.06 | 0.002            | 3.75  | 0.100   | 1.28 | .034     |      | 3.2 |       |     |
| 1500        | 73.81      | 0.11 | 0.001              | 0.40 | 0.005            | 5.73  | 0.078   | 2.08 | .028     | 47.4 | 6.4 | 0.135 |     |
| 1800        | 103.85     | 0.29 | 0.003              | 0.17 | 0.002            | 10.69 | 0.103   | 3.72 | .036     |      |     |       |     |
| 2000        | 27.72      | 0.12 | 0.004              | 0.11 | 0.004            | 6.58  | 0.237   | 2.27 | .082     |      |     |       |     |
| 2400        | 14.13      | 0.39 | 0.028              | 0.23 | 0.016            | 4.33  | 0.306   | 1.65 | .117     |      |     |       |     |
| 3200        | 18.96      | 0.05 | 0.003              |      |                  | 6.06  | 0.320   |      |          |      |     |       |     |
| 3600        | 7.70       | 0.06 | 0.008              | 0.27 | 0.035            | 4.85  | 0.630   | 1.73 | .224     | 11.9 | 4.9 | 0.412 | 3.8 |
| 4125        | 1.65       | 0.24 | 0.145              | 0.32 | 0.194            | 4.20  | 2.545   | 1.59 | .962     | 4.1  | 4.0 | 0.976 | 4.0 |
| 4400        | 2.66       | 0.05 | 0.019              | 0.15 | 0.056            | 1.38  | 0.519   | .53  | .198     | 9.5  | 4.2 | 0.442 | 3.3 |
| 4800        | 0.29       | 0.07 | 0.241              | 0.27 | 0.901            |       |         |      |          | 3.1  | 3.6 | 1.161 | 3.6 |
| 5225        | 0.00       | 0.11 |                    | 0.24 |                  |       |         |      |          | 2.4  | 2.9 | 1.208 | 2.8 |
| 5525        | 0.09       | 0.33 | 3.667              | 0.54 | 6.000            |       |         |      |          |      |     |       |     |
| 6000        | 0.23       | 0.28 | 1.217              | 0.51 | 2.217            |       |         |      |          | 2.6  | 3.0 | 1.154 | 4.4 |
| 6300        | 0.38       | 0.30 | 0.789              | 0.73 | 1.921            |       |         |      |          | 1.9  | 2.3 | 1.211 | 3.5 |
| 6600        | 0.39       | 0.22 | 0.564              | 0.46 | 1.179            |       |         |      |          | 1.2  | 1.7 | 1.417 | 1.6 |
| 6900        | 0.21       | 0.22 | 1.048              | 0.34 | 1.619            |       |         |      |          | 1.4  | 1.6 | 1.143 | 2.3 |
| 7100        | 2.08       | 0.89 | 0.428              | 1.40 | 0.673            |       |         |      |          |      |     |       |     |
| 7820        |            |      |                    |      |                  |       |         |      |          |      |     |       |     |
| 8400        |            |      |                    |      |                  |       |         |      |          | 2.5  | 2.7 | 1.08  | 2.1 |
| 8820        |            |      |                    |      |                  |       |         |      |          | 4.5  | 4.2 | 0.933 | 4.5 |
| 9400        |            |      |                    |      |                  |       |         |      |          |      |     |       |     |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF BROMOFORM**

I - Influent Concentration,  $\mu$ g/l; O - Effluent Concentration,  $\mu$ g/l; O/I - Fractional Concentration

| BED VOLUMES | NEW CARBON |      | REGENERATED CARBON |       | EXHAUSTED CARBON |       | AVERAGE |       | WMS DATA |       |       | PLANT |        |
|-------------|------------|------|--------------------|-------|------------------|-------|---------|-------|----------|-------|-------|-------|--------|
|             | I          | O    | O                  | O/I   | O                | O/I   | O       | O/I   | I        | O     | O/I   | I     | O      |
| 300         | 0.56       | 0.02 | 0.00               | 0.036 | 0.00             | 0.000 | 0.13    | 0.232 |          |       |       |       |        |
| 600         | 1.99       | 0.00 | 0.00               | 0.000 | 0.00             | 0.000 | 0.32    | 0.161 | 12.8     | 10.0  | 0.781 |       |        |
| 900         | 3.48       | 0.00 | 0.00               | 0.000 | 0.00             | 0.000 | 0.73    | 0.210 | 19.7     | 10.3  | 0.523 |       |        |
| 1200        | 1.44       | 0.00 | 0.00               | 0.000 | 0.00             | 0.000 | 1.01    | 0.701 |          |       |       |       |        |
| 1500        | 0.30       | 0.00 | 0.00               | 0.000 | 0.00             | 0.000 | 0.84    | 2.800 | 7.6      | 9.8   | 1.289 |       |        |
| 1835        | 0.35       | 0.00 | 0.05               | 0.000 | 0.05             | 0.143 | 0.71    | 2.029 |          |       |       |       |        |
| 2090        | 0.14       | 0.00 | 0.03               | 0.000 | 0.03             | 0.214 | 0.36    | 2.571 |          |       |       |       |        |
| 2430        | 0.17       | 0.74 | 0.64               | 4.353 | 0.64             | 3.765 | 0.43    | 2.529 | 0.60     | 3.549 |       |       |        |
| 3235        | 0.39       | 0.00 | 0.00               | 0.000 |                  |       | 0.46    | 1.179 |          |       |       |       |        |
| 3660        | 0.55       | 0.07 | 0.22               | 0.127 | 0.22             | 0.400 | 0.36    | 0.655 | 0.22     | 0.394 | 8.5   | 9.6   | 1.129  |
| 4125        | 0.55       | 0.00 | 0.13               | 0.000 | 0.13             | 0.236 | 0.34    | 0.618 | 0.16     | 0.285 | 8.6   | 8.6   | 1.0    |
| 4465        | 0.00       | 0.00 | 0.08               |       | 0.08             |       | 0.14    |       | 0.07     |       |       |       | 4.0    |
| 4800        | 0.55       | 0.11 | 0.00               | 0.200 | 0.00             | 0.000 |         |       |          |       |       |       | 3.9    |
| 5225        | 2.98       | 0.22 | 0.12               | 0.074 | 0.12             | 0.040 |         |       | 0.17     | 0.057 | 2.9   | 3.5   | 1.207  |
| 5525        | 1.05       | 0.34 | 0.42               | 0.324 | 0.42             | 0.400 |         |       | 0.38     | 0.362 |       |       |        |
| 6000        | 2.84       | 0.51 | 0.54               | 0.180 | 0.54             | 0.190 |         |       | 0.53     | 0.185 | 0.3   | 3.8   | 12.667 |
| 6300        | 2.13       | 0.46 | 0.94               | 0.216 | 0.94             | 0.441 |         |       | 0.70     | 0.329 | 1.2   | 0.0   | 0      |
| 6600        | 1.15       | 0.36 | 0.59               | 0.313 | 0.59             | 0.513 |         |       | 0.48     | 0.413 | 1.0   | 0.0   | 0      |
| 6900        | 1.77       | 0.39 | 0.55               | 0.220 | 0.55             | 0.311 |         |       | 0.47     | 0.266 | 0.1   | 0.1   | 1.0    |
| 7100        | 0.23       | 0.20 | 0.25               | 0.870 | 0.25             | 1.067 |         |       | 0.23     | 0.978 |       |       |        |
| 7820        |            |      |                    |       |                  |       |         |       |          |       |       |       |        |
| 8400        |            |      |                    |       |                  |       |         |       |          |       |       |       |        |
| 8820        |            |      |                    |       |                  |       |         |       |          |       | 0.1   | 1.8   | 18.0   |
| 9400        |            |      |                    |       |                  |       |         |       |          |       | 0.0   | 0.0   | 0      |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF ETHYLBENZENE**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUMES | I   | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|-----|------------|-------|--------------------|-------|------------------|-------|
|             |     | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 45  | 115        | 2.556 | 70                 | 1.556 | 85               | 1.889 |
| 600         | 325 | 35         | 0.108 | 35                 | 0.108 | 95               | 0.292 |
| 900         | 125 | 15         | 0.120 | 20                 | 0.160 | 110              | 0.880 |
| 1240        | 240 | 105        | 0.438 | 25                 | 0.104 | 130              | 0.542 |
| 1580        | 55  | 35         | 0.636 | 45                 | 0.818 | 250              | 4.545 |
| 1835        | 90  | 120        | 1.333 | 45                 | 0.500 | 150              | 1.667 |
| 2090        | 25  | 25         | 1.000 | 0                  | 0.000 | 35               | 1.400 |
| 2430        | 135 | 25         | 0.185 | 0                  | 0.000 | 20               | 0.148 |
| 3235        | 60  | 130        | 2.167 |                    |       | 95               | 1.583 |
| 3660        | 35  | 0          | 0.000 | 30                 | 0.857 | 30               | 0.857 |
| 4125        | 80  | 35         | 0.438 | 0                  | 0.000 | 45               | 0.563 |
| 4465        | 75  | 50         | 0.667 | 30                 | 0.400 | 25               | 0.333 |
| 4800        | 65  | 45         | 0.692 | 35                 | 0.538 |                  |       |
| 5225        | 200 | 40         | 0.200 | 230                | 1.150 |                  |       |
| 5525        | 60  |            |       | 235                | 3.917 |                  |       |
| 6000        | 220 | 110        | 0.500 | 40                 | 0.182 |                  |       |
| 6300        | 245 | 175        | 0.714 | 80                 | 0.327 |                  |       |
| 6600        | 510 | 75         | 0.147 | 145                | 0.284 |                  |       |
| 6900        | 270 | 125        | 0.463 | 60                 | 0.222 |                  |       |
| 7100        | 360 | 155        | 0.431 | 135                | 0.375 |                  |       |
| 9400        | 135 | 25         | 0.185 | 50                 | 0.370 |                  |       |



**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF CHLOROBENZENE**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUMES | I    | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|------|------------|-------|--------------------|-------|------------------|-------|
|             |      | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 215  | 100        | 0.465 | 9                  | 0.042 | 475              | 2.209 |
| 600         | 885  | 130        | 0.147 | 170                | 0.192 | 245              | 0.277 |
| 900         | 270  | 25         | 0.093 | 45                 | 0.167 | 535              | 1.981 |
| 1200        | 1040 | 295        | 0.160 | 100                | 0.054 | 390              | 0.212 |
| 1500        | 1190 | 180        | 0.151 | 120                | 0.101 | 1015             | 0.853 |
| 1835        | 1005 | 390        | 0.388 | 105                | 0.104 | 560              | 0.557 |
| 2090        | 135  | 100        | 0.741 | 40                 | 0.296 | 200              | 1.481 |
| 2430        | 730  | 120        | 0.164 | 45                 | 0.062 | 160              | 0.219 |
| 3235        | 1550 | 345        | 0.223 |                    |       | 480              | 0.310 |
| 3660        | 120  | 50         | 0.417 | 60                 | 0.500 | 185              | 1.542 |
| 4125        | 300  | 125        | 0.417 | 125                | 0.417 | 270              | 0.900 |
| 4465        | 295  | 150        | 0.508 | 135                | 0.458 | 190              | 0.644 |
| 4800        | 190  | 165        | 0.868 | 80                 | 0.421 |                  |       |
| 5225        | 260  | 120        | 0.462 | 220                | 0.846 |                  |       |
| 5525        | 195  |            |       | 255                | 1.308 |                  |       |
| 6000        | 345  | 235        | 0.681 | 60                 | 0.174 |                  |       |
| 6300        | 315  | 345        | 1.095 | 245                | 0.778 |                  |       |
| 6600        | 890  | 510        | 0.573 | 135                | 0.152 |                  |       |
| 6900        | 525  | 575        | 1.095 | 295                | 0.562 |                  |       |
| 7100        | 9405 | 2050       | 0.218 | 580                | 0.062 |                  |       |
| 9400        | 445  | 230        | 0.517 | 385                | 0.865 |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF 1, 3 DICHLOROBENZENE**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUMES | I    | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|------|------------|-------|--------------------|-------|------------------|-------|
|             |      | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 1315 | 35         | 0.027 | 15                 | 0.011 | 215              | 0.163 |
| 600         | 1610 | 50         | 0.031 | 20                 | 0.012 | 190              | 0.118 |
| 900         | 4945 | 0          | 0.000 | 70                 | 0.014 | 180              | 0.036 |
| 1200        | 4095 | 70         | 0.017 | 20                 | 0.005 | 80               | 0.020 |
| 1500        | 4015 | 20         | 0.005 | 15                 | 0.004 | 295              | 0.073 |
| 1835        | 5930 | 100        | 0.017 | 25                 | 0.004 | 180              | 0.030 |
| 2090        | 135  | 0          | 0.000 | 25                 | 0.185 | 110              | 0.815 |
| 2430        | 1965 | 25         | 0.013 | 0                  | 0.000 | 250              | 0.127 |
| 3235        | 905  | 0          | 0.000 |                    |       | 215              | 0.238 |
| 3660        | 445  | 20         | 0.045 | 20                 | 0.045 | 145              | 0.326 |
| 4125        | 620  | 20         | 0.032 | 30                 | 0.048 | 195              | 0.315 |
| 4465        | 275  | 15         | 0.055 | 50                 | 0.182 | 160              | 0.582 |
| 4800        | 165  | 200        | 1.212 | 150                | 0.909 |                  |       |
| 5225        | 1575 | 75         | 0.048 | 250                | 0.159 |                  |       |
| 5525        | 1980 |            |       | 325                | 0.164 |                  |       |
| 6000        | 375  | 210        | 0.560 | 50                 | 0.133 |                  |       |
| 6300        | 585  | 160        | 0.274 | 100                | 0.171 |                  |       |
| 6600        | 575  | 40         | 0.070 | 95                 | 0.165 |                  |       |
| 6900        | 610  | 640        | 1.049 | 90                 | 0.148 |                  |       |
| 7100        | 1183 | 195        | 0.165 | 30                 | 0.025 |                  |       |
| 9400        | 130  | 60         | 0.462 | 95                 | 0.731 |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF 1, 4 DICHLOROBENZENE**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUME | I    | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|------------|------|------------|-------|--------------------|-------|------------------|-------|
|            |      | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300        | 2010 | 15         | 0.007 | 65                 | 0.032 | 190              | 0.095 |
| 600        | 2815 | 345        | 0.123 | 70                 | 0.025 | 190              | 0.067 |
| 900        | 5070 | 0          | 0     | 105                | 0.021 | 145              | 0.029 |
| 1200       | 4545 | 165        | 0.036 | 55                 | 0.012 | 195              | 0.043 |
| 1500       | 4415 | 55         | 0.012 | 50                 | 0.011 | 330              | 0.075 |
| 1835       | 6820 | 100        | 0.015 | 35                 | 0.005 | 245              | 0.036 |
| 2090       | 200  | 40         | 0.200 | 30                 | 0.150 | 205              | 1.025 |
| 2430       | 3760 | 30         | 0.008 | 40                 | 0.011 | 470              | 0.125 |
| 3235       | 2075 | 15         | 0.007 |                    |       | 365              | 0.176 |
| 3660       | 1280 | 0          | 0     | 20                 | 0.016 | 230              | 0.180 |
| 4125       | 2795 | 20         | 0.010 | 50                 | 0.024 | 310              | 0.148 |
| 4465       | 835  | 0          | 0     | 100                | 0.120 | 290              | 0.347 |
| 4800       | 490  | 199        | 0.406 | 340                | 0.694 |                  |       |
| 5225       | 820  | 210        | 0.256 | 175                | 0.213 |                  |       |
| 5525       | 750  |            |       | 320                | 0.427 |                  |       |
| 6000       | 2075 | 220        | 0.106 | 285                | 0.137 |                  |       |
| 6300       | 3025 | 135        | 0.045 | 210                | 0.069 |                  |       |
| 6600       | 3175 | 445        | 0.140 | 210                | 0.066 |                  |       |
| 6900       | 1525 | 490        | 0.321 | 95                 | 0.062 |                  |       |
| 7100       | 6344 | 0          | 0     | 240                | 0.038 |                  |       |
| 9400       | 475  | 20         | 0.042 | 45                 | 0.095 |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF 1, 2 DICHLOROBENZENE**

1- Influent Concentration, ng/l; 0- Effluent Concentration, ng/l; 0/1- Fractional Concentration

| BED VOLUMES | I    | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|------|------------|-------|--------------------|-------|------------------|-------|
|             |      | 0          | 0/1   | 0                  | 0/1   | 0                | 0/1   |
| 300         | 2220 | 30         | 0.014 | 30                 | 0.014 | 260              | 0.117 |
| 600         | 4800 | 45         | 0.009 | 40                 | 0.008 | 230              | 0.048 |
| 900         | 7890 | 15         | 0.002 | 175                | 0.022 | 270              | 0.034 |
| 1200        | 6510 | 45         | 0.007 | 35                 | 0.005 | 240              | 0.037 |
| 1500        | 4655 | 60         | 0.013 | 75                 | 0.016 | 535              | 0.115 |
| 1835        | 6840 | 75         | 0.011 | 30                 | 0.004 | 390              | 0.057 |
| 2090        | 230  | 25         | 0.109 | 60                 | 0.261 | 225              | 0.978 |
| 2430        | 2420 | 45         | 0.019 | 50                 | 0.021 | 480              | 0.198 |
| 3235        | 1410 | 25         | 0.018 |                    |       | 410              | 0.291 |
| 3660        | 1170 | 15         | 0.013 | 55                 | 0.047 | 270              | 0.231 |
| 4125        | 3140 | 55         | 0.018 | 100                | 0.032 | 365              | 0.116 |
| 4465        | 1325 | 25         | 0.019 | 125                | 0.094 | 330              | 0.249 |
| 4800        | 590  | 70         | 0.119 | 180                | 0.305 |                  |       |
| 5225        | 430  | 90         | 0.209 | 80                 | 0.186 |                  |       |
| 5525        | 325  |            |       | 80                 | 0.246 |                  |       |
| 6000        | 1520 | 40         | 0.026 | 95                 | 0.063 |                  |       |
| 6300        | 2745 | 0          | 0     | 80                 | 0.029 |                  |       |
| 6600        | 3030 | 155        | 0.051 | 70                 | 0.023 |                  |       |
| 6900        | 210  | 235        | 1.119 | 50                 | 0.238 |                  |       |
| 7100        | 3906 | 610        | 0.156 | 200                | 0.051 |                  |       |
| 9400        | 585  | 50         | 0.085 | 100                | 0.171 |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF 1, 2, 4 TRICHLOROBENZENE**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUMES | I     | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|-------|------------|-------|--------------------|-------|------------------|-------|
|             |       | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 17290 | 625        | 0.036 | 610                | 0.035 | 1295             | 0.075 |
| 600         | 12590 | 85         | 0.007 | 50                 | 0.004 | 655              | 0.052 |
| 900         | 12160 | 50         | 0.004 | 1010               | 0.083 | 550              | 0.045 |
| 1200        | 16180 | 95         | 0.006 | 50                 | 0.003 | 365              | 0.023 |
| 1500        | 18190 | 105        | 0.006 | 70                 | 0.004 | 1050             | 0.058 |
| 1835        | 44345 | 105        | 0.002 | 60                 | 0.001 | 705              | 0.016 |
| 2090        | 220   | 365        | 1.659 | 545                | 2.477 | 1080             | 4.909 |
| 2430        | 7495  | 60         | 0.008 | 195                | 0.026 | 1050             | 0.140 |
| 3235        | 4020  | 85         | 0.021 |                    |       | 945              | 0.235 |
| 3660        | 7420  | 90         | 0.012 | 70                 | 0.009 | 1015             | 0.137 |
| 4125        | 10660 | 50         | 0.005 | 370                | 0.035 | 675              | 0.063 |
| 4465        | 4685  | 70         | 0.015 | 595                | 0.127 | 815              | 0.174 |
| 4800        | 3105  | 100        | 0.032 | 135                | 0.043 |                  |       |
| 5225        | 1090  | 95         | 0.087 | 155                | 0.142 |                  |       |
| 5525        | 1095  |            |       | 85                 | 0.078 |                  |       |
| 6000        | 5440  | 810        | 0.149 | 255                | 0.047 |                  |       |
| 6300        | 4840  | 65         | 0.013 | 165                | 0.034 |                  |       |
| 6600        | 8655  | 190        | 0.022 | 140                | 0.016 |                  |       |
| 6900        | 7840  | 385        | 0.049 | 75                 | 0.010 |                  |       |
| 7100        | 7439  | 75         | 0.010 | 190                | 0.026 |                  |       |
| 9400        | 2045  | 50         | 0.024 | 120                | 0.059 |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF NAPHTHALENE AND 1, 2, 3 TRICHLOROBTZENE**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUMES | I    | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|------|------------|-------|--------------------|-------|------------------|-------|
|             |      | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 9725 | 475        | 0.049 | 480                | 0.049 | 665              | 0.068 |
| 600         | 7865 | 75         | 0.010 | 115                | 0.015 | 435              | 0.355 |
| 900         | 7320 | 65         | 0.009 | 1095               | 0.150 | 435              | 0.059 |
| 1200        | 4990 | 70         | 0.014 | 245                | 0.049 | 380              | 0.076 |
| 1500        | 3950 | 150        | 0.038 | 140                | 0.035 | 635              | 0.161 |
| 1835        | 7930 | 35         | 0.004 | 20                 | 0.003 | 405              | 0.051 |
| 2090        | 1305 | 260        | 0.199 | 1365               | 1.046 | 1500             | 1.149 |
| 2430        | 1880 | 165        | 0.088 | 345                | 0.184 | 470              | 0.250 |
| 3235        | 2335 | 50         | 0.021 |                    |       | 390              | 0.167 |
| 3660        | 3560 | 50         | 0.014 | 345                | 0.097 | 470              | 0.132 |
| 4125        | 5845 | 15         | 0.003 | 155                | 0.027 | 395              | 0.068 |
| 4465        | 1335 | 45         | 0.034 | 115                | 0.086 | 435              | 0.326 |
| 4800        | 1460 | 15         | 0.010 | 20                 | 0.014 |                  |       |
| 5225        | 235  | 25         | 0.106 | 50                 | 0.213 |                  |       |
| 5525        | 250  |            |       | 40                 | 0.160 |                  |       |
| 6000        | 680  | 280        | 0.412 | 65                 | 0.096 |                  |       |
| 6300        | 530  | 1280       | 2.415 | 40                 | 0.075 |                  |       |
| 6600        | 845  | 250        | 0.296 | 20                 | 0.024 |                  |       |
| 6900        | 560  | 1485       | 2.652 | 15                 | 0.027 |                  |       |
| 7100        | 1124 | 410        | 0.365 | 85                 | 0.076 |                  |       |
| 2400        | 2515 | 35         | 0.014 | 20                 | 0.008 |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF HEPTALDCHYDF**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUMES | I    | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|------|------------|-------|--------------------|-------|------------------|-------|
|             |      | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 40   | 80         | 2.000 | 105                | 2.625 | 0                | 0     |
| 600         | 0    | 0          |       | 0                  |       | 55               |       |
| 900         | 140  | 40         | 0.286 | 75                 | 0.536 | 0                | 0     |
| 1200        | 80   | 0          | 0     | 110                | 1.375 | 80               | 1.000 |
| 1500        | 85   | 75         | 0.882 | 65                 | 0.765 | 435              | 5.118 |
| 1835        | 160  | 20         | 0.125 | 15                 | 0.094 | 215              | 1.344 |
| 2090        | 35   | 15         | 0.429 | 0                  | 0     | 0                | 0     |
| 2430        | 205  | 120        | 0.585 | 80                 | 0.390 | 0                | 0     |
| 3235        | 40   | 35         | 0.875 |                    |       | 45               | 1.125 |
| 3660        | 50   | 50         | 1.000 | 135                | 2.700 | 40               | 0.800 |
| 4125        | 130  | 115        | 0.885 | 135                | 1.038 | 55               | 0.423 |
| 4465        | 0    | 30         |       | 85                 |       | 0                |       |
| 4800        | 240  | 35         | 0.146 | 25                 | 0.104 |                  |       |
| 5225        | 1910 | 50         | 0.026 | 265                | 0.139 |                  |       |
| 5525        | 370  |            |       | 345                | 0.932 |                  |       |
| 6000        | 180  | 190        | 1.056 | 75                 | 0.417 |                  |       |
| 6300        | 150  | 220        | 1.467 | 130                | 0.867 |                  |       |
| 6600        | 1445 | 160        | 0.111 | 200                | 0.138 |                  |       |
| 6990        | 1530 | 0          | 0     | 140                | 0.092 |                  |       |
| 7100        | 0    |            |       |                    |       |                  |       |
| 3400        | 0    |            |       |                    |       |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF P-XYLENE**

I- Influent Concentration, g/l; O- Effluent Concentration, g/l; O/I- Fractional Concentration

| BED VOLUMES | I   | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|-----|------------|-------|--------------------|-------|------------------|-------|
|             |     | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 80  | 60         | 0.750 | 0                  | 0     | 115              | 1.438 |
| 600         | 95  | 35         | 0.368 | 25                 | 0.263 | 100              | 1.053 |
| 900         | 60  | 0          | 0     | 0                  | 0     | 105              | 1.750 |
| 1200        | 55  | 95         | 1.727 | 0                  | 0     | 75               | 1.364 |
| 1500        | 50  | 30         | 0.600 | 30                 | 0.600 | 220              | 4.400 |
| 1835        | 75  | 120        | 1.600 | 35                 | 0.467 | 120              | 1.600 |
| 2030        | 30  | 30         | 1.000 | 0                  | 0     | 40               | 1.333 |
| 2430        | 55  | 35         | 0.636 | 0                  | 0     | 30               | 0.545 |
| 3235        | 125 | 50         | 0.400 |                    |       | 90               | 0.720 |
| 3600        | 60  | 0          | 0     | 35                 | 0.583 | 30               | 0.500 |
| 4125        | 65  | 30         | 0.462 | 35                 | 0.538 | 50               | 0.769 |
| 4465        | 35  | 40         | 1.143 | 25                 | 0.714 | 0                | 0     |
| 4800        | 85  | 20         | 0.235 | 0                  | 0     |                  |       |
| 5225        | 55  | 0          | 0     | 135                | 2.455 |                  |       |
| 5525        | 30  |            |       | 95                 | 3.167 |                  |       |
| 6000        | 65  | 40         | 0.615 | 20                 | 0.308 |                  |       |
| 6300        | 0   | 75         |       | 45                 |       |                  |       |
| 6600        | 0   | 120        |       | 80                 |       |                  |       |
| 6900        | 190 | 70         | 0.368 | 65                 | 0.342 |                  |       |
| 7100        |     |            |       | 220                |       |                  |       |
| 9400        | 70  | 55         | 0.786 | 80                 | 1.143 |                  |       |



**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF M-XYLENE**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUMES | I   | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|-----|------------|-------|--------------------|-------|------------------|-------|
|             |     | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 155 | 270        | 1.742 | 105                | 0.677 | 440              | 2.839 |
| 600         | 360 | 105        | 0.292 | 90                 | 0.250 | 295              | 0.819 |
| 900         | 50  | 25         | 0.500 | 20                 | 0.400 | 350              | 7.000 |
| 1240        | 185 | 390        | 2.108 | 25                 | 0.135 | 235              | 1.270 |
| 1580        | 90  | 80         | 0.889 | 95                 | 1.056 | 695              | 7.722 |
| 1835        | 110 | 315        | 2.864 | 100                | 0.909 | 460              | 4.182 |
| 2090        | 70  | 65         | 0.929 | 15                 | 0.214 | 125              | 1.786 |
| 2430        | 135 | 110        | 0.815 | 15                 | 0.111 | 75               | 0.556 |
| 3235        | 320 | 95         | 0.297 |                    |       | 310              | 0.969 |
| 3660        | 215 | 55         | 0.256 | 100                | 0.465 | 105              | 0.488 |
| 4125        | 180 | 75         | 0.417 | 35                 | 0.194 | 180              | 1.000 |
| 4465        | 150 | 120        | 0.800 | 60                 | 0.400 | 135              | 0.900 |
| 4800        | 120 | 40         | 0.333 | 25                 | 0.208 |                  |       |
| 5225        | 75  |            |       | 275                | 3.667 |                  |       |
| 5525        | 70  |            |       | 185                | 2.643 |                  |       |
| 6000        | 110 | 60         | 0.545 | 35                 | 0.318 |                  |       |
| 6300        | 105 | 95         | 0.905 | 100                | 0.952 |                  |       |
| 6600        | 215 | 65         | 0.302 | 175                | 0.814 |                  |       |
| 6900        | 200 | 80         | 0.400 | 115                | 0.575 |                  |       |
| 7100        | 490 | 665        | 1.357 | 500                | 1.020 |                  |       |
| 9400        | 175 | 65         | 0.371 | 125                | 0.714 |                  |       |

C-4

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF 2-METHYL NAPHTHALENE**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUMES | I   | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|-----|------------|-------|--------------------|-------|------------------|-------|
|             |     | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 130 | 0          | 0     | 0                  | 0     | 0                | 0     |
| 600         | 75  | 30         | 0.400 | 0                  | 0     | 50               | 0.667 |
| 900         | 100 | 15         | 0.150 | 45                 | 0.450 | 40               | 0.400 |
| 1200        | 105 | 40         | 0.381 | 165                | 1.571 | 225              | 2.143 |
| 1500        | 130 | 0          | 0     | 0                  | 0     | 55               | 0.423 |
| 1835        | 135 | 30         | 0.222 | 20                 | 0.148 | 90               | 0.667 |
| 2090        | 0   |            |       |                    |       |                  |       |
| 2430        | 365 | 170        | 0.466 |                    |       | 25               | 0.068 |
| 3235        | 40  |            |       |                    |       |                  |       |
| 3660        | 0   |            |       |                    |       |                  |       |
| 4125        | 40  |            |       |                    |       |                  |       |
| 4465        | 0   |            |       |                    |       |                  |       |
| 4800        | 0   |            |       |                    |       |                  |       |
| 5225        | 265 |            |       | 90                 | 0.340 |                  |       |
| 5525        | 185 |            |       |                    |       |                  |       |
| 6000        | 315 | 280        | 0.889 | 95                 | 0.302 |                  |       |
| 6300        | 80  | 100        | 1.250 | 30                 | 0.375 |                  |       |
| 6600        | 85  | 20         | 0.235 | 30                 | 0.353 |                  |       |
| 6900        | 0   | 155        |       |                    |       |                  |       |
| 7100        | 75  | 105        | 1.400 | 25                 | 0.333 |                  |       |
| 9400        | 95  | 40         | 0.421 |                    |       |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF 1-METHYL NAPHTHALENE**

I- Influent Concentration, ng/l; O- Effluent Concentration, ng/l; O/I- Fractional Concentration

| BED VOLUMES | I   | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|-----|------------|-------|--------------------|-------|------------------|-------|
|             |     | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 80  | 0          | 0     | 0                  | 0     | 0                | 0     |
| 600         | 45  | 30         | 0.667 | 0                  | 0     | 25               | 0.556 |
| 900         | 90  | 0          | 0     | 55                 | 0.611 | 60               | 0.667 |
| 1200        | 120 | 25         | 0.208 | 50                 | 0.417 | 50               | 0.417 |
| 1500        | 115 | 0          | 0     | 0                  | 0     | 110              | 0.957 |
| 1835        | 70  | 0          | 0     | 0                  | 0     | 40               | 0.571 |
| 2090        | 0   | 0          |       | 0                  |       | 0                |       |
| 2430        | 385 | 170        | 0.442 | 0                  | 0     | 15               | 0.039 |
| 3235        | 45  | 0          | 0     |                    |       | 0                | 0     |
| 3660        | 0   | 0          |       | 0                  |       | 0                |       |
| 4125        | 80  | 0          | 0     | 0                  | 0     | 0                | 0     |
| 4465        | 20  | 0          | 0     | 0                  | 0     | 0                | 0     |
| 4800        | 0   | 40         |       | 0                  |       |                  |       |
| 5225        | 290 | 0          | 0     | 115                | 0.397 |                  |       |
| 5525        | 85  |            |       | 0                  | 0     |                  |       |
| 6000        | 365 | 475        | 1.301 | 130                | 0.356 |                  |       |
| 6300        | 80  | 135        | 1.688 | 65                 | 0.813 |                  |       |
| 6600        | 160 | 65         | 0.406 | 40                 | 0.250 |                  |       |
| 6900        | 0   | 205        |       | 0                  |       |                  |       |
| 7100        | 485 | 355        | 0.732 | 65                 | 0.134 |                  |       |
| 9400        | 85  | 15         | 0.176 | 0                  | 0     |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF TOTAL ORGANIC HALOGEN - TOX**

1- Influent Concentration,  $\mu\text{g/l}$ ; 0- Effluent Concentration,  $\mu\text{g/l}$ ; 0/1- Fractional Concentration

| BED VOLUMES | I     | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|-------|------------|-------|--------------------|-------|------------------|-------|
|             |       | 0          | 0/1   | 0                  | 0/1   | 0                | 0/1   |
| 300         | 160.0 | 50.0       | .313  | 56.9               | .355  | 142.0            | .888  |
| 600         | 204.0 | 35.6       | .175  | 38.0               | .186  | 149.0            | .730  |
| 900         | 294.0 | 113.0      | .384  | 50.2               | .205  | 167.0            | .568  |
| 1200        | 263.0 | 116.0      | .441  | 97.3               | .370  | 172.0            | .654  |
| 1500        | 316.0 | 75.4       | .239  | 133.0              | .421  | 187.0            | .592  |
| 1835        | 400.0 | 38.7       | .097  | 123.0              | .308  | 222.0            | .555  |
| 2050        | 276.0 | 58.4       | .212  | 47.3               | .171  | 139.0            | .504  |
| 2430        | 147.0 | 38.0       | .259  | 59.9               | .407  | 130.0            | .884  |
| 3235        | 112.0 |            |       |                    |       | 158.0            | 1.411 |
| 3660        | 150.0 | 70.6       | .471  | 64.6               | .431  | 172.0            | 1.147 |
| 4125        | 121.0 | 90.5       | .748  | 105.0              | .868  | 115.0            | .950  |
| 4465        | 144.0 | 102.0      | .708  | 100.0              | .694  | 90.8             | .631  |
| 4800        | 105.0 | 148.0      | 1.410 | 111.0              | 1.057 |                  |       |
| 5225        | 147.0 | 72.3       | .492  | 85.5               | .582  |                  |       |
| 5525        | 151.0 | 66.5       | .440  | 83.0               | .550  |                  |       |
| 6000        | 111.0 | 66.0       | .595  | 79.3               | .714  |                  |       |
| 6300        | 93.4  | 68.1       | .729  | 117.0              | 1.253 |                  |       |
| 6600        | 86.5  | 91.7       | 1.060 | 73.2               | .846  |                  |       |
| 6900        | 91.1  | 64.3       | .706  | 76.6               | .841  |                  |       |
| 7100        |       |            |       |                    |       |                  |       |
| 9400        |       |            |       |                    |       |                  |       |

**PERFORMANCE OF GRANULAR ACTIVATED CARBON  
FOR REMOVAL OF PURGABLE ORGANIC HALOGEN - POX**

I- Influent Concentration,  $\mu\text{g/l}$ ; O- Effluent Concentration,  $\mu\text{g/l}$ ; O/I- Fractional Concentration

| BED VOLUMES | I     | NEW CARBON |       | REGENERATED CARBON |       | EXHAUSTED CARBON |       |
|-------------|-------|------------|-------|--------------------|-------|------------------|-------|
|             |       | O          | O/I   | O                  | O/I   | O                | O/I   |
| 300         | 98.4  | 6.2        | .063  | 4.2                | .043  | 75.1             | .763  |
| 600         | 129.0 | 23.1       | .179  | 21.1               | .164  | 112.0            | .868  |
| 900         | 187.0 | 94.1       | .503  | 38.3               | .205  | 116.0            | .620  |
| 1200        | 173.0 | 104.0      | .601  | 93.1               | .538  | 117.0            | .676  |
| 1500        | 191.0 | 5.6        | .029  | 107.0              | .560  | 118.0            | .618  |
| 1835        | 210.0 | 5.6        | .027  | 77.5               | .369  | 139.0            | .662  |
| 2090        | 99.2  | 6.1        | .061  | 3.4                | .034  | 79.8             | .795  |
| 2430        | 81.1  | 13.0       | .160  | 15.5               | .191  | 65.2             | .804  |
| 3235        | 33.6  |            |       |                    |       | 83.7             | 2.491 |
| 3660        | 93.6  | 30.1       | .322  | 27.1               | .290  | 40.3             | .431  |
| 4125        | 34.0  | 38.1       | 1.121 | 45.6               | 1.341 | 46.0             | 1.353 |
| 4465        | 40.0  | 33.5       | .833  | 38.8               | .970  | 28.6             | .715  |
| 4800        | 23.3  | 26.7       | 1.146 | 31.3               | 1.343 |                  |       |
| 5225        | 30.9  | 24.9       | .806  | 25.9               | .838  |                  |       |
| 5525        | 16.4  | 30.4       | 1.854 | 31.9               | 1.945 |                  |       |
| 6009        | 29.8  | 31.8       | 1.067 | 32.0               | 1.074 |                  |       |
| 6300        | 28.0  | 29.6       | 1.057 | 26.4               | .945  |                  |       |
| 6600        | 22.2  | 45.4       | 2.045 | 23.4               | 1.054 |                  |       |
| 6900        | 19.3  | 19.4       | 1.005 | 18.6               | .964  |                  |       |
| 7100        |       |            |       |                    |       |                  |       |
| 9400        |       |            |       |                    |       |                  |       |

APPENDIX F  
PLANT DOWNTIME AND MAINTENANCE LOG

APPENDIX F

PLANT DOWNTIME AND MAINTENANCE LOG

This section contains a chronological listing of equipment problems experienced during Part II of the test period.

PLANT DOWNTIME AND MAINTENANCE LOG

\* Equipment or Process Causing Plant Shutdown  
 (#) Number of Process Causing Downtime

| Date         | Plant Shutdown (1) | Influent Unavailable (2) | Problem Description   | Computer (3) | Chemical Clarification (4) | Recarbonation (5) | Ozonation (6) | Filters (7) | Carbon Adsorption (8) | Chlorination (9) | Maintenance Manhours | Material \$ |
|--------------|--------------------|--------------------------|---|--------------|----------------------------|-------------------|---------------|-------------|-----------------------|------------------|----------------------|-------------|
| Feb 4 to 7   | 72 (4)             |                          | Calcium carbonate deposits on 24" delivery line from flash mixer to flocculator reduced the flow capacity to 0.7 MGD. The deposits were partially removed by soaking in 36% inhibited hydrochloric acid for 22 hours. |              | 72 *                       |                   |               |             |                       |                  |                      | 3650        |
| Feb 17 to 21 | 91 (4, 5, 7)       |                          | The softened deposits were later removed by hydroflushing (high pressure water cleaning)  | 5            | 75 * 29 *                  |                   |               | 11 *        |                       |                  | 44                   |             |
| Feb 9 to 20  |                    |                          | Calcium carbonate deposits on recarbonation mixer turbine caused unbalance and excessive vibration. Deposits were removed.  |              |                            | 187 (mixer)       |               |             |                       |                  |                      |             |
| Feb 9        | 6 (3)              |                          | Computer maintenance  | 6 *          |                            |                   |               |             |                       |                  | 6                    |             |
| Feb 10       | 8 (3)              |                          | Computer maintenance  | 8 *          |                            |                   |               |             |                       |                  | 7                    |             |
| Feb 23       | 5 (3)              |                          | Computer maintenance  | 5 *          |                            |                   |               |             |                       |                  | 5                    |             |



PLANT DOWNTIME AND MAINTENANCE LOG

| Date         | Plant Shutdown (1) | Influent Unavailable (2) | Description Problem  | Computer (3) | Chemical Clarification (4) | Recarbonation (5) | Ozonation (6) | Filters (7) | Carbon Adsorption (8) | Chlorination (9) | Maintenance Manhours | Material |
|--------------|--------------------|--------------------------|--|--------------|----------------------------|-------------------|---------------|-------------|-----------------------|------------------|----------------------|----------|
| Dec 3        |                    |                          | Ozonizer repair  |              |                            |                   |               |             |                       |                  | 50                   |          |
| Dec 4        |                    |                          | Ozonizer repair  | 4            |                            |                   | 208           | 9           |                       |                  | 25                   |          |
| Dec 1 to 9   |                    |                          | Water jacket leak in ozonizer  |              | 9 *                        |                   |               | 72          |                       |                  | 7                    |          |
| Dec 24 to 28 | 9 (4)              |                          | Computer maintenance   |              | 40 *                       |                   |               |             |                       |                  |                      |          |
| Dec 28 to 30 | 40 (3)             |                          | Aerator sump pump flush  |              |                            |                   |               | 33          |                       |                  |                      |          |
| Jan 1 to 4   |                    |                          | Aerator clean-up to remove encrusted calcium carbonate   |              |                            |                   |               |             |                       |                  |                      | 14       |
| Jan 5 to 11  |                    |                          | Ozonizer down  |              |                            |                   |               |             |                       |                  |                      | 22       |
| Jan 12 to 18 |                    |                          | Lime system maintenance  |              |                            |                   |               |             |                       |                  |                      | 18       |
| Jan 19 to 25 | 5 (2)              |                          | Lime system maintenance  |              |                            |                   |               |             |                       |                  |                      | 14       |
| Jan 26 to 31 | 5 (3)              | 5 *                      | Lime system maintenance<br>Ozonizer system maintenance<br>Influent dye test<br>Lime system maintenance |              | 5 *                        |                   |               |             |                       |                  |                      |          |

PLANT DOWNTIME AND MAINTENANCE LOG

\* Equipment or Process Causing Plant Shutdown  
 (#) Number of Process Causing Downtime

| Date         | Plant Shutdown (1) | Influent Unavailable (2) | Problem Description  | Computer (3) | Chemical Clarification (4) | Recarbonation (5) | Ozonation (6) | Filters (7) | Carbon Adsorption (8) | Chlorination (9) | Maintenance Manhours | Material S |
|--------------|--------------------|--------------------------|--|--------------|----------------------------|-------------------|---------------|-------------|-----------------------|------------------|----------------------|------------|
| Nov 3        | 5                  |                          | Power out  |              |                            |                   |               |             |                       |                  | 9                    |            |
| Nov 4        |                    |                          | Flushed lime slaker and lime slurry feed tank; computer maintenance            |              | 3                          |                   |               |             |                       |                  | 13                   |            |
| Nov 5        |                    |                          | Computer maintenance<br>Lime system maintenance<br>Recarbonation maintenance   |              |                            |                   |               |             |                       |                  | 21                   |            |
| Nov 6        |                    |                          | Computer maintenance<br>Lime system maintenance<br>Aeration system maintenance |              |                            |                   |               |             |                       |                  | 24                   |            |
| Nov 6 to 30  |                    |                          | Tube failed in ozonizer  |              |                            |                   | 552           |             |                       |                  |                      |            |
| Nov 11       |                    |                          | Inspect ozonizer   |              |                            |                   |               |             |                       |                  | 1                    |            |
| Nov 12       |                    |                          | Remove ozonizer dielectric tube and wash unit                                  |              |                            |                   |               |             |                       |                  | 8                    |            |
| Nov 13       | 14 (4)             |                          | Aerator sump pump frozen   |              | 14 *                       |                   |               |             |                       |                  | 6                    |            |
| Nov 14       | 15 (4)             |                          | Aerator sump pump frozen   |              | 12 *                       |                   |               |             |                       |                  |                      |            |
| Nov 16 to 30 |                    |                          | General maintenance  |              |                            |                   |               |             |                       |                  | 85                   |            |
| Nov 26       | 3 (3)              |                          |  | 3 *          |                            |                   |               |             |                       |                  | 1                    |            |

PLANT DOWNTIME AND MAINTENANCE LOG

\* Equipment or Process Causing Plant Shutdown  
 (#) Number of Process Causing Downtime

| Date         | Plant Shutdown (1) | Influent Unavailable (2) | Problem Description                    | Computer (3) | Chemical Clarification (4) | Recarbonation (5) | Ozonation (6) | Filters (7) | Carbon Adsorption (8) | Chlorination (9) | Maintenance Manhours | Material |
|--------------|--------------------|--------------------------|--|--------------|----------------------------|-------------------|---------------|-------------|-----------------------|------------------|----------------------|----------|
| Oct 12 to 13 |                    |                          | Ozonizer inspected                     |              |                            |                   | 48            |             |                       |                  | 3                    |          |
| Oct 14       | 2 (3)              |                          | Computer maintenance                   | 2 *          |                            |                   | 24            |             |                       |                  |                      |          |
| Oct 15       |                    |                          | Computer power supply failure          | 1 *          |                            |                   | 24            |             |                       |                  | 4                    |          |
| Oct 16       | 2 (3)              |                          | Tightened stack gas compressor belts   |              |                            | 1                 | 10            |             |                       |                  | 2                    |          |
| Oct 20       |                    |                          | Changed oil - lime clarifier reservoir |              | 4                          |                   |               |             |                       |                  |                      |          |
| Oct 23       |                    |                          | Computer maintenance                   | 1 *          |                            |                   |               |             |                       |                  |                      |          |
| Oct 24       | 1 (3)              |                          | Computer maintenance                   |              |                            |                   |               |             |                       |                  | 12                   |          |
| Oct 27       |                    |                          | Computer maintenance                   |              |                            |                   |               |             |                       |                  | 11                   |          |
| Oct 28       |                    |                          | Computer maintenance                   |              |                            |                   |               |             |                       |                  | 13                   |          |
| Oct 29       |                    |                          | Computer maintenance                   |              | 2                          |                   |               |             |                       |                  | 9                    |          |
| Oct 30       |                    |                          | Computer maintenance                   |              |                            |                   |               |             |                       |                  |                      |          |
| Oct 31       |                    |                          | Computer maintenance                   |              |                            |                   |               |             |                       |                  | 8                    |          |

ORIGINAL PAGE IS OF POOR QUALITY

PLANT DOWNTIME AND MAINTENANCE LOG

\* Equipment or Process Causing Plant Shutdown  
 (#) Number of Process Causing Downtime

| Date         | Plant Shutdown (1) | Influent Unavailable (2) | Problem Description  | Computer (3) | Chemical Clarification (4) | Recarbonation (5) | Ozonation (6) | Filters (7) | Carbon Adsorption (8) | Chlorination (9) | Maintenance Manhours | Materials |
|--------------|--------------------|--------------------------|--|--------------|----------------------------|-------------------|---------------|-------------|-----------------------|------------------|----------------------|-----------|
| Sep 12       |                    |                          | Recarbonation system maintenance                                   |              |                            | 10                |               |             |                       |                  | 5                    |           |
| Sep 15       |                    |                          | Calibrated pit probe   |              |                            |                   |               |             |                       |                  | 2                    |           |
| Sep 16       |                    |                          | Maintenance on furnace controls lockouts; cleaned stack gas filter |              |                            |                   |               |             |                       |                  | 2                    |           |
| Sep 16 to 20 |                    |                          | Disassembled ozonizer and cleaned tubes                            |              |                            |                   | 99            |             |                       |                  | 34                   |           |
| Sep 21       |                    |                          | Replaced belt on dewatering screw drive motor                      |              |                            |                   |               |             |                       |                  | 1                    |           |
| Sep 22       |                    |                          | Replaced bolt on dewatering screw                                  |              |                            |                   |               |             |                       |                  | 2                    |           |
| Sep 23       | 1 (3)              |                          | Computer maintenance   | 1 *          |                            |                   |               |             |                       |                  |                      |           |
| Sep 25       |                    |                          | Repair lime conveyor   |              |                            |                   |               |             |                       |                  | 16                   |           |
| Sep 30       | 2 (2)              |                          | Repair lime mixer  | 2 *          |                            |                   |               |             |                       |                  | 4                    |           |
|              |                    |                          | Computer maintenance   |              |                            |                   |               |             |                       |                  |                      |           |
| Oct 2        |                    |                          | Lime bin vibrator belts  |              |                            |                   |               |             |                       |                  | 2                    |           |
| Oct 8 to 11  | 1 (4)              |                          | Ozonizer out of service; dryer solenoid valve not working          |              | 1 *                        |                   | 82            |             |                       |                  |                      |           |
|              |                    |                          |  |              |                            |                   |               |             |                       |                  |                      |           |

PLANT DOWNTIME AND MAINTENANCE LOG

\* Equipment or Process Causing Plant Shutdown  
 (#) Number of Process Causing Downtime

| Date   | Plant Shutdown (1) | Influent Unavailable (2) | Problem Description                           | Computer (3) | Chemical Clarification (4) | Recarbonation (5) | Ozonation (6) | Filters (7) | Carbon Adsorption (8) | Chlorination (9) | Maintenance Manhours | Material |
|--------|--------------------|--------------------------|---|--------------|----------------------------|-------------------|---------------|-------------|-----------------------|------------------|----------------------|----------|
| Aug 19 | 4 (3)              |                          | Computer maintenance                          | 4 *          | 12                         | 12 (4)            |               |             |                       |                  | 4                    |          |
| Aug 21 |                    |                          | Sludge furnace down                           |              | 5(5)                       | 5                 |               |             |                       |                  | 4                    |          |
| Aug 22 |                    |                          | Sludge furnace down                           |              | 11(5)                      | 11                |               |             |                       |                  | 4                    |          |
| Aug 26 | 5 (3)              |                          | Computer / new facility interface 1300 - 1900 | 5 *          |                            |                   |               |             |                       |                  | 4                    |          |
| Aug 27 | 5 (3)              |                          | Computer maintenance 1200 - 1430              | 5 *          |                            |                   |               |             |                       |                  | 4                    |          |
| Aug 28 | 3 (3)              |                          | Computer maintenance 1330 - 1700              | 3 *          |                            |                   |               |             |                       |                  | 4                    |          |
| Aug 29 | 6 (3)              |                          | Computer maintenance 1130 - 1700              | 6 *          |                            |                   |               |             |                       |                  | 4                    |          |
| Sep 2  | 9 (3)              |                          | Computer maintenance 1000 - 1830              | 9 *          |                            |                   |               |             |                       |                  | 4                    |          |
| Sep 8  |                    |                          | Computer maintenance                          |              | 14                         | 14 (4)            |               |             |                       |                  | 2                    |          |
| Sep 9  |                    |                          | Flushed lime slurry feed tank                 |              | 24                         | 24 (4)            |               |             |                       |                  | 2                    |          |
| Sep 10 |                    |                          | Furnace maintenance calibrated pit probe      |              |                            |                   |               |             |                       |                  | 6                    |          |
| Sep 11 |                    |                          | Tightened stack gas compressor belts          |              | 11                         | 11 (4)            |               |             |                       |                  | 6                    |          |

PLANT DOWNTIME AND MAINTENANCE LOG

| Date         | Plant Shutdown (1) | Influent Unavailable (2) | Problem Description   | Computer (3) | Chemical Clarification (4) | Recarbonation (5) | Ozonation (6) | Filters (7) | Carbon Adsorption (8) | Chlorination (9) | Maintenance Manhours | Material \$ |
|--------------|--------------------|--------------------------|---|--------------|----------------------------|-------------------|---------------|-------------|-----------------------|------------------|----------------------|-------------|
| Jul 26       | 3 (2)              | 3 *                      | Computer maintenance  | 2 *          | 3 *                        |                   |               |             |                       |                  | 6                    |             |
| Jul 28       | 2                  |                          | Aerator sump pump frozen  |              | 7                          |                   |               |             |                       |                  | 6                    |             |
| Jul 31       | 1                  |                          | Aerator sump pump frozen - down   |              | 2                          | 3                 |               | 1           |                       |                  |                      | 4           |
| Aug 2        | 7 (2)              | 7 *                      | Aerator sump pump frozen - 1100   | 1 *          | 1                          |                   |               |             |                       |                  |                      | 38          |
| Aug 5        | 1 (3)              |                          | Computer maintenance  |              |                            | 91 *              |               |             |                       |                  |                      | 9           |
| Aug 6        | 3 (2)              | 3 *                      | Computer maintenance  |              |                            | 18 *              | 6 (4)         |             |                       |                  |                      | 3           |
| Aug 7        |                    |                          | Aerator sump pump frozen  |              |                            | 6                 |               |             |                       |                  |                      | 50          |
| Aug 8 to 11  | 91 (4)             |                          | Removed and started cleaning aerator sump pump valve. (Modified flow pattern implemented 8-12-80 through 8-21-80) |              |                            |                   |               |             |                       |                  |                      |             |
| Aug 12       | 18 (4)             |                          | Computer maintenance  |              | 3 *                        | 192               |               |             |                       |                  |                      |             |
| Aug 13 to 20 | 3 (3)              |                          | Repair aerator sump pump and associated valves  |              |                            |                   |               |             |                       |                  |                      |             |

PLANT DOWNTIME AND MAINTENANCE LOG

\* Equipment or Process Causing Plant Shutdown  
 (#) Number of Process Causing Downtime

| Date   | Plant Shutdown (1) | Influent Unavailable (2) | Description Problem   | Computer (3) | Chemical Clarification (4) | Recarbonation (5) | Ozonation (6) | Filters (7) | Carbon Adsorption (8) | Chlorination (9) | Maintenance Manhours | Material |
|--------|--------------------|--------------------------|---|--------------|----------------------------|-------------------|---------------|-------------|-----------------------|------------------|----------------------|----------|
| Jul 1  | 3 (2)              | 3 *                      | Replaced lime slurry feed pump mechanical seal - on line at 1900                  |              | 19                         |                   |               |             |                       |                  | 8                    |          |
| Jul 2  |                    |                          | Computer maintenance  |              |                            |                   |               |             |                       |                  | 4                    |          |
| Jul 8  | 4                  |                          |   |              |                            |                   |               |             |                       |                  |                      |          |
| Jul 13 | 3                  |                          |   |              |                            |                   |               |             |                       |                  |                      |          |
| Jul 14 | 3 (2)              | 3 *                      |   |              |                            |                   |               |             |                       |                  |                      |          |
| Jul 16 |                    |                          |   |              | 8                          |                   |               |             |                       |                  |                      |          |
| Jul 17 | 20 (2)             | 20 *                     | Down 0400 - 2400  | 1            |                            |                   |               |             |                       |                  |                      |          |
| Jul 18 | 8 (2)              | 8 *                      |   |              |                            |                   |               |             |                       |                  |                      |          |
| Jul 21 | 3 (2)              | 3 *                      | Ozonizer maintenance  |              |                            |                   | 3             |             |                       |                  | 4                    |          |
| Jul 22 |                    |                          | Tightened stack gas compressor belts. Down 1300 - 1400                            |              |                            | 1                 |               |             |                       |                  | 2                    |          |
| Jul 23 | 3 (2)              | 3 *                      |   |              |                            |                   |               |             |                       |                  |                      |          |
| Jul 24 | 13 (4)             |                          | Recarbonation maintenance. Aerator sump pump frozen by calcium carbonate deposits |              | 8 (5)<br>13 *              | 8                 |               |             |                       |                  | 13                   |          |
| Jul 25 |                    |                          |   |              | 13 (5)                     | 13                |               |             |                       |                  | 6                    |          |

APPENDIX G

WMS COSTS



## APPENDIX G

### WMS COSTS

This section contains operating and maintenance costs incurred by each sensor/subsystem in the WMS during the test period. A list of recommended spares is also included.

#### Sample Collection and Distribution System

The following expenditures can be expected for 8 months of continuous operation:

|                                      |                 |
|--------------------------------------|-----------------|
| 1) 50 Stainless Steel Filter Screens | \$ 66.00        |
| 2) Pneumatic Cylinder                | 45.00           |
| 3) Pump Boots                        | 20.00           |
| 4) Pump Parts                        | 66.00           |
| 5) Drive Belts                       | 12.50           |
| 6) Red Valves                        | 62.50           |
| 7) Pressure Transducers              | 165.00          |
| 8) Red Valves Sleeves (4)            | 120.00          |
| Total =                              | <u>\$557.00</u> |

#### Recommended Spares:

- 1) 50 Stainless Steel Filters (10)
- 2) Pressure Gages (1)
- 3) Pump Boots (4)
- 4) Monyo Pump (1)
- 5) Drive Belts (2)
- 6) Red Valves (1)
- 7) Pressure Transducer (1)
- 8) Red Valve Sleeves (4)
- 9) Pneumatic Back Flushing Cylinder (1)

The only major hardware components to fail during the test period were Red Valves, one Monyo pump, and one pneumatic cylinder. As such, it is not yet possible to estimate the life expectancy of the system except to state that it should be at least 4 years.

During the course of the test period, 7 man-hours were spent for scheduled maintenance and 9.75 man-hours for unscheduled maintenance.

## Commercial Sensors

### Total Organic Carbon

The following expenditures can be expected for 8 months of continuous operation:

|                    |           |
|--------------------|-----------|
| 1) Phosphoric Acid | \$125.00  |
| 2) Pump Tubing     | 33.00     |
| 3) Sample Pump     | 250.00    |
| 4) Persulfate      | 744.00    |
| 5) U.V. Lamps (3)  | 540.00    |
| 6) Filters         | 33.00     |
| Total =            | \$1725.00 |

### Recommended Spares:

- 1) Sample Pump (1)
- 2) Reagent Pump (1)
- 3) U.V. Chamber Pump (1)
- 4) U.V. Lamps (3)
- 5) Pump Tubing
- 6) Fiberfax Filter (Mist Filter) (1 lb.)

The overall life of the analyzer has yet to be determined. During the course of the test period 32.0 man-hours were spent on routine maintenance and 11.5 man-hours on unscheduled maintenance.

### Hardness Analyzer

The following expenditures can be expected for 8 months of continuous operation:

|                                 |           |
|---------------------------------|-----------|
| 1) Bromide Electrodes           | \$ 175.00 |
| 2) Copper Electrodes            | 273.00    |
| 3) #113201 Reagent (21.45 Gal.) | 1393.00   |
| 4) Pump Tubes (3 sets)          | 90.00     |
| 5) Calcium Carbonate            | 7.00      |
| 6) Ammonium Hydroxide           | 3.00      |
| 7) Hydrochloric Acid            | 3.00      |
| Total =                         | \$1946.00 |

### Recommended Spares:

- 1) Pump Tubes (2 sets)
- 2) Bromide Electrode (1)
- 3) Copper Electrode (1)

The overall life of the analyzer has yet to be determined. However, the apparent life expectancy of several of the components has been determined:

- 1) Electrodes - 6 months
- 2) Pump Tubes - 3 months
- 3) Flow Cell - 2 years

During the course of the test period, 67.75 man-hours were spent on routine maintenance and 4.75 man-hours on unscheduled maintenance.

#### Nitrate Analyzer

The following expenditures can be expected for 8 months of continuous operation:

|                      |                 |
|----------------------|-----------------|
| 1) Phosphoric Acid   | \$329.00        |
| 2) Marshals Reagent  | 327.00          |
| 3) Sulfanilamide     | 198.00          |
| 4) Poppet Valves     | 30.00           |
| 5) Cadmium           | 50.00           |
| 6) Potassium Nitrate | 8.00            |
| 7) Ammonium Acetate  | 10.00           |
| 8) Acetic Acid       | 10.00           |
| Total =              | <u>\$962.00</u> |

#### Spares

- 1) Poppet Valves (4)
- 2) Metricone Drive w/ Motor (1)
- 3) Pump Bellows (1)
- 4) Pump Motor (1)
- 5) Diaphragms (Air Pump) (2)

The overall life expectancy of the analyzer has yet to be determined. However, the apparent life expectancy of several components has been determined.

- 1) Metricone - 2 years
- 2) Pump Motor - 3 years
- 3) Pump Poppet Valves - 6 months

During the course of the test period, 19.5 man-hours were spent on scheduled maintenance and 22.0 man-hours on unscheduled maintenance.

#### pH Analyzer

The only operating cost incurred during operation will be \$50.00 for standards. It is recommended that a spare electrode be kept on hand. The estimated life expectancy of the electrode is 3 years. During the course of the test period, 2.0 man-hours were spent on routine maintenance and 1.0 man-hour on unscheduled maintenance.

## Residual Chlorine Analyzer

The following expenditures can be expected for 8 months of continuous operation:

|                               |                  |
|-------------------------------|------------------|
| 1) Redox Electrodes           | \$150.00         |
| 2) Iodine Electrodes          | 150.00           |
| 3) #112501 Reagent            | 456.00           |
| 4) #112502 Reagent            | 456.00           |
| 5) Residual Chlorine Standard | 19.80            |
| 6) Pump Tube Sets (3)         | 150.00           |
| Total =                       | <u>\$1381.80</u> |

### Recommended Spares:

- 1) Pump Tubes (2 sets)
- 2) Redox Electrode (1)
- 3) Iodine Electrode (1)

The overall life expectancy of the analyzer has yet to be determined. However, the apparent life expectancy of several of the components has been determined:

- 1) Electrodes - 6 months
- 2) Pump Tubes - 3 months
- 3) Temperature Controlled Flow Cell - 3 years

During the course of the test period, 50.75 man-hours were spent on routine maintenance and 2.25 man-hours on unscheduled maintenance.

## Sodium Analyzer

The following expenditures can be expected for 8 months of continuous operation:

|                                    |                 |
|------------------------------------|-----------------|
| 1) Sodium Electrode (1)            | \$165.00        |
| 2) Reference Electrode (1)         | 42.00           |
| 3) Anhydrous Ammonia (1 cyl.)      | 45.00           |
| 4) Sodium Chloride (3.3 lbs.)      | 14.52           |
| 5) Reference Electrode Electrolyte | 15.00           |
| Total =                            | <u>\$281.52</u> |

### Recommended Spares:

- 1) Sodium Electrode (1)
- 2) Reference Electrode (1)

The overall life expectancy of the analyzer has yet to be determined. However, the life expectancy of the reference electrode is approximately 1 year.

During the course of the test period, 70.00 man-hours were spent on scheduled maintenance and 13.5 man-hours on unscheduled maintenance.

### Temperature Sensor

The following expenditure can be expected for 8 months of continuous operation of the two temperature sensors.

|                                   |          |
|-----------------------------------|----------|
| Action Pac electronics module (1) | \$125.00 |
|-----------------------------------|----------|

The only recommended spare is 1 Action Pac electronics module.

The life expectancy of the sensor has yet to be determined. During the course of the test period, .5 man-hour was spent on scheduled maintenance and .5 on unscheduled maintenance.

### Turbidity

The following expenditures can be expected for 8 months of continuous operation of the Sigrist Model UP52-TJ Photometer:

|                          |                 |
|--------------------------|-----------------|
| 1) Chart Paper (2 rolls) | \$32.00         |
| 2) Light Source (2)      | 15.00           |
| 3) Glow Lamp (1)         | 9.50            |
| —                        | Total = \$56.50 |

#### Recommended Spares:

- 1) Chart Paper (1 roll)
- 2) Light Sources (2)

Since there have been no major component failures in the Sigrist Photometer, the life expectancy has yet to be determined. During the course of the test period, 2.25 man-hours were spent on scheduled maintenance and .25 man-hour on unscheduled maintenance.

### Ammonia Analyzer

The following expenditures can be expected for 8 months of continuous operation:

|                          |                  |
|--------------------------|------------------|
| 1) Sodium Hypochlorite   | \$501.00         |
| 2) Sodium Hydroxide      | 52.00            |
| 3) Phenol                | 134.00           |
| 4) Sodium Metaphosphate  | 7.50             |
| 5) Ammonium Chloride     | 4.00             |
| 6) Pump Check Valves (4) | 60.00            |
| 7) Hydrochloric Acid     | 30.50            |
| —                        | Total = \$789.00 |

Recommended Spares:

- 1) Metricone Drive Unit w/motor (1)
- 2) Pump Check Valves (4)
- 3) Glass Flow Cell (1)
- 4) Spare Pump Motor (1)
- 5) Pump Bellows (1)
- 6) Diaphragms (Air Pump) (2)

The overall life expectancy of the analyzer has yet to be determined. However, the apparent life expectancy of several of the components has been determined:

- 1) Metricone Assembly - 2 years
- 2) Pump Motor - 3 years
- 3) Pump Check Valves - 3-5 months

During the course of the test period, 159.75 man-hours were spent on scheduled maintenance and 18.25 man-hours on unscheduled maintenance.

Conductivity

The Beckman conductivity sensor required no consumables and suffered no part failures during the test period.

There are no recommended spares for this sensor.

During the course of the test period, .5 man-hour was spent on scheduled maintenance, and no man-hours on unscheduled maintenance.

Dissolved Oxygen Analyzer

The following expenditures can be expected for 8 months of continuous operation for the Delta Scientific unit:

|                     |                  |
|---------------------|------------------|
| 1) Sodium Sulfite   | \$ 10.00         |
| 2) Cobalt Chloride  | 8.00             |
| 3) Membrane Kit (1) | 42.00            |
| 4) Electrolyte      | 15.00            |
| 5) D.O. Test Kit    | 25.00            |
|                     | —                |
|                     | Total = \$100.00 |

Recommended Spares:

- 1) Membrane Kit (3)

The overall life expectancy of the analyzer has yet to be determined. The only significant failure which took place was the electrode. Based on this it appears the electrode's life expectancy is 4 years.

During the course of the test period, 4.0 man-hours were spent on routine maintenance and 0.5 man-hour on unscheduled maintenance.

### Chemiluminescence Biosensor

Since the biosensor is a prototype unit unique to the WMS, the major initial material cost figures are presented:

|                            |                    |
|----------------------------|--------------------|
| 1) Photometer (1)          | \$2,000.00         |
| 2) Peristaltic Pumps (2)   | 1,046.00           |
| 3) Chart Recorder (1)      | 700.00             |
| 4) Teflon Valves (5)       | 600.00             |
| 5) Air Solenoid Valves (6) | 480.00             |
| 6) Flow Meters (2)         | 100.00             |
| 7) Tubing and Fittings     | 200.00             |
|                            | —                  |
|                            | Total = \$5,126.00 |

The following expenditures can be expected for 8 months of continuous operation:

|   |                  |
|---|------------------|
| 1) 5- Amino- 2,3- dihydro- 1,4 -<br>phthalazinediane (12 g) | \$ 30.00         |
| 2) Sodium Hydroxide (50%) (1 qt)                            | 7.50             |
| 3) Hydrogen Peroxide (30%) (1 pt)                           | 11.00            |
| 4) Carbon Monoxide (3 cylinders)                            | 173.50           |
| 5) Pump Tubes (4 pks)                                       | 10.00            |
| 6) Solenoid Valves (2)                                      | 180.00           |
| 7) Valve Bushings (4)                                       | 6.00             |
|   | —                |
|   | Total = \$418.00 |

### Recommended Spares:

- 1) Photomultiplier Tube (1)
- 2) Valve Bushings (8)
- 3) Teflon Valve (1)
- 4) Solenoid Valve (1)
- 5) Peristaltic Pump (1)

As there have been no major component failures, the life expectancy of the biosensor has yet to be determined.

During the course of the test period, 77.0 man-hours were spent on scheduled maintenance and 15.0 man-hours on unscheduled maintenance.

### Coliform Detector

The estimated material cost for the breadboard detector is \$5K.

The following expenditures can be expected for 8 months with one run a day:

|                                   |                  |
|-----------------------------------|------------------|
| 1) Media (5.6 lbs)                | \$ 89.00         |
| 2) Platinum Electrodes (3)        | 255.00           |
| 3) Nitric Acid (2 pts)            | 45.00            |
| 4) Pump Tubes (5 pks)             | 33.50            |
| 5) Thermometers (5)               | 118.00           |
| 6) Thermistors (3)                | 61.00            |
| 7) Temperature Control Boards (2) | 125.00           |
| 8) Electrolyte (6.6 pts)          | 40.00            |
|                                   | —                |
|                                   | Total = \$766.50 |

Recommended Spares:

- 1) Thermometers (5)
- 2) Electrodes (3)
- 3) Peristaltic Pump (1)
- 4) Teflon Valves (2)
- 5) Valve Bushings (10)
- 6) Valve Port Faces (10)
- 7) Solenoid Valves (2)

As yet the overall life expectancy of the coliform detector has not been determined. However, the apparent life expectancy of the electrodes appears to be 3 years. The life expectancy of the valve bushings and port faces is also 3 years.

During the course of the test period, 110.00 man-hours were spent on routine maintenance and 100.00 man-hours on unscheduled maintenance.

Gas Chromatograph

The initial cost of the WMS automated GC was \$78K.

The following expenditures can be expected for 8 months of continuous operation:

|                              |                  |
|------------------------------|------------------|
| 1) Nitrogen Gas (2 cyl)      | \$130.00         |
| 2) Argon-methane Gas (3 cyl) | 150.00           |
| 3) Chart Paper (4 boxes)     | 237.00           |
| 4) Printer Head (1)          | 100.00           |
| 5) Valve Bushings (2)        | 50.00            |
|                              | —                |
|                              | Total = \$667.00 |

Recommended Spares:

- 1) Preparative Column Prefilter (1)
- 2) Bendix Valve Bushings (2)
- 3) Analytical Column (1)



The useful life of the GC has yet to be determined. The instrumentation should last for many years; however, the analytical and preparative columns may require replacement more often.

During the course of the test period, 51.0 man-hours were spent on routine maintenance and 140.0 man-hours on unscheduled maintenance.

#### Deionized Water System

The following expenditures can be expected for 8 months of continuous operation:

|                              |                   |
|------------------------------|-------------------|
| 1) Rogard Filters            | \$ 130.00         |
| 2) Carbon Filters            | 160.00            |
| 3) Ion-Exchange Filters      | 475.00            |
| 4) Reverse Osmosis Cartridge | 550.00            |
| 5) Pump Impellers (3)        | 16.50             |
| 6) Sodium Hypochlorite       | 23.00             |
| 7) Chlorine Filter           | 16.00             |
|                              | -----             |
|                              | Total = \$1370.50 |

#### Recommended Spares:

- 1) Pump Impellers (3)
- 2) Rogard Filters (8)
- 3) Carbon Filters (4)
- 4) Ion-Exchange Filters (8)

The useful life of the deionized water system has yet to be determined. The life expectancy of the various filters has varied significantly throughout the test period.

During the course of the test period, 10.0 man-hours were spent on routine maintenance and 3.5 man-hours on unscheduled maintenance.