

TM 7001

## TECHNICAL REPORT

*CR-151230*FEASIBILITY STUDY OF AUTOMATIC CONTROL  
OF CREW COMFORT IN THE SHUTTLE  
EXTRAVEHICULAR MOBILITY UNIT (EMU)

Job Order 81-107

(NASA-CR-151230) FEASIBILITY STUDY OF  
AUTOMATIC CONTROL OF CREW COMFORT IN THE  
SHUTTLE EXTRAVEHICULAR MOBILITY UNIT  
(Lockheed Electronics Co.) 27 p  
HC A03/MF A01N77-19755  
Unclass  
CSCL 05E 63/54 20566

Prepared By

Lockheed Electronics Company, Inc.  
Aerospace Systems Division  
Houston, Texas

Contract NAS 9-15200

For

CREW SYSTEMS DIVISION

*National Aeronautics and Space Administration*  
**LYNDON B. JOHNSON SPACE CENTER***Houston, Texas*

February 22, 1977

LEC 9980



TM 7001

TECHNICAL REPORT

FEASIBILITY STUDY OF AUTOMATIC CONTROL  
OF CREW COMFORT IN THE SHUTTLE  
EXTRAVEHICULAR MOBILITY UNIT (EMU)

Job Order 81-107

PREPARED BY

David W. Cook Jr.  
D. W. Cook

APPROVED BY

H. T. Crenshaw  
H. T. Crenshaw, Supervisor  
Applied Physics Section

W. J. Reicks  
W. J. Reicks, Manager  
Applied Mechanics Department

Prepared By  
Lockheed Electronics Company, Inc.  
For  
Crew Systems Division

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION  
LYNDON B. JOHNSON SPACE CENTER  
HOUSTON, TEXAS

February 1977

LEC 9980

## 1. INTRODUCTION

During the Apollo project, crew comfort in the Apollo Extravehicular Mobility Unit (EMU) was maintained by manual manipulation of a valve that controlled the inlet coolant temperature to the liquid cooled garment (LCG). Four inlet temperature selections were possible ranging approximately from 45°F to 80°F. During Skylab, similar comfort control was achieved by manually operating a valve which varied LCG coolant flow rate.

The Shuttle EMU design proposal includes an 11-position manual valve to vary inlet coolant temperature similar to the method used in Apollo. Eleven inlet temperatures would be available for selection vs. the four previously available.

Apollo experience indicates that some training is necessary to enhance the crewman's comfort and optimize his ability to carry a workload. Several tendencies were noted during lunar and Skylab extravehicular activities (EVA's):

- a. Some crewmen precooled themselves in anticipation of a high activity level and left the valve in the valve position selected prior to the activity. A high level of training is needed for such anticipation.
- b. Some crewmen tended to work at rates that were conducive to their comfort at some intermediate cooling level. They would slow down or stop and rest if they became too hot, or they would speed up or hurry to the next activity if they were too cool.
- c. At times, preoccupation with a task would cause a crewman to forget comfort until excessive sweating or fatigue became imminent, and ground controllers would suggest valve changes.

It was proposed that the manual control valve be replaced with an automatic one as a product improvement item for the Shuttle program. The automatic valve proposed would sense the normally measured parameters of LCG inlet coolant temperature and LCG coolant inlet and outlet temperature difference (LCG  $\Delta T$ ) for use in controlling comfort. It was further proposed that if computer

simulations gave encouraging results, that tests would be run on Apollo hardware in which the controller logic was simulated by real-time calculations.

LEC/ASD was tasked with determining the feasibility of such a controller using Program J196 on the 1110 computer and to develop suggested control logic for testing. This memorandum contains the results of that effort.

This concludes the requirements outlined by Action Item 46, Project 3030. The study was conducted by LEC/ASD, Dept. 641-11.

## 2. DISCUSSION

### 2.1 CONTROLLER LOGIC

#### 2.1.1 GENERAL

Using Program J196, the 41-node man program (ref. 1), a map of comfort can be plotted at steady state. Heat stored at steady state can be calculated for a grid of metabolic rates and inlet coolant temperatures at a given inlet gas dry bulb temperature, dewpoint temperature, and flow rate, and at a given suit heat leak. LCG coolant temperature difference (LCG  $\Delta T$ ) as calculated at steady state by the program can be plotted vs. metabolic rate for constant inlet coolant temperatures. At each plotted point, the heat stored at steady state can be noted. When the grid is completed, comfort boundaries can be interpolated between the heat storage value as follows:

$$\text{Stored heat at comfort (Btu)} = \frac{\text{Metabolic rate (Btu/hr)} - 278 \pm 65}{13.2}$$

A series of these comfort maps have been plotted. An example of such a study is found in reference 2. An example of this type of plot is shown in figure 1.

From plots such as figure 1, a relationship between inlet coolant temperature and LCG  $\Delta T$  at steady-state comfort is established (figure 2). It was established by averaging together results from several comfort curves such as in figure 1 and modifying them to get better results while developing the controller logic.

To develop logic for this controller, however, some transient data was needed in order to input to the controller how much variation in LCG  $\Delta T$  was due to previous inlet temperature adjustments and how much was due to changes in the activity level of the crewman (metabolic rate). Therefore, a controller was simulated on the 41-node man program which adjusted inlet LCG temperature by the heat storage of the body. This would be the ideal controller, but the hardware is not practical. Changes in  $\Delta T$  vs. changes in inlet temperature

were determined as the simulated man remained at perfect comfort while being stepped from one metabolic rate to another. These points were then plotted and an average curve drawn through the points (fig. 3). This curve represents the expected changes in  $\Delta T$  for every change in inlet temperature if the controller is perfectly tracking comfort during a transient in metabolic rate.

#### 2.1.2 METHOD 1 - USE OF FIGURE 2

The logic of the controller using figure 2 was developed as follows:

$$\Delta T_{in_1} = K_1 (T_{in'} - \bar{T}_{in_1}) \quad (1)$$

where  $\Delta T_{in_1}$  = the adjustment signal to the final control element,  $T_{in}$  (set point for the inlet coolant temperature to the LCG), calculated from the method using figure 2.

$K_1$  = The proportional gain constant for the method using figure 2.

$T_{in'}$  = The current inlet temperature to the LCG.

$\bar{T}_{in_1}$  = The inlet temperature at steady state comfort read off figure 2 as a function of the currently measured  $\Delta T$ .

#### 2.1.3 METHOD 2 - USE OF FIGURE 3

The logic of the controller using figure 3 was as follows:

$$\Delta T_{in_2} = K_2 (\bar{\Delta T}_{in_2}) \quad (2)$$

where

$\Delta T_{in_2}$  = The adjustment signal to the final control element  $T_{in}$  calculated from the method using figure 2.

$K_2$  = The proportional gain constant for this method.

$\bar{\Delta T}_{in_2}$  = The changes in the inlet temperature based on figure 3.

$\Delta T_{in2}$  is read from figure 3 in the following manner.  $dT_{in}/dt$  is calculated (the changes in inlet temperature with time).  $d\Delta T/dt$  is read from figure 3 as the expected change in  $\Delta T$  ( $\overline{\Delta T}$ ) during the same period of time. Since the same period of time is used,  $\overline{\Delta T}$  is read as a function of  $\Delta T_{in}$ . The actual change in  $\Delta T$  ( $\Delta\Delta T'$ ) from the expected  $\overline{\Delta T}$  is then calculated. A calculation of the deviation ( $\delta\Delta T$ ) of the actual  $\Delta\Delta T'$  from the expected  $\overline{\Delta T}$  is made as follows:

$$\delta\Delta T = \Delta\Delta T' - \overline{\Delta T} \quad (3)$$

$\delta\Delta T$  is the main error signal for this method. Error derivative and error integral compensation were also added:

$$\delta\Delta T = (\Delta\Delta T' - \overline{\Delta T}) + K_3 \frac{d(\delta\Delta T)}{dt} + K_4 \int \delta\Delta T dt \quad (4)$$

where

$$\delta\Delta T = \Delta\Delta T' - \overline{\Delta T} \text{ (eq. (3)).}$$

$K_3$  = the gain constant for error derivative compensation.

$\frac{d(\delta\Delta T)}{dt}$  = the error derivative compensation.

$K_4$  = the gain constant for the error integral compensation.

$\delta\Delta T dt$  = the error integral compensation.

The total error signal  $\delta\Delta T$  is then used on the  $\Delta\Delta T/\Delta T$  curve (fig. 3) to determine the adjustment to the final control element,  $T_{in}$ , by reading  $\overline{\Delta T}_{in2}$ .  $\overline{\Delta T}_{in2}$  is then applied in eq. (2) to determine the adjustment to the final control element supplied by this method.

#### 2.1.4 FINAL TOTAL CONTROLLER SIGNAL COMBINED FROM FIGURE 2 AND FIGURE 3 METHODS

The two methods described in eqs. (1) and (2) are then combined to give a final calculated value to the final control element,  $T_{in}$ :

$$T_{in} = T_{in}' + \left( \frac{\Delta T_{in_1} + \Delta T_{in_2}}{2} \right)$$

where  $T_{in}'$  is the current value of the final control element, the inlet LCG coolant temperature set point.

#### 2.1.5 NEGLECTED CONTROLLER CONSIDERATIONS

Sensor response times, controller deadband, and speed of the final control element were neglected. It should be pointed out that the final control element is the set point for the inlet temperature to the LCG. Another controller would be required to operate the diverter valve bypassing coolant flow around the sublimator in the portable life support system (PLSS) to control the actual LCG inlet temperature. The delay and logic of this controller was neglected in the program and the inlet temperature of the LCG was set instantly to the set point required.

Output differential and integral compensation were attempted in both methods (eqs. 1 and 2). Lack of time prevented the development of gain constants that would improve controller results and these items were not incorporated into the test logic. Error differential and integral compensation in method 1 was never tried for lack of time.

Controller logic was based on Reference 3, pages 6-SERVO-1 through 6-SERVO-20.

#### 2.1.6 PROGRAM CODE AND SAMPLE INPUT

Appendix A shows the program edits used to add the controller logic to Program J196. A nomenclature list is included.

Appendix B shows the input used to develop the necessary calculations from program J196 to do the required pretest predictions.

## 2.2 CONTROLLER LOGIC VERIFICATION AND PRETEST PREDICTIONS

A 40-hour metabolic profile was run on the J196 program, and values for the gain constants  $K_1$ ,  $K_2$ ,  $K_3$  and  $K_4$  were varied to obtain optimum controller action. Figures 4 and 5 show the best results that were obtained before an actual hardware test of a simulated controller was run. Figure 4 shows the metabolic profile vs. time. On the same graph, the controller selected inlet temperature and the resulting LCG AT are plotted. Figure 5 shows the resulting heat stored vs. time and how it compares to the comfort limits. On the same graph, controller action is shown by a plot of LCG inlet temperature vs. time.

The best values for the controller parameters resulting from these computer runs were as follows:

- a. Values for the inlet temperature vs. LCG AT at steady state comfort were taken from figure 2.
- b. Values for  $\Delta\Delta T$  vs.  $\Delta T$  while tracking perfect comfort were taken from figure 3.
- c. Values for  $K_1$ ,  $K_2$ ,  $K_3$  and  $K_4$  were set at 0.085, 2.6, 0.0000001, and 0.01, respectively.

Pretest predictions of the controller test profile were run using the best controller logic achieved to that point. Metabolic rate levels were proposed to be 15 minutes each of 800, 2000, 400, and 1600 Btu/hr. Results are shown in figure 6. This graph shows heat stored vs. comfort limits. Valve action is shown by plotting inlet LCG temperature for expected test conditions. Recommendations for the test simulated controller included the following:

- a. Set point values for the two curves were set at the figure 2 and 3 values as before.
- b.  $K_1$ ,  $K_2$ ,  $K_3$ , and  $K_4$  values were set at 0.0952, 2.912, 0.0000001, and 0.01, respectively.

### 3. CONCLUSIONS AND RECOMMENDATIONS

#### 3.1 CONCLUSIONS

It can be concluded from computer simulation that crewman comfort can be assured by using automatic control of the inlet temperature of the coolant into the LCG when input to the controller consists of measurements of the LCG inlet temperature and AT. Subsequent tests using a facsimile of the control logic developed in the computer program confirmed the feasibility of such a design scheme.

Automatic comfort control has been demonstrated as a desirable product improvement. It is not a design requirement.


#### 3.2 RECOMMENDATIONS

This controller should be fabricated and tested if funds can be made available for product improvement or if some reason is discovered that makes the inclusion of the device mandatory.

Design of the controller should include manual adjustment for shifting the curves from figures 2 and 3 to conform to physical changes such as a heat leak or inlet suit ventilation conditions and to compensate for personal preferences in comfort level. Design provisions should also be included in the PLSS hardware to allow that the controller be bypassed and that manual control of the diverter valve be available.


Final values of  $K_1$ ,  $K_2$ ,  $K_3$ , and  $K_4$  should be determined by test. Final values for curves 2 and 3 can also be fine-tuned in testing. Output differential and integral compensation should be tested on both methods and error differential and integral compensation tried on method 1.

Recommendations for controller logic considerations were taken from reference 3, pages 6-SERVO-1 through 6-SERVO-20.




LCG INLET TEMPERATURE VS  
 $\Delta T$  AT COMFORT

REPRODUCTION OF THE  
ORIGINAL PAGE IS POOR



CHANGE IN LCG AT VS CHANGE IN LCG INLET  
TEMPERATURE WHILE TRACKING COMFORT



CHANGE IN LCG INLET T (°F)

DWC  
12/4/77




FIGURE 4




FIGURE 5

DWC  
1/6/77




FIGURE 6

#### REFERENCES

1. Morgan, Lois W., et al: 41-Node Transient Metabolic Man Program, LEC/672-23-030031, May 1970.
2. Cook, D. W.: EMU Comfort Reference Data, TM-675-44-00103, August 25, 1970
3. Barker, R. S., et al: G-189A Generalized Environmental/Thermal Control and Life Support Systems Computer Program, McDonnell Douglas Contract NAS9-10330, September 1971.

## APPENDIX A

PROGRAM EDITS TO MODEL THE  
PROPOSED CONTROLLER  
(NOMENCLATURE LIST IS INCLUDED)

**REPRODUCIBILITY OF THE  
ORIGINAL PAGE IS POOR**

```

0125    74*      CCTB(5G),CCMODE(5G)
0126    75*      DIMENSION CCOLDL(16),CCDTWI(16)
0127    76*      DIMENSION CCDELT(12),CCDLOP(12)
0127    77*      IF ANY CURVE DIMENSION IS CHANGED CRVS MUST BE RDIMENSIONED
0127    78*      IF NEW CURVES ARE ADDED ACRV,ICRVP,CRVs, AND CRVL SHOULD BE UPDATED
00130    79*      EQUIVALENCE ( CRVL(1),CGASH8 ),( CRVL(2),CMODE ),( CRVL(3),CTGIN ),
00130    80*          ( CRVL(4),CTDW ),( CRVL(5),CTWI ),( CRVL(6),CPCAP ),
00130    81*          ( CRVL(7),CPSC ),( CRVL(8),CPL2 ),( CRVL(9),CPH ),
00130    82*          ( CRVL(10),CUEFF ),( CRVL(11),CAF ),( CRVL(12),CCFMS ),
00130    83*          ( CRVL(13),CAKS ),( CRVL(14),DAKS ),( CRVL(15),CTDEWC ),
00130    84*          ( CRVL(16),CTCAB ),( CRVL(17),CVLAb ),( CRVL(18),CTW )
00131    85*      EQUIVALENCE ( ICRVF(1),LPCASB ),( ICRVP(2),PMODE ),( ICRVP(3),NPTGIN ),
00131    86*          ( ICRVP(4),NPTEF ),( ICRVP(5),NPTWI ),( ICRVP(6),NPPCAB ),
00131    87*          ( ICRVP(7),NPFGC ),( ICRVP(8),NPPOZ ),( ICRVP(9),NPRM ),
00131    88*          ( ICRVF(10),NPUEFF ),( ICRVP(11),MPF ),( ICRVP(12),NPCFMS ),
00131    89*          ( ICRVF(13),NPAKS ),( ICRVP(14),OPAKS ),( ICRVP(15),NPTDWC ),
00131    90*          ( ICRVP(16),NPTCAF ),( ICRVP(17),NPVCAP ),( ICRVP(18),NPTW )
00132    91*      EQUIVALENCE ( CPVS(1,1),CCASB(1,1) ),( CPVS(1,11),CCYODE ),
00132    92*          ( CPVS(1,12),CCTCIN ),( CPVS(1,13),CCTDEx ),
00132    93*          ( CPVS(1,14),CCTWI ),( CPVS(1,15),CCPCAB ),
00132    94*          ( CPVS(1,16),CCPBC ),( CPVS(1,17),CCPOZ ),
00132    95*          ( CPVS(1,18),CCNM ),( CPVS(1,19),CCUEFF ),
00132    96*          ( CPVS(1,20),CAF ),( CPVS(1,21),CCCFMS ),
00132    97*          ( CPVS(1,22),CCAKS ),( CPVS(1,23),DDAKS ),
00132    98*          ( CPVS(1,24),CCTCAC ),( CPVS(1,25),CCTCAB ),
00132    99*          ( CPVS(1,26),CCVCAE ),( CPVS(1,27),CCT )
00133   100*      DATA (TSET(I),I=1,41)/98.0,97.0,97.0,96.0,98.0,98.3,95.9,94.4,96.1,
00133   101*          .,95.1,94.1,93.7,96.1,95.1,94.1,93.7,97.6,96.5,
00133   102*          .,95.1,94.5,97.0,96.5,95.1,94.5,95.9,95.7,95.6,
00133   103*          .,95.0,95.0,95.7,95.6,95.5,95.8,95.5,95.5,95.5,
00133   104*          .,95.0,95.5,95.7,95.5,95.5,95.5,95.5,95.5,95.5
00134   105*      DATA (C(I),I=1,41)/6.67,1.426,0.496,0.535,20.9,34.9,9.42,2.69,1.382
00134   106*          ,3.35,0.644,0.438,1.352,3.35,0.644,0.484,4.4,10.2
00134   107*          .,1.59,1.192,0.4,1.2,1.58,1.192,0.1568,0.0738,
00134   108*          .,0.0392,0.164,0.1568,0.3738,3.0992,0.184,0.2645,
00134   109*          .,0.0738,0.148,0.247,0.2645,0.0738,0.148,0.247,
00134   110*          4.94/
00135   111*      DATA ( PCFL0(J),J=1,5)/-2.,125.,275.,275/
00136   112*      DATA NB/71*0./,AKI/15.5/
00137   113*      DATA (CCDELT(J),J=1,12)/0.46,90.0,1.51,80.0,2.75,70.0,0.4,0.05,60.0,
00138   114*          5.37,50.0,6.75,40.0/
00138   115*      DATA (CCCOLDL(J),J=1,16)/-4.0,27.5,-1.2,9.0,-0.5,5.0,0.0,0.0,0.4,
00138   116*          -3.0,0.0,-7.0,2.1,-15.0,4.4,-30.0/
00138   117*      DATA (CCDTWI(J),J=1,16)/-31.0,4.4,-15.0,2.1,-7.0,0.9,-3.0,0.4,0.0,
00138   118*          0.0,5.0,-0.5,9.0,-1.2,27.5,-4.0/
00139   119*      DATA DELIA(5/20.0)
00140   120*      C DEFINITION OF BODY SEGMENT TEMPERATURE SUBSCRIPTS
00140   121*          C T(1) = HEAD CORE      T(2) = HEAD MUSCLE      T(3) = HEAD FAT
00140   122*          C T(4) = HEAD SKIN       T(5) = TRUNK CORE      T(6) = TRUNK MUSCLE
00140   123*          C T(7) = TRUNK FAT        T(8) = TRUNK SKIN      T(9) = RIGHT ARM CORE
00140   124*          C T(10) = RIGHT ARM MUSCLE  T(11) = RIGHT ARM FAT   T(12) = RIGHT ARM SKIN
00140   125*          C T(13) = LEFT ARM CORE     T(14) = LEFT ARM MUSCLE  T(15) = LEFT ARM FAT
00140   126*          C T(16) = LEFT ARM SKIN      T(17) = RIGHT LEG CORE  T(18) = RIGHT LEG MUSCLE
00140   127*          C T(19) = RIGHT LEG FAT       T(20) = RIGHT LEG SKIN  T(21) = LEFT LEG CORE
00140   128*          C T(22) = LEFT LEG MUSCLE     T(23) = LEFT LEG FAT    T(24) = LEFT LEG SKIN
00140   129*          C T(25) = RIGHT HAND CORE    T(26) = RIGHT HAND MUSCLE T(27) = RIGHT HAND FAT

```

CD362	302*	C	SO THAT CRANE CAN STEP MORE ACCURATELY	CD5220
CD304	303*		CALL DISCON	000222
CD305	304*		CONTINUE	000225
CD306	305*		ENDCNX=.TRUE.	000225
CD307	306*		JTE=JT+1	000226
CD310	307*		XHATAR(JT)=SETI/60.	000231
CD311	308*		IF(JT.EQ.1)GO TO 247	000235
CD311	309*	C	PUT THE XHAT VALUES IN ASCENDING ORDER	000235
CD313	311*		CALL ASCEND(XHATAR,JT)	000240
CD314	311*		CONTINUE	000245
CD315	312*		XHAT=XHATAR(1)	000245
CD316	313*		IXH=1	000246
CD317	314*		PREC=5.	000250
CD322	315*		IF(ICOND.EQ.0) PREC=3.	000252
CD322	316*		OLCT=-1.	000256
CD323	317*		DTIME=DT/60.	000260
CD324	318*		MIN=3	000263
CD325	319*		VPPCAB = VPP(TDE,C)	000265
CD326	320*		SPHCAB=VPPCAB*18/(PCAB*29.)	000271
CD327	321*		TOTCO2=0.0	000276
CD330	322*		TOTCO2=0.0	000277
CD331	323*		TOTWCNE=0.0	000300
CD332	324*		FD=TR=0.0	000301
CD333	325*	B37	CONTINUE	000303
CD334	326*		HDTIME	000303
CD335	327*		INITL=0	000304
CD336	328*		HC=H	000305
CD337	329*		AP=API	000305
CD340	330*		IF(MODE.GT.0) ARE=AC	000307
CD342	331*		IF(MODE-1)21,22,23	000311
CD345	332*	21	WRITE(6,117)	000316
CD347	333*		FORMAT(16X,17HSHIRTSLEEVES MODE//)	000322
CD350	334*		GO TO 26	000327
CD351	335*	22	WRITE(6,118)	000327
CD353	336*		FORMAT(16X,18HNORMAL SUITED MODE//)	000331
CD354	337*		GO TO 26	000335
CD355	338*	23	IF(MODE.GT.2) GO TO 24	000337
CD357	339*		EVA=.TRUE.	000342
CD360	340*		WRITE(6,119)	000344
CD362	341*		FORMAT(21X,8HEVA MODE//)	000351
CD363	342*		GO TO 26	000351
CD364	343*	24	WRITE(6,120)	000353
CD365	344*		FORMAT(13X,27HSUITED WITH HELMET OFF MODE//)	000360
CD367	345*	26	IF(IPLOP) WRITE(6,1001)	000360
CD372	346*	1501	FORMAT(18X,12HPOST LANDING)	000366
CD373	347*		IF(.NOT.IPLOP) GO TO 1010	000366
CD375	348*		WRITE(6,1702)PLAS,TATM,VOLCAB,PO2A,PN2A,CPA,NUMEN,PA,AREAW,	000370
CD375	349*		* TDEA,CFMC	000370
CD412	350*	1701	FORMAT(* ATMOSPHERIC GAS CONSTANT, LB-FT/(LBM-DEG R))-----,F9.3/	000411
CD412	351*	1	DRY BULB TEMP. OF ATMOSPHERE, DEG.F-----,F9.3/	000411
CD412	352*	2	VOLUME OF CABIN, CU FT-----,F9.3/	000411
CD412	353*	3	ATMOSPHERIC OXYGEN PARTIAL PRESSURE, PSIA-----,F9.3/	000411
CD412	354*	4	ATMOSPHERIC NITROGEN PARTIAL PRESSURE, PSIA-----,F9.3/	000411
CD412	355*	5	SPECIFIC HEAT OF ATMOSPHERE, BTU/(LBM-DEG F))-----,F9.3/	000411
CD412	356*	6	NUMBER OF MEN-----,I9/	000411
CD412	357*	7	ATMOSPHERIC PRESSURE, PSIA-----,F9.3/	000411
CD412	358*	8	CABIN WALL AREA, SQ FT-----,F9.3/	000411

```

1002      587*
1004      588*
1005      589*
1006      590*
1007      591*
1008      592*
1009      593*
1010      594*
1011      595*
1012      596*
1013      597*
1014      598*
1015      599*
1016      600*
1017      601*
1018      602*
1019      603*
1020      604*
1021      605*
1022      606*
1023      607*
1024      608*
1025      609*
1026      610*
1027      611*
1028      612*
1029      613*
1030      614*
1031      615*
1032      616*
1033      617*
1034      618*
1035      619*
1036      620*
1037      621*
1038      622*
1039      623*
1040      624*
1041      625*
1042      626*
1043      627*
1044      628*
1045      629*
1046      630*
1047      631*
1048      632*
1049      633*
1050      634*
1051      635*
1052      636*
1053      637*
1054      638*
1055      639*
1056      640*
1057      641*
1058      642*
1059      643*

      *RITE(6,99)
      MODEC=MODE
      MODE=MODEC
      EVAE=.FALSE.
      GO TO 287
      288 CONTINUE
      IF (CTCIN) CALL LAGIN (1,CCTGIN,NPTGIN,2,TIME,TGIN)
      IF (CTDEW) CALL LAGIN (2,CCTDEW,NPTDEW,2,TIME,TDEW)
      IF (CTWI) CALL LAGIN (3,CCTWI,NPTWI,2,TIME,TWI)
      IF (CPGCAE) CALL LAGIN (4,CCPGCAE,NPPCAE,2,TIME,PCAB)
      IF (CPGC) CALL LAGIN (5,CCPGC,NPPGC,2,TIME,PG1)
      IF (CP02) CALL LAGIN (6,CCP02,NPP02,2,TIME,P02)
      IF (CRM) CALL LAGIN (7,CCRM,NPRM,2,TIME,RM)
      IF (CUEFF) CALL LAGIN (8,CCUEFF,NPUEFF,2,TIME,UEFF)
      IF (.NOT. CWF) GO TO 380
      *FCOLD=WF
      CALL LAGIN (9,CCWF,NPWF,2,TIME,WF)
      WDT1=WDT1*WF/WFOLD
      380 CONTINUE
      IF (CCCFMS) CALL LAGIN (10,CCCFMS,NPCFMS,2,TIME,CFMS)
      IF (.NOT. CAKS) GO TO 720
      CALL LACIN (11,CCAKS,NPAKS,2,TIME,AKST)
      DO 725 I=1,10
      AKS(I)=AKST
      725 CONTINUE
      IF (DAKS) CALL LAGIN (12,DDAKS,UPAKS,2,TIME,AKS(10))
      730 IF (.NOT. COASRB) GO TO 400
      DO 726 I=1,10
      CALL LAGIN (13,CCQASPB(I),NPQASB,2,TIME,QASPB(I))
      726 CONTINUE
      430 CONTINUE
      IF (TRAN .OR. IQ.EQ. 0) GO TO 430
      CALL THTRX
      430 CONTINUE
      DLTTAT=DELTAT
      *LPLT=LDLT
      CALL SUIT
      DELTAT=T-TWI
      TWI1=TWI
      DLDLT=DELTAT-DELTAT1
      EDLDLT=EDDLT*T/H/H0
      *CLDLT=CLDLT-CLDLT
      LUDLDT=(DLDLT-WDLDT)*H/H0/H
      TDLDT=TDLDT+GLDLT*H/H0/H
      WDLDT=WDLDT*DDLDT+T.H0/H0/TDLDT
      CALL LAGIN (9,CCDLDT,6,2,DELTAT,TWI1)
      TWI=TWI+2.6*T1
      CALL LAGIN (9,CCDELT,6,2,DELTAT,TWI2)
      TWI2=TWI+0.65*(TWI2-TWI1)
      TWI=(TWI1+TWI2)/2.0
      IF (TWI.LT.90.0) TWI=90.0
      IF (TWI.GT.40.0) TWI=40.0
      DTWI=TWI-TWI1
      CALL LAGIN (10,CCDTWI,6,2,DTWI,EDDLT)
      H0/H
      O2RATE= (0.0001708-(IPU-0.7071/0.293*0.000123))/RM
      CO2RATE=O2RATE*44.0/32.0*RL

```

REPRODUCTION OF THE  
 INFORMATION HEREIN IS PROHIBITED

```

001226
001233
001235
001237
001240
001242
001242
001253
001265
001277
001311
001323
001335
001347
001361
001363
001365
001375
001402
001402
001413
001415
001430
001430
001432
001445
001452
001452
001467
001467
001467
001467
001474
001477
001500
001502
001504
001507
001511
001513
001517
001521
001530
001533
001537
001547
001553
001563
001570
001573
001601
001607
001612
001622
001624
001633

```

```

1244    701*      KOUNTR = KOUNTR+24
1245    702*      704 IF (IMPAIP .AND. OSTOR .GT. 1000) GO TO 706
1247    703*      GO TO 705
1250    704*      716 IF (KOUNTR .GT. 24) GO TO 709
1252    705*      WRITE(6,632)
1254    706*      WRITE(6,601)
1256    707*      GO TO 714
1257    708*      709 WRITE(6,99)
1261    709*      WRITE(6,601)
1263    710*      714 WRITE(6,608)
1265    711*      TERM=.TRUE.
1266    712*      GO TO 14
1267    713*      705 LCONTINUE
1270    714*      WRITE(6,113) PTIM,TGOUTS,SHSO,T(1),T(72),TISAV,TOSAV,QTSUIT,SOUG,
1271    715*      ICEVAP,TOTL,STORAT,OSHIV,CSTOR
1271    716*      SUROT = SUBOUT - SURIN
1271    717*      UTTPP=760.0/14.7*PH2050
1271    718*      TDE=OTDEWPT(OTPRT)
1313    719*      UTTPPI=PG*SHSO#32.D/18.U*760.0/14.7
1314    720*      TOWOT1=DEWPT(OTPRT)
1315    721*      SATPRS=VPP(TGOUTS)
1316    722*      HELPPCMEPH2050/SATPRS
1317    723*      IF(ILCG) WRITE(6,999) T1,I,TWO,DELTAT,TDEW,TGIN,TOTR2,TOTC02,TOTWCN,
1317    724*      FDRTF,RHM,WF
1335    725*      NAMELIST/W01/TW11,GLTAT1,GLDLT,WGLDLT,DTWI,EDLDLT,TW12
1335    726*      WRITE(6,001)
1341    727*      IF (MODE .EQ. 1 .OR. MODE .EQ. 2) WRITE(6,2002) HC02MH
1345    728*      IF (IPL0P) WRITE(6,1603) TCAB,TDEWC,CO2MMH
1353    729*      1603 FORMAT(15H CABIN TEMP =,F7.2, 6H DEG F,17H DEWPOINT TEMP =,
1353    730*      F7.2, 6H DEG F +17H CO2 PRESSURE =,F7.2, 6H MM HG/)
1354    731*      OLATTR = OLAT(1) + OLAT(5) + OLAT(2) + OLAT(3) + OLAT(6)
1355    732*      IF (IPL0P) GO TO 1605
1357    733*      IF (KOUNTR .EQ. 48) GO TO 1606
1361    734*      KOUNTR = KOUNTR + 3
1362    735*      GO TO 1608
1363    736*      1606 WRITE(6,112)
1365    737*      KOUNTR = 0
1366    738*      GO TO 1608
1367    739*      1605 IF (KOUNTR .EQ. 48) GO TO 1607
1371    740*      KOUNTR = KOUNTR + 4
1372    741*      GO TO 1602
1373    742*      1607 WRITE(6,112)
1375    743*      KCUNTR = P
1376    744*      1608 IF (ITRAN) GO TO 490
1380    745*      ASSIGN 14 TO IJM
1381    746*      ASSIGN 12 TO IJMP
1382    747*      GO TO 780
1382    748*      49. CONTINUE
1384    749*      IF(JT .LE. 0 .OR. ENDONX)GO TO 915
1386    750*      IXH=IXH+1
1387    751*      IF(IXH .LE. JT)GO TO 910
1391    752*      JT=2
1392    753*      GO TO 915
1412    753*      914 ENDONX=.TRUE.
1413    754*      XHAT=XHATAR(IXH)
1414    755*      915 CONTINUE
1415    756*      C 915 CHECK IF CRANE HAS SET THE FLAG ENDONX TO FALSE TO INDICATE THE

```

## NOMENCLATURE OF VARIABLES APPEARING IN CONTROLLER EDITS

<u>Program name</u>	<u>Document engineering symbol</u>	<u>Description</u>
CCDELT	Figure 2	Curve of LCG $\Delta T$ vs. inlet temperature at comfort (both in $^{\circ}\text{F}$ ).
CCDLDL	Figure 3	Curve of change in LCG $\Delta T$ vs. change in LCG inlet temperature while tracking perfect comfort with the changes in inlet temperature as the dependent variable (all $^{\circ}\text{F}$ ).
CCDLDP	not currently used.	
CCDTWI	Figure 3	Curve of change in LCG $\Delta T$ vs. change in LCG inlet temperature while tracking perfect comfort with the change in LCG $\Delta T$ as the dependent variable (all $^{\circ}\text{F}$ ).
DELTAT	LCG $\Delta T$	Difference in the liquid cooled garment inlet and outlet coolant temperature ( $^{\circ}\text{F}$ ).
DDLDLT	$d\Delta T/dt$	Error differential compensation ( $^{\circ}\text{F}/\text{hr}$ ).
DLDLT	$\Delta\Delta T$ or $d\Delta T/dt$	Change in LCG $\Delta T$ with respect to time. (Time cancels out on the $\Delta\Delta T$ vs. $\Delta T$ curve) <sup>1</sup> ( $^{\circ}\text{F}/\text{hr}$ or $^{\circ}\text{F}$ ).
DLTAT1	-----	Difference in the liquid cooled garment inlet and outlet coolant temperatures calculated in previous time step ( $^{\circ}\text{F}$ ).
DTWI (first appearance)	$\Delta T_{in2}$	The adjustment signal to the final control element using method 2, figure 3, eq. (2).
DTWI (second appearance)	-----	Final complete adjustment signal to the final control element, $T_{in}$ .

NOMENCLATURE OF VARIABLES APPEARING IN CONTROLLER EDITS (Continued)

<u>Program name</u>	<u>Document engineering symbol</u>	<u>Description</u>
DTWI (second appearance)	$dT_{in}/dt$	Changes in LCG inlet temperature between current time increment and last ( $^{\circ}\text{F}/\text{hr}$ ).
EDLDLT	$\bar{\Delta T}$	Expected change in LCG $\Delta T$ ( $d\Delta T/dt$ ) that would accompany a change in LCG inlet temperature if perfect comfort were being tracked ( $^{\circ}\text{F}/\text{hr}$ ).
H	dt	Current time increment (hr).
HO	-----	Previous time increment (hr).
RDLDLT	$\int \delta\Delta T dt$	Summation of $\delta\Delta T$ times the time increment ( $^{\circ}\text{F}/\text{hr}$ ).
TWI (first appearance)	-----	New position of the final control element as calculated by method 2, figure 3, eq. (2) ( $^{\circ}\text{F}$ ).
TWI (second appearance)	$T_{in}$	New position of the final control element ( $^{\circ}\text{F}$ ).
TWI1	-----	Position of the final control element at the previous time increment ( $^{\circ}\text{F}$ ).
TWI2	-----	Position of the final control element as calculated by method 1, figure 2, eq. (1).
WDLDLT	$\delta\Delta T$	Deviation of the actual change in LCG $\Delta T$ from the expected change in LCG $\Delta T$ WDLDLT at the previous time increment.
WILDLT	-----	

**APPENDIX B**

**INPUT TO PROGRAM J196 TO BRING ABOUT  
THE NECESSARY CONTROLLER PRETEST PREDICTIONS  
AND EVALUATIONS**

ELT,ULL DATA:  
ELT007 RL71-3 D9/18/76 08:20:50 (1,2)

00001 C00 \$INPUT  
00002 C00 MODE=2,  
00003 NEW C02 MODE=1,  
00004 C00 RM=1200.,  
00005 NEW C02 RM=1000.0,  
00006 C00 DEFF=0.0,  
00007 C00 AC=19.3,  
00008 NEW C02 AP1=19.5,  
00009 -01 C00 G=C.,  
000010 C00 ALUG=0.0141,  
000011 C00 AKUG=.046,  
000012 C00 EUG=0.9,  
000013 C01 ACSUITE=9.22,2.91,2.91,6.38,6.38,0.77,0.77,1.19,1.19,1.19,  
000014 C01 ARSUITE=7.34,2.32,2.32,5.07,5.07,0.62,0.62,0.96,0.96,1.47,  
000015 C01 ALS=9\*.0078,.021,  
000016 C01 AKSE=9\*.000383,.02155,  
000017 C01 EOS=9\*0.91,.62,  
000018 C01 ETSE=10\*0.90,  
000019 C01 WS=15.60,4.89,4.89,10.82,10.82,1.22,1.22,1.95,1.95,2.75,  
000020 C01 CPS=9\*0.22,0.30,  
000021 NEW C02 GASRE=10\*308.,  
000022 NEW C02 GASRB=10\*120.0,  
000023 C00 VF=0.0,  
000024 C00 VOLHMT=0.1968,  
000025 C00 CFMS=6.,  
000026 NEW C02 CFMS=8.90,  
000027 C00 TGIN=80.,  
000028 NEW C02 TGIN=45.0,  
000029 C00 TDE=750.,  
000030 NEW C02 TDE=43.0,  
000031 C00 CPG=0.22,  
000032 C00 PG=3.65,  
000033 NEW C02 PG=4.0,  
000034 C00 PG2=3.65,  
000035 NEW C02 PG2=4.0,  
000036 C00 LCUST,  
000037 -01 C00 WF=240.,  
000038 C00 THI=4.,  
000039 NEW C02 THI=72.,  
000040 C00 CPW=1.0,  
000041 C00 UAGE=43.5,  
000042 C00 DT=0.05,  
000043 C00 PRINTI=5.0,  
000044 C00 SETI=600.,  
000045 NEW C02 SETI=240.0,  
000046 MCASES=25.0,  
000047 NEW C02 STLPFE=TRUE.,  
000048 NEW C02 PM=800.0,  
000049 NEW C02 TWI=75.0,  
000050 NEW C02 PRINTI=1.0,  
000051 C00 SEND  
000052 NEW C02 \$INPUT  
000053 NEW C02 RM=500.0,  
000054 NEW C02 SETI=15.0,  
000055 NEW C02 RM=800.0,

L00-056 NEW 0.72  
L00057 NEW 0.02  
L00058 NEW 0.02  
L00059 NEW 0.02  
L00060 NEW 0.02  
L00061 NEW 0.02  
L00062 NEW 0.02  
L00063 NEW 0.02  
L00064 NEW 0.02  
L00065 NEW 0.02  
L00066 NEW 0.02  
L00067 NEW 0.02  
L00068 NEW 0.02  
L00069 NEW 0.02  
L00070 NEW 0.02  
L00071 NEW 0.02  
L00072 NEW 0.72  
L00073 NEW 0.72  
L00074 NEW 0.02  
L00075 -15 0.00  
  
SEND  
SINPUT  
    RM=1000.0,  
    SETI=420.0,  
    SETI=30.0,  
    RM=2100.0,  
  
SEND  
SINPUT  
    RM=1500.0,  
    SETI=720.0,  
    SETI=45.0,  
    RM=400.0,  
  
SEND  
SINPUT  
    RM=2000.0,  
    SETI=960.0,  
    SETI=60.0,  
    RM=1600.0,  
  
SEND  
SPMD,B

END ELT.

PHEP  
PURPUR 0026-09/18-08:20