

## JSC/EC5 U.S. Spacesuit Knowledge Capture (KC) Series Synopsis

All KC events will be approved for public using NASA Form 1676.

*This synopsis provides information about the Knowledge Capture event below.*

**Topic:** CO2 Washout Testing of NASA Space Suits

**Date:** October 2, 2012 **Time:** 10:30-12:30 pm **Location:** JSC/B5S/R3102

**DAA 1676 Form #: 38113**

A PDF of the presentation is also attached to the DAA 1676 and this is a link to all lecture material and video: [\\js-ea-fs-03\pd01\EC\Knowledge-Capture\FY13 Knowledge Capture\20121002 Norcross\\_CO2 Washout\FOR 1676 Review and Public Release](\\js-ea-fs-03\pd01\EC\Knowledge-Capture\FY13 Knowledge Capture\20121002 Norcross_CO2 Washout\FOR 1676 Review and Public Release)

\*A copy of the video will be provided to NASA Center for AeroSpace Information (CASI) via the Agency's Large File Transfer (LFT), or by DVD using the USPS when the DAA 1676 review is complete.

### **Assessment of Export Control Applicability:**

This Knowledge Capture event has been reviewed by the EC5 Spacesuit Knowledge Capture manager in collaboration with the author and is assessed to not contain any technical content that is export controlled. It is requested to be publicly released to the NESC and JSC Engineering Academy, as well as to STI for distribution through NTRS or NA&SD (public or non-public) and with video through DVD or Large File Transfer request or YouTube viewing with download of any presentation material.

\*Jason Norcross' personal contact information has been removed in the final PDF of the original PowerPoint presentation, which is attached to this 1676, and will be used for distribution.

**Presenter:** Jason Norcross

**Synopsis:** During the presentation "CO2 Washout Testing of NASA Spacesuits," Jason Norcross discussed the results of recent carbon dioxide CO2 washout testing of NASA spacesuits including the Rear Entry I-suit (REI), Enhanced Mobility Advanced Crew Escape Suit (EM-ACES), and possibly the ACES and Z-1 EVA prototype. When a spacesuit is used during ground testing, adequate CO2 washout must be provided for the suited subject. Symptoms of acute CO2 exposure depend on the partial pressure of CO2 (ppCO2) available to enter the lungs during respiration. The primary factors during ground-based testing that influence the ppCO2 level in the oronasal area include the metabolic rate of the subject and air flow through the suit. These tests were done to characterize inspired oronasal ppCO2 for a range of workloads and flow rates for which ground testing is nominally performed. During this presentation, Norcross provided descriptions of the spacesuits, test hardware, methodology, and results, as well as implications for future ground testing and verification of flight requirements.

**Biography:** Jason Norcross is the lead for the EVA Physiology Laboratory and a lead scientist for the Human Health and Countermeasures Element in the Human Research Program (HRP). He has research interests in environmental physiology, human health and performance in EVA suits, and decompression sickness. Recently, he was the lead for the Human Health and Performance sub-team as part of the

Exploration Atmospheres Action Team, which studied the implications of choosing an alternative environment to facilitate robust EVA operations. He is a frequent presenter at both the Aerospace Medical Association annual meeting and HRP Investigators' Workshop. He came to the Johnson Space Center in 2005 as an employee with Wyle Laboratories and has worked in the Exercise Physiology Laboratory and EVA Physiology, Systems and Performance Project before his current roles. Norcross was graduated from the University of California, Davis with a bachelor of science degree in exercise science in 1999 and a master of science in exercise science in 2002.

**EC5 Spacesuit Knowledge Capture POCs:**

Cinda Chullen, Manager

[cinda.chullen-1@nasa.gov](mailto:cinda.chullen-1@nasa.gov)

(281) 483-8384

Vlادenka Oliva, Technical Editor (Jacobs)

[vladenka.r.oliva@nasa.gov](mailto:vladenka.r.oliva@nasa.gov)

(281) 461-5681

# CO<sub>2</sub> Washout Testing of NASA Space Suits


*Jason Norcross, MS*

*Lead Scientist, EVA Physiology Laboratory*

*[jason.norcross-1@nasa.gov](mailto:jason.norcross-1@nasa.gov)*

*281-483-7114*

# Presentation Outline

- Background
  - Test Objectives
  - Test Plan Overview
  - Test Hardware Description
  - Methods
  - Data Analysis
  - Conclusions
  - Recommended Forward Work
  - Z-1 Test Quicklook Results
  - EVA Suit CO<sub>2</sub> Washout Comparison
  - ACES Test Quicklook Results
  - MMSEV Test Quicklook Results
  - Lessons Learned
- 
- REI Suit and EM-ACES

# Background

- Carbon dioxide (CO<sub>2</sub>) can build up quickly inside an enclosed environment if proper ventilation is not in place
- Acute health effects of high CO<sub>2</sub> exposures include:
  - Headache,
  - Dizziness
  - Shortness of breath
  - Sweating
  - Increased blood pressure
  - Unconsciousness
  - Death
- Maintaining adequate CO<sub>2</sub> washout during EVA or ground based suit testing is critical to crew and subject safety

## Life Support Inputs

Dry Air  
O<sub>2</sub>  
LCG Cold Water




The liquid cooling garment (LCG) is the primary control for heat removal



## Metabolic Outputs

CO<sub>2</sub>  
Heat  
Humidity

The suit ventilation loop handles suit pressurization, O<sub>2</sub> delivery, CO<sub>2</sub> washout, humidity removal and contributes to heat removal



# Background

Carbon dioxide (CO<sub>2</sub>) can build up quickly inside an enclosed environment if proper ventilation is not in place and lead to acute health effects

- Maintaining adequate CO<sub>2</sub> washout during an extravehicular activity (EVA) is required to avoid negative health and performance effects
- Likewise, maintaining adequate CO<sub>2</sub> washout during space suit ground testing is necessary for test subject safety

The NASA Space Suit and Crew Survival Systems Branch, in conjunction with the EVA Physiology Laboratory, developed a protocol for evaluating CO<sub>2</sub> washout in various prototype space suits

- Testing was performed to determine if the suit ventilation systems provided adequate CO<sub>2</sub> washout during ground-based testing.

More stringent CO<sub>2</sub> washout requirements may be necessary for cases in which the subject cannot be quickly returned to a low level of ambient ppCO<sub>2</sub>, such as during spaceflight.

- These cases were out of the scope of this test series and were therefore not examined in depth.
- Results from these tests all assume perfect CO<sub>2</sub> removal in the system

# CO<sub>2</sub> Exposure Limits

NASA/TP-2010-216126 (Law et. al, 2010)

**Table 1. Physiological tolerance time for various CO<sub>2</sub> concentrations and acute health effects of high concentrations of CO<sub>2</sub>.**

| PHYSIOLOGICAL TOLERANCE |      |                              | ACUTE HEALTH EFFECTS   |  |
|-------------------------|------|------------------------------|--|--|
| ppCO <sub>2</sub>       |      | Maximum Exposure Limit (min) | Duration of Exposure   | Effects  |
| mm Hg                   | %    |                              |  |  |
| 3.8                     | 0.5% | Indefinite                   |  |  |
| 7.5                     | 1.0% | Indefinite                   |  |  |
| 11                      | 1.5% | 480                          |  |  |
| 15                      | 2.0% | 60                           | Several hours  | Headache, dyspnea upon mild exertion   |
| 23                      | 3.0% | 20                           | 1 hour   | Headache, sweating, dyspnea at rest  |
| 30                      | 4.0% | 10                           | (4-5%)   |  |
| 38                      | 5.0% | 7                            | Within few minutes   | Headache, dizziness, increased blood pressure, uncomfortable dyspnea   |
| 45                      | 6.0% | 5                            | 1-2 minutes<br>≤16 minutes<br>Several hours                      | Hearing, visual disturbances<br>Headache, dyspnea<br>Tremors   |
| 53                      | 7.0% | <3                           | (7-10%)  |  |
| 68                      | 9%   | N/A                          | Few minutes<br>1.5 minutes to 2 hours<br><i>9% for 5 minutes</i> | Unconsciousness, near-unconsciousness<br>Headache, increased heart rate, shortness of breath, dizziness, sweating, rapid breathing<br><i>Lowest published lethal concentration</i> |
| 75                      | 10%  | N/A                          | (>10-15%)  |  |
| 113                     | 15%  | N/A                          | 1 minute to several minutes                                      | Dizziness, drowsiness, severe muscle twitching, unconsciousness  |
| 128                     | 17%  | N/A                          | (17-30%)<br>Within 1 minute                                      | Loss of controlled and purposeful activity, unconsciousness, convulsions, coma, death  |

# CO<sub>2</sub> Exposure Limits

NASA/TP-2010-216126 (Law et. al, 2010)

Table 2. Key CO<sub>2</sub> concentrations discussed in this paper. 1% = 7.5 mm Hg.

| % CO <sub>2</sub> | PPCO <sub>2</sub> (mm Hg) | Note <sup>[Reference]</sup>   |
|-------------------|---------------------------|---|
| 0.03%             | 0.23                      | Ambient outdoor CO <sub>2</sub> level on Earth  |
|                   | 2                         | Relief of symptoms on Expedition 6 <sup>[1]</sup>   |
| 0.3-0.7%          | 2.3-5.3                   | Typical spacecraft CO <sub>2</sub> concentrations <sup>[2]</sup>  |
| 0.5%              | 3.4                       | New NIOSH Recommended Exposure Limit <sup>[3]</sup>   |
|                   | >4                        | Lethargy, malaise, listlessness, and fatigue on Expedition 6 <sup>[1]</sup>   |
|                   | 4.9                       | Derived threshold corresponding to 90% negative predictive value for CO <sub>2</sub> -related symptoms <sup>[4]</sup>         |
|                   | 5                         | Safe chronic CO <sub>2</sub> level in terms of performance <sup>[5]</sup><br>Empiric threshold established by flight surgeons |
|                   | 2.7 to <6                 | Headaches on STS-112/ISS-9A <sup>[1]</sup>  |
|                   | Up to 7.5                 | Headache on STS-113/ISS-11A <sup>[1]</sup>  |
| 1%                | 7.5                       | NIOSH Permissible Exposure Limit <sup>[6]</sup>   |
|                   | 8                         | EMU EVA termination limit with baseline Caution and Warning System <sup>[7]</sup>   |
| 1.2%              | 9                         | Slight performance decrement after chronic exposure <sup>[5]</sup>  |
|                   | 10                        | Orlan EVA termination limit with crew at rest <sup>[8]</sup>  |
|                   | 12.4                      | EMU EVA termination limit with enhanced Caution and Warning System <sup>[7]</sup>   |
| 1.99%             | 14.9                      | Maximum CO <sub>2</sub> concentration on Apollo 13 <sup>[9]</sup>   |
| 2%                | 15                        | Headache, exertional dyspnea start <sup>[10]</sup><br>ISS Off-Nominal ppCO <sub>2</sub> Level <sup>[11]</sup>                 |
|                   | 20                        | ISS Emergency ppCO <sub>2</sub> Level <sup>[11]</sup><br>Orlan EVA termination limit <sup>[8]</sup>                           |
| 3%                | 23                        | Sweating, resting dyspnea start <sup>[10]</sup><br>NIOSH Short-Term Exposure Limit <sup>[3]</sup>                             |
| 4%                | 30                        | NIOSH Immediately Dangerous to Life or Health limit <sup>[3]</sup>  |
| 4-5%              | 30-38                     | Dizziness, lethargy, uncomfortable dyspnea start <sup>[10]</sup>  |



# Partial Pressure Considerations for CO<sub>2</sub> Exposure

CO<sub>2</sub> effects are primarily due to the partial pressure

Most instruments measure %CO<sub>2</sub>

| Pressure Condition     | Total Pressure<br>psia (mmHg) | ppCO <sub>2</sub><br>mmHg | % CO <sub>2</sub> |
|------------------------|-------------------------------|---------------------------|-------------------|
| Earth/ISS Cabin        | 14.7 (760)                    | 10                        | 1.32 %            |
| Ground Based Suit Test | 14.7 + 4.3 = 19.0 (982)       | 10                        | 1.02 %            |
| EVA Suit               | 4.3 (222)                     | 10                        | 4.50 %            |
| MMSEV/Suitport         | 8.2 (424)                     | 10                        | 2.36 %            |

# Spacesuits / Spacecrafts Tested



Rear  
Entry I-  
Suit  
(REI)



Multi Mission Space  
Exploration Vehicle  
(MMSEV)



Enhanced  
Mobility  
Advanced  
Crew  
Escape  
Suit (EM  
ACES)

Modified  
Advanced  
Crew  
Escape  
Suit  
(ACES)



Z-1 Suitport  
Compatible Suit



# CO<sub>2</sub> Washout Test Objectives

## REI, EM-ACES, Z-1

Primary Objective: Characterize the workloads and flow rates for which CO<sub>2</sub> is adequately washed away from the suited subject's oronasal area in several prototype spacesuits

- Immediate goal: Define acceptable workloads and flow rates for laboratory-based ground testing

Secondary Objective: Begin building a database of CO<sub>2</sub> washout test data that can be used to validate analysis models as well as help inform future space suit helmet and ventilation flow path design efforts

# CO<sub>2</sub> Washout Test Protocol

REI-Suit, EM-ACES, Z-1

| Target Metabolic Rate | Supply Air Flow Rate |  |                |  |                |  |
|-----------------------|----------------------|--|----------------|--|----------------|--|
|                       | 6 ACFM               |  | 5 ACFM         |  | 4 ACFM         |  |
| Rest                  | Data Point #1        | Breaks as needed to adjust flow and rest subject | Data Point #2  | Breaks as needed to adjust flow and rest subject | Data Point #3  | Breaks as needed to adjust flow and rest subject |
| 1000 BTU/hr           | Data Point #4        |  | Data Point #5  |  | Data Point #6  |  |
| 2000 BTU/hr           | Data Point #7        |  | Data Point #8  |  | Data Point #9  |  |
| 3000 BTU/hr           | Data Point #10       |  | Data Point #11 |  | Data Point #12 |  |

## Other parameters

- All testing at 4.3 psid
- 3 subjects per suit evaluation
- Each subject repeats test twice on different days
- Rest was standing in donning stand
- 1000 BTU/hr test point used arm ergometry
- 2000 and 3000 BTU/hr used arm ergometry or treadmill depending on suit capability

# Test Plan Overview

All testing was performed at 4.3 psid (standard suit operating pressure)

Three test subjects were tested in each suit

- Each subject performed the test twice to allow for day-to-day data comparison

In the REI-suit and Z-1, CO<sub>2</sub> washout performance was tested at rest, 1000, 2000, and 3000 BTU/hr for 3-minute steady-state durations

- Metabolic rate values were selected based on historical suited test data to bound the majority of ground-based suited testing that might be conducted in the future

In the EM-ACES, CO<sub>2</sub> washout performance was tested at rest, 1000 and 2000 BTU/hr

- Since it is primarily a launch/entry suit, suited subjects in the EM-ACES rarely perform activities likely to generate metabolic rates above 2000 BTU/hr

Supply airflow was varied at each workload from a high of 6 actual cubic feet per minute (ACFM), which is the standard advanced suit test air flow rate, down to a low of 4 ACFM

Oronasal CO<sub>2</sub> levels and trending in the helmet were monitored real-time via gas analyzers with sampling tubes positioned in the subject's oronasal area and a separate in-helmet location.

Metabolic rate was calculated in real-time from the total CO<sub>2</sub> production as measured by an additional gas analyzer at the air outlet from the suit.

- Real-time metabolic rate was used to monitor and adjust the arm ergometer workload or treadmill speed to meet the target metabolic rates.

# Integration of Science and Engineering

## Life Science Responsibilities

- Custom integrated metabolic and CO<sub>2</sub> washout data collection system
- Data analysis
- Quicklook test reports
- Integration with SD for test termination criteria related to CO<sub>2</sub>
- Serve as test conductor role (responsible for completing data collection)

## Engineering Responsibilities

- Spacesuits and suit support
- Experienced suited test subjects with proper fit-check
- Data collection system integration into suited ventilation loop
- Pre-test documentation – CPHS, TRR, etc.
- Serve as test director role (oversee subject and hardware safety)

# Test Hardware Description – REI Suit



Nominal operating pressure: 4.3 psid



Planetary exploration suit prototype primarily constructed of softgoods, but incorporating hatch hardware and a limited number of bearings.

Bearings are located at the scye, upper arm, hip, and upper thigh (a 2-bearing hip)

Neck ring that accommodates a 16 ×12-inch oval dome hemispherical helmet.

Designed to receive certified breathing air at 5 to 6 ACFM to both inflate the pressure garment and provide a breathable atmosphere for the suited subject.

- Breathing air is delivered at the blue connection located on the rear entry door ('Air In') and is routed through a vent plenum into the helmet.
- Return air is removed from the suit at the red 'Air Out' connection on the rear-entry door.



# Test Hardware Description – EM-ACES



Nominal operating pressure: 4.3 psid

Optimized for non-pressurized activities such as those encountered during launch, dynamic on-orbit events, landing and post landing scenarios.


Addition of specific mobility features at hips, upper arm, and shoulder provide capability for simplistic, pressurized EVA activities

Helmet is a modified Shuttle EMU bubble helmet

- Removed from original EMU neck disconnect and attached to ACES neck ring disconnect

Designed to receive certified breathing air at 5 to 6 ACFM to both inflate the pressure garment and provide a breathable atmosphere for the suited subject.

- Breathing air is delivered at the blue connection located on the right thigh ('Air In') and is routed through soft tubing to the helmet neck ring
- Return air is removed from the suit at the red 'Air Out' connection also on the right thigh





# Methods – CO<sub>2</sub> Measurement

Key parameter for indication of adequate CO<sub>2</sub> washout is direct measurement of CO<sub>2</sub> in the oronasal area

- Represents amount of CO<sub>2</sub> that the subject inspires with each breath

Test subjects wore an oronasal mask to allow for CO<sub>2</sub> sampling in the oronasal area

Tygon sampling tubes were inserted at the right and left side of the opening to measure oronasal CO<sub>2</sub>


- Each signal analyzed separately - exact time syncing between the left and right side was not critical

One additional CO<sub>2</sub> sampling tube was placed in the top, center of the helmet to allow for observation of the CO<sub>2</sub> level at an alternate in-helmet location

The sampling tubes were routed through a pass-through port in the suit hatch, through a rotameter that controlled flow rate to 1.0 l/min per sample line and then out to CO<sub>2</sub> analyzers for real-time CO<sub>2</sub> measurement

Suit delta pressure forced airflow through the sampling tubes

Rotameters on the gas analyzers allowed the flow rate to be adjusted to the range required by the analyzers




# Methods – CO<sub>2</sub> Measurement

Inspired CO<sub>2</sub> levels determined by looking at the low points of the respiratory cycle

- Without direct flow measurement at the mouth, a time weighted average across the inspiration cycle could not be calculated
- While a time weighted average would be preferred, the majority of the inspiration by volume occurs near the bottom of the cycle
- Some error associated with this method, but it allows for accurate relative comparisons between suits, metabolic rates and flow rates

Left and right side measurements were given equal weight and the average was used to determine CO<sub>2</sub> washout



# Methods – Metabolic Rate Measurement

Necessary to have a way to calculate the actual energy expenditure (metabolic rate) of each individual subject to control the test for specific workloads

Method used has been adapted for use in space suits from the Exercise Physiology industry standard

- Metabolic rate determined through standard equations using  $\text{CO}_2$  production, the flow rate of breathing air, and the respiratory exchange ratio (RER) – assumed constant of 0.85

System used consisted of a Kurz flow meter on the suit air inlet line and an AEI Technologies CD-3A infrared  $\text{CO}_2$  analyzer on the suit air outlet line

- The  $\text{CO}_2$  level measured by this system has been shown to track closely to the subject's workload and can be an effective method of controlling to a desired workload.

During testing, personnel would monitor the metabolic rate at each workload until it appeared to have stabilized, and then begin a 3-minute data collection trial

In some cases, workload had to be adjusted during the data collection period to keep the metabolic rate at the desired level

A LabVIEW program was used to calculate and display metabolic rate as well as in-suit  $\text{CO}_2$  levels on a single display screen.

Data was displayed real-time during test and recorded for post-test analysis

# Data Analysis - Overview

Not all test points were completed for the REI-suit test

- Due to an installation error of the flow meter on the first test day, data was collected at rest, 750, 1400, and 2000 BTU/hr instead of at rest, 1000, 2000, and 3000 BTU/hr.
  - Missing points at 3000 BTU/hr were not made up
  - To allow for day-to-day data comparison, we were able to average the results of the 750 and 1400 BTU/hr trials to compare against this subject's 1000 BTU/hr trial on day 2.
- Subject 2 completed all test points except for the 3000 BTU/hr trial at 4 ACFM due to an issue with the suit.
- Subject 3 completed the rest, 1000, and 2000 BTU/hr trials, but did not complete the 3000 BTU/hr test points because the subject's heart rate could not be maintained below the test termination value.

For the EM-ACES, not all test points were completed either

- Subject 1 completed all test points on both days
- Subject 2 completed all test points on day 2 but only the test points at 5 and 4 ACFM on day 1, because the facility air supply could not supply the target flow rate of 6 ACFM
- Subject 3 completed all test points only once

# Data Analysis – Overview

CO<sub>2</sub> washout testing in the REI-Suit and EM-ACES was an engineering pilot test

Statistical power was not a consideration in the number of test subjects


Comparisons within the same subject and between different subjects were made through visual inspections of the graphical data and through numerical comparisons.

- In most cases, test day comparisons across the same subjects were very similar
- In some cases, test days across the same subject showed significant variation
  - Often related to peak expired ppCO<sub>2</sub> values

# Data Analysis – REI-Suit

Example comparison of subject at 2000 BTU/hr / 5 ACFM test points during the REI-Suit Test


- Example of how similar day-to-day data was in some cases



# Data Analysis – REI-Suit

Comparison of subject at 2000 BTU/hr / 5 ACFM test points during the REI-Suit Test

- Example of how different day-to-day data was in some cases



# Data Analysis – REI Suit


Day-to-day differences for subject in REI-Suit for all metabolic and flow rates

| Target         |        | Differences - All data are Day 2 - Day 1 |             |   |  |                                 |
|----------------|--------|--|-------------|---|--|---------------------------------|
| Metabolic Rate | Flow   | Metabolic Rate (BTU/hr)                  | Flow (SCFM) | Average Oronasal ppCO <sub>2</sub> (mmHg) | Oronasal Inspired ppCO <sub>2</sub> (mmHg) | Helmet ppCO <sub>2</sub> (mmHg) |
| Rest           | 6 ACFM | 186                                      | -0.20       | 0.28                                      | 1.46                                       | -0.28                           |
|                | 5 ACFM | 293                                      | -0.44       | 2.06                                      | 1.94                                       | 0.63                            |
|                | 4 ACFM | 197                                      | -0.35       | 0.58                                      | 0.55                                       | 0.62                            |
| 1000 BTU/hr    | 6 ACFM | 321                                      | -0.18       | 0.32                                      | 0.70                                       | 0.79                            |
|                | 5 ACFM | 1  | -0.45       | -0.85                                     | -0.64                                      | -0.18                           |
|                | 4 ACFM | 25                                       | -0.32       | -1.02                                     | 0.59                                       | -0.17                           |
| 2000 BTU/hr    | 6 ACFM | 83                                       | -0.14       | -0.95                                     | -0.26                                      | -0.38                           |
|                | 5 ACFM | -50                                      | -0.37       | -0.07                                     | 0.56                                       | -0.55                           |
|                | 4 ACFM | -22                                      | -0.48       | -0.35                                     | 0.52                                       | -0.51                           |
| 3000 BTU/hr    | 6 ACFM | 60                                       | 0.02        | -1.19                                     | -0.24                                      | -0.08                           |
|                | 5 ACFM | 29                                       | -0.10       | -0.51                                     | 0.49                                       | -0.12                           |
|                | 4 ACFM | N/A                                      | N/A         | N/A                                       | N/A  | N/A                             |




# Data Analysis – REI Suit

ppCO<sub>2</sub> variables as a function of metabolic rate in the REI-suit




# Data Analysis – REI Suit

Inspired oronasal ppCO<sub>2</sub> as a function of metabolic rate for different REI suit flow rates



# Data Analysis – REI-Suit


Statistical regression model showing the estimated inspired oronasal  $\text{ppCO}_2$  (mmHg) at different metabolic rates (BTU/hr) and flow rates (SCFM)



# Data Analysis – EM-ACES

Example comparison of subject at 1000 BTU/hr / 4 ACFM test points during the EM-ACES Test


- Shows some left/right variation between test days



# Data Analysis – EM-ACES

Example comparison of subject at 1000 BTU/hr / 6 ACFM test points during the EM-ACES Test

- Shows a slight upward shift from day 1 to day 2



# Data Analysis – EM-ACES


Day-to-day differences for one subject in the EM-ACES test for all metabolic and flow rates

Only 2 subjects completed testing both days

| Target         |        | Differences - All data are Day 2 - Day 1 |             |                                    |   |                                  |
|----------------|--------|--|-------------|------------------------------------|---|----------------------------------|
| Metabolic Rate | Flow   | Metabolic Rate (BTU/hr)                  | Flow (SCFM) | Oronasal ppCO <sub>2</sub> (mm Hg) | Oronasal Inspired ppCO <sub>2</sub> (mm Hg) | Helmet ppCO <sub>2</sub> (mm Hg) |
| Rest           | 6 ACFM | -40                                      | -0.13       | 1.12                               | 1.15  | -2.61                            |
|                | 5 ACFM | 134                                      | -0.29       | 2.18                               | 1.70  | -0.21                            |
|                | 4 ACFM | 26                                       | -0.43       | 0.58                               | 1.62  | -0.08                            |
| 1000 BTU/hr    | 6 ACFM | 16                                       | -0.13       | 2.94                               | 2.51  | 1.10                             |
|                | 5 ACFM | 67                                       | -0.32       | 4.14                               | 3.50  | 4.23                             |
|                | 4 ACFM | 97                                       | -0.33       | 2.94                               | 2.86  | 4.73                             |
| 2000 BTU/hr    | 6 ACFM | 116                                      | -0.15       | 1.35                               | 2.44  | 2.62                             |
|                | 5 ACFM | 157                                      | -0.18       | 2.54                               | 4.40  | 1.53                             |
|                | 4 ACFM | 266                                      | 0.25        | -0.18                              | 1.82  | 1.49                             |


# Data Analysis – EM-ACES

ppCO<sub>2</sub> variables as a function of metabolic rate in the EM-ACES



# Data Analysis – EM-ACES


Inspired oronasal ppCO<sub>2</sub> as a function of metabolic rate for different EM-ACES suit flow rates





# Data Analysis – EM-ACES

Statistical regression model showing the estimated inspired oronasal  $\text{ppCO}_2$  (mmHg) at different metabolic rates (BTU/hr) and flow rates (SCFM)



# Data Analysis – Comparison Between Suits

CO<sub>2</sub> washout performance was similar with slight differences between the 2 suits

- Actual metabolic rate and suit flow were very similar between suits.
- Average oronasal ppCO<sub>2</sub> and inspired ppCO<sub>2</sub> were higher in the EM-ACES at rest, but higher in the REI during exercise.
- The biggest difference between suits was the helmet ppCO<sub>2</sub> as measured by the CO<sub>2</sub> sampling line at the top of the head.
  - Helmets were different shapes/sizes
  - Air flow pathways were notably different
  - Results will be further analyzed by modeling and/or future testing with more fixed points in the helmet.

# Data Comparison – REI Suit and EM-ACES

| Target                  |                  | EM-ACES                 |             |  |   |                                 |                                  | REI                     |             |  |   |                                 |                                  |
|-------------------------|------------------|-------------------------|-------------|--|---|---------------------------------|----------------------------------|-------------------------|-------------|--|---|---------------------------------|----------------------------------|
| Metabolic Rate (BTU/hr) | Suit Flow (ACFM) | Metabolic Rate (BTU/hr) | Flow (SCFM) | Average Oronasal ppCO <sub>2</sub> (mm Hg) | Oronasal Inspired ppCO <sub>2</sub> (mm Hg) | Helmet ppCO <sub>2</sub> (mmHg) | Number of test points in average | Metabolic Rate (BTU/hr) | Flow (SCFM) | Average Oronasal ppCO <sub>2</sub> (mm Hg) | Oronasal Inspired ppCO <sub>2</sub> (mm Hg) | Helmet ppCO <sub>2</sub> (mmHg) | Number of test points in average |
| Rest                    | 6                | 547                     | 7.64        | 13.45                                      | 4.19  | 5.51                            | 4                                | 543                     | 7.72        | 13.00                                      | 3.94  | 2.04                            | 6                                |
| Rest                    | 5                | 483                     | 6.73        | 14.30                                      | 4.05  | 5.54                            | 5                                | 522                     | 6.81        | 13.05                                      | 4.08  | 2.00                            | 6                                |
| Rest                    | 4                | 482                     | 5.41        | 14.16                                      | 4.41  | 7.27                            | 5                                | 486                     | 5.55        | 13.27                                      | 4.23  | 2.23                            | 6                                |
| 1000                    | 6                | 1067                    | 7.67        | 15.59                                      | 6.54  | 11.42                           | 4                                | 1080                    | 7.70        | 18.50                                      | 8.33  | 4.10                            | 7                                |
| 1000                    | 5                | 1082                    | 6.71        | 16.50                                      | 7.37  | 12.77                           | 5                                | 1066                    | 6.80        | 18.37                                      | 8.34  | 4.50                            | 7                                |
| 1000                    | 4                | 1101                    | 5.46        | 17.59                                      | 8.32  | 14.49                           | 5                                | 1045                    | 5.56        | 18.92                                      | 8.74  | 5.45                            | 7                                |
| 2000                    | 6                | 2003                    | 7.67        | 18.43                                      | 10.18                                       | 17.95                           | 4                                | 2022                    | 7.70        | 22.11                                      | 13.13                                       | 7.96                            | 6                                |
| 2000                    | 5                | 2076                    | 6.74        | 19.26                                      | 11.05                                       | 18.93                           | 5                                | 1957                    | 6.82        | 22.03                                      | 13.54                                       | 8.62                            | 6                                |
| 2000                    | 4                | 2027                    | 5.50        | 20.23                                      | 12.82                                       | 21.82                           | 5                                | 1949                    | 5.56        | 23.35                                      | 15.30                                       | 10.83                           | 6                                |

# Conclusions for REI Suit and EM-ACES

- At all flow rates, metabolic rates  $\leq 1000$  BTU/hr could be tolerated indefinitely from a CO<sub>2</sub> perspective.
- At 1500 BTU/hr, it would likely take about 3 hours at the lowest suit flow rate before any acute CO<sub>2</sub> related problems might be expected.
- At metabolic rates  $\geq 2000$  BTU/hr, the flow rate has a significant effect on exposure limits.
- At metabolic rates of 2500 to 3000 BTU/hr, there is less than 1 hour before acute CO<sub>2</sub> symptoms could be expected.
- Subjects experienced exertional fatigue and increased heat storage when working at high metabolic rates.
  - Time at 2500 BTU/hr or above should therefore be minimized for several physiologic reasons.
- Acute CO<sub>2</sub> related problems are easily resolved by reduction in the inspired ppCO<sub>2</sub>.
  - In the case of ground-based testing, this can be accomplished by reducing workload and thus the expected metabolic rate and/or by increasing the suit air flow.
  - Therefore, the suited subject can quickly be returned to a low level of ambient ppCO<sub>2</sub> and is in a much safer situation than someone during flight.

# Conclusions for REI Suit and EM-ACES

Normal operations in the REI-suit are expected to be at ~ 1500 BTU/hr with spikes above 2000 BTU/hr.

Normal operations in the EM-ACES are expected to be  $\leq 1500$  BTU/hr.

Additionally, the suit test team monitors all subjects for symptoms of high CO<sub>2</sub> throughout testing, and will terminate testing if any issues arise.

Given the following,

- (1) nominal operations are in a zone where CO<sub>2</sub> symptoms are unlikely to occur
- (2) the suit test team monitors for CO<sub>2</sub> related symptoms
- (3) ppCO<sub>2</sub> can quickly be reduced by decreasing workload and increasing flow

The REI-suit and EM-ACES CO<sub>2</sub> washout is acceptable at flow rates equal to or greater than 4 ACFM.

# Recommended Forward Work

Further testing should evaluate how differences in the suit ventilation loop affect CO<sub>2</sub> washout performance

- For instance, if the REI suit was modified to have the air outlet pickup downstream in the torso or leg, it is highly likely that CO<sub>2</sub> washout performance would improve

Additionally, testing with several sensors in fixed locations in the helmet will provide key information for the suit ventilation modeling team

- This data could be used in conjunction with the oronasal CO<sub>2</sub> washout data to predict performance of future suit and helmet designs

# Z-1 CO<sub>2</sub> Washout

*Initial Results Quicklook*

# Initial Thoughts – Z-1 Test Results

Z-1 testing showed the greatest variability from test day to test day and between left and right analyzers

The oronasal analyzer from the right seems to be a bit consistent than the analyzer on the left


- Differences in tubes, fittings, analyzers, flow patterns, mask fit, rotameters
- Best solution is to average the data coming from both as this is what we have done with past test or possibly to consider using the data from the right side only and comparing
  - Numerical differences were not very large with this comparison
- Could be alleviated with some data collection changes
  - Use suit flow to drive air into CO<sub>2</sub> analyzer
    - Need to determine if increased pressure truly affected CO<sub>2</sub> analyzer integrity
  - Use vacuum pump to drive air into CO<sub>2</sub> analyzer
    - Need larger rotameters - needs 1.5-2.0 l/min flow out instead of 1 l/min
    - We need to sample deeper into the outlet using more consistent placement

Differences between tests and between subjects are still fairly small numerically, although this is quite a bit of variation graphically




# Subject Induced Variability

Rest – 6 ACFM



— MET Rate (BTU/hr) — Right (mm Hg)  
— Left (mm Hg) — Helmet CO<sub>2</sub> (mm Hg)




— MET Rate (BTU/hr) — Right (mm Hg)  
— Left (mm Hg) — Helmet CO<sub>2</sub> (mm Hg)


# Large Day to Day Variance Example

1000 BTU/hr – 6 ACFM

- likely a methods issue



— MET Rate (BTU/hr) — Right (mm Hg)  
— Left (mm Hg) — Helmet CO<sub>2</sub> (mm Hg)




— MET Rate (BTU/hr) — Right (mm Hg)  
— Left (mm Hg) — Helmet CO<sub>2</sub> (mm Hg)


# Left to Right Variance Example

Rest – 5 ACFM

- likely a methods issue (not seen in all tests)



— MET Rate (BTU/hr) — Right (mm Hg)  
— Left (mm Hg) — Helmet CO<sub>2</sub> (mm Hg)




— MET Rate (BTU/hr) — Right (mm Hg)  
— Left (mm Hg) — Helmet CO<sub>2</sub> (mm Hg)

# Average Test Variability


3000 BTU/hr – 6 ACFM

Day 1



— MET Rate (BTU/hr) — Right (mm Hg)  
— Left (mm Hg) — Helmet CO<sub>2</sub> (mm Hg)

Day 2




— MET Rate (BTU/hr) — Right (mm Hg)  
— Left (mm Hg) — Helmet CO<sub>2</sub> (mm Hg)

# Z-1 Met rate vs. ppCO<sub>2</sub>


Metabolic rate is the primary driver for CO<sub>2</sub> production

Clearer differences are seen when flow rate is considered




# Z-1 Flow effects on oronasal ppCO<sub>2</sub>

Flow has a notable effect on oronasal CO<sub>2</sub> washout at all flow rates at met rates > 1000 BTU/hr



# Z-1 CO<sub>2</sub> Washout Implications



# EVA Suit CO<sub>2</sub> Washout Comparisons


*REI Suit*

*EM-ACES*


*Z-1*




# 6 ACFM – Suit Comparison




# 6 ACFM – Suit Comparison




# 5 ACFM – Suit Comparison




# 5 ACFM – Suit Comparison



# 4 ACFM – Suit Comparison



# 4 ACFM – Suit Comparison



# ACES CO<sub>2</sub> Washout

*Initial Results Quicklook*

# ACES Test Objectives

Primary Objective: Characterize the workloads, flow rates and suit pressures for which CO<sub>2</sub> is adequately washed away from the suited subject's oronasal area in several prototype spacesuits

- Immediate goal: Define acceptable workloads and flow rates for laboratory-based ground testing using vent and 4.3 psid test pressures

Secondary Objective: Begin building a database of CO<sub>2</sub> washout test data that can be used to validate analysis models as well as help inform future space suit helmet and ventilation flow path design efforts



# ACES CO<sub>2</sub> Washout Test Protocol

## Test Variables

- Metabolic Rate: Rest, 1500 BTU/hr, 2500 BTU/hr
- Suit Flow: 6, 4, 2 SCFM
- Suit Pressure: 4.3 psid, vent pressure
- Head Position: looking left, straight and right (only at rest)

## Test Order


- Resting Conditions
  - Head Position at 4.3 psid and vent pressure
- Exercise at 4.3 psid
  - 1500 BTU/hr at 6, 4, 2 SCFM
  - 2500 BTU/hr at 6, 4 SCFM
- Exercise at vent pressure
  - 1500 BTU/hr at 6, 4, 2 SCFM
  - 2500 BTU/hr at 6, 4 SCFM

## Other Parameters


- 4 subjects total
- Some subjects repeated some test parameters
- Rest was in the mockup vehicle chair (lying on back with hips and knees ~ 90°)
- 1500 and 2500 BTU/hr test point used arm ergometry

# Head Position at Rest - ACES

*Vent Pressure – no differences*





*4.3 psi – no differences*



# Pressure Effects – Rest w/ ACES


*Center – no differences*

*Left – no differences*




# Pressure Effects – Rest w/ACES

*Right - No differences*




All Resting Data

*No differences. All data is widely overlapping.*



# CO<sub>2</sub> Washout – Flow Effects w/ACES


*Vent*



◆ Vent - 2 SCFM    ■ Vent - 4 SCFM    ▲ Vent - 6 SCFM

Results clearly show that at metabolic rates > rest, flow impacts CO<sub>2</sub> washout performance


*4.3 psi*



× 4.3 psi - 2 SCFM    \* 4.3 psi - 4 SCFM    ● 4.3 psi - 6 SCFM

Results show an improvement with CO<sub>2</sub> washout with increased flow, but results are widely different at the 1000-2000 BTU/hr range, which limits predictive reliability

# CO<sub>2</sub> Washout – Pressure Effects w/ACES





Results clearly indicate the likelihood that pressure affects CO<sub>2</sub> washout

- Maybe back pressure limits flow out of the helmet?
- Suit fits differently when pressurized, which may affect head position

Wide variability at 1500 BTU/hr data point


- Head position in suit?
- DAQ issues?

# CO<sub>2</sub> Washout – Pressure Effects w/ACES



The pressure difference seems to be independent of flow rate with CO<sub>2</sub> washout much better at vent pressure than at 4.3 psi

# CO<sub>2</sub> Exposure Limits






# MMSEV CO<sub>2</sub> Washout

*Purpose – inform requirements for MMSEV habitability testing and to provide initial feedback on changes to the cabin ventilation system*

# MMSEV CO<sub>2</sub> Washout



- All data was for 2 subjects in MMSEV with hatches and suitports closed
- MMSEV CO<sub>2</sub> washout was markedly improved after adjustments to the ventilation system

# Lessons Learned

*Oronasal Mask*

*Sampling Rate for Oronasal CO<sub>2</sub>*

*Integrated DAQ System*

# Initial CO<sub>2</sub> Sensor Placement



In-Helmet CO<sub>2</sub> Sampling Locations



Oronasal CO<sub>2</sub> Sampling Location

# Example Difference

## 1000 BTU/hr – 4 ACFM





◆ Metabolic Rate — Oronasal % CO<sub>2</sub>  
— Top % CO<sub>2</sub> — Right % CO<sub>2</sub>

◆ Metabolic Rate — Oronasal % CO<sub>2</sub>  
— Top % CO<sub>2</sub> — Right % CO<sub>2</sub>

- Differences were due to CO<sub>2</sub> data output rate change and possibly placement of the oronasal sampling port.

# Oronasal Placement Differences



## 2000 BTU/hr – 6 ACFM



- CO<sub>2</sub> data output rate was the same (5-6 Hz) between tests


# Oronasal Placement Differences

## 2000 BTU/hr – 5 ACFM



- Not all differences were huge
- Post hoc, this looks similar to some differences we see with the oronasal mask

# Oronasal CO<sub>2</sub> Measurement Options



- (1) Mouthpiece and nose clip
- (2) Mouthpiece and nasal cannula
- (3) Nasal cannula only (mouth kept closed)
- (4) Oronasal mask (valves in place) – 1 air entry/exit point available
- (5) Oronasal mask (valves removed) – 3 air entry/exit points available



# Oronasal CO<sub>2</sub> Measurement Options

## Results (n=1)

| Test Set-up                                   | Trough % CO <sub>2</sub> | Average % CO <sub>2</sub> | Peak % CO <sub>2</sub> | Notes   |
|---|--------------------------|---------------------------|------------------------|---|
| (1)<br>Mouthpiece and nose clip               | 0.08                     | 2.06                      | ~5                     | Reference Condition   |
| (2)<br>Mouthpiece and nasal cannula           | 0.19                     | 2.22                      | ~4.5-5                 | Assumed 50/50 mix between mouth and nose and averaged the 2 equally |
| (3)<br>Nasal cannula only (mouth kept closed) | 0.24                     | 2.34                      | ~4.5-5.5               |   |
| (4)<br>Oronasal Mask (valves in place)        | 0.08                     | 2.12                      | ~4-5.5                 | Assumed 50/50 mix for left and right side and averaged              |
| (5)<br>Oronasal Mask (valves removed)         | 0.22                     | 1.46                      | ~2-5                   | Assumed 50/50 mix for left and right side and averaged              |

# CO<sub>2</sub> Washout Initial DAQ System

- Metabolic rate data acquisition system was separate from the oronasal/helmet CO<sub>2</sub> data collection system
- CO<sub>2</sub> analyzers initially only output a signal at 1-2 Hz and eventually this was improved to 5-6 Hz
- Oronasal CO<sub>2</sub> analyzer range of 0-5% CO<sub>2</sub>
- Non oronasal CO<sub>2</sub> analyzers had range of 0-2.5% CO<sub>2</sub>

## Upgraded DAQ

- Metabolic rate and oronasal/helmet CO<sub>2</sub> data collection system integrated into one visual display and one data output file
- All CO<sub>2</sub> analyzers had range of 0-15% and all were same make/models
- All CO<sub>2</sub> analyzers had data output frequencies of 25 Hz

# Thank You

## Advanced Suit Lab

Kate Mitchell

Adam Korona

Amy Ross

Lindsay Aitchison

Richard Rhodes

Kevin Groneman

Nathan Smith

Pete Meeh

John Harris

## Crew Escape Lab

Dick Watson

Dustin Gohmert

Kris Cyrus

Mike Dang

Joe Lopez

Bill Owens

## EVA Physiology Lab

Jill Klein

Jim Wessel

Igor Kofman