



Mckeeman, Iain James and Niewczas, Pawel and Khan, Saadat (2017) A comparison of brazed metal and epoxied fibre Bragg grating strain sensors under high strain regimes. In: 25th International Conference on Optical Fiber Sensors. Proceedings of SPIE - The International Society for Optical Engineering, Bellingham, WA. ISBN 9781510610910 , <http://dx.doi.org/10.1117/12.2264997>

This version is available at <https://strathprints.strath.ac.uk/61087/>

Strathprints is designed to allow users to access the research output of the University of Strathclyde. Unless otherwise explicitly stated on the manuscript, Copyright © and Moral Rights for the papers on this site are retained by the individual authors and/or other copyright owners. Please check the manuscript for details of any other licences that may have been applied. You may not engage in further distribution of the material for any profitmaking activities or any commercial gain. You may freely distribute both the url (<https://strathprints.strath.ac.uk/>) and the content of this paper for research or private study, educational, or not-for-profit purposes without prior permission or charge.

Any correspondence concerning this service should be sent to the Strathprints administrator: strathprints@strath.ac.uk

A comparison of brazed metal and epoxied fibre Bragg grating strain sensors under high strain regimes

I. Mckeeman^{*a}, P. Niewczas^a, S. Khan^b

^aDepartment of Electronic and Electrical Engineering, University of Strathclyde, Glasgow UK

^bCivil Design Group, EDF Energy, Nuclear Generation, East Kilbride, United Kingdom

*iain.mckeeman@strath.ac.uk

ABSTRACT

Three different fibre Bragg grating strain sensors were tested for their suitability for measuring high strain. The sensor types were: a bare epoxied fibre Bragg grating, a standard fibre Bragg grating epoxied into a metal capillary and, finally, a metal coated fibre Bragg grating brazed into a metal capillary. The sensors were calibrated on a steel specimen up to 1400MPa (equivalent to 7.3mε). The results show that the bare epoxied Bragg grating and the metal packaged grating are suitable for measuring strains of this level.

Keywords: prestress monitoring, fibre Bragg gratings, structural health monitoring.

1. INTRODUCTION

Structural health monitoring is increasingly employed on large structures that are either safety critical or valuable assets such as nuclear containment buildings and long-span bridges [1]. There are numerous advantages of recording the real time response of the strain, temperature and acceleration of these structures. Optical sensors are capable of measuring such quantities with well-known advantages like multiplexibility and immunity to EM interference [2]. Fibre Bragg gratings (FBGs) are one of the most common methods for optically measuring strain and temperature. FBGs are written directly into optical fibre and consequently must be packaged in a proper manner if they are to survive deployment in a practical scenario. Different applications require appropriate packaging methods, for example when monitoring high strain in nuclear applications it might be beneficial for the FBG to be packaged without using epoxy [3].

This paper compares three different strain sensors for their suitability in practical high strain structural health monitoring applications. Two of the sensors consisted of an FBG sealed inside a metal capillary. One had an all metal construction; a metal coated fibre was brazed into the metal capillary with high-temperature metal solder, while the other was a standard optical fibre epoxied into the capillary. We show that the packaged FBGs can survive stresses of up to 1400MPa (equivalent to 7.3mε). While the sensitivity of the packaged FBGs was lower than a bare epoxied FBG (the third sensor), they are more suitable for practical applications due to the ease of attaching them to the structure. Furthermore the metal brazed sensor wavelength response was more repeatable than that of the epoxy-capillary sensor.

2. THEORY

The peak wavelength of an FBG reflection spectrum can be measured to infer temperature or strain. In the case of an FBG that is attached to a steel specimen, the change in wavelength ($\Delta\lambda$) of the FBG when subjected to mechanical strain (ε_m) without temperature variations, as was the case in this experiment, is given by the equation [4]:

$$\frac{\Delta\lambda}{\lambda_0} = K_\varepsilon(1 - \rho_e)\varepsilon_m$$

Where K_ε and ρ_e are the strain transfer between the specimen and the FBG and the photo-elastic coefficient respectively.

3. SENSOR FABRICATION

Epoxied FBG

A standard FBG written in SMF-28 fibre, with no recoating, was bonded directly to the specimen (Figure 1b) with EPO-TEK 301 epoxy and cured at 65°C for two hours. The epoxy was applied along the length of the FBG. This method of

attachment removes the influence of sensor packaging on the strain sensitivity of the FBG, leaving only the strain transfer between the epoxy and the specimen. However this could lead to inconsistencies between multiple sensors due the epoxy curing and the amount applied. The epoxied FBG must also be protected as the interrogating fibre will be exposed. The epoxied FBG enabled the effect of the sensor package on the strain transfer to the FBG to be investigated.

FBG epoxied into sensor package

A second type of FBG strain sensor was attached to the steel specimen (Figure 1a). A standard fibre FBG was epoxied (with EPO-TEK 301 epoxy) into a kovar capillary. Epoxy was applied to the length of the FBG and at both ends of the capillary; the FBG was then inserted into the capillary and pulled back and forth in the capillary to ensure the epoxy coated the FBG evenly. Steel shim was brazed onto the capillary prior to the FBG being epoxied into it. The sensor was then spot welded onto the steel specimen. This type of sensor provided a direct comparison for the metal packaged sensors that have been developed previously [3]. The shims were slightly closer together on the capillary compared to the metal sensor so that brazing paste did not cover the capillary holes where the fibre was inserted.

FBG brazed into sensor package

The third sensor attached to the steel specimen had an identical sensor package but the fibre inserted into the capillary was metal coated and the fibre was brazed into the capillary (Figure 1a)[3]. This sensor was also spot welded to the specimen.




Figure 1. The attached packaged FBG strain sensors can be seen in 1a. Although they look similar, the sensor on the left of the photo had the FBG brazed into the capillary with metal brazing paste while the one on the right had the FBG epoxied into the capillary. The final sensor (1c) was a bare FBG epoxied onto the steel specimen. Photo 1c shows the steel specimen, with sensors attached, mounted on the tensile machine.

4. SENSOR TEST METHOD

The sensors were attached to a high strength (CS95 grade) steel dumbbell specimen. The steel had a Rockwell hardness of 50-52, equivalent to a tensile strength of 1663-1725MPa. The dimensions were chosen so that the steel could be stressed upwards of 1400MPa on a 10kN tensile machine; this resulted in the steel having a width and thickness of 7 mm and 1mm respectively. The required stress was achieved by tensioning the specimen to a force of 9.8kN.

The steel specimen was mounted on a 10kN tensile machine (Figure 1c). A test profile was programmed for the machine to increase force in multiples of 1kN (up to 10kN), hold the force for 20 seconds and then return to 0N in 1kN steps, see Figure 2a. This was repeated for three cycles. The FBG sensors were interrogated continuously during the test on separate channels of a National Instruments PXI-4844 interrogator. Force measured by an external load cell was also recorded. Additionally, temperature was recorded by a thermocouple to compensate the strain sensors. The temperature during the experiment changed by 0.02°C, the strain sensors had an average temperature sensitivity of 15pm/°C. The National Instruments interrogator has an accuracy of 1 pm therefore the result of this temperature change was negligible, especially considering the wavelength changes due to stressing the sensors.

In order to calibrate the strain sensors, the load cell force was converted to strain using the Young's modulus of the specimen (193MPa). Figure 2b shows the stress-strain relationship of the specimen, showing that the stress to strain conversion was relatively linear across the force range; therefore this is an appropriate approximation. Figure 2b also shows that the extension measured by the machine was possibly unreliable because a larger than expected strain was recorded. This was because its reading includes extension of the machine grips. The load cell measurement has a better

accuracy and this is why it was used for the calibration. Future work would benefit from using an external extensometer. The converted strain was compared with the wavelength measurements from the three sensors. The wavelength and strain readings used for the calibration were taken midway through the 20 second period when the tensile machine was holding a given force. A line of best fit using the least squares method was applied and from this the strain transfer (K_ϵ) of the individual sensors could be calculated. This assumed a perfect strain transfer would change the wavelength of the FBG by 0.78ϵ (see Theory section).




Figure 2. The test profile for the experiment, 2a. Stress against strain measured by the machine, 2b. Note that the extension measurement (converted to strain) is possibly unreliable; future work will benefit from an external extensometer.


5. RESULTS AND DISCUSSION

Figure 3 shows the results of the calibration procedure for the three sensors. The epoxied FBG wavelength response can be seen in 3a. The response was linear up to 1400MPa which is equivalent to $7.3m\epsilon$. The least squares fit for the three cycles shows that the sensor reading was very repeatable. The sensitivity is high, with a strain transfer of about 95%. This is beneficial for accurately measuring small changes in strain however there is a trade-off between sensitivity and the number of sensors that can be multiplexed. Additionally, from a practical perspective curing epoxy in an industrial environment, often in wet ambient conditions will likely impact the consistency of the attachment. Furthermore, without protection the epoxied sensor is vulnerable to damage as the fibre is exposed.

The FBG epoxied into a metal capillary did not perform consistently over the three cycles. For each cycle, the zero strain wavelength and the slope of the least squares fit changed, showing that the epoxy was not able to secure the optical fibre into the capillary to survive the applied stress. The strain transfer was about 1%, therefore with a 1pm accuracy interrogator the minimum strain change that could be detected would be approximately $70\mu\epsilon$. Although this particular sensor cannot be reliably calibrated, additional sensors of this type need to be tested to ensure that this sensor was not faulty and that other sensors perform adequately.

Finally the calibration of the FBG brazed into a metal capillary can be seen in Figure 3c. The wavelength response of the sensor shows that it was repeatable over the 1400MPa range. There was some hysteresis that was repeatable and this could be included in the calibration. The wavelength change across the force range was about 1nm leading to a strain transfer of 10%. Although this was lower than the epoxied FBG, this also means more sensors can be multiplexed within a given bandwidth. Additionally the sensitivity is adequate for a strain resolution of less than $10\mu\epsilon$, which is acceptable for most applications. This sensor can be attached to a structure relatively quickly by spot welding.

From these results it is clear that in terms of strain sensitivity and repeatability the epoxied FBG performed the best, although the metal package sensor also had a repeatable wavelength response. However if the sensors are to be deployed in a practical scenario there are several considerations for deciding the most suitable sensor as mentioned above. Where high precision strain measurements are required, based on these results it would be advisable to epoxy a bare FBG directly onto the specimen, assuming this can be done. Whereas if a fast installation and additional fibre protection is needed the metal packaged sensor would be more suitable.



Sensor type	Slope (nm/ε)	Intercept (nm)
Epoxied FBG	1166±2	1559.9±.01
Epoxy sensor package	14.1±0.6	1572.5±.02
Metal sensor package	133±2	1542±.01

Table 1. Parameters of the straight-line least square fit.

Figure 3. Calibration of the epoxied FBG (3a), the epoxy sensor (3b) and the metal sensor (3c)

6. CONCLUSION

This paper compares three different types of FBG strain sensor. The sensors were calibrated up to 1400MPa, equivalent to 7.3mε. Despite the high stress and strain, the epoxied FBG and metal packaged sensor wavelength responses were repeatable and these sensors have been shown to be suitable for measuring these high strains. We have also discussed some of the practical considerations for choosing the most suitable type of sensor. Further investigation is needed to determine if the FBG epoxied into the metal capillary was defective or if this technique is not suitable for fabricating strain sensors to monitor high strain.

ACKNOWLEDGEMENTS

This work was supported by the Engineering and Physical Sciences Research Council (EPSRC) and EDF Energy Nuclear Generation, Ltd.

REFERENCES

- [1] J. M. Lopez-Higuera, L. Rodriguez Cobo, A. Quintela Incera, and A. Cobo, "Fiber Optic Sensors in Structural Health Monitoring," *J. Light. Technol.*, vol. 29, no. 4, pp. 587–608, Feb. 2011.
- [2] L. S. Grattan and B. T. Meggitt, *Optical Fiber Sensor Technology: Fundamentals*. Springer Science & Business Media, 2013.
- [3] I. Mckeeman et al., "First-time demonstration of measuring concrete prestress levels with metal packaged fibre optic sensors," *Smart Mater. Struct.*, vol. 25, no. 9, p. 95051, Sep. 2016.
- [4] M. Kreuzer, "Strain measurement with fiber Bragg grating sensors," HBM, Darmstadt, Germany.