


NASA CONTRACTOR
REPORT



NASA CR-237

NASA CR-237

FACILITY FORM 602

N65-24773

(ACCESSION NUMBER)
65
(PAGES)

(THRU)
1
(CODE)
23
(CATEGORY)

(NASA CR OR TMX OR AD NUMBER)

GPO PRICE \$ _____

OTS PRICE(S) \$ 3.00

Hard copy (HC) _____

Microfiche (MF) .75

ABSORPTION OF SOUND
IN AIR BELOW 1000 CPS

by Cyril M. Harris and W. Tempest

Prepared under Contract No. NAS 8-11002 by

COLUMBIA UNIVERSITY

New York, N. Y.

for

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION • WASHINGTON, D. C. • JUNE 1965

ABSORPTION OF SOUND IN AIR BELOW 1000 CPS

By Cyril M. Harris and W. Tempest

Distribution of this report is provided in the interest of information exchange. Responsibility for the contents resides in the author or organization that prepared it.

Prepared under Contract No. NAS 8-11002 by
COLUMBIA UNIVERSITY
New York, N. Y.

for

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION

For sale by the Clearinghouse for Federal Scientific and Technical Information
Springfield, Virginia 22151 - Price \$3.00

TABLE OF CONTENTS

	Page
SUMMARY	1
SECTION I. INTRODUCTION	1
SECTION II. MEASUREMENT PROCEDURE.....	2
SECTION III. RESULTS OF MEASUREMENTS OF SOUND ABSORPTION IN AIR	3
SECTION IV. COMPARISON WITH THEORY	4
SECTION V. ABSORPTION OF SOUND IN OXYGEN-WATER AND OXYGEN- DEUTERIUM OXIDE MIXTURES.....	5
APPENDIX A: EXPERIMENTAL SETUP.....	7
APPENDIX B: TABULAR DATA	11
ILLUSTRATIONS	44
REFERENCES.....	58

LIST OF ILLUSTRATIONS

Figure	Title	Page
1.	Attenuation Coefficient m versus Percent Relative Humidity for Air at 20° C and Normal Atmospheric Pressure	44
2.	Attenuation Coefficient m versus Percent Relative Humidity for Air at 0° C and Normal Atmospheric Pressure	45
3.	Attenuation Coefficient m versus Percent Relative Humidity for Air at -20° C and Normal Atmospheric Pressure	46
4.	Attenuation Coefficient m versus Percent Relative Humidity for Air at -40° C and Normal Atmospheric Pressure	47
5.	Plot of Experimental Data at 20° C, 0° C and -20° C of Attenuation in Air versus Humidity. These Data Are Presented in Normalized Form m/m_{\max} versus h/h_{\max}	48
6.	Maximum Attenuation Coefficient m_{\max} versus Frequency	49
7.	Relaxation Frequency Plotted as a Function of h , the Percent Molar Concentration of Water Vapor in Air	50
8.	Attenuation Coefficient m versus Percent Molar Concentration of Water Vapor for Oxygen at 20° C and Normal Pressure	51
9.	Relaxation Frequency, f_{\max} , Plotted as a Function of h , the Percent Molar Concentration of Water Vapor in Oxygen	52
10.	Attenuation Coefficient m versus Percent Relative Humidity for Air at 20° C and Pressure of 400 mm	53
11.	Attenuation Coefficient m versus Percent Relative Humidity for Air at 20° C and Pressure of 200 mm	54
12.	Attenuation Coefficient m versus Percent Molar Concentration of Deuterium Oxide Vapor for Oxygen at 20° C and Normal Pressure	55
13.	Drawing Showing the Spherical Chamber Used in Measurements. Copper Tubing Attached to Exterior Surface is Part of the Temperature-Control System	56

LIST OF ILLUSTRATIONS (Cont'd)

Figure	Title	Page
14.	Simplified Schematic Diagram of the Air-Circulation System. Air is Recirculated Continuously Through the Spherical Chamber. The Saturator Either Takes Away Moisture From the Air or Adds Moisture to It--Depending on The Relative Temperatures of the Spherical Chamber and the Saturator	57

LIST OF TABLES

Table	Title	Page
1.	Tabulation of Original Data Points for Absorption of Sound in Air Versus Relative Humidity at 20 Degrees Centigrade	12
2.	Tabulation of Original Data Points for Absorption of Sound in Air Versus Relative Humidity at 0 Degrees Centigrade	15
3.	Tabulation of Original Data Points for Absorption of Sound in Air Versus Relative Humidity at -20 Degrees Centigrade	18
4.	Tabulation of Original Data Points for Absorption of Sound in Air Versus Relative Humidity at -40 Degrees Centigrade	20
5.	Tabulation of Data Points for Absorption of Sound in Dry Nitrogen at 20 Degrees Centigrade for the Computation of Wall Losses	21
6A.	Tabulation of Original Data Points for Absorption of Sound in Air Versus Relative Humidity at 20 Degrees Centigrade	22
6B.	Tabulation of Original Data Points for Absorption of Sound in Air Versus Relative Humidity at 20 Degrees Centigrade	25
7.	Tabulation of Original Data Points for Absorption of Sound in Dry Nitrogen at 20 Degrees Centigrade	28
8.	Tabulation of Smoothed Data Points for Absorption of Sound in Air Versus Relative Humidity at 20 Degrees Centigrade	29
9.	Tabulation of Smoothed Data Points for Absorption of Sound in Air Versus Relative Humidity at 0 Degrees Centigrade	32
10.	Tabulation of Smoothed Data Points for Absorption of Sound in Air Versus Relative Humidity at -20 Degrees Centigrade	35
11.	Tabulation of Smoothed Data Points for Absorption of Sound in Air Versus Relative Humidity at -40 Degrees Centigrade	37
12.	Tabulation of Original Data Points for Absorption of Sound in Oxygen Versus Relative Humidity at 20 Degrees Centigrade	38

LIST OF TABLES (Cont'd)

Table	Title	Page
13.	Tabulation of Original Data Points for Absorption of Sound in Oxygen Versus Concentration of Deuterium Oxide	41

24713

ABSORPTION OF SOUND IN AIR BELOW 1000 CPS

SUMMARY

For many acoustic problems associated with the propagation of sound which is generated by launch vehicles, it is important to have accurate data of absorption of sound in air as a function of atmospheric conditions such as temperature, pressure, and humidity. Accurate data of this type have not been available below 2000 cps. Hence the purpose was to extend to lower frequencies the present range of reliable air absorption data. This report presents such information in the frequency range from about 125 cps to 1000 cps at 20° C, 0° C, -20° C, and -40° C.

The data described in this report can be applied to studies of acoustic propagation in the atmosphere in addition to the problem of establishing a theoretical model of sound absorption in air. In this connection measurements were made of the absorption in mixtures of oxygen and water vapor and also in mixtures of oxygen and deuterium oxide.

Author

SECTION I. INTRODUCTION

At present it is not possible to make accurate estimates of the attenuation of sound that has propagated through the atmosphere for a considerable distance. Such estimates are of considerable value in many acoustic problems associated with launch vehicles. The total attenuation between two points depends on a number of factors including the absorption of sound in air, refraction, and scattering. It is obvious that reliable data must be available which provide information regarding the absorption of sound in air as a function of atmospheric conditions. Unfortunately, accurate data of this type have not been available for frequencies below 2000 cps. In general, where such data have been required, they have been estimated by extrapolation from measurements at higher frequencies. The purpose of this study was to extend the range over which reliable air absorption data are available to lower frequencies.

During the past six years in this laboratory, an active program of research has been carried out for investigating the absorption of sound (from 125 cps to 12,500 cps) in air for different conditions of pressure, temperature, and humidity. The results of the measurements in the range from 2000 to 12,500 cps were published in a paper last year [1]. The present report on sound absorption in air provides data in the range from approximately 125 cps to 1000 cps.

In addition to the application of the data described in this report to studies of acoustic propagation in the atmosphere, these data can be applied to the problem of establishing a theoretical model of sound absorption in air. In this connection measurements were made of the absorption of sound in mixtures of oxygen and water vapor and also in mixtures of oxygen and deuterium oxide.

SECTION II. MEASUREMENT PROCEDURE

A detailed description of the experimental setup used for obtaining the data presented in this report has been given by Harris [1] in a paper which describes the technique of sound absorption measurement employed here. A complete description of the spherical chamber, the electro-acoustic measurement system, the humidity control, and evaluation of wall losses of the spherical chamber, given in that paper, is reproduced in Appendix A. A summary of this information is abstracted in this section.

The spherical chamber in which the measurements are made has an inner diameter of 1.68 meters. It is fabricated of heavy steel in order to minimize the effects of wall losses, which are quite low. For example, the reverberation time at 1000 cps when the chamber is filled with dry air is 43 seconds. Excellent temperature stability of the sphere is obtained and the temperature can be adjusted by pumping a coolant through coils affixed to the exterior surface of the chamber. The spherical chamber and associated equipment can be evacuated before filling the chamber with air to avoid contamination which can have considerable effect on the measurements.

Sound is introduced from a loudspeaker driving unit through a probe tube into the spherical chamber, thereby producing an acoustic point source within the chamber. This source was very poorly matched to the spherical enclosure so that its contribution to the absorption of the chamber would be negligible. The length of the probe was selected so that the point source is near a pressure maximum for the normal modes of vibration of the enclosure that are used in the low frequency measurements (described below), but of such a length as to discriminate against the excitation of nearby normal modes. After an acoustic steady-state has been established by the sound source, the source is turned off and the rate of decay of sound, in decibels per second, is measured.

The method of establishing a steady-state condition of humidity in the spherical enclosure is to pump the air from the sphere through an auxiliary "saturator" chamber which either adds or subtracts moisture--depending on the temperature of the saturator. Air is re-circulated through the saturator until the air contains approximately the amount of water vapor desired. Then the saturator is bypassed, but re-circulated until a steady-state humidity condition has been achieved--during this time, water vapor may be absorbed or given off by the steel walls of the spherical chamber. The humidity in the spherical enclosure is measured by an electric hygrometer which uses lithium chloride sensing elements manufactured by Hydrometrics, Inc.

Nitrogen has a sound absorption value that is well established. Hence, if the sphere is filled with this gas it is possible to compute the contribution to the measured decay rate R_{N_2} that is due to nitrogen along. If decay rate measurements are made in the sphere when filled with nitrogen, the measured value of the decay rate will be greater than R_{N_2} ; the remaining contribution is due to losses at the wall. Now because air and nitrogen are similar in characteristic impedance and in molecular weight, the wall losses are approximately the same for the decay of sound when the sphere is filled with either gas. Thus, decay rate measurements in nitrogen (Tables 5 and 6) provide data for evaluating the wall losses when measurements are made in air. It follows that the decay rate of sound in the sphere, R_{air} , is given by eq. 3 of Appendix A:

$$R_{air} = R_{measured \text{ (air)}} - R_{measured \text{ (N}_2\text{)}} + R_{N_2}$$

In this manner the value of the rate of decay for sound in air was evaluated. The attenuation coefficient m per meter (as expressed in the equation $I = I_0 e^{-mx}$) is related to the decay rate by the equation:

$$m = R_{air} / (4.34c) \text{ meters}^{-1}$$

where c is the velocity in meters/seconds.

SECTION III. RESULTS OF MEASUREMENTS OF SOUND ABSORPTION IN AIR

In this report the results of measurement of the absorption of sound in air are given as a function of water vapor content at atmospheric pressure for four temperatures, 20°C , 0°C , -20°C , and -40°C . Additional data for air are given at 20°C for pressures of 400 mm and 200 mm. This information is presented in both tabular and graphic form.

The data presented in Reference 1 at higher frequencies were taken by measuring the rate of decay of a large number of modes of vibrations, within a third-octave band, which were excited by a random noise source. Here, in the lower frequency range, the decay rate of individual modes which are excited by a pure tone is measured. Thus, data are given for each of the conditions at the five normal frequencies (eigenfrequencies) of the following normal modes of vibration of the spherical chamber: $(1, 1)$, $(0, 1)$, $(0, 2)$, $(0, 3)$, and $(0, 4)$. For example, at normal pressure and a temperature of 20°C , the $(0, 1)$ normal mode of vibration, which is the first radial mode, has a normal frequency of 293 cps. Since the normal frequencies depend upon the velocity of sound, and since the velocity of sound is a function of temperature, the set of curves presented in Figures 1 through 4 are not at the same set of frequencies for the various temperatures.

The actual data points for the absorption measurements taken at atmospheric pressure are given in Tables 1 through 4 along with other system measurements. For application to practical problems, smoothed curves drawn through the actual data points are more useful. Such smoothed curves are shown in Figures 1 through 4. These data are in good agreement with earlier measurements at higher frequencies [1]. Good accuracy was obtained in all measurements except at -40°C where the attenuation is exceedingly low. For this reason the data at this temperature may be regarded as a best estimate. The data points corresponding to the smoothed curves are given in Tables 8 through 11. Data for reduced air pressure at 20°C are shown in Figures 10 and 11 and are listed in Table 6.

SECTION IV. COMPARISON WITH THEORY

It is of interest to compare the data presented here with the theoretical studies by Kneser [2] of the absorption of sound in air containing water vapor. The first comparison is shown in Figure 5. This curve of normalized attenuation versus normalized humidity was obtained as follows: The original data points for the attenuation coefficient due to molecular absorption are listed in Tables 1 through 4 under "AIR MOL." The data for each curve has a maximum attenuation value m_{\max} at a particular value of water vapor concentration, h_{\max} . The data points for each "attenuation versus water vapor" curve were normalized by dividing each value of AIR MOL by m_{\max} . According to the theory of Kneser, the normalized data for all frequencies should fall along the dashed curve shown. The solid curve which represents the present results is in close agreement with similar data presented by Harris [1] and with similar data obtained by Delsasso [3].

According to the theory, the maximum value of absorption increases linearly with frequency. This relationship is shown by the solid lines in Figure 6 for 20°C, 0°C, and -20°C. Also shown are the values of m_{\max} taken from the original data points.

In Figure 7 another comparison with theory is shown in a plot of relaxation frequency, f_{\max} , versus the molar concentration of water vapor in the air. The relaxation frequency for a given condition of humidity is the frequency of maximum absorption and is related to the angular relaxation frequency by the equation

$$k = 2\pi f_{\max} = \omega_{\max}$$

The data obtained in this study are plotted together with similar data from Reference 1 obtained at higher frequencies.

SECTION V. ABSORPTION OF SOUND IN OXYGEN-WATER AND OXYGEN-DEUTERIUM OXIDE MIXTURES

In the past, a number of experiments have been performed to determine the absorption of sound in dry oxygen and in oxygen containing water vapor [4, 11]. It has been shown that there is a peak in the curve of "sound absorption versus moisture content" due to the relaxation of the internal energy of the vibrational mode of the oxygen molecule. In the dry gas, recent work (Parker [7], Holmes, Smith and Tempest [8]) has shown the peak in absorption to occur at about 9 cps at a pressure of 1 atm and at a temperature of 20°C. Other work indicated a higher relaxation frequency (Knotzel and Knotzel [6], 50 cps; and Henderson [9], 60 cps). As is the case with air-water mixtures, measurements in oxygen-water mixtures have shown that small quantities of water significantly affect the relaxation frequency and that this frequency of maximum absorption rises rapidly with increasing moisture content.

Measurements are reported here of the absorption of sound in extremely-dry oxygen of high purity, as a function of water vapor content. Figure 8 shows the results plotted in the form of intensity attenuation coefficient m per meter as a function of moisture content in percent molar concentration of water for the following frequencies (the pairs of numbers in the brackets specify the normal mode of vibration): [(1, 1), 130 cps; (0, 1), 280 cps; (0, 2), 482 cps; (0, 3), 680 cps; (0, 4), 878 cps]. These data are tabulated in Table 12. The moisture content at which the peak in the absorption curve occurs, increases with increasing frequency. The expected values of maximum absorption at the various frequencies were calculated from the Kneser theory [2], and were found to be on average about 5 percent higher than the measured values.

Figure 9 shows a comparison between the experimental data presented here and data of other researchers. Four curves are plotted of relaxation frequency as a function of moisture content as calculated from the following equations which are given in their respective papers:

$$\text{Knudsen and Obert [5]} \quad f_{\max} = 4.96 \times 10^2 h + 6.05 \times 10^3 h^2$$

$$\text{Knotzel and Knotzel [6]} \quad f_{\max} = 40 + 1.95 \times 10^3 h + 1.32 \times 10^4 h^2$$

$$\text{Clark and Henderson [10]} \quad f_{\max} = 3 + 1.66 \times 10^3 h + 1.45 \times 10^4 h^2$$

$$\text{Harlow and Kitching [11]} \quad f_{\max} = 2.10 \times 10^2 h + 1.20 \times 10^4 h^2$$

where f_{\max} is the frequency of maximum absorption in cps and h is the percent molar concentration of water. The data of Knudsen and Obert, which differs considerably from the other results shown, is extrapolated from measurements at 3,000 cps and higher; it is probably subject to considerable error at low frequencies. In contrast, the data of

Harlow and Kitching is based on measurements at frequencies as low as 98 cps, which rules out error due to extrapolation. It is possible that the difference between their results and those of others may be due to the method by which they determined the moisture content in their gas. Before the air re-circulation system shown in Figure 14 (Appendix A) was developed for humidity control, some measurements were made in which moisture content was determined from weights of evaporated water in the system. Results so obtained were compared with results in which humidity is measured by the direct technique of circulating the gas over calibrated electrical conductivity elements. It was found that the two methods gave quite different results, in terms of the moisture content required to produce a particular frequency of maximum absorption, with the evaporation technique giving humidity levels as high as three times the direct measurements. It was concluded that a considerable amount of moisture may be taken out of the gas in the chamber by the walls. Such an effect would result in an apparently lower measured value of relaxation frequency for a given moisture content as reported by Harlow and Kitching. The results of the present study shown by the x's in Figure 9 are in good agreement with those of Knotzel and Knotzel; they are in very close agreement with the data of Clark and Henderson, thus supporting the view that the frequency dependence of the absorption peak on moisture content contains a quadratic term.

Data are shown in Figure 12 for the absorption of sound in a mixture of oxygen and deuterium oxide. (These data are tabulated in Table 13.) A comparison of Figures 8 and 12 indicates that for a given frequency, the maximum value of absorption in oxygen-water mixture is approximately the same as the maximum value for water vapor and deuterium oxide mixture. However, the curves for the oxygen-deuterium oxide mixture have their peaks at significantly lower vapor concentrations. At present there is no satisfactory theoretical model to explain these results but these data may prove useful in helping to provide the necessary information required in establishing such a model.

APPENDIX A

I. EXPERIMENTAL SETUP¹

Spherical Chamber

The spherical chamber used in this study has an inner diameter of 1.68 m (volume=2.48 m³). It was specially fabricated, in two hemispherical shells, from hot-rolled steel having a thickness of 16 mm. The two halves are fitted with flanges and bolted together with a Teflon gasket, as illustrated in Figure 13. That the acoustic boundary losses are low in this chamber is illustrated by the fact that at 1000 cps its reverberation time is 43 sec when the chamber is filled with dry air. Measurements of the decay of sound in the chamber, when it is filled with nitrogen, show that there are no isolated mechanical resonances of the spherical chamber housing which have significant effect on the rate of decay of sound in the enclosure over the frequency range employed. The entire chamber is packed in glass-fiber blankets to provide thermal insulation. Its temperature is controlled by pumping a methanol coolant through copper tubing fastened to the exterior surface of the sphere (Fig. 13). By this means the air temperature within the chamber can be set at any value between 20° and -60°C and can be held constant to within ± 0.1°C.

A high-capacity vacuum pump connected to the chamber, together with a diffusion pump, can reduce the pressure within the sphere and its associated air lines to 1 micron (mercury column height). This is essential in order to free the entire system from contamination and to rid all parts of the system of water vapor which may be absorbed by the interior walls of the sphere and walls of the air-circulation system. During the actual decay measurements, the air-circulation system is not in operation; then the lines are closed by gate valves to avoid the loss of acoustic energy from the spherical chamber to the lines.

Electro-Acoustic Measurement System

The sound source is a 60-watt loudspeaker unit that is coupled to the spherical chamber by a stainless steel probe tube, 1/4 inch in diameter, as illustrated in Figure 13. This arrangement provides an effective acoustic point source within the chamber at the end of the probe tube. The electrical and acoustical coupling of the acoustic source are purposely mismatched in impedance so that the amount of acoustic energy that

¹

The material contained in this Appendix is taken from the reprint "Absorption of Sound in Air in the Audio-Frequency Range," Cyril M. Harris, Journal of the Acoustical Society of America, Vol. 35, No. 1, pp. 11-17, January 1963, Reference 1.

is absorbed by this transducer, while it is inactive during decay measurement, will not be significant. The loudspeaker is driven from a random-noise source. A small dynamic microphone is located in the wall of the spherical chamber. The output of the microphone is amplified, fed through a Brüel and Kjaer third-octave filter (type 2109), and thence to a high-speed level recorder. When the random-noise source is turned off, a curve of the rate of decay of sound in the spherical chamber is obtained with the level recorder. The slope of this decay curve determines the decay rate in db/sec at the center frequency of the band at which the third-octave analyzer is set.

Humidity Control

The problem of accurately controlling and measuring the humidity in a chamber in which air absorption measurements are made has always presented difficulties. In past studies, the accuracy of humidity-measurement techniques at low values of humidity, a range which is often of considerable interest, has been poor. In addition to the question of accuracy, there is the problem of ensuring that the humidity measured actually is representative of conditions within the chamber. Difficulties arise because of the absorption of water by surfaces within the measurement system.

Humidity control and measurement probably account for a major source of discrepancy among published data on the absorption of sound in air. The method used here for establishing controlled conditions of humidity is illustrated in Figure 14. Air is circulated through a closed system by means of a circulation pump which consists of a small high-speed turbofan. Air leaves the spherical chamber through an outlet at the bottom of the sphere. Then it passes through a "saturator" which is a small stainless steel cylinder whose temperature can be controlled from approximately -60°C to +20°C by means of a coolant in which the saturator is immersed. Distilled water is contained in the bottom of the saturator. Moisture either is taken from the air that passes through the saturator and deposited in the saturator, or is taken from the saturator and added to the air that passes through the saturator -- depending upon the relative temperatures of the spherical chamber and the saturator. Air is recirculated through the system until the air in the spherical chamber contains approximately the amount of water vapor required to achieve the desired equilibrium condition. Then the saturator is bypassed (by a valve system that is not shown in Fig. 14); this causes the air to re-circulate from the sphere, through the pump, and then back to the sphere -- until a steady-state humidity condition is obtained. This usually requires about a half hour.

Two sets of electric hygrometers were employed to measure relative humidity. The operation of the hygrometers is based upon the change in the resistance, with humidity, of lithium chloride sensing elements (class A, type H) which are in a bridge circuit and are manufactured by Hygrodynamics, Inc. Under the conditions employed, these elements have a rapid response time and provide a continuous monitoring of the humidity within the spherical chamber during conditions of re-circulation of air. The individual sensing elements in the two sets covered the following ranges: 1.6 to 5%, 5 to 14%, 12

to 20%, 18 to 30%, 29 to 43%, 41 to 59%, 54 to 72%. The two sets were closely matched against each other. One set was placed at the air inlet near the top of the spherical chamber and the other at the air outlet at the bottom. Observations of the readings of these sets of elements were used to determine when equilibrium was achieved. These humidity-sensing elements were calibrated in the laboratory of the manufacturer immediately before the data contained in this paper were taken--then all units were calibrated once again in a similar manner directly after the experimental data were taken. Essentially, a substitution method of humidity calibration was employed so that the accuracy provided by the sensing elements was greater than that usually quoted for such units which are used under varying field conditions -- here the accuracy was better than $\pm 1\%$ RH (relative humidity) except in the lowest range where it was about $\pm 0.5\%$ RH.

Two calibration techniques are employed by the manufacturer of the humidity-sensing elements that were used. Above 5% RH, elements are calibrated in a controlled-humidity chamber using a high-precision psychrometer employing thermometers calibrated by the National Bureau of Standards. These psychrometric readings are referred to relative-humidity tables based on the barometric pressure corresponding to that in the calibration chamber. In the very low humidity range, elements are calibrated using a two-pressure technique embodying the principles outlined by Weaver and Riley in which a known humidity condition is generated by saturating a gas stream at elevated pressures, and then expanding to atmospheric pressure. Calibrations of the sensing elements used in this study are reproducible within $\pm 0.2\%$ RH. The two techniques are compared at the lower-humidity ranges and are in close agreement (within $\pm 0.5\%$ RH).

Evaluation of Wall Losses of Spherical Chamber

In order to determine the absorption of sound in air from measurements of the rate of decay of sound in the spherical chamber used in this study, it is necessary to know the extent of the contribution to the rate of decay that may be attributed to wall losses. This may be evaluated from measurements of the rate of decay of sound in the chamber when it is filled with nitrogen since nitrogen exhibits no anomalous absorption in the frequency range of measurement. By comparing the measured values of decay rate in nitrogen with the decay rate computed from absorption data for nitrogen, one obtains a small difference which represents the effects of wall losses. This is shown as follows: The decay rate of sound, $R_{\text{measured (air)}}$, that one measures in the spherical chamber when it is filled with air is given (in decibels per second) by

$$R_{\text{measured (air)}} = R_{\text{air}} + R_{\text{wall}}, \quad (1)$$

where R_{air} is the decay rate due to absorption in the air, and R_{wall} is the decay rate due to absorption at the walls.

When the chamber is filled with prepurified dry nitrogen,

$$R_{\text{measured (N}_2\text{)}} = R_{N_2} + R_{\text{wall}}, \quad (2)$$

where R_{N_2} is the decay rate due to absorption in nitrogen in db/sec.

If it is assumed that the wall losses for N_2 and air are approximately the same, because these gases are closely similar in molecular weight and characteristic impedance, then subtracting eq. 2 from eq. 1:

$$R_{\text{air}} = R_{\text{measured (air)}} - R_{\text{measured (N}_2\text{)}} + R_{N_2} \quad (3)$$

The first two terms on the right are obtained from measurements of the rate of decay of sound in the spherical chamber while the third term is calculated from the data for nitrogen by Parbrook and Tempest. Consideration has been given to possible variation in the boundary losses with changes in the humidity within the sphere. As pointed out by Evans and Bazley in discussing this possibility, the work of Knudsen, Wilson and Anderson indicates that such an effect is not significant; their data show that there is no appreciable change in wall absorption even when moisture condenses on the wall surfaces.

The value of R_{air} in db/sec given by eq. 3 is converted to the attenuation coefficient m per meter as expressed in the equation $I = I_0 e^{-mx}$ by the relation

$$m = R_{\text{air}} / (4.34c) \text{ meters}^{-1}$$

where c is the velocity of sound in m/sec.

APPENDIX B
TABULAR DATA *

TABLE NO.	DATA POINTS	GAS	PRESSURE MM	TEMPERATURE DEG. CENT
1	ORIGINAL	AIR + WATER VAPOR	760	20
2	ORIGINAL	AIR + WATER VAPOR	760	0
3	ORIGINAL	AIR + WATER VAPOR	760	-20
4	ORIGINAL	AIR + WATER VAPOR	760	-40
5	ORIGINAL ORIGINAL ORIGINAL ORIGINAL	DRY NITROGEN DRY NITROGEN DRY NITROGEN DRY NITROGEN	760 760 760 760	20 0 -20 -40
6A	ORIGINAL	AIR + WATER VAPOR	400	20
6B	ORIGINAL	AIR + WATER VAPOR	200	20
7	ORIGINAL	DRY NITROGEN VS. PRESSURE		20
8	SMOOTHED	AIR + WATER VAPOR	760	20
9	SMOOTHED	AIR + WATER VAPOR	760	0
10	SMOOTHED	AIR + WATER VAPOR	760	-20
11	SMOOTHED	AIR + WATER VAPOR	760	-40
12	ORIGINAL	OXYGEN + WATER VAPOR	760	20
13	ORIGINAL	OXYGEN + D20	760	20

* These tabular data, actually computer run sheets, are graphically illustrated in various figures from 1 through 12.

TABLE NO. 1
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ WALL	ONLY	ONLY	CLAS	MOL	LOG
PRCT	DEG	CENT	CPS	METRS	DB/S	DB/S	DB/S	/M	RH
	1	2		3	4	5		/M	
									6
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890
•1	20	136	2.520	2.54	1.99	.55	0037	0007	0037 0093-2999
1.2	20	136	2.520	3.18	1.99	1.19	0080	0007	0080 0202 238
1.4	20	136	2.520	3.08	1.99	1.09	0073	0007	0073 0184 438
1.8	20	136	2.520	2.76	1.99	.77	0052	0007	0052 0131 766
2.1	20	136	2.520	2.64	1.99	.65	0044	0007	0044 0111 967
2.7	20	136	2.520	2.50	1.99	.51	0034	0007	0034 0086 1294
3.8	20	136	2.520	2.36	1.99	.37	0025	0007	0025 0063 1739
5.1	20	136	2.520	2.30	1.99	.31	0021	0007	0021 0053 2123
6.1	20	136	2.520	2.26	1.99	.27	0018	0007	0018 0045 2356
6.2	20	136	2.520	2.36	1.99	.37	0025	0007	0025 0063 2377
7.2	20	136	2.520	2.32	1.99	.33	0022	0007	0022 0056 2572
7.4	20	136	2.520	2.26	1.99	.27	0018	0007	0018 0045 2608
8.2	20	136	2.520	2.35	1.99	.36	0024	0007	0024 0061 2741
9.0	20	136	2.520	2.22	1.99	.23	0015	0007	0015 0038 2863
10.1	20	136	2.520	2.26	1.99	.27	0018	0007	0018 0045 3013
13.3	20	136	2.520	2.38	1.99	.39	0026	0007	0026 0066 3372
16.3	20	136	2.520	2.35	1.99	.36	0024	0007	0024 0061 3637
20.0	20	136	2.520	2.36	1.99	.37	0025	0007	0025 0063 3903
25.4	20	136	2.520	2.23	1.99	.24	0016	0007	0016 0040 4215
31.0	20	136	2.520	2.22	1.99	.23	0015	0007	0015 0038 4474
39.0	20	136	2.520	2.22	1.99	.23	0015	0007	0015 0038 4773
•1	20	293	1.170	1.95	1.36	.59	0040	0032	0040 0047-2999
1.2	20	293	1.170	4.05	1.36	2.69	0181	0032	0181 0212 238
1.4	20	293	1.170	4.17	1.36	2.81	0189	0032	0189 0221 438
1.8	20	293	1.170	4.06	1.36	2.70	0181	0032	0181 0212 766
2.1	20	293	1.170	3.70	1.36	2.34	0157	0032	0157 0184 967
2.7	20	293	1.170	3.18	1.36	1.82	0122	0032	0122 0143 1294
3.8	20	293	1.170	2.86	1.36	1.50	0101	0032	0101 0118 1739
5.1	20	293	1.170	2.43	1.36	1.07	0072	0032	0072 0084 2123
6.1	20	293	1.170	2.22	1.36	.86	0058	0032	0058 0068 2356
6.2	20	293	1.170	2.22	1.36	.86	0058	0032	0058 0068 2377
7.2	20	293	1.170	2.12	1.36	.76	0051	0032	0051 0060 2572
7.4	20	293	1.170	2.09	1.36	.73	0049	0032	0049 0057 2608
8.2	20	293	1.170	2.07	1.36	.71	0048	0032	0048 0056 2741
9.0	20	293	1.170	2.01	1.36	.65	0044	0032	0044 0052 2863
10.1	20	293	1.170	2.03	1.36	.67	0045	0032	0045 0053 3013
13.3	20	293	1.170	1.99	1.36	.63	0042	0032	0042 0049 3372
16.3	20	293	1.170	1.98	1.36	.62	0042	0032	0042 0049 3637
20.0	20	293	1.170	1.98	1.36	.62	0042	0032	0042 0049 3903
25.4	20	293	1.170	1.97	1.36	.61	0041	0032	0041 0048 4215
31.0	20	293	1.170	1.98	1.36	.62	0042	0032	0042 0049 4474
39.0	20	293	1.170	1.96	1.36	.60	0040	0032	0040 0047 4773

* last column employed in computer plotting only.

TABLE NO. 1
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ WALL	ONLY WALL	ONLY CLAS	ONLY MOL		LOG RH
PRCT	DEG	CENT	CPS	METRS	DB/S	DB/S	DB/S	/M	/M
		1	2		3	4	5	6	
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890
.1	20	504	.681	1.81	1.17	.64	0043	0094	0042 0029-2999
1.2	20	504	.681	4.76	1.17	3.59	0241	0094	0240 0163 238
1.4	20	504	.681	5.30	1.17	4.13	0277	0094	0276 0188 438
1.8	20	504	.681	5.97	1.17	4.80	0322	0094	0321 0219 766
2.1	20	504	.681	6.12	1.17	4.95	0332	0094	0331 0225 967
2.7	20	504	.681	5.56	1.17	4.39	0295	0094	0294 0200 1294
3.8	20	504	.681	4.95	1.17	3.78	0254	0094	0253 0172 1739
5.1	20	504	.681	3.92	1.17	2.75	0185	0094	0184 0125 2123
6.1	20	504	.681	3.29	1.17	2.12	0142	0094	0141 0096 2356
6.2	20	504	.681	3.26	1.17	2.09	0140	0094	0139 0095 2377
7.2	20	504	.681	2.93	1.17	1.76	0118	0094	0117 0080 2572
7.4	20	504	.681	2.87	1.17	1.70	0114	0094	0113 0077 2608
8.2	20	504	.681	2.76	1.17	1.59	0107	0094	0106 0072 2741
9.0	20	504	.681	2.57	1.17	1.40	0094	0094	0093 0063 2863
10.1	20	504	.681	2.52	1.17	1.35	0091	0094	0090 0061 3013
13.3	20	504	.681	2.29	1.17	1.12	0075	0094	0074 0050 3372
16.3	20	504	.681	2.19	1.17	1.02	0068	0094	0067 0046 3637
20.0	20	504	.681	2.14	1.17	.97	0065	0094	0064 0044 3903
25.4	20	504	.681	2.12	1.17	.95	0064	0094	0063 0043 4215
31.0	20	504	.681	2.15	1.17	.98	0066	0094	0065 0044 4474
39.0	20	504	.681	2.19	1.17	1.02	0068	0094	0067 0046 4773
.1	20	712	.482	2.77	2.07	.70	0047	0187	0045 0022-2999
1.2	20	712	.482	6.22	2.07	4.15	0279	0187	0277 0134 238
1.4	20	712	.482	6.97	2.07	4.90	0329	0187	0327 0158 438
1.8	20	712	.482	8.30	2.07	6.23	0418	0187	0416 0201 766
2.1	20	712	.482	9.13	2.07	7.06	0474	0187	0472 0228 967
2.7	20	712	.482	9.26	2.07	7.19	0483	0187	0481 0232 1294
3.8	20	712	.482	8.73	2.07	6.66	0447	0187	0445 0215 1739
5.1	20	712	.482	7.30	2.07	5.23	0351	0187	0349 0168 2123
6.1	20	712	.482	6.21	2.07	4.14	0278	0187	0276 0133 2356
6.2	20	712	.482	6.19	2.07	4.12	0277	0187	0275 0133 2377
7.2	20	712	.482	5.54	2.07	3.47	0233	0187	0231 0111 2572
7.4	20	712	.482	5.41	2.07	3.34	0224	0187	0222 0107 2608
8.2	20	712	.482	5.13	2.07	3.06	0205	0187	0203 0098 2741
9.0	20	712	.482	4.79	2.07	2.72	0183	0187	0181 0087 2863
10.1	20	712	.482	4.74	2.07	2.67	0179	0187	0177 0085 3013
13.3	20	712	.482	4.15	2.07	2.08	0140	0187	0138 0067 3372
16.3	20	712	.482	3.89	2.07	1.82	0122	0187	0120 0058 3637
20.0	20	712	.482	3.72	2.07	1.65	0111	0187	0109 0053 3903
25.4	20	712	.482	3.62	2.07	1.55	0104	0187	0102 0049 4215
31.0	20	712	.482	3.61	2.07	1.54	0103	0187	0101 0049 4474
39.0	20	712	.482	3.65	2.07	1.58	0106	0187	0104 0050 4773

TABLE NO. 1
TABULATION OF ORIGINAL DATA POINTS FOR
ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
AT 20 DEGREES CENTIGRADE

R.H. PRCT	TEMP CENT	FREQ cps	LAMDA DEG METRS	AIR	AIR	AIR	AIR	MU	3000* LOG RH
				+ WALL	ONLY	ONLY	CLAS	MEL	
				DB/S	DB/S	DB/S	/M	/M	
1	2		3	4	5	6			
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890
•1	20	918	•374	5.22	4.50	•72	0046	0312	0045
1.2	20	918	•374	8.55	4.50	4.05	0272	0312	0269
1.4	20	918	•374	9.26	4.50	4.76	0320	0312	0317
1.8	20	918	•374	11.00	4.50	6.50	0436	0312	0433
2.1	20	918	•374	12.40	4.50	7.90	0530	0312	0527
2.7	20	918	•374	13.35	4.50	8.85	0594	0312	0591
3.8	20	918	•374	13.20	4.50	8.70	0584	0312	0581
5.1	20	918	•374	11.70	4.50	7.20	0483	0312	0480
6.1	20	918	•374	10.35	4.50	5.85	0393	0312	0390
6.2	20	918	•374	10.30	4.50	5.80	0389	0312	0386
7.2	20	918	•374	9.48	4.50	4.98	0334	0312	0331
7.4	20	918	•374	9.26	4.50	4.76	0320	0312	0317
8.2	20	918	•374	9.85	4.50	4.35	0292	0312	0289
9.0	20	918	•374	8.33	4.50	3.83	0257	0312	0254
10.1	20	918	•374	9.25	4.50	3.75	0252	0312	0249
13.3	20	918	•374	7.25	4.50	2.75	0185	0312	0182
16.3	20	918	•374	6.90	4.50	2.40	0161	0312	0158
20.0	20	918	•374	6.50	4.50	2.00	0134	0312	0131
25.4	20	918	•374	6.28	4.50	1.78	0119	0312	0113
31.0	20	918	•374	6.23	4.50	1.73	0115	0312	0116
39.0	20	918	•374	6.28	4.50	1.78	0119	0312	0116
39.5	20	918	•374	6.03	4.50	1.53	0103	0312	0100
									0037 4790

* last column employed in computer plotting only.

TABLE NO. 2
TABULATION OF ORIGINAL DATA POINTS FOR
ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
AT 0 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ PRCT	WALL	WALL	ONLY	ONLY	LOG
				DEG CENT	DB/S	DB/S	DB/S	/M	RH
1	2	3	4	5	6				
12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678
.1	0	132	2.520	2.10	1.88	.22	0015	0007	0015 0038-2999
3.1	0	132	2.520	2.60	1.88	.72	0050	0007	0050 0126 1474
4.1	0	132	2.520	2.67	1.88	.79	0055	0007	0055 0138 1838
4.4	0	132	2.520	2.67	1.88	.79	0055	0007	0055 0138 1930
5.4	0	132	2.520	2.64	1.88	.76	0053	0007	0053 0133 2197
6.2	0	132	2.520	2.53	1.88	.65	0045	0007	0045 0113 2377
7.3	0	132	2.520	2.55	1.88	.67	0047	0007	0047 0118 2590
8.9	0	132	2.520	2.34	1.88	.46	0032	0007	0032 0080 2848
11.1	0	132	2.520	2.37	1.88	.49	0034	0007	0034 0085 3136
11.9	0	132	2.520	2.26	1.88	.38	0026	0007	0026 0065 3227
12.4	0	132	2.520	2.17	1.88	.29	0020	0007	0020 0050 3280
13.0	0	132	2.520	2.10	1.88	.22	0015	0007	0015 0038 3342
15.4	0	132	2.520	2.10	1.88	.22	0015	0007	0015 0038 3563
17.5	0	132	2.520	2.07	1.88	.19	0013	0007	0013 0033 3729
25.1	0	132	2.520	2.04	1.88	.16	0011	0007	0011 0028 4199
27.4	0	132	2.520	2.02	1.88	.14	0010	0007	0010 0025 4313
33.6	0	132	2.520	2.02	1.88	.14	0010	0007	0010 0025 4579
38.4	0	132	2.520	1.97	1.88	.09	0006	0007	0006 0015 4753
44.6	0	132	2.520	2.02	1.88	.14	0010	0007	0010 0025 4948
54.0	0	132	2.520	1.99	1.88	.11	0008	0007	0008 0020 5197
64.0	0	132	2.520	2.03	1.88	.15	0010	0007	0010 0025 5419
84.0	0	132	2.520	1.99	1.88	.11	0008	0007	0008 0020 5773
91.0	0	132	2.520	2.00	1.88	.12	0008	0007	0008 0020 5877
.1	0	282	1.170	1.63	1.34	.29	0020	0031	0020 0024-2999
3.1	0	282	1.170	2.49	1.34	1.15	0080	0031	0080 0094 1474
4.1	0	282	1.170	2.75	1.34	1.41	0098	0031	0098 0115 1838
4.4	0	282	1.170	2.92	1.34	1.58	0110	0031	0110 0129 1930
5.4	0	282	1.170	3.05	1.34	1.71	0119	0031	0119 0140 2197
6.2	0	282	1.170	3.08	1.34	1.74	0121	0031	0121 0142 2377
7.3	0	282	1.170	3.14	1.34	1.80	0125	0031	0125 0147 2590
8.9	0	282	1.170	3.07	1.34	1.73	0120	0031	0120 0141 2848
11.1	0	282	1.170	2.95	1.34	1.61	0112	0031	0112 0132 3136
11.9	0	282	1.170	2.75	1.34	1.41	0098	0031	0098 0115 3227
12.4	0	282	1.170	2.58	1.34	1.24	0086	0031	0086 0101 3280
13.0	0	282	1.170	2.39	1.34	1.05	0073	0031	0073 0086 3342
15.4	0	282	1.170	2.22	1.34	.88	0061	0031	0061 0072 3563
17.5	0	282	1.170	2.06	1.34	.72	0050	0031	0050 0059 3729
25.1	0	282	1.170	1.88	1.34	.54	0038	0031	0038 0045 4199
27.4	0	282	1.170	1.87	1.34	.53	0037	0031	0037 0043 4313
33.6	0	282	1.170	1.74	1.34	.40	0028	0031	0028 0033 4579
38.4	0	282	1.170	1.69	1.34	.35	0024	0031	0024 0028 4753
44.6	0	282	1.170	1.65	1.34	.31	0022	0031	0022 0026 4948
54.0	0	282	1.170	1.64	1.34	.30	0021	0031	0021 0025 5197
64.0	0	282	1.170	1.59	1.34	.25	0017	0031	0017 0020 5419
84.0	0	282	1.170	1.59	1.34	.25	0017	0031	0017 0020 5773
91.0	0	282	1.170	1.59	1.34	.25	0017	0031	0017 0020 5877

TABLE NO. 2
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 0 DEGREES CENTIGRADE

R.H. PRCT	TEMP CENT	FREQ CPS	LAMDA DEG METRS	AIR	AIR	AIR	AIR	MU	3000*
				+ WALL	ONLY WALL	ONLY CLAS	/M	/M	LOG RH
1	2	3	4	5	6				
12.3	45.6	78.9	01.23	45.6	78.9	01.23	45.6	78.9	01.23
4.1	0	486	.681	1.43	1.10	.33	0023	0090	0022
3.1	0	486	.681	2.40	1.10	1.30	0090	0090	0089
4.1	0	486	.681	2.76	1.10	1.66	0115	0090	0114
4.4	0	486	.681	2.98	1.10	1.88	0131	0090	0130
5.4	0	486	.681	3.32	1.10	2.22	0154	0090	0153
6.2	0	486	.681	3.54	1.10	2.44	0170	0090	0169
7.3	0	486	.681	3.78	1.10	2.68	0186	0090	0185
8.9	0	486	.681	4.03	1.10	2.93	0204	0090	0203
11.1	0	486	.681	4.13	1.10	3.03	0211	0090	0210
11.9	0	486	.681	4.12	1.10	3.02	0210	0090	0209
12.4	0	486	.681	3.97	1.10	2.87	0200	0090	0199
13.0	0	486	.681	3.71	1.10	2.61	0181	0090	0180
15.4	0	486	.681	3.37	1.10	2.27	0158	0090	0157
17.5	0	486	.681	3.05	1.10	1.95	0136	0090	0135
25.1	0	486	.681	2.58	1.10	1.48	0103	0090	0102
27.4	0	486	.681	2.57	1.10	1.47	0102	0090	0101
33.6	0	486	.681	2.16	1.10	1.06	0074	0090	0073
38.4	0	486	.681	2.00	1.10	.90	0063	0090	0062
44.6	0	486	.681	1.88	1.10	.78	0054	0090	0053
54.0	0	486	.681	1.81	1.10	.71	0049	0090	0048
64.0	0	486	.681	1.67	1.10	.57	0040	0090	0039
84.0	0	486	.681	1.61	1.10	.51	0035	0090	0034
91.0	0	486	.681	1.59	1.10	.49	0034	0090	0033
									0023
									5877
.1	0	686	.482	2.70	2.62	.08	0006	0179	0004
3.1	0	686	.482	3.77	2.62	1.15	0080	0179	0078
4.1	0	686	.482	4.03	2.62	1.41	0098	0179	0096
4.4	0	686	.482	4.38	2.62	1.76	0122	0179	0120
5.4	0	686	.482	4.79	2.62	2.17	0151	0179	0149
6.2	0	686	.482	5.14	2.62	2.52	0175	0179	0173
7.3	0	686	.482	5.49	2.62	2.87	0200	0179	0198
8.9	0	686	.482	5.97	2.62	3.35	0233	0179	0231
11.1	0	686	.482	6.28	2.62	3.66	0254	0179	0252
11.9	0	686	.482	6.58	2.62	3.96	0275	0179	0273
12.4	0	686	.482	6.70	2.62	4.08	0284	0179	0282
13.0	0	686	.482	6.63	2.62	4.01	0279	0179	0277
15.4	0	686	.482	6.28	2.62	3.66	0254	0179	0252
17.5	0	686	.482	5.80	2.62	3.18	0221	0179	0219
25.1	0	686	.482	5.03	2.62	2.41	0168	0179	0166
27.4	0	686	.482	5.16	2.62	2.54	0177	0179	0175
33.6	0	686	.482	4.33	2.62	1.71	0119	0179	0117
38.4	0	686	.482	4.03	2.62	1.41	0098	0179	0096
44.6	0	686	.482	3.77	2.62	1.15	0080	0179	0078
54.0	0	686	.482	3.62	2.62	1.00	0070	0179	0068
64.0	0	686	.482	3.37	2.62	.75	0052	0179	0050
84.0	0	686	.482	3.26	2.62	.64	0044	0179	0042
91.0	0	686	.482	3.13	2.62	.51	0035	0179	0033
									0016
									5877

TABLE NO. 2
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 0 DEGREES CENTIGRADE

R.H. PRCT	TEMP CENT	FREQ CPS	LAMDA METRS	AIR	AIR	AIR	AIR	MU	3000*
				+ ONLY	WALL	WALL	CLAS	MOL	LOG
				DEG	DB/S	DB/S	DB/S	/M	RH
1	2	3	4		5	6			
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890
•1	0	886	•374	4.57	4.00	.57	0040	0299	0037 0014-2999
3.1	0	886	•374	5.58	4.00	1.58	0110	0299	0107 0040 1474
4.1	0	886	•374	6.08	4.00	2.08	0145	0299	0142 0053 1838
4.4	0	886	•374	6.13	4.00	2.13	0148	0299	0145 0054 1930
5.4	0	886	•374	6.65	4.00	2.65	0184	0299	0181 0068 2197
6.2	0	886	•374	7.10	4.00	3.10	0216	0299	0213 0080 2377
7.3	0	886	•374	7.43	4.00	3.43	0238	0299	0235 0088 2590
8.9	0	886	•374	8.29	4.00	4.29	0298	0299	0295 0110 2848
11.1	0	886	•374	8.68	4.00	4.68	0325	0299	0322 0120 3136
11.9	0	886	•374	9.40	4.00	5.40	0375	0299	0372 0139 3227
12.4	0	886	•374	9.78	4.00	5.78	0402	0299	0399 0149 3280
13.0	0	886	•374	10.00	4.00	6.00	0417	0299	0414 0155 3342
15.4	0	886	•374	9.67	4.00	5.67	0394	0299	0391 0146 3563
17.5	0	886	•374	9.45	4.00	5.45	0379	0299	0376 0141 3729
25.1	0	886	•374	6.67	4.00	2.67	0186	0299	0183 0068 4199
27.4	0	886	•374	8.36	4.00	4.36	0303	0299	0300 0112 4313
33.6	0	886	•374	7.40	4.00	3.40	0236	0299	0233 0087 4579
38.4	0	886	•374	6.96	4.00	2.96	0206	0299	0203 0076 4753
44.6	0	886	•374	6.52	4.00	2.52	0175	0299	0172 0064 4948
54.0	0	886	•374	6.28	4.00	2.28	0158	0299	0155 0058 5197
64.0	0	886	•374	5.77	4.00	1.77	0123	0299	0120 0045 5419
84.0	0	886	•374	5.42	4.00	1.42	0099	0299	0096 0036 5773

* last column employed in computer plotting only.

TABLE 3
TABULATION OF ORIGINAL DATA POINTS FOR
ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
AT -20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ DEG	ONLY	ONLY	CLAS	MOL	LOG
PRCT	CENT	CPS	METRS	WALL	WALL				RH
1	2	3	4						
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890
1.0	-20	272	1.170	1.40	1.21	.19	0014	0029	0014
17.7	-20	272	1.170	1.65	1.21	.44	0032	0029	0032
22.2	-20	272	1.170	1.90	1.21	.69	0050	0029	0050
29.3	-20	272	1.170	2.10	1.21	.89	0064	0029	0064
31.1	-20	272	1.170	2.16	1.21	.95	0069	0029	0069
37.0	-20	272	1.170	2.16	1.21	.95	0069	0029	0069
42.8	-20	272	1.170	2.17	1.21	.91	0066	0029	0066
46.7	-20	272	1.170	2.05	1.21	.84	0061	0029	0061
58.0	-20	272	1.170	1.95	1.21	.74	0053	0029	0053
66.5	-20	272	1.170	1.86	1.21	.65	0047	0029	0047
72.0	-20	272	1.170	1.79	1.21	.58	0042	0029	0042
78.0	-20	272	1.170	1.73	1.21	.52	0038	0029	0038
80.0	-20	272	1.170	1.71	1.21	.50	0036	0029	0036
98.0	-20	272	1.170	1.68	1.21	.47	0034	0029	0034
1.0	-20	468	.680	1.19	.99	.20	0014	0086	0013
17.7	-20	468	.680	1.45	.99	.46	0033	0086	0032
22.2	-20	468	.680	1.78	.99	.79	0057	0086	0056
29.3	-20	468	.680	2.04	.99	1.05	0076	0086	0075
31.1	-20	468	.680	2.34	.99	1.35	0098	0086	0097
37.0	-20	468	.680	2.55	.99	1.56	0113	0086	0112
42.8	-20	468	.680	2.63	.99	1.64	0118	0086	0117
46.7	-20	468	.680	2.64	.99	1.65	0119	0086	0118
58.0	-20	468	.680	2.62	.99	1.63	0118	0086	0117
66.5	-20	468	.680	2.53	.99	1.54	0111	0086	0110
72.0	-20	468	.680	2.42	.99	1.43	0103	0086	0102
78.0	-20	468	.680	2.31	.99	1.32	0095	0086	0094
80.0	-20	468	.680	2.25	.99	1.26	0091	0086	0090
98.0	-20	468	.680	2.10	.99	1.11	0080	0086	0079

* last column employed in computer plotting only.

TABLE 3
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT -20 DEGREES CENTIGRAD

R.H. PRCT	TEMP DEG CENT	FREQ METRS	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ WALL	ONLY WALL	ONLY CLAS	CLAS MOL		LOG
				DB/S	DB/S	DB/S	/M	/M	RH
12345678901234567890123456789012345678901234567890123456789012345678	12345678901234567890123456789012345678901234567890123456789012345678	12345678901234567890123456789012345678901234567890123456789012345678	12345678901234567890123456789012345678901234567890123456789012345678	12345678901234567890123456789012345678901234567890123456789012345678	12345678901234567890123456789012345678901234567890123456789012345678	12345678901234567890123456789012345678901234567890123456789012345678	12345678901234567890123456789012345678901234567890123456789012345678	12345678901234567890123456789012345678901234567890123456789012345678	12345678901234567890123456789012345678901234567890123456789012345678
1.0	-20	660	.482	2.00	1.86	.14	0010	0170	0008 0004 0
17.7	-20	660	.482	2.32	1.86	.46	0033	0170	0031 0015 3744
22.2	-20	660	.482	2.66	1.86	.80	0058	0170	0056 0027 4039
29.3	-20	660	.482	2.98	1.86	1.12	0081	0170	0079 0038 4401
31.1	-20	660	.482	3.40	1.86	1.54	0111	0170	0109 0053 4478
37.0	-20	660	.482	3.73	1.86	1.87	0135	0170	0133 0064 4705
42.8	-20	660	.482	3.99	1.86	2.13	0154	0170	0152 0073 4894
46.7	-20	660	.482	4.14	1.86	2.28	0165	0170	0163 0079 5008
58.0	-20	660	.482	4.25	1.86	2.39	0173	0170	0171 0083 5290
66.5	-20	660	.482	4.23	1.86	2.37	0171	0170	0169 0082 5468
72.0	-20	660	.482	4.20	1.86	2.34	0169	0170	0167 0081 5572
78.0	-20	660	.482	4.08	1.86	2.22	0160	0170	0158 0076 5676
80.0	-20	660	.482	4.04	1.86	2.18	0157	0170	0155 0075 5709
98.0	-20	660	.482	3.96	1.86	2.10	0152	0170	0150 0072 5974
1.0	-20	853	.373	3.62	3.58	.04	0003	0288	0000 0000 0
17.7	-20	853	.373	3.82	3.58	.24	0017	0288	0014 0005 3744
22.2	-20	853	.373	4.05	3.58	.47	0034	0288	0031 0012 4039
29.3	-20	853	.373	4.38	3.58	.80	0058	0288	0055 0021 4401
31.1	-20	853	.373	4.83	3.58	1.25	0090	0288	0087 0033 4478
37.0	-20	853	.373	5.27	3.58	1.69	0122	0288	0119 0045 4705
42.8	-20	853	.373	5.67	3.58	2.09	0151	0288	0148 0055 4894
46.7	-20	853	.373	5.92	3.58	2.34	0169	0288	0166 0062 5008
58.0	-20	853	.373	6.20	3.58	2.62	0189	0288	0186 0070 5290
66.5	-20	853	.373	6.20	3.58	2.62	0189	0288	0186 0070 5468
72.0	-20	853	.373	6.35	3.58	2.77	0200	0288	0197 0074 5572
78.0	-20	853	.373	6.29	3.58	2.71	0196	0288	0193 0072 5676
80.0	-20	853	.373	6.21	3.58	2.63	0190	0288	0187 0070 5709
98.0	-20	853	.373	6.25	3.58	2.67	0193	0288	0190 0071 5974

* last column employed in computer plotting only.

TABLE 4

TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT -40 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	AIR	MU	3000*
				+	ONLY	ONLY	CLAS	MOL		LOG
PRCT	CENT	CPS	METRS	DEG	WALL	WALL				RH
1	2	3	4		5	6				
12345678901234567890123456789012345678901234567890123456789012345678										
9.0	40	260	1.170	1.34 1.31	.13 0010	0083 0009	0007 2680			
32.0	40	260	1.170	1.33 1.31	.12 0009	0083 0008	0006 4510			
43.0	40	260	1.170	1.37 1.31	.16 0012	0083 0011	0008 4910			
74.0	40	260	1.170	1.39 1.31	.18 0013	0083 0012	0009 5610			
88.0	40	260	1.170	1.38 1.31	.17 0013	0083 0012	0009 5830			
97.0	40	260	1.170	1.40 1.31	.19 0014	0083 0013	0010 5970			
9.0	40	447	.680	1.15 .95	.20 0015	0164 0013	0010 2860			
32.0	40	447	.680	1.12 .95	.17 0013	0164 0011	0009 4510			
43.0	40	447	.680	1.14 .95	.19 0014	0164 0013	0010 4910			
74.0	40	447	.680	1.17 .95	.22 0015	0164 0014	0011 5610			
88.0	40	447	.680	1.17 .95	.23 0016	0164 0014	0011 5830			
97.0	40	447	.680	1.18 .95	.24 0017	0164 0015	0012 5970			
9.0	40	631	.482	1.82 1.71	.11 0008	0277 0005	0004 2860			
32.0	40	631	.482	1.82 1.71	.11 0008	0277 0005	0004 4510			
43.0	40	631	.482	1.83 1.71	.12 0009	0277 0006	0004 4910			
74.0	40	631	.482	1.87 1.71	.16 0012	0277 0009	0006 5610			
88.0	40	631	.482	1.87 1.71	.16 0012	0277 0009	0006 5830			
97.0	40	631	.482	1.87 1.71	.16 0012	0277 0009	0006 5970			

* last column employed in computer plotting only.

TABLE NO. 5
 TABULATION OF DATA POINTS FOR
 ABSORPTION OF SOUND IN DRY NITROGEN
 AT 20 DEGREES CENTIGRADE
 FOR THE COMPUTATION OF WALL LOSSES

MICROPHN	1111111111111111	2222222222222222	2222222222222222	111111111111				
TEMP	+20C	0C	-20C	-40C				
MODE	F	R	F	R	F	R	F	R
11	139	2.14	134	1.88	129	1.92	----	----
01	298	1.39	288	1.34	277	1.28	265	1.21
02	512	1.20	495	1.10	475	1.02	456	0.95
03	724	2.06	698	2.62	673	1.93	644	1.71
04	933	4.31	900	4.00	867	3.49	830	3.13

TABLE 6A-----400 MM PRESSURE
 TABULATION OF ORIGINAL DATA POINTS FOR:
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H. PRCT	TEMP CENT	FREQ CPS	LAMDA METRS	AIR	AIR	AIR	AIR	MU	3000*
				+	ONLY	ONLY	CLAS	MOL	LOG
				DEG	WALL	WALL	DB/S	DB/S	RH
1	2	3	4	5	6				
12345678901234567890123456789012345678901234567890123456789012345678									
1.5	20	504	.681 400	5.52	1.68	3.84	0258	0180	0256 0174 528
1.8	20	504	.681 400	6.33	1.68	4.65	0312	0180	0310 0211 766
1.9	20	504	.681 400	6.42	1.68	4.74	0318	0180	0316 0215 836
2.0	20	504	.681 400	6.23	1.68	4.55	0305	0180	0303 0206 903
2.2	20	504	.681 400	5.76	1.68	4.08	0274	0180	0272 0185 1027
2.8	20	504	.681 400	5.17	1.68	3.49	0234	0180	0232 0158 1341
4.8	20	504	.681 400	4.65	1.68	2.97	0199	0180	0197 0134 2044
5.2	20	504	.681 400	4.13	1.68	2.45	0164	0180	0162 0110 2148
5.8	20	504	.681 400	3.66	1.68	1.98	0133	0180	0131 0089 2290
6.7	20	504	.681 400	3.28	1.68	1.60	0107	0180	0105 0072 2478
8.0	20	504	.681 400	2.94	1.68	1.26	0085	0180	0083 0057 2709
10.0	20	504	.681 400	2.68	1.68	1.00	0067	0180	0065 0044 3000
12.2	20	504	.681 400	2.55	1.68	.87	0058	0180	0056 0038 3259
13.7	20	504	.681 400	2.51	1.68	.83	0056	0180	0054 0037 3410
18.5	20	504	.681 400	2.48	1.68	.80	0054	0180	0052 0035 3802
23.1	20	504	.681 400	2.45	1.68	.77	0052	0180	0050 0034 4091
26.8	20	504	.681 400	2.47	1.68	.79	0053	0180	0051 0035 4284
33.0	20	504	.681 400	2.50	1.68	.82	0055	0180	0053 0036 4556
37.0	20	504	.681 400	2.51	1.68	.83	0056	0180	0054 0037 4705
1.5	20	712	.482 400	7.30	2.92	4.38	0294	0368	0290 0140 528
1.8	20	712	.482 400	8.90	2.92	5.98	0401	0368	0397 0191 766
1.9	20	712	.482 400	9.38	2.92	6.46	0434	0368	0430 0207 836
2.0	20	712	.482 400	9.70	2.92	6.78	0455	0368	0451 0217 903
2.2	20	712	.482 400	9.48	2.92	6.56	0440	0368	0436 0210 1027
2.8	20	712	.482 400	9.00	2.92	6.08	0408	0368	0404 0195 1341
4.8	20	712	.482 400	8.32	2.92	5.40	0362	0368	0358 0173 2044
5.2	20	712	.482 400	7.51	2.92	4.59	0308	0368	0304 0147 2148
5.8	20	712	.482 400	6.75	2.92	3.83	0257	0368	0253 0122 2290
6.7	20	712	.482 400	6.00	2.92	3.08	0207	0368	0203 0098 2478
8.0	20	712	.482 400	5.33	2.92	2.41	0162	0368	0158 0076 2709
10.0	20	712	.482 400	4.80	2.92	1.88	0126	0368	0122 0059 3000
12.2	20	712	.482 400	4.52	2.92	1.60	0107	0368	0103 0050 3259
13.7	20	712	.482 400	4.38	2.92	1.46	0098	0368	0094 0045 3410
18.5	20	712	.482 400	4.21	2.92	1.29	0087	0368	0083 0040 3802
23.1	20	712	.482 400	4.08	2.92	1.16	0078	0368	0074 0036 4091
26.8	20	712	.482 400	4.07	2.92	1.15	0077	0368	0073 0035 4284
33.0	20	712	.482 400	4.04	2.92	1.12	0075	0368	0071 0034 4556
37.0	20	712	.482 400	4.07	2.92	1.15	0077	0368	0073 0035 4705

* last column employed in computer plotting only.

TABLE 6A----400 MM PRESSURE
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H. PRCT	TEMP CENT	FREQ CPS	LAMDA METRS	AIR	AIR	AIR	AIR	MU	3000*
				+ DEG	WALL	WALL	ONLY	ONLY	LOG
				1	2	3	4	5	RH
12345678901234567890123456789012345678901234567890123456789012345678									
1.5	20	918	.374 400	11.00	6.98	4.02	0270	0618	0264 0099 528
1.8	20	918	.374 400	13.00	6.98	6.02	0404	0618	0398 0149 766
1.9	20	918	.374 400	13.60	6.98	6.62	0444	0618	0438 0164 836
2.0	20	918	.374 400	14.70	6.98	7.72	0518	0618	0512 0191 903
2.2	20	918	.374 400	14.70	6.98	7.72	0518	0618	0512 0191 1027
2.8	20	918	.374 400	14.70	6.98	7.72	0518	0618	0512 0191 1341
4.8	20	918	.374 400	14.10	6.98	7.12	0478	0618	0472 0176 2044
5.2	20	918	.374 400	13.30	6.98	6.32	0424	0618	0418 0156 2148
5.8	20	918	.374 400	12.10	6.98	5.12	0344	0618	0338 0126 2290
6.7	20	918	.374 400	11.20	6.98	4.22	0283	0618	0277 0104 2478
8.0	20	918	.374 400	10.20	6.98	3.22	0216	0618	0210 0079 2709
10.0	20	918	.374 400	9.20	6.98	2.22	0149	0618	0143 0053 3000
12.2	20	918	.374 400	8.79	6.98	1.81	0122	0618	0116 0043 3259
13.7	20	918	.374 400	8.79	6.98	1.81	0122	0618	0116 0043 3410
18.5	20	918	.374 400	8.53	6.98	1.55	0104	0618	0098 0037 3802
23.1	20	918	.374 400	8.30	6.98	1.32	0089	0618	0083 0031 4091
26.8	20	918	.374 400	8.03	6.98	1.05	0070	0618	0064 0024 4284
33.0	20	918	.374 400	8.11	6.98	1.13	0076	0618	0070 0026 4556
37.0	20	918	.374 400	8.11	6.98	1.13	0076	0618	0070 0026 4705

* last column employed in computer plotting only.

TABLE 6B----200 MM PRESSURE
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H. PRCT	TEMP CENT	FREQ CPS	LAMDA METRS	AIR	AIR	AIR	AIR	MU	3000*			
				+	ONLY	ONLY	CLAS	MOL	LOG			
				DEG	WALL	WALL	DB/S	DB/S	RH			
1	2	3	4	5	6							
12345678901234567890123456789012345678901234567890123456789012345678												
1.4	20	136	2.520	200	3.52	3.05	.47	0032	0027	0032	0081	438
1.5	20	136	2.520	200	3.59	3.05	.54	0036	0027	0036	0091	528
1.7	20	136	2.520	200	3.36	3.05	.31	0021	0027	0021	0053	691
1.8	20	136	2.520	200	3.30	3.05	.25	0017	0027	0017	0043	766
1.9	20	136	2.520	200	3.33	3.05	.28	0019	0027	0019	0048	836
2.1	20	136	2.520	200	3.30	3.05	.25	0017	0027	0017	0043	967
2.4	20	136	2.520	200	3.20	3.05	.15	0010	0027	0010	0025	1141
3.1	20	136	2.520	200	3.10	3.05	.05	0003	0027	0003	0008	1474
4.7	20	136	2.520	200	3.13	3.05	.08	0005	0027	0005	0013	2016
6.4	20	136	2.520	200	3.05	3.05	.00	0000	0027	0000	0000	2419
8.3	20	136	2.520	200	3.11	3.05	.06	0004	0027	0004	0010	2757
16.7	20	136	2.520	200	3.22	3.05	.17	0011	0027	0011	0028	3668
22.0	20	136	2.520	200	3.23	3.05	.18	0012	0027	0012	0030	4027
26.3	20	136	2.520	200	3.26	3.05	.21	0014	0027	0014	0035	4260
1.4	20	293	1.170	200	4.58	2.38	2.20	0148	0122	0147	0172	438
1.5	20	293	1.170	200	4.28	2.38	1.90	0128	0122	0127	0149	528
1.7	20	293	1.170	200	3.78	2.38	1.40	0094	0122	0093	0109	691
1.8	20	293	1.170	200	3.63	2.38	1.25	0084	0122	0083	0097	766
1.9	20	293	1.170	200	3.48	2.38	1.10	0074	0122	0073	0086	836
2.1	20	293	1.170	200	3.31	2.38	.93	0062	0122	0061	0071	967
2.4	20	293	1.170	200	3.23	2.38	.85	0057	0122	0056	0066	1141
3.1	20	293	1.170	200	3.10	2.38	.72	0048	0122	0047	0055	1474
4.7	20	293	1.170	200	2.95	2.38	.57	0038	0122	0037	0043	2016
6.4	20	293	1.170	200	2.81	2.38	.43	0029	0122	0028	0033	2419
8.3	20	293	1.170	200	2.72	2.38	.34	0023	0122	0022	0026	2757
16.7	20	293	1.170	200	2.74	2.38	.36	0024	0122	0023	0027	3668
22.0	20	293	1.170	200	2.77	2.38	.39	0026	0122	0025	0029	4027
26.3	20	293	1.170	200	2.83	2.38	.45	0030	0122	0029	0034	4260

* last column employed in computer plotting only.

TABLE 6B----200 MM PRESSURE
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ WALL	ONLY WALL	ONLY	CLAS	MOL	LOG RH
PRCT	CENT	CPS	METRS	DB/S	DB/S	DB/S	/M	/M	
1	2	3	4	5	6				
12345678901234567890123456789012345678901234567890123456789012345678									
1.4	20	504	.681	200	7.12	2.40	4.72	0317	0360 0313 0213 438
1.5	20	504	.681	200	6.84	2.40	4.44	0298	0360 0294 0200 528
1.7	20	504	.681	200	6.08	2.40	3.68	0247	0360 0243 0165 691
1.8	20	504	.681	200	5.80	2.40	3.40	0228	0360 0224 0153 766
1.9	20	504	.681	200	5.50	2.40	3.10	0208	0360 0204 0139 836
2.1	20	504	.681	200	5.10	2.40	2.70	0181	0360 0177 0121 967
2.4	20	504	.681	200	4.81	2.40	2.41	0162	0360 0158 0108 1141
3.1	20	504	.681	200	4.42	2.40	2.02	0136	0360 0132 0090 1474
4.7	20	504	.681	200	4.00	2.40	1.60	0107	0360 0103 0070 2016
6.4	20	504	.681	200	3.49	2.40	1.09	0073	0360 0069 0047 2419
8.3	20	504	.681	200	3.18	2.40	.78	0052	0360 0048 0033 2757
16.7	20	504	.681	200	3.02	2.40	.62	0042	0360 0038 0026 3668
22.0	20	504	.681	200	3.03	2.40	.63	0042	0360 0038 0026 4027
26.3	20	504	.681	200	3.11	2.40	.71	0048	0360 0044 0030 4260
-	1.4	20	712	.482	200	10.60	4.14	6.46	0434 0736 0427 0206 438
1.5	20	712	.482	200	10.70	4.14	6.56	0440	0736 0433 0209 528
1.7	20	712	.482	200	10.20	4.14	6.06	0407	0736 0400 0193 691
1.8	20	712	.482	200	10.00	4.14	5.86	0393	0736 0386 0186 766
1.9	20	712	.482	200	9.59	4.14	5.45	0366	0736 0359 0173 836
2.1	20	712	.482	200	9.04	4.14	4.90	0329	0736 0322 0155 967
2.4	20	712	.482	200	8.63	4.14	4.49	0301	0736 0294 0142 1141
3.1	20	712	.482	200	7.97	4.14	3.83	0257	0736 0250 0121 1474
4.7	20	712	.482	200	7.23	4.14	3.09	0207	0736 0200 0096 2016
6.4	20	712	.482	200	6.20	4.14	2.06	0138	0736 0131 0063 2419
8.3	20	712	.482	200	5.58	4.14	1.44	0097	0736 0090 0043 2757
16.7	20	712	.482	200	5.08	4.14	.94	0063	0736 0056 0027 3668
22.0	20	712	.482	200	5.02	4.14	.88	0059	0736 0052 0025 4027
26.3	20	712	.482	200	5.09	4.14	.95	0064	0736 0057 0027 4260

* last column employed in computer plotting only.

TABLE 6B----200 MM PRESSURE
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ WALL	ONLY WALL	ONLY	CLAS	MOL	LOG
PRCT	DEG	CENT	CPS	DB/S	DB/S	DB/S	/M	/M	RH
	1	2		3	4		5		6
12345678901234567890123456789012345678901234567890123456789012345678									
1.4	20	918	•374	200	15.20	8.02	7.18	0482	1236 0470 0176 438
1.5	20	918	•374	200	15.80	8.02	7.78	0522	1236 0510 0191 528
1.7	20	918	•374	200	15.70	8.02	7.68	0516	1236 0504 0188 691
1.8	20	918	•374	200	16.00	8.02	7.98	0536	1236 0524 0196 766
1.9	20	918	•374	200	15.50	8.02	7.48	0502	1236 0490 0183 836
2.1	20	918	•374	200	14.70	8.02	6.68	0448	1236 0436 0163 967
2.4	20	918	•374	200	14.40	8.02	6.38	0428	1236 0416 0156 1141
3.1	20	918	•374	200	13.40	8.02	5.38	0361	1236 0349 0130 1474
4.7	20	918	•374	200	12.60	8.02	4.58	0307	1236 0295 0110 2016
6.4	20	918	•374	200	11.00	8.02	2.98	0200	1236 0188 0070 2419
8.3	20	918	•374	200	10.00	8.02	1.98	0133	1236 0121 0045 2757
16.7	20	918	•374	200	9.20	8.02	1.18	0079	1236 0067 0025 3668
22.0	20	918	•374	200	9.04	8.02	1.02	0068	1236 0056 0021 4027
26.3	20	918	•374	200	9.00	8.02	.98	0066	1236 0054 0020 4260

* last column employed in computer plotting only.

TABLE NO. 7
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN DRY NITROGEN
 AT 20 DEGREES CENTIGRADE

SPHERE CONTAINS TWO MICROPHONES+++NOMINAL VALUES OF FREQUENCY ARE LISTED

FREQUENCY	139 CPS	298 CPS	512 CPS	724 CPS	933 CPS
PRESSURE	R IN DB/S				
765 MM	2.14	1.39	1.20	2.06	4.31
493 MM	2.31	1.61	1.50	2.66	6.23
399 MM	2.42	1.75	1.68	2.92	6.98
298 MM	2.68	1.99	1.94	3.36	7.60
193 MM	3.08	2.41	2.44	4.20	8.05
148 MM	3.55	2.77	2.82	4.78	7.98

TABLE NO. 8
 TABULATION OF SMOOTHED DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ WALL	ONLY WALL	ONLY CLAS	ONLY MOL		LOG RH
PRCT	CENT	CPS	METRS	DB/S	DB/S	DB/S	/M	/M	
	1	2	3	4	5	6			
12345678901234567890123456789012345678901234567890123456789012345678									
•1	20	136	2.520	2.54	1.99	.55	0009	0007	0009
1.2	20	136	2.520	3.18	1.99	1.19	0085	0007	0085
1.4	20	136	2.520	3.08	1.99	1.09	0083	0007	0083
1.8	20	136	2.520	2.76	1.99	.77	0074	0007	0074
2.1	20	136	2.520	2.64	1.99	.65	0065	0007	0065
2.7	20	136	2.520	2.50	1.99	.51	0048	0007	0048
3.8	20	136	2.520	2.36	1.99	.37	0032	0007	0032
5.1	20	136	2.520	2.30	1.99	.31	0023	0007	0023
6.1	20	136	2.520	2.26	1.99	.27	0020	0007	0020
6.2	20	136	2.520	2.36	1.99	.37	0019	0007	0019
7.2	20	136	2.520	2.32	1.99	.33	0017	0007	0017
7.4	20	136	2.520	2.26	1.99	.27	0017	0007	0017
8.2	20	136	2.520	2.35	1.99	.36	0017	0007	0017
9.0	20	136	2.520	2.22	1.99	.23	0017	0007	0017
10.1	20	136	2.520	2.26	1.99	.27	0017	0007	0017
13.3	20	136	2.520	2.38	1.99	.39	0017	0007	0017
16.3	20	136	2.520	2.35	1.99	.36	0017	0007	0017
20.0	20	136	2.520	2.36	1.99	.37	0017	0007	0017
25.4	20	136	2.520	2.23	1.99	.24	0017	0007	0017
31.0	20	136	2.520	2.22	1.99	.23	0017	0007	0017
39.0	20	136	2.520	2.22	1.99	.23	0017	0007	0017
									0038 4773
1.2	20	293	1.170	4.05	1.36	2.69	0174	0032	0174
1.4	20	293	1.170	4.17	1.36	2.81	0185	0032	0185
1.8	20	293	1.170	4.06	1.36	2.70	0183	0032	0183
2.1	20	293	1.170	3.70	1.36	2.34	0170	0032	0170
2.7	20	293	1.170	3.18	1.36	1.82	0137	0032	0137
3.8	20	293	1.170	2.86	1.36	1.50	0092	0032	0092
5.1	20	293	1.170	2.43	1.36	1.07	0065	0032	0065
6.1	20	293	1.170	2.22	1.36	.86	0054	0032	0054
6.2	20	293	1.170	2.22	1.36	.86	0052	0032	0052
7.2	20	293	1.170	2.12	1.36	.76	0045	0032	0045
7.4	20	293	1.170	2.09	1.36	.73	0043	0032	0043
8.2	20	293	1.170	2.07	1.36	.71	0039	0032	0039
9.0	20	293	1.170	2.01	1.36	.65	0037	0032	0037
10.1	20	293	1.170	2.03	1.36	.67	0037	0032	0037
13.3	20	293	1.170	1.99	1.36	.63	0037	0032	0037
16.3	20	293	1.170	1.98	1.36	.62	0037	0032	0037
20.0	20	293	1.170	1.98	1.36	.62	0037	0032	0037
25.4	20	293	1.170	1.97	1.36	.61	0037	0032	0037
31.0	20	293	1.170	1.98	1.36	.62	0037	0032	0037
39.0	20	293	1.170	1.96	1.36	.60	0037	0032	0037
									0047 4773

* last column employed in computer plotting only.

TABLE NO. 8
TABULATION OF SMOOTHED DATA POINTS FOR
ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
AT 20 DEGREES CENTIGRADE

R.H. PRCT	TEMP CENT	FREQ CPS	LAMDA METRS	AIR		AIR	AIR	AIR	MU	3000*	
				+ DEG	WALL	ONLY	ONLY	CLAS	MOL	LOG RH	
				1	2	3	4	5	6		
12.34	56.78	90.01	20.504	•.681	1.81	1.17	.64	0020	0094	0020	0029 0000
1.2	20	504	•.681	4.76	1.17	3.59	0232	0094	0232	0163	238
1.4	20	504	•.681	5.30	1.17	4.13	0274	0094	0274	0188	438
1.8	20	504	•.681	5.97	1.17	4.80	0320	0094	0320	0219	766
2.1	20	504	•.681	6.12	1.17	4.95	0323	0094	0323	0225	967
2.7	20	504	•.681	5.56	1.17	4.39	0304	0094	0304	0200	1294
3.8	20	504	•.681	4.95	1.17	3.78	0229	0094	0229	0172	1739
5.1	20	504	•.681	3.92	1.17	2.75	0160	0094	0160	0125	2123
6.1	20	504	•.681	3.29	1.17	2.12	0131	0094	0131	0096	2356
6.2	20	504	•.681	3.26	1.17	2.09	0127	0094	0127	0095	2377
7.2	20	504	•.681	2.93	1.17	1.76	0108	0094	0108	0080	2572
7.4	20	504	•.681	2.87	1.17	1.70	0104	0094	0104	0077	2608
8.2	20	504	•.681	2.76	1.17	1.59	0091	0094	0091	0072	2741
9.0	20	504	•.681	2.57	1.17	1.40	0085	0094	0085	0063	2863
10.1	20	504	•.681	2.52	1.17	1.35	0075	0094	0075	0061	3013
13.3	20	504	•.681	2.29	1.17	1.12	0065	0094	0065	0050	3372
16.3	20	504	•.681	2.19	1.17	1.02	0065	0094	0065	0046	3637
20.0	20	504	•.681	2.14	1.17	.97	0065	0094	0065	0044	3903
25.4	20	504	•.681	2.12	1.17	.95	0065	0094	0065	0043	4215
31.0	20	.504	•.681	2.15	1.17	.98	0065	0094	0065	0044	4474
39.0	20	504	•.681	2.19	1.17	1.02	0065	0094	0065	0046	4773
•1	20	712	•.482	2.77	2.07	.70	0024	0187	0023	0022	0000
1.2	20	712	•.482	6.22	2.07	4.15	0259	0187	0258	0134	238
1.4	20	712	•.482	6.97	2.07	4.90	0301	0187	0300	0158	438
1.8	20	712	•.482	8.30	2.07	6.23	0379	0187	0378	C201	766
2.1	20	712	•.482	9.13	2.07	7.06	0429	0187	0428	0228	967
2.7	20	712	•.482	9.26	2.07	7.19	0458	0187	0457	0232	1294
3.8	20	712	•.482	8.73	2.07	6.66	0411	0187	0410	0215	1739
5.1	20	712	•.482	7.30	2.07	5.23	0315	0187	0314	0168	2123
6.1	20	712	•.482	6.21	2.07	4.14	0250	0187	0249	0133	2356
6.2	20	712	•.482	6.19	2.07	4.12	0245	0187	0244	0133	2377
7.2	20	712	•.482	5.54	2.07	3.47	0204	0187	0203	0111	2572
7.4	20	712	•.482	5.41	2.07	3.34	0199	0187	0198	0107	2608
8.2	20	712	•.482	5.13	2.07	3.06	0176	0187	0175	0098	2741
9.0	20	712	•.482	4.79	2.07	2.72	0158	0187	0157	0087	2863
10.1	20	712	•.482	4.74	2.07	2.67	0139	0187	0138	0085	3013
13.3	20	712	•.482	4.15	2.07	2.08	0102	0187	0101	0067	3372
16.3	20	712	•.482	3.89	2.07	1.82	0093	0187	0092	0058	3637
20.0	20	712	•.482	3.72	2.07	1.65	0093	0187	0092	0053	3903
25.4	20	712	•.482	3.62	2.07	1.55	0093	0187	0092	0049	4215
31.0	20	712	•.482	3.61	2.07	1.54	0093	0187	0092	0049	4474
39.0	20	712	•.482	3.65	2.07	1.58	0093	0187	0092	0050	4773

* last column employed in computer plotting only.

TABLE NO. 8
 TABULATION OF SMOOTHED DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H. PRCT	TEMP DEG CENT	FREQ CPS	LAMDA METRS	AIR + WALL	AIR ONLY WALL	AIR ONLY CLAS	AIR MOL	MU	3000* LOG RH
1	2	3	4	5	6				
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890
.1	20	918	.374	5.22 4.50	.72 0027	0312 0024	0017 0000		
1.2	20	918	.374	8.55 4.50	4.05 0291	0312 0288	0101 238		
1.4	20	918	.374	9.26 4.50	4.76 0333	0312 0330	0119 438		
1.8	20	918	.374	11.00 4.50	6.50 0417	0312 0414	0162 766		
2.1	20	918	.374	12.40 4.50	7.90 0489	0312 0486	0197 967		
2.7	20	918	.374	13.35 4.50	8.85 0585	0312 0582	0221 1294		
3.8	20	918	.374	13.20 4.50	8.70 0591	0312 0588	0217 1739		
5.1	20	918	.374	11.70 4.50	7.20 0483	0312 0480	0179 2123		
6.1	20	918	.374	10.35 4.50	5.85 0405	0312 0402	0146 2356		
6.2	20	918	.374	10.30 4.50	5.80 0389	0312 0386	0144 2377		
7.2	20	918	.374	9.48 4.50	4.98 0327	0312 0324	0124 2572		
7.4	20	918	.374	9.26 4.50	4.76 0315	0312 0312	0119 2608		
8.2	20	918	.374	8.85 4.50	4.35 0285	0312 0282	0108 2741		
9.0	20	918	.374	8.33 4.50	3.83 0255	0312 0252	0095 2863		
10.1	20	918	.374	8.25 4.50	3.75 0225	0312 0222	0093 3013		
13.3	20	918	.374	7.25 4.50	2.75 0165	0312 0162	0068 3372		
16.3	20	918	.374	6.90 4.50	2.40 0135	0312 0132	0059 3637		
20.0	20	918	.374	6.50 4.50	2.00 0123	0312 0120	0049 3903		
25.4	20	918	.374	6.28 4.50	1.78 0123	0312 0120	0043 4215		
31.0	20	918	.374	6.23 4.50	1.73 0123	0312 0120	0042 4474		
39.0	20	918	.374	6.28 4.50	1.78 0123	0312 0120	0043 4773		
39.5	20	918	.374	6.03 4.50	1.53 0123	0312 0120	0037 4790		

* last column employed in computer plotting only.

TABLE NO. 9
 TABULATION OF SMOOTHED DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 0 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
PRCT	CENT	CPS	METRS	+ .	ONLY	ONLY	CLAS	MOL	LOG
DEG				WALL	WALL				RH
1	2			3	4				6
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890
.3.1	0	132	2.520	2.60	1.88	.72	0053	0007	0053 0126 1474
4.1	0	132	2.520	2.67	1.88	.79	0060	0007	0060 0138 1838
4.4	0	132	2.520	2.67	1.88	.79	0060	0007	0060 0138 1930
5.4	0	132	2.520	2.64	1.88	.76	0058	0007	0058 0133 2197
6.2	0	132	2.520	2.53	1.88	.65	0053	0007	0053 0113 2377
7.3	0	132	2.520	2.55	1.88	.67	0046	0007	0046 0118 2590
8.9	0	132	2.520	2.34	1.88	.46	0037	0007	0037 0080 2848
11.1	0	132	2.520	2.37	1.88	.49	0028	0007	0028 0085 3136
11.9	0	132	2.520	2.26	1.88	.38	0026	0007	0026 0065 3227
12.4	0	132	2.520	2.17	1.88	.29	0025	0007	0025 0050 3280
13.0	0	132	2.520	2.10	1.88	.22	0023	0007	0023 0038 3342
15.4	0	132	2.520	2.10	1.88	.22	0019	0007	0019 0038 3563
17.5	0	132	2.520	2.07	1.88	.19	0017	0007	0017 0033 3729
25.1	0	132	2.520	2.04	1.88	.16	0012	0007	0012 0028 4199
27.4	0	132	2.520	2.02	1.88	.14	0012	0007	0012 0025 4313
33.6	0	132	2.520	2.02	1.88	.14	0012	0007	0012 0025 4579
38.4	0	132	2.520	1.97	1.88	.09	0012	0007	0012 0015 4753
44.6	0	132	2.520	2.02	1.88	.14	0012	0007	0012 0025 4948
54.0	0	132	2.520	1.99	1.88	.11	0012	0007	0012 0020 5197
64.0	0	132	2.520	2.03	1.88	.15	0012	0007	0012 0025 5419
84.0	0	132	2.520	1.99	1.88	.11	0012	0007	0012 0020 5773
91.0	0	132	2.520	2.00	1.88	.12	0012	0007	0012 0020 5877
.1	0	282	1.170	1.63	1.34	.29	0001	0031	0001 0024 0000
3.1	0	282	1.170	2.49	1.34	1.15	0070	0031	0070 0094 1474
4.1	0	282	1.170	2.75	1.34	1.41	0089	0031	0089 0115 1838
4.4	0	282	1.170	2.92	1.34	1.58	0096	0031	0096 0129 1930
5.4	0	282	1.170	3.05	1.34	1.71	0106	0031	0106 0140 2197
6.2	0	282	1.170	3.08	1.34	1.74	0123	0031	0123 0142 2377
7.3	0	282	1.170	3.14	1.34	1.80	0123	0031	0123 0147 2590
8.9	0	282	1.170	3.07	1.34	1.73	0119	0031	0119 0141 2848
11.1	0	282	1.170	2.95	1.34	1.61	0101	0031	0101 0132 3136
11.9	0	282	1.170	2.75	1.34	1.41	0095	0031	0095 0115 3227
12.4	0	282	1.170	2.58	1.34	1.24	0091	0031	0091 0101 3280
13.0	0	282	1.170	2.39	1.34	1.05	0087	0031	0087 0086 3342
15.4	0	282	1.170	2.22	1.34	.88	0070	0031	0070 0072 3563
17.5	0	282	1.170	2.06	1.34	.72	0060	0031	0060 0059 3729
25.1	0	282	1.170	1.88	1.34	.54	0040	0031	0040 0045 4199
27.4	0	282	1.170	1.87	1.34	.53	0036	0031	0036 0043 4313
33.6	0	282	1.170	1.74	1.34	.40	0029	0031	0029 0033 4579
38.4	0	282	1.170	1.69	1.34	.35	0026	0031	0026 0028 4753
44.6	0	282	1.170	1.65	1.34	.31	0025	0031	0025 0026 4948
54.0	0	282	1.170	1.64	1.34	.30	0025	0031	0025 0025 5197
64.0	0	282	1.170	1.59	1.34	.25	0025	0031	0025 0020 5419
84.0	0	282	1.170	1.59	1.34	.25	0025	0031	0025 0020 5773
91.0	0	282	1.170	1.59	1.34	.25	0025	0031	0025 0020 5877

* last column employed in computer plotting only.

TABLE NO. 9
 TABULATION OF SMOOTHED DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT 0 DEGREES CENTIGRADE

R.H. PRCT	TEMP CENT	FREQ cps	LAMDA METRS	AIR + WALL		AIR ONLY	AIR ONLY	AIR CLAS	AIR MOL.	3000* LOG RH		
				DEG 1	2	DB/S	DB/S	DB/S	/M	/M	/M	6
12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901
·1	0	486	·681		1.43	1.10	.33	0002	0090	0002	0015	-2999
3·1	0	486	·681		2.40	1.10	1.30	0083	0090	0083	0061	1474
4·1	0	486	·681		2.76	1.10	1.66	0109	0090	0109	0078	1838
4·4	0	486	·681		2.98	1.10	1.88	0117	0090	0117	0089	1930
5·4	0	486	·681		3.32	1.10	2.22	0143	0090	0143	0104	2197
6·2	0	486	·681		3.54	1.10	2.44	0160	0090	0160	0115	2377
7·3	0	486	·681		3.78	1.10	2.68	0192	0090	0192	0126	2590
8·9	0	486	·681		4.03	1.10	2.93	0209	0090	0209	0138	2848
11·1	0	486	·681		4.13	1.10	3.03	0209	0090	0209	0143	3136
11·9	0	486	·681		4.12	1.10	3.02	0207	0090	0207	0143	3227
12·4	0	486	·681		3.97	1.10	2.87	0204	0090	0204	0136	3280
13·0	0	486	·681		3.71	1.10	2.61	0200	0090	0200	0123	3342
15·4	0	486	·681		3.37	1.10	2.27	0177	0090	0177	0107	3563
17·5	0	486	·681		3.05	1.10	1.95	0158	0090	0158	0092	3729
25·1	0	486	·681		2.58	1.10	1.48	0102	0090	0102	0070	4199
27·4	0	486	·681		2.57	1.10	1.47	0092	0090	0092	0069	4313
33·6	0	486	·681		2.16	1.10	1.06	0072	0090	0072	0050	4579
38·4	0	486	·681		2.00	1.10	.90	0062	0090	0062	0042	4753
44·6	0	486	·681		1.88	1.10	.78	0053	0090	0053	0036	4948
54·0	0	486	·681		1.81	1.10	.71	0045	0090	0045	0033	5197
64·0	0	486	·681		1.67	1.10	.57	0042	0090	0042	0027	5419
84·0	0	486	·681		1.61	1.10	.51	0042	0090	0042	0023	5773
91·0	0	486	·681		1.59	1.10	.49	0042	0090	0042	0023	5877
·1	0	686	·482		2.70	2.62	.08	0004	0179	0003	0002	0000
3·1	0	686	·482		3.77	2.62	1.15	0094	0179	0093	0038	1474
4·1	0	686	·482		4.03	2.62	1.41	0125	0179	0124	0046	1838
4·4	0	686	·482		4.38	2.62	1.76	0131	0179	0130	0058	1930
5·4	0	686	·482		4.79	2.62	2.17	0158	0179	0157	0072	2197
6·2	0	686	·482		5.14	2.62	2.52	0182	0179	0181	0084	2377
7·3	0	686	·482		5.49	2.62	2.87	0209	0179	0208	0096	2590
8·9	0	686	·482		5.97	2.62	3.35	0255	0179	0254	0112	2848
11·1	0	686	·482		6.28	2.62	3.66	0294	0179	0293	0122	3136
11·9	0	686	·482		6.58	2.62	3.96	0300	0179	0299	0132	3227
12·4	0	686	·482		6.70	2.62	4.08	0303	0179	0302	0136	3280
13·0	0	686	·482		6.63	2.62	4.01	0308	0179	0307	0134	3342
15·4	0	686	·482		6.28	2.62	3.66	0295	0179	0296	0122	3563
17·5	0	686	·482		5.80	2.62	3.18	0275	0179	0274	0106	3729
25·1	0	686	·482		5.03	2.62	2.41	0200	0179	0199	0080	4199
27·4	0	686	·482		5.16	2.62	2.54	0176	0179	0175	0085	4313
33·6	0	686	·482		4.33	2.62	1.71	0140	0179	0139	0057	4579
38·4	0	686	·482		4.03	2.62	1.41	0122	0179	0121	0046	4753
44·6	0	686	·482		3.77	2.62	1.15	0101	0179	0100	0038	4948
54·0	0	686	·482		3.62	2.62	1.00	0083	0179	0082	0033	5197
64·0	0	686	·482		3.37	2.62	.75	0070	0179	0069	0024	5419
84·0	0	686	·482		3.26	2.62	.64	0061	0179	0060	0020	5773
91·0	0	686	·482		3.13	2.62	.51	0061	0179	0060	0016	5877

* last column employed in computer plotting only.

TABLE NO. 9
TABULATION OF SMOOTHED DATA POINTS FOR
ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
AT 0 DEGREES CENTIGRADE

R.H. PRCT	TEMP DEG CENT	FREQ CPS	LAMDA METRS	AIR		AIR	AIR	AIR	MU	3000*	
				+ WALL	ONLY WALL	ONLY	CLAS	MOL	LOG RH		
1	2		3	4		5		6			
12.3	45.6	78.9	01.2	34.5	67.8	90.1	23.4	56.7	89.0	12.3	45.6
•1	0	886	•374	4.57	4.00	•57	0006	0299	0004	0014	0000
3.1	0	886	•374	5.58	4.00	1.58	0115	0299	0113	0040	1474
4.1	0	886	•374	6.08	4.00	2.08	0146	0299	0144	0053	1838
4.4	0	885	•374	6.13	4.00	2.13	0158	0299	0156	0054	1930
5.4	0	886	•374	6.65	4.00	2.65	0193	0299	0191	0068	2197
6.2	0	886	•374	7.10	4.00	3.10	0221	0299	0219	0080	2377
7.3	0	886	•374	7.43	4.00	3.43	0252	0299	0250	0088	2590
8.9	0	886	•374	8.29	4.00	4.29	0306	0299	0304	0110	2848
11.1	0	886	•374	8.68	4.00	4.68	0372	0299	0370	0120	3136
11.9	0	886	•374	9.40	4.00	5.40	0378	0299	0378	0139	3227
12.4	0.	886	•374	9.78	4.00	5.78	0388	0299	0386	0149	3280
13.0	0	886	•374	10.00	4.00	6.00	0392	0299	0390	0155	3342
15.4	0	886	•374	9.67	4.00	5.67	0388	0299	0386	0146	3563
17.5	0	886	•374	9.45	4.00	5.45	0372	0299	0370	0141	3729
27.4	0	886	•374	8.36	4.00	4.36	0256	0299	0254	0112	4313
33.6	0	886	•374	7.40	4.00	3.40	0197	0299	0195	0087	4579
38.4	0	886	•374	6.96	4.00	2.96	0170	0299	0168	0076	4753
44.6	0	886	•374	6.52	4.00	2.52	0143	0299	0141	0064	4948
54.0	0	886	•374	6.28	4.00	2.28	0115	0299	0113	0058	5197
64.0	0	886	•374	5.77	4.00	1.77	0099	0299	0097	0045	5419
84.0	0	886	•374	5.42	4.00	1.42	0080	0299	0078	0036	5780
91.0	0	886	•374	5.36	4.00	1.36	0080	0299	0078	0034	5870

* last column employed in computer plotting only.

TABLE NO. 10

TABULATION OF SMOOTHED DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT -20 DEGREES CENTIGRADE.

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ DEG	ONLY	ONLY	CLAS	MOL	LOG
PRCT	CENT	CPS	METRS	WALL	WALL				RH
1	2	3	4	5	6				
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890
17.7 -20	272	1.170	1.65	1.21	.44	0044	0029	0044	0038 3744
22.2 -20	272	1.170	1.90	1.21	.69	0058	0029	0058	0059 4039
29.3 -20	272	1.170	2.10	1.21	.89	0066	0029	0066	0075 4401
31.1 -20	272	1.170	2.16	1.21	.95	0067	0029	0067	0081 4478
37.0 -20	272	1.170	2.16	1.21	.95	0067	0029	0067	0081 4705
42.8 -20	272	1.170	2.12	1.21	.91	0062	0029	0062	0077 4894
46.7 -20	272	1.170	2.05	1.21	.84	0058	0029	0058	0072 5008
58.0 -20	272	1.170	1.95	1.21	.74	0049	0029	0049	0062 5290
66.5 -20	272	1.170	1.86	1.21	.65	0044	0029	0044	0055 5468
72.0 -20	272	1.170	1.79	1.21	.58	0042	0029	0042	0049 5572
78.0 -20	272	1.170	1.73	1.21	.52	0039	0029	0039	0045 5676
80.0 -20	272	1.170	1.71	1.21	.50	0038	0029	0038	0042 5709
98.0 -20	272	1.170	1.68	1.21	.47	0032	0029	0032	0040 5974
17.7 -20	468	.680	1.45	.99	.46	0037	0086	0036	0022 3744
22.2 -20	468	.680	1.78	.99	.79	0056	0086	0055	0038 4039
29.3 -20	468	.680	2.04	.99	1.05	0090	0086	0089	0051 4401
31.1 -20	468	.680	2.34	.99	1.35	0098	0086	0097	0066 4478
37.0 -20	468	.680	2.55	.99	1.56	0113	0086	0112	0076 4705
42.8 -20	468	.680	2.63	.99	1.64	0119	0086	0118	0080 4894
46.7 -20	468	.680	2.64	.99	1.65	0121	0086	0120	0080 5008
58.0 -20	468	.680	2.62	.99	1.63	0118	0086	0117	0080 5290
66.5 -20	468	.680	2.53	.99	1.54	0110	0086	0109	0075 5468
72.0 -20	468	.680	2.42	.99	1.43	0103	0086	0102	0070 5572
78.0 -20	468	.680	2.31	.99	1.32	0098	0086	0097	0064 5676
80.0 -20	468	.680	2.25	.99	1.26	0095	0086	0094	0061 5709
98.0 -20	468	.680	2.10	.99	1.11	0082	0086	0081	0054 5974

* last column employed in computer plotting only.

TABLE NO. 10

TABULATION OF SMOOTHED DATA POINTS FOR -
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT -20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
DEG				WALL	WALL	ONLY	ONLY	CLAS	LOG
PRCT	CENT	CPS	METRS	DB/S	DB/S	DB/S	/M	/M	RH
1	2	3	4	5	6				
1234567890123456789012345678901234567890123456789012345678									
17.7	-20	660	.482	2.32	1.86	.46	0033	0170	0031 0015 3744
22.2	-20	660	.482	2.66	1.86	.80	0052	0170	0050 0027 4039
29.3	-20	660	.482	2.98	1.86	1.12	0096	0170	0094 0038 4401
31.1	-20	660	.482	3.40	1.86	1.54	0110	0170	0108 0053 4478
37.0	-20	660	.482	3.73	1.86	1.87	0139	0170	0137 0064 4705
42.8	-20	660	.482	3.99	1.86	2.13	0159	0170	0157 0073 4894
46.7	-20	660	.482	4.14	1.86	2.28	0166	0170	0164 0079 5008
58.0	-20	660	.482	4.25	1.86	2.39	0174	0170	0172 0083 5290
66.5	-20	660	.482	4.23	1.86	2.37	0172	0170	0170 0082 5468
72.0	-20	660	.482	4.20	1.86	2.34	0167	0170	0165 0081 5572
78.0	-20	660	.482	4.08	1.86	2.22	0159	0170	0157 0076 5676
80.0	-20	660	.482	4.04	1.86	2.18	0157	0170	0155 0075 5709
98.0	-20	660	.482	3.96	1.86	2.10	0135	0170	0133 0072 5974
17.7	-20	853	.373	3.82	3.58	.24	0021	0288	0018 0005 3744
22.2	-20	853	.373	4.05	3.58	.47	0045	0288	0042 0012 4039
29.3	-20	853	.373	4.38	3.58	.80	0080	0288	0077 0021 4401
31.1	-20	853	.373	4.83	3.58	1.25	0089	0288	0086 0033 4478
37.0	-20	853	.373	5.27	3.58	1.69	0123	0288	0120 0045 4705
42.8	-20	853	.373	5.67	3.58	2.09	0152	0288	0149 0055 4894
46.7	-20	853	.373	5.92	3.58	2.34	0170	0288	0167 0062 5008
58.0	-20	853	.373	6.20	3.58	2.62	0194	0288	0191 0070 5290
66.5	-20	853	.373	6.20	3.58	2.62	0199	0288	0196 0070 5468
72.0	-20	853	.373	6.35	3.58	2.77	0201	0288	0198 0074 5572
78.0	-20	853	.373	6.29	3.58	2.71	0199	0288	0196 0072 5676
80.0	-20	853	.373	6.21	3.58	2.63	0197	0288	0194 0070 5709
98.0	-20	853	.373	6.25	3.58	2.67	0179	0288	0176 0071 5974

* last column employed in computer plotting only.

TABLE NO. 11

TABULATION OF SMOOTHED DATA POINTS FOR
 ABSORPTION OF SOUND IN AIR VERSUS RELATIVE HUMIDITY
 AT -40 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	AIR	AIR	AIR	AIR	MU	3000*
				+ ONLY	ONLY	CLAS	VOL		LOG
PRCT	CENT	CPS	METRS	WALL	WALL				RH
1	2	3	4	DB/S	DB/S	DB/S	/M	/M	
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	12345678
4.0	-40	121	2.520					0000	
8.0	-40	121	2.520					0001	
16.0	-40	121	2.520					0002	
39.0	-40	121	2.520					0004	
79.0	-40	121	2.520					0008	
4.0	-40	260	1.170					0001	
8.0	-40	260	1.170					0001	
16.0	-40	260	1.170					0002	
39.0	-40	260	1.170					0006	
79.0	-40	260	1.170					0012	
4.0	-40	447	.680					0001	
8.0	-40	447	.680					0002	
16.0	-40	447	.680					0003	
39.0	-40	447	.680					0007	
79.0	-40	447	.680					0014	
4.0	-40	631	.482					0002	
8.0	-40	631	.482					0003	
16.0	-40	631	.482					0004	
39.0	-40	631	.482					0009	
79.0	-40	631	.482					0017	
4.0	-40	815	.373					0003	
8.0	-40	815	.373					0004	
16.0	-40	815	.373					0006	
39.0	-40	815	.373					0012	
79.0	-40	815	.373					0022	

* last column employed in computer plotting only.

TABLE NO. 12
TABULATION OF ORIGINAL DATA POINTS FOR
ABSORPTION OF SOUND IN OXYGEN VERSUS RELATIVE HUMIDITY
AT 20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	02								MU	3000*
				+ DEG	WALL PRCT	WALL CENT	DB/S	DB/S	DB/S	/M	/M		
				1	2	3	4	5	6				
1.3	20	130	2.510	4.08	2.05	2.03	0143	0007	0143	0361	342		
1.4	20	130	2.510	6.60	2.05	4.55	0320	0007	0320	0807	438		
1.9	20	130	2.510	7.41	2.05	5.36	0376	0007	0376	0949	836		
2.3	20	130	2.510	7.59	2.05	5.54	0389	0007	0389	0982	1085		
2.8	20	130	2.510	6.96	2.05	4.91	0345	0007	0345	0871	1341		
4.2	20	130	2.510	6.42	2.05	4.37	0307	0007	0307	0775	1870		
5.1	20	130	2.510	5.58	2.05	3.53	0248	0007	0248	0626	2123		
5.9	20	130	2.510	4.70	2.05	2.65	0186	0007	0186	0469	2313		
6.4	20	130	2.510	4.16	2.05	2.11	0148	0007	0148	0373	2419		
8.3	20	130	2.510	3.62	2.05	1.57	0110	0007	0110	0278	2757		
8.9	20	130	2.510	3.43	2.05	1.38	0097	0007	0097	0245	2848		
9.9	20	130	2.510	3.13	2.05	1.08	0076	0007	0076	0192	2987		
10.8	20	130	2.510	2.93	2.05	.88	0062	0007	0062	0156	3100		
12.8	20	130	2.510	2.61	2.05	.56	0039	0007	0039	0098	3322		
14.9	20	130	2.510	2.46	2.05	.41	0029	0007	0029	0073	3520		
17.3	20	130	2.510	2.35	2.05	.30	0021	0007	0021	0053	3714		
20.3	20	130	2.510	2.26	2.05	.21	0015	0007	0015	0038	3922		
24.0	20	130	2.510	2.17	2.05	.12	0008	0007	0008	0020	4141		
29.0	20	130	2.510	2.11	2.05	.06	0004	0007	0004	0010	4387		
32.5	20	130	2.510	2.06	2.05	.01	0001	0007	0001	0003	4536		
44.0	20	130	2.510	2.05	2.05	.00	0000	0007	0000	0000	4930		
50.0	20	130	2.510	2.05	2.05	.00	0000	0007	0000	0000	5097		
54.0	20	130	2.510	2.05	2.05	.00	0000	0007	0000	0000	5197		
0	20	279	1.170	2.21	1.35	.86	0060	0031	0060	0071	0		
1.3	20	279	1.170	3.82	1.35	2.47	0173	0031	0173	0203	342		
1.4	20	279	1.170	6.90	1.35	5.55	0390	0031	0390	0459	438		
1.9	20	279	1.170	8.82	1.35	7.47	0525	0031	0525	0617	836		
2.3	20	279	1.170	11.90	1.35	10.55	0741	0031	0741	0871	1085		
2.8	20	279	1.170	12.70	1.35	11.35	0797	0031	0797	0937	1341		
4.2	20	279	1.170	13.20	1.35	11.85	0832	0031	0832	0978	1870		
5.1	20	279	1.170	12.70	1.35	11.35	0797	0031	0797	0937	2123		
5.9	20	279	1.170	11.25	1.35	9.90	0695	0031	0695	0817	2313		
6.4	20	279	1.170	10.25	1.35	8.90	0625	0031	0625	0735	2419		
8.3	20	279	1.170	8.32	1.35	6.97	0490	0031	0490	0576	2757		
8.9	20	279	1.170	7.48	1.35	6.13	0431	0031	0431	0507	2848		
9.9	20	279	1.170	6.30	1.35	4.95	0348	0031	0348	0409	2987		
10.8	20	279	1.170	5.60	1.35	4.25	0299	0031	0299	0352	3100		
12.8	20	279	1.170	4.52	1.35	3.17	0223	0031	0223	0262	3322		
14.9	20	279	1.170	3.55	1.35	2.20	0155	0031	0155	0182	3520		
17.3	20	279	1.170	3.04	1.35	1.69	0119	0031	0119	0140	3714		
20.3	20	279	1.170	2.64	1.35	1.29	0091	0031	0091	0107	3922		
24.0	20	279	1.170	2.22	1.35	.87	0061	0031	0061	0072	4141		
29.0	20	279	1.170	1.97	1.35	.62	0044	0031	0044	0052	4387		
32.5	20	279	1.170	1.83	1.35	.48	0034	0031	0034	0040	4536		
44.0	20	279	1.170	1.64	1.35	.29	0020	0031	0020	0024	4930		
50.0	20	279	1.170	1.53	1.35	.18	0013	0031	0013	0015	5097		
54.0	20	279	1.170	1.46	1.35	.11	0008	0031	0008	0009	5197		

* last column employed in computer plotting only.

TABLE NO. 12
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN OXYGEN VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	02						MU	3000*
				02	02	02	02	CLAS	MOL		
PRCT	DEG			WALL	WALL						RH
1	2			DB/S	DB/S	DB/S	/M	/M	/M		
12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	
0.0	20	479	.680	1.94	1.07	.87	0061	0092	0060	0041	0
1.3	20	479	.680	3.52	1.07	2.45	0172	0092	0171	0117	342
1.4	20	479	.680	7.28	1.07	6.21	0436	0092	0435	0298	438
1.9	20	479	.680	9.45	1.07	8.38	0589	0092	0588	0403	836
2.3	20	479	.680	12.40	1.07	11.33	0796	0092	0795	0544	1085
2.8	20	479	.680	15.70	1.07	14.63	1028	0092	1027	0703	1341
4.2	20	479	.680	17.90	1.07	16.83	1182	0092	1181	0809	1870
5.1	20	479	.680	20.60	1.07	19.53	1372	0092	1371	0939	2123
5.9	20	479	.680	21.40	1.07	20.33	1428	0092	1427	0977	2313
6.4	20	479	.680	20.60	1.07	19.53	1372	0092	1371	0939	2419
8.3	20	479	.680	18.40	1.07	17.33	1217	0092	1216	0833	2757
8.9	20	479	.680	16.75	1.07	15.68	1101	0092	1100	0753	2848
9.9	20	479	.680	14.45	1.07	13.38	0940	0092	0939	0643	2987
10.8	20	479	.680	12.80	1.07	11.73	0824	0092	0823	0564	3100
12.8	20	479	.680	10.30	1.07	9.23	0648	0092	0647	0443	3322
14.9	20	479	.680	7.70	1.07	6.63	0466	0092	0465	0318	3520
17.3	20	479	.680	6.28	1.07	5.21	0366	0092	0365	0250	3714
20.3	20	479	.680	5.12	1.07	4.05	0284	0092	0283	0194	3922
24.0	20	479	.680	3.88	1.07	2.81	0197	0092	0196	0134	4141
29.0	20	479	.680	3.14	1.07	2.07	0145	0092	0144	0099	4387
32.5	20	479	.680	2.72	1.07	1.65	0116	0092	0115	0079	4536
44.0	20	479	.680	2.22	1.07	1.15	0081	0092	0080	0055	4930
50.0	20	479	.680	1.89	1.07	.82	0058	0092	0057	0039	5097
54.0	20	479	.680	1.78	1.07	.71	0050	0092	0049	0034	5197
0.0	20	677	.482	3.16	1.93	1.23	0086	0183	0084	0041	0
1.3	20	677	.482	4.73	1.93	2.80	0197	0183	0195	0094	342
1.4	20	677	.482	8.72	1.93	6.79	0477	0183	0475	0230	438
1.9	20	677	.482	11.00	1.93	9.07	0637	0183	0635	0308	836
2.3	20	677	.482	14.10	1.93	12.17	0855	0183	0853	0413	1085
2.8	20	677	.482	18.50	1.93	16.57	1164	0183	1162	0563	1341
4.2	20	677	.482	21.60	1.93	19.67	1382	0183	1380	0669	1870
5.1	20	677	.482	27.20	1.93	25.27	1775	0183	1773	0859	2123
5.9	20	677	.482	30.40	1.93	28.47	2000	0183	1998	0968	2313
6.4	20	677	.482	31.60	1.93	29.67	2084	0183	2082	1009	2419
8.3	20	677	.482	30.20	1.93	28.27	1986	0183	1984	0961	2757
8.9	20	677	.482	28.60	1.93	26.67	1873	0183	1871	0907	2848
9.9	20	677	.482	26.10	1.93	24.17	1698	0183	1696	0822	2987
10.8	20	677	.482	23.30	1.93	21.37	1501	0183	1499	0726	3100
12.8	20	677	.482	19.55	1.93	17.62	1238	0183	1236	0599	3322
14.9	20	677	.482	15.10	1.93	13.17	0925	0183	0923	0447	3520
17.3	20	677	.482	12.30	1.93	10.37	0728	0183	0726	0352	3714
20.3	20	677	.482	10.20	1.93	8.27	0581	0183	0579	0281	3922
24.0	20	677	.482	7.77	1.93	5.84	0410	0183	0408	0198	4141
29.0	20	677	.482	6.30	1.93	4.37	0307	0183	0305	0148	4387
32.5	20	677	.482	5.45	1.93	3.52	0247	0183	0245	0119	4536
44.0	20	677	.482	4.48	1.93	2.55	0179	0183	0177	0086	4930
50.0	20	677	.482	3.84	1.93	1.91	0134	0183	0132	0064	5097
54.0	20	677	.482	3.57	1.93	1.64	0115	0183	0113	0055	5197

* last column employed in computer plotting only.

TABLE NO. 12
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN OXYGEN VERSUS RELATIVE HUMIDITY
 AT 20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	02	02	02	02	MU	3000*
				+	ONLY	ONLY	CLAS	MOL	
				DEG	WALL	WALL			LOG
PRCT	CENT	CPS	METRS		DB/S	DB/S	DB/S	/M	RH
1	2			3	4	5		/M	6
12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678901	12345678
.0	20	874	.373	5.32	4.00	1.32	0093	0310	0090 0034 0
1.3	20	874	.373	6.86	4.00	2.86	0201	0310	0198 0074 342
1.4	20	874	.373	10.70	4.00	6.70	0471	0310	0468 0176 438
1.9	20	874	.373	13.00	4.00	9.00	0632	0310	0629 0236 836
2.3	20	874	.373	16.30	4.00	12.30	0864	0310	0861 0323 1085
2.8	20	874	.373	21.00	4.00	17.00	1194	0310	1191 0447 1341
4.2	20	874	.373	24.60	4.00	20.60	1447	0310	1444 0542 1870
5.1	20	874	.373	32.70	4.00	28.70	2016	0310	2013 0756 2123
5.9	20	874	.373	37.10	4.00	33.10	2325	0310	2322 0872 2313
6.4	20	874	.373	39.60	4.00	35.60	2501	0310	2498 0938 2419
8.3	20	874	.373	40.30	4.00	36.30	2550	0310	2547 0956 2757
8.9	20	874	.373	41.40	4.00	37.40	2627	0310	2624 0985 2848
9.9	20	874	.373	36.80	4.00	32.80	2304	0310	2301 0864 2987
10.8	20	874	.373	34.60	4.00	30.60	2149	0310	2146 0805 3100
12.8	20	874	.373	31.20	4.00	27.20	1911	0310	1908 0716 3322
14.9	20	874	.373	25.00	4.00	21.00	1475	0310	1472 0552 3520
17.3	20	874	.373	20.80	4.00	16.80	1180	0310	1177 0442 3714
20.3	20	874	.373	17.20	4.00	13.20	0927	0310	0924 0347 3922
24.0	20	874	.373	13.60	4.00	9.60	0674	0310	0671 0252 4141
29.0	20	874	.373	11.10	4.00	7.10	0499	0310	0496 0186 4387
32.5	20	874	.373	9.76	4.00	5.76	0405	0310	0402 0151 4536
44.0	20	874	.373	7.85	4.00	3.85	0270	0310	0267 0100 4930
50.0	20	874	.373	7.05	4.00	3.05	0214	0310	0211 0079 5097
54.0	20	874	.373	6.69	4.00	2.69	0189	0310	0186 0070 5197

* last column employed in computer plotting only.

R.H.	TEMP	FREQ	LAMDA	02	02	02	02	MU	3000*
				+	ONLY	ONLY	CLAS	MOL	LOG
PRCT	DEG		WALL	WALL					RH
12345678901234567890123456789012345678901234567890123456789012345678901234567890123456789012345678			DB/S	DB/S	DB/S	/M	/M	/M	
•1	20	130	2.510	3.19	2.05	1.14	0080	0007	0080 0201-2999
1.2	20	130	2.510	6.73	2.05	4.68	0330	0007	0330 0830 238
1.3	20	130	2.510	6.88	2.05	4.83	0340	0007	0340 0855 342
1.4	20	130	2.510	7.08	2.05	5.03	0354	0007	0354 0890 438
1.5	20	130	2.510	6.89	2.05	4.84	0341	0007	0341 0858 528
1.6	20	130	2.510	6.63	2.05	4.58	0323	0007	0323 0812 612
1.7	20	130	2.510	6.36	2.05	4.31	0304	0007	0304 0765 691
1.8	20	130	2.510	6.09	2.05	4.04	0285	0007	0285 0717 766
1.9	20	130	2.510	6.40	2.05	4.35	0307	0007	0307 0772 836
2.2	20	130	2.510	6.08	2.05	4.03	0284	0007	0284 0714 1027
2.5	20	130	2.510	5.63	2.05	3.58	0252	0007	0252 0634 1194
4.1	20	130	2.510	5.08	2.05	3.03	0214	0007	0214 0538 1838
4.3	20	130	2.510	4.89	2.05	2.84	0200	0007	0200 0503 1900
4.8	20	130	2.510	4.43	2.05	2.38	0168	0007	0168 0423 2044
5.8	20	130	2.510	4.02	2.05	1.97	0139	0007	0139 0350 2290
7.1	20	130	2.510	3.31	2.05	1.26	0089	0007	0089 0224 2554
8.2	20	130	2.510	2.95	2.05	0.90	0063	0007	0063 0158 2741
10.9	20	130	2.510	2.78	2.05	0.73	0051	0007	0051 0128 3112
14.0	20	130	2.510	2.49	2.05	0.44	0031	0007	0031 0078 3438
18.0	20	130	2.510	2.34	2.05	0.29	0020	0007	0020 0050 3766
22.4	20	130	2.510	2.24	2.05	0.19	0013	0007	0013 0033 4051
28.8	20	130	2.510	2.19	2.05	0.14	0010	0007	0010 0025 4378
32.0	20	130	2.510	2.17	2.05	0.12	0008	0007	0008 0020 4515
37.0	20	130	2.510	2.11	2.05	0.06	0004	0007	0004 0010 4705
43.0	20	130	2.510	2.10	2.05	0.05	0004	0007	0004 0010 4900
47.0	20	130	2.510	2.09	2.05	0.04	0003	0007	0003 0008 5016
•1	20	279	1.170	2.42	1.35	1.07	0075	0031	0075 0088-2999
1.2	20	279	1.170	7.43	1.35	6.08	0428	0031	0428 0502 238
1.3	20	279	1.170	8.40	1.35	7.05	0497	0031	0497 0583 342
1.4	20	279	1.170	9.01	1.35	7.66	0540	0031	0540 0633 438
1.5	20	279	1.170	9.43	1.35	8.08	0569	0031	0569 0667 528
1.6	20	279	1.170	11.35	1.35	10.00	0705	0031	0705 0826 612
1.7	20	279	1.170	11.28	1.35	9.93	0700	0031	0700 0820 691
1.8	20	279	1.170	13.10	1.35	11.75	0828	0031	0828 0970 766
1.9	20	279	1.170	13.60	1.35	12.25	0863	0031	0863 1011 836
2.2	20	279	1.170	13.80	1.35	12.45	0877	0031	0877 1028 1027
2.5	20	279	1.170	13.50	1.35	12.15	0856	0031	0856 1003 1194
4.1	20	279	1.170	12.70	1.35	11.35	0800	0031	0800 0938 1838
4.3	20	279	1.170	12.40	1.35	11.05	0779	0031	0779 0913 1900
4.8	20	279	1.170	10.15	1.35	8.80	0620	0031	0620 0727 2044
5.8	20	279	1.170	8.23	1.35	6.88	0485	0031	0485 0568 2290
7.1	20	279	1.170	6.90	1.35	5.55	0391	0031	0391 0458 2554
8.2	20	279	1.170	5.51	1.35	4.16	0293	0031	0293 0343 2741
10.9	20	279	1.170	4.48	1.35	3.13	0221	0031	0221 0259 3112
14.0	20	279	1.170	3.54	1.35	2.19	0154	0031	0154 0180 3438
18.0	20	279	1.170	3.01	1.35	1.66	0117	0031	0117 0137 3766
22.4	20	279	1.170	2.45	1.35	1.10	0078	0031	0078 0091 4051
28.8	20	279	1.170	2.15	1.35	0.80	0056	0031	0056 0066 4378
32.0	20	279	1.170	2.02	1.35	0.67	0047	0031	0047 0055 4515
37.0	20	279	1.170	1.91	1.35	0.56	0039	0031	0039 0046 4705
47.0	20	279	1.170	1.80	1.35	0.45	0032	0031	0032 0038 5016

* last column employed in computer plotting only.

TABLE NO. 13
 TABULATION OF ORIGINAL DATA POINTS FOR
 ABSORPTION OF SOUND IN OXYGEN VS CONCENTRATION OF DEUTERIUM OXIDE

R.H.	TEMP	FREQ	LAMDA	02	02	02	02	MU	3000*
PRCT	DEG	CENT	CPS	METRS	WALL	WALL			LOG
•1	20	479	•680	2•37	1•35	1•02	0072	0092	0071 0048-2999
1•2	20	479	•680	7•60	1•35	6•25	0440	0092	0439 0300 238
1•3	20	479	•680	9•23	1•35	7•88	0555	0092	0554 0378 342
1•4	20	479	•680	10•20	1•35	8•85	0624	0092	0623 0425 438
1•5	20	479	•680	11•20	1•35	9•85	0694	0092	0693 0473 528
1•6	20	479	•680	12•70	1•35	11•35	0800	0092	0799 0545 612
1•7	20	479	•680	14•00	1•35	12•65	0891	0092	0890 0608 691
1•8	20	479	•680	15•45	1•35	14•10	0994	0092	0993 0678 766
1•9	20	479	•680	17•30	1•35	15•95	1124	0092	1123 0767 836
2•2	20	479	•680	19•20	1•35	17•85	1258	0092	1257 0858 1027
2•5	20	479	•680	20•80	1•35	19•45	1371	0092	1370 0935 1194
4•1	20	479	•680	21•20	1•35	19•85	1399	0092	1398 0954 1838
4•3	20	479	•680	21•50	1•35	20•15	1420	0092	1419 0969 1900
4•8	20	479	•680	20•80	1•35	19•45	1371	0092	1370 0935 2044
5•8	20	479	•680	18•70	1•35	17•35	1223	0092	1222 0834 2290
7•1	20	479	•680	15•60	1•35	14•25	1004	0092	1003 0685 2554
8•2	20	479	•680	13•25	1•35	11•90	0839	0092	0838 0572 2741
10•9	20	479	•680	10•70	1•35	9•35	0659	0092	0658 0449 3112
14•0	20	479	•680	8•07	1•35	6•72	0474	0092	0473 0323 3438
18•0	20	479	•680	6•52	1•35	5•17	0364	0092	0363 0248 3766
22•4	20	479	•680	4•85	1•35	3•50	0247	0092	0246 0168 4051
28•8	20	479	•680	3•98	1•35	2•63	0185	0092	0184 0126 4378
32•0	20	479	•680	3•60	1•35	2•25	0159	0092	0158 0108 4515
37•0	20	479	•680	3•24	1•35	1•89	0133	0092	0132 0090 4705
43•0	20	479	•680	3•08	1•35	1•73	0122	0092	0121 0083 4900
47•0	20	479	•680	2•92	1•35	1•57	0111	0092	0110 0075 5016
•1	20	677	•482	3•69	1•93	1•76	0124	0183	0122 0059-2999
1•2	20	677	•482	9•08	1•93	7•15	0504	0183	0502 0242 238
1•3	20	677	•482	10•80	1•93	8•87	0625	0183	0623 0301 342
1•4	20	677	•482	11•85	1•93	9•92	0699	0183	0697 0337 438
1•5	20	677	•482	13•10	1•93	11•17	0787	0183	0785 0379 528
1•6	20	677	•482	14•70	1•93	12•77	0900	0183	0898 0434 612
1•7	20	677	•482	16•40	1•93	14•47	1020	0183	1018 0492 691
1•8	20	677	•482	18•20	1•93	16•27	1146	0183	1144 0553 766
1•9	20	677	•482	20•70	1•93	18•77	1323	0183	1321 0638 836
2•2	20	677	•482	23•70	1•93	21•77	1534	0183	1532 0740 1027
2•5	20	677	•482	27•10	1•93	25•17	1774	0183	1772 0856 1194
4•1	20	677	•482	28•90	1•93	26•97	1900	0183	1898 0917 1838
4•3	20	677	•482	29•80	1•93	27•87	1964	0183	1962 0948 1900
4•8	20	677	•482	31•70	1•93	29•77	2098	0183	2096 1012 2044
5•8	20	677	•482	31•30	1•93	29•37	2070	0183	2068 0999 2290
7•1	20	677	•482	27•90	1•93	25•97	1830	0183	1828 0883 2554
8•2	20	677	•482	24•40	1•93	22•47	1583	0183	1581 0764 2741
10•9	20	677	•482	20•40	1•93	18•47	1301	0183	1299 0627 3112
14•0	20	677	•482	16•10	1•93	14•17	0998	0183	0996 0481 3438
18•0	20	677	•482	12•90	1•93	10•97	0773	0183	0771 0372 3766
22•4	20	677	•482	9•85	1•93	7•92	0558	0183	0556 0269 4051
28•8	20	677	•482	8•15	1•93	6•22	0438	0183	0436 0211 4378
32•2	20	677	•482	7•43	1•93	5•50	0388	0183	0386 0186 4524
37•0	20	677	•482	6•64	1•93	4•71	0332	0183	0330 0159 4705
43•0	20	677	•482	6•38	1•93	4•45	0314	0183	0312 0151 4900
47•0	20	677	•482	6•05	1•93	4•12	0290	0183	0288 0139 5016

* last column employed in computer plotting only.

TABLE NO. 13

TABULATION OF ORIGINAL DATA POINTS FOR
ABSORPTION OF SOUND IN OXYGEN VS CONCENTRATION OF DEUTERIUM OXIDE
AT 20 DEGREES CENTIGRADE

R.H.	TEMP	FREQ	LAMDA	02 + DEG	02 ONLY	02 ONLY	02 CLAS	MU	3000*
PRCT	CENT	CPS	METRS	WALL	WALL	DB/S	DB/S	/M	LOG
1	2			3	4	5	6	/M	RH
1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890	1234567890
•1	20	874	•373	5.63	4.00	1.63	0115	0310	0112 0042-2999
1.2	20	874	•373	10.90	4.00	6.90	0486	0310	0483 0181 238
1.3	20	874	•373	12.60	4.00	8.60	0606	0310	0603 0226 342
1.4	20	874	•373	13.50	4.00	9.50	0669	0310	0666 0249 438
1.5	20	874	•373	14.85	4.00	10.85	0765	0310	0762 0285 528
1.6	20	874	•373	16.60	4.00	12.60	0888	0310	0885 0331 612
1.7	20	874	•373	18.30	4.00	14.30	1008	0310	1005 0376 691
1.8	20	874	•373	19.90	4.00	15.90	1120	0310	1117 0418 766
1.9	20	874	•373	23.00	4.00	19.00	1339	0310	1336 0500 836
2.2	20	874	•373	26.00	4.00	22.00	1550	0310	1547 0579 1027
2.5	20	874	•373	30.00	4.00	26.00	1832	0310	1829 0684 1194
4.1	20	874	•373	32.20	4.00	28.20	1987	0310	1984 0742 1838
4.3	20	874	•373	36.40	4.00	32.40	2283	0310	2280 0853 1900
4.8	20	874	•373	38.90	4.00	34.90	2459	0310	2456 0919 2044
5.8	20	874	•373	40.70	4.00	36.70	2586	0310	2583 0966 2290
7.1	20	874	•373	37.40	4.00	33.40	2353	0310	2350 0879 2554
8.2	20	874	•373	34.70	4.00	30.70	2163	0310	2160 0808 2741
10.9	20	874	•373	30.50	4.00	26.50	1867	0310	1864 0697 3112
14.0	20	874	•373	25.50	4.00	21.50	1515	0310	1512 0566 3438
18.0	20	874	•373	20.70	4.00	16.70	1177	0310	1174 0439 3766
22.4	20	874	•373	16.00	4.00	12.00	0846	0310	0843 0315 4051
28.8	20	874	•373	13.50	4.00	9.50	0669	0310	0666 0249 4378
32.0	20	874	•373	12.40	4.00	8.40	0592	0310	0589 0220 4515
37.0	20	874	•373	11.20	4.00	7.20	0507	0310	0504 0189 4705
43.0	20	874	•373	10.80	4.00	6.80	0479	0310	0476 0178 4900
47.0	20	874	•373	10.40	4.00	6.40	0451	0310	0448 0168 5016

* last column employed in computer plotting only.




FIGURE 1. ATTENUATION COEFFICIENT m VERSUS PERCENT RELATIVE HUMIDITY FOR AIR AT 20°C AND NORMAL ATMOSPHERIC PRESSURE




FIGURE 2. ATTENUATION COEFFICIENT E VERSUS PERCENT RELATIVE HUMIDITY FOR AIR AT $0^\circ C$ AND NORMAL ATMOSPHERIC PRESSURE




FIGURE 3. ATTENUATION COEFFICIENT m VERSUS PERCENT RELATIVE HUMIDITY FOR AIR AT -20°C AND NORMAL ATMOSPHERIC PRESSURE




FIGURE 4. ATTENUATION COEFFICIENT m VERSUS PERCENT RELATIVE HUMIDITY FOR AIR AT -40°C AND NORMAL ATMOSPHERIC PRESSURE




FIGURE 5. PLOT OF EXPERIMENTAL DATA AT 20°C, 0°C AND -20°C OF ATTENUATION IN AIR VERSUS HUMIDITY. THESE DATA ARE PRESENTED IN NORMALIZED FORM M/m_{\max} VERSUS h/h_{\max}




FIGURE 6. MAXIMUM ATTENUATION COEFFICIENT m_{\max} VERSUS FREQUENCY




FIGURE 7. RELAXATION FREQUENCY PLOTTED AS A FUNCTION OF h , THE PERCENT MOLAR CONCENTRATION OF WATER VAPOR IN AIR




FIGURE 8. ATTENUATION COEFFICIENT m VERSUS PERCENT MOLAR CONCENTRATION OF WATER VAPOR FOR OXYGEN AT 20°C AND NORMAL PRESSURE




FIGURE 9. RELAXATION FREQUENCY, f_{\max} , PLOTTED AS A FUNCTION OF \underline{h} , THE PERCENT MOLAR CONCENTRATION OF WATER VAPOR IN OXYGEN




FIGURE 10. ATTENUATION COEFFICIENT m VERSUS PERCENT RELATIVE HUMIDITY FOR AIR AT 20°C AND PRESSURE OF 400 mm




FIGURE 11. ATTENUATION COEFFICIENT m VERSUS PERCENT RELATIVE HUMIDITY FOR AIR AT 20°C AND PRESSURE OF 200 mm




FIGURE 12. ATTENUATION COEFFICIENT m VERSUS PERCENT MOLAR CONCENTRATION OF DEUTERIUM OXIDE VAPOR FOR OXYGEN AT 20°C AND NORMAL PRESSURE




FIGURE 13. DRAWING SHOWING THE SPHERICAL CHAMBER USED IN MEASUREMENTS.
COPPER TUBING ATTACHED TO EXTERIOR SURFACE IS PART OF THE
TEMPERATURE-CONTROL SYSTEM




FIGURE 14. SIMPLIFIED SCHEMATIC DIAGRAM OF THE AIR-CIRCULATION SYSTEM.
AIR IS RECIRCULATED CONTINUOUSLY THROUGH THE SPHERICAL CHAMBER.
THE SATURATOR EITHER TAKES AWAY MOISTURE FROM THE AIR OR ADDS
MOISTURE TO IT--DEPENDING ON THE RELATIVE TEMPERATURES OF THE
SPHERICAL CHAMBER AND THE SATURATOR

REFERENCES

1. Harris, C. M., J. Acoust. Soc. Am., 35, 11-17 (1963).
2. Kneser, H. O., Ergeb. exact. Naturw., 22, 121-185 (1949).
3. Delsasso, L. P., Air Force Contract W28 (099)-ac-228 (1953).
4. Knudsen, V. O., J. Acoust. Soc. Am., 5, 112-121 (1933).
5. Knudsen, V. O., and Obert, L., J. Acoust. Soc. Am., 7, 249-253 (1936).
6. Knotzel, H. and Knotzel, L., Ann. Phys. Leipz., 2, 393-403 (1948).
7. Parker, J. G., J. Chem. Phys., 34, 1763 (1961).
8. Holmes, R., Smith, F. and Tempest, W., Proc. Phys. Soc., 81, 311-319 (1963).
9. Henderson, M. C., J. Acoust. Soc. Am., 34, 349-350 (1962).
10. Clark, A. and Henderson, M. C., J. Acoust. Soc. Am., 35, 1909 (A) (1964).
11. Harlow, R. G. and Kitching, R., J. Acoust. Soc. Am., 36, 1100 (1964).