

## Strathprints Institutional Repository

Roscoe, Andrew J. and Mackay, Andrew and Burt, G.M. and McDonald, J.R. (2010) *Architecture of a network-in-the-Loop environment for characterizing AC power system behavior*. IEEE Transactions on Industrial Electronics, 57 (4). pp. 1245-1253. ISSN 0278-0046

Strathprints is designed to allow users to access the research output of the University of Strathclyde. Copyright © and Moral Rights for the papers on this site are retained by the individual authors and/or other copyright owners. You may not engage in further distribution of the material for any profitmaking activities or any commercial gain. You may freely distribute both the url (<http://strathprints.strath.ac.uk/>) and the content of this paper for research or study, educational, or not-for-profit purposes without prior permission or charge.

Any correspondence concerning this service should be sent to Strathprints administrator: <mailto:strathprints@strath.ac.uk>

# Architecture of a network-in-the-loop environment for characterizing AC power system behavior

Andrew J. Roscoe, Andrew Mackay, Graeme M. Burt, *Member, IEEE* and J.R. McDonald, *Member IEEE*

**Abstract**— This paper describes the method by which a large hardware-in-the-loop environment has been realized for 3-phase AC power systems. The environment allows an entire laboratory power network topology (generators, loads, controls, protection devices and switching) to be placed in the loop of a large power network simulation. The system is realized by using a real-time power network simulator, which interacts with the hardware via indirect control of a large synchronous generator and by measuring currents flowing from its terminals. These measured currents are injected into the simulation via current sources to close the loop. This paper describes the system architecture and, most importantly, the calibration methodologies which have been developed to overcome measurement and loop latencies. In particular a new phase advance calibration removes the requirement to add unwanted components into the simulated network to compensate for loop delay. The results of early commissioning experiments are demonstrated. The present system performance limits under transient conditions (approximately 0.25 Hz/s and 30 V/s to contain peak phase and voltage tracking errors within 5° and 1%) are defined mainly by the controllability of the synchronous generator.

**Index Terms**— Power system simulation, Power system stability, Power system security, Power system protection, Calibration, Electric variables measurement, Real time systems, Digital control

## I. NOMENCLATURE

$I_G$	Vector of 3-phase currents from 80kVA generator
$I_N$	Vector of 3-phase currents flowing into hardware
$K_f$	Feedforward control gain (normally 1) for throttle
$K_\phi$	Frequency target offset per radian of phase tracking error
$t_C$	Interface delay time which needs to be calibrated
$V_N$	Vector of 3-phase voltages at shared node in hardware
$V_N^*$	Vector of 3-phase voltages at shared node in simulation

Manuscript received March 3rd, 2009. Accepted for publication May 31, 2009.

Copyright © 2009 IEEE. Personal use of this material is permitted. However, permission to use this material for any other purposes must be obtained from the IEEE by sending a request to [pubs-permissions@ieee.org](mailto:pubs-permissions@ieee.org).

This work was supported in part by Rolls-Royce PLC and the EPSRC Supergen programme.

A. J. Roscoe (e-mail: [Andrew.Roscoe@eee.strath.ac.uk](mailto:Andrew.Roscoe@eee.strath.ac.uk)), G. M. Burt (e-mail: [g.burt@eee.strath.ac.uk](mailto:g.burt@eee.strath.ac.uk)) and J. R. McDonald (e-mail: [j.mcdonald@eee.strath.ac.uk](mailto:j.mcdonald@eee.strath.ac.uk)) are with the University of Strathclyde, Glasgow, UK. A. Mackay (e-mail: [andrew.mackay@rolls-royce.com](mailto:andrew.mackay@rolls-royce.com)) was with the University of Strathclyde, Glasgow, UK. He is now with Rolls-Royce PLC, Derby, England.

## II. INTRODUCTION

THE use of hardware-in-the-loop (HIL) digital simulation for testing of power equipment has increased in popularity over recent years. A key enabler of this is the availability of computing power necessary to simulate power systems in real-time, with the fidelity required to simulate transient phenomena in power systems. Traditionally hardware-in-the-loop simulation has been used for testing of secondary power equipment such as protection relays and controllers for machines and converters [1-7].

A key aspiration, however, is to couple entire electrical networks in hardware to digital models of other electrical networks running in real-time. The hardware network might contain many generators, loads, cables, transmission lines and transformers. The simulated network might be even more complex, or might be a very simple network such as an infinite bus or large single generator. The construction of such a system allows sections of power systems to be constructed in hardware, and coupled to simulations of larger power networks which cannot be implemented in hardware due to constraints of time, cost, and space. The results from experiments performed on such a system have high credibility due to the use of actual hardware and control systems wherever possible. For example the works of [8-11] could be further verified by installing the proposed hardware (several PV inverters with controllers, diesel generators and/or battery storage, loads etc.) in the laboratory at the multi-kW scale, and coupling them to a simulation of a the distribution grid at a suitable point of common coupling (PCC). The proposed hardware network can then be subjected to simulations of grid perturbations and faults, etc., and the desired response verified. Such a step represents a sensible final test of a prototype power system before deployment in the real world.

To achieve such a goal requires a specialized interface to “transfer” power and maintain the conservation of energy between the simulated network and the hardware network. This interface must emulate the simulated model at the point where the hardware is connected. Generally a controllable power supply is needed where the current and voltage output can be set. This is known as Power-Hardware-in-the-Loop (PHIL) simulation.

The characterization of the restrictions for stable PHIL must

be highlighted. A key issue is the delay introduced in the interface between the digitally simulated network and the physical hardware network. Generally the minimum delay possible is restricted by the time-frame of the digital simulation. This is generally in the region of 10 – 100 $\mu$ s in a dynamic electromagnetic simulation; for example the default time frame for network simulations on the RTDS real-time digital simulator [12] system is 50 $\mu$ s.

There are methods for reducing errors caused by the interface delay by adding additional components in simulation to compensate for the delay. This may be a transmission line model, using the Bergeron traveling wave method, or a transformer. This is a recommended method for use with the RTDS simulator [13]. There are limits to this however. The compensating component must have the parameters that will compensate for the delay. If a transmission line is used, the minimum length of the line is restricted by the size of the time delay. Similarly, if a transformer is used, the minimum reactance of the transformer is restricted. There have been efforts to minimize this restriction. Verma et al. [14] demonstrate a method for utilizing shorter lines to interface the hardware and software. These techniques still require the introduction of additional components into the simulated network. This may not be ideal in certain networks; for example real marine power systems have low impedance, so adding such artificial components can degrade the accuracy of dynamic studies or fault studies on these networks.

Wu et al. proposes a solution to the error caused by this time delay by representing the hardware-under-test (HUT) with a linear time-varying first order system to predict the behavior of the HUT [15]. Results show that this can reduce the error introduced by the delay, although in the example used the HUT is a first-order resistor/inductor circuit. This technique may be not as effective for more complex networks with non-linear components.

Other constraints for PHIL must also be considered such as measurement accuracy and interface dynamics. Ayasun et al. suggests a system to evaluate the performance of the interface by categorizing parameters required such as latency, and measurement accuracy [16]. Ren et al. [17] highlight the stability issues that become inherent in PHIL simulation and assess the effectiveness of several interfacing techniques highlighting the strengths and weaknesses of each.

There are few test facilities that are available that have capabilities of PHIL simulation with primary hardware. The Centre for Advanced Power Systems (CAPS) facility in Florida State University has the capability to test 5MW machines [18], wind energy systems [19], drive controllers [20] and run complex all-electric ship models in real-time [21] using several RTDS simulator systems in parallel operation.

The University of Newcastle-Upon-Tyne has also reported the capability of power-hardware-in-the-loop with the development of a 145kW Virtual Power System [22].

PHIL simulation generally relies on high powered, controllable sources to interface the hardware and emulate the

software network. A solid-state inverter is typically used, but this requires expensive high powered components and a custom control system. Depending on the study, it may also need refined voltage or current resolution. The method presented in this paper relies on control of a synchronous generator as the interface between the hardware and software components of the network (see section III). This is particularly suited for simulating balanced 3-phase systems with low dynamic changes, since hardware capacitive/inductive filters at the interface for improving total harmonic distortion (THD) are not required.

In the method described, no artificial components are introduced to the simulated network to compensate for the interface delay. Instead, interface delay compensation is dealt with by introducing a new phase advance calibration. This technique is not specific to the synchronous generator method described here, and could equally be applied to an inverter-based interface. In addition, since the laboratory is a large power network with many devices, substantial care must be taken with all voltage and current measurements to ensure that their amplitude and phase accuracy is acceptable. This paper describes the optimized calibration methodologies which have been developed to account for varying performance across many hardware measurement channels, including the effects of anti-aliasing filters and analog to digital converter (ADC) skews. These calibrations are described in detail in Section IV. Section V follows on to describe the control of the synchronous generator. Finally, performance of the entire PHIL system, when perturbed by dynamic load changes within both simulation and hardware, is demonstrated in section VI. Conclusions and further work opportunities are summarized in section VII.

### III. ARCHITECTURE OVERVIEW AND PRINCIPLE

The system architecture consists of a simulated power network, and a real hardware network under test (HUT) in the laboratory (Fig. 1). The two networks are coupled together via a shared 3-phase node which exists both in simulation and in hardware. In the hardware, the node voltages  $V_N$  are forced at the terminals of a large (80kVA) 3-phase synchronous generator, which is directly coupled to a resistive loadbank set to approximately 10-20kW. The load magnitude is not critical but must be sufficient to enable sinking of power or negative Rates of Change of Frequency (ROCOF) required by the simulation scenarios. Injection of power or positive ROCOF is provided by a 67kW DC motor coupled to a fast-responding active rectifier which allows tight control. The inertia of the combined motor-generator set is approximately  $H=1.0$  pu. The excitation for the generator is via a small solid-state motor-drive card which supplies the rotor field within a fixed-speed dynamo, whose stator in turn connects to the generator field. This system was originally installed to mimic a generator installation at the multi-megawatt scale.




Fig. 1. Closing the loop between simulation and hardware

The voltages at the generator/loadbank terminals are driven, as accurately as can be achieved, to match the simulated nodal voltages at the shared node in real time. This causes currents  $I_N$  to flow in the laboratory network (HUT). The hardware can consist of cables, switches, impedances, generators (synchronous, induction and/or inverter etc.), or loads (static resistive, static reactive, and/or induction etc.). This in turn causes frequency, voltage and power flow fluctuations in these hardware elements. Microgrid management algorithms which control parts of the laboratory power network may also react by adjusting controls, switches, loads or generators in real time. Closure of the simulation loop is achieved by measuring the 3 phase currents  $I_N$ . These 3 current measurements are then passed back to the simulation, where they are injected at the shared node by using 3 single-phase current-source elements.

#### A. Architecture details

The network simulation is carried out on an RTDS simulator [12], which operates with a  $50\mu\text{s}$  frame time. This uses the RSCAD [23] simulation environment. This simulation resource is two floors distant from the laboratory hardware and the machine controls. The laboratory hardware, including the machine controls for the 80kVA motor-generator set, is controlled using an RTS real-time-system controller [24], which is a multi-processor VME-based system, operating at a  $2000\mu\text{s}$  fundamental frame time with ADC sampling and digital pre-filtering at  $666.66\mu\text{s}$ . The RTS controller can be programmed via MATLAB Simulink (using the Real-Time Workshop extension) which makes it suitable for rapid prototyping and implementation of novel power system control and protection schemes [3]. The RTS controller is situated locally to the laboratory hardware, since it has many hard-wired instrumentation connections to the hardware. This hybrid use of the RTDS simulator and the RTS controller results in some communication overhead, but allows the different strengths of each of these two devices to be best used.

#### B. Instrumentation and communication

Measurement of  $V_N$ , the voltage at the shared node, is done by using a 3-phase Voltage Transformer (VT). Measurement of the currents  $I_N$  and  $I_G$  is done using Current Transformers (CTs) burdened with suitable resistances. In all cases, shielded treble twisted-pair cable sets are used to bring the signals to the RTS controller ( $V_N$  and  $I_G$ ) and RTDS simulator ( $I_N$ ), via suitable scaling, isolation and anti-aliasing filtering. The measurement  $I_G$  is not directly required for the hardware-in-the-loop system, but is used for the feed-forward control of the 80kVA drive, described in section V. At the RTS controller and RTDS simulator, signals are sampled using ADCs. A non-trivial stage is the passing of data from the RTDS simulator to the RTS controller. This data consists of the 3-phase voltage set  $V_N^*$  which the RTDS simulation wishes to force at the shared node. This passing of data is required because the simulation and control functions have been split between the RTDS simulator and RTS controller.

It was considered to implement this control digitally via an optical link, and this may eventually prove to be a better system due to lower calibration and noise errors. In the present implementation, however, the simulated 3-phase voltage set  $V_N^*$  at the shared node in the simulation is simply passed using analogue voltages. The signals pass from 3 digital to analog converters (DACs) at the RTDS simulator via a shielded treble twisted-pair cable set to the RTS controller where they are re-sampled on 3 unfiltered ADCs.

Comprehensive data logging is carried out using the RTS controller infrastructure. The results of the simulation on the RTDS can also be captured. Matching the two sets of data together after test runs presently requires some degree of manual intervention since there is currently no synchronized clock information between the RTS and RTDS datasets.

#### IV. CALIBRATION AND LOOP LATENCY

Referring to Fig. 1, there are three important latency mechanisms which need to be understood. These mechanisms are described below. The second and third mechanisms must be carefully accounted for via calibrations.

Firstly, there is an overall loop latency which includes the RTS processing/measurement time, 80kVA generator response time, and RTDS processing time. The processing loop latency is of the order of  $3000\text{--}6000\mu\text{s}$ , dominated by a time of  $1\frac{1}{2}$ –3 frames for the RTS controller to sample, process and output its results. This time is of little consequence being of the order of 15% of one cycle at 50Hz. The signal measurement algorithms within the RTS controller average over  $1\frac{1}{2}$ –2 cycles for amplitude and phase measurements and 5 cycles for measuring frequency, adding up to  $\sim 50\text{ms}$  to the complete response time. These measurement algorithms have been optimized to minimize noise and ripple in the presence of interference and THD during laboratory experiments, and there is scope to reduce these times for use specifically in the PHIL application. Of most significance is the generator response time to torque

and field controls, which dominates the loop latency. The generator response time thus sets limits on the ROCOF rate (Hz/s) and voltage slew rate (V/s) which can be accurately tracked by the hardware. These limits are demonstrated in section VI.

The second mechanism involves amplitude and time/phase calibrations of all the signals sampled on the RTS controller. Ideally, all these signals would be sampled on identical ADC channels with identical instrumentation and anti-aliasing filters, with all ADCs read at the exact same instant in time. In practice, due to the number of ADC channels used by the RTS controller for this (and other) applications, the measurements are spread over different ADC cards which are read at different times. In addition, some of the ADC cards contain 64 multiplexed channels with a 10 $\mu$ s channel-channel relative skew over up to 64 channels (640 $\mu$ s total read time). Also, several different anti-aliasing filter designs have been installed over time due to legacy work carried out in the laboratory. This is tolerable, although it is useful (and sensible) if a common filter design is used for each group of 3 or 6 channels (voltages, currents, or voltages and currents) since this simplifies the calibration implementation and Fourier/sequence/power-flow analysis. The sets of 3 or 6 measurements should also be made on adjacent ADC channels to minimize the timing skew within the sets.

Fortunately, because the timings of the ADC reads are repeatable on a frame-by-frame basis, and because the designs of the anti-aliasing filters are known, it is possible to calculate and implement calibrations for amplitude and time/phase on all channels. This process has been developed and optimized for the PHIL application, both for accuracy and minimization of computational effort. The steps are:-

- 1) Calculate amplitude attenuations at the system frequency due to anti-alias filter characteristics and correct each ADC reading by linear multiplication
- 2) To account for the relative ADC channel-channel time skews within each set of 3 readings (voltages or currents) or 6 readings (voltages and currents), the sample sets can be corrected in the time domain by using a 2<sup>nd</sup>-order interpolation technique optimized from [25], using the most recent 3 samples. A simpler 1<sup>st</sup>-order technique was considered but this introduces small attenuations to the signals which would require correction using additional amplitude calibrations. The interpolation delays the signals by very small amounts in a staggered manner so that all readings appear coherent within each set (but not necessarily between sets). Normally the maximum relative skews within sets are only of the order of 20 $\mu$ s for sets of 3 readings or 50 $\mu$ s for sets of 6 readings, which represent small delays within a 2000 $\mu$ s frame. Carrying out this correction in the time domain for the sets of 3 or 6 readings allows a significant reduction in subsequent computational effort when carrying out sequence and power flow analysis, by reducing the

number of trigonometric functions required for those stages. On each channel, the procedure calculates

$$k_0 = y_{-1}, \quad k_1 = \frac{(y_0 - y_{-2})}{2}, \quad k_2 = \frac{(y_0 + y_{-2})}{2} - y_{-1}$$

Where  $y_0$ ,  $y_{-1}$ , and  $y_{-2}$  are the most recent, previous and oldest samples respectively. Then, the reading can be made coherent with other channels by calculating

$$x = 1 - \frac{t_{Lag}}{T_s}, \quad y = k_2 x^2 + k_1 x + k_0$$

Where  $t_{Lag}$  for each channel is the small required time offset to bring each channel into coherence with all the others in the set, and  $T_s$  is the frame time.

- 3) Carry out Fourier analysis, sequence analysis, and power flow analysis, using algorithms optimized for accuracy and computational speed, using minimal calculations of trigonometric functions by careful re-use of such calculations [26, 27].
- 4) Apply overall gross phase lag corrections due to anti-alias filter lags and overall relative ADC timings across all ADC cards at the system frequency. These lags can be significant (up to 45° for an anti-alias filter and 800 $\mu$ s for overall ADC channel skews across all channels). The gross phase lags are applied by linear addition (in the frequency domain) to the calculated phases of the voltages, currents, and sequences. This finally brings all the results from all the measurement sets to a point where the signal phases can be compared accurately.

The VT, CT, instrumentation circuits and anti-alias filters are designed and constructed using fixed 1% tolerance parts throughout (2-pole Sallen-Key filter circuits in the unity-gain configuration proving highly effective and repeatable), with overall amplitude accuracy of this order and phase accuracy of approximately 1°. Thus far, this approach has allowed all calibration factors to be calculated theoretically and has avoided the necessity for many time-consuming measurement-based calibrations. The accuracy of the system can be checked against a calibrated third-party device at intervals to validate the performance.

An important item to note is that if the RTS controller calibrations are successfully implemented, the RTS controller acquires coherent measurements of  $V_N^*$  and  $V_N$  (and  $I_G$ ). Thus, the closed-loop nature of the 80kVA generator control by the RTS controller means that (at steady state) the voltages  $V_N$  can be held exactly in synchronism with the target voltage set  $V_N^*$  provided by the RTDS simulator, to within approximately 1% amplitude and 1° phase.

The third latency mechanism involves the processing delay (interface delay)  $t_C$  within the hardware-RTDS-RTS part of the loop. This delay is small, but it must be accounted for, otherwise the measured currents  $I_N$  will lag behind those that should ideally arise given the simulated target voltages  $V_N^*$ .

As previously mentioned, the time taken to read the values of  $V_N^*$  at the RTS controller does not contribute to this delay, since the  $V_N^*$  and  $V_N$  voltages can be brought to coherency. The processing delay  $t_C$  is thus given by the time taken for the RTDS simulator to measure  $I_N$ , process the simulation, and output the result. Propagation delays through the twisted pair lines will account for only a few microseconds (0.33 $\mu$ s for 100m in free space). The delay is therefore dominated by the CT phase lag (which might give 55 $\mu$ s for a 1 $^\circ$  lag at 50 Hz), RTDS anti-aliasing filter (a 1 kHz single-pole low-pass filter was used, giving a 159 $\mu$ s lag at 50Hz), RTDS ADC sample time, processing time (at a 50 $\mu$ s frame time), and DAC output time.

Thus  $t_C$  might be expected to be in the region of 250-500 $\mu$ s, bearing in mind that within the RTDS simulator, the network simulation, controls, ADC reading and DAC outputs are handled by different processors, and a single 50 $\mu$ s delay is incurred for each processor-processor communication. This adds several multiples of 50 $\mu$ s to the nominal 50 $\mu$ s frame time. The overall delay can be measured and calibrated by adjusting  $t_C$  which introduces a phase advance of  $2\pi f t_C$  into the control of the 80kVA generator (where  $f$  is frequency, see Fig. 2), such that the power angle (of  $I_N$  relative to  $V_N$ ) at the shared node becomes the same (within allowed measurement uncertainty bounds) both on the RTS controller measurements, and within the RTDS simulation/measurement. In practice, by this procedure  $t_C$  has been found to be 425 $\mu$ s, at the higher end of the expected range. During the calibration, 20kVA was flowing at 400V line-line (29A per phase) at a power factor of 0.93 (lagging). The average power angle of the measured power flows on both the RTS controller and RTDS simulator was adjusted (via  $t_C$ ) to be  $-20.7 \pm 0.2^\circ$ .

Note that if the loop latency was not accounted for, the power angles perceived at the RTDS and RTS would then be divergent by  $\text{atan}(425\mu\text{s}/(1/50\text{Hz}))=1.2^\circ$  even at steady-state during all PHIL scenarios, unless artificial components were added into the RTDS simulation. During calibration, the peak noise on individual sampled RTS/RTDS power angle measurements was up to  $\pm 0.6^\circ$  despite the careful use of screened twisted pair cables and differential inputs throughout the instrumentation/measurement circuits. The noise on the power angle measurement occurs partly because the current  $I_N$  can be measured up to 125A, so a 29A flow represents only 23% of the full-scale range.

## V. CONTROL OF THE FORCED VOLTAGE SOURCE (80 kVA GENERATOR)

A critical capability, handled by the RTS controller, is the ability to match the actual voltages  $V_N$  to the simulated voltages  $V_N^*$  in real time, both in amplitude and phase. Active control of the phase of a synchronous generator is unconventional, and is achieved here by using fast-acting controls for the armature current of the motor which drives the 80 kVA generator. To create the phase-locking control system, an existing application which implemented a droopless

frequency and voltage control via PID (Proportional Integral Differential) control loops has been modified and augmented. The generator frequency/phase is manipulated with the throttle control, while the voltage magnitude is manipulated with the field control. Fig. 2 shows a simplified diagram of the control scheme. The error signal for the field PID controller is simply the difference between the positive sequence magnitudes of  $V_N^*$  and  $V_N$ .

The error signal to the throttle PID controller is more complex, consisting of two main terms. The first is the difference between the frequencies of  $V_N^*$  and  $V_N$ , which tends to bring the frequency of the generator towards that of the simulation. The second error term consists of a gain  $K_\phi$  times the difference between the phases of  $V_N^*$  and  $V_N$ . This error term tends to bring the generator terminal voltages into phase-lock with the desired simulation voltages  $V_N^*$ . The value of  $K_\phi$  has been set by empirical tuning to  $0.2/\pi$ , equating to a maximum 5 offset for a 90 $^\circ$  phase lock error. The compensation parameter  $t_C$  is described in section IV. Use of a throttle feed-forward control term  $K_f$  ( $=1$ ) significantly improves the phase/frequency response of the generator when subjected to step changes in load. The improvement occurs because a change in power flow can be measured within 1/2-2 cycles, whereas any resulting change in frequency occurs more slowly, as an integral response to power imbalance, inversely proportional to the inertia of the generator and HUT hardware.

Subtle extra features of the control are an addition small frequency offset added during the lock acquisition, and code for detection of successful lock acquisition/hold. When lock is not yet acquired or has been lost, the gain  $K_\phi$  is set to 0.




Fig. 2. 80kVA generator throttle and field controls

The PID controls contain some non-standard code which limits the differential control contributions to fixed proportions of the error signal magnitudes. This allows differential controls to be used (to minimize the generator response time) without adding noisy differential control outputs when they are not required. A further additional feature is that the field control voltage is allowed to become negative at certain times. This can be used to forcibly collapse the field current as fast as possible, to introduce voltage dips into the hardware.

## VI. EXAMPLE SCENARIOS

Results from two scenarios are shown below. These scenarios are deliberately designed to show the limits of performance of the PHIL system as implemented. Figs. 3 & 4 show simplified one-line diagrams of the simulation and hardware environments.




Fig. 3. Example of a simple simulation on the RTDS




Fig. 4. Example of a laboratory network Hardware Under Test (HUT)

### A. Scenario A: Direct on-line start in simulation

In the first scenario, an induction machine is started direct-on-line (DOL) in simulation (Fig. 3), and then disconnected. This causes a transient in frequency and voltage which the laboratory network reacts to. In this scenario, DG1 and DG2 generators are both on-line, working at setpoints of 1500W, 0 VAR and 8000W, 0 VAR respectively, both with frequency droops of 5% and voltage droops of 10%. The constant impedance loadbank local to DG1 is set to 9.5kW at unity power factor (PF). The constant impedance loadbank local to DG2 is set to 9.5kW at PF=0.95 (3.3kVAR). The induction machine local to DG2 is running unloaded,

consuming 1.4kW and 5.2kVAR.

Fig. 5 shows that the tracking of frequency between the HUT and the simulation is suitably maintained.




Fig. 5. Scenario A: Frequency tracking between hardware and simulation

Phase tracking (Fig. 6) is generally within  $1^\circ$ , apart from a brief excursion to  $7^\circ$  during the DOL at  $t=4s$  when ROCOF suddenly exceeds 0.5 Hz/s. Accurate phase tracking recovers quickly following the initial transient.

Voltage tracking is shown in Figs. 7 & 8. Generally, performance is satisfactory, although there is a finite reaction time in the hardware, as the 80 kVA generator field current is adjusted to hit the target set by  $V_N^*$ . The generator has been shown capable of achieving average 200 V/s (line-line RMS) slew rates over 1 second, but for sudden changes over smaller timeframes the 200 V/s figure is not achievable. Over the initial 200ms of a transient, the achievable slew rate is approximately 30 V/s. Thus, although  $V_N^*$  only drops at 70 V/s in Fig. 7, a lag in the actual performance of  $V_N$  in hardware is still noticeable. The peak voltage tracking error is 5V at  $t=4s$ .




Fig. 6. Scenario A: Phase tracking (angle by which  $V_N$  leads  $V_N^*$ )

The active power flows in the hardware are shown in Fig. 9. Clearly, the hardware loads, especially the loads local to DG2 including the induction motor, consume less power during the startup transient around  $t=4$  to  $t=7s$ , due to the drop in frequency and voltage. In addition the active power output from DG2 rises due to its 4% droop slope. DG1 is not shown as its power output is much lower, rising from 1300W to 1500W during the event.




Fig. 7. Scenario A: Voltage tracking between hardware and simulation




Fig. 8. Scenario A: Voltage tracking error




Fig. 9. Scenario A: Active power flows (DG1 not shown for clarity)

To achieve adequate tracking, the recommendation for the present system is therefore to limit ROCOF within the simulation to less than 0.25 Hz/s, and to limit the voltage slew rate within the simulation to 30V/s (0.075pu/s). This should ensure peak transient phase tracking errors within  $5^\circ$ , and peak transient voltage tracking errors less than 4V (1%).

### B. Scenario B: Direct on-line start in hardware

In the second scenario, a sequence of loads are added and then removed in hardware (Fig. 4). The generators DG1 and DG2 are disconnected during this experiment. First, a constant impedance 9.5kW load at PF=0.95 (3.3kVAR) is added local to DG1 ( $t=6s$ ). Then, a constant impedance 9.5kW load at PF=0.95 is added local to DG2 ( $t=17s$ ). Finally an induction machine is started direct-on-line (DOL) in hardware ( $t=29s$ ). These steps are then reversed to disconnect the apparatus.

Frequency tracking is generally satisfactory (Fig. 10) apart from some transient deviations immediately following the DOL start. This also shows up as some large (up to  $40^\circ$ ) but

brief phase tracking errors (Fig. 11). The tracking of frequency and phase performs much better (less than  $5^\circ$  peak error) during the addition and removal of the static loads, and during the removal of the induction machine load.




Fig. 10. Scenario B: Frequency tracking between hardware and simulation




Fig. 11. Scenario B: Phase tracking (angle by which  $V_N$  leads  $V_N^*$ )

The voltage tracking is shown in Figs. 12 & 13. In this case, a major deviation is visible during the DOL start when the hardware voltage drops by more than 100V (0.25pu) for just over 2 seconds, while the simulation voltage oscillates around 400V. During the DOL start, the active power reaches 35kW and reactive power reaches 45kVAR, a total of 57kVA, 71% of the rating of the 80kVA generator. Smaller unwanted hardware voltage drops (and rises) of 10V (0.025pu) can be seen during the static load additions and removals (about 10kVA each, 12% of the rating of the 80kVA generator).




Fig. 12. Scenario B: Voltage tracking between hardware and simulation






Fig. 13. Scenario B: Voltage tracking error

To achieve adequate tracking, the recommendation for the present system is therefore to limit sudden load steps in the hardware to less than 8kVA, i.e. less than 10% of the rating of the generator. This should ensure peak transient phase tracking errors within  $5^\circ$ , and peak transient voltage tracking errors within about 10V (2.5%).

## VII. CONCLUSION

The methods presented in this paper allow entire power networks to be embedded as hardware-in-the-loop. An effective new “phase advance” method for coping with the interface delay present in a PHIL environment has been presented, in which a measured/calibrated parameter  $t_c$ , equal to the interface delay time, is used to calculate a phase advance angle. This angle advance is then applied to the PHIL hardware generator control as an offset. This method avoids the requirement for unwanted artificial components to be added to the simulation, which is the traditional method to cope with interface delay.

In addition, in order to cope with the real-world problems of anti-alias filter design and ADC skew, methods for accurately calibrating measured amplitudes and phases of hardware voltages and currents have been developed and presented. These methods use a combination of time-domain and frequency-domain techniques which lead to reduced computational burden.

Using a synchronous generator as the interface between hardware and simulation has the constraint that neither harmonics nor unbalance can be deliberately injected into the hardware. There are also limits to the ROCOF and rate-of-change of voltage in simulation which can be tracked accurately. Using the described setup, tracking with peak errors of  $5^\circ$  (phase) and 1% (amplitude) can be achieved for simulation slew rates of 0.25 Hz/s and 30 V/s for fast transient events. Hardware transients of up to 10% of the synchronous generator rating can also be accommodated with  $5^\circ$  (phase) and 2.5% (amplitude) tracking errors. However, the use of a synchronous generator may allow brief hard faults to be placed in the hardware, with resulting currents much larger than 1pu. In contrast, an inverter would have to be significantly over-designed with corresponding expense to allow such large currents to be accommodated without requiring a trip of the inverter itself.

To achieve the demonstrated phase tracking accuracy, using a synchronous generator, a fast-responding prime mover in conjunction with a feedforward throttle control term has been used to good effect. The active power controls are almost as tight as can be achieved without the risk of instability, although early experiments into the use of a non-linear slope in place of the linear gain  $K_\phi$  show that this might yield some further reduction in phase tracking error.

There are several opportunities for further work. It might be possible to improve the demonstrated voltage tracking performance using some relatively inexpensive modifications. Addition of a feed-forward term to the excitation control (feeding forward VAR flow to the field control) might provide some improvement. Also, a more powerful solid-state excitation system for the synchronous generator would allow faster forcing of the field current to hit target voltage values, especially during times of dynamically changing VAR flows. Only a single-channel device capable of  $\pm 30V$  and 20A would be enough to excite the generator with the present slew rates, although a larger (bidirectional) voltage range would increase the field current slew rate and an oversized current rating would be a prudent measure. A lower leakage reactance of the generator would also be desirable, although this is an inherent property of the generator and cannot be reduced for the existing installation. The measurement averaging times of  $1\frac{1}{2}$ -5 cycles could also be reduced for the specific PHIL application, leading to improved tracking of both phase and amplitude. Finally, the simulation architecture and anti-aliasing filter design could be modified to reduce the magnitude of the  $425\mu s$  interface delay ( $t_c$ ).

## REFERENCES

- [1] A. Bouscayrol, X. Guillaud, P. Delarue, and B. Lemaire-Semail, "Energetic Macroscopic Representation and inversion-based control illustrated on a wind energy conversion systems using Hardware-in-the-loop simulation," *IEEE Transactions on Industrial Electronics*, vol. XX, pp. xxxx-xxxx, 2009 (accepted for publication).
- [2] B. Lu, X. Wu, H. Figueroa, and A. Monti, "A low-cost real-time hardware-in-the-loop testing approach of power electronics controls," *IEEE Transactions on Industrial Electronics*, vol. 54, pp. 919-931, Apr 2007.
- [3] D. Hercog, B. Gergic, S. Uran, and K. Jezernik, "A DSP-based remote control laboratory," *IEEE Transactions on Industrial Electronics*, vol. 54, pp. 3057-3068, Dec 2007.
- [4] D. Zhang and H. Li, "A stochastic-based FPGA controller for an induction motor drive with integrated neural network algorithms," *IEEE Transactions on Industrial Electronics*, vol. 55, pp. 551-561, Feb 2008.
- [5] G. G. Parma and V. Dinavahi, "Real-time digital hardware simulation of power electronics and drives," *IEEE Transactions on Power Delivery*, vol. 22, pp. 1235-1246, Apr 2007.
- [6] S. C. Oh, "Evaluation of motor characteristics for hybrid electric vehicles using the Hardware-in-the-Loop concept," *IEEE Transactions on Vehicular Technology*, vol. 54, pp. 817-824, May 2005.
- [7] L. W. Qian, D. A. Cartes, and H. Li, "An improved adaptive detection method for power quality improvement," *IEEE Transactions on Industry Applications*, vol. 44, pp. 525-533, Mar-Apr 2008.

- [8] J. T. Bialasiewicz, "Renewable energy systems with photovoltaic power generators: Operation and modeling," *IEEE Transactions on Industrial Electronics*, vol. 55, pp. 2752-2758, Jul 2008.
- [9] S. K. Kim, J. H. Jeon, C. H. Cho, J. B. Ahn, and S. H. Kwon, "Dynamic modeling and control of a grid-connected hybrid generation system with versatile power transfer," *IEEE Transactions on Industrial Electronics*, vol. 55, pp. 1677-1688, Apr 2008.
- [10] Y. K. Lo, T. P. Lee, and K. H. Wu, "Grid-connected photovoltaic system with power factor correction," *IEEE Transactions on Industrial Electronics*, vol. 55, pp. 2224-2227, May 2008.
- [11] N. Femia, G. Lisi, G. Petrone, G. Spagnuolo, and M. Vitelli, "Distributed maximum power point tracking of photovoltaic arrays: Novel approach and system analysis," *IEEE Transactions on Industrial Electronics*, vol. 55, pp. 2610-2621, Jul 2008.
- [12] RTDS Hardware Overview. RTDS Technologies Inc. [Online]. Available: <http://www.rtds.com/hardware.htm>
- [13] R. Kuffel, R. P. Wierckx, H. Duchen, M. Lagerkvist, X. Wang, P. Forsyth, and P. Holmberg, "Expanding an Analogue HVDC Simulator's Modelling Capability Using a Real-Time Digital Simulator (RTDS)," in *ICDS Digital Power System Simulators*, 1995.
- [14] S. C. Verma, H. Odani, S. Ogawa, K. Kuroda, and Y. Kono, "Real time interface for interconnecting fully digital and analog simulators using short line or transformer," in *IEEE Power Engineering Society General Meeting*, 2006.
- [15] X. Wu, S. Lentijo, and A. Monti, "A novel interface for power-hardware-in-the-loop simulation," in *Workshop on Computers in Power Electronics*: IEEE, 2004, pp. 178-182.
- [16] S. Ayasun, R. Fischl, T. Chmielewski, S. Vallieu, K. Miu, and C. Nwankpa, "Evaluation of the static performance of a simulation-stimulation interface for power hardware in the loop," in *Power Tech Conference*, Bologna, 2003.
- [17] W. Ren, M. Steurer, and T. L. Baldwin, "Improve the stability and the accuracy of power hardware-in-the-loop simulation by selecting appropriate interface algorithms," *IEEE Transactions on Industry Applications*, vol. 44, pp. 1286-1294, Jul-Aug 2008.
- [18] S. Woodruff, H. Boenig, F. Bogdan, T. Fikse, L. Petersen, M. Sloderbeck, G. Snitchler, and M. Steurer, "Testing a 5 MW high-temperature superconducting propulsion motor," in *Electric Ship Technologies Symposium*: IEEE, 2005, pp. 206-213.
- [19] H. Li., M. Steurer, K. L. Shi, S. Woodruff, and D. Zhang, "Development of a Unified Design, Test, and Research Platform for Wind Energy Systems Based on Hardware-in-the-Loop Real-Time Simulation," *IEEE Transactions on Industrial Electronics*, vol. 53, pp. 1144-1151 2006.
- [20] Y. Liu, M. Steurer, and P. Ribeiro, "A novel approach to power quality assessment: Real time hardware-in-the-loop test bed," *IEEE Transactions on Power Delivery*, vol. 20, pp. 1200-1201, Apr 2005.
- [21] J. Langston, S. Suryanarayanan, M. Steurer, M. Andrus, S. Woodruff, and P. F. Ribeiro, "Experiences with the simulation of a notional all-electric ship integrated power system on a large-scale high-speed electromagnetic transient simulator," in *Power Engineering Society General Meeting*: IEEE, 2006.
- [22] M. Armstrong, D. J. Atkinson, A. G. Jack, and S. Turner, "Power system emulation using a real time, 145 kW, virtual power system," in *European Conference on Power Electronics and Applications*, 2005.
- [23] RSCAD Simulation Software. RTDS Technologies Inc. [Online]. Available: <http://www.rtds.com/software.htm>
- [24] Real Time Station (RTS). Applied Dynamics International. [Online]. Available: [http://www.adi.com/products\\_sim\\_tar\\_rts.htm](http://www.adi.com/products_sim_tar_rts.htm)
- [25] A. J. Roscoe, "Systems and methods for performing analysis of a multi-tone signal," U.S. patent US2005075812, April 7 2005.
- [26] A. J. Roscoe, "Measurement, control and protection of microgrids at low frame rates supporting security of supply," PhD thesis, Department of Electronic and Electrical Engineering, University of Strathclyde, Glasgow, 2009.
- [27] A. J. Roscoe, G. M. Burt, and J. R. McDonald, "Frequency and fundamental signal measurement algorithms for distributed control

and protection applications," *IET Proceedings on Generation, Transmission & Distribution* vol. 3, pp. 485-495, May 2009.



**Andrew Roscoe** received the B.A. degree in Electrical and Information Sciences Tripos at Pembroke College, Cambridge, England in 1991. Andrew worked for GEC Marconi from 1991 to 1995, where he was involved in antenna design and calibration, specialising in millimetre wave systems and solid state phased array radars. Andrew worked from 1995 to 2004 with Hewlett Packard and subsequently Agilent Technologies, in the field of microwave communication systems, specialising in the design of test and measurement systems for personal mobile and satellite communications. Andrew was awarded an MSc from the University of Strathclyde in 2004, in the field of "Energy systems and the Environment", and received his Ph.D degree in 2009. Andrew is currently a Research Fellow in the Institute for Energy and the Environment, Department of Electronic and Electrical Engineering at Strathclyde University, working in the field of distributed generation and active network management. Recent projects include real time pricing studies, the creation and deployment of microgrid control algorithms at the 100kVA scale, the design/build of a 10kVA 3-phase inverter, new algorithms for the measurement of dynamic system parameters using low sample rates, and loss-of-mains detection strategies.



**Andrew Mackay** received his B.Eng. (Hons) and M.Sc. in Electrical and Electronic Engineering in 2001 and 2003 respectively. He is currently pursuing the Ph.D degree in Electrical and Electronic Engineering at the University of Strathclyde. He has worked on several projects involving real-time hardware-in-the-loop simulation, DC protection on UAV platforms, loss of mains of distributed generation and simulation of more-electric aeronautic and marine systems.



**Prof. Graeme M. Burt** (M'95) currently holds a chair in Power Systems within the Institute for Energy and Environment at the University of Strathclyde. He received his B.Eng. in Electrical and Electronic Engineering from the University of Strathclyde in 1988. His Ph.D. was awarded in 1992 by the University of Strathclyde following research into fault diagnostic techniques for power networks. He is currently the Director of the University Technology Centre in Electrical Power Systems sponsored by Rolls-Royce. His current research interests lie in the areas of: protection and control for distributed generation; power system modeling and simulation; and active distribution networks.



**Professor J. R. McDonald** (M'90) has co-authored over 500 journal and conference papers and three books. He is the Director of the Institute for Energy and Environment which is one of the largest Power Engineering Research Groups internationally with over 200 academic, research and technical staff. He was appointed as Deputy Principal at Strathclyde in 2006, and as Principal in 2009. In 2007, he became the Director of the Glasgow Research Partnership in Engineering. His research interests include power system protection and control, distributed generation, and active network management.